



**Important Information For Gasoline
Dispensing Facility Operators Using
MARCONI COMMERCE SYSTEMS INC. “MCS”
(Formerly Gilbarco Vapor-Vac)
Vacuum Assist Vapor Recovery Systems**

As of July 12, 2000 the California Air Resources Board (CARB) has modified various requirements listed in Executive Order G-70-150. The Executive Order certifies the Marconi Commerce Systems Inc. “MCS” (formerly Gilbarco Vapor-Vac) vacuum assist vapor recovery system for use in California and supercedes all previous certifications.

Most notable is the change in the Air to Liquid Ratio (A/L) testing frequency from once every two years to **once every twelve months.**

All facilities that are equipped with the MCS vacuum assist vapor recovery system must conduct the A/L Ratio testing once every twelve months. Failure to do so is a violation of Ventura County Air Pollution Control District (APCD) Rules and Regulations.

The facility operator must notify the District’s Compliance Division at least five working days prior to the tests and shall submit the results within two weeks to the Compliance Division. All testing must be observed by District personnel.

If the requirements listed above are not met, the facility owner/operator will be subject to enforcement action by the APCD, including monetary penalties.

QUESTIONS?

If you have any questions regarding this matter, please contact APCD Inspector Eric Wetherbee at (805)645-1496.