



April 11, 2011

Mr. Keith Duval
Manager, Compliance Division
Ventura County Air Pollution Control District
669 County Square Drive
Ventura, CA 93003

**SUBJECT: ANNUAL TITLE V COMPLIANCE CERTIFICATION
FOR PERIOD JANUARY 1, 2011 – FEBRUARY 28, 2011
VENTURA COUNTY APCD PERMIT 0990**

Dear Mr. Duval:

Enclosed please find Aera Energy LLC's (Aera) Annual Compliance Certification report for the period January 1, 2011 through February 28, 2011 for Permit No. 0990. Ownership of the Sespe Compressor Plant was officially transferred to Seneca Resources on March 1, 2011 and therefore Seneca will be responsible for the Annual Compliance Certification report for the period March 1, 2011 through December 31, 2011.

Aera completed the Annual Compliance Certification report to the best of its ability using the permit. Aera is willing to meet and confer with District management and staff to discuss any matters for which the District requests additional information or explanation of Aera's responses.

Should you have any questions concerning this report or require additional information, please feel free to contact me at (805) 648-8207.

Sincerely,

Christopher Logan
Compliance Assurance Specialist

cc: U.S. Environmental Protection Agency
Region IX, Air-3
75 Hawthorne Street
San Francisco, CA 94105

RECEIVED
VENTURA COUNTY
A.P.C.D.
11 APR 11 PM 4:40

**ANNUAL COMPLIANCE CERTIFICATION OF
FEDERAL (TITLE V, PART 70) OPERATING PERMITS**

**VENTURA COUNTY
AIR POLLUTION CONTROL DISTRICT
PERMIT NO. 0990**

**AERA ENERGY LLC
SESPE COMPRESSOR PLANT
JANUARY – FEBRUARY 2011**

APRIL 11, 2011



**AERA ENERGY LLC
P.O. BOX 11164
BAKERSFIELD, CALIFORNIA 93389-1164**



Ventura County
Air Pollution
Control District

**ANNUAL COMPLIANCE CERTIFICATION
SIGNATURE COVER FORM**

A copy of each Annual Compliance Certification shall be submitted to EPA, Region 9 at the following address:


Mr. Gerardo Rios, Chief
Permits Office (Air-3)
Office of Air Division
EPA Region 9
75 Hawthorne Street
San Francisco, CA 94105

Confidentiality

All information in a Part 70 permit compliance certification is public information. The Part 70 permit is also public information.

Certification by Responsible Official

I certify that, based on the information and belief formed after reasonable inquiry, the statements and information in this compliance certification are true, accurate, and complete.

Signature and Title of Responsible Official:  Title: <i>VICE PRESIDENT</i>	Date: <i>4-11-11</i>
--	-------------------------

Time Period Covered by Compliance Certification <i>01 / 01 / 11</i> (MM/DD/YY) to <i>02 / 28 / 11</i> (MM/DD/YY)



Ventura County Air Pollution Control District

Company Name: Aera Energy LLC		Permit: 0990		
Certification Period: 01/01/2011 through 02/28/2011		Page 1 of 12		
COLUMN 1 Citation	COLUMN 2 Compliance Status (As indicated by most recent monitoring measurement or observation)	COLUMN 3 Determination Method: "CONTINUOUS" OR "INTERMITTENT"	COLUMN 4 Method for determining Compliance Status.	COLUMN 5 Additional Information (excursions, exceedences, or additional data that indicated non compliance during the certification period)
Equipment, Facilities, and Processes Subject to 40 CFR 61.1005				
40CFR61.M Cond 1	In Compliance	Continuous	Work Practices - Asbestos Activities	
40CFR61.M Cond 2	In Compliance	Continuous	Work Practices - Asbestos Activities	
40CFR68 Cond 1	In Compliance	Continuous	Reference Condition	
40CFR70 Cond 1	In Compliance	Continuous	Reference Condition	
40CFR70 Cond 2	In Compliance	Continuous	Reference Condition	
40CFR70 Cond 3	In Compliance	Continuous	Documentation of prompt reporting and followup deviation reports	
40CFR70 Cond 4	In Compliance	Continuous	Reference Condition	
40CFR70 Cond 5	In Compliance	Continuous	Documentation of Part 70 compliance records	
40CFR70 Cond 6	In Compliance	Continuous	Documentation of Part 70 permit records upon District request	
40CFR70 Cond 7	In Compliance	Continuous	Reference Condition	
40CFR70 Cond 8	In Compliance	Continuous	Reference Condition	
40CFR70 Cond 9	In Compliance	Continuous	Reference Condition	
40CFR70 Cond 10	In Compliance	Continuous	Reference Condition	
40CFR70 Cond 11	In Compliance	Continuous	Reference Condition	
40CFR70 Cond 12	In Compliance	Continuous	Reference Condition	
40CFR70 Cond 13	In Compliance	Continuous	Documentation of Title V five year renewal	



Ventura County Air Pollution Control District

Company Name: Aera Energy LLC				Permit: 0990	
Certification Period: 01/01/2011 through 02/28/2011				Page 2 of 12	
COLUMN 1 Citation	COLUMN 2 Compliance Status (As indicated by most recent monitoring measurement or observation)	COLUMN 3 Determination Method: "CONTINUOUS" OR "INTERMITTENT"	COLUMN 4 Method for determining Compliance Status.	COLUMN 5 Additional Information (excursions, exceedences, or additional data that indicated non compliance during the certification period)	
40CFR70 Cond 14	In Compliance	Continuous	Documentation of Certification by Responsible Official		
40CFR70 Cond 15	In Compliance	Continuous	Documentation of Annual Certification submittals		
40CFR82 Cond 1	In Compliance	Continuous	Work Practices - Refrigerant/Air Conditioners		
40CFR82 Cond 2	In Compliance	Continuous	Work Practices - Refrigerant/Air Conditioners		
50 Cond 1	In Compliance	Continuous	Work Practices - Visible Emissions		
50 Cond 2	In Compliance	Continuous	Documentation of visible emissions		
50 Cond 3	In Compliance	Continuous	Documentation of visual emission evaluations and Annual Certification by Responsible Official		
50 Cond 4	In Compliance	Continuous	Documentation of visible emissions upon District request		
54.B.1 Cond 1	In Compliance	Continuous	Reference Condition		
54.B.1 Cond 2	In Compliance	Continuous	Reference Condition		
54.B.1 Cond 3	In Compliance	Continuous	Documentation of compliance upon District request		
54.B.2 Cond 1	In Compliance	Continuous	Documentation of fuel sulfur analysis and modeling data		
54.B.2 Cond 2	In Compliance	Continuous	Documentation of fuel sulfur analysis and modeling data		



Ventura County Air Pollution Control District

Company Name: Aera Energy LLC		Permit: 0990		
Certification Period: 01/01/2011 through 02/28/2011		Page 3 of 12		
COLUMN 1 Citation	COLUMN 2 Compliance Status (As indicated by most recent monitoring measurement or observation)	COLUMN 3 Determination Method: "CONTINUOUS" OR "INTERMITTENT"	COLUMN 4 Method for determining Compliance Status.	COLUMN 5 Additional Information (excursions, exceedences, or additional data that indicated non compliance during the certification period)
54.B.2 Cond 3	In Compliance	Continuous	Documentation of air modeling for ground level SO2 based on District request	
57.1 Cond 1	In Compliance	Continuous	Documentation of source test reports	
57.1 Cond 2	In Compliance	Continuous	Documentation of compliance upon District request	
57.1 Cond 3	In Compliance	Continuous	Reference Condition	
64.B.1 Cond 1	In Compliance	Continuous	Documentation of fuel sulfur analysis	
64.B.1 Cond 2	In Compliance	Continuous	Reference Condition	
64.B.1 Cond 3	In Compliance	Continuous	Documentation of fuel sulfur analysis	
64.B.1 Cond 4	In Compliance	Continuous	Documentation of fuel sulfur analysis and annual submittal	
71.1.C Cond 1	In Compliance	Continuous	Documentation of equipment configuration	
71.1.C Cond 2	In Compliance	Continuous	Reference Condition	
71.1.C Cond 3	In Compliance	Continuous	Annual visual inspection and certification that the vapor recovery system is a closed system	
71.1.C Cond 4	In Compliance	Continuous	Documentation of flare inspection records	
71.1.C Cond 5	In Compliance	Continuous	Documentation of 74.10 leak inspections	
71.4.B.1 Cond 1	In Compliance	Continuous	Work Practices - Pits, Ponds, and Well Cellars	



Ventura County Air Pollution Control District

Company Name: Aera Energy LLC				Permit: 0990
Certification Period: 01/01/2011 through 02/28/2011				Page 4 of 12
COLUMN 1 Citation	COLUMN 2 Compliance Status (As indicated by most recent monitoring measurement or observation)	COLUMN 3 Determination Method: "CONTINUOUS" OR "INTERMITTENT"	COLUMN 4 Method for determining Compliance Status.	COLUMN 5 Additional Information (excursions, exceedences, or additional data that indicated non compliance during the certification period)
71.4.B.1 Cond 2	In Compliance	Continuous	Documentation of Annual Certification by Responsible Official	
74.1 Cond 1	In Compliance	Continuous	Work Practices - Abrasive Blasting	
74.1 Cond 2	In Compliance	Continuous	Work Practices - Abrasive Blasting	
74.1 Cond 3	In Compliance	Continuous	Work Practices - Abrasive Blasting	
74.1 Cond 4	In Compliance	Continuous	Work Practices - Abrasive Blasting	
74.1 Cond 5	In Compliance	Continuous	Work Practices - Abrasive Blasting	
74.1 Cond 6	In Compliance	Continuous	Work Practices - Abrasive Blasting	
74.1 Cond 7	In Compliance	Continuous	Documentation of abrasive blasting operations & surveillance	
74.10 Cond 1	In Compliance	Continuous	Documentation of 74.10 Operator Management Plan	
74.10 Cond 2	In Compliance	Continuous	Work Practices - Tank Inspection	
74.10 Cond 3	In Compliance	Continuous	Reference Condition	
74.10 Cond 4	In Compliance	Continuous	Documentation of 74.10 Operator Management Plan	
74.10 Cond 5	In Compliance	Continuous	Documentation of 74.10 Operator Management Plan	
74.10 Cond 6	In Compliance	Continuous	Documentation of 74.10 Operator Management Plan	
74.10 Cond 7	In Compliance	Continuous	Documentation of 74.10 Operator Management Plan	



Ventura County Air Pollution Control District

Company Name: Aera Energy LLC					Permit: 0990
Certification Period: 01/01/2011 through 02/28/2011					Page 5 of 12
COLUMN 1 Citation	COLUMN 2 Compliance Status (As indicated by most recent monitoring measurement or observation)	COLUMN 3 Determination Method: "CONTINUOUS" OR "INTERMITTENT"	COLUMN 4 Method for determining Compliance Status.	COLUMN 5 Additional Information (excursions, exceedences, or additional data that indicated non compliance during the certification period)	
74.10 Cond 8	In Compliance	Continuous	Documentation of 74.10 Operator Management Plan		
74.10 Cond 9	In Compliance	Continuous	Documentation of 74.10 Operator Management Plan		
74.10 Cond 10	In Compliance	Continuous	Documentation of 74.10 Operator Management Plan		
74.10 Cond 11	In Compliance	Continuous	Reference Condition		
74.10 Cond 12	In Compliance	Continuous	Reference Condition		
74.10 Cond 13	In Compliance	Continuous	Documentation of 74.10 Operator Management Plan		
74.10 Cond 14	In Compliance	Continuous	Reference Condition		
74.10 Cond 15	In Compliance	Continuous	Reference Condition		
74.10 Cond 16	In Compliance	Continuous	Reference Condition		
74.10 Cond 17	In Compliance	Continuous	Documentation of Operator Management Plan annual submittal/update		
74.10 Cond 18	In Compliance	Continuous	Documentation of 74.10 Operator Management Plan		
74.10 Cond 19	In Compliance	Continuous	Documentation of 74.10 Operator Management Plan		
74.10 Cond 20	In Compliance	Continuous	Documentation of 74.10 Operator Management Plan		
74.10 Cond 21	In Compliance	Continuous	Documentation of 74.10 inspection logs		



Ventura County Air Pollution Control District

Company Name: Aera Energy LLC				Permit: 0990
Certification Period: 01/01/2011 through 02/28/2011				Page 6 of 12
COLUMN 1 Citation	COLUMN 2 Compliance Status (As indicated by most recent monitoring measurement or observation)	COLUMN 3 Determination Method: "CONTINUOUS" OR "INTERMITTENT"	COLUMN 4 Method for determining Compliance Status.	COLUMN 5 Additional Information (excursions, exceedences, or additional data that indicated non compliance during the certification period)
74.10 Cond 22	In Compliance	Continuous	Documentation of 74.10 Operator Management Plan	
74.10 Cond 23	In Compliance	Continuous	Documentation of 74.10 Operator Management Plan	
74.10 Cond 24	In Compliance	Continuous	Documentation of 74.10 Operator Management Plan	
74.10 Cond 25	In Compliance	Continuous	Reference Condition	
74.10 Cond 26	In Compliance	Continuous	Reference Condition	
74.10 Cond 27	In Compliance	Continuous	Reference Condition	
74.10 Cond 28	In Compliance	Continuous	Reference Condition	
74.10 Cond 29	In Compliance	Continuous	Documentation of 74.10 inspection logs	
74.10 Cond 30	In Compliance	Continuous	Documentation of 74.10 inspection logs	
74.10 Cond 31	In Compliance	Continuous	Documentation of 74.10 inspection logs	
74.10 Cond 32	In Compliance	Continuous	Documentation of calibration records	
74.10 Cond 33	In Compliance	Continuous	Reference Condition	
74.10 Cond 34	In Compliance	Continuous	Reference Condition	
74.10 Cond 35	In Compliance	Continuous	Reference Condition	
74.10 Cond 36	In Compliance	Continuous	Reference Condition	
74.11.1 Cond 1	In Compliance	Continuous	Documentation of annual verification that no units exist	



Ventura County Air Pollution Control District

Company Name: Aera Energy LLC		Permit: 0990		
Certification Period: 01/01/2011 through 02/28/2011		Page 7 of 12		
COLUMN 1 Citation	COLUMN 2 Compliance Status (As indicated by most recent monitoring measurement or observation)	COLUMN 3 Determination Method: "CONTINUOUS" OR "INTERMITTENT"	COLUMN 4 Method for determining Compliance Status.	COLUMN 5 Additional Information (excursions, exceedences, or additional data that indicated non compliance during the certification period)
74.11.1 Cond 2	In Compliance	Continuous	Documentation of annual verification that no units exist	
74.11.1 Cond 3	In Compliance	Continuous	Documentation of manufacturers information	
74.11.1 Cond 4	In Compliance	Continuous	Documentation of annual verification that no units exist and Annual Certification by Responsible Official	
74.2 Cond 1	In Compliance	Continuous	Work Practices - Architectural Coatings	
74.2 Cond 2	In Compliance	Continuous	Work Practices - Architectural Coatings	
74.2 Cond 3	In Compliance	Continuous	Work Practices - Architectural Coatings	
74.2 Cond 4	In Compliance	Continuous	Work Practices - Architectural Coatings	
74.2 Cond 5	In Compliance	Continuous	Documentation of VOC content of architectural coatings	
74.2 Cond 6	In Compliance	Continuous	Reference Condition	
74.22 Cond 1	In Compliance	Continuous	Reference Condition	
74.22 Cond 2	In Compliance	Continuous	Documentation of compliance upon District request	
74.22 Cond 3	In Compliance	Continuous	Documentation of annual survey/verification and Annual Certification by Responsible Official	
74.4.D Cond 1	In Compliance	Continuous	Documentation of road oil constituents	




Ventura County Air Pollution Control District

Company Name: Aera Energy LLC		Permit: 0990		
Certification Period: 01/01/2011 through 02/28/2011		Page 8 of 12		
COLUMN 1 Citation	COLUMN 2 Compliance Status (As indicated by most recent monitoring measurement or observation)	COLUMN 3 Determination Method: "CONTINUOUS" OR "INTERMITTENT"	COLUMN 4 Method for determining Compliance Status.	COLUMN 5 Additional Information (excursions, exceedences, or additional data that indicated non compliance during the certification period)
74.4.D Cond 2	In Compliance	Continuous	Documentation of oil analysis records	
74.6 Cond 1	In Compliance	Continuous	Work Practices - Solvent Usage	
74.6 Cond 2	In Compliance	Continuous	Work Practices - Solvent Usage	
74.6 Cond 3	In Compliance	Continuous	Work Practices - Solvent Usage	
74.6 Cond 4	In Compliance	Continuous	Work Practices - Solvent Usage	
74.6 Cond 5	In Compliance	Continuous	Work Practices - Solvent Usage	
74.6 Cond 6	In Compliance	Continuous	Work Practices - Solvent Usage	
74.6 Cond 7	In Compliance	Continuous	Work Practices - Solvent Usage	
74.6 Cond 8	In Compliance	Continuous	Documentation of equipment configuration and operating parameters	
74.6 Cond 9	In Compliance	Continuous	Documentation of equipment configuration and operating parameters	
74.6 Cond 10	In Compliance	Continuous	Documentation of operating parameters	
74.6 Cond 11	In Compliance	Continuous	Reference Condition	
74.6 Cond 12	In Compliance	Continuous	Reference Condition	
74.6 Cond 13	In Compliance	Continuous	Reference Condition	
74.6 Cond 14	In Compliance	Continuous	Documentation of ROC containing solvent	
74.6 Cond 15	In Compliance	Continuous	Work Practices - Solvent Usage	




Ventura County Air Pollution Control District

Company Name: Aera Energy LLC		Permit: 0990		
Certification Period: 01/01/2011 through 02/28/2011		Page 9 of 12		
COLUMN 1 Citation	COLUMN 2 Compliance Status (As indicated by most recent monitoring measurement or observation)	COLUMN 3 Determination Method: "CONTINUOUS" OR "INTERMITTENT"	COLUMN 4 Method for determining Compliance Status.	COLUMN 5 Additional Information (excursions, exceedences, or additional data that indicated non compliance during the certification period)
General Cond 1	In Compliance	Continuous	Reference Condition	
Equipment: 906 BHP Rich Burn Waukesha NG Engine (SN 17240 NSCR, Revision 8/11/2009)				
0990PC1 Cond 1	In Compliance	Continuous	Documentation of throughput records	
74.9N3 Cond 1	In Compliance	Continuous	Documentation of source test reports	
74.9N3 Cond 2	In Compliance	Continuous	Documentation of I.C. engine source test methods and submittal requirements	
74.9N3 Cond 3	In Compliance	Continuous	Documentation of quarterly engine screening analysis	
74.9N3 Cond 4	In Compliance	Continuous	Documentation of IC Engine Operator Inspection Plan	
74.9N3 Cond 5	In Compliance	Continuous	Documentation of I.C. engine inspection logs	
74.9N3 Cond 6	In Compliance	Continuous	Documentation of Annual Certification submittals	
74.9N3 Cond 7	In Compliance	Continuous	Documentation of Compliance Assurance Monitoring (CAM) test records and implementation of IC Engine Operator Inspection Plan	
Equipment: 906 BHP Rich Burn Waukesha NG Engine (SN 192297) NSCR, Revision 8/11/2009				
0990PC1 Cond 1	In Compliance	Continuous	Documentation of throughput records	
74.9N3 Cond 1	In Compliance	Continuous	Documentation of source test reports	
74.9N3 Cond 2	In Compliance	Continuous	Documentation of I.C. engine source test methods and submittal requirements	




Ventura County Air Pollution Control District

Company Name: Aera Energy LLC		Permit: 0990		
Certification Period: 01/01/2011 through 02/28/2011		Page 10 of 12		
COLUMN 1 Citation	COLUMN 2 Compliance Status (As indicated by most recent monitoring measurement or observation)	COLUMN 3 Determination Method: "CONTINUOUS" OR "INTERMITTENT"	COLUMN 4 Method for determining Compliance Status.	COLUMN 5 Additional Information (excursions, exceedences, or additional data that indicated non compliance during the certification period)
74.9N3 Cond 3	In Compliance	Continuous	Documentation of quarterly engine screening analysis	
74.9N3 Cond 4	In Compliance	Continuous	Documentation of IC Engine Operator Inspection Plan	
74.9N3 Cond 5	In Compliance	Continuous	Documentation of I.C. engine inspection logs	
74.9N3 Cond 6	In Compliance	Continuous	Documentation of Annual Certification submittals	
74.9N3 Cond 7	In Compliance	Continuous	Documentation of Compliance Assurance Monitoring (CAM) test records and implementation of IC Engine Operator Inspection Plan	
Equipment 105 BBL Electronic Waste Gasoline Revised on 1/1/2008				
0990PC1 Cond 1	In Compliance	Continuous	Documentation of throughput records	
0990PC2 Cond 1	In Compliance	Continuous	Documentation of flare operating logs	
0990PC2 Cond 2	In Compliance	Continuous	Documentation of flare operating logs	
TP0990P Cond 1	In Compliance	Continuous	Documentation of fuel consumption records	
Equipment 105 BBL Condensate Tank (1-10) VFR Revised on 1/1/2008				
0990PC1 Cond 1	In Compliance	Continuous	Documentation of throughput records	



Ventura County Air Pollution Control District

Company Name: Aera Energy LLC		Permit: 0990		
Certification Period: 01/01/2011 through 02/28/2011		Page 11 of 12		
COLUMN 1 Citation	COLUMN 2 Compliance Status (As indicated by most recent monitoring measurement or observation)	COLUMN 3 Determination Method: "CONTINUOUS" OR "INTERMITTENT"	COLUMN 4 Method for determining Compliance Status.	COLUMN 5 Additional Information (excursions, exceedences, or additional data that indicated non compliance during the certification period)
71.1N1 Cond 1	In Compliance	Intermittent	Documentation of equipment configuration	Produced gas was not controlled when the discharge line for the vapor recovery compressors froze during unusually cold weather. Breakdown relief requested and granted. Event Date: 02/27/2011
71.1N1 Cond 2	In Compliance	Continuous	Documentation of maintenance activities and APCD notifications	
71.1N1 Cond 3	In Compliance	Continuous	Documentation of 74.10 leak inspections and 74.10 Operator Management Plan	
71.1N1 Cond 4	In Compliance	Continuous	Documentation of vapor recovery component inspections and maintenance activities	
71.1N1 Cond 5	In Compliance	Continuous	Documentation of equipment configuration and Annual Certification by Responsible Official	
Equipment: Glycol Dehydrator System consisting of: 1. Glycol Dehydrator Vent VR 1. 0.5 MMEI/HR NG Glycol Reboiler UNG Revised on 1/1/2008				
71.5N1 Cond 1	In Compliance	Continuous	Documentation of equipment configuration	
71.5N1 Cond 2	In Compliance	Continuous	Documentation of equipment configuration	
71.5N1 Cond 3	In Compliance	Continuous	Documentation of 74.10 Operator Management Plan	



Ventura County Air Pollution Control District

Company Name: Aera Energy LLC				Permit: 0990
Certification Period: 01/01/2011 through 02/28/2011				Page 12 of 12
COLUMN 1 Citation	COLUMN 2 Compliance Status (As indicated by most recent monitoring measurement or observation)	COLUMN 3 Determination Method: "CONTINUOUS" OR "INTERMITTENT"	COLUMN 4 Method for determining Compliance Status.	COLUMN 5 Additional Information (excursions, exceedences, or additional data that indicated non compliance during the certification period)
71.5N1 Cond 4	In Compliance	Continuous	Documentation of 74.10 leak inspections and 74.10 Operator Management Plan	
71.5N1 Cond 5	In Compliance	Continuous	Documentation of glycol unit records	
71.5N1 Cond 6	In Compliance	Continuous	Documentation of equipment configuration /leak inspections and Annual Certification by Responsible Official	
Equipment, Solvent, Maintenance, Repair, Revision, Hazards				
0990PC1 Cond 1	In Compliance	Continuous	Documentation of throughput records	



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION DEVIATION SUMMARY FORM

Period Covered by Compliance Certification: 01/01/11 (MM/DD/YY) to 02/28/11 (MM/DD/YY)

A. Attachment # or Permit Condition #: Code: 74.9N3 Code No.: 7	B. Equipment Description: 1 - 105 BBL Condensate Tank (T-101) VR	C. Deviation Period: Date & Time Begin: 2/27/2011 3:15:00AM End: 2/27/2011 8:45:00AM When Discovered: Date & Time 2/27/2011 3:15:00AM
D. Parameters monitored: Not Applicable	E. Limit: Not Applicable	F. Actual: Not Applicable
G. Probable Cause of Deviation: Cold weather caused the discharge line to freeze.		H. Corrective actions taken: Once the line was cleared, the vapor recovery system resumed normal operation.

Aera Energy LLC

Sespe Compressor Station

Annual Report

January 1, 2011 – February 28, 2011

Additional Information:

40 CFR Part 61.145 Compliance

No notifications were necessary because no asbestos-related activities were undertaken during the certification period.

Rule 74.2 Compliance

No paintings or coatings were applied to equipment during the certification period.

Rule 64 Compliance

The fuel for the Sespe engines was tested for sulfur content in accordance with Rule 64, Method ASTM D 4810-88. The results were 0.2 ppm H₂S in the fuel gas tested on January 21, 2011.

Rule 74.6 Compliance

All solvent used while cleaning at this facility did not exceed an ROC content of 25 grams per liter.

Biennial Source Testing

Source testing was completed for Sespe 1 on May 12, 2010 and Sespe 2 on May 11, 2010 and therefore not included as part of this certification.

Ventura County Air Pollution Control District
AERA ENERGY LLC
Permit to Operate No. 0990
Sespe Compressor Plant
Internal Combustion Engines - NG Fuel Consumption

Reporting Period	906-BHP Rich-Burn Waukesha NG Engine #1 Serial # 17230		906-BHP Rich-Burn Waukesha NG Engine #2 Serial # 192297		Both Engines
Month & Year	Meter No. 446 MCF	12-Month Total MCF	Meter No. 447 MCF	12-Month Total MCF	Cumulative Totals MCF*
January 2011	599	6,417	2,102	15,901	22,318
February 2011	1,818	7,226	169	15,398	22,624

*Limit: 127.8 MMCF/Yr

Ventura County Air Pollution Control District

AERA ENERGY LLC

Permit to Operate No. 0990

Sespe Compressor plant

Macronic Waste Gas Flare

Throughput-Consumption

Reporting Period	262.5 MMBTU/Hr Macronic Waste Gas Flare Consumption in MCF			
Month & Year	Total Flare Volume (Meter No. 451)	Planned Flare Volume	Exempt Flare Volume	12-Month Rolling Total Planned Flare Volume*
January 2011	515	0	515	10,082
February 2011	1,563	1,162	401	11,003

*The VCAPCD annual limit for NG consumed is 234,000 MCF.

Ventura County Air Pollution Control District
AERA ENERGY LLC
Permit to Operate No. 0990
Sespe Compressor Plant
Condensate Tank
Throughput-Consumption

Month & Year		Condensate Tank BBL / Month	12-Month Total Cond. Tank BBL*
2011	January	185	3,230
2011	February	185	3,250

*Limit: 9,100 BBL/Yr

Ventura County Air Pollution Control District
AERA ENERGY LLC
Permit to Operate No. 0990
Sespe Compressor Plant
Visible Smoke Checks
Rule 50 Requirements

Date	Smoke/No Smoke
January 17, 2011	No Smoke
February 21, 2011	No Smoke

**APPENDIX D
I.C. ENGINE MAINTENANCE LOG
AERA ENERGY LLC**

Engine Location: Sespe Unit #1												
Engine I.D.: Waukesha 7042G												
Oil Filter No. _____ Plug No.: RM77N Fan Belt No. N/A Oil Capacity _____ Gal.												
Engine Water Pump Belt No.	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEPT	OCT	NOV	DEC
Year: 2011												
Date:		2/16/2011										
PM Number:		910543553										
Engine Oil Change		No										
Engine Filter Change		Yes										
Compressor Oil Change		Yes										
Compressor Filter Change		Yes										
Set Valves		Yes										
Change Ignition Timer		No										
Change Plugs		Yes										
Set Timing		Yes										
Change Air Filters		No										
Change Pre-Air Filters		Yes										
Change Belts – Fan / Water Pump		No										
Check Safety Shutdowns		No										
Change Converter		No										
Change O2 Sensor		No										
Inspect Fuel Control Valve		Yes										
Clean Carburetor		No										
Run-Time hours Since Last Service (Permit Limit: After 2000 hours)		1,256										
Engine RPM		850										
(Permit Limit: _____)												
Other Notes/Corrections:												
total engine hours runtime >		14,738										
Operator Initials												
Test Converter		DES										
Date												
Result												
Operator Initials												

**APPENDIX D
I.C. ENGINE MAINTENANCE LOG
AERA ENERGY LLC**

Engine Location: Sespe Unit #2												
Engine I.D.: Waukesha 7042G												
Oil Filter No.		Plug No.: RM77N		Fan Belt No. N/A		Oil Capacity _____ Gal.		Fan N/A				
Engine Water Pump Belt No. B-66 [4]												
Auxiliary Water Pump N/A												
Year: 2011	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEPT	OCT	NOV	DEC
Date:	1/24/2011											
PM Number:	910542799											
Engine Oil Change	No											
Engine Filter Change	Yes											
Compressor Oil Change	No											
Compressor Filter Change	Yes											
Set Valves	Yes											
Change Ignition Timer	No											
Change Plugs	Yes											
Set Timing	Yes											
Change Air Filters	No											
Change Pre-Air Filters	Yes											
Change Belts - Fan / Water Pump	No											
Check Safety Shutdowns	No											
Change Converter	No											
Change O2 Sensor	No											
Inspect Fuel Control Valve	Yes											
Clean Carburetor	No											
Run-Time Hours Since Last Service (Permit Limit: After 2000 hours)	2939											
Engine RPM	850											
(Permit Limit: _____)												
Other Notes/Corrections:												
total engine hours runtime >	11398											
Operator Initials	DES											
Test Converter												
Date												
Result												
Operator Initials												

Sespe Compressor Plant CAM Testing

Engine #1

Test Date	Test Value	Auto/Man	Length	Cause	Corrective Action
01-Jan-11					
02-Jan-11					
03-Jan-11					
04-Jan-11					
05-Jan-11					
06-Jan-11					
07-Jan-11					
08-Jan-11					
09-Jan-11					
10-Jan-11					
11-Jan-11					
12-Jan-11					
13-Jan-11					
14-Jan-11					
15-Jan-11					
16-Jan-11					
17-Jan-11					
18-Jan-11					
19-Jan-11					
20-Jan-11					
21-Jan-11					
22-Jan-11					
23-Jan-11					
24-Jan-11					
25-Jan-11	1.1	Auto			
26-Jan-11	1.5	Auto			
27-Jan-11	1.9	Auto			
28-Jan-11	1.3	Auto			
29-Jan-11	0.9	Auto			
30-Jan-11	1.2	Auto			
31-Jan-11	0.8	Auto			

NO_x Limit is 25 PPM at 15% O₂

(1) Only one engine runs at a time

Engine #2

Test Date	Test Value	Auto/Man	Length	Cause	Corrective Action
01-Jan-11	3.6	Auto			
02-Jan-11	2.6	Auto			
03-Jan-11	3.6	Auto			
04-Jan-11	3.6	Auto			
05-Jan-11	3.6	Auto			
06-Jan-11	2.8	Auto			
07-Jan-11	1.8	Auto			
08-Jan-11	6.7	Auto			
09-Jan-11	4.6	Auto			
10-Jan-11	5.7	Auto			
11-Jan-11	4.4	Auto			
12-Jan-11	2.4	Auto			
13-Jan-11	8.6	Auto			
14-Jan-11	5.8	Auto			
15-Jan-11	4.6	Auto			
16-Jan-11	6.2	Auto			
17-Jan-11	5.0	Auto			
18-Jan-11	4.4	Auto			
19-Jan-11	4.4	Auto			
20-Jan-11	4.0	Auto			
21-Jan-11	1.8	Auto			
22-Jan-11	3.8	Auto			
23-Jan-11	4.1	Auto			
24-Jan-11	6.9	Auto			
25-Jan-11					
26-Jan-11					
27-Jan-11					
28-Jan-11					
29-Jan-11					
30-Jan-11					
31-Jan-11					

