

SCS ENGINEERS

February 14, 2008
File No. 01201056.04, Task 4

Keith Duval
Ventura County Air Pollution Control District
669 County Square Drive
Second Floor
Ventura, California 93003

SUBJECT: SEMI-ANNUAL TITLE V/NSPS REPORT, SEMI-ANNUAL SSM PLAN REPORT, AND ANNUAL TITLE V COMPLIANCE CERTIFICATION, SIMI VALLEY LANDFILL, SIMI VALLEY, CALIFORNIA

Dear Mr. Duval:

On behalf of the Waste Management of California, Inc., SCS Engineers hereby provides the Ventura County Air Pollution Control District (VCAPCD) with one copy each of the Semi-Annual Title V/ New Source Performance Standards (NSPS) Report, Semi-Annual Startup, Shutdown, and Malfunction (SSM) Plan Report, and Annual Title V Compliance Certification for the Simi Valley Landfill in Simi Valley, California. Copies of these documents have also been sent to the Air Division at the U.S. Environmental Protection Agency (USEPA).

The semi-annual Title V/NSPS and SSM reports were developed for the reporting period from July 1, 2007 through December 31, 2007. The annual Title V compliance certification was developed for the reporting period from January 1, 2007 through December 31, 2007. The reports satisfy the requirements under the site's Title V permit, as well as NSPS for municipal solid waste landfills (40 CFR Part 60, Subpart WWW).

The SSM Plan Report satisfies the requirements under the Maximum Achievable Control Technology (MACT) rule for semi-annual reporting of SSM plan implementation including 40 CFR 63.10(d)(s).

If you have any questions or need any additional information, please contact the undersigned at (562) 426-9544 or Mr. Bruce Matlock at (805) 579-7267.

Sincerely,



Gabrielle N. Fourie
Project Scientist
SCS ENGINEERS

Enclosures

Mr. Keith Duval
February 14, 2008
Page 2 of 2

cc: Gerardo Rios; USEPA Region IX (w/enclosures)
Bruce Matlock; Waste Management (w/enclosures)
Patrick Sullivan; SCS Engineers (w/enclosures)
Christian Colline; Waste Management (w/enclosures)
Laura Keener; Waste Management (w/enclosures)

**2007 TITLE V ANNUAL COMPLIANCE CERTIFICATION
SIMI VALLEY LANDFILL
SIMI VALLEY, CALIFORNIA**

Prepared for:

WASTE MANAGEMENT OF CALIFORNIA, INC
2801 Madera Road
Simi Valley, California 93065

Prepared by:

SCS ENGINEERS
3900 Kilroy Airport Way
Suite 100
Long Beach, California 90806

File No. 01201056.04
February 2008

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM

Cover Sheet

Form TVPF45/07-21-03 Page 1 of 1

A copy of each compliance certification shall be submitted to EPA Region IX at the following address:


Mr. Gerardo Rios, Chief
Permits Office (AIR-3)
Office of Air Division
EPA Region IX
75 Hawthorne Street
San Francisco, CA 94105

Confidentiality

All information in a Part 70 permit compliance certification is public information. The Part 70 permit is also public information.

Certification by Responsible Official

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in this compliance certification are true, accurate, and complete.

Signature and Title of Responsible Official:  Title: <u>DISTRICT MGR</u>	Date: <u>2-08-08</u>
--	-------------------------

Time Period Covered by Compliance Certification: <u>01</u> / <u>01</u> / <u>2007</u> (MM/DD/YY) to <u>12</u> / <u>31</u> / <u>2007</u> (MM/DD/YY)
--

TABLE OF CONTENTS

SECTION 1. APPLICABLE REQUIREMENT FORM (TVPF46)

1-1. SPECIFIC APPLICABLE REQUIREMENTS

1-2. PERMIT SPECIFIC CONDITIONS

1-3. GENERAL APPLICABLE REQUIREMENTS

1-4. GENERAL REQUIREMENTS FOR SHORT-TERM ACTIVITIES

SECTION 2. QUANTIFIABLE APPLICABLE REQUIREMENT FORM (TVPF47)

APPENDICES

APPENDIX A – Summary of Annual Emission Survey

APPENDIX B –Emission Inspections Results for IC Engines

SECTION 1. APPLICABLE REQUIREMENT FORM

1-1. Specific Applicable Requirements

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
 Applicable Requirement or Part 70 Permit Condition Attachment

Form TVPF46/07-21-03 Page 1 of 2

Applicable Requirement or Part 70 Permit Condition

Citation, Including Attachment Number and/or Permit Condition Number: 74.6.1N1	Description: Cold cleaner – Free board ratio compliance
---	--

Attach to this form any information specifically required to be submitted with the compliance certification in the applicable requirement or Part 70 permit condition.

1. Please indicate the method(s) that you use for determining compliance. Indicate the frequency of monitoring and indicate the source test reference method, if applicable.

The landfill used a remote reservoir cold cleaner (RRCC) and was exempt from the annual measurement and verification requirements as specified in Condition 9 of Attachment 74.6.1N1. The RRCC onsite complies with the drain hole and free board height requirements as specified in Rule 74.6.1.

The site replaced the RRCC with a new cold cleaner that utilizes a low reactive organic compounds (ROC) content solvent with a ROC content of 25 grams per liter or less during 2004. The new cold cleaner is exempt from the new Rule 74.6.1, which was effective on July 1, 2004.

2. Yes No Are you currently in compliance as indicated by the most recent monitoring measurement or observation as described above?

3. Please indicate if compliance during the reporting period was continuous or intermittent:

- Continuous – All monitoring measurements show compliance with the Part 70 permit condition
 Intermittent – One or more measurements indicate a failure to meet the Part 70 permit condition

4. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any excursions, if applicable? An *excursion* is defined as “a departure from an indicator or surrogate parameter range established for monitoring under the applicable requirement or Part 70 permit condition, consistent with any averaging period specified for averaging the results of the monitoring.”

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment
Form TVPF46/07-21-03 Page 2 of 2

5. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any exceedances, if applicable? An *exceedance* is defined as "a condition that is detected by monitoring that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) are greater than the applicable emission limitation or standard (or less than the applicable standard in the case of percent reduction requirement) consistent with any averaging period specified for averaging the results of the monitoring."
6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.
8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
 Applicable Requirement or Part 70 Permit Condition Attachment
 Form TVPF46/07-21-03 Page 1 of 2

Applicable Requirement or Part 70 Permit Condition

Citation, Including Attachment Number and/or Permit Condition Number:	Description:
74.9N7	The engine shall only be operated during an emergency or during maintenance operation of not more than 50 hours per calendar year.

Attach to this form any information specifically required to be submitted with the compliance certification in the applicable requirement or Part 70 permit condition.

1. Please indicate the method(s) that you use for determining compliance. Indicate the frequency of monitoring and indicate the source test reference method, if applicable.

The site is in compliance with the applicable requirement listed above, upon reviewing of the emergency engine hours of operation log (Date, time, duration, and reason for emergency operation). The engine was operated for a total of 5 hours during the reporting year. The rental engine (used while the emergency engine was being repaired) operated 5.3 hours during the reporting year.

2. Yes No Are you currently in compliance as indicated by the most recent monitoring measurement or observation as described above?
3. Please indicate if compliance during the reporting period was continuous or intermittent:
 - Continuous – All monitoring measurements show compliance with the Part 70 permit condition
 - Intermittent – One or more measurements indicate a failure to meet the Part 70 permit condition
4. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any excursions, if applicable? An *excursion* is defined as “a departure from an indicator or surrogate parameter range established for monitoring under the applicable requirement or Part 70 permit condition, consistent with any averaging period specified for averaging the results of the monitoring.”

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment

Form TVPF46/07-21-03 Page 2 of 2

5. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any exceedances, if applicable? An *exceedance* is defined as "a condition that is detected by monitoring that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) are greater than the applicable emission limitation or standard (or less than the applicable standard in the case of percent reduction requirement) consistent with any averaging period specified for averaging the results of the monitoring."
6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.
8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

 01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
 Applicable Requirement or Part 70 Permit Condition Attachment
 Form TVPF46/07-21-03 Page 1 of 2

Applicable Requirement or Part 70 Permit Condition

Citation, Including Attachment Number and/or Permit Condition Number: 74.17.1N4	Description: Operate the landfill gas (LFG) collection and control system (GCCS) in accordance with the requirements of Rule 74.17.1
--	---

Attach to this form any information specifically required to be submitted with the compliance certification in the applicable requirement or Part 70 permit condition.

1. Please indicate the method(s) that you use for determining compliance. Indicate the frequency of monitoring and indicate the source test reference method, if applicable.

The site is in compliance with the applicable requirement listed above, upon reviewing of the site LFG GCCS operational records for the following:

Surface emissions monitoring – As reviewed under the 2007 Title V Semi-Annual Reports for the site, which summarized the quarterly surface emission monitoring results and monthly surface emission monitoring around structures results.

Source test - As reviewed under Condition No.1 and No. 2 of Attachment PO01395PC2 below for the Nitrogen Oxides (NOx) and ROC compliance verifications. Both flares also meet Carbon Monoxide (CO) emission limits and achieves at least 99% NMOC destruction efficiencies, per review of source test results conducted in October 2005 for Flare No. 2 and October 2007 for Flare No. 1.

Wellhead monitoring for pressure, oxygen content, and temperature – As reviewed under the 2007 Title V Semi-Annual Reports for the site, which summarized the monthly wellhead monitoring results.

1. Yes No Are you currently in compliance as indicated by the most recent monitoring measurement or observation as described above?
2. Please indicate if compliance during the reporting period was continuous or intermittent:
 - Continuous – All monitoring measurements show compliance with the Part 70 permit condition
 - Intermittent – One or more measurements indicate a failure to meet the Part 70 permit condition

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment

Form TVPF46/07-21-03 Page 2 of 2

4. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any excursions, if applicable? An *excursion* is defined as "a departure from an indicator or surrogate parameter range established for monitoring under the applicable requirement or Part 70 permit condition, consistent with any averaging period specified for averaging the results of the monitoring."
5. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any exceedances, if applicable? An *exceedance* is defined as "a condition that is detected by monitoring that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) are greater than the applicable emission limitation or standard (or less than the applicable standard in the case of percent reduction requirement) consistent with any averaging period specified for averaging the results of the monitoring."
6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.

8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

1-2. Permit-Specific Conditions

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
 Applicable Requirement or Part 70 Permit Condition Attachment
 Form TVPF46/07-21-03 Page 1 of 2

Applicable Requirement or Part 70 Permit Condition

Citation, Including Attachment Number and/or Permit Condition Number: PO01395PC1 – Condition No.1	Description: Recordkeeping on monthly records of LFG throughput and consumption to the control devices.
--	--

Attach to this form any information specifically required to be submitted with the compliance certification in the applicable requirement or Part 70 permit condition.

1. Please indicate the method(s) that you use for determining compliance. Indicate the frequency of monitoring and indicate the source test reference method, if applicable.

The site is in compliance with the applicable requirement by keeping monthly records of LFG throughput and consumption to the control devices on file.

2. Yes No Are you currently in compliance as indicated by the most recent monitoring measurement or observation as described above?

3. Please indicate if compliance during the reporting period was continuous or intermittent:

- Continuous – All monitoring measurements show compliance with the Part 70 permit condition
 Intermittent – One or more measurements indicate a failure to meet the Part 70 permit condition

4. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any excursions, if applicable? An *excursion* is defined as “a departure from an indicator or surrogate parameter range established for monitoring under the applicable requirement or Part 70 permit condition, consistent with any averaging period specified for averaging the results of the monitoring.”

5. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any exceedances, if applicable? An *exceedance* is defined as “a condition that is detected by monitoring that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) are greater than the applicable emission limitation or standard (or less than the applicable standard in the case of percent reduction requirement) consistent with any averaging period specified for averaging the results of the monitoring.”

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment
Form TVPF46/07-21-03 Page 2 of 2

6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.
8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
 Applicable Requirement or Part 70 Permit Condition Attachment
 Form TVPF46/07-21-03 Page 1 of 2

Applicable Requirement or Part 70 Permit Condition

Citation, Including Attachment Number and/or Permit Condition Number: PO01395PC1 – Condition No.2	Description: Annual amount of LFG combusted in the two flares and the two IC engines shall not exceed 878,190 MMBtu/yr. Total combined amount of LFG combusted in the two engines shall not exceed 306,000 MMBtu/hr.
--	---

Attach to this form any information specifically required to be submitted with the compliance certification in the applicable requirement or Part 70 permit condition.

1. Please indicate the method(s) that you use for determining compliance. Indicate the frequency of monitoring and indicate the source test reference method, if applicable.

The site is in compliance with the applicable requirement listed above, per review of the monthly LFG throughput summary records to the control devices. The records are kept on file and will be made available upon request.

2. Yes No Are you currently in compliance as indicated by the most recent monitoring measurement or observation as described above?
3. Please indicate if compliance during the reporting period was continuous or intermittent:
 - Continuous – All monitoring measurements show compliance with the Part 70 permit condition
 - Intermittent – One or more measurements indicate a failure to meet the Part 70 permit condition
4. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any excursions, if applicable? An *excursion* is defined as “a departure from an indicator or surrogate parameter range established for monitoring under the applicable requirement or Part 70 permit condition, consistent with any averaging period specified for averaging the results of the monitoring.”
5. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any exceedances, if applicable? An *exceedance* is defined as “a condition that is detected by monitoring that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) are greater than the applicable emission limitation or standard (or less than the applicable standard in the case of percent reduction requirement) consistent with any averaging period specified for averaging the results of the monitoring.”

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment
Form TVPF46/07-21-03 Page 2 of 2

6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.
8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment

Form TVPF46/07-21-03 Page 1 of 2

Applicable Requirement or Part 70 Permit Condition

Citation, Including Attachment Number and/or Permit Condition Number: PO01395PC1 – Condition No.3	Description: Each engine and each flare shall be equipped with a totalizing fuel meter.
--	--

Attach to this form any information specifically required to be submitted with the compliance certification in the applicable requirement or Part 70 permit condition.

1. Please indicate the method(s) that you use for determining compliance. Indicate the frequency of monitoring and indicate the source test reference method, if applicable.

The flares and engines are equipped with the required components and are in compliance with the applicable requirements listed above.

2. Yes No Are you currently in compliance as indicated by the most recent monitoring measurement or observation as described above?
3. Please indicate if compliance during the reporting period was continuous or intermittent:
 Continuous – All monitoring measurements show compliance with the Part 70 permit condition
 Intermittent – One or more measurements indicate a failure to meet the Part 70 permit condition
4. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any excursions, if applicable? An *excursion* is defined as “a departure from an indicator or surrogate parameter range established for monitoring under the applicable requirement or Part 70 permit condition, consistent with any averaging period specified for averaging the results of the monitoring.”
5. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any exceedances, if applicable? An *exceedance* is defined as “a condition that is detected by monitoring that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) are greater than the applicable emission limitation or standard (or less than the applicable standard in the case of percent reduction requirement) consistent with any averaging period specified for averaging the results of the monitoring.”

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment
Form TVPF46/07-21-03 Page 2 of 2

6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.
8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
 Applicable Requirement or Part 70 Permit Condition Attachment
 Form TVPF46/07-21-03 Page 1 of 2

Applicable Requirement or Part 70 Permit Condition

Citation, Including Attachment Number and/or Permit Condition Number:	Description:
PO01395PC1 – Condition No.4	Recordkeeping on monthly records of solvent purchase and usage. (District enforceable only)

Attach to this form any information specifically required to be submitted with the compliance certification in the applicable requirement or Part 70 permit condition.

1. Please indicate the method(s) that you use for determining compliance. Indicate the frequency of monitoring and indicate the source test reference method, if applicable.

The condition is District enforceable only and needs not to be certified via the Title V annual compliance certification. However, the landfill keeps associated records on file as specified in the permit condition.

1. Yes No Are you currently in compliance as indicated by the most recent monitoring measurement or observation as described above?
2. Please indicate if compliance during the reporting period was continuous or intermittent:
 - Continuous – All monitoring measurements show compliance with the Part 70 permit condition
 - Intermittent – One or more measurements indicate a failure to meet the Part 70 permit condition
4. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any excursions, if applicable? An *excursion* is defined as “a departure from an indicator or surrogate parameter range established for monitoring under the applicable requirement or Part 70 permit condition, consistent with any averaging period specified for averaging the results of the monitoring.”
5. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any exceedances, if applicable? An *exceedance* is defined as “a condition that is detected by monitoring that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) are greater than the applicable emission limitation or standard (or less than the applicable standard in the case of percent reduction requirement) consistent with any averaging period specified for averaging the results of the monitoring.”

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment
Form TVPF46/07-21-03 Page 2 of 2

6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.
8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
 Applicable Requirement or Part 70 Permit Condition Attachment
 Form TVPF46/07-21-03 Page 1 of 2

Applicable Requirement or Part 70 Permit Condition

Citation, Including Attachment Number and/or Permit Condition Number: PO01395PC2 – Condition No.1	Description: McGill flare BACT limits: <ol style="list-style-type: none"> 1. Temperature 2. Source test (ROC, NOx) every two years 3. Testing of Sulfur Oxides (SOx) every four years
--	---

Attach to this form any information specifically required to be submitted with the compliance certification in the applicable requirement or Part 70 permit condition.

1. Please indicate the method(s) that you use for determining compliance. Indicate the frequency of monitoring and indicate the source test reference method, if applicable.

The flare is in compliance with the applicable requirements listed above, based on the following:

1. Source test conducted in October 1-2, 2007 for Flare No. 1 with the ROC emission rate of 0.0333 lb/hr, NOx emission rate of 0.0294 lb/MMBtu, the CO emission rate of 0.0201 lb/MMBtu, and the calculated SOx emission rate was 0.018 lb/MMBtu. The flare meets the ROC, NOx, CO, and SOx emission limits as specified in the permit conditions
2. The flare will be automatically shutdown when the temperature falls below the minimum temperature as required under the permit. Flare temperatures are monitored and recorded via a continuous recorder.

2. Yes No Are you currently in compliance as indicated by the most recent monitoring measurement or observation as described above?

3. Please indicate if compliance during the reporting period was continuous or intermittent:

- Continuous – All monitoring measurements show compliance with the Part 70 permit condition
 Intermittent – One or more measurements indicate a failure to meet the Part 70 permit condition

4. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any excursions, if applicable? An *excursion* is defined as “a departure from an indicator or surrogate parameter range established for monitoring under the applicable requirement or Part 70 permit condition, consistent with any averaging period specified for averaging the results of the monitoring.”

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment

Form TVPF46/07-21-03 Page 2 of 2

5. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any exceedances, if applicable? An *exceedance* is defined as "a condition that is detected by monitoring that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) are greater than the applicable emission limitation or standard (or less than the applicable standard in the case of percent reduction requirement) consistent with any averaging period specified for averaging the results of the monitoring."
6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.
8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
 Applicable Requirement or Part 70 Permit Condition Attachment

Form TVPF46/07-21-03 Page 1 of 2

Applicable Requirement or Part 70 Permit Condition

Citation, Including Attachment Number and/or Permit Condition Number: PO01395PC2 – Condition No.2	Description: John Zink flare BACT limits: 1. Temperature 2. Source test (ROC, NOx) every two years 3. Testing of SOx every four years
--	---

Attach to this form any information specifically required to be submitted with the compliance certification in the applicable requirement or Part 70 permit condition.

1. Please indicate the method(s) that you use for determining compliance. Indicate the frequency of monitoring and indicate the source test reference method, if applicable.

The flare is in compliance with the applicable requirements listed above, based on the following:

1. Source test conducted in October 12-21, 2005 for Flare 2 with the ROC emission rate of 0.08 lb/hr, NOx emission rate of 0.04 lb/MMBtu, and the calculated SOx emission rate was 0.018 lb/MMBtu. The flare meets the ROC, NOx, and SOx emission limits as specified in the permit condition. Please note that the results from the source test conducted in October 2007 were not considered valid due to a malfunction event causing the Yokagawa chart recorder to record higher than actual temperature data. It was determined that a re-test must be performed and the last valid compliance test will remain October 12-21 and November 21-22, 2005 until the results of the re-test that was performed on January 14, 2008 are published.
2. The flare will be automatically shutdown when the temperature falls below the minimum temperature as required under the permit. Flare temperatures are monitored and recorded via a continuous recorder.

2. Yes No Are you currently in compliance as indicated by the most recent monitoring measurement or observation as described above?

3. Please indicate if compliance during the reporting period was continuous or intermittent:

- Continuous – All monitoring measurements show compliance with the Part 70 permit condition
 Intermittent – One or more measurements indicate a failure to meet the Part 70 permit condition

4. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any excursions, if applicable? An *excursion* is defined

as "a departure from an indicator or surrogate parameter range established for monitoring under the applicable requirement or Part 70 permit condition, consistent with any averaging period specified for averaging the results of the monitoring."

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment

Form TVPF46/07-21-03 Page 2 of 2

5. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any exceedances, if applicable? An *exceedance* is defined as "a condition that is detected by monitoring that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) are greater than the applicable emission limitation or standard (or less than the applicable standard in the case of percent reduction requirement) consistent with any averaging period specified for averaging the results of the monitoring."
6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.
8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
 Applicable Requirement or Part 70 Permit Condition Attachment
 Form TVPF46/07-21-03 Page 1 of 2

Applicable Requirement or Part 70 Permit Condition

Citation, Including Attachment Number and/or Permit Condition Number: PO01395PC2 – Condition No.3	Description: Flare particulate matter (PM) emission requirement
--	--

Attach to this form any information specifically required to be submitted with the compliance certification in the applicable requirement or Part 70 permit condition.

1. Please indicate the method(s) that you use for determining compliance. Indicate the frequency of monitoring and indicate the source test reference method, if applicable.

The site is in compliance with the applicable requirement listed above, per District analysis of Rule 52 compliance based on EPA PM emission factor.

1. Yes No Are you currently in compliance as indicated by the most recent monitoring measurement or observation as described above?
2. Please indicate if compliance during the reporting period was continuous or intermittent:
 - Continuous – All monitoring measurements show compliance with the Part 70 permit condition
 - Intermittent – One or more measurements indicate a failure to meet the Part 70 permit condition
4. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any excursions, if applicable? An *excursion* is defined as “a departure from an indicator or surrogate parameter range established for monitoring under the applicable requirement or Part 70 permit condition, consistent with any averaging period specified for averaging the results of the monitoring.”
5. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any exceedances, if applicable? An *exceedance* is defined as “a condition that is detected by monitoring that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) are greater than the applicable emission limitation or standard (or less than the applicable standard in the case of percent reduction requirement) consistent with any averaging period specified for averaging the results of the monitoring.”

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment
Form TVPF46/07-21-03 Page 2 of 2

6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.
8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment

Form TVPF46/07-21-03 Page 1 of 2

Applicable Requirement or Part 70 Permit Condition

Citation, Including Attachment Number and/or Permit Condition Number: PO01395PC2 – Condition No.4	Description: Source test every four years on the emission of sulfur compounds.
--	---

Attach to this form any information specifically required to be submitted with the compliance certification in the applicable requirement or Part 70 permit condition.

1. Please indicate the method(s) that you use for determining compliance. Indicate the frequency of monitoring and indicate the source test reference method, if applicable.

The site is in compliance with the applicable requirement listed above, per source test conducted in October 2007 for the McGill flare and October 2005 for the John Zink flare.

2. Yes No Are you currently in compliance as indicated by the most recent monitoring measurement or observation as described above?
3. Please indicate if compliance during the reporting period was continuous or intermittent:
 Continuous – All monitoring measurements show compliance with the Part 70 permit condition
 Intermittent – One or more measurements indicate a failure to meet the Part 70 permit condition
4. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any excursions, if applicable? An *excursion* is defined as “a departure from an indicator or surrogate parameter range established for monitoring under the applicable requirement or Part 70 permit condition, consistent with any averaging period specified for averaging the results of the monitoring.”
5. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any exceedances, if applicable? An *exceedance* is defined as “a condition that is detected by monitoring that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) are greater than the applicable emission limitation or standard (or less than the applicable standard in the case of percent reduction requirement) consistent with any averaging period specified for averaging the results of the monitoring.”

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment

Form TVPF46/07-21-03 Page 2 of 2

6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.
8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment

Form TVPF46/07-21-03 Page 1 of 2

Applicable Requirement or Part 70 Permit Condition

Citation, Including Attachment Number and/or Permit Condition Number: PO01395PC2 – Condition No.5	Description: Combustion contaminates discharge requirement
--	---

Attach to this form any information specifically required to be submitted with the compliance certification in the applicable requirement or Part 70 permit condition.

1. Please indicate the method(s) that you use for determining compliance. Indicate the frequency of monitoring and indicate the source test reference method, if applicable.

The site is in compliance with the applicable requirement listed above, per District analysis of Rule 57.B compliance based on EPA PM emission factor.

2. Yes No Are you currently in compliance as indicated by the most recent monitoring measurement or observation as described above?
3. Please indicate if compliance during the reporting period was continuous or intermittent:
- Continuous – All monitoring measurements show compliance with the Part 70 permit condition
 Intermittent – One or more measurements indicate a failure to meet the Part 70 permit condition
4. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any excursions, if applicable? An *excursion* is defined as “a departure from an indicator or surrogate parameter range established for monitoring under the applicable requirement or Part 70 permit condition, consistent with any averaging period specified for averaging the results of the monitoring.”
5. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any exceedances, if applicable? An *exceedance* is defined as “a condition that is detected by monitoring that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) are greater than the applicable emission limitation or standard (or less than the applicable standard in the case of percent reduction requirement) consistent with any averaging period specified for averaging the results of the monitoring.”

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment
Form TVPF46/07-21-03 Page 2 of 2

6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.
8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
 Applicable Requirement or Part 70 Permit Condition Attachment
 Form TVPF46/07-21-03 Page 1 of 2

Applicable Requirement or Part 70 Permit Condition

Citation, Including Attachment Number and/or Permit Condition Number: PO01395PC2 – Condition No.6	Description: Source test every two years on the emission of CO
--	---

Attach to this form any information specifically required to be submitted with the compliance certification in the applicable requirement or Part 70 permit condition.

1. Please indicate the method(s) that you use for determining compliance. Indicate the frequency of monitoring and indicate the source test reference method, if applicable.

The site is in compliance with the applicable requirement listed above, per source test conducted in October 2007 with the CO emission rate of 0.0201 lb/MMbtu for the McGill flare and October 2005 with a CO emission rate of 0.003 lb/MMbtu for the John Zink flare.

2. Yes No Are you currently in compliance as indicated by the most recent monitoring measurement or observation as described above?
3. Please indicate if compliance during the reporting period was continuous or intermittent:
 - Continuous – All monitoring measurements show compliance with the Part 70 permit condition
 - Intermittent – One or more measurements indicate a failure to meet the Part 70 permit condition
4. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any excursions, if applicable? An *excursion* is defined as “a departure from an indicator or surrogate parameter range established for monitoring under the applicable requirement or Part 70 permit condition, consistent with any averaging period specified for averaging the results of the monitoring.”
5. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any exceedances, if applicable? An *exceedance* is defined as “a condition that is detected by monitoring that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) are greater than the applicable emission limitation or standard (or less than the applicable standard in the case of percent reduction requirement) consistent with any averaging period specified for averaging the results of the monitoring.”

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment
Form TVPF46/07-21-03 Page 2 of 2

6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.
8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

 01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment

Form TVPF46/07-21-03 Page 1 of 2

Applicable Requirement or Part 70 Permit Condition

Citation, Including Attachment Number and/or Permit Condition Number: PO01395PC2 – Condition No.7	Description: Flare equipment requirements for McGill flare
--	---

Attach to this form any information specifically required to be submitted with the compliance certification in the applicable requirement or Part 70 permit condition.

1. Please indicate the method(s) that you use for determining compliance. Indicate the frequency of monitoring and indicate the source test reference method, if applicable.

The flare is equipped with the required components and is in compliance with the applicable requirements listed above.

2. Yes No Are you currently in compliance as indicated by the most recent monitoring measurement or observation as described above?
3. Please indicate if compliance during the reporting period was continuous or intermittent:
 Continuous – All monitoring measurements show compliance with the Part 70 permit condition
 Intermittent – One or more measurements indicate a failure to meet the Part 70 permit condition
4. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any excursions, if applicable? An *excursion* is defined as “a departure from an indicator or surrogate parameter range established for monitoring under the applicable requirement or Part 70 permit condition, consistent with any averaging period specified for averaging the results of the monitoring.”
5. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any exceedances, if applicable? An *exceedance* is defined as “a condition that is detected by monitoring that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) are greater than the applicable emission limitation or standard (or less than the applicable standard in the case of percent reduction requirement) consistent with any averaging period specified for averaging the results of the monitoring.”

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment

Form TVPF46/07-21-03 Page 2 of 2

6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.
8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
 Applicable Requirement or Part 70 Permit Condition Attachment
 Form TVPF46/07-21-03 Page 1 of 2

Applicable Requirement or Part 70 Permit Condition

Citation, Including Attachment Number and/or Permit Condition Number: PO01395PC2 – Condition No.8	Description: Flare equipment requirements for John Zink flare
--	--

Attach to this form any information specifically required to be submitted with the compliance certification in the applicable requirement or Part 70 permit condition.

1. Please indicate the method(s) that you use for determining compliance. Indicate the frequency of monitoring and indicate the source test reference method, if applicable.

The flare is equipped with the required components and is in compliance with the applicable requirements listed above.

2. Yes No Are you currently in compliance as indicated by the most recent monitoring measurement or observation as described above?

3. Please indicate if compliance during the reporting period was continuous or intermittent:
- Continuous – All monitoring measurements show compliance with the Part 70 permit condition
 Intermittent – One or more measurements indicate a failure to meet the Part 70 permit condition

4. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any excursions, if applicable? An *excursion* is defined as “a departure from an indicator or surrogate parameter range established for monitoring under the applicable requirement or Part 70 permit condition, consistent with any averaging period specified for averaging the results of the monitoring.”

5. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any exceedances, if applicable? An *exceedance* is defined as “a condition that is detected by monitoring that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) are greater than the applicable emission limitation or standard (or less than the applicable standard in the case of percent reduction requirement) consistent with any averaging period specified for averaging the results of the monitoring.”

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment

Form TVPF46/07-21-03 Page 2 of 2

6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.
8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
 Applicable Requirement or Part 70 Permit Condition Attachment
 Form TVPF46/07-21-03 Page 1 of 2

Applicable Requirement or Part 70 Permit Condition

Citation, Including Attachment Number and/or Permit Condition Number: PO01395PC2 – Condition No.9	Description: Condensate knockout /filter vessel equipment requirement for both flares
--	--

Attach to this form any information specifically required to be submitted with the compliance certification in the applicable requirement or Part 70 permit condition.

1. Please indicate the method(s) that you use for determining compliance. Indicate the frequency of monitoring and indicate the source test reference method, if applicable.

The two flares are equipped with the required condensate knockout / filter vessel and are in compliance with the applicable requirement listed above.

2. Yes No Are you currently in compliance as indicated by the most recent monitoring measurement or observation as described above?
3. Please indicate if compliance during the reporting period was continuous or intermittent:
 - Continuous – All monitoring measurements show compliance with the Part 70 permit condition
 - Intermittent – One or more measurements indicate a failure to meet the Part 70 permit condition
4. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any excursions, if applicable? An *excursion* is defined as “a departure from an indicator or surrogate parameter range established for monitoring under the applicable requirement or Part 70 permit condition, consistent with any averaging period specified for averaging the results of the monitoring.”
5. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any exceedances, if applicable? An *exceedance* is defined as “a condition that is detected by monitoring that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) are greater than the applicable emission limitation or standard (or less than the applicable standard in the case of percent reduction requirement) consistent with any averaging period specified for averaging the results of the monitoring.”

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment

Form TVPF46/07-21-03 Page 2 of 2

6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.
8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
 Applicable Requirement or Part 70 Permit Condition Attachment
 Form TVPF46/07-21-03 Page 1 of 2

Applicable Requirement or Part 70 Permit Condition

Citation, Including Attachment Number and/or Permit Condition Number: PO01395PC2 – Condition No.10	Description: Flare dimensions and exhaust velocity requirements for John Zink flare (District enforceable only)
---	--

Attach to this form any information specifically required to be submitted with the compliance certification in the applicable requirement or Part 70 permit condition.

1. Please indicate the method(s) that you use for determining compliance. Indicate the frequency of monitoring and indicate the source test reference method, if applicable.

The condition is District enforceable only and needs not to be certified via the Title V annual compliance certification. However, the flare meets the dimension requirement as specified in the condition and is in compliance with the exhaust velocity requirement, per source test conducted in October 2005.

2. Yes No Are you currently in compliance as indicated by the most recent monitoring measurement or observation as described above?

3. Please indicate if compliance during the reporting period was continuous or intermittent:
 Continuous – All monitoring measurements show compliance with the Part 70 permit condition
 Intermittent – One or more measurements indicate a failure to meet the Part 70 permit condition

4. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any excursions, if applicable? An *excursion* is defined as “a departure from an indicator or surrogate parameter range established for monitoring under the applicable requirement or Part 70 permit condition, consistent with any averaging period specified for averaging the results of the monitoring.”

5. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any exceedances, if applicable? An *exceedance* is defined as “a condition that is detected by monitoring that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) are greater than the applicable emission limitation or standard (or less than the applicable standard in the case of percent reduction requirement) consistent with any averaging period specified for averaging the results of the monitoring.”

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment
Form TVPF46/07-21-03 Page 2 of 2

6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.
8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

 01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment

Form TVPF46/07-21-03 Page 1 of 2

Applicable Requirement or Part 70 Permit Condition

Citation, Including Attachment Number and/or Permit Condition Number: PO01395PC2 – Condition No.11	Description: Annual calibration / function-check requirement for GCCS
---	--

Attach to this form any information specifically required to be submitted with the compliance certification in the applicable requirement or Part 70 permit condition.

1. Please indicate the method(s) that you use for determining compliance. Indicate the frequency of monitoring and indicate the source test reference method, if applicable.

The calibration / function-check on the flare and collection system components as required under the condition are performed annually. Associated records are kept on file. The site is in compliance with the applicable requirement listed above.

2. Yes No Are you currently in compliance as indicated by the most recent monitoring measurement or observation as described above?

3. Please indicate if compliance during the reporting period was continuous or intermittent:

- Continuous – All monitoring measurements show compliance with the Part 70 permit condition
 Intermittent – One or more measurements indicate a failure to meet the Part 70 permit condition

4. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any excursions, if applicable? An *excursion* is defined as “a departure from an indicator or surrogate parameter range established for monitoring under the applicable requirement or Part 70 permit condition, consistent with any averaging period specified for averaging the results of the monitoring.”

5. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any exceedances, if applicable? An *exceedance* is defined as “a condition that is detected by monitoring that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) are greater than the applicable emission limitation or standard (or less than the applicable standard in the case of percent reduction requirement) consistent with any averaging period specified for averaging the results of the monitoring.”

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment
Form TVPF46/07-21-03 Page 2 of 2

6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.
8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

 01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
 Applicable Requirement or Part 70 Permit Condition Attachment
 Form TVPF46/07-21-03 Page 1 of 2

Applicable Requirement or Part 70 Permit Condition

Citation, Including Attachment Number and/or Permit Condition Number: PO01395PC2 – Condition No.12	Description: Collection vessel emission requirements
---	---

Attach to this form any information specifically required to be submitted with the compliance certification in the applicable requirement or Part 70 permit condition.

1. Please indicate the method(s) that you use for determining compliance. Indicate the frequency of monitoring and indicate the source test reference method, if applicable.

The site is in compliance with the applicable requirement for the piping system from the condensate storage tank to the LFG collection system as specified in the condition.

2. Yes No Are you currently in compliance as indicated by the most recent monitoring measurement or observation as described above?
3. Please indicate if compliance during the reporting period was continuous or intermittent:
 - Continuous – All monitoring measurements show compliance with the Part 70 permit condition
 - Intermittent – One or more measurements indicate a failure to meet the Part 70 permit condition
4. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any excursions, if applicable? An *excursion* is defined as “a departure from an indicator or surrogate parameter range established for monitoring under the applicable requirement or Part 70 permit condition, consistent with any averaging period specified for averaging the results of the monitoring.”
5. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any exceedances, if applicable? An *exceedance* is defined as “a condition that is detected by monitoring that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) are greater than the applicable emission limitation or standard (or less than the applicable standard in the case of percent reduction requirement) consistent with any averaging period specified for averaging the results of the monitoring.”

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment
Form TVPF46/07-21-03 Page 2 of 2

6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.
8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

 01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment

Form TVPF46/07-21-03 Page 1 of 2

Applicable Requirement or Part 70 Permit Condition

Citation, Including Attachment Number and/or Permit Condition Number: PO1395PC2 – Condition No.13	Description: Collection vessel vacuum requirement
--	--

Attach to this form any information specifically required to be submitted with the compliance certification in the applicable requirement or Part 70 permit condition.

1. Please indicate the method(s) that you use for determining compliance. Indicate the frequency of monitoring and indicate the source test reference method, if applicable.

The site is in compliance with the vacuum requirement for the collection vessel as specified in the condition.

2. Yes No Are you currently in compliance as indicated by the most recent monitoring measurement or observation as described above?

3. Please indicate if compliance during the reporting period was continuous or intermittent:

- Continuous – All monitoring measurements show compliance with the Part 70 permit condition
 Intermittent – One or more measurements indicate a failure to meet the Part 70 permit condition

4. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any excursions, if applicable? An *excursion* is defined as “a departure from an indicator or surrogate parameter range established for monitoring under the applicable requirement or Part 70 permit condition, consistent with any averaging period specified for averaging the results of the monitoring.”

5. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any exceedances, if applicable? An *exceedance* is defined as “a condition that is detected by monitoring that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) are greater than the applicable emission limitation or standard (or less than the applicable standard in the case of percent reduction requirement) consistent with any averaging period specified for averaging the results of the monitoring.”

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment
Form TVPF46/07-21-03 Page 2 of 2

6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.
8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
 Applicable Requirement or Part 70 Permit Condition Attachment
 Form TVPF46/07-21-03 Page 1 of 2

Applicable Requirement or Part 70 Permit Condition

Citation, Including Attachment Number and/or Permit Condition Number:	Description:
PO1395PC2 – Condition No.14	Well location requirement

Attach to this form any information specifically required to be submitted with the compliance certification in the applicable requirement or Part 70 permit condition.

- Please indicate the method(s) that you use for determining compliance. Indicate the frequency of monitoring and indicate the source test reference method, if applicable.

The landfill acknowledged and is in compliance with the applicable requirements as specified in the condition.

- Yes No Are you currently in compliance as indicated by the most recent monitoring measurement or observation as described above?

- Please indicate if compliance during the reporting period was continuous or intermittent:

- Continuous – All monitoring measurements show compliance with the Part 70 permit condition
- Intermittent – One or more measurements indicate a failure to meet the Part 70 permit condition

- Yes No During the time period covered by this compliance certification, does the monitoring data indicate any excursions, if applicable? An *excursion* is defined as “a departure from an indicator or surrogate parameter range established for monitoring under the applicable requirement or Part 70 permit condition, consistent with any averaging period specified for averaging the results of the monitoring.”

- Yes No During the time period covered by this compliance certification, does the monitoring data indicate any exceedances, if applicable? An *exceedance* is defined as “a condition that is detected by monitoring that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) are greater than the applicable emission limitation or standard (or less than the applicable standard in the case of percent reduction requirement) consistent with any averaging period specified for averaging the results of the monitoring.”

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment
Form TVPF46/07-21-03 Page 2 of 2

6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.
8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment
Form TVPF46/07-21-03 Page 2 of 2

5. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any exceedances, if applicable? An *exceedance* is defined as "a condition that is detected by monitoring that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) are greater than the applicable emission limitation or standard (or less than the applicable standard in the case of percent reduction requirement) consistent with any averaging period specified for averaging the results of the monitoring."
6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.
8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
 Applicable Requirement or Part 70 Permit Condition Attachment

Form TVPF46/07-21-03 Page 1 of 2

Applicable Requirement or Part 70 Permit Condition

Citation, Including Attachment Number and/or Permit Condition Number: PO01395PC3 – Condition No.1	Description: Deutz IC engines emission limits: 1. BACT limits 2. Rule 74.9.B.1 limits 3. Emissions testing biennially to verify compliance
--	--

Attach to this form any information specifically required to be submitted with the compliance certification in the applicable requirement or Part 70 permit condition.

- Please indicate the method(s) that you use for determining compliance. Indicate the frequency of monitoring and indicate the source test reference method, if applicable.

The performance test for Engine No. 2 was conducted on March 19, 2007 by Total Air Analysis, Inc of Carson. The performance test for Engine No. 1 was performed on June 22, 2007. Engine No. 1 source test had NOx emission rate of 28.92 ppmv at 15% O₂, CO emission rate of 215.51 ppmv at 15% O₂, and ROC emission rate of 7.58 ppmv at 15% O₂. Engine No. 2 source test had NOx emission rate of 32.10 ppmv at 15% O₂, CO emission rate of 236.70 ppmv at 15% O₂, and ROC emission rate of 4.34 ppmv at 15% O₂. The test result showed that both engines are in compliance with the NOx, CO, and ROC permitted emission limits.

- Yes No Are you currently in compliance as indicated by the most recent monitoring measurement or observation as described above?

- Please indicate if compliance during the reporting period was continuous or intermittent:
 - Continuous – All monitoring measurements show compliance with the Part 70 permit condition
 - Intermittent – One or more measurements indicate a failure to meet the Part 70 permit condition

- Yes No During the time period covered by this compliance certification, does the monitoring data indicate any excursions, if applicable? An *excursion* is defined as “a departure from an indicator or surrogate parameter range established for monitoring under the applicable requirement or Part 70 permit condition, consistent with any averaging period specified for averaging the results of the monitoring.”

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment

Form TVPF46/07-21-03 Page 2 of 2

5. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any exceedances, if applicable? An *exceedance* is defined as "a condition that is detected by monitoring that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) are greater than the applicable emission limitation or standard (or less than the applicable standard in the case of percent reduction requirement) consistent with any averaging period specified for averaging the results of the monitoring."
6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.

7. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment

Form TVPF46/07-21-03 Page 2 of 2

6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.
8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment

Form TVPF46/07-21-03 Page 1 of 2

Applicable Requirement or Part 70 Permit Condition

Citation, Including Attachment Number and/or Permit Condition Number: PO01395PC3 – Condition No.3	Description: Annual source test requirement on IC engines
--	--

Attach to this form any information specifically required to be submitted with the compliance certification in the applicable requirement or Part 70 permit condition.

1. Please indicate the method(s) that you use for determining compliance. Indicate the frequency of monitoring and indicate the source test reference method, if applicable.

The site is in compliance with the applicable requirement listed above, per source tests conducted in March and June 2007 for the IC engines.

2. Yes No Are you currently in compliance as indicated by the most recent monitoring measurement or observation as described above?

3. Please indicate if compliance during the reporting period was continuous or intermittent:

- Continuous – All monitoring measurements show compliance with the Part 70 permit condition
 Intermittent – One or more measurements indicate a failure to meet the Part 70 permit condition

4. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any excursions, if applicable? An *excursion* is defined as “a departure from an indicator or surrogate parameter range established for monitoring under the applicable requirement or Part 70 permit condition, consistent with any averaging period specified for averaging the results of the monitoring.”

5. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any exceedances, if applicable? An *exceedance* is defined as “a condition that is detected by monitoring that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) are greater than the applicable emission limitation or standard (or less than the applicable standard in the case of percent reduction requirement) consistent with any averaging period specified for averaging the results of the monitoring.”

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment
Form TVPF46/07-21-03 Page 2 of 2

6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.
8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

 01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment
Form TVPF46/07-21-03 Page 2 of 2

6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.
8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment

Form TVPF46/07-21-03 Page 1 of 2

Applicable Requirement or Part 70 Permit Condition

Citation, Including Attachment Number and/or Permit Condition Number: PO01395PC3 – Condition No.4	Description: Source test report and submittal requirement
--	--

Attach to this form any information specifically required to be submitted with the compliance certification in the applicable requirement or Part 70 permit condition.

1. Please indicate the method(s) that you use for determining compliance. Indicate the frequency of monitoring and indicate the source test reference method, if applicable.

The site is in compliance with the applicable requirement listed above, per source tests reports summarizing March and June 2007 tests results for the IC engines. The source tests reports were submitted to the District within the required time frame.

1. Yes No Are you currently in compliance as indicated by the most recent monitoring measurement or observation as described above?
2. Please indicate if compliance during the reporting period was continuous or intermittent:
 Continuous – All monitoring measurements show compliance with the Part 70 permit condition
 Intermittent – One or more measurements indicate a failure to meet the Part 70 permit condition
4. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any excursions, if applicable? An *excursion* is defined as “a departure from an indicator or surrogate parameter range established for monitoring under the applicable requirement or Part 70 permit condition, consistent with any averaging period specified for averaging the results of the monitoring.”
5. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any exceedances, if applicable? An *exceedance* is defined as “a condition that is detected by monitoring that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) are greater than the applicable emission limitation or standard (or less than the applicable standard in the case of percent reduction requirement) consistent with any averaging period specified for averaging the results of the monitoring.”

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment
Form TVPF46/07-21-03 Page 2 of 2

6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.
8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

 01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment
Form TVPF46/07-21-03 Page 1 of 2

Applicable Requirement or Part 70 Permit Condition

Citation, Including Attachment Number and/or Permit Condition Number: PO01395PC3 – Condition No.5	Description: Engine Inspection Plan pursuant to Rule 74.9C
--	---

Attach to this form any information specifically required to be submitted with the compliance certification in the applicable requirement or Part 70 permit condition.

1. Please indicate the method(s) that you use for determining compliance. Indicate the frequency of monitoring and indicate the source test reference method, if applicable.

The LFGTE facility maintains an Engine Inspection Plan and performs quarterly (or every 2,000 hours of operation) inspections. Emission screening using a portable analyzer was performed in accordance with the Engine Inspection Plan. Please note that the source tests conducted in March 2007 were considered the inspection for the First Quarter 2007. However, Engine No. 2 malfunctioned on the day of the test and was offline until June 2007 at which time the source test and an inspection was conducted.

The screenings performed in all quarters were in compliance with BACT and District Rule 74.9. Annual IC engines emission inspection information are provided in Appendix B.

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment

Form TVPF46/07-21-03 Page 2 of 2

2. Yes No Are you currently in compliance as indicated by the most recent monitoring measurement or observation as described above?
3. Please indicate if compliance during the reporting period was continuous or intermittent:
- Continuous – All monitoring measurements show compliance with the Part 70 permit condition
 Intermittent – One or more measurements indicate a failure to meet the Part 70 permit condition
4. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any excursions, if applicable? An excursion is defined as “a departure from an indicator or surrogate parameter range established for monitoring under the applicable requirement or Part 70 permit condition, consistent with any averaging period specified for averaging the results of the monitoring.”
5. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any exceedances, if applicable? An *exceedance* is defined as “a condition that is detected by monitoring that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) are greater than the applicable emission limitation or standard (or less than the applicable standard in the case of percent reduction requirement) consistent with any averaging period specified for averaging the results of the monitoring.”
6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered “yes” to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.
8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
 Applicable Requirement or Part 70 Permit Condition Attachment
 Form TVPF46/07-21-03 Page 1 of 2

Applicable Requirement or Part 70 Permit Condition

Citation, Including Attachment Number and/or Permit Condition Number: PO01395PC3 – Condition No.6	Description: Record keeping requirements for engine emission inspection pursuant to Rule 74.9.E
--	--

Attach to this form any information specifically required to be submitted with the compliance certification in the applicable requirement or Part 70 permit condition.

1. Please indicate the method(s) that you use for determining compliance. Indicate the frequency of monitoring and indicate the source test reference method, if applicable.

The site is in compliance with the applicable requirement listed above by keeping all the emission inspections logs and associated information on file.

1. Yes No Are you currently in compliance as indicated by the most recent monitoring measurement or observation as described above?
2. Please indicate if compliance during the reporting period was continuous or intermittent:
 - Continuous – All monitoring measurements show compliance with the Part 70 permit condition
 - Intermittent – One or more measurements indicate a failure to meet the Part 70 permit condition
4. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any excursions, if applicable? An *excursion* is defined as “a departure from an indicator or surrogate parameter range established for monitoring under the applicable requirement or Part 70 permit condition, consistent with any averaging period specified for averaging the results of the monitoring.”
5. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any exceedances, if applicable? An *exceedance* is defined as “a condition that is detected by monitoring that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) are greater than the applicable emission limitation or standard (or less than the applicable standard in the case of percent reduction requirement) consistent with any averaging period specified for averaging the results of the monitoring.”

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment
Form TVPF46/07-21-03 Page 2 of 2

6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.
8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment

Form TVPF46/07-21-03 Page 1 of 2

Applicable Requirement or Part 70 Permit Condition

Citation, Including Attachment Number and/or Permit Condition Number: PO01395PC3 – Condition No.7	Description: Reporting requirements for engine emission inspection pursuant to Rule 74.9.F
--	---

Attach to this form any information specifically required to be submitted with the compliance certification in the applicable requirement or Part 70 permit condition.

1. Please indicate the method(s) that you use for determining compliance. Indicate the frequency of monitoring and indicate the source test reference method, if applicable.

The site is in compliance with the applicable requirement listed above by providing the engines emission inspections results with the Title V annual certification. The associated information can be found in Appendix B.

2. Yes No Are you currently in compliance as indicated by the most recent monitoring measurement or observation as described above?
3. Please indicate if compliance during the reporting period was continuous or intermittent:
 Continuous – All monitoring measurements show compliance with the Part 70 permit condition
 Intermittent – One or more measurements indicate a failure to meet the Part 70 permit condition
4. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any excursions, if applicable? An *excursion* is defined as “a departure from an indicator or surrogate parameter range established for monitoring under the applicable requirement or Part 70 permit condition, consistent with any averaging period specified for averaging the results of the monitoring.”
5. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any exceedances, if applicable? An *exceedance* is defined as “a condition that is detected by monitoring that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) are greater than the applicable emission limitation or standard (or less than the applicable standard in the case of percent reduction requirement) consistent with any averaging period specified for averaging the results of the monitoring.”

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment

Form TVPF46/07-21-03 Page 2 of 2

6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.
8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

1-3. General Applicable Requirements

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment

Form TVPF46/07-21-03 Page 1 of 2

Applicable Requirement or Part 70 Permit Condition

Citation, Including Attachment Number and/or Permit Condition Number: 50	Description: Opacity requirement
---	---

Attach to this form any information specifically required to be submitted with the compliance certification in the applicable requirement or Part 70 permit condition.

1. Please indicate the method(s) that you use for determining compliance. Indicate the frequency of monitoring and indicate the source test reference method, if applicable.

The site is in compliance with the applicable requirement listed above. Annual survey on emission units was conducted on 1/24/07 and no visible emissions were identified during the survey. The result of the survey is included in Appendix A.

2. Yes No Are you currently in compliance as indicated by the most recent monitoring measurement or observation as described above?
3. Please indicate if compliance during the reporting period was continuous or intermittent:
- Continuous – All monitoring measurements show compliance with the Part 70 permit condition
 Intermittent – One or more measurements indicate a failure to meet the Part 70 permit condition
4. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any excursions, if applicable? An *excursion* is defined as “a departure from an indicator or surrogate parameter range established for monitoring under the applicable requirement or Part 70 permit condition, consistent with any averaging period specified for averaging the results of the monitoring.”
5. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any exceedances, if applicable? An *exceedance* is defined as “a condition that is detected by monitoring that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) are greater than the applicable emission limitation or standard (or less than the applicable standard in the case of percent reduction requirement) consistent with any averaging period specified for averaging the results of the monitoring.”

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment
Form TVPF46/07-21-03 Page 2 of 2

6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.
8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment

Form TVPF46/07-21-03 Page 1 of 2

Applicable Requirement or Part 70 Permit Condition

Citation, Including Attachment Number and/or Permit Condition Number: 52	Description: Particulate matter (PM) emission requirement
---	--

Attach to this form any information specifically required to be submitted with the compliance certification in the applicable requirement or Part 70 permit condition.

1. Please indicate the method(s) that you use for determining compliance. Indicate the frequency of monitoring and indicate the source test reference method, if applicable.

The site is in compliance with the applicable requirement listed above, per District analysis of Rule 52 compliance based on EPA PM emission factor.

2. Yes No Are you currently in compliance as indicated by the most recent monitoring measurement or observation as described above?
3. Please indicate if compliance during the reporting period was continuous or intermittent:
 Continuous – All monitoring measurements show compliance with the Part 70 permit condition
 Intermittent – One or more measurements indicate a failure to meet the Part 70 permit condition
4. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any excursions, if applicable? An *excursion* is defined as “a departure from an indicator or surrogate parameter range established for monitoring under the applicable requirement or Part 70 permit condition, consistent with any averaging period specified for averaging the results of the monitoring.”
5. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any exceedances, if applicable? An *exceedance* is defined as “a condition that is detected by monitoring that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) are greater than the applicable emission limitation or standard (or less than the applicable standard in the case of percent reduction requirement) consistent with any averaging period specified for averaging the results of the monitoring.”

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment

Form TVPF46/07-21-03 Page 2 of 2

6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.
8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
 Applicable Requirement or Part 70 Permit Condition Attachment
 Form TVPF46/07-21-03 Page 1 of 2

Applicable Requirement or Part 70 Permit Condition

Citation, Including Attachment Number and/or Permit Condition Number:	Description:
54.B.1	Sulfur compounds emission requirement

Attach to this form any information specifically required to be submitted with the compliance certification in the applicable requirement or Part 70 permit condition.

1. Please indicate the method(s) that you use for determining compliance. Indicate the frequency of monitoring and indicate the source test reference method, if applicable.

The site is in compliance with the applicable requirement listed above, per compliance with the fuel sulfur content limits of Rule 64.

2. Yes No Are you currently in compliance as indicated by the most recent monitoring measurement or observation as described above?

3. Please indicate if compliance during the reporting period was continuous or intermittent:

- Continuous – All monitoring measurements show compliance with the Part 70 permit condition
 Intermittent – One or more measurements indicate a failure to meet the Part 70 permit condition

4. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any excursions, if applicable? An *excursion* is defined as “a departure from an indicator or surrogate parameter range established for monitoring under the applicable requirement or Part 70 permit condition, consistent with any averaging period specified for averaging the results of the monitoring.”

5. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any exceedances, if applicable? An *exceedance* is defined as “a condition that is detected by monitoring that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) are greater than the applicable emission limitation or standard (or less than the applicable standard in the case of percent reduction requirement) consistent with any averaging period specified for averaging the results of the monitoring.”

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment
Form TVPF46/07-21-03 Page 2 of 2

6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.
8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment

Form TVPF46/07-21-03 Page 1 of 2

Applicable Requirement or Part 70 Permit Condition

Citation, Including Attachment Number and/or Permit Condition Number: 54.B.2	Description: Sulfur dioxide concentration requirement at or beyond property line
---	---

Attach to this form any information specifically required to be submitted with the compliance certification in the applicable requirement or Part 70 permit condition.

1. Please indicate the method(s) that you use for determining compliance. Indicate the frequency of monitoring and indicate the source test reference method, if applicable.

The landfill acknowledged the applicable requirement listed above and will perform associated testing upon District's request.

2. Yes No Are you currently in compliance as indicated by the most recent monitoring measurement or observation as described above?

3. Please indicate if compliance during the reporting period was continuous or intermittent:

- Continuous – All monitoring measurements show compliance with the Part 70 permit condition
 Intermittent – One or more measurements indicate a failure to meet the Part 70 permit condition

4. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any excursions, if applicable? An *excursion* is defined as “a departure from an indicator or surrogate parameter range established for monitoring under the applicable requirement or Part 70 permit condition, consistent with any averaging period specified for averaging the results of the monitoring.”

5. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any exceedances, if applicable? An *exceedance* is defined as “a condition that is detected by monitoring that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) are greater than the applicable emission limitation or standard (or less than the applicable standard in the case of percent reduction requirement) consistent with any averaging period specified for averaging the results of the monitoring.”

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment

Form TVPF46/07-21-03 Page 2 of 2

6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.
8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
 Applicable Requirement or Part 70 Permit Condition Attachment
 Form TVPF46/07-21-03 Page 1 of 2

Applicable Requirement or Part 70 Permit Condition

Citation, Including Attachment Number and/or Permit Condition Number: 57.B	Description: Combustion contaminates discharge requirement
---	---

Attach to this form any information specifically required to be submitted with the compliance certification in the applicable requirement or Part 70 permit condition.

1. Please indicate the method(s) that you use for determining compliance. Indicate the frequency of monitoring and indicate the source test reference method, if applicable.

The site is in compliance with the applicable requirement listed above, per District analysis of Rule 57.B compliance based on EPA PM emission factor.

2. Yes No Are you currently in compliance as indicated by the most recent monitoring measurement or observation as described above?
3. Please indicate if compliance during the reporting period was continuous or intermittent:
 - Continuous – All monitoring measurements show compliance with the Part 70 permit condition
 - Intermittent – One or more measurements indicate a failure to meet the Part 70 permit condition
4. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any excursions, if applicable? An *excursion* is defined as “a departure from an indicator or surrogate parameter range established for monitoring under the applicable requirement or Part 70 permit condition, consistent with any averaging period specified for averaging the results of the monitoring.”
5. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any exceedances, if applicable? An *exceedance* is defined as “a condition that is detected by monitoring that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) are greater than the applicable emission limitation or standard (or less than the applicable standard in the case of percent reduction requirement) consistent with any averaging period specified for averaging the results of the monitoring.”

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment

Form TVPF46/07-21-03 Page 2 of 2

6. Yes No . During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.
8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
 Applicable Requirement or Part 70 Permit Condition Attachment
 Form TVPF46/07-21-03 Page 1 of 2

Applicable Requirement or Part 70 Permit Condition

Citation, Including Attachment Number and/or Permit Condition Number:	Description:
64.B.1	Sulfur content of gaseous fuel requirement

Attach to this form any information specifically required to be submitted with the compliance certification in the applicable requirement or Part 70 permit condition.

- Please indicate the method(s) that you use for determining compliance. Indicate the frequency of monitoring and indicate the source test reference method, if applicable.

The landfill is in compliance with the applicable limit, per review of the sulfur content of LFG analysis result performed during the flare source tests.

- Yes No Are you currently in compliance as indicated by the most recent monitoring measurement or observation as described above?

- Please indicate if compliance during the reporting period was continuous or intermittent:

- Continuous – All monitoring measurements show compliance with the Part 70 permit condition
 Intermittent – One or more measurements indicate a failure to meet the Part 70 permit condition

- Yes No During the time period covered by this compliance certification, does the monitoring data indicate any excursions, if applicable? An *excursion* is defined as “a departure from an indicator or surrogate parameter range established for monitoring under the applicable requirement or Part 70 permit condition, consistent with any averaging period specified for averaging the results of the monitoring.”

- Yes No During the time period covered by this compliance certification, does the monitoring data indicate any exceedances, if applicable? An *exceedance* is defined as “a condition that is detected by monitoring that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) are greater than the applicable emission limitation or standard (or less than the applicable standard in the case of percent reduction requirement) consistent with any averaging period specified for averaging the results of the monitoring.”

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment

Form TVPF46/07-21-03 Page 2 of 2

6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.
8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
 Applicable Requirement or Part 70 Permit Condition Attachment
 Form TVPF46/07-21-03 Page 1 of 2

Applicable Requirement or Part 70 Permit Condition

Citation, Including Attachment Number and/or Permit Condition Number: 64.B.2	Description: Sulfur content of liquid fuel requirement
---	---

Attach to this form any information specifically required to be submitted with the compliance certification in the applicable requirement or Part 70 permit condition.

1. Please indicate the method(s) that you use for determining compliance. Indicate the frequency of monitoring and indicate the source test reference method, if applicable.

The landfill uses CARB certified diesel fuel on the emergency IC engine and is exempt from the certification and testing requirement as specified in Attachment 64.B.2. The fuel is purchased from the local distributor for Shell Oil. Shipping records on each fuel load showing a distillate certification certifying use in California under "CARB Diesel Regulations" are kept on file at the site.

2. Yes No Are you currently in compliance as indicated by the most recent monitoring measurement or observation as described above?
3. Please indicate if compliance during the reporting period was continuous or intermittent:
 - Continuous – All monitoring measurements show compliance with the Part 70 permit condition
 - Intermittent – One or more measurements indicate a failure to meet the Part 70 permit condition
4. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any excursions, if applicable? An *excursion* is defined as "a departure from an indicator or surrogate parameter range established for monitoring under the applicable requirement or Part 70 permit condition, consistent with any averaging period specified for averaging the results of the monitoring."

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment

Form TVPF46/07-21-03 Page 2 of 2

5. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any exceedances, if applicable? An *exceedance* is defined as "a condition that is detected by monitoring that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) are greater than the applicable emission limitation or standard (or less than the applicable standard in the case of percent reduction requirement) consistent with any averaging period specified for averaging the results of the monitoring."
6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.
8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
 Applicable Requirement or Part 70 Permit Condition Attachment
 Form TVPF46/07-21-03 Page 1 of 2

Applicable Requirement or Part 70 Permit Condition

Citation, Including Attachment Number and/or Permit Condition Number: 68	Description: CO emission requirement
---	---

Attach to this form any information specifically required to be submitted with the compliance certification in the applicable requirement or Part 70 permit condition.

- Please indicate the method(s) that you use for determining compliance. Indicate the frequency of monitoring and indicate the source test reference method, if applicable.

The site is in compliance with the applicable requirement listed above, per District analysis of Rule 68 compliance based on EPA CO emission factor.

- Yes No Are you currently in compliance as indicated by the most recent monitoring measurement or observation as described above?
- Please indicate if compliance during the reporting period was continuous or intermittent:
 - Continuous – All monitoring measurements show compliance with the Part 70 permit condition
 - Intermittent – One or more measurements indicate a failure to meet the Part 70 permit condition
- Yes No During the time period covered by this compliance certification, does the monitoring data indicate any excursions, if applicable? An *excursion* is defined as “a departure from an indicator or surrogate parameter range established for monitoring under the applicable requirement or Part 70 permit condition, consistent with any averaging period specified for averaging the results of the monitoring.”
- Yes No During the time period covered by this compliance certification, does the monitoring data indicate any exceedances, if applicable? An *exceedance* is defined as “a condition that is detected by monitoring that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) are greater than the applicable emission limitation or standard (or less than the applicable standard in the case of percent reduction requirement) consistent with any averaging period specified for averaging the results of the monitoring.”

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment

Form TVPF46/07-21-03 Page 2 of 2

6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.
8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment

Form TVPF46/07-21-03 Page 1 of 2

Applicable Requirement or Part 70 Permit Condition

Citation, Including Attachment Number and/or Permit Condition Number: 74.6	Description: Solvent information for surface cleaning and degreasing
---	---

Attach to this form any information specifically required to be submitted with the compliance certification in the applicable requirement or Part 70 permit condition.

1. Please indicate the method(s) that you use for determining compliance. Indicate the frequency of monitoring and indicate the source test reference method, if applicable.

The site is exempt from the solvent requirement and cleaning devices and methods requirements as specified in Rule 74.6.B.1 and B.2, per compliance with the requirements of Rule 74.6.1. The site acknowledged the applicable requirements specified in Rule 74.6.B.3 and B.4 and is in compliance with those practices.

2. Yes No Are you currently in compliance as indicated by the most recent monitoring measurement or observation as described above?
3. Please indicate if compliance during the reporting period was continuous or intermittent:
 Continuous – All monitoring measurements show compliance with the Part 70 permit condition
 Intermittent – One or more measurements indicate a failure to meet the Part 70 permit condition
4. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any excursions, if applicable? An *excursion* is defined as “a departure from an indicator or surrogate parameter range established for monitoring under the applicable requirement or Part 70 permit condition, consistent with any averaging period specified for averaging the results of the monitoring.”

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment

Form TVPF46/07-21-03 Page 2 of 2

5. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any exceedances, if applicable? An *exceedance* is defined as "a condition that is detected by monitoring that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) are greater than the applicable emission limitation or standard (or less than the applicable standard in the case of percent reduction requirement) consistent with any averaging period specified for averaging the results of the monitoring."
6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.
8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment

Form TVPF46/07-21-03 Page 1 of 2

Applicable Requirement or Part 70 Permit Condition

Citation, Including Attachment Number and/or Permit Condition Number: 74.11.1	Description: Large water heater and small boiler requirement
--	---

Attach to this form any information specifically required to be submitted with the compliance certification in the applicable requirement or Part 70 permit condition.

1. Please indicate the method(s) that you use for determining compliance. Indicate the frequency of monitoring and indicate the source test reference method, if applicable.

The landfill does not have any regulated large water heater or small boiler installed onsite prior to the end of the reporting period. The requirements of this attachment did not apply.

2. Yes No Are you currently in compliance as indicated by the most recent monitoring measurement or observation as described above?
3. Please indicate if compliance during the reporting period was continuous or intermittent:
 Continuous – All monitoring measurements show compliance with the Part 70 permit condition
 Intermittent – One or more measurements indicate a failure to meet the Part 70 permit condition
4. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any excursions, if applicable? An *excursion* is defined as “a departure from an indicator or surrogate parameter range established for monitoring under the applicable requirement or Part 70 permit condition, consistent with any averaging period specified for averaging the results of the monitoring.”
5. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any exceedances, if applicable? An *exceedance* is defined as “a condition that is detected by monitoring that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) are greater than the applicable emission limitation or standard (or less than the applicable standard in the case of percent reduction requirement) consistent with any averaging period specified for averaging the results of the monitoring.”

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment
Form TVPF46/07-21-03 Page 2 of 2

6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.
8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

 01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment

Form TVPF46/07-21-03 Page 1 of 2

Applicable Requirement or Part 70 Permit Condition

Citation, Including Attachment Number and/or Permit Condition Number: 74.22	Description: Natural gas-fired fan-type central furnaces requirement
--	---

Attach to this form any information specifically required to be submitted with the compliance certification in the applicable requirement or Part 70 permit condition.

1. Please indicate the method(s) that you use for determining compliance. Indicate the frequency of monitoring and indicate the source test reference method, if applicable.

The landfill does not have any regulated furnaces installed onsite prior to the end of the reporting period. The requirements of this attachment did not apply.

2. Yes No Are you currently in compliance as indicated by the most recent monitoring measurement or observation as described above?
3. Please indicate if compliance during the reporting period was continuous or intermittent:
 Continuous – All monitoring measurements show compliance with the Part 70 permit condition
 Intermittent – One or more measurements indicate a failure to meet the Part 70 permit condition
4. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any excursions, if applicable? An *excursion* is defined as “a departure from an indicator or surrogate parameter range established for monitoring under the applicable requirement or Part 70 permit condition, consistent with any averaging period specified for averaging the results of the monitoring.”
5. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any exceedances, if applicable? An *exceedance* is defined as “a condition that is detected by monitoring that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) are greater than the applicable emission limitation or standard (or less than the applicable standard in the case of percent reduction requirement) consistent with any averaging period specified for averaging the results of the monitoring.”

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment
Form TVPF46/07-21-03 Page 2 of 2

6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.
8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

1-4. General Requirements for Short-Term Activities

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
 Applicable Requirement or Part 70 Permit Condition Attachment
 Form TVPF46/07-21-03 Page 1 of 2

Applicable Requirement or Part 70 Permit Condition

Citation, Including Attachment Number and/or Permit Condition Number: 74.1	Description: Abrasive blasting requirement
---	---

Attach to this form any information specifically required to be submitted with the compliance certification in the applicable requirement or Part 70 permit condition.

1. Please indicate the method(s) that you use for determining compliance. Indicate the frequency of monitoring and indicate the source test reference method, if applicable.

There were no abrasive blasting activities performed on the landfill during the reporting period. The requirements of this attachment did not apply.

2. Yes No Are you currently in compliance as indicated by the most recent monitoring measurement or observation as described above?
3. Please indicate if compliance during the reporting period was continuous or intermittent:
 - Continuous – All monitoring measurements show compliance with the Part 70 permit condition
 - Intermittent – One or more measurements indicate a failure to meet the Part 70 permit condition
4. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any excursions, if applicable? An *excursion* is defined as “a departure from an indicator or surrogate parameter range established for monitoring under the applicable requirement or Part 70 permit condition, consistent with any averaging period specified for averaging the results of the monitoring.”
5. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any exceedances, if applicable? An *exceedance* is defined as “a condition that is detected by monitoring that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) are greater than the applicable emission limitation or standard (or less than the applicable standard in the case of percent reduction requirement) consistent with any averaging period specified for averaging the results of the monitoring.”

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment
Form TVPF46/07-21-03 Page 2 of 2

6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.
8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

 01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment

Form TVPF46/07-21-03 Page 1 of 2

Applicable Requirement or Part 70 Permit Condition

Citation, Including Attachment Number and/or Permit Condition Number: 74.2	Description: Architectural coating requirement
---	---

Attach to this form any information specifically required to be submitted with the compliance certification in the applicable requirement or Part 70 permit condition.

1. Please indicate the method(s) that you use for determining compliance. Indicate the frequency of monitoring and indicate the source test reference method, if applicable.

There were no regulated activities performed on the landfill during the reporting period. The requirements of this attachment did not apply.

2. Yes No Are you currently in compliance as indicated by the most recent monitoring measurement or observation as described above?
3. Please indicate if compliance during the reporting period was continuous or intermittent:
 Continuous – All monitoring measurements show compliance with the Part 70 permit condition
 Intermittent – One or more measurements indicate a failure to meet the Part 70 permit condition
4. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any excursions, if applicable? An *excursion* is defined as “a departure from an indicator or surrogate parameter range established for monitoring under the applicable requirement or Part 70 permit condition, consistent with any averaging period specified for averaging the results of the monitoring.”
5. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any exceedances, if applicable? An *exceedance* is defined as “a condition that is detected by monitoring that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) are greater than the applicable emission limitation or standard (or less than the applicable standard in the case of percent reduction requirement) consistent with any averaging period specified for averaging the results of the monitoring.”

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment
Form TVPF46/07-21-03 Page 2 of 2

6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.
8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

 01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
 Applicable Requirement or Part 70 Permit Condition Attachment
 Form TVPF46/07-21-03 Page 1 of 2

Applicable Requirement or Part 70 Permit Condition

Citation, Including Attachment Number and/or Permit Condition Number:	Description:
74.4.D	Cutback asphalt – road oils requirement

Attach to this form any information specifically required to be submitted with the compliance certification in the applicable requirement or Part 70 permit condition.

1. Please indicate the method(s) that you use for determining compliance. Indicate the frequency of monitoring and indicate the source test reference method, if applicable.

There were no regulated activities performed on the landfill during the reporting period. The requirements of this attachment did not apply.

2. Yes No Are you currently in compliance as indicated by the most recent monitoring measurement or observation as described above?
3. Please indicate if compliance during the reporting period was continuous or intermittent:
 - Continuous – All monitoring measurements show compliance with the Part 70 permit condition
 - Intermittent – One or more measurements indicate a failure to meet the Part 70 permit condition
4. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any excursions, if applicable? An *excursion* is defined as “a departure from an indicator or surrogate parameter range established for monitoring under the applicable requirement or Part 70 permit condition, consistent with any averaging period specified for averaging the results of the monitoring.”
5. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any exceedances, if applicable? An *exceedance* is defined as “a condition that is detected by monitoring that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) are greater than the applicable emission limitation or standard (or less than the applicable standard in the case of percent reduction requirement) consistent with any averaging period specified for averaging the results of the monitoring.”

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment
Form TVPF46/07-21-03 Page 2 of 2

6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.
8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment

Form TVPF46/07-21-03 Page 1 of 2

Applicable Requirement or Part 70 Permit Condition

Citation, Including Attachment Number and/or Permit Condition Number: 74.28	Description: Asphalt roofing operations
--	--

Attach to this form any information specifically required to be submitted with the compliance certification in the applicable requirement or Part 70 permit condition.

1. Please indicate the method(s) that you use for determining compliance. Indicate the frequency of monitoring and indicate the source test reference method, if applicable.

There were no regulated activities performed on the landfill during the reporting period. The requirements of this attachment did not apply.

2. Yes No Are you currently in compliance as indicated by the most recent monitoring measurement or observation as described above?
3. Please indicate if compliance during the reporting period was continuous or intermittent:
- Continuous – All monitoring measurements show compliance with the Part 70 permit condition
 Intermittent – One or more measurements indicate a failure to meet the Part 70 permit condition
4. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any excursions, if applicable? An *excursion* is defined as “a departure from an indicator or surrogate parameter range established for monitoring under the applicable requirement or Part 70 permit condition, consistent with any averaging period specified for averaging the results of the monitoring.”
5. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any exceedances, if applicable? An *exceedance* is defined as “a condition that is detected by monitoring that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) are greater than the applicable emission limitation or standard (or less than the applicable standard in the case of percent reduction requirement) consistent with any averaging period specified for averaging the results of the monitoring.”

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment
Form TVPF46/07-21-03 Page 2 of 2

6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.
8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

 01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
 Applicable Requirement or Part 70 Permit Condition Attachment
 Form TVPF46/07-21-03 Page 1 of 2

Applicable Requirement or Part 70 Permit Condition

Citation, Including Attachment Number and/or Permit Condition Number: 74.29	Description: Soil decontamination operations
--	---

Attach to this form any information specifically required to be submitted with the compliance certification in the applicable requirement or Part 70 permit condition.

1. Please indicate the method(s) that you use for determining compliance. Indicate the frequency of monitoring and indicate the source test reference method, if applicable.

There were no regulated activities performed on the landfill during the reporting period. The requirements of this attachment did not apply.

2. Yes No Are you currently in compliance as indicated by the most recent monitoring measurement or observation as described above?

3. Please indicate if compliance during the reporting period was continuous or intermittent:

- Continuous – All monitoring measurements show compliance with the Part 70 permit condition
- Intermittent – One or more measurements indicate a failure to meet the Part 70 permit condition

4. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any excursions, if applicable? An *excursion* is defined as “a departure from an indicator or surrogate parameter range established for monitoring under the applicable requirement or Part 70 permit condition, consistent with any averaging period specified for averaging the results of the monitoring.”

5. Yes No During the time period covered by this compliance certification, does the monitoring data indicate any exceedances, if applicable? An *exceedance* is defined as “a condition that is detected by monitoring that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) are greater than the applicable emission limitation or standard (or less than the applicable standard in the case of percent reduction requirement) consistent with any averaging period specified for averaging the results of the monitoring.”

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment
Form TVPF46/07-21-03 Page 2 of 2

6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.
8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

 01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
 Applicable Requirement or Part 70 Permit Condition Attachment
 Form TVPF46/07-21-03 Page 1 of 2

Applicable Requirement or Part 70 Permit Condition

Citation, Including Attachment Number and/or Permit Condition Number:	Description:
40CFR.61.M	Asbestos demolition or renovation activities

Attach to this form any information specifically required to be submitted with the compliance certification in the applicable requirement or Part 70 permit condition.

- Please indicate the method(s) that you use for determining compliance. Indicate the frequency of monitoring and indicate the source test reference method, if applicable.

There were no regulated activities performed on the landfill during the reporting period. The requirements of this attachment did not apply.

- Yes No Are you currently in compliance as indicated by the most recent monitoring measurement or observation as described above?
- Please indicate if compliance during the reporting period was continuous or intermittent:
 - Continuous – All monitoring measurements show compliance with the Part 70 permit condition
 - Intermittent – One or more measurements indicate a failure to meet the Part 70 permit condition
- Yes No During the time period covered by this compliance certification, does the monitoring data indicate any excursions, if applicable? An *excursion* is defined as “a departure from an indicator or surrogate parameter range established for monitoring under the applicable requirement or Part 70 permit condition, consistent with any averaging period specified for averaging the results of the monitoring.”
- Yes No During the time period covered by this compliance certification, does the monitoring data indicate any exceedances, if applicable? An *exceedance* is defined as “a condition that is detected by monitoring that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) are greater than the applicable emission limitation or standard (or less than the applicable standard in the case of percent reduction requirement) consistent with any averaging period specified for averaging the results of the monitoring.”

Ventura County Air Pollution Control District
COMPLIANCE CERTIFICATION PERMIT FORM
Applicable Requirement or Part 70 Permit Condition Attachment
Form TVPF46/07-21-03 Page 2 of 2

6. Yes No During the time period covered by this compliance certification, do you have any other information or data that indicates that you are not in compliance?
7. If you answered "yes" to Question Nos. 4, 5, or 6 above, please identify all instances of excursions, exceedances, or other indications of non-compliance during the certification period. Attach all relevant information to this form. You may reference deviation reports, by date and subject, previously submitted to the District.
8. If this applicable requirement or Part 70 permit condition requires a source test to demonstrate compliance with a quantifiable emission rate, attach a summary of the most recent source test to this form; or complete and attach Form TVPF47, the quantifiable applicable requirement or Part 70 permit condition attachment.

Time Period Covered by Compliance Certification:

01 / 01 / 2007 (MM/DD/YY) to 12 / 31 / 2007 (MM/DD/YY)

**SECTION 2. QUANTIFIABLE APPLICABLE REQUIREMENT
FORM**

APPENDIX A

**Simi Valley Landfill Annual Emission Certification -
VCAPCD Rule 50: Opacity**

Date of Inspection: 01/24/07 Time: 1:00am

Inspector Name: Bruce Matlock

Emission Unit

Flare Station :

1. Any visible emissions aggregating more than 3 minutes in any 1-hour period?

Yes No N/A Comments

X

Emergency Generator:

1. Any visible emissions aggregating more than 3 minutes in any 1-hour period?

Backup engine not operation at time of certification

X

Deutz Engines:

1. Any visible emissions aggregating more than 3 minutes in any 1-hour period?

Yes No N/A Comments

X

Observations/Comments:

APPENDIX B

