



DEPARTMENT OF THE NAVY  
NAVAL BASE VENTURA COUNTY  
311 MAIN ROAD, SUITE 1  
POINT MUGU, CA 93042-5033

IN REPLY REFER TO

5090  
Ser N0000CV/0322  
March 17, 2015

Mr. Dan Searcy  
Manager Compliance Division  
Ventura County  
Air Pollution Control District  
669 County Square Drive  
Ventura, CA 93003

Ventura County

MAR 17 2015


Air Pollution Control District

Dear Mr. Searcy:

Enclosed are the Annual Compliance Certification documents for Title V Federal Operating Permit (Part 70 Permit) Numbers 00997, 01006, and 01207 issued to the Naval Base Ventura County (NBVC). The enclosed documents provide NBVC's compliance status for the period January 1, 2014 through December 31, 2014.

The enclosed documents are submitted to fulfill the requirements stated in Condition 15, Section 10 of our Part 70 Permits. If you have any questions on the submitted documents, please contact Mr. Hasan Jafar by telephone at (805) 989-3210.

Sincerely,

  
L. R. VASQUEZ  
Captain, U.S. Navy  
Commanding Officer

- Enclosures:
1. Annual Compliance Certification Document for Title V Permit Number 00997
  2. Annual Compliance Certification Document for Title V Permit Number 01006
  3. Annual Compliance Certification Document for Title V Permit Number 01207

**COMPLIANCE CERTIFICATION  
JANUARY 1, 2014 – DECEMBER 31, 2014**

**TITLE V  
FEDERAL OPERATING PERMIT  
PART 70 PERMIT NO. 00997**

**NAVAL BASE VENTURA COUNTY  
POINT MUGU**



*For submittal to:*

Ventura County Air Pollution Control District  
669 County Square Drive  
Ventura, CA 93003

EPA Region IX  
75 Hawthorne St.  
San Francisco, CA 94105

March 16, 2015



**2014 Twelve-Month Rolling Sum Throughput/Usage Report  
Title V Permit 00997**

Title V Description	Annual Throughput Limit	Dec-14	Nov-14	Oct-14	Sep-14	Aug-14	Jul-14	Jun-14	May-14	Apr-14	Mar-14	Feb-14	Jan-14
1,1,1 Trichloroethane @ 1.67 lb/gal	30 Gallons	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Solvents @ 1.67 lb/gal	2,000 Gallons	170.0	170.0	145.0	115.0	115.0	125.0	120.0	130.0	145.0	155.0	140.0	140.0
Adhesives and Sealants @ 2.92 lb/gal	400 Gallons	120.9	121.6	106.9	106.1	98.8	104.8	109.9	112.3	114.1	104.1	102.5	104.1
Adhesives and Sealants @ 7.5 lb/gal	200 Gallons	92.7	89.0	85.4	86.1	84.7	82.0	74.8	76.4	77.1	77.4	68.8	66.9
<b>Surface Coating Operations, Metal Parts, Mob. Equip, Automotive</b>													
Coatings @ 2.8 lb/gal	1,016 Gallons	7.6	7.4	7.0	5.1	4.6	2.9	5.4	8.9	9.1	9.1	9.1	9.1
Coatings @ 3.5 lb/gal	400 Gallons	2.3	1.8	2.3	2.3	2.3	1.0	1.7	3.5	3.5	3.5	3.5	3.5
Coatings @ 4.34 lb/gal	140 Gallons	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Solvents @ 7.4 lb/gal	118 Gallons	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Solvents @ 0.58 lb/gal	146 Gallons	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Solvents @ 1.67 lb/gal	112 Gallons	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
<b>Surface Coating Operations, Architectural</b>													
Coatings @ 3.5 lb/gal	1,864 Gallons	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Solvents @ 7.4 lb/gal	1,000 Gallons	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
<b>Powder Coating Operation</b>													
Powder Coating Booth	3,600 Lbs	175.0	175.0	178.0	143.0	113.0	103.0	118.0	128.0	108.0	123.0	113.0	98.0
NG Fired Burn Off Oven	1,135 Hours	2.1	2.1	2.1	0.2	0.2	0.2	0.2	0.0	0.0	0.0	0.0	0.0
<b>Abrasive Blasting Operation</b>													
Blast Cabinet	2 Tons	0.9	0.8	0.8	0.5	0.4	0.3	0.3	0.2	0.2	0.1	0.1	0.0
<b>Degreasing Operations</b>													
Degreasing Tanks	200 Gallons	0.0	0.0	180.0	180.0	180.0	180.0	180.0	180.0	180.0	180.0	180.0	180.0
Wipe Cleaning	385 Gallons	242.6	226.1	212.0	154.5	123.6	128.9	171.9	234.8	231.7	232.5	195.5	129.5
1,1,1 Trichloroethane & Trichlorofluoroethane	100 Gallons	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
<b>Gasoline Fuelling Operations</b>													
Fuel Farm/Government Gas Station Throughput	400,000 Gallons	143,349	143,955	144,819	146,701	146,193	146,526	146,331	147,188	148,321	148,483	149,241	147,606
Fuel Farm/Government Gas Station Vehicle Fueling Operation	200,000 Gallons	107,034	107,004	107,690	108,230	107,779	108,000	108,177	108,938	109,625	109,199	109,681	109,289
NEX Gas Station Throughput	1,800,000 Gallons	1,296,980	1,296,022	1,291,419	1,282,818	1,272,343	1,256,397	1,246,800	1,232,928	1,221,788	1,208,707	1,197,263	1,195,383

**2014 Twelve-Month Rolling Sum Throughput/Usage Report  
Title V Permit 00997**

Title V Description	Annual Throughput Limit	Dec-14	Nov-14	Oct-14	Sep-14	Aug-14	Jul-14	Jun-14	May-14	Apr-14	Mar-14	Feb-14	Jan-14
<b>Emergency Generators</b>													
Operated for maintenance purposes													
Building Number:													
1	50 Hours	6.2	6.7	6.7	3.7	3.7	4.2	4.0	4.0	4.2	4.2	3.9	3.6
13	20 Hours	4.9	5.4	8.5	7.4	7.4	7.4	7.1	6.6	6.3	6.0	5.5	5.2
14	20 Hours	1.5	1.5	1.5	1.5	2.0	2.5	2.5	3.0	3.0	3.2	2.7	2.2
3008 - Out of Service	20 Hours	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3015	20 Hours	4.6	5.0	5.0	5.0	5.1	4.6	4.1	3.6	3.1	2.6	2.1	1.6
303 - Removed	20 Hours	0.0	0.0	0.0	0.0	0.0	5.5	5.5	12.5	12.2	12.2	11.7	11.7
303- New	50 Hours	7.0	7.0	7.0	7.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
323	50 Hours	0.8	0.8	1.4	2.7	2.7	3.3	3.9	20.1	20.3	21.1	21.1	21.1
322	20 Hours	3.6	3.9	4.2	4.1	3.5	2.8	2.3	1.8	1.8	1.7	1.0	0.9
355	50 Hours	12.8	12.8	12.8	12.3	12.3	12.8	12.3	27.4	27.1	18.3	18.3	26.9
359	50 Hours	4.5	5.0	5.0	5.0	4.8	4.8	4.3	19.2	18.9	18.8	18.3	18.0
369	20 Hours	4.0	4.0	4.0	4.5	4.0	4.0	4.2	11.1	10.9	10.4	9.9	9.4
50	50 Hours	13.2	14.3	13.8	14.4	14.4	14.9	14.2	21.4	21.3	21.0	21.3	22.3
531	50 Hours	17.0	17.4	17.4	16.9	16.4	16.4	15.9	22.5	10.1	9.6	9.1	8.9
53-2	20 Hours	0.9	0.7	0.7	0.9	0.9	0.9	0.9	9.0	9.0	9.0	9.0	9.0
58	20 Hours	5.0	5.5	5.5	5.5	5.5	5.6	5.1	12.8	12.5	12.2	11.7	11.2
63	50 Hours	25.1	25.1	25.1	25.1	25.1	25.6	25.6	25.1	25.1	25.1	23.1	23.1
64	50 Hours	4.5	5.0	5.0	5.0	5.1	5.1	5.1	5.1	4.8	5.0	4.5	4.0
67	20 Hours	4.0	4.0	4.0	4.0	4.5	5.0	5.0	5.0	4.7	4.3	3.6	2.9
674	50 Hours	26.6	26.6	26.1	26.1	26.1	26.6	26.6	33.4	33.4	33.4	31.4	31.3
812	30 Hours	16.7	17.2	17.2	17.7	17.2	17.3	17.3	24.8	12.3	11.8	11.3	11.0
905 - Out of Service	20 Hours	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
916 - Out of Service	20 Hours	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
93	20 Hours	1.9	1.9	1.4	2.4	2.4	2.5	3.0	3.5	3.2	3.2	3.2	3.2
99	20 Hours	1.7	1.7	2.2	2.7	2.2	2.7	3.2	3.7	3.8	3.8	3.6	3.6
Radar System	50 Hours	5.9	6.7	6.9	7.4	7.4	13.6	13.1	13.1	16.3	16.0	14.7	13.1



Ventura County  
Air Pollution  
Control District

**ANNUAL COMPLIANCE CERTIFICATION  
SIGNATURE COVER FORM**

A copy of each Annual Compliance Certification shall be submitted to EPA, Region 9, at the following address:

Mr. Gerardo Rios, Chief  
Permits Office (AIR-3)  
Office of Air Division  
EPA Region 9  
75 Hawthorne Street  
San Francisco, CA 94105


Ventura County  
MAR 17 2015  
Air Pollution Control District

**Confidentiality**

All information in a Part 70 permit compliance certification is public information. The Part 70 permit is also public information.

**Certification by Responsible Official**

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in this compliance certification are true, accurate, and complete.

<p>Signature and Title of Responsible Official:</p>  <p>Title: Lawrence R. Vasquez, Captain, U.S. Navy Commanding Officer, Naval Base Ventura County</p>	<p>Date:</p> <p>3-17-15</p>
-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-----------------------------

<p>Time Period Covered by Compliance Certification</p> <p>01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)</p>
------------------------------------------------------------------------------------------------------------------

**COMPLIANCE CERTIFICATION  
JANUARY 1, 2014 - DECEMBER 31, 2014**

**TITLE V FEDERAL OPERATING PERMIT  
PART 70 PERMIT NO. 00997**

**NAVAL BASE VENTURA COUNTY  
POINT MUGU**



<b>1</b>	<b>COMPLIANCE CERTIFICATION FOR SPECIFIC APPLICABLE REQUIREMENTS</b>	
<b>2</b>	<b>COMPLIANCE CERTIFICATION FOR PERMIT SPECIFIC CONDITIONS</b>	
<b>3</b>	<b>COMPLIANCE CERTIFICATION FOR GENERAL APPLICABLE REQUIREMENTS</b>	
<b>4</b>	<b>COMPLIANCE CERTIFICATION FOR SHORT-TERM ACTIVITIES</b>	
<b>5</b>	<b>COMPLIANCE CERTIFICATION FOR GENERAL PERMIT CONDITIONS</b>	
<b>6</b>	<b>COMPLIANCE CERTIFICATION FOR MISCELLANEOUS FEDERAL PROGRAM CONDITIONS</b>	
<b>7</b>	<b>APPENDIX - A SUPPORTING DOCUMENTATION FOR USE OF CARB-CERTIFIED DIESEL AND SULFUR COMPLIANT JP-8/F-24</b>	
<b>8</b>	<b>APPENDIX - B SOURCE TEST SUMMARY FORMS/RICE NESHAP MAINTENANCE RECORDS</b>	
<b>9</b>	<b>APPENDIX- C FORMAL SURVEYS/ENGINES HOURS OF OPERATION RECORDS</b>	
<b>10</b>	<b>APPENDIX- D GAS STATION VERIFICATION TESTING RESULTS</b>	



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 70N3a- rev531, Condition No. 1</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: General requirements of Rule 70, including requirements for pressure/vacuum relief valves at vent pipes, requirements for bulk transfers, and good operating practices, as applicable to fueling facility at Building 631</p>	<p>Periodic</p>
<p>C. Method of monitoring: All vent pipes are equipped with the appropriate pressure/vacuum relief valve and connected per Condition No.1. Proper operation of valves is verified annually at the time of the static pressure performance test. All bulk transfers utilized the vapor recovery system associated with the permitted loading rack. Good operating practices are ensured through daily inspection of hanging hardware by Supply Department, Fuel Branch and periodic monitoring by the Environmental Division Air Quality Program (EDAQP) staff.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>	

<p>A. Attachment # or Permit Condition #: Attachment 70N3a- rev531, Condition No. 2</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Phase I vapor recovery requirements as applicable to the fueling facility at Building 631</p>	<p>Annual</p>
<p>C. Method of monitoring: Presence of submerged fill pipe in the form of a bottom-fed tank inlet (2.1) is verified at the time of annual inspections. Lack of leaks (2.1 and 2.3) is ensured by annual static pressure performance tests. Presence of CARB-certified Phase I vapor recovery system (2.2 and 2.4) and poppetted dry breaks (2.6) are verified at the time of the annual inspection. Phase I vapor recovery system is operated during all product deliveries.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>	

<p>A. Attachment # or Permit Condition #: Attachment 70N3a- rev531, Condition Nos. 3.1-3.10</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Phase II vapor recovery requirements as applicable to the fueling facility at Building 631</p>	<p>Periodic</p>
<p>C. Method of monitoring: A Hirt Model VCS-200 CARB-certified Phase II vapor recovery systems was installed on 10/6/2009 at Bldg. 631 Fueling Facility in accordance with CARB Exec. Order G-70-139. All equipment is clearly identified, maintained in good working order, absent of leaks, and installed in compliance with permit conditions.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>	





## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 70N3a- rev531, Condition No. 3.11</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Requirement that the hanging hardware on Phase II vapor recovery systems be inspected daily</p>	<p>Daily</p>
<p>C. Method of monitoring: The hanging hardware on Phase II vapor recovery systems is inspected daily by Supply Department, Fuel Branch.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 70N3a- rev531, Condition No. 4</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Requirement that Phase II vapor recovery system at Building 631 Fueling Facility be operated with none of the defects listed in California Code of Regulations Section 94006, Subchapter 8, Chapter 1, Part III, of Title 17, and that defective equipment be tagged "out of order" and not operated per Condition 4.2</p>	<p>Periodic</p>
<p>C. Method of monitoring: Proper ongoing maintenance of the Building 631 Fueling Facility is ensured by the Supply Department, Fuel Branch. Periodic checks for proper station maintenance are conducted by the EDAQP staff. Proper maintenance is also verified at the time of the annual compliance inspection.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 70N3a- rev531, Condition No. 5</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Requirement that proper signs be posted at Building 631 Fueling Facility as listed in Conditions 5.1 through 5.5</p>	<p>Periodic</p>
<p>C. Method of monitoring: Proper ongoing maintenance of the Building 631 Fueling Facility is ensured by Supply Department, Fuel Branch. Periodic checks for proper signage are conducted by the EDAQPs. Proper signage is also verified at the time of the annual compliance inspection. Condition 5.5 is not applicable as all dispensers are used for motor vehicles.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



# ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 70N3a- rev531, Condition No. 6.1</p>	<p>D. Frequency of monitoring:</p> <p>Annual</p>
<p>B. Description:</p> <p>Requirement to perform and pass the 20 minute static pressure test at 2.5 inches water column as outlined in Exhibit 2 of CARB Executive Order G-70-139 every 12 months at Building 631 Fueling Facility</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>The most recent 20 minute static pressure test using CARB Test Procedure TP-201.3b at Building 631 Fueling Facility was performed on 10/16/2014. Facility was found to be in compliance. Appendix D includes the results of the gas station testing during this compliance certification period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 70N3a- rev531, Condition No. 6.2</p>	<p>D. Frequency of monitoring:</p> <p>Annual</p>
<p>B. Description:</p> <p>Requirement to perform a dynamic pressure performance test every 12 months at Building 631 Fueling Facility per California Air Resources Board (CARB) Test Procedure TP-201.4. Also, the requirement to notify the District before the test and submit the results within 14 days after the tests</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>The dynamic pressure performance test using CARB Test Procedure TP-201.4 was performed at Building 631 Fueling Facility on 10/16/2014. Facility was found to be in compliance. Appendix D includes the results of the gas station testing during this compliance certification period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 70N3a- rev531, Condition No. 7.1</p>	<p>D. Frequency of monitoring:</p> <p>Periodic</p>
<p>B. Description:</p> <p>Requirement for the fueling facility at Building 631 to keep records of tests performed on the vapor recovery systems</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>Records of tests of the vapor recovery system at Building 631 Fueling Facility are maintained by the EDAQP.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 70N3a- rev531, Condition No. 7.2</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Requirement for the fueling facility at Building 631 to keep records of all maintenance performed on the vapor recovery systems</p>	<p>Periodic</p>
<p>C. Method of monitoring: Records of all maintenance of the vapor recovery system at fueling facility at Building 631 are maintained by the EDAQP. Records contain the required elements and are reviewed periodically by EDAQP staff.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p>
	<p>G. Compliance Status? (C or I): <u>C</u></p>
	<p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 70N3a- rev531, Condition No. 7.3</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Requirement for the GDF at Building 631 to keep records of daily hanging hardware inspections on phase II vapor recovery systems</p>	<p>Periodic</p>
<p>C. Method of monitoring: Records of all daily hanging hardware inspection are maintained by the Supply Department, Fuel Branch. Records are reviewed periodically by EDAQP staff.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p>
	<p>G. Compliance Status? (C or I): <u>C</u></p>
	<p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 70N3a- rev531, Condition No. 8</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Requirement to submit an application prior to any major modification to the fueling facility at Building 631</p>	<p>As Needed</p>
<p>C. Method of monitoring: No major modifications were made to the fueling facility at Building 631 during the compliance certification period.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p>
	<p>G. Compliance Status? (C or I): <u>C</u></p>
	<p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



# ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 70N3b- 561, Condition No. 1</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: General requirements of Rule 70, including requirements for pressure/vacuum relief valves at vent pipes, minimization of solar gain, bulk transfers, and good operating practices, as applicable to Navy Exchange (NEX) Gas Station</p>	<p>Periodic</p>
<p>C. Method of monitoring: All vent pipes are equipped with the appropriate pressure/vacuum relief valve and connected per Condition No.1. Proper operation of valves is verified annually at the time of the static pressure performance test. All vent piping and manholes are maintained in a color which minimizes solar gain. All bulk transfers utilized a properly operating California Air Resources Board (CARB)-certified vapor recovery system. Good operating practices are ensured by periodic monitoring by Environmental Division Air Quality Program (EDAQP) staff.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>	

<p>A. Attachment # or Permit Condition #: Attachment 70N3b- 561, Condition No. 2</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Phase I vapor recovery requirements as applicable to the NEX Gas Station</p>	<p>Annual</p>
<p>C. Method of monitoring: Presence and length of submerged fill pipe (2.1) are verified at the time of annual inspections. Lack of leaks (2.1 and 2.3) is ensured by annual static pressure performance tests and Phase I Enhanced Vapor Recovery (EVR) testing every three years. Presence of CARB-certified Phase I vapor recovery system (2.2) and poppetted dry breaks (2.5) are verified at the time of the annual inspection. Phase I vapor recovery system is operated during all product deliveries as required by CARB Executive Order G-70-191(2.4).</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>	

<p>A. Attachment # or Permit Condition #: Attachment 70N3b- 561, Condition No. 3</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Phase II vapor recovery requirements as applicable to the NEX Gas Station</p>	<p>Periodic</p>
<p>C. Method of monitoring: A CARB-certified Phase II EVR system including In-Station Diagnostic system was installed on 6/29/2012. The Phase II EVR system is maintained, and operated at the NEX Gas Station in accordance with CARB Exec. Order VR-202. All equipment is clearly identified, maintained in good working order, absent of leaks, and installed in compliance with permit conditions 3.1 - 3.10. A vapor to liquid test was performed and passed on 8/7/2014. Appendix D includes the results of the gas station testing during this compliance certification period.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>	



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 70N3b- 561, Condition Nos. 4.1 and 4.2</p>	<p>D. Frequency of monitoring:  Periodic</p>
<p>B. Description:  Requirement that Phase II vapor recovery systems at NEX Gas Station be operated with none of the defects listed in California Code of Regulations Section 94006, Subchapter 8, Chapter 1, Part III, of Title 17, and that defective equipment be tagged "out of order" and not operated per Condition 4.2</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:  Proper ongoing maintenance of the NEX Gas Station is ensured by Supply Department, Fuel Branch. Periodic checks for proper station maintenance are conducted by the EDAQP staff. Proper maintenance is also verified at the time of the annual compliance inspection.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u>  G. Compliance Status? (C or I): <u>C</u>  H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u>  *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 70N3b- 561, Condition No. 5</p>	<p>D. Frequency of monitoring:  Periodic</p>
<p>B. Description:  Requirement that proper signs be posted at the NEX Gas Station as listed in Conditions 5.1 through 5.5</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:  Proper ongoing maintenance of the NEX Gas Station is ensured by Supply Department, Fuel Branch. Periodic checks for proper signage are conducted by the EDAQP staff. Proper signage is also verified at the time of the annual compliance inspection. Condition 5.5 is not applicable as all dispensers are used for motor vehicles.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u>  G. Compliance Status? (C or I): <u>C</u>  H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u>  *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 70N3b- 561, Condition No. 6.1</p>	<p>D. Frequency of monitoring:  Annual</p>
<p>B. Description:  Requirement to perform and pass "Determination of 2 Inch WC Static Pressure Performance of Vapor Recovery Systems of Dispensing Facilities" test every 12 months at the NEX Gas Station</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:  The most recent test using CARB Test Procedure TP-201.3 at the NEX Gas Station was performed upon startup on 8/7/2014. The Facility was found to be in compliance. Appendix D includes the results of the gas station testing during this compliance certification period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u>  G. Compliance Status? (C or I): <u>C</u>  H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u>  *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 70N3b- 561, Condition No. 6.2</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Requirement to perform "Determination of Static Pressure Performance of the Healy Clean Air Separator" test every 12 months at the NEX Gas Station</p>	<p>Annual</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: The most recent test was performed according to Exhibit 4 of Executive Order VR-202-N upon startup on 8/7/2014. The Facility was found to be in compliance. . Appendix D includes the results of the gas station testing during this compliance certification period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 70N3b- 561, Condition No. 6.3</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Requirement to perform "Vapor to Liquid Volume Ratio" test every 12 months at the NEX Gas Station</p>	<p>Annual</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: The most recent test was performed according to Exhibit 5 of Executive Order VR-202-N upon startup on 8/7/2014. The Facility was found to be in compliance. . Appendix D includes the results of the gas station testing during this compliance certification period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 70N3b- 561, Condition No. 6.4</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Requirement to perform "Veeder-Root ISD Operability Test Procedure" every 12 months at the NEX Gas Station</p>	<p>Annual</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: The most recent test was performed according to Exhibit 9 of Executive Order VR-202-N upon startup on 8/7/2014. The Facility was found to be in compliance. . Appendix D includes the results of the gas station testing during this compliance certification period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 70N3b- 561, Condition No. 6.5</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Requirement to perform "Nozzle Bag Test Procedure" upon startup at the NEX Gas Station</p>	<p>Annual</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Nozzle Bag Test Procedure was performed according to Exhibit 7 of Executive Order VR-202-N upon startup on 8/8/2012. The Facility was found to be in compliance. Appendix D includes the results of the gas station testing during this compliance certification period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 70N3b- 561, Condition No. 6.6</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Requirement to perform "Dynamic Back Pressure" test every 12 months at the NEX Gas Station at the NEX Gas Station</p>	<p>Annual</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: A Wet (2 gallons per dispenser) Vapor-to-Liquid Volume Ratio Test was performed in place of TP 201.4, Dynamic Backpressure testing upon startup on 8/7/2014. The Facility was found to be in compliance. Appendix D includes the results of the gas station testing during this compliance certification period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 70N3b- 561, Condition No. 6.4</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Requirement to perform the following tests every three years at the NEX Gas Station: TP-201.3, Determination of 2 Inch WC Static Pressure Performance of Vapor Recovery Systems of Dispensing Facilities, TP-201.1B, Static Torque Test, TP-201.1D, Leak Rate of Drop Tube Overfill Prevention Device Test, and if requested by the District TP-201.1E, Leak Rate and Cracking Pressure of pressure/Vacuum Vent Valves Test</p>	<p>Every Three Years</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: The Static Pressure Performance Test (TP-201.3), Static Torque Test (TP-201.1B), Leak Rate of Drop Tube Overfill Prevention Device (TP-201.1D), and Leak Rate and Cracking Pressure of P/V Vent Valve Test (TP-201.1E) were performed at the Navy Exchange Gas Station upon startup on 8/8/2012. The Facility was found to be in compliance.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 70N3b- 561, Condition No. 7.1</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Requirement to keep records of tests performed on the vapor recovery system at NEX Gas Station</p>	<p>Periodic</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Records of tests of the vapor recovery systems at the NEX Gas Station are maintained by the EDAQP.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 70N3b- 561, Condition No. 7.2</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Requirement that a log of all maintenance performed on the vapor recovery system at NEX Gas Station be maintained in chronological order and includes the date, a description and location of any equipment replaced, and a description of the system problem which required repair</p>	<p>Periodic</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Records of all maintenance of the vapor recovery system at the NEX Gas Station are maintained by the station manager. Records contain the required elements and are reviewed periodically by EDAQP staff. These records are available to District personnel upon request.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 70N3b- 561, Condition No. 8</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Requirement to submit an application prior to any major modification to the Navy Exchange Gas Station, conduct and pass all required tests within 45 days after modifying, and submit the test results to the District within 14 days after the tests are conducted</p>	<p>As Needed</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: No major modifications were made to the Navy Exchange Gas Station during the compliance certification period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>





## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 74.6 (2003), Condition No. 1</p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Surface Cleaning and Degreasing -- Solvent ROC and/or Vapor Pressure</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Compliance with ROC and vapor pressure limits is ensured by the fact that all solvents must be approved by Environmental Division Air Quality Program (EDAQP) staff before they can be issued and used by any Naval Base Ventura County (NBVC) entity or tenant organization aboard NBVC.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 74.6 (2003), Condition Nos. 2 through 7</p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Conditions relating to solvent handling procedures</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Compliance with Conditions 2 through 7 of Attachment 74.6 is verified by means of routine surveillance of solvent activities that are carried out by EDAQP staff during routine visits to subject facilities.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 74.6 (2003), Condition No. 8</p>	<p>D. Frequency of monitoring: Routine</p>
<p>B. Description: Equipment and work practice requirements applicable to all cold cleaners (except remote reservoir type) -- Measurement of freeboard height, verification of initial boiling point, ROC content, and ROC composite partial pressure</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Inspection of the cold cleaner at Building 333 was conducted on 12/4/2014. Freeboard heights were found to be greater than 6", and solvents were found to have a vapor pressure less than 2mmHg @ 20 degrees Celsius on all units.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



# ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 74.6 (2003), Condition No. 9</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description:</p> <p>Equipment and work practice standards as applicable to remote reservoir cold cleaners -- Measurement of freeboard height, verification of initial boiling point, ROC content, and ROC composite partial pressure</p>	<p>Routine</p>
<p>C. Method of monitoring:</p> <p>An inspection of four remote reservoir cold cleaner units at Building 311 was conducted on 12/4/2014. A permanent label summarizing the applicable operating requirements was posted. Drain hole area was found to be &lt;15 square inches, freeboard height was found to be greater than 6", and solvent was found to have a vapor pressure less than 2mmHg @ 20 degrees Celsius.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p> <p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 74.6 (2003), Condition No. 10</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description:</p> <p>Conditions related to cold cleaning operation</p>	<p>Periodic</p>
<p>C. Method of monitoring:</p> <p>A permanent label summarizing the applicable operating requirements for cold cleaning operations is posted on each cold cleaner. Also, compliance with Condition 10 of Attachment 74.6 is verified by means of routine surveillance carried out by EDAQP staff during routine visits to subject facilities.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p> <p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 74.6 (2003), Condition Nos. 14 and 15</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description:</p> <p>Recordkeeping requirements associated with surface cleaning and degreasing and routine surveillance to comply with Rule 74.6</p>	<p>Periodic</p>
<p>C. Method of monitoring:</p> <p>Compliance with the requirement to maintain a current material list showing the name, ROC and vapor pressure, and intended uses of each solvent material is accomplished by means of a database that records each issuance of a solvent material to any operation aboard NBVC. For each issuance of material, this database contains a reference to the applicable MSDS sheet. The database also contains references to the recipient of the material, and ultimately to the screening sheet, which is the document that approved the material, and describes all intended uses. In addition, EDAQP staff performs routine inspection of the applicable solvent cleaning activities to ensure compliance with Rule 74.6.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p> <p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 74.9 N6, Condition Nos. 1 and 2</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description:</p> <p>Requirement associated with engines declared exempt from Rule 74.9 based on operation less than 200 hours per year and a limited combined fuel usage of 2,000 gallons per year as described in Table No. 3 of Ventura County Air Pollution Control District Title V Permit 0997</p>	<p>Monthly</p>
<p>C. Method of monitoring:</p> <p>Each of the eight airfield arresting gear engines subject to this requirement is equipped with an operating, non-resettable, elapsed operating hour meter. Hour meters are read on a monthly basis and the total engine operating hours will be submitted to the Ventura County Air Pollution Control District by February 15. No engine exceeded 200 hours of annual operation at any time during the compliance certification period. In addition, fuel usage records are kept on all subject engines as required.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 74.9 N6, Condition Nos. 3 and 4</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description:</p> <p>Requirement that engine operating hours are reported annually. The report must also include engine manufacturer, engine model number, operator identification number, and location. In addition, the specified report must accompany the Annual Compliance Certification.</p>	<p>Annually</p>
<p>C. Method of monitoring:</p> <p>A formatted report detailing engine manufacturer, engine model number, operator identification number, location, and annual operating hours for each engine is included in Appendix-C of this Compliance Certification report as required.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 74.9N7, Condition No. 1</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description:</p> <p>Requirement that emergency standby stationary internal combustion engines shall be operated only during an emergency, or for maintenance operation not to exceed 50 hours per year</p>	<p>Monthly</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>Base-wide Instructions prohibit the use of emergency generators for "non-emergency" purposes. An investigation into the hours of operation of all emergency standby stationary internal combustion engines greater than 50 BHP is performed monthly. Logs maintained at each engine are reviewed regularly. Hour meter readings are recorded before and after each maintenance operation, typically 0.5 hours, once per month. Any additional operation events are readily apparent upon review of the logs. All such events are further investigated to verify that they were the result of an emergency. In addition, Environmental Division Air Quality Program is notified by Public Works of all planned maintenance of the power distribution system and construction of power distribution system prior to the maintenance.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>Y</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 74.9N7, Condition No. 2</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description:</p> <p>Requirement that each emergency standby engine shall be equipped with an operating, non-resettable, elapsed-time hour meter</p>	<p>Monthly</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>All emergency engines are equipped with operating, non-resettable, elapsed-time hour meters.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>Y</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Condition Nos. 3 and 4</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description:</p> <p>Requirement that engine operating hours for maintenance be reported annually. The report must also include engine manufacturer, engine model number, operator identification number, and location. In addition, the specified report must accompany the Annual Compliance Certification</p>	<p>Annually</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>A formatted report detailing engine manufacturer, engine model number, operator identification number, location, and annual maintenance operating hours for each engine is included in Appendix-C of this Compliance Certification report as required.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



Ventura County  
Air Pollution  
Control District

## ANNUAL COMPLIANCE CERTIFICATION DEVIATION SUMMARY FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

A. Attachment # or Permit Condition #:  74.9 N7, Part 70 General	B. Equipment description:  300 BHP Caterpillar Engine, Model 3306BD1,, Serial Number 64Z08034	C. Deviation Period: Date & Time Begin: <u>September 9, 2014</u>  End: <u>October 1, 2014</u> When Discovered: Date & Time  <u>October 1, 2014 at 1000</u>
D. Parameters monitored: Hours of operation	E. Limit: 20 Hrs Operation/Yr for maintenance	F. Actual: 4.9 Hrs
G. Probable Cause of Deviation: The hour meter was wired to the engine "on/off" switch which was inadvertently left in the "on" position. As a result, the hour meter registered 551.8 hours run time despite the fact that the engine did not operate between September 9, 2014 and October 1, 2014.		H. Corrective actions taken: The engine was tagged out of service and breakdown was reported to VCAPCD Breakdown Line. The hour meter rewired to register the run time only when the engine is operating on December 6.



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 74.12N1</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: ROC limits for coatings and solvents, work practice standards, and recordkeeping requirements associated with the coating of metal parts and products</p>	<p>Monthly</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Only the Fleet Readiness Center (FRC) Ground Support Equipment coating operation is authorized to coat metal parts and products. This operation also coats mobile equipment that is subject to Rule 74.18. All coatings, solvent materials, and methods used by this operation are compliant with both 74.12 and 74.18. A current material list showing the name and manufacturer of the components is accomplished by means of a database that records each issuance of a coating and solvent material to FRC. In addition, FRC keeps daily usage record of the type, manufacturer, ROC content, mix ratio, and volume of coatings and submits it to the Environmental Division Air Quality Program on a monthly basis. Acetone is the only solvent is used at FRC for cleanup and cleaning of coating equipment. Routine inspection of coating operations is performed to ensure compliance with all standards.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 74.13N1</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description:</p> <p>ROC limits for coatings, solvents, strippers, sealants and adhesives and vapor pressure limits for solvents, work practice standards, and recordkeeping requirements associated with the coating of aerospace assembly and components</p>	<p>Periodic</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p>N/A</p>
<p>C. Method of monitoring:</p> <p>All materials used in the maintenance of aircraft, including coatings, solvents, sealants, adhesives, and strippers must be approved by Environmental Division Air Quality Program staff to ensure compliance with ROC and vapor pressure limits. Volume of coatings applied and cleanup solvents is compiled from daily entries in logs that are submitted monthly. Volume of adhesives, sealants and associated materials, strippers, corrosion preventive compounds, and specialty coatings is tracked by a database that records all materials issued to the end user. This database is compiled on a monthly basis for reporting purposes. Routine inspections of the coating operations are performed to ensure compliance with all standards.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 74.15N1</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Emissions not to exceed 40 ppmvd NOx or 400 ppmvd CO, as demonstrated by biennial source test report</p>	<p>Biennial</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable CARB Method 100 and EPA Method 19</p>
<p>C. Method of monitoring: The most recent source test of 7.3 MMBTU Hurst Boiler located at Building 36A was conducted on January 26, 2010, and reported NOx, CO, and Stack Gas Oxygen values in accordance with CARB Method 100 and EPA Method 19. Source test results are presented in Appendix B. Building 36A boiler has been out of service during the compliance certification period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>





## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 74.15.1N1</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Emissions not to exceed 30 ppmvd NOx or 400 ppmvd CO, as demonstrated by biennial source test report</p>	<p>Biennial</p>
<p>C. Method of monitoring: The most recent source tests were conducted on the following dates: Boilers 20 and 351, 1/29/14; and Boilers 36 and 355, 1/30/14. All passing tests reported NOx, CO, and Stack Gas Oxygen values in accordance with CARB Method 100 and EPA Method 19. Source test results are presented in Appendix B.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable CARB Method 100 and EPA Method 19</p>
<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>	



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 74.18N1, as applicable to the Fleet Readiness Center (FRC) Ground Support Equipment (GSE) coating operation at Building 319</p>	<p>D. Frequency of monitoring:  Periodic</p>
<p>B. Description:  ROC limits for coatings and solvents, work practice standards and application method requirements, and recordkeeping requirements associated with the coating of motor vehicles and mobile equipment</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:  The FRC coats GES equipment subject to Rule 74.18 and metal parts subject to rule 74.12. All coatings, solvent materials, and methods used by this operation are compliant with both 74.12 and 74.18. A current material list showing the name and manufacturer of the components is accomplished by means of a database that records each issuance of a coating and solvent material to FRC. In addition, FRC keeps daily usage record of the type, manufacturer, ROC content, mix ratio, and volume of coatings and submits it to the Environmental Division Air Quality Program on a monthly basis. Acetone is the only solvent is used at FRC for cleanup and cleaning of coating equipment. Routine inspection of coating operations is performed to ensure compliance with all standards.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u>  *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 74.18N1, as applicable to the Morale Welfare and Recreation (MWR) Auto Hobby Shop (AHS) coating operation at Building 154</p>	<p>D. Frequency of monitoring:  Periodic</p>
<p>B. Description:  ROC limits for coatings and solvents, work practice standards and application equipment requirements, and recordkeeping requirements associated with the coating of motor vehicles and mobile equipment</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:  The AHS paint booth is used by private individuals to coat their personal vehicles. All coatings and solvent materials used must be approved by Air Quality Program personnel prior to receiving authorization to be used in the paint booth. Records showing actual amounts of materials used are submitted to the Hobby Shop by the customer. These records show the type, manufacturer, ROC content, mix ratio, and volume of coatings applied. These records are later submitted to the Air Quality Program and compiled on an annual basis for reporting purposes. Compiled records are capable of showing annual usage over any 12-month period. HVLP guns are the only paint application method. Acetone is the only solvent is approved to be used at FRC for cleanup and cleaning of coating equipment. Routine inspection of the coating activities is performed to ensure compliance with all standards.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u>  *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 74.29N2, Condition Nos.2, 3, and 7</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Requirement to limit the ROC concentration of the Vapor Extraction System to 100 ppmv, measured as methane, and to monitor and record the ROC concentration</p>	<p>N/A</p>
<p>C. Method of monitoring: The Vapor Extraction System at Building 161 was removed from service.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 74.29, Condition Nos. 5 and 7 (Condition Nos. 4 and 6 are not applicable)</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Requirement that the minimum temperature of the catalytic oxidizer be maintained at 650 F by a modulating control system</p>	<p>N/A</p>
<p>C. Method of monitoring: The Vapor Extraction System at Building 161 was removed from service.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



Ventura County  
Air Pollution  
Control District

## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment NESHAP GG</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Requirement to keep records to demonstrate the stationary source is not a major source of HAPs</p>	<p>As Needed</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Hazardous Air Pollutant (HAP) emission calculations were performed to demonstrate that NBVC Point Mugu site is not a major source of HAPs. No changes occurred during 2014 that would have influenced NBVC's HAP status. Documentation of the original HAP calculations is maintained by the NBVC Air Program and is available upon request.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 40CFR63ZZZN3, Condition No. 1</p>	<p>D. Frequency of monitoring:</p> <p>Air cleaner inspection: every 1000 hours of operation or annually, whichever comes first Oil and filter change: every 500 hours of operation or annually, whichever comes first Hoses and belts inspection: every 500 hours of operation or annually, whichever comes first</p>
<p>B. Description:</p> <p>National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (RICE)- Requirements to change filter and oil , and inspect air cleaner, hoses, and belts</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>Naval Base Ventura County has a maintenance plan to ensure compliance with the maintenance requirements of Attachment 40CFR63ZZZN3</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>Y</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 40CFR63ZZZN3, Condition No. 2</p>	<p>D. Frequency of monitoring:</p> <p>Routine</p>
<p>B. Description:</p> <p>Requirement that all existing emergency diesel stationary RICE are operated and maintained according to the manufacture's emission-related written instructions or NVBC plan in a manner to minimize emissions</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>All existing emergency diesel stationary RICE were operated and maintained according to the manufacturer's instructions and RICE NESHAP maintenance requirements during the compliance certification period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 40CFR63ZZZN3, Condition No. 3</p>	<p>D. Frequency of monitoring:</p> <p>Monthly</p>
<p>B. Description:</p> <p>Requirement that existing emergency diesel stationary RICE are equipped with a non-resettable hour meter</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>All existing emergency diesel stationary RICE are equipped with a non-resettable hour meter.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



# ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 40CFR63ZZZN3, Condition No. 4</p>	<p>D. Frequency of monitoring: Routine</p>
<p>B. Description: Requirement that permittee minimize the engine's time spent at idle during startup, not to exceed 30 minutes</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: To conserve resources and reduce emissions, NBVC limits the idling of stationary engines to the period of time required to bring the subject engines to a mechanically optimal operating temperature. In no case do these periods of optimization exceed 30 minutes.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 40CFR63ZZZN3, Condition No. 5(b)</p>	<p>D. Frequency of monitoring: N/A</p>
<p>B. Description: Requirement that existing emergency diesel stationary RICE operations are limited to 100 hours per calendar year for maintenance and testing, emergency demand response, frequency deviation situations, and up to 50 hours per year for non-emergency situations.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Federally enforceable Rule 74.9 limits the maintenance hours of operation to 50 hours per calendar year for the emergency standby stationary internal combustion engines rated at 50 or more horsepower operated at NBVC. In addition, Airborne Toxic Control Measure (ATCM) for stationary compression ignition engines limits the maintenance hours of operation to 20 hours per calendar year for engines installed prior to January 1, 2005 and 50 hours per calendar year for engines installed after January 1, 2005.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 40CFR63ZZZN3, Condition No. 5(c)</p>	<p>D. Frequency of monitoring: N/A</p>
<p>B. Description: Operation of the existing emergency diesel stationary RICE for Peak shaving or non-emergency demand response program</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: None of the existing emergency stationary RICE located at NBVC were operated for peak shaving or non-emergency demand response during the compliance certification period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 40CFR63ZZZN3, Condition No. 6</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Recordkeeping requirements</p>	<p>Monthly</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:  Naval Base Ventura County has developed a maintenance plan to ensure compliance with the maintenance requirements of 40 CFR Part 63, Subpart ZZZZ. The records of maintenance are retained by the Environmental Division Air Quality Program (EDAQP). All stationary emergency RICE at NBVC are equipped with non-resettable hour meters. Hours of maintenance and emergency use are recorded for each engine on a monthly basis by the EDAQP.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 40CFR63ZZZN3, Condition No. 9</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Requirement that on an annual basis, the permitte certify that all engines at the stationary source are operating in compliance with 40 CFR Part 63, Subpart ZZZZ, NESHAP for RICE</p>	<p>N/A</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:  As of 7/24/2014 all engines at NBVC were operated in compliance with 40 CFR Part 63, Subpart ZZZZ, NESHAP for RICE.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>Y</u> *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION DEVIATION SUMMARY FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #:  40CFR63ZZZN3, Part 70 General</p>	<p>B. Equipment description:  300 BHP Caterpillar Engine Located at Building PM-13, 103 BHP Caterpillar Engine Located at Building PM-67, 290 BHP John Deere Engine Located at Building LP-93, 343 BHP Caterpillar Engine Located at Building LP-99, and 196 BHP General Motors Engine Located at Building PM-323</p>	<p>C. Deviation Period: Date &amp; Time Begin: <u>May 4, 2014</u>  End: <u>July 24, 2014</u> When Discovered: Date &amp; Time <u>May 4, 2014</u></p>
<p>D. Parameters monitored: Annual filter and oil change, or passing oil analysis</p>	<p>E. Limit: 500 hours of operation or annual</p>	<p>F. Actual: Annual + 27 days to 80 days</p>
<p>G. Probable Cause of Deviation: Logistical difficulty, difficulty scheduling personnel, difficulty scheduling security escort, delays in material shipment, and misplaced analytical samples</p>		<p>H. Corrective actions taken: Advanced planning for maintenance activities, earlier sampling of oil for analysis to allow for resampling in case of sample misplacement by lab</p>

<p>A. Attachment # or Permit Condition #:  40CFR63ZZZN3, Part 70 General</p>	<p>B. Equipment description:  343 BHP Caterpillar Engine Located at Building LP-99,</p>	<p>C. Deviation Period: Date &amp; Time Begin: <u>May 4, 2014</u>  End: <u>May 30, 2014</u> When Discovered: Date &amp; Time <u>May 4, 2014</u></p>
<p>D. Parameters monitored: Annual air cleaner, hoses and belts inspection</p>	<p>E. Limit: 1000 hours of operation or annual for air cleaner, and 500 hours of operation or annual for hoses and belts</p>	<p>F. Actual: Annual + 27 days</p>
<p>G. Probable Cause of Deviation: Difficulty scheduling security escort</p>		<p>H. Corrective actions taken: Advanced planning for scheduling security escort</p>





## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 40CFR60IIIIN1, Condition No. 1</p>	<p>D. Frequency of monitoring:  Per Event</p>
<p>B. Description:  Requirement that stationary compression ignition engines which are 2007 model or later, are used for emergency purposes, and have an engine displacement of less than 10 liters per cylinder comply with the certification emission standards for new nonroad compression ignition engines for the same model year and maximum engine power found in 40 CFR 89.112 and 40 CFR 89.113.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:  Environmental Division Air Quality Program staff review and verify the California Air Resources Board (CARB) and Environmental Protection Agency emission certification for the new stationary compression ignition internal combustion engine prior to purchasing and installing the engine. In addition, VCAPCD Rule 26.2 has required Best Available Control Technology (BACT) for all new emissions units. Therefore, all new emergency diesel engines installed and permitted in Ventura County after 2007 are in compliance with this requirement because the BACT requirements are at least as stringent as the engine standards of 40 CFR 89.112 and 40 CFR 89.113.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u>  *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 40CFR60IIIIN1, Condition No. 2</p>	<p>D. Frequency of monitoring:  Periodic</p>
<p>B. Description:  Requirement to use CARB diesel fuel in stationary compression ignition emergency engines</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:  All diesel fuel combusted in stationary emergency engines at Naval Base Ventura County (NBVC) during the compliance period was supplied by the NBVC Supply Department, Fuel Branch. All diesel fuel received by the Supply Department, Fuel Branch, is CARB certified. Data demonstrating the use of CARB-certified fuel is provided in Appendix A.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u>  *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment ATCM Engine N1</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Non-federally enforceable requirement to use only California Air Resources Board (CARB) diesel fuel in stationary CI engines that drive fire pump assemblies(1), keep a monthly log of each engine's hours of operation(2), and provide documentation supporting CARB fuel usage(3)</p>	<p>Periodic</p>
<p>C. Method of monitoring: Building 916 fire pump assembly engine was out of service during this compliance calendar.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *if yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment ATCM Engine N2, Condition Nos. 1 and 3c</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description:</p> <p>Non-federally enforceable requirement to use only California Air Resources Board (CARB) diesel fuel in emergency standby stationary CI engines(1) and provide documentation supporting such use(3c)</p>	<p>Periodic</p>
<p>C. Method of monitoring:</p> <p>All diesel fuel combusted in stationary emergency standby engines at Naval Base Ventura County (NBVC) during the compliance period was supplied by the NBVC Supply Department, Fuel Branch. All diesel fuel received by the Supply Department, Fuel Branch, is CARB certified. Data demonstrating the use of CARB-Certified fuel is provided in Appendix A.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment ATCM Engine N2, Condition No. 2 and 3(a&amp;b)</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description:</p> <p>Non-federally enforceable requirement that as of January 1, 2006, annual hours of operation for maintenance and testing of the emergency engine(s) not to exceed 20 hours per year. Also, requirement to equip engine(s) with a non-resettable hour meter and maintain a log that differentiates operation during maintenance and testing from emergency use. In addition, the operational hours of each engine shall be summarized by use (emergency or maintenance/testing) on a monthly basis and compiled into a 12-month rolling-sum report</p>	<p>Periodic</p>
<p>C. Method of monitoring:</p> <p>All stationary emergency standby engines at NBVC are equipped with non-resettable hour meters. Hours of maintenance and emergency use are recorded for each engine on a monthly basis and summarized into 12-month rolling-sum reports as required.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment ATCM Engine N5, Condition Nos. 1 and 4.c</p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Non-federally enforceable requirement to use only California Air Resources Board (CARB) diesel fuel in emergency standby stationary Compression Ignition (CI) engines installed after January 1, 2005 (1) and provide documentation supporting such use(4)</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: All diesel fuel combusted in stationary emergency standby engines installed after January 1, 2005 was supplied by the Naval Base Ventura County (NBVC) Supply Department, Fuel Branch. All diesel fuel received by the Supply Department, Fuel Branch, is CARB certified. Data demonstrating the use of CARB-Certified fuel is provided in Appendix A.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment ATCM Engine N5, Conditions No. 2, 4.a, and 4.b</p>	<p>D. Frequency of monitoring: Monthly</p>
<p>B. Description: Non-federally enforceable requirement to equip emergency standby stationary CI engines installed after January 1, 2005 with hour meters and limit the number of hours these engines are operated for maintenance and testing to no more than 50 hours during any 12-month period. In addition, the operational hours of each engine shall be summarized by use (emergency or maintenance/testing) on a monthly basis and compiled into a 12-month rolling-sum report. Also, When not being operated for maintenance or testing, the emergency engine(s) are used only for "emergency use".</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: All stationary emergency standby engines installed after January 1, 2005 at NBVC are equipped with non-resettable hour meters. Hours of maintenance and emergency use are recorded for each engine on a monthly basis and summarized into 12-month rolling-sum reports as required.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment ATCM Engine N5, Condition No.3</p>	<p>D. Frequency of monitoring: Ensured at ATC application submittal</p>
<p>B. Description: Non-federally enforceable requirement that all emergency standby stationary CI engines installed after January 1, 2005 be EPA/CARB certified to meet the particulate matter standard of 0.15 grams/BHP-hr</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: All stationary emergency standby engines installed after January 1, 2005 at NBVC are CARB certified as required. Certification documents are available upon request.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



# ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment ATCM Portable Engine Condition No. <u>1</u></p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Non-federally enforceable requirement to use only California Air Resources Board (CARB) diesel fuel in portable diesel engines</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: All diesel fuel combusted in portable diesel engines at Naval Base Ventura County (NBVC) during the compliance period was supplied by the NBVC Supply Department, Fuel Branch. All diesel fuel received by the Supply Department, Fuel Branch, is CARB certified. Data demonstrating the use of CARB-Certified fuel is provided in Appendix A.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment ATCM Portable Engine Condition No. <u>2</u></p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Non-federally enforceable requirement that all portable diesel-fueled engines permitted prior to January 1, 2010 be certified to meet federal or California standard for newly manufactured engines</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: All portable diesel-fueled engines permitted prior to January 1, 2010 at NBVC meet federal or California standard for newly manufactured engines. All Tier zero portable diesel-fueled engines owned by NBVC were removed from service before January 1, 2010.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment ATCM Portable Engine Condition No. <u>3</u></p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Non-federally enforceable requirement that all portable diesel-fueled engines permitted on or after January 1, 2010 be certified to the most stringent standards contained in the federal or California emission standards for nonroad engines</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: All portable diesel-fueled engines permitted on or after January 1, 2010 at NBVC are certified to the most stringent standards contained in the federal or California emission standards for nonroad engines.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment ATCM Portable Engine Condition No. 4</p>	<p>D. Frequency of monitoring:</p> <p>Periodic</p>
<p>B. Description:</p> <p>Non-federally enforceable requirement that the weighted average particulate matter emission rate for the fleet of portable diesel engines shall not exceed the standards specified at Section 93116.3(c), Title 17, California Code of Regulations</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>The fleet average was calculated for January 1, 2013 regulatory compliance deadline as required in Section 93116.3 (d) and it was determined that the weighted average particulate matter emission rate did not exceed the standards specified at Section 93116.3(c) during the compliance certification period. The fleet average will be re-evaluated again for January 1, 2017 regulatory compliance deadline.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>



# ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment CARB Truck &amp; Bus, Condition No.1</p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Non-federally enforceable requirement that all sweeper vehicle auxiliary engines be operated with the applicable requirements of CARB Regulation to reduce emissions from in-use heavy-duty diesel-fueled vehicles</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: All portable diesel sweeper engines operate at NBVC are in compliance with the applicable requirements of CARB "Regulation to Reduce Emission of Diesel Particulate Matter, NOx, and Other Pollutants from In-Use Heavy-Duty Diesel-Fueled Vehicles".</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment CARB Truck &amp; Bus, Condition No. 2</p>	<p>D. Frequency of monitoring: Per case</p>
<p>B. Description: Non-federally enforceable requirement that sweeper vehicle auxiliary engines be equipped with an original equipment manufacturer (OEM) diesel particulate filter starting January 1, 2020</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment CARB Truck &amp; Bus, Condition No.3</p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Non-federally enforceable requirement to maintain records of sweeper drive engine miles traveled per calendar year</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Records of sweepers drive engine miles traveled per calendar year is maintained by the Environmental Division Air Quality Program.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment CARB Truck &amp; Bus, Condition No. 4</p>	<p>D. Frequency of monitoring:</p> <p>Periodic</p>
<p>B. Description:</p> <p>Non-federally enforceable requirement to submit an Authority to Construct application to install a OEM diesel particulate filter for each sweeper vehicle auxiliary engine prior to July 2019</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p>N/A</p>
<p>C. Method of monitoring:</p> <p>No OEM diesel particulate filter was installed during this compliance certification period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>





## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC1, Condition No. 1</p>	<p>D. Frequency of monitoring: Monthly</p>
<p>B. Description: Requirement to keep monthly records of throughput/usage for all operations listed in Table 3 of Permit 0997. On an ongoing basis, monthly usage for each operation is to be summed for the previous 12 months, and the totals reported</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Applicable data are gathered each month and entered into a database. For each throughput/usage limit, data are compiled to determine the throughput/usage for each month. Monthly data are then summed for each period of 12 consecutive months. These 12-month rolling sums are reported.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC1, Condition No. 2</p>	<p>D. Frequency of monitoring: Monthly</p>
<p>B. Description: Non-federally enforceable requirement for solvent cleaning activities, requirement to keep records of solvents purchased and disposed</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Records of solvents purchased are extracted from a database called Enterprise Resources Planning (ERP), which keeps a record each time a hazardous material is issued to the end user. Some data as to solvents disposed is gathered from a database called HWDS. There are not always records of solvents disposed, and in such cases, the solvents are conservatively assumed to have evaporated, and are reported as such.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC1, Condition No. 3</p>	<p>D. Frequency of monitoring: Annual</p>
<p>B. Description: Requirement that all State-registered portable equipment comply with State registration requirements, and that a copy of State registration be available</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: All equipment registered by Naval Base Ventura County under the CARB's Portable Equipment Registration Program is military tactical support equipment, for which there are very few requirements. The only requirement is to provide data as to the number of each type of units kept at the installation, along with a description, and to pay the appropriate fees. There is no need to record hours of operation, or even serial numbers of individual units, and there is no need to post a copy of the certification on each equipment unit. Required data are kept on file at the Environmental Division Air Quality Program office.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC2-rev501,531,551, Condition No. 1</p>	<p>D. Frequency of monitoring:</p> <p>Annually</p>
<p>B. Description:</p> <p>Non-Federally enforceable requirement that all space heaters and boilers listed in Table 2, Section 2 of the Title V permit are operated on Public Utilities Commission-regulated natural gas only</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>All space heaters and boilers listed in Table 2, Section 2 of the Title V permit are operated on PUC natural gas.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC2-rev rev501,531,551, Condition No. 2</p>	<p>D. Frequency of monitoring:</p> <p>Monthly</p>
<p>B. Description:</p> <p>A limit on the total natural gas usage for two Ajax boilers (at Buildings 20, and 36) of 37.7 MMCF per year</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>Boiler gas meter readings are taken each month. These readings are compiled into reports that express gas usage on a monthly basis and usage over the preceding 12 months. Reports were generated for each of the twelve 12-month periods that ended during the permit term.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC2-rev rev501,531,551, Condition No. 3</p>	<p>D. Frequency of monitoring:</p> <p>Monthly</p>
<p>B. Description:</p> <p>Requirement that flue gas recirculation valves and nozzles on three Hurst boilers are operated at the same setting as when operated during the most recent source test</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>Compliance is demonstrated by verifying, on a monthly basis, that the FGR nozzle position has not been changed, and that the FGR valve (which is closed during the gas purge cycle) opens properly once the boiler is firing.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC2-rev rev501,531,551, Condition No. 4</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description:</p> <p>BACT requirement that NOx emissions from the Hurst boiler at Building 36A not exceed 30 ppmvd as demonstrated by a source test and by maintaining the FGR system</p>	<p>Biennial</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable CARB Method 100 and EPA Method 19</p>
<p>C. Method of monitoring:</p> <p>Boiler 36A was source tested last on January 26, 2010 using CARB Method 100 and EPA Method 19. A satisfactory result was reported to the VCAPCD following the source test. Building 36A boiler is designated as "Out of Service" and did not operate during this compliance certification period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC3-rev611, Condition No. 1</p>	<p>D. Frequency of monitoring: N/A</p>
<p>B. Description: Non-federally enforceable requirement that F-24 fuel consumption in the Portable Engine Test Stands not exceed 14,971 pounds in any one hour</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Maximum hourly fuel consumption by largest engine tested (T56-A-16) is only 2,219 LB/HR.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u>  G. Compliance Status? (C or I): <u>C</u>  H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u>  *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC3-rev611, Condition No. 2</p>	<p>D. Frequency of monitoring: N/A</p>
<p>B. Description: Non-federally enforceable requirement that F-24 fuel consumption in the Target Drone Jet Testing Operation not exceed 4,944 pounds in any one hour</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Compliance is demonstrated by the fact that the largest target drone jet engine operated at Building 393 is only capable of consuming 2,890 pounds of fuel per hour, and the largest engine operated at Building 557 is only capable of consuming 228 pounds of fuel per hour. As neither testing operation is capable of testing more than one engine, the maximum fuel consumption in any one hour is (2890 + 228) = 3,118 pounds per hour.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u>  G. Compliance Status? (C or I): <u>C</u>  H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u>  *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC3-rev611, Condition No.3</p>	<p>D. Frequency of monitoring: N/A</p>
<p>B. Description: Non-federally enforceable requirement that no more than one engine may be tested at Building 393, and no more than one engine be tested at Building 557 at any one time</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Neither the test setup at Building 393 nor the test setup at Building 557 is physically capable of accommodating more than one engine.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u>  G. Compliance Status? (C or I): <u>C</u>  H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u>  *If yes, attach Deviation Summary Form</p>



# ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC3-rev611, Condition No. 4</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Requirement to keep documentation that the fuel sulfur content of F-24 fuel burned in Jet Testing Operations does not exceed 0.3 percent by weight</p>	<p>Periodic</p>
<p>C. Method of monitoring: Fuel samples are taken from the F-24 storage tanks at NBVC fuel farm on a monthly basis and sent to a lab for sulfur analysis. Fuel burned in jet engine testing operations is obtained only from the fuel farm. Fuel sulfur content data are reviewed periodically by Air Quality Program personnel.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p>
	<p>G. Compliance Status? (C or I): <u>C</u></p>
	<p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC3-rev611, Condition No. 5</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Requirement for favorable atmospheric condition and wind direction during testing to assure good dispersion and no particulate fallout over inhabited areas</p>	<p>Periodic</p>
<p>C. Method of monitoring: Routine surveillance by NBVC Environmental staff and other NBVC personnel is sufficient to ensure that operation of the Jet Engine Test Cells do not create a nuisance condition as defined in Rule 51.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p>
	<p>G. Compliance Status? (C or I): <u>C</u></p>
	<p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC3-rev611, Condition No. 6</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Recordkeeping requirements associated with Jet Engine Testing</p>	<p>Daily during operations and Monthly for recordkeeping purposes</p>
<p>C. Method of monitoring: Each time a jet engine is operated, the following information is recorded on a log sheet; Type of engine tested, amount of fuel used, and minutes of operation in each mode. Log sheets are forwarded to Environmental Division Air Quality Program staff on a monthly basis, and are compiled into 12-month cumulative reports and it is verified that usage does not exceed annual limits. Air Quality Program also maintains records of fuel sulfur content.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p>
	<p>G. Compliance Status? (C or I): <u>C</u></p>
	<p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



# ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC4-rev591, Condition No. 1</p>	<p>D. Frequency of monitoring:</p> <p>Periodic</p>
<p>B. Description:</p> <p>Requirement that the sulfur content of distillate fuel burned in portable internal combustion engines shall not exceed 0.05% by weight</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>Compliance with this requirement is demonstrated by the fact that all diesel fuel burned in portable internal combustion engines is supplied by the Naval Base Ventura County (NBVC) Supply Department, Fuel Branch, and that all diesel fuel received by the Supply Department, Fuel Branch is California Air Resources Board (CARB) certified. Please see Appendix A for fuel purchase documentation.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC4-rev591, Condition No. 2, as applicable to individual engines with limits expressed in hours per year</p>	<p>D. Frequency of monitoring:</p> <p>Monthly</p>
<p>B. Description:</p> <p>Requirement that engine usage be properly recorded and compiled so as to demonstrate compliance with the usage limits of Table 3</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>Each engine is equipped with a properly installed and maintained hour meter. Hour meters of each engine are read on a monthly basis to ensure compliance with rolling-12-month limits. Hours of operation over each of twelve 12-month periods are determined from hour meter readings.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC4-rev591, Condition No. 2, as applicable to runway arresting gear engines</p>	<p>D. Frequency of monitoring:</p> <p>Monthly</p>
<p>B. Description:</p> <p>Requirement that total fuel used by an engine group be properly recorded and compiled so as to demonstrate compliance with the usage limits of Table 3</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>Each time a fuel delivery is made to arresting gear engines, the amount of fuel delivered to all of the engines (not to individual engines) is recorded. Data as to the total amount of fuel delivered are forwarded to the Environmental Division Air Quality Program.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC4-rev491, Condition No. 2, as applicable to engine and engine groups with a limit expressed in brake horsepower hours per year</p>	<p>D. Frequency of monitoring:  Monthly</p>
<p>B. Description:  Requirement that engine usage be properly recorded and compiled so as to demonstrate compliance with the usage limits of Table 3</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:  Each engine is equipped with a properly installed and maintained hour meter. Hour meter of each engine is read on a monthly basis and multiplied by the maximum rated engine brake horsepower. The monthly BHP-Hrs records for all engines in each group are summed for the previous 12 months to ensure compliance with rolling-12-month limits.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC4-rev591, Condition No. 3</p>	<p>D. Frequency of monitoring:  Periodic</p>
<p>B. Description:  Non-federally enforceable requirement that simultaneous power output by portable diesel engines listed on Part 70 Permit #0997 (including diesel engines in the tactical military operation) not exceed 1,393 BHP</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:  The simultaneous power output by portable diesel engines listed on Part 70 Permit #0997 was less than 1,393 BHP.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC4-rev591, Condition No. 4</p>	<p>D. Frequency of monitoring:  Per Operation</p>
<p>B. Description:  Non-federally enforceable requirement that the four 165 BHP and one 315 BHP John Deere portable engines provide power to a) individual buildings housing critical infrastructure during grid maintenance and electrical repair operations, b) provide power during emergency use, and C) maintenance and testing of the engines</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:  Each engine is equipped with a non-resettable hour meter. A log of engine operation which includes usage record and describes the purpose of each engine use is maintained by NBVC Air Quality Program office.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC4-rev591, Condition No. 5</p>	<p>D. Frequency of monitoring:</p> <p>Monthly</p>
<p>B. Description:</p> <p>Non-federally enforceable requirement that a log of engine operation for four 165 BHP and one 315 BHP John Deere portable engines be maintained based on the hour meter reading and describe the purpose of each engine use</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>Each engine is equipped with a non-resettable hour meter. A log of engine operation which includes usage record and describes the purpose of each engine use is maintained by NBVC Air Quality Program office.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC4-rev591, Condition No. 6</p>	<p>D. Frequency of monitoring:</p> <p>Per Operation</p>
<p>B. Description:</p> <p>Recordkeeping requirement for the 67 BHP Isuzu portable diesel engine</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>The 67 BHP Isuzu portable diesel engine is equipped with a non-resettable hour meter. An hour meter reading is taken on a monthly basis and recorded on a log by the Environmental Division Air Quality Program.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC4-rev591, Condition No. 7</p>	<p>D. Frequency of monitoring:</p> <p>Per Operation</p>
<p>B. Description:</p> <p>Non-federally enforceable requirement to notify Ventura County Air Pollution Control District of long term operations requiring the use of portable engines</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>Condition 6 of Attachment PO0997PC4 did not become applicable at any time during this compliance certification period, as no portable engines were used at any single location where operations might reasonably be expected to last for more than 30 days.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>





## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC4-rev591, Condition No. 8</p>	<p>D. Frequency of monitoring:  Periodic</p>
<p>B. Description: Prohibition against using a portable engine to perform a permanent function</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Portable engines at NBVC are used mainly by the Public Works Department. Due to the inherent nature of their work, engines are constantly moved from one location to another within the site to perform work.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u>  G. Compliance Status? (C or I): <u>C</u>  H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u>  *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC4-rev591, Condition No.9</p>	<p>D. Frequency of monitoring:  Periodic</p>
<p>B. Description: NOx emission requirements for sweepers</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Documents of sweepers' engine certification are maintained by Environmental Division Air Quality Program.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u>  G. Compliance Status? (C or I): <u>C</u>  H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u>  *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC4-rev591, Condition No.10</p>	<p>D. Frequency of monitoring:  Periodic</p>
<p>B. Description: Non-federally enforceable requirement that all sweeper vehicle auxiliary engines be operated with the applicable requirements of CARB Regulation to reduce emissions from in-use heavy-duty diesel-fueled vehicles</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: All portable diesel sweeper engines operate at NBVC are in compliance with the applicable requirements of CARB "Regulation to Reduce Emission of Diesel Particulate Matter, NOx, and Other Pollutants from In-Use Heavy-Duty Diesel-Fueled Vehicles".</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u>  G. Compliance Status? (C or I): <u>C</u>  H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u>  *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC4-rev591, Condition No.11</p>	<p>D. Frequency of monitoring:</p> <p>Periodic</p>
<p>B. Description:</p> <p>CARB applicable requirements for the portable diesel crane engine</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p>N/A</p>
<p>C. Method of monitoring:</p> <p>The portable diesel crane engine operated at NBVC is in compliance with all applicable requirements of the CARB "Regulations of In-Use Off-Road Diesel Vehicles".</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC5-rev591, Condition No. 1(a)(i)</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description:</p> <p>Annual limit of 360 gallons of topcoats having a maximum ROC content of 3.5 lbs/gallon to be applied to aircraft and aerospace components</p>	<p>Daily during operations and monthly for recordkeeping purposes</p>
<p>C. Method of monitoring:</p> <p>Daily records of aerospace topcoats applied are kept by aerospace coating operations at Buildings 34, 319, 372, and 553, and are submitted on a monthly basis to the Environmental Division Air Quality Program (EDAQP). Usage of corrosion preventive compounds (CPCs) and walkway compounds by aerospace organizations are also reported as aerospace topcoats. These data are derived from hazardous material issue data. Coatings and CPCs are summed each month by the EDAQP, and the total is compiled into a 12-month cumulative report.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p> <p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC5-rev591, Condition No. 1(a)(ii)</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description:</p> <p>Annual limit of 108 gallons of primers having a maximum ROC content of 2.92 lbs/gallon to be applied to aircraft and aerospace components</p>	<p>Daily during operations and monthly for recordkeeping purposes</p>
<p>C. Method of monitoring:</p> <p>Daily records of all aerospace primers applied are kept by aerospace coating operations at Buildings 34, 319, 372, and 553, and are submitted on a monthly basis to the NBVC Air Quality Program. Primer usage is summed each month by the EDAQP, and the total is compiled into a 12-month cumulative report.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p> <p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC5-rev591, Condition No. 1(a)(iii)</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description:</p> <p>Annual limit of 100 gallons of specialty coatings having a maximum ROC content of 7.72 lbs/gallon to be applied to aircraft and aerospace components</p>	<p>Daily during operations and monthly for recordkeeping purposes</p>
<p>C. Method of monitoring:</p> <p>Records of all specialty coating are derived from the HAZMIN Center database called Enterprise Resources Planning (ERP) database. Total basewide usage is summed for each month, and compiled into a 12-month cumulative report by the EDAQP.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p> <p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC5-rev591, Condition No. 1(a)(iv)</p>	<p>D. Frequency of monitoring: Daily during operations and monthly for recordkeeping purposes</p>
<p>B. Description: Annual limit of 300 gallons of solvents having a maximum ROC content of 7.40 lbs/gallon to be used in association with aerospace coating operations</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Daily records of usage of high-ROC solvents associated with aerospace coating operations are kept by aerospace coating operations at Buildings 34, 319, 372, and 553, are submitted on a monthly basis to the EDAQP. Records of the gunwasher solvent, EP-921, are derived from ERP database. These monthly usages are then compiled into 12-month cumulative reports by the EDAQP.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC5-rev591, Condition No. 1(a)(v)</p>	<p>D. Frequency of monitoring: Monthly</p>
<p>B. Description: Annual limit of 110 gallons of methylene chloride based stripper having a maximum ROC content of 2.50 lbs/gallon to be used in association with aerospace coating operations</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: All hazardous materials are recorded upon their issue to the end user by means of the ERP database, which contains an accurate record of all stripper issued. Monthly usage of methylene -chloride stripper is derived from this database. These monthly records are then compiled into 12-month cumulative reports by the EDAQP.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC5-rev591, Condition No. 1(a)(vi)</p>	<p>D. Frequency of monitoring: Monthly</p>
<p>B. Description: Annual limit of 110 gallons of non-methylene chloride based stripper having a maximum ROC content of 2.50 lbs/gallon to be used in association with aerospace coating operations</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: No non-methylene chloride based stripper was used at any time during this compliance certification period. This is known, because EDAQP must approve all purchases of new materials. No new usages of non-methylene chloride stripper have been approved and none had ever been used in the past. It can be verified that no non-methylene chloride stripper was issued by reviewing the ERP database.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC5-rev591, Condition No. 1(a)(vii)</p>	<p>D. Frequency of monitoring:</p> <p style="text-align: center;">Monthly</p>
<p>B. Description:</p> <p>Annual limit of 30 gallons of 1,1,1 trichloroethane having a maximum ROC content of 1.67 lbs/gallon to be used in association with aerospace coating operations</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>No 1,1,1 trichloroethane was used at any time during this compliance certification period. This is known because EDAQP must approve all purchases of new materials. No purchases of 1,1,1 trichloroethane have been approved since Navy policy banned the use of 1,1,1 Trichloroethane in 1995. It can be verified that no 1,1,1 trichloroethane was issued by reviewing the ERP database.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC5-rev591, Condition No. 1(a)(viii)</p>	<p>D. Frequency of monitoring:</p> <p style="text-align: center;">Daily during operations and monthly for recordkeeping purposes</p>
<p>B. Description:</p> <p>Annual limit of 2,000 gallons of solvents having a maximum ROC content of 1.67 lbs/gallon to be used in association with aerospace coating and cleaning operations</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>NBVC uses solvents for aircraft maintenance having greater than de minimis amounts of ROC and less than 1.67 lb/gal ROC. Such solvents include aircraft engine gas path cleaner. Records of gas path cleaning solvent are derived from ERP database. These monthly records are then compiled into 12-month cumulative reports by the EDAQP</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC5-rev591, Condition No. 1(a)(ix)</p>	<p>D. Frequency of monitoring:</p> <p style="text-align: center;">Monthly</p>
<p>B. Description:</p> <p>Annual limit of 400 gallons of adhesives, adhesive primers, sealants, substrate surface preparation materials, solvents, and strippers having a maximum ROC content of 2.92 lbs/gallon to be used in association with aerospace operations</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>Usages of adhesives, sealants, adhesive primers, etc. are quantified through the ERP database. These monthly usage are then compiled into 12-month cumulative reports. All adhesives and sealants issued are assumed to be used for aircraft, unless another use is clearly obvious from issue data.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>



# ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC5-rev591, Condition No. 1(a)(x)</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description:</p> <p>Annual limit of 200 gallons of adhesives, adhesive primers, sealants, substrate surface preparation materials, solvents, and strippers having a maximum ROC content of 7.50 lbs/gallon to be used in association with aerospace operations</p>	<p>Daily during solvent cleaning operations and monthly for recordkeeping purposes</p>
<p>C. Method of monitoring:</p> <p>Usages of adhesives, sealants, adhesive primers, etc. are quantified through the ERP database. These monthly usage are then compiled into 12-month cumulative reports. All adhesives and sealants issued are assumed to be used for aircraft, unless another use is clearly obvious from issue data.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC5-rev591, Condition No. 1(b)(i)</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description:</p> <p>Annual limit of 1,016 gallons of coatings having a maximum ROC content of 2.80 lbs/gallon for the coating of metal parts and products and motor vehicles and mobile equipment</p>	<p>Daily during operations and monthly for recordkeeping purposes</p>
<p>C. Method of monitoring:</p> <p>Usage of coatings at the Fleet Readiness Center (FRC) Ground Support Equipment (GSE) Operation (Building 319) is reported against this limit. Volume of all coatings applied are recorded on a daily basis by the GSE operation, and submitted to the EDAQP on a monthly basis. Also, Records of amounts of coatings applied are submitted by customers of the MWR Auto Hobby Shop (AHS) who paint their personal vehicles in the paint booth at Building 154. Records are then submitted to EDAQP for reporting purposes. Then, monthly usage is determined, and compiled into 12-month cumulative reports.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC5-rev591, Condition No. 1(b)(ii)</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description:</p> <p>Annual limit of 400 gallons of coatings having a maximum ROC content of 3.50 lbs/gallon for the coating of metal parts and products and motor vehicles and mobile equipment</p>	<p>Daily during operations and monthly for recordkeeping purposes</p>
<p>C. Method of monitoring:</p> <p>Usage of coatings at the Fleet Readiness Center (FRC) Ground Support Equipment (GSE) Operation (Building 319) is reported against this limit. Volume of all coatings applied are recorded on a daily basis by the GSE operation, and submitted to the EDAQP on a monthly basis. Also, Records of amounts of coatings applied are submitted by customers of the MWR Auto Hobby Shop (AHS) who paint their personal vehicles in the paint booth at Building 154. Records are then submitted to EDAQP for reporting purposes. Then, monthly usage is determined, and compiled into 12-month cumulative reports.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC5-rev591, Condition No. 1(b)(iii)</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Annual limit of 140 gallons of coatings having a maximum ROC content of 4.340 lbs/gallon for the coating of metal parts and products and motor vehicles and mobile equipment</p>	<p>Daily during operations and monthly for recordkeeping purposes</p>
<p>C. Method of monitoring: Records of amounts of coatings applied are submitted by customers of the MWR AHS who paint their personal vehicles in the paint booth at Building 154. Records are then submitted to the EDAQP for reporting purposes. Monthly usage is determined, and compiled into 12-month cumulative reports. All customers of the AHS must have their paint pre-approved by Air Quality Program personnel.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC5-rev591, Condition No. 1(b)(iv)</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Annual limit of 118 gallons of solvents having a maximum ROC content of 7.40 lbs/gallon used in association with the coating of metal parts and products and motor vehicles and mobile equipment</p>	<p>Monthly</p>
<p>C. Method of monitoring: Both AIMD GSE and MWR Auto Hobby Shop use acetone in association with the coating of metal parts and products, and motor vehicles and mobile equipment.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC5-rev591, Condition No. 1(b)(v)</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Annual limit of 146 gallons of solvents having a maximum ROC content of 0.58 lbs/gallon used in association with the coating of metal parts and products and motor vehicles and mobile equipment</p>	<p>Monthly</p>
<p>C. Method of monitoring: Both AIMD GSE and MWR Auto Hobby Shop use acetone in association with the coating of metal parts and products, and motor vehicles and mobile equipment.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC5-rev591, Condition No. 1(b)(vi)</p>	<p>D. Frequency of monitoring: Monthly</p>
<p>B. Description: Annual limit of 112 gallons of solvents having a maximum ROC content of 1.67 lbs/gallon used in association with the coating of motor vehicles and mobile equipment</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Both AIMD GSE and MWR Auto Hobby Shop use acetone in association with the coating of metal parts and products, and motor vehicles and mobile equipment.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC5-rev591, Condition No. 1(c) (i)</p>	<p>D. Frequency of monitoring: Per operation</p>
<p>B. Description: Annual limit of 1,864 gallons per year of coatings having a maximum ROC content of 3.50 lbs/gallon applied by contractors to process and industrial equipment</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Any significant projects in which contractors must be hired are subject to approval by a "project review board", which includes one member of NBVC Environmental Division staff. In the event that coating of process and industrial equipment by contractors will take place, the contractor is directed to keep logs of the amount and types of coatings applied, and submit them to the EDAQP. These records are compiled into monthly totals and 12-month cumulative reports.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC5-rev591, Condition No. 1(c) (ii)</p>	<p>D. Frequency of monitoring: Per operation</p>
<p>B. Description: Annual limit of 1,000 gallons per year of solvents having a maximum ROC content of 7.40 lbs/gallon used by contractors in association with the coating of process and industrial equipment</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Any significant projects in which contractors must be hired are subject to approval by a "project review board", which includes one member of NBVC Environmental Division staff. In the event that coating of process and industrial equipment by contractors will take place, the contractor is directed to keep logs of the amount and types of solvents used and submit them to the EDAQP. These records are compiled into monthly totals and 12-month cumulative reports.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>





## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC5-rev591, Condition No. 1(d)</p>	<p>D. Frequency of monitoring: Daily during operations and monthly for recordkeeping purposes</p>
<p>B. Description: Annual limit of 3,600 pounds per year of powder coating having a maximum ROC content of 5% by weight used for powder coating operation</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable' N/A</p>
<p>C. Method of monitoring: Daily records of the powder coating applied are submitted on a monthly basis to the EDAQP. The total usage is compiled into a 12-month cumulative report.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC5-rev591, Condition No. 2</p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Non-federally enforceable requirement that paint booths not be operated without overspray filters, and that filters be replaced as required</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Presence of intact air filters is checked during periodic monitoring. The necessity to change filters before the pressure drop exceeds 0.5" of water column is a safety and industrial hygiene issue as well as an air quality issue, and is monitored periodically by EDAQP staff and the Safety and/or Industrial Hygiene programs.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC5-rev591, Condition No. 3</p>	<p>D. Frequency of monitoring: Per iod ic</p>
<p>B. Description: Non-federally enforceable prohibition against the spraying of coatings containing hexavalent chromium at the MWR AHS (Building 154)</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: All coatings applied at the AHS must be pre-approved by Air Quality Program. The presence of hexavalent chromium is one of the items that is checked during the approval process. Coatings containing hexavalent chromium are disapproved.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC5-rev591, Condition No. 5</p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Requirement that the powder coating operation shall be conducted in a powder coating booth that is equipped with a two-stage filtration system and does not exhaust to the outside atmosphere</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: The powder coating booth is equipped with a two-stage filtration system and does not exhaust to the outside atmosphere.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC5-rev591, Condition No. 6</p>	<p>D. Frequency of monitoring: Monthly</p>
<p>B. Description: Requirement that annual operation of the Epcon natural gas burn-off oven not to exceed 1135 hours, monthly records of hours of operation be maintained and summed for the previous twelve months</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: The Epcon natural gas burn-off oven is equipped with an hour meter. Monthly records of hours of operation are submitted on a monthly basis to the EDAQP. These records are compiled into a 12-month cumulative report.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC5-rev591, Condition Nos. 7(a) and 7(b)</p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Requirement that the Epcon natural gas fired burn-off oven uses only natural gas(a), and is only used to remove coatings from metal substrates(b)</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Epcon natural gas fired burn-off oven is operated on PUC natural gas. Nothing other than coated items with metal substrates were processed in the burn-off oven during the compliance period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC5-rev591, Condition No. 7(c)</p>	<p>D. Frequency of monitoring:</p> <p>Annually</p>
<p>B. Description:</p> <p>Requirement that the Epcon burn-off oven be operated in accordance with the manufacturer's instructions and recommendations</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>It is verified by the EDAQP that the Epcon burn-off oven is operated in accordance with the manufacturer's instructions and recommendations.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC5-rev591, Condition No. 7(d)</p>	<p>D. Frequency of monitoring:</p> <p>annually</p>
<p>B. Description:</p> <p>Requirement that all exhaust from the Epcon burn-off oven be processed through an afterburner/secondary chamber to control emissions.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>Primary and afterburner operational parameters are controlled to specification by a factory programmed control system that insures proper system operation and the destructive efficiency of the afterburner. In addition, site verifiable parameters are checked by trained technicians during system operation.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC6-rev501, Condition No. 1</p>	<p>D. Frequency of monitoring:</p> <p>Monthly for records</p> <p>Periodic for inspections</p>
<p>B. Description:</p> <p>Requirement that only Garnet be used in the confined abrasive blasting operations at Building 3014</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>Monthly records are received as to the amount and type of abrasives used in the blast room at Building 3014. These records are reviewed by Environmental Division Air Quality Program (EDAQP) staff to ensure that garnet is the only type of abrasive which is used. In addition periodic inspections of the blasting operations at Building 3014 confirmed that garnet was the only blast media which was used during the compliance certification period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC6-rev501, Condition No. 2</p>	<p>D. Frequency of monitoring:</p> <p>Periodic</p>
<p>B. Description:</p> <p>Requirement to comply with applicable provisions of Title 17, California Administrative Code, Subchapter 6, and APCD Rule 74.1</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>Inspections are performed by the EDAQP staff to ensure compliance with the visible emissions standards, nuisance prohibitions, and performance standards of the above rules.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC6-rev501, Condition No. 3(a)</p>	<p>D. Frequency of monitoring:</p> <p>Annually</p>
<p>B. Description:</p> <p>Opacity limit of Ringelmann #1 on discharge into the atmosphere from within the permanent building equipped with exhaust filters at Building 311</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>An opacity observation from blasting operation at Building 311 was made on 12/17/2014 while the filters were in operation, but no abrasive blasting operation was taking place. No opacity was noted.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC6-rev501, Condition No. 3(b)</p>	<p>D. Frequency of monitoring:  Periodic</p>
<p>B. Description: Requirement that confined abrasive blasting operations at Building 311 be controlled by a Torit Downflow II cartridge dust collector</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Routine surveillance by EDAQP staff is sufficient to verify that the abrasive blast room and the Torit Downflow II dust collector operated properly throughout the compliance certification period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u>  G. Compliance Status? (C or I): <u>C</u>  H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u>  *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC6-rev501, Condition No. 3 (c)</p>	<p>D. Frequency of monitoring:  Periodic</p>
<p>B. Description: Performance and inspection requirement for the Torit Downflow II cartridge dust collector at Building 311</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: The pressure gauge was observed on 12/17/2014 while the filters were in operation, but no abrasive blasting operation was taking place. The static pressure differential across the cartridge was noted to be 1.0 inches of water column.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u>  G. Compliance Status? (C or I): <u>C</u>  H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u>  *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC6-rev501, Condition No. 4, as applicable to Abrasive Blast Rooms at Building 311 and 3014</p>	<p>D. Frequency of monitoring:  Annually</p>
<p>B. Description: Requirement for annual survey and certification of confined abrasive blasting operations</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: At 11:15 AM on 12/17/2014, the dust collection system exhaust port at the Buildings 311 abrasive blast room was surveyed. At 11:32 AM on 12/17/2014 the dust collection system exhaust port at the Buildings 3014 abrasive blast room was surveyed. No visible emissions were noted from the exhaust ports.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u>  G. Compliance Status? (C or I): <u>C</u>  H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u>  *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC6-rev501, Condition No. 5</p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Requirement that abrasive blasting operation at Building 3014 be conducted inside a confined abrasive blasting room equipped with a media recovery system and a dust collection system</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Building 3014 confined abrasive blast room is equipped with a media recovery system and a dust collection system for the control of particulate emissions.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC6-rev501, Condition No. 6</p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Requirement that the blasting media used in the Blast-It-All located inside Building 319 be plastic bead or other material approved by the manufacturer for use in the cabinet</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Plastic bead is used as the blast media in the Blast-It-All abrasiv blasting cabinet at Building 319.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC6-rev501, Condition No. 7</p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Requirement that the Blast-It-All abrasive blasting cabinet be operated within a permanent building</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: The Blast-It-All abrasive blasting cabinet is located and operated inside Building 319.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC6-rev501, Condition No. 8</p>	<p>D. Frequency of monitoring:</p> <p>Periodic</p>
<p>B. Description:</p> <p>Requirements associated with the Blast-It-All pull through dust collector proper operation, filters replacement, collection of dust, and annual inspection of filters</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p>N/A</p>
<p>C. Method of monitoring:</p> <p>Routine surveillance by EDAQP staff is sufficient to verify Blast-It-All pull through dust collector operated properly, filters are replaced as necessary, and dusts are collected and removed in a manner that prevents re-entrainment into the atmosphere. An annual inspection of the filters was performed on 12/9/2014. Filter repair or replacement was not required.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC7-531, Condition No. 1</p>	<p>D. Frequency of monitoring:</p> <p>Monthly</p>
<p>B. Description:</p> <p>Requirement to monitor and record the level in the condensate collection tank at the Automotive Gasoline Bulk Plant</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>The liquid level in the condensate collection tank associate with the loading rack at the Automobile Gasoline Bulk Plant is monitored monthly. Records documenting the monitoring of the condensate tank and recording the volume of condensate removed are kept by the Environmental Division Air Quality Program.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC7-531, Condition No. 2</p>	<p>D. Frequency of monitoring:</p> <p>Periodic</p>
<p>B. Description:</p> <p>Non-federally enforceable requirement to operate the vapor recovery system on the loading rack at the Automotive Gasoline Bulk Plant in compliance with California Air Resources Board (CARB) Executive Order #G-70-124B</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>The loading rack is equipped with a CARB Certified Balance Vapor Recovery System. Proper operation of the vapor recovery system is ensured by periodic monitoring by Supply Department, Fuel Branch personnel.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC7-531, Condition No. 3</p>	<p>D. Frequency of monitoring:</p> <p>Periodic</p>
<p>B. Description:</p> <p>Requirement that the Automotive Gasoline Bulk Plant not be used for the storage or transfer of Aviation Gasoline, and that only JP-5 fuel be stored in the former Aviation Gasoline Bulk Plant</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>No aviation gasoline is stored in the Automobile Gasoline Bulk Plant.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>





## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC7-531, Condition No. 4</p>	<p>D. Frequency of monitoring: Annually</p>
<p>B. Description: Requirement that the condensate trap is located at the lowest point of the vapor return line, is self-evacuating, has access for inspection, is maintained in good working order, and that the maximum pressure through the system with the condensate trap in place drop not exceed 0.5 inches of wc at 60 scfh</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: The NEX Gas Station condensate trap is located at the lowest point of the vapor return line. It is self-evacuating and has an access for inspection. A dynamic pressure test was performed on 8/7/2014 verified that the maximum pressure drop was less than 0.5 inches of water at 60 scfh.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u>  G. Compliance Status? (C or I): <u>C</u>  H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u>  *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC7-531, Condition No. 5</p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Requirement to meet CARB requirements for enhanced vapor recovery (EVR) for Phase I control systems and vapor recovery nozzles</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Phase I "Enhanced Vapor Recovery" was installed at the Navy Exchange Gas Station on or about April 11, 2003 as specified in CARB Executive Order VR-102-A. Presence of CARB-certified Phase I vapor recovery system is verified at the time of the annual inspection.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u>  G. Compliance Status? (C or I): <u>C</u>  H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u>  *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC7-531, Condition No.6</p>	<p>D. Frequency of monitoring: Monthly</p>
<p>B. Description: Requirement to check the liquid level in the condensate tank at the "Government Gasoline Station" (Building 631) and at the Fuel Farm</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: The condensate tank is inspected monthly and drained as necessary. Records of fluid level inspections and liquid drained from the tanks are kept by the Environmental Division Air Quality Program.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u>  G. Compliance Status? (C or I): <u>C</u>  H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u>  *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC8, Condition No. 1(a)</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description:</p> <p>Requirement that all blowers or fans at the vapor extraction system at the Navy Exchange Gas Station be electrically powered</p>	<p>N/A</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p>N/A</p>
<p>C. Method of monitoring:</p> <p>The vapor extraction system at the Navy Exchange Gasoline Station was removed from the service.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC8, Condition No. 1(b)</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description:</p> <p>Requirement that any thermal or catalytic oxidizer be electrically operated or be fired on natural gas or propane with a rating of 1 MMBTU/hr or less</p>	<p>N/A</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p>N/A</p>
<p>C. Method of monitoring:</p> <p>The vapor extraction system at the Navy Exchange Gasoline Station was removed from the service.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC8, Condition No. 2</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description:</p> <p>Requirement that all wastewater collected from the vapor extraction system be stored in a covered container or tank, and that all tanks greater than 250 gallons use a submerged fill pipe</p>	<p>N/A</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p>N/A</p>
<p>C. Method of monitoring:</p> <p>The vapor extraction system at the Navy Exchange Gasoline Station was removed from the service.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>



# ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC9- rev261, Condition No. 1</p>	<p>D. Frequency of monitoring: Monthly</p>
<p>B. Description: Requirement and associated recordkeeping that ROC solvent usage in permitted dip tank not exceed 200 gallons per year</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Usage of solvent in the dip tank at Building 333 is calculated from Enterprise Resources Planning (ERP) database issue data. Usage is compiled into reports, which are used to document that usage did not exceed the 200 gallon limit during any of the twelve rolling-12-month periods during this compliance certification period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC9- rev261, Condition No. 2</p>	<p>D. Frequency of monitoring: As Needed</p>
<p>B. Description: Requirement that only solvents having a vapor pressure less than 2 mmHg be used in the dip tank listed on the permit</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: A member of the NBVC Air Quality Program must approve all new uses of hazardous materials. The vapor pressure of the solvent used in the Bldg 333 dip tank is less than 2 mmHg at 20 degrees Celsius as required.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC9- rev261, Condition No. 3(a)</p>	<p>D. Frequency of monitoring: Monthly</p>
<p>B. Description: Limit on the use of ROC solvent cleaning materials to 385 gallons per year, and a requirement to maintain monthly records of solvent purchase, usage, and disposal</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Solvent purchase data is derived from ERP database. Solvent disposal data is derived from another database. Exempt solvent (solvent used outside of Ventura County or used for non-cleaning purposes) is documented in monthly logs. Solvent usage is calculated by subtracting disposal data and exempt solvent data from purchase data. Usage is compiled into 12-month cumulative reports.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC9-rev261, Condition No. <u>293</u></p>	<p>D. Frequency of monitoring: Monthly</p>
<p>B. Description: Limit on the combined use of 1,1,1 trichloroethane and trichlorotrifluoroethane solvent cleaning materials to 100 gallons per year, and a requirement to maintain monthly records of solvent purchase, usage, and disposal</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Records of issuance of all solvent materials are maintained by the ERP database, and are compiled on a monthly basis. No 1,1,1 trichloroethane and trichlorotrifluoroethane solvent cleaning materials were used during the compliance period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u>  G. Compliance Status? (C or I): <u>C</u>  H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u>  *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC10</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Conditions associated with alternative operating scenarios</p>	<p>N/A</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p>N/A</p>
<p>C. Method of monitoring: No surge condition on or national security emergency was declared during this compliance certification period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC11-rev451,481, Conditions 1 and 3</p>	<p>D. Frequency of monitoring:  Monthly</p>
<p>B. Description: Requirement that any equipment designated as "Out of Service" in Tables 2, 3, and 4 of this permit is shut down and not operated</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: All the equipments designated as "Out of Service" in Tables 2, 3, and 4 of this permit were shut down and not operated during the compliance period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u>  G. Compliance Status? (C or I): <u>C</u>  H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u>  *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO0997PC11-rev451,481, Condition 2</p>	<p>D. Frequency of monitoring:  As Needed</p>
<p>B. Description: Requirement that before operating any equipment designated as "Out of Service", a Modification to Part 70 Permit application be submitted</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: A Modification to Part 70 Permit application is submitted before operating any equipment designated as "Out of Service".</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u>  G. Compliance Status? (C or I): <u>C</u>  H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u>  *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Rule 50-- Opacity</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Prohibition of visible emissions, requirement for routine surveillance and a formal opacity survey</p>	<p>Annual</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: A formal survey by an untrained observer was conducted of emission units at the facility. Survey was completed in December 2014. No visible emissions were observed during the survey. Appendix C includes a copy of the formal survey.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 54.B.1</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Sulfur emissions at point of discharge</p>	<p>N/A</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Compliance with Attachment 54.B.1 is demonstrated by compliance with Rule 64 as noted in the Applicability section of Attachment 54.B.1.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>





## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 54.B.2</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Ground or sea level sulfur emissions at or beyond the stationary source property line</p>	<p>N/A</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p>N/A</p>
<p>C. Method of monitoring: Compliance with Attachment 54.B.2 is demonstrated by screening level dispersion modeling tests referenced in the Ventura County Air Pollution Control District (VCAPCD) Memorandum dated May 23, 1996, authored by Terri Thomas of the VCAPCD.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 55</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Applicable requirements for activities capable of generating fugitive dust</p>	<p>Routine</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: The Public Works Project Review Board requires that contractors who perform construction activities at Naval Base Ventura County and are capable of generating fugitive dust to comply with the Ventura County Air Pollution Control District Rule 55 conditions.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 55.1</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Applicable requirements for paved and unpaved road activities</p>	<p>Routine</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: The Public Works Project Review Board requires that contractors who perform road construction activities at Naval Base Ventura County to comply with the Ventura County Air Pollution Control District Rule 55.1 conditions.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 57.1</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Limit on emissions of particulate matter to 0.12 pounds per MMBTU of fuel input</p>	<p>N/A</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: According to an analysis of the facility by VCAPCD using Rule 57.B dated December 3, 1997, periodic monitoring is not necessary to demonstrate compliance with Rule 57.1. Compliance with other conditions of this permit is sufficient to ensure compliance with Rule 57.1.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 64</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Sulfur Content of Fuels</p>	<p>Periodic</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Compliance with Rule 64.B.1 is demonstrated by the fact that P.U.C. regulated natural gas is the only gaseous fuel combusted at this facility. Compliance with Rule 64.B.2 is demonstrated by the fact that the diesel fuel and reformulated gasoline combusted at this facility are California Air Resources Board-certified. F-24 is burned in the engines of some ground support equipment and all jet engine test cells. All of these fuels comply with the 0.5% sulfur content limits of Rule 64. F-24 fuel complies with military specification MIL-DTL-83133E, which includes a maximum allowable sulfur content limit of 0.3%.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 74.6 (2003), Condition No. 1</p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Surface Cleaning and Degreasing -- Solvent ROC and/or Vapor Pressure</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Compliance with ROC and vapor pressure limits is ensured by the fact that all solvents must be approved by Environmental Division Air Quality Program (EDAQP) staff before they can be issued and used by any Naval Base Ventura County (NBVC) entity or tenant organization aboard NBVC.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 74.6 (2003), Condition Nos. 2 through 7</p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Conditions relating to solvent handling procedures</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Compliance with Conditions 2 through 7 of Attachment 74.6 is verified by means of routine surveillance of solvent activities that are carried out by EDAQP staff during routine visits to subject facilities.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 74.6 (2003), Condition No. 8</p>	<p>D. Frequency of monitoring: Routine</p>
<p>B. Description: Equipment and work practice requirements applicable to all cold cleaners (except remote reservoir type) -- Measurement of freeboard height, verification of initial boiling point, ROC content, and ROC composite partial pressure</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Inspection of the cold cleaner at Building 333 was conducted on 12/4/2014. Freeboard heights were found to be greater than 6", and solvents were found to have a vapor pressure less than 2mmHg @ 20 degrees Celsius on all units.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



# ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 74.6 (2003), Condition No. 9</p>	<p>D. Frequency of monitoring: Routine</p>
<p>B. Description: Equipment and work practice standards as applicable to remote reservoir cold cleaners -- Measurement of freeboard height, verification of initial boiling point, ROC content, and ROC composite partial pressure</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: An inspection of four remote reservoir cold cleaner units at Building 311 was conducted on 12/4/2014. A permanent label summarizing the applicable operating requirements was posted. Drain hole area was found to be &lt;15 square inches, freeboard height was found to be greater than 6", and solvent was found to have a vapor pressure less than 2mmHg @ 20 degrees Celsius.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 74.6 (2003), Condition No. 10</p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Conditions related to cold cleaning operation</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: A permanent label summarizing the applicable operating requirements for cold cleaning operations is posted on each cold cleaner. Also, compliance with Condition 10 of Attachment 74.6 is verified by means of routine surveillance carried out by EDAQP staff during routine visits to subject facilities.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 74.6 (2003), Condition Nos. 14 and 15</p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Recordkeeping requirements associated with surface cleaning and degreasing and routine surveillance to comply with Rule 74.6</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Compliance with the requirement to maintain a current material list showing the name, ROC and vapor pressure, and intended uses of each solvent material is accomplished by means of a database that records each issuance of a solvent material to any operation aboard NBVC. For each issuance of material, this database contains a reference to the applicable MSDS sheet. The database also contains references to the recipient of the material, and ultimately to the screening sheet, which is the document that approved the material, and describes all intended uses. In addition, EDAQP staff performs routine inspection of the applicable solvent cleaning activities to ensure compliance with Rule 74.6.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 74.11</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description:</p> <p>Natural gas-fired water heaters rated at less than 75,000 BTU/hr installed after July 1, 2010</p>	<p>Upon Installation</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>Through the Public Works Project Review Board, installers of water heaters rated at less than 75,000 BTU/hr are required to comply with conditions of Ventura County Air Pollution Control District Rule 74.11. In addition, a Standard Operating Procedure (SOP) was developed and implemented by the Environmental Division Air Quality Program (EDAQP) which required the purchasers or installers of water heaters rated at less than 75,000 BTU/hr to seek an approval from EDAQP prior to purchase. Appendix C includes the result of a limited survey of water heaters at point Mugu, NBVC during this compliance certification period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>





## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 74.11.1</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description:</p> <p>Large water heaters and small boilers, steam generators and process heaters with a rated heat input capacity greater than 75,000 BTU/hr and less than or equal to 2,000,000 BTU/hr</p>	<p>Routine</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>Through the Public Works Project Review Board, installers of large water heaters, small boilers, steam generators, and process heaters are required to comply with conditions of Ventura County Air Pollution Control District Rule 74.11.1. In addition, a Standard Operating Procedure (SOP) was developed and implemented by the Environmental Division Air Quality Program (EDAQP) which required the purchasers or installers of such devices to seek an approval from EDAQP prior to purchase. Appendix C includes the result of a limited survey of large water heaters, small boilers, steam generators, and process heaters at point Mugu, NBVC during this compliance certification period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 74.22</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Natural Gas-Fired Fan-Type Central Furnaces</p>	<p>Routine</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Through the Public Works Project Review Board, installers of natural gas-fired fan-type central furnaces are required to comply with conditions of Ventura County Air Pollution Control District Rule 74.22. In addition A Standard Operating Procedure (SOP) was developed and implemented by the Environmental Division Air Quality Program (EDAQP) which requires the purchasers or installers of natural gas-fire fan-type furnaces to obtain certification documents from the seller or manufacturer and submit it to the EDAQP for review and approval.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 74.1, Condition No. 1</p>	<p>D. Frequency of monitoring:</p> <p>Periodic</p>
<p>B. Description:</p> <p>Requirement that abrasive blasting of moveable items take place within a permanent building</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>As a Navy policy, all abrasive blasting of moveable items must take place within an abrasive blast room or an abrasive blast cabinet with a control device. Routine surveillance of general operations is sufficient to verify compliance.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 74.1, Condition No. 2</p>	<p>D. Frequency of monitoring:</p> <p>Per Operation</p>
<p>B. Description:</p> <p>Requirement that permissible outdoor blasting take place using approved methods</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>All projects that would involve permissible outdoor blasting are required to go through the Public Works Project Review Board. Such projects are reviewed by a member of the Environmental Division Air Quality Program (EDAQP), who would stipulate that all blasting be conducted in compliance with Rule 74.1.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 74.1, Condition Nos. 3 and 4</p>	<p>D. Frequency of monitoring:</p> <p>Per Operation</p>
<p>B. Description:</p> <p>Requirements for the blasting of pavement and stucco</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>All projects that would involve blasting of pavement and stucco are required to go through the Public Works Project Review Board. Such projects would therefore be reviewed by a member of the EDAQP, who would stipulate that all blasting be conducted in compliance with Rule 74.1.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>



Ventura County  
Air Pollution  
Control District

## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 74.1, Condition No. 7</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Routine surveillance and recordkeeping associated with permissible outdoor blasting</p>	<p>Periodic</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: EDAQP requires all contractors to follow Rule 74.1 for permissible outdoor blasting operations. Contractors are required to submit records specified in Condition 7 of Attachment 74.1.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



# ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 74.2, Condition Nos. 1 and 2</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: VOC content limits for flat, nonflat, nonflat-high gloss, specialty, and industrial maintenance architectural coatings</p>	<p>Per Operation</p>
<p>C. Method of monitoring: The Public Works Project Review Board requires contractors perform architectural coatings at NBVC to comply with the VOC limits of Ventura County Air Pollution Control District (VCAPCD) Rule 74.2.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p>
	<p>G. Compliance Status? (C or I): <u>C</u></p>
	<p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 74.2, Condition No. 3</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Requirement that all the architectural coating which are applied directly from the containers, and any VOC-containing materials used for thinning and cleanup be stored in closed containers when not in use</p>	<p>Routine</p>
<p>C. Method of monitoring: The Public Works Project Review Board requires contractors to comply with conditions of VCAPCD Rule 74.2. In addition, hazardous material storage areas and coating operations are inspected by the EDAQP staff routinely.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p>
	<p>G. Compliance Status? (C or I): <u>C</u></p>
	<p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 74.2, Condition No. 4</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Requirement to comply with the architectural coating VOC limits specified in Rule 74.2.B.1</p>	<p>Per Operation</p>
<p>C. Method of monitoring: The Public Works Project Review Board requires contractors perform architectural coatings at NBVC to comply with the VOC limits of Ventura County Air Pollution Control District (VCAPCD) Rule 74.2.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p>
	<p>G. Compliance Status? (C or I): <u>C</u></p>
	<p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 74.2, Condition No. 5</p>	<p>D. Frequency of monitoring:  Per Operation</p>
<p>B. Description:  Requirement to specify VOC compliant architectural coatings, and to maintain VOC records of coatings used</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:  The Public Works Project Review Board requires contractors perform architectural coatings at NBVC to comply with the VOC limits of Ventura County Air Pollution Control District (VCAPCD) Rule 74.2. The VOC records of architectural coatings are kept by EDAQP.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u>  *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 74.4</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Short-term cutback asphalt activities</p>	<p>Per Operation</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: No cutback asphalt activities took place during the compliance certification period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 74.27</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Short-term gasoline and ROC liquid storage tank degassing operations</p>	<p>Per Operation</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Through the Public Works Project Review Board, the Environmental Division Air Quality Program (EDAQP) staff is notified of any planned large projects that may involve emissions of air contaminants. The EDAQP staff reviews the applicability of air regulations to the project and inspects the activities, as needed.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>





## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 74.28</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Short-term asphalt roofing operations</p>	<p>Per Operation</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Through the Public Works Project Review Board, the Environmental Division Air Quality Program (EDAQP) staff is notified of any planned large projects that may involve emissions of air contaminants. The EDAQP staff reviews the applicability of air regulations to the project and inspects the activities, as needed.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 74.29</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Short-term soil decontamination operations</p>	<p>Per Operation</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: No short-term soil decontamination activities occurred at Naval Base Ventura County Point Mugu site during this compliance certification period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



Ventura County  
Air Pollution  
Control District

## SEMIANNUAL COMPLIANCE CERTIFICATION TITLE V PERMIT #0997 ASBESTOS REQUIREMENTS

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

A. Attachment # or Permit Condition #: 40CFR61.M	D. Frequency of monitoring:
B. Description: Short-term asbestos demolition or renovation activities - requirements for inspection, notification, removal, and disposal procedures	Periodic
C. Method of monitoring: All short-term demolition and renovation activities undertaken at Naval Base Ventura County (NBVC) are performed by contractors. The Public Works Department at NBVC requires contractors to meet all inspection, notification, removal, and disposal requirements of Attachment 40CFR61.M as a condition of contract. In addition, the NBVC Asbestos Program Manager routinely monitors asbestos abatement contractor activity, and ensures that all requirements for inspection, notification, removal, and disposal are met as required.	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
	F. Currently in Compliance? (Y or N): <u>Y</u>
	G. Compliance Status? (C or I): <u>C</u>
	H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: General Part 70 Permit</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: General Title V Requirements</p>	<p>Periodic</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Naval Base Ventura County Environmental Division personnel have conducted regular inspections of permitted sources, retained records as required, and reviewed records for compliance.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>Y</u> *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION DEVIATION SUMMARY FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #:  40CFR63ZZZN3, Part 70 General</p>	<p>B. Equipment description:  300 BHP Caterpillar Engine Located at Building PM-13, 103 BHP Caterpillar Engine Located at Building PM-67, 290 BHP John Deere Engine Located at Building LP-93, 343 BHP Caterpillar Engine Located at Building LP-99, and 196 BHP General Motors Engine Located at Building PM-323</p>	<p>C. Deviation Period: Date &amp; Time Begin: <u>May 4, 2014</u>  End: <u>July 24, 2014</u> When Discovered: Date &amp; Time <u>May 4, 2014</u></p>
<p>D. Parameters monitored: Annual filter and oil change, or passing oil analysis</p>	<p>E. Limit: 500 hours of operation or annual</p>	<p>F. Actual: Annual + 27 days to 80 days</p>
<p>G. Probable Cause of Deviation: Logistical difficulty, difficulty scheduling personnel, difficulty scheduling security escort, delays in material shipment, and misplaced analytical samples</p>		<p>H. Corrective actions taken: Advanced planning for maintenance activities, earlier sampling of oil for analysis to allow for resampling in case of sample misplacement by lab</p>

<p>A. Attachment # or Permit Condition #:  40CFR63ZZZN3, Part 70 General</p>	<p>B. Equipment description:  343 BHP Caterpillar Engine Located at Building LP-99,</p>	<p>C. Deviation Period: Date &amp; Time Begin: <u>May 4, 2014</u>  End: <u>May 30, 2014</u> When Discovered: Date &amp; Time <u>May 4, 2014</u></p>
<p>D. Parameters monitored: Annual air cleaner, hoses and belts inspection</p>	<p>E. Limit: 1000 hours of operation or annual for air cleaner, and 500 hours of operation or annual for hoses and belts</p>	<p>F. Actual: Annual + 27 days</p>
<p>G. Probable Cause of Deviation: Difficulty scheduling security escort</p>		<p>H. Corrective actions taken: Advanced planning for scheduling security escort</p>



## ANNUAL COMPLIANCE CERTIFICATION DEVIATION SUMMARY FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

A. Attachment # or Permit Condition #:  74.9 N7, Part 70 General	B. Equipment description:  300 BHP Caterpillar Engine, Model 3306BD1., Serial Number 64Z08034	C. Deviation Period: Date & Time Begin: <u>September 9, 2014</u>  End: <u>October 1, 2014</u> When Discovered: Date & Time  <u>October 1, 2014 at 1000</u>
D. Parameters monitored: Hours of operation	E. Limit: 20 Hrs Operation/Yr for maintenance	F. Actual: 4.9 Hrs
G. Probable Cause of Deviation: The hour meter was wired to the engine "on/off" switch which was inadvertently left in the "on" position. As a result, the hour meter registered 551.8 hours run time despite the fact that the engine did not operate between September 9, 2014 and October 1, 2014.		H. Corrective actions taken: The engine was tagged out of service and breakdown was reported to VCAPCD Breakdown Line. The hour meter rewired to register the run time only when the engine is operating on December 6.



Ventura County  
Air Pollution  
Control District

**SEMIANNUAL COMPLIANCE CERTIFICATION**  
**TITLE V PERMIT #0997**

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

A. Attachment # or Permit Condition #: General Permit to Operate	D. Frequency of monitoring:
B. Description: All requirements of Title V Permit # 0997	Periodic
	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring: Routine inspections by Environmental Division Air Quality Program staff ensure that permits are posted and other general permits to operate conditions are complied with.	F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form



Ventura County  
Air Pollution  
Control District

## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: 40CFRPart 68</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Accidental Release Prevention and Risk Management Plans</p>	<p>N/A</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p>N/A</p>
<p>C. Method of monitoring: No substances regulated by the California Accidental Release Prevention (ARP) Program or the federal Risk Management Plan (RMP) were contained in a process in a quantity that exceeded the respective threshold for California ARP Program or federal RMP.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>





## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: 40CFR82</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Protection of stratospheric ozone</p>	<p>Periodic</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Naval Base Ventura County (NBVC) Point Mugu has an established Ozone Depleting Substances (ODS) management policy and maintains records of all ODS procured, utilized and recovered from units subject to the record keeping requirements of 40 CFR Part 82, Subpart F. NBVC also verifies all technician certifications, utilizes compliant ODS recovery equipment, follows safe disposal protocols for ODS, adheres to all ODS evacuation requirements, and follows leak detection and management protocols outlined in 40 CFR Part 82.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

## **Appendix A**

### **NBVC Point Mugu Supporting Documentation of CARB- Certified Diesel & Sulfur Compliant JP-8/F-24**

UNIT: 10000000000000000000  
 DATE: 10/10/2000 10:00  
 TIME: 10:00

UNIT: 10000000000000000000  
 DATE: 10/10/2000 10:00  
 TIME: 10:00

UNIT: 10000000000000000000  
 DATE: 10/10/2000 10:00  
 TIME: 10:00

UNIT: 10000000000000000000  
 DATE: 10/10/2000 10:00  
 TIME: 10:00

This is to certify that the herein named materials are properly classified, described, packaged, marked, and labeled, and are in proper condition for transportation, according to the applicable regulations of the Department of Transportation.

DELIVERY INSTRUCTIONS:  
 BOL COMMENTS: ABOVE SUPPLIER IS RESPONSIBLE FOR DESTINATION STATE TAX ON MOTOR FUEL.  
 FOR EMERGENCY INFORMATION, CALL: (800) 424-9300, CHEMTREC (Texas) # 2 # 111 Customer Number: 20423.

PRODUCT DESCRIPTION	GROSS WT.	NET WT.	TEMP	GRAV	WT	REV	DATE	MESSAGE NUMBER
424217 ULS CARB DIESEL	7500	7450	66.9	40.3	40.0			ULS, 20, 8108A
TOTAL	7500	7450						

MSG # MESSAGE  
 ULS MV Designated 10 pps sulfur (residual) Ultra-Low Sulfur Diesel Fuel. For use in all Diesel Vehicles and engines.  
 20 Product is H Diesel fuel.  
 8108A Key Contact is U. S. Biodiesel

COMP	RISER	PRODUCT ID	PRODUCT NAME	QUANTITY	NET WT	TEMP	GRAV
01	55	000017	ULS CARB DIESEL	2500	2490	66.9	40.3
		000020	ULS CARB MOTOR VEHICLE	2500	2490	66.9	40.3
		000036	INNSPEC OL19181.7	0.3320	0.3320	66.9	40.3
02	51	000017	ULS CARB DIESEL	2500	2490	66.9	40.3
		000020	ULS CARB MOTOR VEHICLE	2500	2490	66.9	40.3
		000036	INNSPEC OL19181.7	0.3320	0.3320	66.9	40.3
03	53	000017	ULS CARB DIESEL	2500	2490	66.9	40.3
		000020	ULS CARB MOTOR VEHICLE	2500	2490	66.9	40.3
		000036	INNSPEC OL19181.7	0.3320	0.3320	66.9	40.3
04	54	000017	ULS CARB DIESEL	2500	2490	66.9	40.3
		000020	ULS CARB MOTOR VEHICLE	2500	2490	66.9	40.3
		000036	INNSPEC OL19181.7	0.3320	0.3320	66.9	40.3



RECEIVED  
 U.S. DEPARTMENT OF COMMERCE  
 BUREAU OF ECONOMIC ANALYSIS  
 WASHINGTON, D. C. 20540  
 DATE: 10/15/54  
 TO: DIRECTOR, BUREAU OF ECONOMIC ANALYSIS  
 FROM: [Illegible]  
 SUBJECT: [Illegible]

*[Handwritten Signature]*

It is to be noted that the foregoing report materials were prepared, classified, packaged, marked, and certified, and the  
 in proper condition for transport, in accordance with the applicable regulations of the Bureau and of the Department.

The information shown herein is responsible for destination state for all purposes.  
 THE EXPLANATION INFORMATION IS: [Illegible]

PRODUCT DESCRIPTION: [Illegible]  
 U.S. CARB DIESEL  
 U.S. CARB MOTOR VEHICLE  
 U.S. CARB DIESEL  
 U.S. CARB MOTOR VEHICLE

COMF		RUELF		PRODUCT & DESCRIPTION		TOTAL		
WT	CB	WT	CB	WT	CB	WT	CB	
14.78	0.71	70.5	40.10	U.S. CARB DIESEL	14.78	0.71	70.5	40.10
29.78	0.440	70.5	40.10	U.S. CARB MOTOR VEHICLE	29.78	0.440	70.5	40.10
				UNMOUNTED OL19191.1				
				U.S. CARB DIESEL				
				U.S. CARB MOTOR VEHICLE				
				UNMOUNTED OL19191.1				
				U.S. CARB DIESEL				
				U.S. CARB MOTOR VEHICLE				
				UNMOUNTED OL19191.1				

[Faint, mostly illegible text at the bottom of the page, possibly including a signature block or additional notes.]

REVERSE SIDE FOR EMERGENCY RESPONSE INFORMATION  
In Case of Product Emergency, Spill, Leak, Fire, Exposure, or Accident,  
CALL CHEMTREC, Day or Night, in the US at (800) 424-9300 or International at (703) 527-3887.  
Reference CHEMTREC Contract CCN222996

Customer Name: [Illegible]  
Customer Address: [Illegible]  
City: [Illegible]  
State: [Illegible]  
Zip: [Illegible]

Ship To Address: [Illegible]  
Ship To Address: [Illegible]  
City: [Illegible]  
State: [Illegible]  
Zip: [Illegible]

Ship From Address: [Illegible]  
City: [Illegible]  
State: [Illegible]  
Zip: [Illegible]

Ship From Address: [Illegible]  
City: [Illegible]  
State: [Illegible]  
Zip: [Illegible]

Product Code: [Illegible]

Product Description	Gross Qty	Net Qty
---------------------	-----------	---------

TOTAL QUANTITY: [Illegible]  
GROSS WEIGHT: [Illegible]  
NET WEIGHT: [Illegible]  
UNITS: [Illegible]  
DATE: [Illegible]  
TIME: [Illegible]

SHIP TO STATE: CA

\*This Shipping Order - Short Form - Carrier Must Submit Original Bill of Lading with Freight Bill.  
Carrier, Received, subject to the classifications and tariffs in effect on the date of the issue of this Bill of Lading, and all conditions herein contained, including conditions on back hereof.  
This is to certify that the above-named materials are properly classified, described, packaged, marked and labeled, and are in proper condition for transportation according to the applicable regulations of the Department of Transportation. Consignor: CHEVON PRODUCTS COMPANY  
Carrier has inspected and accepted the above-named material and certifies the cargo for safe packing, container for the transportation of this commodity under applicable Department of Transportation regulations.  
Signature of Carrier: [Illegible] Delivered By: (Full Signature) [Illegible]  
Received By: (Signature) [Illegible] Date: [Illegible]



TESORO PETROLEUM

TESORO

THIS IS TO CERTIFY THAT THE BELOW NAMED MATERIALS ARE PROPERLY CLASSIFIED, DESCRIBED, PACKAGED, MARKED AND LABELED, AND ARE IN PROPER CONDITION FOR TRANSPORTATION, ACCORDING TO APPLICABLE REGULATIONS OF THE D.O.T.

IF SHIPMENT INCLUDES UNLEADED GASOLINE THE PRODUCT CONTAINS NO MORE THAN 0.05 GRAMS OF LEAD PER GALLON AND NO MORE THAN 0.005 GRAMS OF PROSOPROGUS PER GALLON CONFORMING TO E.P.A. REGULATIONS - 40 CFR 80 -

RECEIVED SUBJECT TO TARIFFS OR CONTRACT IN EFFECT THIS DATE.

THE CARRIER CERTIFIES THAT THE CARGO TANK SUPPLIED FOR THIS SHIPMENT IS A PROPER CONTAINER FOR THE TRANSPORTATION OF THIS COMMODITY AS DESCRIBED BY THE SHIPPER.

TRUCK MANIFEST NUMBER 432038

SHIPPER CERTIFIES THAT THE GOODS COVERED BY THIS MANIFEST WERE PRODUCED IN COMPLIANCE WITH ALL REQUIREMENTS OF THE FAIR LABOR STANDARDS ACT, AS AMENDED.

SUBJECT TO SECTION 7 CONDITIONS OF APPLICABLE BILL OF LADING, IF THIS SHIPMENT IS TO BE DELIVERED TO THE CONSIGNEE WITHOUT RECOURSE ON THE CONSIGNOR, THE CONSIGNOR SHALL SIGN THE FOLLOWING STATEMENT:

THE CARRIER SHALL NOT MAKE DELIVERY OF THIS SHIPMENT WITHOUT PAYMENT OF FREIGHT AND ALL OTHER LAWFUL CHARGES.

SHIPPER / CONSIGNOR	
Signature	Date
RECEIVED QUANTITIES IN GOOD ORDER	
Signature	Date

THE DRIVER BY SIGNING THIS TICKET HEREBY CERTIFIES THAT TRANSPORT WAS LOADED AS SPECIFIED

Signature: *[Signature]* DATE: 6/3/2014

IN CASE OF TRANSPORTATION EMERGENCY INVOLVING PUBLIC SAFETY  
CALL CHEMTREC 800-424-9300 TESORO ACCT NO. 22013

SHIPPING DESCRIPTIONS  
NA 1993, Diesel Fuel, 3, P.G. III - 7501 GALLONS 2 Cargo Tank

SHIPPER	CUSTOMER:
TESORO REFINING AND MKTG. CO. / 19100 RIDGEWOOD PKWY SAN ANTONIO, TX 78259 (2000)	FALCON FUELS / 314861 (VARIOUS CALIF. DESTINATIONS) 7300 ALONDRA BLVD PARAMOUNT, CA 90723

SHIP FROM ADDRESS	DATE SHIPPED	PETROEX ID	MANIFEST NO.	MANIFEST DATE
Tesoro Logistics Operations, LLC 1930 E Pacific Coast Hwy, Wilmington, Ca,	6/3/2014	314861	432038	6/3/2014

PETROEX SPLC CODE	FACILITY REGISTRATION NO.	TERMINAL CONTROL NO.	PURCHASE ORDER NO.
883178	EPA # 4249-82914	T33CA4768	

FREIGHT TERMS	TRUCK NO./TRAILER	SHIP VIA - CARRIER NAME / I.D.	STARTED LOADING AT	DRIVER NO.	COMPLETED LOADING AT	LOAD POS.
PPD COLL	TRK# 00029 TLR# 0003a	BENNETT, MICHAEL MIKE ROCHE INC	06:04	ROH1MB	06:22	2

CODE	PRODUCT	KVP	OCT. RATING (R+m)/2	GROSS GALLONS	TEMP.	GRAV.	NET GALLONS
1866	CARB MV #2D (S-15PPM) ULSD (SEE FN 24)		0	7501	69.6	38.10	7467

FN-24 CALIFORNIA DIESEL FUEL. MAXIMUM 15PPM SULFUR. MEETS CALIFORNIA AIR RESOURCE BOARD AND FEDERAL REQUIREMENTS FOR ON HIGHWAY USE. UNDYED ULTRA-LOW SULFUR DIESEL #2 FUEL FOR USE IN ALL DIESEL VEHICLES AND ENGINES.

DRIVER INSTRUCTIONS / SPECIAL MESSAGES

Empty box for driver instructions or special messages.

PM

SUBJECT TO CORRECTION OF CLERICAL ERRORS

PAGE: 1 OF 1

CUSTOMER SIGNATURE

Vinvale Terminal #. 7902050  
EPA #0102002390  
8601 S. Garfield Ave  
South Gate, CA 90280, CA  
BILL OF LADING

Order Number:  
Direct Order:  
Order Date: 08/06/14  
Folio Number: 08/006  
Input Serial Number: 3907

BDL Number: 0977764  
DATE ENTRY: 08/06/14  
Load Start: 08/06/14 04:35  
Load End: 08/06/14 04:48  
Order Type: Rack  
Loadspot Number: 07

Stockholder/Customer : SHIP TO  
Type: Account #: 0418000  
0000100 : ISP Mnum: 90200418000  
Tesoro Refining & Marketing LLC : PO BOX 347  
9200418 : FALCON FUELS  
FALCON FUELS : 7300 ALONDRA BLVD SU  
Xata Facility Number : PARAMOUNT CA 90729  
Destination State:  
Retail or Petroex #: 90125775  
COT 18 UNBRANDED JOBBER  
P.O.#  
Req #

RECEIVED BY  
0009344 MIKE ROCHE INC  
SEAC #: R0AZ  
Tractor #:  
Trailer #: 43  
Trailer2 #: 35A  
DRIVER  
Signature:  
X  
00024651 ANGLIS, VICTOR Mike Roche

This is to certify that the herein named materials are properly classified, described, packaged, marked, and labeled, and are in proper condition for transportation, according to the applicable regulations of the Department of Transportation.

DELIVERY INSTRUCTIONS:

BDL COMMENTS: ABOVE SUPPLIER IS RESPONSIBLE FOR DESTINATION STATE TAX ON MOTOR FUEL  
FOR EMERGENCY INFORMATION, CALL: (800) 424-9300, CHEMTREC (Tesoro Customer number: 22019).

PRODUCT TOTALS

PRODUCT DESCRIPTION	GROSS GAL	NET GAL	TEMP	GRAV	OCT	RVP	NOX	MESSAGE NUMBER(S)
H2D MSG: NA1993, DIESEL FUEL, COMBUSTIBLE LIQUID III								
020017 ULS CAB DIESEL	7502	7410	85.7	38.0	40.00			ULS,20
TOTAL	7502	7410						

MSG # MESSAGE  
ULS MV Designated. 15 ppm sulfur (maximum) Undyed Ultra-Low Sulfur Diesel Fuel. For use in all diesel vehicles and engines.  
20 Product is #2 Diesel Fuel.

PRODUCT BY COMPARTMENT

LOT	COMP	RISER	PRODUCT ID	PRODUCT NAME	GROSS	NET	TEMP	GRAV
	01	71	020017	ULS CAB DIESEL	3499	3454	85.5	38.0
			020032	ULS CAB MOTOR VEHICLE	3499	3454	85.5	38.0
			020066	INNSPEC OL19181.X	0.4870	0.4870	85.5	46.0
	04	72	020017	ULS CAB DIESEL	1202	1202	85.0	38.0
			020032	ULS CAB MOTOR VEHICLE	1202	1202	85.0	38.0
			020066	INNSPEC OL19181.X	0.1710	0.1710	85.0	46.0
	06	72	020017	ULS CAB DIESEL	2701	2667	86.3	38.0
			020032	ULS CAB MOTOR VEHICLE	2701	2667	86.3	38.0
			020066	INNSPEC OL19181.X	0.3599	0.3599	86.3	46.0

CUSTOMER TAXES

NO CUSTOMER TAXES ON FILE



East Hynes Terminal #1 7750056  
 EPA #  
 5905 Paramount Blvd.  
 Long Beach, CA 90805, CA  
 BILL OF LADING

Order Import:  
 Direct Order:  
 Order Date: 08/19/14  
 Order Number: 08/19/14  
 Input Serial Number: 3954

BOL Number: 146973  
 DATE ENTRY: 08/19/14 21:20  
 Load Start: 08/19/14 21:13  
 Load End: 08/19/14 21:56  
 Order Type: Rack  
 Loadspot Number: 05

Shipholder/Container: SHIP TO  
 Types: Account #: 1496001  
 0000100: ISF name: 9022149000  
 Tesoro Refining & Marketing: SW TO OR CONTRACT  
 00149: TRUCK FUELS INT  
 FALCON FUELS INC: 7300 ALONDRA BLVD SU  
 Data Facility Number: FARAMOUNT CA, CA 90723-  
 Destination State: CA  
 Retail or Petroex #: 90195641  
 DOT 50 PPS NSL OC & PS & C&S  
 PO #  
 Req #

RECEIVED BY: 0009487 ELITE FUELS TRANSPORTATIO  
 SRC #: 2714  
 Tractor #:  
 Trailer #:  
 Trailer2 #: 71  
 DRIVER  
 Signaturer  
 X  
 05054402 CRISTOBAN, WARTAW

This is to certify that the herein named materials are properly classified, described, packaged, marked, and labeled, and are in proper condition for transportation, according to the applicable regulations of the Department of Transportation.

DELIVERY INSTRUCTIONS:

BOL COMMENTS: ABOVE SUPPLIER IS RESPONSIBLE FOR DESTINATION STATE TAX ON MOTOR FUEL  
 FOR EMERGENCY INFORMATION, CALL: (800) 424-9300, CHEMTREC (Tesoro R & M LLC Customer Number: 22013).

PRODUCT DESCRIPTION	GROSS GAL	NET GAL	TEMP	GRAV	OCT	RVP	XOYY	MESSAGE NUMBER(S)
HZD MSG: NA1993, DIESEL FUEL, COMBUSTIBLE LIQUID III	1	CARGO TANK						
020017 ULS CARB DIESEL	7492	7406	84.2	37.6	40.0			ULS,2D,BIOSA
TOTAL	7492	7406						

MSG # MESSAGE  
 ULS CARB KW Designated. 15 ppm sulfur (maximum) Undyed Ultra-Low Sulfur Diesel Fuel. For use in all diesel vehicles and engines.  
 Product is #2 Diesel Fuel.  
 May Contain Up To 5% Biodiesel

LOT	COMP	RISER	PRODUCT ID	PRODUCT NAME	GROSS	NET	TEMP	GRAV
	01	52	020017	ULS CARB DIESEL	2498	2473	81.4	37.6
			020232	ULS CARB MOTOR VEHICLE	2498	2473	81.4	37.6
			023666	INNOSPEC 0L19181.X	0.3320	0.3320	81.4	60.0
	02	52	020017	ULS CARB DIESEL	1998	1974	84.8	37.6
			020232	ULS CARB MOTOR VEHICLE	1998	1974	84.8	37.6
			023666	INNOSPEC 0L19181.X	0.2640	0.2640	84.8	60.0
	03	52	020017	ULS CARB DIESEL	998	986	86.0	37.6
			020232	ULS CARB MOTOR VEHICLE	998	986	86.0	37.6
			023666	INNOSPEC 0L19181.X	0.1360	0.1360	86.0	60.0
	05	52	020017	ULS CARB DIESEL	1998	1973	86.0	37.6
			020232	ULS CARB MOTOR VEHICLE	1998	1973	86.0	37.6
			023666	INNOSPEC 0L19181.X	0.2650	0.2650	86.0	60.0

NO CUSTOMER TANKS ON FILE

Pack Name Terminal #: 7790000

Order Number:

BOL Number: 1490001

EPA #

DATE ENTRY: 02/14

5905 Paramount Blvd.

Direct Order:

Load Start: 10/02/14 05:55

Long Beach, CA 90805, CA

Order Date: 10/02/14

Load End: 10/02/14 06:11

BILL OF LADING

FULL MESSAGE: 10/000

Order Type: Rack

Input Serial Number: 4868

Loadspot Number: 08

Ship To/Order Customer

SHIP TO

RECEIVED BY

Type:

Account #: 1495001

0009344 MIKE ROCHE INC

0000100

ISP Name: 90221 90001

SCAC #: RGAZ

Tesoro Refining & Marketing

C4 TO C4 CONTRACT

Tractor #:

0001401

FALCON CYCLE INC

Trailer #:

FALCON FUELS INC

7300 ALONDRA BLVD SU

Trailer2 #: 3A

Site Facility Number

PARAMOUNT CA, CA 90723-

DRIVER

Destination State: CA

Signature:

Retail or Petrox #: 90195641

X *[Signature]*  
05002661 BENNETT, MICHAEL

COT 50 PPS NSL GC & PS & C&IS

PO #

Req #

This is to certify that the herein named materials are properly classified, described, packaged, marked, and labeled, and are in proper condition for transportation, according to the applicable regulations of the Department of Transportation.

DELIVERY INSTRUCTIONS:

BOL COMMENTS: ABOVE SUPPLIER IS RESPONSIBLE FOR DESTINATION STATE TAX ON MOTOR FUEL

FOR EMERGENCY INFORMATION, CALL: (800) 424-9300, CHEMTREC (Tesoro R & M LLC Customer Number: 22013).

PRODUCT	DESCRIPTION	GROSS GAL	NET GAL	TEMP	GRAV	OCT	RVP	XOXY	MESSAGE NUMBER(S)
MZD MSG: NA1993,	DIESEL FUEL,3,COMBUSTIBLE LIQUID III	1	CARGO TANK						
020017	ULS CARB DIESEL	7497	7424	80.5	37.6	40.0			ULS,2D,B10SA
	TOTAL	7497	7424						

MSG # MESSAGE  
ULS, 15 ppm sulfur (maximum) undyed Ultra-Low Sulfur Diesel fuel. for use in all diesel vehicles and engines.

2D Product is #2 Diesel Fuel.  
P May Contain Up To 5% Biodiesel

LDI	COMP	RISER	PRODUCT ID	PRODUCT NAME	GROSS	NET	TEMP	GRAV
	01	23	020017	ULS CARB DIESEL	3499	3465	80.6	37.6
			020232	ULS CARB MOTOR VEHICLE	3499	3465	80.6	37.6
			023666	INNOPEC OL19181.X	0.4670	0.4670	80.6	60.0
	05	26	020017	ULS CARB DIESEL	1499	1484	81.5	37.6
			020232	ULS CARB MOTOR VEHICLE	1499	1484	81.5	37.6
			023666	INNOPEC OL19181.X	0.1970	0.1970	81.5	60.0
	06	26	020017	ULS CARB DIESEL	2499	2475	79.9	37.6
			020232	ULS CARB MOTOR VEHICLE	2499	2475	79.9	37.6
			023666	INNOPEC OL19181.X	0.3320	0.3320	79.9	60.0

CUSTOMER TANKS  
NO CUSTOMER TANKS ON FILE

**THE REVERSE SIDE FOR EMERGENCY RESPONSE INFORMATION**  
**In case of Product Emergency, Spill, Leak, Fire, Exposure, or Accident,**  
**CALL CHEMTREC, Day or Night, in the US at (800) 424-9300 or International at (703) 527-3887.**  
**Reference CHEMTREC Contract CCN222996**

150575 1 01 1554-000000-110514 0001504-085229700

Product Description	Gross Qty.	Net Qty.
---------------------	------------	----------

CHEVRON PRODUCTS COMPANY  
 6001 BRIDGEWAY, SUITE 100, DALLAS, TEXAS 75246  
 TEL: (214) 954-1000 FAX: (214) 954-1001  
 CHEMTREC: (800) 424-9300  
 CHEVRON PRODUCTS COMPANY  
 6001 BRIDGEWAY, SUITE 100, DALLAS, TEXAS 75246  
 TEL: (214) 954-1000 FAX: (214) 954-1001  
 CHEMTREC: (800) 424-9300

**\*This Shipping Order - Short Form - Carrier must Submit Original Bill of Lading with Freight Bill.**  
 Carrier Received, subject to the classification and tariffs in effect on the date of the issue of this Bill of Lading, and all conditions herein contained, including conditions on back hereof.  
 This is to certify that the above-named materials are properly classified, described, packaged, marked and labeled, and are in proper condition for transportation according to the applicable regulations of the Department of Transportation. **Consignor: CHEVRON PRODUCTS COMPANY**  
 Carrier has labeled and accepted the above-named materials and certifies the cargo tank is a proper container for the transportation of this commodity under applicable Department of Transportation regulations.

(Signature of Carrier) \_\_\_\_\_ Delivered By: (Full Signature) \_\_\_\_\_  
 Received By: (Signature) \_\_\_\_\_ Date: \_\_\_\_\_



CHEVRON PRODUCTS COMPANY  
RICHMOND REFINERY

PURPINE FUEL ENVIRO

RECEIVED

JAN 20 2014

Certificate of Analysis

Sample: 1122014-070001

Batch Produced: 11/2/2014 10:17:48

Report Generated: 11/2/2014 10:18:24

Plant: Che-Mid-Enviro-N-A

Batch No: NET 2014 04713

Label: ENNK-170

Storage: 211210

Method	Draw Type	Description	Unit of Measure	Result	Specification
D420	UPPER	APPEARANCE - CONDITION		0%	REF & CR
D420	MIDDLE	APPEARANCE - CONDITION		0%	REF & CR
D420	LOWER	APPEARANCE - CONDITION		0%	REF & CR
D152	AVERAGE	ACID NUMBER, IDEAL	mg KOH/g	0.003	MAX 0.01
D152	AVERAGE	AROMATIC SULFUR	mg/g	12.7	MAX 100
D152	AVERAGE	CLIPPING NUMBER, IDEAL	mg/g	24	REPORT
D152	AVERAGE	CLIPPING NUMBER, CRIST		40	REPORT
D152	UPPER	COLOR, SAYBOLT		16	REPORT
D152	MIDDLE	COLOR, SAYBOLT		16	REPORT
D152	LOWER	COLOR, SAYBOLT		16	REPORT
D152	AVERAGE	CORROSION, CUSTRIER, 12% INHAL TOBACCOING DE	%	0%	MAX 1
D152	UPPER	INHAL TOBACCOING DE	%	0%	REPORT
D152	LOWER	INHAL TOBACCOING DE	%	0%	REPORT
D152	UPPER	10% RECOVERED	%	66	MAX 100
D152	LOWER	10% RECOVERED	%	66	MAX 100
D152	UPPER	20% RECOVERED	%	173	REPORT
D152	LOWER	20% RECOVERED	%	173	REPORT
D152	UPPER	30% RECOVERED	%	196	REPORT
D152	LOWER	30% RECOVERED	%	196	REPORT
D152	UPPER	40% RECOVERED	%	209	REPORT
D152	LOWER	40% RECOVERED	%	209	REPORT
D152	UPPER	50% RECOVERED	%	211	REPORT
D152	LOWER	50% RECOVERED	%	211	REPORT
D152	UPPER	60% RECOVERED	%	205	MAX 100
D152	LOWER	60% RECOVERED	%	205	MAX 100
D152	UPPER	RESIDUE	mg/g	78	MAX 100
D152	LOWER	RESIDUE	mg/g	78	MAX 100
D152	UPPER	LOSS	mg/g	1.4	MAX 1.5
D152	LOWER	LOSS	mg/g	1.4	MAX 1.5
D152	UPPER	FLASH TAG CLOSED TOP	°C	41	MIN 41
D152	MIDDLE	FLASH TAG CLOSED TOP	°C	41	MIN 41
D152	LOWER	FLASH TAG CLOSED TOP	°C	41	MIN 41
D152	UPPER	FLASH TAG OPEN, 12 MINUTE	°C	46	MIN 39
D152	MIDDLE	FLASH TAG OPEN, 12 MINUTE	°C	46	MIN 39
D152	LOWER	FLASH TAG OPEN, 12 MINUTE	°C	46	MIN 39
D152	AVERAGE	FREEZE POINT	°C	1.9	MAX 1.0
D152	UPPER	GRAVITY	Density@15	44.1	1300-1310
D152	MIDDLE	GRAVITY	Density@15	44.1	1300-1310
D152	LOWER	GRAVITY	Density@15	44.1	1300-1310
D152	UPPER	DENSITY @15C	kg/m <sup>3</sup>	1.4055	1.375-1.400
D152	MIDDLE	DENSITY @15C	kg/m <sup>3</sup>	1.4056	1.375-1.400
D152	LOWER	DENSITY @15C	kg/m <sup>3</sup>	1.4056	1.375-1.400
D152	AVERAGE	COMPLIANCE, SHELL DE	mg/100ml	0.0	MAX 0.0
D152	AVERAGE	HYDROGEN CONTENT	%H <sub>2</sub>	13.1	MIN 12.5
D152	AVERAGE	HEAT OF COMBUSTION, NET	MJ/kg	43.7	MIN 42.8
D152	AVERAGE	INTERFAC TENSION		10	MAX 10
D152	AVERAGE	JET: FILTER PRESSURE, DRG, 100 275C	mm of Hg	0	MAX 250
D152	AVERAGE	WATER AFTER TUBE DENSIFY, 100 275C		0	MAX 0
D152	AVERAGE	ROSI COMPLIANCE, CARBON NUMBER 607		1.10002	REPORT
D152	AVERAGE	ROSI COMPLIANCE	mg/g	0.9	MAX 1.0
D152	AVERAGE	PARTICULATE, COMBUSTION DE	mg/g	1.0	MAX 1.0
D152	AVERAGE	PHOSPHORUS, IDEAL	mg/g	0	MAX 15
D152	AVERAGE	SULFUR, IDEAL	mg/g	2.0	MIN 1.0
D152	AVERAGE	SULFUR, IDEAL	mg/g	0.714	MAX 0.15
D152	AVERAGE	SULFUR, IDEAL	mg/g	0.001	MAX 0.002
D152	AVERAGE	VISCOSITY, KINEMATIC @15C	mm <sup>2</sup> /s	1.960	MAX 1.800



CHEVRON PRODUCTS COMPANY  
RICHMOND REFINERY

BURBINGHAM, ALABAMA

Certificate of Analysis

Sample# 141353432-00000  
Lab# 141353432-00000  
Report# 141353432-00000

Product: Motor, Nonnet, 15W  
Batch No: B-1, 2011-01-23  
Grade: TAN84758  
Sample: 26720

Method	Draw Type	Description	Unit of Measure	Result	Specification
01044	AVERAGE	WATER SEPARATION INDEX (MICROBIP)		99	MIN 96
01045	AVERAGE	MICROSEEP-ADITIVE CONCENTRATION		4	RETRACT
0401	AVERAGE	W/OIL OXIDANT (ACW) (PP)	mg/l	10.2	100-12500

This report does not include all items prescribed for analysis.

\_\_\_\_\_  
KRISTOPHER OLSON  
Customer Representative Date: 1/26/11

\* This report meets the requirements of Method 4001.01.  
\* All values are subject to confirmation of the result for a specific lot with a 3850 (1/1/11).  
\* The oil sample described here is a target sample of 10 mg.  
\* Revision 4/11



CHEVRON PRODUCTS COMPANY  
RICHMOND REFINERY

TURBINE FUEL, AVIATION

Certificate of Analysis

Sample: 259562  
 Date Issued: 07/24/14 10:22 AM  
 Report generated: 08/08/14 09:58 PM

Batch or Skid Number: N/A  
 Batch No: JET 2014-479  
 Assay: TANK 1794  
 Sample: 259562

Method	Draw Type	Description	Unit of Measure	Result	Specification
10178	UPPER	APPEARANCE (CONDITION)		00	00 & 01E
10179	MIDDLE	APPEARANCE (CONDITION)		00	00 & 01E
10180	LOWER	APPEARANCE (CONDITION)		00	00 & 01E
10182	AVERAGE	ACID NUMBER (COLE)	mg KOH/g	0.000	MAX 0.05
10183	AVERAGE	AROMATIC %	%	18.9	MAX 20.0
10184	AVERAGE	OLEFINS	%	8.4	REPORT
10187	AVERAGE	ETHANE NUMBER (ASTM)		14.0	REPORT
10186	UPPER	ETHYLENE SAYBOLT		-4	REPORT
10187	MIDDLE	ETHYLENE SAYBOLT		-4	REPORT
10188	LOWER	ETHYLENE SAYBOLT		-30	REPORT
10190	AVERAGE	EXPANSION (ASTM D6622)		15	MAX 1
10191	UPPER	INITIAL BOILING PT	°C	145	REPORT
10192	LOWER	INITIAL BOILING PT	°C	148	REPORT
10193	UPPER	1% RECOVERED	°C	160	MAX 190
10194	LOWER	1% RECOVERED	°C	166	MAX 190
10195	UPPER	2% RECOVERED	°C	171	REPORT
10196	LOWER	2% RECOVERED	°C	173	REPORT
10197	UPPER	3% RECOVERED	°C	176	REPORT
10198	LOWER	3% RECOVERED	°C	179	REPORT
10199	UPPER	5% RECOVERED	°C	188	REPORT
10200	LOWER	5% RECOVERED	°C	195	REPORT
10201	UPPER	END POINT	°C	200	MAX 300
10202	LOWER	END POINT	°C	204	MAX 300
10203	UPPER	RESIDU	wt%	1.0	MAX 1.5
10204	LOWER	RESIDU	wt%	0.1	MAX 1.0
10205	UPPER	LOSS	wt%	0.3	MAX 1.0
10206	LOWER	LOSS	wt%	0.2	MAX 1.0
10207	UPPER	FLASH (TAGLIASCO) °C	°C	24	MIN 41
10208	MIDDLE	FLASH (TAGLIASCO) °C	°C	33	MIN 41
10209	LOWER	FLASH (TAGLIASCO) °C	°C	43	MIN 41
10210	UPPER	FLASH (PENSKY) MARTEN	°C	36	MIN 36
10211	MIDDLE	FLASH (PENSKY) MARTEN	°C	47	MIN 36
10212	LOWER	FLASH (PENSKY) MARTEN	°C	46	MIN 36
10213	AVERAGE	200°C PCN	°C	30	MAX 30
10214	UPPER	GRAVITY	Dens @ 15°C	0.814	37.0 - 37.0
10215	MIDDLE	GRAVITY	Dens @ 15°C	0.814	37.0 - 37.0
10216	LOWER	GRAVITY	Dens @ 15°C	0.814	37.0 - 37.0
10217	UPPER	DENSITY @ 15C	kg/m <sup>3</sup>	813.95	0.775 - 0.820
10218	MIDDLE	DENSITY @ 15C	kg/m <sup>3</sup>	813.85	0.775 - 0.820
10219	LOWER	DENSITY @ 15C	kg/m <sup>3</sup>	813.99	0.775 - 0.820
10220	AVERAGE	NONEXISTENT STAMPEL	mg/100ml	1.0	MAX 7.0
10221	AVERAGE	HYDROGEN CONTENT	wt%	11.7	MIN 13.4
10222	AVERAGE	HEAT OF COMBUSTION, NET	MJ/kg	41.2	MIN 42.8
10223	AVERAGE	INTERFACE RATING		1	MAX 10
10224	AVERAGE	JET FUEL IMPRESSURE DROP @ 21°C	mmHg	0	MAX 25.0
10225	AVERAGE	JET FUEL FURT DEPOSITS CODE #00		1	MAX 7
10226	AVERAGE	JET FUEL COKER TUBE SERIAL NUMBER @ 1	...	...	REPORT
10227	AVERAGE	NAPHTHALENES	wt%	0.0	MAX 1.0
10228	AVERAGE	PARAFFINIC AROMATIZATION	wt%	0.1	MAX 1.0
10229	AVERAGE	IGNITION TIME	seconds	6	MAX 15
10230	AVERAGE	SMOKE POINT	mm	21.3	MIN 14.0
10231	AVERAGE	SULFUR TOTAL	weight %	0.0068	MAX 0.15
10232	AVERAGE	SULFUR MERCAPTAN	weight %	0.000	MAX 0.002
10233	AVERAGE	VISCOSITY - KINEMATIC @ 100C	cc/stk	0.870	MAX 0.900



CHEVRON PRODUCTS COMPANY  
RICHMOND REFINERY

LUBRICANT FUEL AVERAGES

Certificate of Analysis  
Sampled: 07/2014 07:55:00  
Date of Method: 07/2014 16:32:16  
Report Generated: 07/2014 16:38:59

Product Model Number: 550A  
Batch No.: 011201404968  
Vessel: TANK 1799  
Samples: 2/3/2014

Method	Draw Type	Description	Unit of Measure	Result	Specification
10-648	AVERAGE	WATER SEPARATION INDEX (MICROSECS)		90	MIN 90
10-648	AVERAGE	MICROSLIP ADDITIVE CONCENTRATION		90	REPORT
1-90	AVERAGE	ANTIOXIDANT (AVER) (PPM)	mg/L	2008	112 - 240

Exceeds that also exceeds all other prescribed requirements

MARK G. DECKERSON  
Company Representative

07/2014 16:38:34  
Date/Time

\* This product meets the requirements of MIL-OTL-8313 (R)  
\* Microslip Additive Concentration as the result of a hand blend with diluted fuel.  
\* C11, C12 and C13 show a trace of a single concentration of 17 mg/L  
Comments:

RECEIVED 12 FEB 2014



Report of Analysis

Client:	Defense Finance and Accounting Service	Client Reference Number:
Job Location:	Los Angeles, CA, USA	CARSON, CA
Our Reference Number:	US260-0020363	
Lab Reference Number:	2014-LOSA-000211	

Sample ID:	2014-LOSA-000211-013	Date Taken:	12-Feb-2014
Sample Designated As:	JP 8	Date Submitted:	12-Feb-2014
Vessel/Location:	"EMPIRE STATE"	Date Tested:	12-Feb-2014
Representing:	"EMPIRE STATE", Vessel Tanks Composite		

Method	Test	Result	Unit
ASTM D4052	API Gravity @ 60°F	40.9	API
ASTM D1415	Kinematic Viscosity @ -4°F @ 20"	5.147	mm <sup>2</sup> /s
ASTM D93	Procedure Used	A	
	Corrected Flash Point	53.9	°C
ASTM D2386	Freezing Point	55.0	°C
ASTM D3948	<b>MSEP Rating, Test A</b>	<b>87</b>	
ASTM D86	BP Recovery	145.9	°C
	10% Recovery	181.0	°C
	20% Recovery	188.5	°C
	50% Recovery	210.3	°C
	90% Recovery	243.3	°C
	FBP Recovery	264.5	°C
	Recovery	33.1	Vol %
	Residue	1.7	Vol %
	Total Recovery	90.3	Vol %
	Loss	0.7	Vol %
	Corrected Loss	1.7	Vol %
	Corrected Recovery	93.1	Vol %
	Corrected Total Recovery	99.3	Vol %
ASTM D5457	Sample Volume (Filtered)	3.3	L
	Total Particulates Contamination	0.18	mg/L
ASTM D3241	Test Temperature of Fuel	260	°C
	Heater Tube Deposit Color	0	
	Maximum Pressure Drop Across Filter	0	mm Hg
	Spill Fuel Volume	510	ml
ASTM D2624	Temperature	20.0	°C
	Electrical Conductivity	3	µS/M
ASTM D4294	Sulfur Content	0.0330	Wt %
ASTM D1318	Aromatics	15.2	Vol %

Signed: \_\_\_\_\_  
 Intertek  
 Angel Meza, Laboratory Supervisor

Date: \_\_\_\_\_





CHEVRON PRODUCTS COMPANY  
RICHMOND REFINERY

RECEIVED 4  
MAR  
2014

TURBINE FUEL - AVIA JP8

Certificate of Analysis

Sample: 14950413000  
Batch Number: 148263061144  
Report Generated: 11/25/14 09:18:19

Product Model Number: N/A  
Batch No.: 01120140439  
Version: 1.006.0790  
Sample: 2649379284695

Method	Draw Type	Description	Unit of Measure	Result	Specification
1315	UPPER	APPEARANCE / CONDITION		PASS	BPT & CLR
1316	MIDDLE	APPEARANCE / CONDITION		PASS	BPT & CLR
1317	LOWER	APPEARANCE / CONDITION		PASS	BPT & CLR
1318	AVERAGE	SEC NUMBER TOTAL	mg/kg (ppm)	0.07	MAX 0.10
1319	AVERAGE	AROMATICS	% (V)	71.6	MAX 25.0
1320	AVERAGE	GELINS	% (V)	1.5	REPORT
1321	AVERAGE	CELANE NUMBER, CALD		41.0	REPORT
1322	UPPER	COLOR, SAYBOLT		5	REPORT
1323	MIDDLE	COLOR, SAYBOLT		25	REPORT
1324	LOWER	COLOR, SAYBOLT		5	REPORT
1325	AVERAGE	CORROSION, FUNGICIDE		16	MAX 1
1326	UPPER	INITIAL BOILING PT	°C	148	REPORT
1327	LOWER	INITIAL BOILING PT	°C	142	REPORT
1328	UPPER	80% RECOVERED	%	103	MAX 20
1329	LOWER	80% RECOVERED	%	162	MAX 20
1330	UPPER	70% RECOVERED	%	175	REPORT
1331	LOWER	70% RECOVERED	%	172	REPORT
1332	UPPER	50% RECOVERED	%	199	REPORT
1333	LOWER	50% RECOVERED	%	199	REPORT
1334	UPPER	30% RECOVERED	%	244	REPORT
1335	LOWER	30% RECOVERED	%	247	REPORT
1336	UPPER	END POINT	°C	260	MAX 290
1337	LOWER	END POINT	°C	240	MAX 360
1338	UPPER	RESIDUE	% (V)	1.0	MAX 1.5
1339	LOWER	RESIDUE	% (V)	1.0	MAX 1.5
1340	UPPER	LOSS	% (V)	0.2	MAX 1.5
1341	LOWER	LOSS	% (V)	0.0	MAX 1.5
1342	UPPER	FLASH TAG CLOSED CUP	°C	42	MIN 40
1343	MIDDLE	FLASH TAG CLOSED CUP	°C	42	MIN 31
1344	LOWER	FLASH TAG CLOSED CUP	°C	43	MIN 31
1345	UPPER	FLASH PENSKY MARTIN	°C	47	MIN 39
1346	MIDDLE	FLASH PENSKY MARTIN	°C	47	MIN 39
1347	LOWER	FLASH PENSKY MARTIN	°C	47	MIN 39
1348	AVERAGE	FREEZE POINT	°C	149	MAX 147
1349	UPPER	GRAVITY	Degrees API	44.7	37.0 - 51.0
1350	LOWER	GRAVITY	Degrees API	44.7	37.0 - 51.0
1351	UPPER	DENSITY @ 15C	kg/l	0.8073	0.775 - 0.840
1352	MIDDLE	DENSITY @ 15C	kg/l	0.8073	0.775 - 0.840
1353	LOWER	DENSITY @ 15C	kg/l	0.8073	0.775 - 0.840
1354	AVERAGE	GUM EXISTENT / STEAM HEI	mg/100ml	1.2	MAX 30
1355	AVERAGE	HYDROGEN CONTENT	% (W)	15.6	MIN 13.4
1356	AVERAGE	HEAT OF COMBUSTION, NET	MBtu/g	45.2	MIN 47.8
1357	AVERAGE	INTERFACE RAINING		1	MAX 10
1358	AVERAGE	HTOT FILTER PRESSURE DROP, @ 250	mm of H <sub>2</sub> O	0	MAX 25.0
1359	AVERAGE	HTOT HEATER TUBE DEPOSITS, CODE 4-6		1	MAX 2
1360	AVERAGE	HTOT COCKER TUBE SERIAL NUMBER @ 2		13055750	REPORT
1361	AVERAGE	NAPHTHALENES	% (V)	1.1	MAX 1.0
1362	AVERAGE	PARTICULATE CONTAMINATION	mg/l	0.4	MAX 1.0
1363	AVERAGE	FILTRATION TIME	minutes	4	MAX 15
1364	AVERAGE	SMOKE POINT	mm	21.3	MIN 18.0
1365	AVERAGE	SULFUR, TOTAL	weight %	0.014	MAX 0.15
1366	AVERAGE	SULFUR, MERCAPTAN	weight %	0.001	MAX 0.002
1367	AVERAGE	VISCOSITY, KINEMATIC @ 50-100	cSt	3.9	MAX 8.0



CHEVRON PRODUCTS COMPANY  
RICHMOND REFINERY

TURBINE FUEL - AVIA IPS

Certificate of Analysis

Sampled: 2/17/2014 12:30:00  
 Analyzed: 2/18/2014 09:14:34  
 Report Generated: 2/18/2014 09:15:19

Product: Motor Grade: N/A  
 Batch No: 361-2014-04736  
 Vessel: TANK 1711  
 Sample: 2649179.16-0605

Method	Draw Type	Description	Unit of Measure	Result	Specification
0194S	AVERAGE	WATER SEPARATION INDEX (MICROSEP)		97	MIN 90
0194S	AVERAGE	MICROSEP ADDITIVE CONFIRMATION		99	MIN 90
1501	AVERAGE	ANTIOXIDANT (AVIA IPS)	ppm	2370	17.2-240

Results that do not meet or exceed prescribed requirements:

ALAN KWAN 2/18/2014 09:25:39  
 Company Representative Date/Time

1. This product is certified to meet the requirements of the following specifications:  
 2. This report is valid for 90 days from the date of analysis.  
 3. All measurements are in metric units unless otherwise specified.  
 4. All units are in SI units unless otherwise specified.



CHEVRON PRODUCTS COMPANY  
RICHMOND REFINERY

TURBINE OIL 3-AVLE IPS

Certificate of Analysis

Sampled 2/14/2013 09:00:00  
Tested on 02/14/2013 09:00:00  
Report generated 2/21/2013 11:58:17

Distribution Method Number 5-3  
Batch No. ICE 50475257  
Viscod 15861798  
Sample No. 500092049907

Method	Draw Type	Description	Unit of Measure	Result	Specification
D1176	UPPER	APPEARANCE - CONDITION		00	REF & CLR
D1176	MIDDLE	APPEARANCE - CONDITION		00	REF & CLR
D1176	LOWER	APPEARANCE - CONDITION		00	REF & CLR
D1241	AVERAGE	ACID NUMBER (DM)	mg KOH/g	0.004	MAX 0.015
D1242	AVERAGE	ACID VALUE (DM)	mg/g	0.004	MAX 0.015
D1310	AVERAGE	ASPHEN	vol %	1.2	REPORT
D1311	AVERAGE	CLASL NUMBER (CALC)		11.9	REPORT
D1381	UPPER	COLOR (SAYBOLT)		10	REPORT
D1381	MIDDLE	COLOR (SAYBOLT)		10	REPORT
D1381	LOWER	COLOR (SAYBOLT)		10	REPORT
D1397	AVERAGE	CORROSION (ASTM D1397)		0	MAX 1
D50	UPPER	INITIAL DROUING PT	°C	144	REPORT
D50	LOWER	INITIAL DROUING PT	°C	144	REPORT
D80	UPPER	10% RECOVERED	°C	103	MAX 208
D80	LOWER	10% RECOVERED	°C	103	MAX 208
D80	UPPER	20% RECOVERED	°C	125	REPORT
D80	LOWER	20% RECOVERED	°C	125	REPORT
D80	UPPER	30% RECOVERED	°C	169	REPORT
D80	LOWER	30% RECOVERED	°C	169	REPORT
D80	UPPER	40% RECOVERED	°C	218	REPORT
D80	LOWER	40% RECOVERED	°C	218	REPORT
D80	UPPER	50% RECOVERED	°C	248	REPORT
D80	LOWER	50% RECOVERED	°C	248	REPORT
D80	UPPER	60% RECOVERED	°C	250	MAX 300
D80	LOWER	60% RECOVERED	°C	250	MAX 300
D80	UPPER	70% RECOVERED	°C	301	MAX 350
D80	LOWER	70% RECOVERED	°C	301	MAX 350
D80	UPPER	80% RECOVERED	°C	348	REPORT
D80	LOWER	80% RECOVERED	°C	348	REPORT
D80	UPPER	90% RECOVERED	°C	348	REPORT
D80	LOWER	90% RECOVERED	°C	348	REPORT
D80	UPPER	RESIDUE	vol %	0.0	MAX 0.5
D80	LOWER	RESIDUE	vol %	0.0	MAX 0.5
D80	UPPER	LOSS	vol %	0.0	MAX 0.5
D80	LOWER	LOSS	vol %	0.0	MAX 0.5
D1094	UPPER	FLASH (ASTM D1094)	°C	43	MIN 41
D1094	MIDDLE	FLASH (ASTM D1094)	°C	47	MIN 41
D1094	LOWER	FLASH (ASTM D1094)	°C	40	MIN 41
D60	UPPER	FLASH PENSKY MARTENS	°C	40	MIN 39
D60	MIDDLE	FLASH PENSKY MARTENS	°C	40	MIN 39
D60	LOWER	FLASH PENSKY MARTENS	°C	40	MIN 39
D1094	AVERAGE	FREZZE POINT	°C	50	MAX 40
D1094	UPPER	GRAVITY	Degrees API	43.9	37.0 - 51.0
D1094	MIDDLE	GRAVITY	Degrees API	43.9	37.0 - 51.0
D1094	LOWER	GRAVITY	Degrees API	43.9	37.0 - 51.0
D4001	UPPER	DENSITY @ 15C	kg/l	0.8065	0.775 - 0.840
D4001	MIDDLE	DENSITY @ 15C	kg/l	0.8065	0.775 - 0.840
D4001	LOWER	DENSITY @ 15C	kg/l	0.8065	0.775 - 0.840
D1211	AVERAGE	OXALOXIDENI STEAMIEU	mg/100ml	1.8	MAX 2.0
D1243	AVERAGE	HYDROGEN COMPLET	wt %	1.6	MIN 13.4
D1243	AVERAGE	HEAT OF COMBUSTION (NET)	MJ/kg	42.1	MIN 42.8
D1094	AVERAGE	INTERFACE RATING		14	MAX 10
D1240	AVERAGE	BTOT FILTER PRESSURE DROP @ 175C	mm Hg	0	MAX 25.0
D1240	AVERAGE	BTOT HEATER TUBE DEPOSIT COEFF @ 175C		0	MAX 2
D1241	AVERAGE	BTOT COKER TUBE SERIAL NUMBER @ 175C		1355246	REPORT
D1840	AVERAGE	NAPHTHALENES	vol %	1.1	MAX 3.0
D5402	AVERAGE	PARTICULATE CONTAMINATION	mg/l	0.2	MAX 1.0
D1094	AVERAGE	FILTRATION TIME	minutes	0	MAX 15
D1322	AVERAGE	SMOKE POINT	mm	138	MIN 19.0
D7627	AVERAGE	SULFUR TOTAL	weight %	0.023	MAX 0.45
D7627	AVERAGE	SULFUR MERCAPTAN	weight %	0.000	MAX 0.002
D433	AVERAGE	VISCOSITY KINEMATIC @ 280C	cs	6.0	MAX 8.0



CHEVRON PRODUCTS COMPANY  
RICHMOND REFINERY

TURBINE FUEL ANALYSIS

Certificate of Analysis

Sample: 219629141430000  
 Method: 9661 - 0210141430402  
 Sample: 219629141430000

Reference: Method Number: N/A  
 Batch No: B7 210404757  
 Vessel: TANK 174  
 Sample: 2196291414300

Method	Draw Type	Description	Unit of Measure	Result	Specification
9661	AVERAGE	WATER SEPARATION INDEX (MICROSEPI)		98	MIN 90
9661	AVERAGE	SULFURIC ACID TITRIMETER CONFIRMATION		97	REF 90
9661	AVERAGE	ANTI-OXIDANT (+Active) IPS	mg/l	194	172 - 240

Verify that above result is maximum allowed requirement

STANDARD	21040475708
Compare Representative	Max 1000

1. The product being analyzed is not a Chevron product.  
 2. Method: Analytical Chemistry as the result on a small scale with a lot of 100.  
 3. The following table provides a general overview of the test.  
 Comments:



Shell Oil Products US  
Martinez Refinery  
PO BOX 711 Martinez, CA 94553

CERTIFICATE OF ANALYSIS

Consignee: Defense Logistics Agency  
cc: James Robinson - QAR Selby  
Attn: Jose Rosario - QAR

Shipping Date: 26-MAR-2014  
JP-8  
SMR Code 00646  
SMR Blend ID LC-JPB-14-0020  
Certification Date 18-MAR-2014 17:05  
Tender Name/Number DFSN-05-012  
Customer Order No 0047  
Sample Point TK-00335

Properties	Specifications	Units	Results
Appearance, C&B	Yes		Yes
D-6045, Saybolt Color			28.0
D-4052, API Grav @60F	37.0 <=> 51.0	API	40.0
D-4052, Density @15C	0.775 <=> 0.840	KG_L	0.824
D130, Corr Copper	1a: 1b		1a
D86, IBP		deg_C	158
D86, 10% Recovery	0 <=> 205	deg_C	176
D86, 20% Recovery		deg_C	182
D86, 50% Recovery		deg_C	204
D86, 90% Recovery		deg_C	246
D86, FBP	0 <=> 300	deg_C	274
D86, Loss	0.0 <=> 1.5	%vol	0.7
D86, Residue	0.0 <=> 1.5	%vol	1.2
D93, Flash Pt, PMCC	38 <=> 100	deg_C	49

Properties	Specifications	Units	Results
D5972, Freeze Point	-100 <=> -47	deg_C	-63
D1094, Water Rx Rating	1: 1b		1b
Mil-83133G, Particulate	0.00 <=> 1.00	MG/L	0.16
Filtration Time, min	0 <=> 30	min	8
D5453 Sulfur, Total	0 <=> 1500	ppm	22
D3242 Acidity, Total	0.000 <=> 0.015	MG_G	0.003
D1319 Aromatics-FIA	0 <=> 25	%vol	13.5
D1319 Olefins-FIA	0.0 <=> 5.0	%vol	0.8
D1319 Saturates-FIA		%vol	85.7
D1840 Naphthalenes	0.0 <=> 3.0	%vol	0.2
D1322 Smoke Point	19 <=> 50	mm	20.5
D3227 Mercaptan Sulfur	0.0000 <=> 0.0020	%wt	<0.0003
D3948 Micro Sep	80 <=> 100		90
D3241 Filt P Drop @275C	0 <=> 25	mm_Hg	0.0
D3241 Pre Dep Rating	0: <1: 1: <2: 2: <3		<0
D3241 Tube Color	normal		normal
D381 Existent Gum	0 <=> 7	mg/100ml	<1.0
D445 Viscosity @-20C	0.0 <=> 8.0	CS	5.0
D3343 Hydrogen Content	13.4 <=> 50.0		13.6
D3338 Heat of Combust	42.8 <=> 100.0	MJ/KG	43.1
D976 Cetane Index			36.6
Antioxidant, lb/MB	6.0 <=> 8.4	lb/MB	7.1
Corrosion Inhibitor	9.0 <=> 22.5	mg/L	10.6

- This product conforms to Military Spec MIL-DTL-83133G, Date 30 April 2010.
- Tests conducted according to ASTM Standard Test Methods and verified to be in accordance with the latest published version. The tests results were obtained from a sample taken from the storage tank before shipment. To the best of my knowledge, this product meets the requirements of ASTM-1655 for JP-8.
- Samples drawn according to ASTM D4057 and GR Manual "Sampling of Refinery Streams and Products"

  
 SMR REPRESENTATIVE



Shell Oil Products US  
Martinez Refinery  
PO BOX 711 Martinez, CA 94553

CERTIFICATE OF ANALYSIS

Consignee: Defense Logistics Agency  
cc: James Robinson - QAR Selby  
Attn: Jose Rosario - QAR

Shipping Date: 26-MAR-2014  
JP-8  
SMR Code 00646  
SMR Blend ID LC-JP8-14-0021  
Certification Date 25-MAR-2014 07:00  
Tender Name/Number DFSN-05-011  
Sample Point TK-00334

Properties	Specifications	Units	Results
Appearance, C&B	Yes		Yes
D-6045, Saybolt Color			27.6
D-4052, API Grav @60F	37.0 <=> 51.0	API	39.4
D-4052, Density @15C	0.775 <=> 0.840	KG_L	0.828
D130, Corr Copper	1a: 1b		1a
D86, IBP		deg_C	168
D86, 10% Recovery	0 <=> 205	deg_C	183
D86, 20% Recovery		deg_C	189
D86, 50% Recovery		deg_C	210
D86, 90% Recovery		deg_C	251
D86, FBP	0 <=> 300	deg_C	280
D86, Loss	0.0 <=> 1.5	%vol	0.8
D86, Residue	0.0 <=> 1.5	%vol	1.2
D93, Flash Pt, PMCC	38 <=> 100	deg_C	54

Properties	Specifications	Units	Results
D5972, Freeze Point	-100 <=> -47	deg_C	-57
D1094, Water Rx Rating	1: 1b		1b
Mil-83133G, Particulate	0.00 <=> 1.00	MG/L	0.08
Filtration Time, min	0 <=> 30	min	10
D5453 Sulfur, Total	0 <=> 1500	ppm	22
D3242 Acidity, Total	0.000 <=> 0.015	MG_G	0.003
D1319 Aromatics-FIA	0 <=> 25	%vol	11.6
D1319 Olefins-FIA	0.0 <=> 5.0	%vol	1.3
D1319 Saturates-FIA		%vol	87.1
D1840 Naphthalenes	0.0 <=> 3.0	%vol	0.2
D1322 Smoke Point	19 <=> 50	mm	20.8
D3227 Mercaptan Sulfur	0.0000 <=> 0.0020	%wt	<0.0003
D3948 Micro Sep	80 <=> 100		93
D3241 Filt P Drop @275C	0 <=> 25	mm_Hg	0.0
D3241 Pre Dep Rating	0: <1: 1: <2: 2: <3		<0
D3241 Tube Color	normal		normal
D381 Existent Gum	0 <=> 7	mg/100ml	<1.0
D445 Viscosity @-20C	0.0 <=> 8.0	CS	5.6
D3343 Hydrogen Content	13.4 <=> 50.0		13.6
D3338 Heat of Combust	42.8 <=> 100.0	MJ/KG	43.1
D976 Cetane Index			37.7
Antioxidant, lb/MB	6.0 <=> 8.4	lb/MB	7.0
Corrosion Inhibitor	9.0 <=> 22.5	mg/L	9.6

- This product conforms to Military Spec MIL-DTL-83133G, Date 30 April 2010.
- Tests conducted according to ASTM Standard Test Methods and verified to be in accordance with the latest published version. The tests results were obtained from a sample taken from the storage tank before shipment. To the best of my knowledge, this product meets the requirements of ASTM-1655 for JP-8.
- Samples drawn according to ASTM D4057 and GR Manual "Sampling of Refinery Streams and Products"

  
SMR REPRESENTATIVE



**Benicia Refinery Laboratory**

Authorized

**Final Analysis Report Proprietary**

Product: MILITARY JET FUEL  
 Tank No: 1772  
 Formula: JP8 JET 8  
 Product Spec: JET FUEL  
 Contract No: SP0600-13-D-0464

Sample ID: 1140306045  
 Sample Date: 31-March-2014  
 Sample Time: 3:23  
 Blend No: 14J- 022

Test	Component	Method of Test	Test Results	UOM
WKMNSHIP	WORKMANSHIP	VISUAL	Bright and Clear	Pass/Fail
C SAY 6045	SAYBOLT COLOR	ASTM D 6045	> 30	Color
HAZE JET	PHOTO NUMBER	ASTM D 4176	1	
HAZE JET	APPEARANCE	ASTM D 4176	Bright and Clear	
API DMA DT	API GRAVITY MAX DLTA	CALCULATION	.0	API
SPGR DMA	API GRAVITY 60 DEG F	ASTM D 4052	41.3	API
DENS 15C	DENSITY	ASTM D 4052	.819	q/mL
T ACDTY JT	ACID NUMBER	ASTM D 3242	.004	mg KOH/g
FIA	AROMATICS-FIA	ASTM D 1319	18.7	Vol %
FIA	OLEFINS-FIA	ASTM D 1319	2.1	Vol %
FIA	SATURATES-FIA	ASTM D 1319	79.2	Vol %
DOCTOR	DOCTOR TEST	ASTM D 4952	Negative	
S XRAY2622	SULFUR	ASTM D 2622	.03	Mass %
H CONT3343	HYDROGEN CONTENT	ASTM D 3343	13.6	mass %
DIST REC C	IBP	ASTM D 86	178	Deq C
DIST REC C	T10 REC	ASTM D 86	194	Deq C
DIST REC C	T20 REC	ASTM D 86	201	Deq C
DIST REC C	T50 REC	ASTM D 86	216	Deq C
DIST REC C	T90 REC	ASTM D 86	241	Deq C
DIST REC C	FBP	ASTM D 86	259	Deq C
DIST REC C	RESIDUE	ASTM D 86	1.0	%
DIST REC C	LOSS	ASTM D 86	.9	%
DIST REC C	IBP TIME	ASTM D 86	8	Min
DIST REC C	FBP TIME	ASTM D 86	3	Min
FLS PM DLT	FLASH PM MAX DELTA	Calculation	4.0	Deq F
FLS PM C	PROCEDURE	ASTM D 93	A	
FLS PM C	FLASH POINT PM	ASTM D 93	142	Deq F
FLS PM C	FLASH POINT PM C	ASTM D 93	61	Deq C
FRZ PH	FREEZE POINT	ASTM D 5972	-49	Deq C
VS K -20C	VISCOSITY	ASTM D 445	5.6	cSt
HOC CORRECTED	NET HEAT COMBUSTION	ASTM D 3338	43.1	MJ/kg
SMOKE PT	SMOKE POINT	ASTM D 1322	20.0	mm
NAPHTHA	NAPHTHALENES	ASTM D 1840	.9	Vol %
CI JET	CETANE INDEX	ASTM D 976	43.6	
JFTOT 275C	FILTER DELTA P	ASTM D 3241	0	mm Hq
JFTOT 275C	TUBE INSPECTION	ASTM D 3241	Normal	
JFTOT 275C	TUBE RATING	ASTM D 3241	< 1	
CORR JET	CORROSION 212F 2HOUR	ASTM D 130	1.1	Color scl
GUM EXST	EXISTENT GUM CONTENT	ASTM D 381	1.4	mg/100 ml
PC RESTRCT	FILTRATION TIME	83133G	5	MIN
PC RESTRCT	PARTICULATES	83133G	.1	mg/L
PC RESTRCT	VACUUM PRESSURE	83133G	25	in Hq
WATER RCT	INTERFACE RATING	ASTM D 1094	1B	
MSEP NEAT	MSEP-A RATING	ASTM D 3948	98	
MSEP ADDAT	MSEP-A RATING	ASTM D 3948	92	
MSEP ADDAT	SAMPLE TEMPERTURE	ASTM D 3948	68	Deq F
ANTI OX JT	QUANTITY	Data Entry	29.77	kb
ANTI OX JT	ANTIOXIDANT	Data Entry	6.9	lb/kb

Tests conducted according to ASTM Standard Test Methods are routinely verified to be in compliance with the latest published versions. Minor changes may be made where they have no material impact on the test results and are necessitated by reasons such as safety, environmental standards, and method effectiveness. The following test results were obtained on a sample taken from the tank prior to shipment. To the best of my knowledge this product meets the requirements of ASTM D 1655 latest revision for Jet A.

(A) Automatic Instrument  
 Reviewed by \_\_\_\_\_

LAB Manager

Approved by: \_\_\_\_\_

Fuels Coordinator



Martinez Refinery  
PO BOX 711 Martinez, CA 94553  
Shell Oil Products US

CERTIFICATE OF ANALYSIS

Consignee: Defense Logistics Agency  
cc: James Robinson - QAR Selby  
Attn: Jose Rosario - QAR

Shipping Date: 10-MAR-2014  
Product: JP-8  
SMR Code: 00646  
SMR Blend ID: LC-JP8-14-0017  
Certification Date: 06-MAR-2014 12:19  
Tender Name/Number: DFSN-05-010  
Sample Point: TK-00335

<u>Properties</u>	<u>Specifications</u>	<u>Units</u>	<u>Results</u>
Appearance, C&B	Yes		Yes
D-6045, Saybolt Color			28.0
D-4052, API Grav @60F	37.0 ⇔ 51.0	API	41.1
D-4052, Density @15C	0.775 ⇔ 0.840	KG_L	0.819
D130, Corr Copper	1a: 1b		1a
D86, IBP		deg_C	159
D86, 10% Recovery	0 ⇔ 205	deg_C	173
D86, 20% Recovery		deg_C	177
D86, 50% Recovery		deg_C	198
D86, 90% Recovery		deg_C	245
D86, FBP	0 ⇔ 300	deg_C	279
D86, Loss	0.0 ⇔ 1.5	%vol	0.3
D86, Residue	0.0 ⇔ 1.5	%vol	1.2
D93, Flash Pt, PMCC	38 ⇔ 100	deg_C	48
Page 1 of 2			
D5972, Freeze Point	-100 ⇔ -47	deg_C	-56
D1094, Water Rx Rating	1: 1b		1b
Mil-83133G, Particulate	0.00 ⇔ 1.00	MG/L	0.25
Filtration Time, min	0 ⇔ 30	min	8
D5453 Sulfur, Total	0 ⇔ 1500	ppm	16

<u>Properties</u>	<u>Specifications</u>	<u>Units</u>	<u>Results</u>
D3242 Acidity, Total	0.000 <=> 0.015	MG_G	0.002
D1319 Aromatics-FIA	0 <=> 25	%vol	11.5
D1319 Olefins-FIA	0.0 <=> 5.0	%vol	0.6
D1319 Saturates-FIA		%vol	87.9
D1840 Naphthalenes	0.0 <=> 3.0	%vol	0.2
D1322 Smoke Point	19 <=> 50	mm	22.3
D3227 Mercaptan Sulfur	0.0000 <=> 0.0020	%wt	<0.0003
D3948 Micro Sep	80 <=> 100		96
D3241 Filt P Drop @275C	0 <=> 25	mm_Hg	0.0
D3241 Pre Dep Rating	0: <1: 1: <2: 2: <3		<0
D3241 Tube Color	normal		normal
D381 Existent Gum	0 <=> 7	mg/100ml	<1.0
D445 Viscosity @-20C	0.0 <=> 8.0	CS	4.6
D3343 Hydrogen Content	13.4 <=> 50.0		13.7
D3338 Heat of Combust	42.8 <=> 100.0	MJ/KG	43.2
D976 Cetane Index			35.6
Antioxidant, lb/MB	6.0 <=> 8.4	lb/MB	7.0
Corrosion Inhibitor	9.0 <=> 22.5	mg/L	10.4

- This product conforms to Military Spec MIL-DTL-83133G, Date 30 April 2010.
- Tests conducted according to ASTM Standard Test Methods and verified to be in accordance with the latest published version. The tests results were obtained from a sample taken from the storage tank before shipment. To the best of my knowledge, this product meets the requirements of ASTM-1655 for JP-8.
- Samples drawn according to ASTM D4057 and GR Manual "Sampling of Refinery Streams and Products"

  
 \_\_\_\_\_  
 SMR REPRESENTATIVE

Approved: Salvador, Edilberto S SOPUS-OMU/3



CHEVRON PRODUCTS COMPANY  
RICHMOND REFINERY

FURNACE FUEL, SVAJ37K

RECEIVED  
APR 21 2014  
2014

Certificate of Analysis

Sample # 411571-47445-00

Batch Number: 4072944191105

Report Generated: 4/17/2014 20:25:16

Predictive Model Number: N/A

Batch No. (EJ) 2014-04722

Vessel: TANK 1791

Samples: 20/151

Method	Draw Type	Description	Unit of Measure	Result	Specification
D1176	UPPER	APPEARANCE / CONDITION		PASS	BRI & CLR
D1176	MIDDLE	APPEARANCE / CONDITION		PASS	BRI & CLR
D1176	LOWER	APPEARANCE / CONDITION		PASS	BRI & CLR
D3243	AVERAGE	ACID NUMBER (TOTAL)	mg KOH/g	0.04	MAX 0.05
D1306	AVERAGE	AROMATICS	vol %	29.2	MAX 25.0
D1319	AVERAGE	OLEFINS	vol %	1.0	REPORT
D1240	AVERAGE	CLASANE NUMBER (CMC)		0.6	REPORT
D136	UPPER	COLOR, SAYBOLT		0.0	REPORT
D136	MIDDLE	COLOR, SAYBOLT		0.0	REPORT
D136	LOWER	COLOR, SAYBOLT		0.0	REPORT
D137	AVERAGE	CORROSION, CUMULATIVE @ 212F		0.0	MAX 1
D87	UPPER	INITIAL DROUING (%)	%	0.8	REPORT
D87	LOWER	INITIAL DROUING (%)	%	1.0	REPORT
D87	UPPER	1% RECOVERED	%	16.1	MAX 20%
D87	LOWER	1% RECOVERED	%	16.1	MAX 20%
D87	UPPER	2% RECOVERED	%	17.1	REPORT
D87	LOWER	2% RECOVERED	%	17.8	REPORT
D87	UPPER	3% RECOVERED	%	18.9	REPORT
D87	LOWER	3% RECOVERED	%	19.4	REPORT
D87	UPPER	4% RECOVERED	%	21.7	REPORT
D87	LOWER	4% RECOVERED	%	23.7	REPORT
D87	UPPER	5% RECOVERED	%	23.2	MAX 30%
D87	LOWER	5% RECOVERED	%	23.8	MAX 30%
D87	UPPER	RESIDUE	vol %	1.1	MAX 1.5
D87	LOWER	RESIDUE	vol %	1.1	MAX 1.5
D86	UPPER	LOSS	vol %	0.8	MAX 1.5
D86	LOWER	LOSS	vol %	0.6	MAX 1.5
D85	UPPER	FLASH TAG CLOSED CUP	%	41	MIN 41
D85	MIDDLE	FLASH TAG CLOSED CUP	%	41	MIN 41
D85	LOWER	FLASH TAG CLOSED CUP	%	43	MIN 41
D93	UPPER	FLASH PENSKY-MARTEL	%	46	MIN 33
D93	MIDDLE	FLASH PENSKY-MARTEL	%	46	MIN 33
D93	LOWER	FLASH PENSKY-MARTEL	%	45	MIN 33
D1328	AVERAGE	FRICTION POINT	%	49	MAX 42
D1018	UPPER	GRAVITY	Degrees API	40.0	35.0 - 51.0
D1018	MIDDLE	GRAVITY	Degrees API	40.0	35.0 - 51.0
D1018	LOWER	GRAVITY	Degrees API	40.0	35.0 - 51.0
D1032	UPPER	DENSITY @ 15C	kg/l	0.8091	0.775 - 0.840
D1032	MIDDLE	DENSITY @ 15C	kg/l	0.8093	0.775 - 0.840
D1032	LOWER	DENSITY @ 15C	kg/l	0.8093	0.775 - 0.840
D104	AVERAGE	GUM EXISTENT - STEAM Btl	mg/100ml	0.4	MAX 7.0
D1043	AVERAGE	HYDROGEN CONTENT	wt %	13.5	MIN 13.4
D1036	AVERAGE	HEAT OF COMBUSTION, NET	kJ/kg	43.1	MIN 42.8
D1094	AVERAGE	INTERFACE RATING		4	MAX 10
D1210	AVERAGE	JET-1 FILTER PRESSURE DROP @ 275F	mmHg/Hr	0	MAX 25.0
D1201	AVERAGE	JET-1 HEATER TUBE DEPOSITS, CODE 3-50		1	MAX 7
D1201	AVERAGE	JET-1 CORROSION SERIAL NUMBER 967		1460768	REPORT
D130	AVERAGE	NAPHTHALINES	vol %	0.9	MAX 1.0
D1457	AVERAGE	PARTICULATE CONTAMINATION	mg/g	0.2	MAX 1.0
D1482	AVERAGE	FILTRATION TIME	minutes	0	MAX 15
D1122	AVERAGE	SMOKE POINT	mm	20.5	MIN 19.0
D2627	AVERAGE	SULFUR, TOTAL	weight %	0.0238	MAX 0.15
D1227	AVERAGE	SULFUR, MERCAPTAN	weight %	0.001	MAX 0.002
D105	AVERAGE	VISCOSITY, KINEMATIC @ 50-200F	cent	3.0	MAX 8.0



CHEVRON PRODUCTS COMPANY  
RICHMOND REFINERY

TURBINE FUEL - AVIA JP8

Certificate of Analysis

Sampled: 4/17/04 04:43:00  
Batch Produced: 4/17/04 19:03:00  
Report Generated: 4/17/04 20:25:10

Productive Model Number: 803  
Batch No. (UCL): 204-02772  
Vessel: TANK 1598  
Sample: 2968153

Method	Draw Type	Description	Unit of Measure	Result	Specification
U998X	AVERAGE	WATER SEPARATION INDEX (MICROSEPT)		93	MIN 99
U998X	AVERAGE	MICROSEPARATIVE CONDUCTIVITY		34	RI-P093
U998X	AVERAGE	ANIONIC DIBENZYLACETONE IPS	mg/L	177	UCL 200

Verify that all test material has been properly sampled.

ROGER H SCHUBERT

4/17/04 20:26:21

Control Representative

1060766

- \* This report meets the requirements of MIL-DTL-8838E.
- \* Microsep Address Conductivity is the result only (sanitized with model UCL)
- \* UCL reported has margin at a target concentration of 17 mg/L.

Comments

Updated 04/20/04



CHEVRON PRODUCTS COMPANY  
RICHMOND REFINERY

TURBINE FUEL (AVIA 3P8)

Certificate of Analysis

Sample: 411251576-0060  
Product Name: 41180704002951  
Report Generated: 4/18/2013 02:30:32

Production Model Number: 3CA  
Batch No.: B-1-2013-01794  
Vessel: TANK-1797  
Sample: 568346

Method	Draw Type	Description	Unit of Measure	Result	Specification
04176	UPPER	APPEARANCE / CONDITION		PASS	DTI & CUB
04176	MIDDLE	APPEARANCE / CONDITION		PASS	DTI & CUB
04176	LOWER	APPEARANCE / CONDITION		PASS	DTI & CUB
01247	AVERAGE	ACID NUMBER/TOTAL	mg KOH/g	0.004	MAX 0.3
01000	AVERAGE	AROMATICS	wt %	21.4	MAX 30%
01100	AVERAGE	CELENS	wt %	2.0	REPORT
04187	AVERAGE	CELANE NUMBER/CALC		43.4	REPORT
01196	UPPER	COLOR SAYBOLT		631	REPORT
01196	MIDDLE	COLOR SAYBOLT		634	REPORT
01196	LOWER	COLOR SAYBOLT		636	REPORT
01130	AVERAGE	CORROSION 5% S.D.P. @ 2.2H		0E	MAX 1
089	UPPER	INITIAL BEHINDING PT	%	152	REPORT
089	LOWER	INITIAL BEHINDING PT	%	157	REPORT
086	UPPER	10% RECOVERED	%	166	MAX 205
086	LOWER	10% RECOVERED	%	163	MAX 205
088	UPPER	20% RECOVERED	%	171	REPORT
088	LOWER	20% RECOVERED	%	174	REPORT
088	UPPER	30% RECOVERED	%	169	REPORT
088	LOWER	30% RECOVERED	%	179	REPORT
089	UPPER	40% RECOVERED	%	201	REPORT
086	LOWER	40% RECOVERED	%	218	REPORT
088	UPPER	END POINT	%	253	MAX 300
088	LOWER	END POINT	%	25	MAX 300
088	UPPER	RESIDUE	wt %	1.00	MAX 1.5
088	LOWER	RESIDUE	wt %	1.2	MAX 1.5
088	UPPER	LOSS	wt %	0.96	MAX 1.5
088	LOWER	LOSS	wt %	0.9	MAX 1.5
086	UPPER	FLASH TAG/CLOSED CUP	%	42	MIN 41
086	MIDDLE	FLASH TAG/CLOSED CUP	%	42	MIN 41
086	LOWER	FLASH TAG/CLOSED CUP	%	42	MIN 41
080	UPPER	FLASH PENSKY MARTIN	%	48	MIN 49
082	MIDDLE	FLASH PENSKY MARTIN	%	41	MIN 49
083	LOWER	FLASH PENSKY MARTIN	%	44	MIN 49
04183	AVERAGE	FREEZE POINT	%	-50	MAX -47
04002	UPPER	GRAVITY	Degrees API	43.8	37.0 - 51.0
04002	MIDDLE	GRAVITY	Degrees API	43.9	37.0 - 51.0
04002	LOWER	GRAVITY	Degrees API	43.8	37.0 - 51.0
04002	UPPER	DENSITY @ 15C	kg/l	0.8066	0.775 - 0.840
04002	MIDDLE	DENSITY @ 15C	kg/l	0.8066	0.775 - 0.840
04002	LOWER	DENSITY @ 15C	kg/l	0.8066	0.775 - 0.840
0800	AVERAGE	GUM EXISTENT SULAM BT	mg/100ml	1.0	MAX 1.0
0800	AVERAGE	HYDROGEN CONTENT	wt %	17.5	MIN 13.4
0800	AVERAGE	HEAT OF COMBUSTION NET	MJ/kg	43.4	MIN 42.8
01062	AVERAGE	INTERFACE RATING		4	MAX 10
05241	AVERAGE	JET OF FUEL FOR PRESSURE DROP @ 279	mm of Hg	0	MAX 25.0
05250	AVERAGE	JET OF HEATER TUB DEPOSITS/CABLE #61		1	MAX 2
00207	AVERAGE	JET OF COKE/TURBINE SERIAL NUMBER 3.2	1-3/32"	REPORT	
01040	AVERAGE	NAPHTHALENES	wt %	0.5	MAX 3.0
05402	AVERAGE	PARTICULATE CONCENTRATION	mg/l	0.2	MAX 1.0
05402	AVERAGE	FILTRATION TIME	minutes	5	MAX 15
01102	AVERAGE	SMOKE POINT	mm	16.8	MIN 19.0
02602	AVERAGE	SULFUR TOTAL	weight %	0.006	MAX 0.15
03247	AVERAGE	SOLIDR, MERCAPTAN	weight %	0.000	MAX 0.002
04407	AVERAGE	VISCOSITY KINEMATIC @ 30C	cs	3.8	MAX 8.0



CHEVRON PRODUCTS COMPANY  
RICHMOND REFINERY

TURBINE FUEL ANALYSIS

Certificate of Analysis

Sample: 4112014190609  
Inlet Parameter: TURBINE FUEL 2014  
Report Generated: 11/20/14 02:30:52

Inductive MGR Number: 85A  
Batch No: B-1-2014-04-54  
Yield: 1518.136  
Sample: 266419

Method	Draw Type	Description	Unit of Measure	Result	Specification
D9906	AVERAGE	WATER SEPARATION INDEX (MICROSEPI)		92	MIN 90
D9942	AVERAGE	MICROSEPI ADDITIVE CONCENTRATIONS		94	91-95% <sup>1</sup>
EAP	AVERAGE	ANTI-OXIDANT (AC) (ppb) <sup>2</sup>	mg/l	19.7	17.2-24.0 <sup>3</sup>

1. Reference to ASTM method does not imply requirements.

ROBERT HINSOBERG

11/20/14 02:30:48

Company Representative

Date/Time

- \* This product meets the requirements of MIL-PTL-80130.
  - \*\* Actual Agitation/Seal Lubrication will be result as a woodhead with additional.
  - \*\* Chlorine level downstream at average concentration of 17 mg/l.
- Comments:



Shell Oil Products US  
 Martinez Refinery  
 PO BOX 711 Martinez, CA 94553

**CERTIFICATE OF ANALYSIS**

5/29/2014

Consignee: Defense Logistics Agency  
 cc: James Robinson - QAR Selby  
 Attn: Jose Rosario - QAR

Shipping Date: 29-MAY-2014  
 JP-8  
 SMR Code 00646  
 SMR Blend ID LC-JP8-14-0040  
 Certification Date 27-MAY-2014 11:53  
 Tender Name/Number DFSN-05-720  
 Customer Order No 0066  
 Sample Point TK-00337

Properties	Specifications	Units	Results
Appearance, C&B	Yes		Yes
D-6045, Saybolt Color			+28.6
D-4052, API Grav @60F	37.0 <=> 51.0	API	41.0
D-4052, Density @15C	0.775 <=> 0.840	KG_L	0.820
D130, Corr Copper	1a: 1b		1a
D86, IBP		deg_C	157
D86, 10% Recovery	0 <=> 205	deg_C	174
D86, 20% Recovery		deg_C	179
D86, 50% Recovery		deg_C	199
D86, 90% Recovery		deg_C	245
D86, FBP	0 <=> 300	deg_C	275
D86, Loss	0.0 <=> 1.5	%vol	0.3
D86, Residue	0.0 <=> 1.5	%vol	1.3
D93, Flash Pt, PMCC	38 <=> 100	deg_C	49



Properties	Specifications	Units	Results
D5972, Freeze Point	-100 <=> -47	deg_C	-59
D1094, Water Rx Rating	1: 1b		1b
Mil-83133G, Particulate	0.00 <=> 1.00	MG/L	0.27
Filtration Time, min	0 <=> 30	min	7
D5453 Sulfur, Total	0 <=> 1500	ppm	22
D3242 Acidity, Total	0.000 <=> 0.015	MG_G	0.002
D1319 Aromatics-FIA	0 <=> 25	%vol	13.2
D1319 Olefins-FIA	0.0 <=> 5.0	%vol	1.2
D1319 Saturates-FIA		%vol	85.6
D1840 Naphthalenes	0.0 <=> 3.0	%vol	0.2
D1322 Smoke Point	19 <=> 50	mm	21.4
D3227 Mercaptan Sulfur	0.0000 <=> 0.0020	%wt	<0.0003
D3948 Micro Sep	80 <=> 100		92
D3241 Filt P Drop @275C	0 <=> 25	mm_Hg	0.0
D3241 Pre Dep Rating	0: <1: 1: <2: 2: <3		<1
D3241 Tube Color	normal		normal
D381 Existent Gum	0 <=> 7	mg/100ml	<1.0
D445 Viscosity @-20C	0.0 <=> 8.0	CS	4.6
D3343 Hydrogen Content	13.4 <=> 50.0		13.7
D3338 Heat of Combust	42.8 <=> 100.0	MJ/KG	43.1
D976 Cetane Index			36.1
Antioxidant, lb/MB	6.0 <=> 8.4	lb/MB	7.7
Corrosion Inhibitor	9.0 <=> 22.5	mg/L	9.3

- This product conforms to Military Spec MIL-DTL-83133G, Date 30 April 2010.
- Tests conducted according to ASTM Standard Test Methods and verified to be in accordance with the latest published version. The tests results were obtained from a sample taken from the storage tank before shipment. To the best of my knowledge, this product meets the requirements of ASTM-1655 for JP-8.
- Samples drawn according to ASTM D4057 and GR Manual "Sampling of Refinery Streams and Products"

---

SMR REPRESENTATIVE

**Benicia Refinery Laboratory**

Authorized

**Final Analysis Report Proprietary**

Product: MILITARY JET FUEL  
 Tank No: 1778  
 Formula: JP8 JET 8  
 Product Spec: JET FUEL  
 Contract No: SP0600-13-D-0464

Sample ID: 1140704150  
 Sample Date: 18-July-2014  
 Sample Time: 14:15  
 Blend No: 14J- 049

Test	Component	Method of Test	Test Results	UOM
WKMNSHIP	WORKMANSHIP	VISUAL	Bright and Clear	Pass/Fail
C SAY 6045	SAYBOLT COLOR	ASTM D 6045	21	Color
HAZE JET	PHOTO NUMBER	ASTM D 4176	1	
HAZE JET	APPEARANCE	ASTM D 4176	Bright and Clear	
API DMA DT	API GRAVITY MAX DLTA	CALCULATION	.0	API
SPGR DMA	API GRAVITY 60 DEG F	ASTM D 4052	39.2	API
DENS 15C	DENSITY	ASTM D 4052	.828	g/mL
T ACDTY JT	ACID NUMBER	ASTM D 3242	.006	mg KOH/g
FIA	AROMATICS-FIA	ASTM D 1319	15.3	Vol %
FIA	OLEFINS-FIA	ASTM D 1319	1.6	Vol %
FIA	SATURATES-FIA	ASTM D 1319	83.1	Vol %
S XRAY2622	SULFUR	ASTM D 2622	.08	Mass %
H CONT3343	HYDROGEN CONTENT	ASTM D 3343	13.6	mass %
DIST REC C	IBP	ASTM D 86	179	Deq C
DIST REC C	T10 REC	ASTM D 86	196	Deq C
DIST REC C	T20 REC	ASTM D 86	205	Deq C
DIST REC C	T50 REC	ASTM D 86	222	Deq C
DIST REC C	T90 REC	ASTM D 86	248	Deq C
DIST REC C	FBP	ASTM D 86	266	Deq C
DIST REC C	RESIDUE	ASTM D 86	9	%
DIST REC C	LOSS	ASTM D 86	6	%
DIST REC C	IBP TIME	ASTM D 86	8	Min
ST REC C	FBP TIME	ASTM D 86	3	Min
LS PM DLT	FLASH PM MAX DELTA	Calculation	.0	Deq F
FLS PM C	PROCEDURE	ASTM D 93	A	
FLS PM C	FLASH POINT PM	ASTM D 93	144	Deq F
FLS PM C	FLASH POINT PM C	ASTM D 93	62	Deq C
FRZ PH	FREEZE POINT	ASTM D 5972	-48	Deq C
VS K -20C	VISCOSITY	ASTM D 445	6.3	cSt
HOC CORRECTED	NET HEAT COMBUSTION	ASTM D 3338	43.1	MJ/ka
SMOKE PT	SMOKE POINT	ASTM D 1322	20.0	mm
NAPHTHA	NAPHTHALENES	ASTM D 1840	2.0	Vol %
CI JET	CETANE INDEX	ASTM D 976	41.9	
JFTOT 275C	FILTER DELTA P	ASTM D 3241	0	mm Hq
JFTOT 275C	TUBE INSPECTION	ASTM D 3241	Normal	
JFTOT 275C	TUBE RATING	ASTM D 3241	< 1	
CORR JET	CORROSION 212F 2HOUR	ASTM D 130	1.1	Color scl
GUM EXST	EXISTENT GUM CONTENT	ASTM D 381	< 1	mg/100 ml
PC RESTRCT	FILTRATION TIME	83133G	5	MIN
PC RESTRCT	PARTICULATES	83133G	.2	mg/L
PC RESTRCT	VACUUM PRESSURE	83133G	25	in Hq
WATER RCT	INTERFACE RATING	ASTM D 1094	1B	
MSEP NEAT	MSEP-A RATING	ASTM D 3948	94	
MSEP ADDAT	MSEP-A RATING	ASTM D 3948	78	
MSEP ADDAT	SAMPLE TEMPURTURE	ASTM D 3948	77	Deq F
ANTI OX JT	QUANTITY	Data Entry	54.00	kb
ANTI OX JT	ANTIOXIDANT	Data Entry	7.0	lb/kb
MERC S P	MERCAPTAN SULFUR	ASTM D 3227	6	ppm

Tests conducted according to ASTM Standard Test Methods are routinely verified to be in compliance with the latest published versions. Minor changes may be made where they have no material impact on the test results and are necessitated by reasons such as safety, environmental standards, and method effectiveness. The following test results were obtained on a sample taken from the tank prior to shipment. To the best of my knowledge this product meets the requirements of ASTM D 1555 latest revision for Jet A

(A) Automatic Instrument  
 Reviewed by: Eileen P. [Signature] Approved by: \_\_\_\_\_  
 LAB Manager Fuels Coordinator

7-21-14

**Benicia Refinery Laboratory**

**Authorized**

**Final Analysis Report Proprietary**

Product: JP-5, Military Jet 5 Fuel  
 Tank No: 1778  
 Formula: 00075 JET 5  
 Product Spec: MTL-DTL-5624U  
 Contract No: SP0600-13-D-0464

Sample ID: 1140704150  
 Sample Date: 18-July-2014  
 Sample Time: 14:15  
 Blend No: 14J- 049

Test	Component	Method of Test	Test Results	UOM
WKMNSHIP	WORKMANSHIP	VISUAL	Bright and Clear	Pass/Fail
C SAY 6045	SAYBOLT COLOR	ASTM D 6045	21	Color
SPGR DMA	API GRAVITY 60 DEG F	ASTM D 4052	39.2	API
API DMA DT	API GRAVITY MAX DLTA	CALCULATION	0	API
DENS 15C	DENSITY	ASTM D 4052	828	g/mL
FLS PM DLT	FLASH PM MAX DELTA	Calculation	.0	Deq F
FLS PM C	PROCEDURE	ASTM D 93	A	
FLS PM C	FLASH POINT PM C	ASTM D 93	62	Deq C
FLS PM C	FLASH POINT PM	ASTM D 93	144	Deq F
MSEP ADDAT	MSEP-A RATING	ASTM D 3948	78	
MSEP NEAT	MSEP-A RATING	ASTM D 3948	94	
WATER RCT	INTERFACE RATING	ASTM D 1094	1B	
FRZ PH	FREEZE POINT	ASTM D 5972	-48	Deq C
S XRAY2622	SULFUR	ASTM D 2622	.08	Mass %
CORR JET	CORROSION 212F 2HOUR	ASTM D 130	1.1	Color scl
DIST REC C	IBP	ASTM D 86	179	Deq C
DIST REC C	T10 REC	ASTM D 86	196	Deq C
DIST REC C	T20 REC	ASTM D 86	205	Deq C
DIST REC C	T50 REC	ASTM D 86	222	Deq C
DIST REC C	T90 REC	ASTM D 86	248	Deq C
DIST REC C	FBP	ASTM D 86	266	Deq C
DIST REC C	FBP TIME	ASTM D 86	3	Min
DIST REC C	T05 TIME	ASTM D 86	70	Sec
DIST REC C	IBP TIME	ASTM D 86	8	Min
DIST REC C	LOSS	ASTM D 86	.6	%
DIST REC C	RESIDUE	ASTM D 86	.9	%
CI JET	CETANE INDEX	ASTM D 976	41.9	
FIA	OLEFINS-FIA	ASTM D 1319	1.6	Vol %
FIA	AROMATICS-FIA	ASTM D 1319	15.3	Vol %
FIA	SATURATES-FIA	ASTM D 1319	83.1	Vol %
H CONT7171	HYDROGEN CONTENT	ASTM D 7171	13.6	mass %
HOC CORRECTED	NET HEAT COMBUSTION	ASTM D 3338	43.1	MJ/kg
JFTOT 275C	TUBE INSPECTION	ASTM D 3241	Normal	
JFTOT 275C	FILTER DELTA P	ASTM D 3241	0	mm Hq
JFTOT 275C	TUBE RATING	ASTM D 3241	< 1	
PC	FILTRATION TIME	ASTM D5452 / 5624U	3	MIN
PC	VACUUM PRESSURE	ASTM D5452 / 5624U	24	IN Hq
PC	PARTICULATES	ASTM D5452 / 5624U	.2	mq/L
SMOKE PT	SMOKE POINT	ASTM D 1322	20.0	mm
T ACDTY JT	ACID NUMBER	ASTM D 3242	.006	mq KOH/q
VS K -20C	VISCOSITY	ASTM D 445	6.3	cSt
GUM EXST	EXISTENT GUM CONTENT	ASTM D 381	< 1	mq/100 ml
MERC S P	MERCAPTAN SULFUR	ASTM D 3227	6	ppm
ANTI OX JT	QUANTITY	Data Entry	54.00	kb
ANTI OX JT	ANTIOXIDANT	Data Entry	7.0	lb/kb

Tests conducted according to ASTM Standard Test Methods are routinely verified to be in compliance with the latest published versions. Minor changes may be made where they have no material impact on the test results and are necessitated by reasons such as safety, environmental standards, and method effectiveness. The following test results were obtained on a sample taken from the tank prior to shipment. To the best of my knowledge this product meets the requirements of ASTM D 1655 latest revision for Jet A

(A) Automatic Instrument  
 Reviewed by: Eileen M. [Signature] Approved by: \_\_\_\_\_  
 LAB Manager Fuels Coordinator

1-21-14



Shell Oil Products US  
Martinez Refinery  
PO BOX 711 Martinez, CA 94553

CERTIFICATE OF ANALYSIS

6/4/2014


Consignee: Defense Logistics Agency  
cc: James Robinson - QAR Selby  
Attn: Jose Rosario - QAR

Shipping Date: 05-JUN-2014  
AvJet A  
SMR Code 00410  
SMR Blend ID LC-JETA-14-0087  
Certification Date 04-JUN-2014 15:51  
Tender Name/Number DFSN-15-721  
Customer Order No 0068  
Sample Point TK-00536

Properties	Specifications	Units	Results
Appearance, B and C?	Yes		Yes
Free Water?	No		No
Particulates?	No		No
D6045 Saybolt Color			29.4
D4052 API Grav @60F	37.0 <=> 51.0	API	40.6
D4052 Density @15C	775 <=> 840	kg/m3	822
D130 Copper Corrosion	1a: 1b		1a
D86 IBP		deg_F	318.4
D86 10% recovered	100 <=> 401	deg_F	350
D86 50% recovered		deg_F	398
D86 90% recovered		deg_F	479
D86 95% recovered		deg_F	507
D86 FBP	100 <=> 572	deg_F	533
D86 Loss	0.0 <=> 1.5	%vol	0.6

Properties	Specifications	Units	Results
D86 Recovery		%vol	98.2
D86 Residue	0.0 <=> 1.5	%vol	1.2
D56 Flash Point, TCC	105 <=> 150	deg_F	115
Spectrum Filename			mha14415
MTI171 Smoke Point, NIR		MM	21.2
MTI171 Aromatics, NIR		%vol	15.50
MTI171 API Grav, NIR		API	40.70
MTI171 Flash Point, NIR		deg_F	114.7
D5186 Mono-aromatics		%wt	15.0
D5186 Poly-aromatics		%wt	0.5
D5186 Total Aromatics		%wt	15.5
D5186 Total Aromatics		%vol	15.5
Data Reviewed			Y
D5972 Freeze Point	-100 <=> -40	deg_F	-71
D5452 MFS, Color Rating a0: a1: a2: a3: a4: a5: a6			g1
D5452 MFS, Eval. Cond.			Dry
D5452 MFS, Sample Vol.		l	3.7
D5452 MFS, Particulates	0.0 <=> 1.0	MG/L	0.0
D5453 Sulfur		ppm	17.1
D5453 Sulfur, Calc	0.00 <=> 0.30	%wt	0.00
D3242 Acidity as KOH	0.00 <=> 0.10	MG_G	0.00
D1319 Aromatics-FIA	0 <=> 25	%vol	13
D1319 Olefins-FIA		%vol	3.4
D1319 Saturates-FIA		%vol	83.3
D1840 Naphthalenes	0.00 <=> 3.00	%vol	0.22
D1322 Smoke Point	18 <=> 50	mm	21
D3227 Sulfide		ppm	<5
D3227 Mercaptan Sulfur	0.0000 <=> 0.0030	%wt	0.0008
D3948 Micro Sep	85 <=> 100		97
D3241 Pressure Drop	0 <=> 25	mm_Hg	0
D3241 Deposit Rating	0: <1: 1: <2: 2: <3		<1
D3241 Tube Color	normal		normal
D381 Existent Gum	0 <=> 7	mg/100ml	<1
D445 Viscosity @-4 F	0.0 <=> 8.0	CS	4.9
D3338 Heat of Combust.	18400 <=> 100000	BTU/lb	18546
Blend Number			87
Are all Uniform. <=1.5			Yes

- This product conforms to Military Spec MIL-DTL-83133G, Date 30 April 2010.
- Tests conducted according to ASTM Standard Test Methods and verified to be in accordance with the latest published version. The tests results were obtained from a sample taken from the storage tank before shipment. To the best of my knowledge, this product meets the requirements of ASTM-1655 for JP-8.
- Samples drawn according to ASTM D4057 and GR Manual "Sampling of Refinery Streams and Products"



SMR REPRESENTATIVE



Shell Oil Products US  
Martinez Refinery  
PO BOX 711 Martinez, CA 94553

CERTIFICATE OF ANALYSIS

6/12/2014

Consignee: Defense Logistics Agency  
cc: James Robinson - QAR Selby  
Attn: Jose Rosario - QAR

Shipping Date: 12-JUN-2014  
AvJet A  
SMR Code 00410  
SMR Blend ID LC-JETA-14-0087  
Certification Date 04-JUN-2014 15:51  
Tender Name/Number DFSN-05-722  
Customer Order No 0069  
Sample Point TK-00536

Properties	Specifications	Units	Results
Appearance, B and C?	Yes		Yes
Free Water?	No		No
Particulates?	No		No
D6045 Saybolt Color			29.4
D4052 API Grav @60F	37.0 <=> 51.0	API	40.6
D4052 Density @15C	775 <=> 840	kg/m3	822
D130 Copper Corrosion	1a: 1b		1a
D86 IBP		deg_F	318.4
D86 10% recovered	100 <=> 401	deg_F	350
D86 50% recovered		deg_F	398
D86 90% recovered		deg_F	479
D86 95% recovered		deg_F	507
D86 FBP	100 <=> 572	deg_F	533
D86 Loss	0.0 <=> 1.5	%vol	0.6

Properties	Specifications	Units	Results
D86 Recovery		%vol	98.2
D86 Residue	0.0 <=> 1.5	%vol	1.2
D56 Flash Point, TCC	105 <=> 150	deg_F	115
Spectrum Filename			mha14415
MT1171 Smoke Point, NIR		MM	21.2
MT1171 Aromatics, NIR		%vol	15.50
MT1171 API Grav, NIR		API	40.70
MT1171 Flash Point, NIR		deg_F	114.7
D5186 Mono-aromatics		%wt	15.0
D5186 Poly-aromatics		%wt	0.5
D5186 Total Aromatics		%wt	15.5
D5186 Total Aromatics		%vol	15.5
Data Reviewed			Y
D5972 Freeze Point	-100 <=> -40	deg_F	-71
D5452 MFS, Color Rating	a0: a1: a2: a3: a4: a5: a6		g1
D5452 MFS, Eval. Cond.			Dry
D5452 MFS, Sample Vol.		l	3.7
D5452 MFS, Particulates	0.0 <=> 1.0	MG/L	0.0
D5453 Sulfur		ppm	17.1
D5453 Sulfur, Calc	0.00 <=> 0.30	%wt	0.00
D3242 Acidity as KOH	0.00 <=> 0.10	MG_G	0.00
D1319 Aromatics-FIA	0 <=> 25	%vol	13
D1319 Olefins-FIA		%vol	3.4
D1319 Saturates-FIA		%vol	83.3
D1840 Naphthalenes	0.00 <=> 3.00	%vol	0.22
D1322 Smoke Point	18 <=> 50	mm	21
D3227 Sulfide		ppm	<5
D3227 Mercaptan Sulfur	0.0000 <=> 0.0030	%wt	0.0008
D3948 Micro Sep	85 <=> 100		97
D3241 Deposit Rating	0: <1: 1: <2: 2: <3		<1
D3241 Tube Color	normal		normal
D381 Existent Gum	0 <=> 7	mg/100ml	<1
D445 Viscosity @-4 F	0.0 <=> 8.0	CS	4.9
D3338 Heat of Combust.	18400 <=> 100000	BTU/lb	18546
Blend Number			87
Are all Uniform. <=1.5			Yes

- This product conforms to Military Spec MIL-DTL-83133G, Date 30 April 2010.
- Tests conducted according to ASTM Standard Test Methods and verified to be in accordance with the latest published version. The tests results were obtained from a sample taken from the storage tank before shipment. To the best of my knowledge, this product meets the requirements of ASTM-1655 for JP-8.
- Samples drawn according to ASTM D4057 and GR Manual "Sampling of Refinery Streams and Products"



SMR REPRESENTATIVE



Shell Oil Products US  
 Martinez Refinery  
 PO BOX 711 Martinez, CA 94553

CERTIFICATE OF ANALYSIS

6/12/2014

Consignee: Defense Logistics Agency  
 cc: James Robinson - QAR Selby  
 Attn: Jose Rosario - QAR

Shipping Date: 12-JUN-2014  
 AvJet A or Military Jet A  
 SMR Code 00410  
 SMR Blend ID LC-JETA-14-0094  
 Certification Date 10-JUN-2014 11:47  
 Tender Name/Number DFSN-05-722  
 Customer Order No 0069  
 Sample Point TK-00335

Properties	Specifications	Units	Results
Appearance, B and C?	Yes		Yes
Free Water?	No		No
Particulates?	No		No
D6045 Saybolt Color			+30
D4052 API Grav @60F	37.0 <=> 51.0	API	40.1
D4052 Density @15C	775 <=> 840	kg/m3	824
D130 Copper Corrosion	1a: 1b		1a
D86 IBP		deg_F	318.2
D86 10% recovered	100 <=> 401	deg_F	352
D86 50% recovered		deg_F	401
D86 90% recovered		deg_F	480
D86 95% recovered		deg_F	506
D86 FBP	100 <=> 572	deg_F	526
D86 Loss	0.0 <=> 1.5	%vol	0.7



Properties	Specifications	Units	Results
D86 Recovery		%vol	98.1
D86 Residue	0.0 <=> 1.5	%vol	1.2
D56 Flash Point, TCC	105 <=> 150	deg_F	117
Spectrum Filename			MHA14532
MTI171 Smoke Point, NIR		MM	20.3
MTI171 Aromatics, NIR		%vol	17.00
MTI171 API Grav, NIR		API	40.10
MTI171 Flash Point, NIR		deg_F	117.0
D5186 Mono-aromatics		%wt	16.5
D5186 Poly-aromatics		%wt	0.7
D5186 Total Aromatics		%wt	17.2
D5186 Total Aromatics		%vol	17.1
Data Reviewed			Y
D5972 Freeze Point	-100 <=> -40	deg_F	-71
D5452 MFS, Color Rating a0: a1: a2: a3: a4: a5: a6			b1
D5452 MFS, Eval. Cond.			Dry
D5452 MFS, Sample Vol.		l	3.6
D5452 MFS, Particulates	0.0 <=> 1.0	MG/L	0.1
D5453 Sulfur		ppm	19.8
D5453 Sulfur, Calc	0.00 <=> 0.30	%wt	0.00
D3242 Acidity as KOH	0.00 <=> 0.10	MG_G	0.00
D1319 Aromatics-FIA	0 <=> 25	%vol	14
D1319 Olefins-FIA		%vol	1.1
D1319 Saturates-FIA		%vol	84.7
D1840 Naphthalenes	0.00 <=> 3.00	%vol	0.27
D1322 Smoke Point	18 <=> 50	mm	20
D3227 Sulfide		ppm	<5
D3227 Mercaptan Sulfur	0.0000 <=> 0.0030	%wt	<0.0003
D3948 Micro Sep	85 <=> 100		97
D3241 Deposit Rating	0: <1: 1: <2: 2: <3		<1
D3241 Tube Color	normal		normal
D381 Existent Gum	0 <=> 7	mg/100ml	<1
D445 Viscosity @-4 F	0.0 <=> 8.0	CS	5.0
D3338 Heat of Combust.	18400 <=> 100000	BTU/lb	18530
Blend Number			94
Are all Uniform. <=1.5			Yes

- This product conforms to Military Spec MIL-DTL-83133G, Date 30 April 2010.
- Tests conducted according to ASTM Standard Test Methods and verified to be in accordance with the latest published version. The tests results were obtained from a sample taken from the storage tank before shipment. To the best of my knowledge, this product meets the requirements of ASTM-1655 for JP-8.
- Samples drawn according to ASTM D4057 and GR Manual "Sampling of Refinery Streams and Products"



SMR REPRESENTATIVE



Shell Oil Products US  
 Martinez Refinery  
 PO BOX 711 Martinez, CA 94553

**CERTIFICATE OF ANALYSIS**

6/20/2014

Consignee: Defense Logistics Agency  
 cc: James Robinson - QAR Selby  
 Attn: Jose Rosario - QAR

Shipping Date: 20-JUN-2014  
 AvJet A or Military Jet A  
 SMR Code 00410  
 SMR Blend ID LC-JETA-14-0098  
 Certification Date 15-JUN-2014 10:58  
 Tender Name/Number DFSN-15-723  
 Customer Order No 0071  
 Sample Point TK-00334

Properties	Specifications	Units	Results
Appearance, B and C?	Yes		Yes
Free Water?	No		No
Particulates?	No		No
D6045 Saybolt Color			+30
D4052 API Grav @60F	37.0 <=> 51.0	API	40.4
D4052 Density @15C	775 <=> 840	kg/m3	823
D130 Copper Corrosion	1a: 1b		1a
D86 IBP		deg_F	316.3
D86 10% recovered	100 <=> 401	deg_F	348
D86 50% recovered		deg_F	395
D86 90% recovered		deg_F	478
D86 95% recovered		deg_F	505
D86 FBP	100 <=> 572	deg_F	528
D86 Loss	0.0 <=> 1.5	%vol	0.8

Properties	Specifications	Units	Results
D86 Recovery		%vol	98.0
D86 Residue	0.0 <=> 1.5	%vol	1.2
D56 Flash Point, TCC	108 <=> 150	deg_F	116
D5186 Mono-aromatics		%wt	16.2
D5186 Poly-aromatics		%wt	0.6
D5186 Total Aromatics		%wt	16.8
D5186 Total Aromatics		%vol	16.7
Data Reviewed			yes
D5972 Freeze Point	-100 <=> -40	deg_F	-72
D5452 MFS, Color Rating	a0: a1: a2: a3: a4: a5: a6		b1
D5452 MFS, Eval. Cond.			Dry
D5452 MFS, Sample Vol.		l	3.7
D5452 MFS, Particulates	0.0 <=> 1.0	MG/L	0.0
D5453 Sulfur		ppm	20.6
D5453 Sulfur, Calc	0.00 <=> 0.30	%wt	0.00
D3242 Acidity as KOH	0.00 <=> 0.10	MG_G	0.00
D1319 Aromatics-FIA	0 <=> 25	%vol	15
D1319 Olefins-FIA		%vol	1.1
D1319 Saturates-FIA		%vol	83.7
D1840 Naphthalenes	0.00 <=> 3.00	%vol	0.26
D1322 Smoke Point	18 <=> 50	mm	21
D3227 Sulfide		ppm	<5
D3227 Mercaptan Sulfur	0.0000 <=> 0.0030	%wt	<0.0003
D3948 Micro Sep	85 <=> 100		98
D3241 Deposit Rating	0: <1: 1: <2: 2: <3		<1
D3241 Tube Color	normal		normal
D381 Existent Gum	0 <=> 7	mg/100ml	<1
D445 Viscosity @-4 F	0.0 <=> 8.0	CS	4.8
Blend Number			98
Are all Uniform. <=1.5			Yes

- This product conforms to Military Spec MIL-DTL-83133G, Date 30 April 2010.
- Tests conducted according to ASTM Standard Test Methods and verified to be in accordance with the latest published version. The tests results were obtained from a sample taken from the storage tank before shipment. To the best of my knowledge, this product meets the requirements of ASTM-1655 for JP-8.
- Samples drawn according to ASTM D4057 and GR Manual "Sampling of Refinery Streams and Products"

  
SMR REPRESENTATIVE



Shell Oil Products US  
 Martinez Refinery  
 PO BOX 711 Martinez, CA 94553

**CERTIFICATE OF ANALYSIS**

6/20/2014

Consignee: Defense Logistics Agency  
 cc: James Robinson - QAR Selby  
 Attn: Jose Rosario - QAR

Shipping Date: 20-JUN-2014  
 AvJet A or Military Jet A  
 SMR Code 00410  
 SMR Blend ID LC-JETA-14-0103  
 Certification Date 20-JUN-2014 14:52  
 Tender Name/Number DFSN-15-723  
 Customer Order No 0071  
 Sample Point TK-00536

Properties	Specifications	Units	Results
Appearance, B and C?	Yes		Yes
Free Water?	No		No
Particulates?	No		No
D6045 Saybolt Color			+30
D4052 API Grav @60F	37.0 <=> 51.0	API	40.3
D4052 Density @15C	775 <=> 840	kg/m3	823
D130 Copper Corrosion	1a: 1b		1a
D86 IBP		deg_F	317.3
D86 10% recovered	100 <=> 401	deg_F	347
D86 50% recovered		deg_F	399
D86 90% recovered		deg_F	486
D86 95% recovered		deg_F	517
D86 FBP	100 <=> 572	deg_F	538
D86 Loss	0.0 <=> 1.5	%vol	1.0

Properties	Specifications	Units	Results
D86 Recovery		%vol	97.7
D86 Residue	0.0 <=> 1.5	%vol	1.3
D56 Flash Point, TCC	108 <=> 150	deg_F	115
D5186 Mono-aromatics		%wt	15.8
D5186 Poly-aromatics		%wt	0.4
D5186 Total Aromatics		%wt	16.2
D5186 Total Aromatics		%vol	16.2
Data Reviewed			yes
D5972 Freeze Point	-100 <=> -40	deg_F	-72
D5452 MFS, Color Rating a0: a1: a2: a3: a4: a5: a6			b0
D5452 MFS, Eval. Cond.			Dry
D5452 MFS, Sample Vol.		l	3.9
D5452 MFS, Particulates	0.0 <=> 1.0	MG/L	0.1
D5453 Sulfur		ppm	25.8
D5453 Sulfur, Calc	0.00 <=> 0.30	%wt	0.00
D3242 Acidity as KOH	0.00 <=> 0.10	MG_G	0.00
D1319 Aromatics-FIA	0 <=> 25	%vol	13
D1319 Olefins-FIA		%vol	1.9
D1319 Saturates-FIA		%vol	84.8
D1840 Naphthalenes	0.00 <=> 3.00	%vol	0.25
D1322 Smoke Point	18 <=> 50	mm	21
D3227 Sulfide		ppm	<5
D3227 Mercaptan Sulfur	0.0000 <=> 0.0030	%wt	<0.0003
D3948 Micro Sep	85 <=> 100		99
D3241 Deposit Rating	0: <1: 1: <2: 2: <3		<1
D3241 Tube Color	normal		normal
D381 Existent Gum	0 <=> 7	mg/100ml	<1
D3338 Heat of Comb	18400 <=> 100000	BTU/lb	18540
D445 Viscosity @-4 F	0.0 <=> 8.0	CS	4.9
Blend Number			103
Are all Uniform. <=1.5			Yes

- This product conforms to Military Spec MIL-DTL-83133G, Date 30 April 2010.
- Tests conducted according to ASTM Standard Test Methods and verified to be in accordance with the latest published version. The tests results were obtained from a sample taken from the storage tank before shipment. To the best of my knowledge, this product meets the requirements of ASTM-1655 for JP-8.
- Samples drawn according to ASTM D4057 and GR Manual "Sampling of Refinery Streams and Products"

  
 SMR REPRESENTATIVE



Shell Oil Products US  
 Martinez Refinery  
 PO BOX 711 Martinez, CA 94553

CERTIFICATE OF ANALYSIS

6/27/2014

Consignee: Defense Logistics Agency  
 cc: James Robinson - QAR Selby  
 Attn: Jose Rosario - QAR

Shipping Date: 28-JUN-2014  
 AvJet A or Military Jet A  
 SMR Code 00410  
 SMR Blend ID LC-JETA-14-0103  
 Certification Date 20-JUN-2014 14:52  
 Tender Name/Number DFSN-15-724  
 Customer Order No 0070  
 Sample Point TK-00536

Properties	Specifications	Units	Results
Appearance, B and C?	Yes		Yes
Free Water?	No		No
Particulates?	No		No
D6045 Saybolt Color			+30
D4052 API Grav @60F	37.0 <=> 51.0	API	40.3
D4052 Density @15C	775 <=> 840	kg/m3	823
D130 Copper Corrosion	1a: 1b		1a
D86 IBP		deg_F	317.3
D86 10% recovered	100 <=> 401	deg_F	347
D86 50% recovered		deg_F	399
D86 90% recovered		deg_F	486
D86 95% recovered		deg_F	517
D86 FBP	100 <=> 572	deg_F	538
D86 Loss	0.0 <=> 1.5	%vol	1.0

Properties	Specifications	Units	Results
D86 Recovery		%vol	97.7
D86 Residue	0.0 <=> 1.5	%vol	1.3
D56 Flash Point, TCC	108 <=> 150	deg_F	115
D5186 Mono-aromatics		%wt	15.8
D5186 Poly-aromatics		%wt	0.4
D5186 Total Aromatics		%wt	16.2
D5186 Total Aromatics		%vol	16.2
Data Reviewed			yes
D5972 Freeze Point	-100 <=> -40	deg_F	-72
D5452 MFS, Color Rating	a0: a1: a2: a3: a4: a5: af		b0
D5452 MFS, Eval. Cond.			Dry
D5452 MFS, Sample Vol.		l	3.9
D5452 MFS, Particulates	0.0 <=> 1.0	MG/L	0.1
D5453 Sulfur		ppm	25.8
D5453 Sulfur, Calc	0.00 <=> 0.30	%wt	0.00
D3242 Acidity as KOH	0.00 <=> 0.10	MG_G	0.00
D1319 Aromatics-FIA	0 <=> 25	%vol	13
D1319 Olefins-FIA		%vol	1.9
D1319 Saturates-FIA		%vol	84.8
D1840 Naphthalenes	0.00 <=> 3.00	%vol	0.25
D1322 Smoke Point	18 <=> 50	mm	21
D3227 Sulfide		ppm	<5
D3227 Mercaptan Sulfur	0.0000 <=> 0.0030	%wt	<0.0003
D3948 Micro Sep	85 <=> 100		99
D3241 Deposit Rating	0: <1: 1: <2: 2: <3		<1
D3241 Tube Color	normal		normal
D381 Existent Gum	0 <=> 7	mg/100ml	<1
D3338 Heat of Comb	18400 <=> 100000	BTU/lb	18540
D445 Viscosity @-4 F	0.0 <=> 8.0	CS	4.9
Blend Number			103
Are all Uniform. <=1.5			Yes

- This product conforms to Military Spec MIL-DTL-83133G, Date 30 April 2010.
- Tests conducted according to ASTM Standard Test Methods and verified to be in accordance with the latest published version. The tests results were obtained from a sample taken from the storage tank before shipment. To the best of my knowledge, this product meets the requirements of ASTM-1655 for aviation turbine fuels.
- Samples drawn according to ASTM D4057 and GR Manual "Sampling of Refinery Streams and Products"

  
 \_\_\_\_\_  
 SMR REPRESENTATIVE



Shell Oil Products US  
 Martinez Refinery  
 PO BOX 711 Martinez, CA 94553

CERTIFICATE OF ANALYSIS

6/27/2014

Consignee: Defense Logistics Agency  
 cc: James Robinson - QAR Selby  
 Attn: Jose Rosario - QAR

Shipping Date: 28-JUN-2014  
 AvJet A or Military Jet A  
 SMR Code 00410  
 SMR Blend ID LC-JETA-14-0111  
 Certification Date 26-JUN-2014 15:03  
 Tender Name/Number DFSN-15-724  
 Customer Order No 0070  
 Sample Point TK-00335

Properties	Specifications	Units	Results
Appearance, B and C?	Yes		Yes
Free Water?	No		No
Particulates?	No		No
D6045 Saybolt Color			+30
D4052 API Grav @60F	37.0 <=> 51.0	API	40.4
D4052 Density @15C	775 <=> 840	kg/m3	822
D130 Copper Corrosion	1a: 1b		1a
D86 IBP		deg_F	316.0
D86 10% recovered	100 <=> 401	deg_F	350
D86 50% recovered		deg_F	401
D86 90% recovered		deg_F	478
D86 95% recovered		deg_F	505
D86 FBP	100 <=> 572	deg_F	530
D86 Loss	0.0 <=> 1.5	%vol	0.3



Properties	Specifications	Units	Results
D86 Recovery		%vol	98.3
D86 Residue	0.0 <=> 1.5	%vol	1.4
D56 Flash Point, TCC	108 <=> 150	deg_F	116
D5186 Mono-aromatics		%wt	17.2
D5186 Poly-aromatics		%wt	0.6
D5186 Total Aromatics		%wt	17.8
D5186 Total Aromatics		%vol	17.7
Data Reviewed			Y
D5972 Freeze Point	-100 <=> -40	deg_F	-72
D5452 MFS, Color Rating	a0: a1: a2: a3: a4: a5: a6		g2
D5452 MFS, Eval. Cond.			Dry
D5452 MFS, Sample Vol.		l	3.7
D5452 MFS, Particulates	0.0 <=> 1.0	MG/L	0.0
D5453 Sulfur		ppm	17.6
D5453 Sulfur, Calc	0.00 <=> 0.30	%wt	0.00
D3242 Acidity as KOH	0.00 <=> 0.10	MG_G	0.00
D1319 Aromatics-FIA	0 <=> 25	%vol	16
D1319 Olefins-FIA		%vol	0.8
D1319 Saturates-FIA		%vol	83.6
D1840 Naphthalenes	0.00 <=> 3.00	%vol	0.21
D1322 Smoke Point	18 <=> 50	mm	20
D3227 Sulfide		ppm	<5
D3227 Mercaptan Sulfur	0.0000 <=> 0.0030	%wt	<0.0003
D3948 Micro Sep	85 <=> 100		100
D3241 Deposit Rating	0: <1: 1: <2: 2: <3		<1
D3241 Tube Color	normal		normal
D381 Existent Gum	0 <=> 7	mg/100ml	<1
D3338 Heat of Comb	18400 <=> 100000	BTU/lb	18528
D445 Viscosity @-4 F	0.0 <=> 8.0	CS	4.9
Blend Number			111
Are all Uniform. <=1.5			Yes

- This product conforms to Military Spec MIL-DTL-83133G, Date 30 April 2010.
- Tests conducted according to ASTM Standard Test Methods and verified to be in accordance with the latest published version. The tests results were obtained from a sample taken from the storage tank before shipment. To the best of my knowledge, this product meets the requirements of ASTM-1655 for aviation turbine fuels.
- Samples drawn according to ASTM D4057 and GR Manual "Sampling of Refinery Streams and Products"

  
 \_\_\_\_\_  
 SMR REPRESENTATIVE



CHEVRON PRODUCTS COMPANY  
RICHMOND

JP8  
TURBINE FUEL, AVIA JP8

Certificate of Analysis

Sampled: 07/03/2014 03:30:27  
Batch Finished: 07/03/2014 12:56:23  
Report Generated: 07/03/2014 13:05:13

Batch No: JET\_2014\_04826  
Vessel: TANK-1798  
Samples: R00023697

Method	Description	Unit of Measure	Result	Specification
D4176	APPEARANCE / CONDITION		PASS	BRT & CLR
D3242	ACID NUMBER, TOTAL	mg KOH/g	0.004	MAX 0.015
D1319	AROMATICS	vol %	22.8	MAX 25.0
D1319	OLEFINS	vol %	1.8	REPORT
D4737	CETANE NUMBER, CALC		44.0	REPORT
D156	COLOR, SAYBOLT		+30	REPORT
D130	CORROSION, CU STRIP@212F		1B	MAX 1
D86	INITIAL BOILING PT	°C	154	REPORT
D86	10% RECOVERED	°C	170	MAX 205
D86	20% RECOVERED	°C	178	REPORT
D86	50% RECOVERED	°C	202	REPORT
D86	90% RECOVERED	°C	248	REPORT
D86	END POINT	°C	272	MAX 300
D86	RESIDUE	vol %	1.2	MAX 1.5
D86	LOSS	vol %	0.6	MAX 1.5
D56	FLASH, TAG CLOSED CUP	°C	45	MIN 41
D93	FLASH, PENSKY-MARTEN	°C	47	MIN 39
D7153	FREEZE POINT	°C	-48	MAX -47
D4052	GRAVITY	API Gravity	43.6	37.0 - 51.0
D52	DENSITY @ 15C	kg/L	0.8077	0.775 - 0.840
D381	GUM EXISTENT, STEAMJET	mg/100mL	1.6	MAX 7.0
D3343	HYDROGEN CONTENT	mass %	13.6	MIN 13.4
D3338	HEAT OF COMBUSTION, NET	MJ/kg	43.1	MIN 42.8
D1094	INTERFACE RATING		1B	MAX 1B
D3241	JFTOT: FILTER PRESSURE DROP, @ 275C	mm of Hg	0	MAX 25.0
D3241	JFTOT: HEATER TUBE DEPOSITS, CODE # @275C		1	MAX 2
D3241	JFTOT: COKE TUBE SERIAL NUMBER @ 275C		14A01381	REPORT
D1840	NAPHTHALENES	vol %	1.4	MAX 3.0
D5452	PARTICULATE CONTAMINATION	mg/L	0.1	MAX 1.0
D5452	FILTRATION TIME	minutes	5	MAX 15
D1322	SMOKE POINT	millimeters	20.6	MIN 19.0
D2622	SULFUR, TOTAL	weight %	0.0331	MAX 0.15
D3227	SULFUR, MERCAPTAN	weight %	0.001	MAX 0.002
D445	VISCOSITY, KINEMATIC @ -20C	Centistokes	4.1	MAX 8.0
D3948	WATER SEPARATION INDEX (MICROSEP)		99	MIN 90
D3948	MICROSEP-ADDITIVE CONFIRMATION		98	REPORT
LAB	ANTI-OXIDANT (Active) JP8	mg/L	19.6	17.2 - 24.0



CHEVRON PRODUCTS COMPANY  
RICHMOND

JP8  
TURBINE FUEL, AVIA JP8

Certificate of Analysis

Sampled : 07/03/2014 03:30:27  
Batch Finished: 07/03/2014 12:56:23  
Report Generated: 07/03/2014 13:05:13

Batch No : JET\_2014\_04826  
Vessel : TANK-1798  
Samples: R00023697

Method	Description	Unit of Measure	Result	Specification
D4176	APPEARANCE / CONDITION		PASS	BRT & CLR
D3242	ACID NUMBER, TOTAL	mg KOH/g	0.004	MAX 0.015
D1319	AROMATICS	vol %	22.8	MAX 25.0
D1319	OLEFINS	vol %	1.8	REPORT
D4737	CETANE NUMBER, CALC		44.0	REPORT
D156	COLOR, SAYBOLT		+30	REPORT
D130	CORROSION, CU STRIP@212F		1B	MAX 1
D86	INITIAL BOILING PT	°C	154	REPORT
D86	10% RECOVERED	°C	170	MAX 205
D86	20% RECOVERED	°C	178	REPORT
D86	50% RECOVERED	°C	202	REPORT
D86	90% RECOVERED	°C	248	REPORT
D86	END POINT	°C	272	MAX 300
D86	RESIDUE	vol %	1.2	MAX 1.5
D86	LOSS	vol %	0.6	MAX 1.5
D56	FLASH, TAG CLOSED CUP	°C	45	MIN 41
D93	FLASH, PENSKY-MARTEN	°C	47	MIN 39
D7153	FREEZE POINT	°C	-48	MAX -47
D4052	GRAVITY	API Gravity	43.6	37.0 - 51.0
D4052	DENSITY @ 15C	kg/L	0.8077	0.775 - 0.840
D381	GUM EXISTENT, STEAM JET	mg/100mL	1.6	MAX 7.0
D3343	HYDROGEN CONTENT	mass %	13.6	MIN 13.4
D3338	HEAT OF COMBUSTION, NET	MJ/kg	43.1	MIN 42.8
D1094	INTERFACE RATING		1B	MAX 1B
D3241	JFTOT: FILTER PRESSURE DROP, @ 275C	mm of Hg	0	MAX 25.0
D3241	JFTOT: HEATER TUBE DEPOSITS, CODE # @275C		1	MAX 2
D3241	JFTOT: COKER TUBE SERIAL NUMBER @ 275C		14A01381	REPORT
D1840	NAPHTHALENES	vol %	1.4	MAX 3.0
D5452	PARTICULATE CONTAMINATION	mg/L	0.1	MAX 1.0
D5452	FILTRATION TIME	minutes	5	MAX 15
D1322	SMOKE POINT	millimeters	20.6	MIN 19.0
D2622	SULFUR, TOTAL	weight %	0.0331	MAX 0.15
D3227	SULFUR, MERCAPTAN	weight %	0.001	MAX 0.002
D445	VISCOSITY, KINEMATIC @ -20C	Centistokes	4.1	MAX 8.0
D3948	WATER SEPARATION INDEX (MICROSEP)		99	MIN 90
D3948	MICROSEP-ADDITIVE CONFIRMATION		98	REPORT
LAB	ANTI-OXIDANT (Active) JP8	mg/L	19.6	17.2 - 24.0



CHEVRON PRODUCTS COMPANY  
RICHMOND

JP8  
TURBINE FUEL, AVIA JP8

Certificate of Analysis

Sampled : 07/05/2014 01:45:24  
Batch Finished : 07/05/2014 10:59:53  
Report Generated : 07/05/2014 11:05:49

Batch No : JET\_2014\_04827  
Vessel : TANK-1799  
Samples : R00024254

Method	Description	Unit of Measure	Result	Specification
D4176	APPEARANCE / CONDITION		B/C	BRT & CLR
D3242	ACID NUMBER, TOTAL	mg KOH/g	0.004	MAX 0.015
D1319	AROMATICS	vol %	20.5	MAX 25.0
D1319	OLEFINS	vol %	1.4	REPORT
D4737	CETANE NUMBER, CALC		45.8	REPORT
D156	COLOR, SAYBOLT		+30	REPORT
D130	CORROSION, CU STRIP@212F		1B	MAX 1
D86	INITIAL BOILING PT	°C	153	REPORT
D86	10% RECOVERED	°C	168	MAX 205
D86	20% RECOVERED	°C	174	REPORT
D86	50% RECOVERED	°C	198	REPORT
D86	90% RECOVERED	°C	250	REPORT
D86	END POINT	°C	274	MAX 300
D86	RESIDUE	vol %	1.1	MAX 1.5
D86	LOSS	vol %	1.2	MAX 1.5
D56	FLASH, TAG CLOSED CUP	°C	44	MIN 41
D93	FLASH, PENSKY-MARTEN	°C	45	MIN 39
D7153	FREEZE POINT	°C	-48	MAX -47
D4052	GRAVITY	API Gravity	45.1	37.0 - 51.0
1052	DENSITY @ 15C	kg/L	0.8007	0.775 - 0.840
D381	GUM EXISTENT, STEAM JET	mg/100mL	1.0	MAX 7.0
D3343	HYDROGEN CONTENT	mass %	13.7	MIN 13.4
D3338	HEAT OF COMBUSTION, NET	MJ/kg	43.2	MIN 42.8
D1094	INTERFACE RATING		1	MAX 1B
D3241	JFTOT: FILTER PRESSURE DROP, @ 275C	mm of Hg	0	MAX 25.0
D3241	JFTOT: HEATER TUBE DEPOSITS, CODE # @275C		1	MAX 2
D3241	JFTOT: COKER TUBE SERIAL NUMBER @ 275C		14A01397	REPORT
D1840	NAPHTHALENES	vol %	0.7	MAX 3.0
D5452	PARTICULATE CONTAMINATION	mg/L	0.0	MAX 1.0
D5452	FILTRATION TIME	minutes	5	MAX 15
D1322	SMOKE POINT	millimeters	22.8	MIN 19.0
D2622	SULFUR, TOTAL	weight %	0.0182	MAX 0.15
D3227	SULFUR, MERCAPTAN	weight %	0.000	MAX 0.002
D445	VISCOSITY, KINEMATIC @ -20C	Centistokes	3.9	MAX 8.0
D3948	WATER SEPARATION INDEX (MICROSEP)		100	MIN 90
D3948	MICROSEP-ADDITIVE CONFIRMATION		100	REPORT
LAB	ANTI-OXIDANT (Active) JP8	mg/L	23.7	17.2 - 24.0



CHEVRON PRODUCTS COMPANY  
RICHMOND

JP8  
TURBINE FUEL, AVIA JP8

**Certificate of Analysis**

Sampled: 07/05/2014 01:45:24  
Batch Finished: 07/05/2014 10:59:53  
Report Generated: 07/05/2014 11:05:49

Batch No: JET\_2014\_04827  
Vessel: TANK-1799  
Samples: R00024254

Method	Description	Unit of Measure	Result	Specification
--------	-------------	-----------------	--------	---------------

I certify that above material meets prescribed requirements.

Margaret Z. Syed                      07/05/2014 11:05:49

\_\_\_\_\_  
Company Representative                      Date/Time

\* This product meets the requirements of MIL-DTL-83133G

\* Microsep Additive Confirmation is the result on a handblend with added C111

\* C111 injected downstream at a target concentration of 17 mg/L

Comments:

[09068]		ANALYSIS OF AVIATION TYPING FLUID		DATE PRINTED: 09/10/2014 12:38	
FROM: NAVSUP PLENET LOGISTICS CENTER SAN DIEGO Petroleum Laboratory, B-93A 199 Rodgersway Street San Diego, CA 92106			TO: SAN JUAN MIQUEL FUEL DIVISION - CODE 5316E BUILDING 61 - 12TH STREET NAVAL BASE AVENUE, SAN DIEGO COUNTY, CALIFORNIA CA 92132		
LAB SAMPLE NO. 120868		SOURCE OF SAMPLE (Truck, tank, Aircraft, etc) TANK 65801 MIQUEL			
DATE SAMPLED 09/09/2014 04:09 AM		DATE RECEIVED 09/08/2014 05:04:09 AM		DATE TESTS COMPLETE 09/09/2014 02:27:00 PM	
PRODUCT CODE 1A Sample Amount		TEST TYPE 1A CN		BATCH NO 1316	
		REPRESENTED AMOUNT		SAMPLE RECEIVED AT PLENET	
				SAMPLE TAKEN BY	
REF (A) ASTM D1555		REF (B) MIL-STD-7004			
PRODUCT AS REPRESENTED BY SAMPLE MIQT		ON SPEC			
SPEC. LIMITS OF REF (A)? YES		USE LIMITS OF REF (B)? YES			
MARKING		LIMITS OF REF (A) & (B)		RESULTS	
FLASHPOINT, PMCC		18 MIN		48	
SEDIMENT, mg/L		2 MAX		0.2	
APPEARANCE (DESCRIPTION)		C & B NFW		C & B NFW	
ICING INHIBITOR, %		REPORT		0.09	
				METHOD NO	
				D99	
				D2276	
				XXX	
				D5006	
REMARKS:					
SULFUR CONTENT: 0.0415% -- RICH TEXT --					
SUBMITTED BY LAB			APPROVED BY / DIRECTION DRIAD Supervisory Chemist		

ANALYSIS OF AVIATION TURBINE FUEL, JP-8

DATE PRINTED: 10/2/2014

FROM: NAVSUP FLEET LOGISTICS CENTER SAN DIEGO  
Petroleum Laboratory B-70A  
199 Rosecrans Street  
San Diego, CA 92106

DATE SAMPLE RECEIVED: 9/29/2014

DATE SAMPLE TESTED: 9/30/2014

BATCH: 1751

TO: PT MUGU

SAMPLE GRADE: JA-CN

SAMPLE ID	SAMPLE DATE	SOURCE	FLASH POINT (°C)	FSII %	SEDIMENT mg/L	APPEAR	WATER VISUAL
1208801	9/23/2014	TK 639	50	0.09	0.2	C & B	NFW

REQUIREMENT LIMITS:	38 MIN	REPORT	2 MAX	C & B	NFW
METHOD	D93	D5006	D2276		

REMARKS:

SULFUR= 0.070%

SUBMITTED BY:

APPROVED BY DIRECTION OF:

Ophelia Acain

Digna M. Feria  
Supervisory Chemist

ANALYSIS OF AVIATION TURBINE FUEL, JP-8

DATE PRINTED: 11/06/124

FROM: NAVSUP FLEET LOGISTICS CENTER SAN DIEGO  
Petroleum Laboratory B-70A  
199 Rosecrans Street  
San Diego, CA 92106

DATE SAMPLE RECEIVE 11/4/2014

DATE SAMPLE TESTED: 11/6/2014

BATCH: 1815

TO: PT MUGU

SAMPLE GRADE: JA-CN

SAMPLE ID	SAMPLE DATE	SOURCE	FLASH POINT (°C)	FSII %	SEDIMENT mg/L	APPEAR	WATER VISUAL
1224339	10/23/2014	TK 639	50	0.09	0.2	C & B	NFW

REQUIREMENT LIMITS:	38 MIN	REPORT	2 MAX	C & B	NFW
METHOD	D93	D5006	D2276		

REMARKS:  
SULFUR= 0.10%

SUBMITTED BY:

APPROVED BY DIRECTION OF:

Ophelia Acain

Digna M. Feria  
Supervisory Chemist



ANALYSIS OF AVIATION TURBINE FUEL, JP-8

DATE PRINTED: 12/9/2014

FROM: NAVSUP FLEET LOGISTICS CENTER SAN DIEGO  
Petroleum Laboratory B-70A  
199 Rosecrans Street  
San Diego, CA 92106

DATE RECEIVED: 12/4/2014

DATE COMPLETED: 12/8/2014

BATCH: 1864

TO: NAS PT MUGU

SAMPLE GRADE: JA-CN

SAMPLE ID	SAMPLE DATE	SOURCE	FLASH POINT (°C)	FSII %	SEDIMENT mg/L	APPEAR	WATER VISUAL
1231372	11/21/2014	TK 639	50	0.085	0.2	C & B	NFW

REQUIREMENT LIMITS:	38 MIN	REPORT	2 MAX	C & B	NFW
METHOD	D93	D5006	D2276		

REMARKS:  
SULFUR= 0.13%

SUBMITTED BY: Ophelia Acain

APPROVED BY DIRECTION OF: Digna M. Feria  
Supervisory Chemist

1232271			
ANALYSIS OF AVIATION TURBINE FUEL, JET A		DATE PRINTED 01/07/2015 11:18:25	
<b>FROM</b> NAVSUP FLEET LOGISTICS CENTER SAN DIEGO Petroleum Laboratory B-70A 199 Roscerans Street San Diego, CA 92106		<b>TO</b> NAS POINT MUGU FUEL DIVISION / CODE N31VF BUILDING 63 - 12TH STREET NAVAL BASE VENTURA COUNTY, PT MUGU CA 93042	
LAB SAMPLE NO. 1232271	SOURCE OF SAMPLE (Truck, tank, Aircraft, etc) TANK 638 NAS POINT MUGU		
DATE SAMPLED 12/22/2014 09:32:00 AM	DATE RECEIVED 12/24/2014 09:32:00 AM	DATE TESTS COMPLETE 01/07/2015 09:12:00 AM	
PRODUCT CODE JA	TEST TYPE JA-CN	BATCH NO	
Sample Amount	REPRESENTED AMOUNT	SAMPLE RECEIVED AT PTLOMA	SAMPLE TAKEN BY
REF (A) ASTM D1655		REF (B) MIL-STD-3004	
PRODUCT AS REPRESENTED BY SAMPLE MEET		ON SPEC	
SPEC. LIMITS OF REF (A)? YES		USE LIMITS OF REF (B)? YES	
MARKING	LIMITS OF REF (A) & (B)	RESULTS	METHOD NO
FLASH POINT, PMCC, °C	38 MIN	49	D93
SEDIMENT, mg/L	2 MAX	0.6	D2276
APPEARANCE (DESCRIPTION)	C & B/ NFW	C & B/ NFW	XXX
ICING INHIBITOR, %V	REPORT	0.09	D5006
REMARKS: SULFUR, %: 0.06			
SUBMITTED BY: FERIAD	ASSIGNED TECH:	APPROVED BY DIRECTION: FERIAD Supervisory Chemist	

## **Appendix B**

### **NBVC Point Mugu Source Test Summary Forms & RICE NESHAP Maintenance Records**



## ANNUAL COMPLIANCE CERTIFICATION

### SOURCE TEST SUMMARY FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

A. Emission Unit Description: 1- 2.5 MMBTU/hr Ajax Model SA-60 Boiler equipped with Alzeta Low-NOx Burner (Building 20)			B. Pollutant: NOx
C. Measured Emission Rate:  18.5 ppm	D. Limited Emission Rate:  30 ppm	E. Specific Source Test or Monitoring Record Citation: Source Test Report, The Alliance Compliance Group Joint Venture Contract No. N44255-09-D-4001 Submitted March 4, 2014	F. Test Date:  January 29, 2014

A. Emission Unit Description: 1- 2.5 MMBTU/hr Ajax Model SA-60 Boiler equipped with Alzeta Low-NOx Burner (Building 20)			B. Pollutant: CO
C. Measured Emission Rate:  84.0 ppm	D. Limited Emission Rate:  400 ppm	E. Specific Source Test or Monitoring Record Citation: Source Test Report, The Alliance Compliance Group Joint Venture Contract No. N44255-09-D-4001 Submitted March 4, 2014	F. Test Date:  January 29, 2014

A. Emission Unit Description: 1- 4.25 MMBTU/hr Ajax Model WNG-4500 Boiler equipped with Alzeta Low-NOx Burner (Building 36)			B. Pollutant: NOx
C. Measured Emission Rate:  10.0 ppm	D. Limited Emission Rate:  30 ppm	E. Specific Source Test or Monitoring Record Citation: Source Test Report, The Alliance Compliance Group Joint Venture Contract No. N44255-09-D-4001 Submitted March 4, 2014	F. Test Date:  January 30, 2014

A. Emission Unit Description: 1- 4.25 MMBTU/hr Ajax Model WNG-4500 Boiler equipped with Alzeta Low-NOx Burner (Building 36)			B. Pollutant: CO
C. Measured Emission Rate:  198.2 ppm	D. Limited Emission Rate:  400 ppm	E. Specific Source Test or Monitoring Record Citation: Source Test Report, The Alliance Compliance Group Joint Venture Contract No. N44255-09-D-4001 Submitted March 4, 2014	F. Test Date:  January 30, 2014



# ANNUAL COMPLIANCE CERTIFICATION

## SOURCE TEST SUMMARY FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

A. Emission Unit Description: 1- 3.0 MMBTU/hr Hurst Model S45-C-75-30W Boiler equipped with a combustion specialties Noxmiser 80-N3/P4 Low-NOx Burner and an external flue gas recirculation system (Building 351)			B. Pollutant: NOx
C. Measured Emission Rate:  16.9 ppm	D. Limited Emission Rate:  30 ppm	E. Specific Source Test or Monitoring Record Citation: Source Test Report, The Alliance Compliance Group Joint Venture Contract No. N44255-09-D-4001 Submitted March 4, 2014	F. Test Date:  January 29, 2014

A. Emission Unit Description: 1- 3.0 MMBTU/hr Hurst Model S45-C-75-30W Boiler equipped with a combustion specialties Noxmiser 80-N3/P4 Low-NOx Burner and an external flue gas recirculation system (Building 351)			B. Pollutant: CO
C. Measured Emission Rate:  194.1 ppm	D. Limited Emission Rate:  400 ppm	E. Specific Source Test or Monitoring Record Citation: Source Test Report, The Alliance Compliance Group Joint Venture Contract No. N44255-09-D-4001 Submitted March 4, 2014	F. Test Date:  January 29, 2014

A. Emission Unit Description: 1- 3.0 MMBTU/hr Hurst Model S45-C-75-30W Boiler equipped with a combustion specialties Noxmiser 80-N3/P4 Low-NOx Burner and an external flue gas recirculation system (Building 355)			B. Pollutant: NOx
C. Measured Emission Rate:  22.9 ppm	D. Limited Emission Rate:  30 ppm	E. Specific Source Test or Monitoring Record Citation: Source Test Report, The Alliance Compliance Group Joint Venture Contract No. N44255-09-D-4001 Submitted March 4, 2014	F. Test Date:  January 29, 2014



Ventura County  
Air Pollution  
Control District

## ANNUAL COMPLIANCE CERTIFICATION SOURCE TEST SUMMARY FORM

Period Covered by Compliance Certification: 01 / 01 / 14 (MM/DD/YY) to 12 / 31 / 14 (MM/DD/YY)

A. Emission Unit Description: 1- 3.0 MMBTU/hr Hurst Model S45-C-75-30W Boiler equipped with a combustion specialties Noxmiser 80-N3/P4 Low-NOx Burner and an external flue gas recirculation system (Building 355)		B. Pollutant: CO	
C. Measured Emission Rate:  189.5 ppm	D. Limited Emission Rate:  400 ppm	E. Specific Source Test or Monitoring Record Citation: Source Test Report, The Alliance Compliance Group Joint Venture Contract No. N44255-09-D-4001 Submitted March 4, 2014	F. Test Date:  January 29, 2014

NAVFAC POINT MUGU RICE NESHAP MAINTENANCE RECORD

Bldg	Device	Engine Oil Analysis <sup>2</sup>		Engine and Filter Oil Change <sup>3</sup>		Air Cleaner Inspection <sup>4</sup>		Hoses and Belts Inspection <sup>5</sup>	
		Date of Engine Oil Sample Collection	Hour Meter Reading at Time of Engine Oil Sample Collection	Date of Engine Oil and Oil Filter Change	Hour Meter Reading at Time of Engine Oil and Oil Filter Change	Date of Inspection	Hour Meter Reading at Time of Inspection	Date of Inspection	Hour Meter Reading at Time of Inspection
1	170 BHP Cummins <sup>1</sup>	4/15/2014	32	Passing Analysis - N/R	Passing Analysis - N/R	4/15/2014	32	4/15/2014	32
3	49 BHP Kubota	Post 2006 Construction, Maintenance not Required							
13	300 BHP Caterpillar <sup>1</sup>	4/14/2014	20	6/19/2014	21.7	4/14/2014	20	4/14/2014	20
14	112 BHP Hino <sup>1</sup>	4/1/2014	568	Passing Analysis - N/R	Passing Analysis - N/R	4/1/2014	568	4/1/2014	568
50	368 BHP Caterpillar	Post 2006 Construction, Maintenance not Required							
53	2,168 BHP Caterpillar <sup>1</sup>	4/15/2014	457	Passing Analysis - N/R	Passing Analysis - N/R	4/15/2014	457	4/15/2014	457
58	90 BHP Cummins <sup>1</sup>	4/4/2014	315	Passing Analysis - N/R	Passing Analysis - N/R	4/4/2014	315	4/4/2014	315
64	369 BHP Cummins	Post 2006 Construction, Maintenance not Required							
67	103 BHP Caterpillar <sup>1</sup>	5/30/2014	227	6/24/2014	228.5	4/22/2014	227	4/22/2014	227
93	290 BHP John Deere <sup>1</sup>	N/A	N/A	7/10/2014	1653.8	5/30/2014	1653.7	5/30/2014	1653.7
94	48 BHP John Deere	Post 2006 Construction, Maintenance not Required							
99	343 BHP Caterpillar <sup>1</sup>	5/30/2014	394.2	7/24/2014	394.7	1/30/2014	394.2	1/30/2014	394.2
303	218 BHP Hercules <sup>1</sup>	4/3/2014	443	5/1/2014	444.2	4/3/2014	443.7	4/3/2014	443
323	217 BHP Caterpillar	Post 2006 Construction, Maintenance not Required							
322	99 BHP Cummins <sup>1</sup>	4/11/2014	180	Passing Analysis - N/R	Passing Analysis - N/R	4/11/2014	180	4/11/2014	180
323	196 BHP General Motors (NG)**** <sup>1</sup>	4/3/2014	408	6/20/2014	410.2	4/3/2014	408	4/3/2014	408
326	49 BHP Kubota	Post 2006 Construction, Maintenance not Required							
355	315 BHP John Deere	Post 2006 Construction, Maintenance not Required							
359	288 BHP Cummins <sup>1</sup>	4/2/2014	160	Passing Analysis - N/R	Passing Analysis - N/R	4/2/2014	160	4/2/2014	160
369	355 BHP Cummins <sup>1</sup>	4/15/2014	1078	Passing Analysis - N/R	Passing Analysis - N/R	4/15/2014	1078	4/15/2014	1078
391	48 BHP Caterpillar	Post 2006 Construction, Maintenance not Required							
531	364 BHP Cummins	Post 2006 Construction, Maintenance not Required							
642	48 BHP Caterpillar	Post 2006 Construction, Maintenance not Required							
812	188 BHP Cummins <sup>1</sup>	4/7/2014	346	Passing Analysis - N/R	Passing Analysis - N/R	4/7/2014	346	4/7/2014	346
3015	1,588 BHP Caterpillar <sup>1</sup>	4/15/2014	506	Passing Analysis - N/R	Passing Analysis - N/R	4/15/2014	506	4/15/2014	506

1. Maintenance Required

- <sup>1</sup> Engine oil and oil filters are required to be changed every 500 hours of operation or annually, whichever comes first (not required with passing oil analysis)
- <sup>2</sup> Air cleaners are required to be inspected every 1,000 hours of operation or annually, whichever comes first
- <sup>3</sup> Hoses and belts are required to be inspected every 500 hours of operation or annually, whichever comes first
- <sup>4</sup> Inspect spark plugs every 1,000 hours of operation or annually, whichever comes first in lieu of air cleaner inspection.

2. Optional Oil Analysis Results:

Notes:  
New oil TBN = 12  
New oil V100 = 15



## **Appendix C**

# **NBVC Point Mugu Formal Surveys & Engines Hours of Operations**



# **NBVC Point Mugu Opacity Survey**

**NBVC Point Mugu  
Stationary Standby Emergency Engines  
Emergency and Maintenance 12-Month  
Rolling Sum Hours of Operation**



**NBVC Point Mugu Stationary Emergency Standby Engines**  
**2014 Maintenance Hours of Operation 12-Month Rolling Sum Report**

Permit Description	Model #	Serial #	BLDG	Dec	Nov	Oct	Sep	Aug	Jul	Jun	May	Apr	Mar	Feb	Jan
170 BHP Cummins	68TA5.9-G4	46476248	1	6.2	6.7	6.7	3.7	3.7	4.2	4.0	4.0	4.2	4.2	3.9	3.6
300 BHP Caterpillar	3306BD1	64Z08034	13	4.9	5.4	8.5	7.4	7.4	7.4	7.1	6.6	6.3	6.0	5.5	5.2
112 BHP Hino	4.0 Liter	2003740	14	1.5	1.5	1.5	1.5	2.0	2.5	2.5	3.0	3.0	3.2	2.7	2.2
1,588 BHP Caterpillar - Out of Service	3512	24Z01557	3008	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1,588 BHP Caterpillar	3512	24Z03302	3015	4.6	5.0	5.0	5.1	5.1	4.6	4.1	3.6	3.1	2.6	2.1	1.6
218 BHP Hercules - Removed	D46007A	4024618	303						5.5	5.5	12.5	12.2	12.2	11.7	11
324 BHP Cummins - New	QSB7-G5-NR3	73668636	303	7.0	7.0	7.0	7.0	0.0							
217 BHP Caterpillar	C-6.6	E6M02040	323	0.8	0.8	1.4	2.7	2.7	3.3	3.9	20.1	20.3	21.1	21.1	21.1
99 BHP Cummins	4BT3.9-G4	40403413	322	3.6	3.9	4.2	4.1	3.5	2.8	2.3	1.8	1.8	1.7	1.0	0.9
315 BHP John Deere	6068HF485T	PE6068L194673	355	12.8	12.8	12.8	12.3	12.3	12.8	12.3	27.4	27.1	18.3	18.3	26.9
288 BHP Cummins	6CTAA8.3-G3	46379697	359	4.5	5.0	5.0	5.0	4.8	4.8	4.3	19.2	18.9	18.8	18.3	18.0
355 BHP Cummins	NT-855-G2	11386660	369	4.0	4.0	4.0	4.5	4.0	4.0	4.2	11.1	10.9	10.4	9.9	9.4
398 BHP Caterpillar	C-9	C9E01847	50	13.2	14.3	13.8	14.4	14.4	14.9	14.2	21.4	21.3	21.0	21.3	22.3
364 BHP Cummins	QSL9-32	46572998	531	17.0	17.4	17.4	16.9	16.4	16.4	15.9	22.5	10.1	9.6	9.1	8.9
2,168 BHP Caterpillar	3516	25Z02032	53-2	0.9	0.7	0.7	0.9	0.9	0.9	0.9	9.0	9.0	9.0	9.0	9.0
90 BHP Cummins	4BT3.9-GA	46401266	58	5.0	5.5	5.5	5.5	5.5	5.6	5.1	12.8	12.5	12.2	11.7	11.2
145 BHP Cummins	QSB5-G3-NR3	73147572	63	25.1	25.1	25.1	25.1	25.1	25.6	25.6	25.1	25.1	25.1	23.1	23.1
399 BHP Cummins	QSL9-G3-NR3	46983124	64	4.5	5.0	5.0	5.0	5.1	5.1	5.1	5.1	4.8	5.0	4.5	4.0
103 BHP Caterpillar	3054	4ZK00846	67	4.0	4.0	4.0	4.0	4.5	5.0	5.0	5.0	4.7	4.3	3.6	2
145 BHP Cummins	QSB5-G3-NR3	73147613	674	26.6	26.6	26.1	26.1	26.1	26.6	26.6	33.4	33.4	33.4	31.4	31.3
188 BHP Cummins	6CT8.3-G2	46246632	812	16.7	17.2	17.2	17.7	17.2	17.3	17.3	24.8	12.3	11.8	11.3	11.0
166 BHP John Deere - Out of Service	6059TF001	T6059F414930	905	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
82 BHP Detroit - Out of Service	10347110	3A0096190	916	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
290 BHP John Deere	6076AF00	RG6076A153044	93	1.9	1.9	1.4	2.4	2.4	2.5	3.0	3.5	3.2	3.2	3.2	3.2
343 BHP Caterpillar	3406D1	2WB01836	99	1.7	1.7	2.2	2.7	2.2	2.7	3.2	3.7	3.8	3.8	3.6	3.6
158 BHP John Deere	4045H	PE4045L204764	Radar Road	5.9	6.7	6.9	7.4	7.4	13.6	13.1	13.1	16.3	16.0	14.7	13.1

**NBVC Point Mugu  
Airfield Runway Arresting Gear Engines  
Twelve-Month Rolling Sum Hours of Operation**

**NBVC Point Mugu Airfield Runway Arresting Gear Engines  
2014 Annual Hours of Operation 12-Month Rolling Sum Report**

Permit Description	Model #	Identification #	Location	Dec	Nov	Oct	Sep	Aug	Jul	Jun	May	Apr	Mar	Feb	Jan
65.9 BHP Wisconsin	V-465-D1	Unit-2-RAG1	Airfield Runway	46.0	45.0	45.5	46.1	47.3	49.7	46.8	49.8	46.9	41.2	36.0	28.3
65.9 BHP Wisconsin	V-465-D1	Unit-2-RAG2	Airfield Runway	44.0	43.4	44.4	45.2	46.4	48.6	46.2	48.5	45.4	39.6	33.7	29.0
65.9 BHP Wisconsin	V-465-D1	Unit-3-RAG3	Airfield Runway	48.1	50.5	52.5	56.8	61.0	65.0	66.4	64.6	66.8	59.3	55.5	50.8
65.9 BHP Wisconsin	V-465-D1	Unit-3-RAG4	Airfield Runway	47.8	50.4	52.3	56.5	60.7	63.6	64.9	63.8	66.6	59.1	55.0	50.6
65.9 BHP Wisconsin	V-465-D1	Unit-4-RAG5	Airfield Runway	42.0	45.8	49.3	53.7	58.7	64.7	68.3	68.1	71.8	65.5	61.1	56.5
65.9 BHP Wisconsin	V-465-D1	Unit-4-RAG6	Airfield Runway	42.8	41.0	38.9	37.8	37.5	37.8	36.1	37.1	35.9	29.5	25.8	20.7
65.9 BHP Wisconsin	V-465-D1	Unit-5-RAG7	Airfield Runway	50.6	49.4	50.8	51.4	52.1	53.8	51.3	53.5	49.4	43.5	38.5	31.4
65.9 BHP Wisconsin	V-465-D1	Unit-5-RAG8	Airfield Runway	47.7	46.4	48.2	49.4	49.9	51.6	48.4	50.6	46.4	40.0	35.7	29.6

**NBVC Point Mugu**  
**Stationary Standby Emergency Engines**  
**Emergency Hours of Operation**

**2014 Pint Mugu Stationary Emergency Standby Engines Emergency Hours of Operation**

Engine Description	Location	Emergency Usage (HR)	Date of Emergency Usage	Reason for Emergency Usage
343 BHP Caterpillar	99	27.2	1/29/2014-1/30/2014	Grid Power Failure
		40.9	2/28/2014-3/2/2014	Grid Power Failure



**NBVC Point Mugu  
Portable Engines Operation**

**Permitted Portable Engines Usage Record - Point Mugu 2014**

Engine USN	Date	Purpose of Engine Use	
		Emergency	Non-emergency/Maintenance
51-26066	Jan-14		18.5
51-26066	Mar-14		0.5
51-26066	Apr-14		0.5
51-26066	May-14		0.5
51-26066	Jul-14		0.5
51-26066	Aug-14		0.5
51-26066	Nov-14		0.8
51-26067	Feb-14		0.5
51-26067	Mar-14		0.5
51-26067	Apr-14		0.5
51-26067	May-14		0.5
51-26067	Jul-14		0.5
51-26067	Aug-14		0.5
51-26067	Sep-14		0.5
51-26067	Nov-14		0.5
51-26068	Jan-14		2.2
51-26068	Mar-14		0.5
51-26068	Apr-14		0.6
51-26068	May-14		0.5
51-26068	Jul-14		0.5
51-28008	Jan-14		18.5
51-28008	Mar-14		0.5
51-28008	Jun-14		0.6
51-28008	Jul-14		0.4
51-28008	Aug-14		0.5

**NBVC Point Mugu  
Rules 74.11 and 74.11.1 Small Boilers and  
Water Heaters Survey**

**2014 NBVC Point Mugu Rules 74.11 and 74.11.1 Survey Result**

Location	Building Number	Heat Input (BTU/HR)	Make	Model	Serial Number	Year Installed	In Compliance with the Rule 74.11.1?
PM	512	992,000	Raypak, Hi Delta Series	H8-0992B	1409385773	2014	Yes
PM	507	150,000	A.O.Smith Water Products Company	BTH 150 100	1406M002404	2014	Yes

## **Appendix D**

### **NBVC Point Mugu Gas Station Dispensing Facilities Verification Testing Results**

**NBVC Point Mugu  
Government Gasoline Dispensing Facility  
Verification Testing Results**



# Dynamic Back Pressure TP201.4

Ref. No.: \_\_\_\_\_  
 AQMD Id: \_\_\_\_\_  
 Site Name: NAVAL AIR STATION POINT MUGU  
 Address: BUILDING 63  
           POINT MUGU CA  
 Phone: 805-989-7903

## Testing Company

Name: Western Pump Inc.  
 Address: 3235 "F" St.  
           San Diego CA, 92102  
 Phone: 619-239-9988

DISPENSER No.	PRODUCT GRADE	NOZZLE MFG. & MODEL NUMBER	40CFH	60CFH	80 CFH
5	MOGAS	EMCO WHEATON 4005 EVR	0.12	0.32	0.56
6	MOGAS	EMCO WHEATON 4005 EVR	0.14	0.28	0.45
7	MOGAS	EMCO WHEATON 4005 EVR	0.14	0.24	0.36
8	MOGAS	EMCO WHEATON 4005 EVR	0.16	0.32	0.45

6/18/2014 Rotameter calibration date (Annual)  
6/18/2014 Pressure measuring device calibration date (Annual)  
9:25 Time of back pressure unit leak check (Prior to each sites' tests)  
0.48 Final pressure decay of back pressure unit in 5 minute.

Tester: BILLY HERNANDEZ  
 Signature:

Tester Id: 175862  
 Test Date: 10/16/2014

Updated 04/19/06 TATT Team

## 2 Inch Pressure Decay TP201.3

### Testing Company

Ref. No.: \_\_\_\_\_  
 AQMD Id: \_\_\_\_\_  
 Site Name: NAVAL AIR STATION POINT MUGU  
 Address: BUILDING 63  
POINT MUGU CA  
 Phone: 805-989-7903  
 Phase I System? \_\_\_\_\_ VAPOR POT  
 Phase II System? \_\_\_\_\_ BALANCE  
 Total # of Nozzles \_\_\_\_\_ 4  
 Products per Nozzle \_\_\_\_\_ 1

Name: WESTERN PUMP  
 Address: 3235 F STREET  
SAN DIEGO 92102  
 Phone: 619-239-9988  
 Tanks Manifolder? \_\_\_\_\_ N/A  
 Vapor Pot Present? \_\_\_\_\_ YES  
 Total # of Tanks \_\_\_\_\_ VAPOR POT

Tank Information	<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>All</u>
1. Product Grade	MOGAS				
2. Actual Tank Capacity, gallons	VAPOR POT				
3. Gasoline Volume, gallons	VAPOR POT				
4. Ullage, (V) gallons (line #2 minus line#3)	VAPOR POT				
Test Information	<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>5</u>
5. Start time	8:17				
6. Initial Test Pressure, inches H2O	2.50				
7. Pressure after 5 minutes, inches H2O	2.85				
8. Pressure after 10 minutes, inches H2O	2.95				
9. Pressure after 15 minutes, inches H2O	2.74				
10. Pressure after 20 minutes, inches H2O	2.65				
11. Pressure after 20 minutes, inches H2O	2.65				
12. Allowable Final Pressure	SIGNIFICANT				
13. Pass / Fail (Enter "GF" for Gross failure)	PASS				

10/16/2014	Requested Test Date.
8:00	Requested Test Time.
DIGITAL	What type of pressure device used?
9/15/2014	Calibration date for pressure device (90 days).
-0.34	Enter initial tank ullage pressure (Vent if over 0.5 in. w.c., then start the 30 min no dispensing period)
3CFM	Enter flowmeter rate, F(Must be 1 to 5 CFM).
VAPOR POT	Calculate ullage fill time, $t_2$ .
VAPOR POT	Calculate gross failure time (Twice $t_2$ ).
0	Enter ending value of drift test (Must be 0.01 in. w.c. or less).
VENT RISER	Record Vapor Coupler Integrity Test Assembly pressure after 1 minute and location.
VENT RISER	Nitrogen introduction point. Phase I vapor coupler or Phase II vapor riser?

$$t_2 = \frac{V}{[1522]F}$$

Tester: \_\_\_\_\_ BILLY HERNANDEZ \_\_\_\_\_

Tester Id: \_\_\_\_\_ 175862 \_\_\_\_\_

Signature: \_\_\_\_\_

Test Date: \_\_\_\_\_ 10/16/2014 \_\_\_\_\_





Liquid Removal  
TP 201.6 C

Ref. No.:

AQMD Id.:

Site Name:

Address:

Phone:

Testing Company

\*Note: If using short version, disregard adhesion/evaporation column.

Name:

Address:

Phone:

Dispenser Number	Product Grade	Gasoline Added (M), ml.	Gasoline Dispensed (G), gal.	Dispense Time (T), sec.	Dispensing Rate (GPM) 60(G)/(T)	Gasoline Remaining (VF), ml.	Adhesion/Evaporation (VW), ml.	Removal Rate ml/gal (M-VW-VF)/G	Comments (Liquid Drained - No Test required if less than 25mL)
5	MOGAS	100	10			0			
6	MOGAS	100	10			0			
7	MOGAS	100	10			0			
8	MOGAS	100	10			0			

Tester Name:

BILLY HERNANDEZ  
*Billy Hernandez*

Tester Id.:

175862

Signature:

Test Date:

10/16/2014

**NBVC Point Mugu  
Navy Exchange Gasoline Dispensing Facility  
Verification Testing Results**

**Veeder-Root In-Station Diagnostics (ISD)  
Site Shutdown Test Worksheet**

---

DATE OF TEST: 8/7/2014

SERVICE COMPANY NAME: TMR Environmental Testing	SERVICE COMPANY'S TELEPHONE: 805-218-0360
SERVICE TECHNICIAN Pramdeep Chase	VEEDER-ROOT TECH CERTIFICATION #: B38354
STATION NAME: Navy Exchange Auto Port	DISTRICT PERMIT #: NA
STATION ADDRESS: Building 161	CITY, STATE, ZIP: Point Mugu, CA 93042

STEP 1.	POWER REMOVED FROM TLS CONSOLE?	Yes
STEP 2.	POWER TO SUBMERSIBLE PUMPS REMOVED BY TLS? (VERIFY GASOLING FUELING DISABLED)	Yes
STEP 3.	POWER RESTORED TO TLS CONSOLE?	Yes

COMMENTS	(INCLUDE DESCRIPTION OF REPAIRS MADE)
----------	---------------------------------------

## SUMMARY OF SOURCE TEST DATA

SOURCE INFORMATION		FACILITY PARAMETERS		
GDF Name and Address <u>Navy Exchange Auto Port</u> <u>Building 161</u> <u>Point Mugu, CA 93042</u>	GDF Representative and Title  GDF Phone No. <u>NA</u>	PHASE II SYSTEM TYPE (Check One)		
Permit Conditions	Source: GDF Vapor Recovery System  GDF # _____ A/C # _____	Balance Hirt Red Jacket Hasstech Healy <span style="float: right;">X</span> Other	Manifolded? <span style="float: right;">Yes</span>	
Operating Parameters				
Number of Nozzels Served by Tank #1	<u>8</u>	Number of Nozzels Served by Tank #3	<u>8</u>	
Number of Nozzels Served by Tank #2	<u>8</u>	Number of Nozzels Served by Tank #4	<u>8</u>	
Applicable Regulations:		VN Recommended		
Source Test Results and Comments				
<b>Tank #</b>	<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>
1. Product Grade	<u>87-1</u>	<u>87-2</u>	<u>87-3</u>	<u>91</u>
2. Actual Tank Capacity, gallons	<u>12068</u>	<u>12068</u>	<u>12068</u>	<u>12068</u>
3. Gasoline Volume	<u>4415</u>	<u>3037</u>	<u>5812</u>	<u>4886</u>
4. Ullage, gallons (#2,#3)	<u>7653</u>	<u>9031</u>	<u>6256</u>	<u>7182</u>
5. Initial Pressure, inches H2O	<u>2.00</u>	<u>NA</u>		
6. Pressure After 1 Minute, inches H2O	<u>2.00</u>			
7. Pressure After 2 Minute, inches H2O	<u>1.99</u>			
8. Pressure After 3 Minute, inches H2O	<u>1.98</u>			
9. Pressure After 4 Minute, inches H2O	<u>1.97</u>			
10. Final Pressure After 5 Minute, inches H2O	<u>1.96</u>			
11. Allowable Final Pressure	<u>1.96</u>			
Test Conducted by:	Test Company:	Date of Test:		
<u>Jeff Briggs</u>	<u>TMR Environmental Testing</u>	<u>8/7/2014</u>		

TESTING COMPANY:

Site Name: Navy Exchange Auto Port  
Address: Building 161  
Point Mugu, CA 93042  
Phone: NA

Name: TMR Environmental Testing  
Address: P.O. Box 941983  
Simi Valley, CA 93094  
Phone: 805-218-0360

Figure 3  
Data Form for Determination of Satic Pressure Performance  
of the Healy Clean Air Seperator

Date and Time of Last Fuel Drop to GDF: 8-6-2014 / 12:24 PM  
Date of Last Calibration for Pressure Measurement Device: 5/9/2014

VACUUM TEST (Section 7.1 through 7.2.7)	
Vacuum at start of test, inches water column (7.2.3)	
Vacuum at one minute, inches water column	
Vacuum at two minutes, inches water column	
Vacuum at three minutes, inches water column	
Vacuum at four minutes, inches water column	
Final vacuum at five minutes, inches water column	
<b>System was not under a vacuum</b>	
Allowable minimum vacuum, inches water column (from table1):	

POSTIVE PRESSURE TEST (Section 7.3 through 7.3.9)	
Pressure at start of test, inches water column (7.3.8)	2.00
Pressure at one minute, inches water column	2.00
Pressure at two minutes, inches water column	2.06
Pressure at three minutes, inches water column	2.12
Pressure at four minutes, inches water column	2.20
Final Pressure at five minutes, inches water column	2.30
Allowable final Pressure, inches water column (7.3.9):	
	1.77

Tester: Jeff Briggs

Test Date: 8/7/2014

**Site:**

Site Name: Navy Exchange Auto Port  
 Address: Building 161  
Point Mugu, CA 93042  
 Phone: NA

**Testing Company**

Name: TMR Environmental Testing  
 Address: P.O. Box 941983  
Simi Valley, CA 93094  
 Phone: (805) 218-0360

Allowable A/L: 0.95-1.15

CARB EO: VR-202

Meter Leak Tests: Pre-Test Leak Check (Pass/Fail):  
 (For TriTester only) Post-Test Leak Check (Pass/Fail):

Test Unit Serial Number: 0438565

Test Unit Calibration Date: 7/16/2014

Pass  
Pass

*Note: Bulb must not inflate in less than 30 seconds.*

Dispenser Number	Product Grade	Nozzle Model #	V/L	GPM	PASS /FAIL	Comments
1	87	900	1.01	7.14	Pass	2 Gallons @ Vapor Pipe
1	89	900	1.01	6.79	Pass	
1	91	900	1.00	7.21	Pass	
2	87	900	1.01	7.65	Pass	
2	89	900	1.00	7.21	Pass	
2	91	900	1.02	7.58	Pass	
3	87	900	1.11	7.35	Pass	2 Gallons @ Vapor Pipe
3	89	900	1.01	7.08	Pass	
3	91	900	1.01	7.58	Pass	
4	87	900	1.01	7.58	Pass	
4	89	900	1.02	7.65	Pass	
4	91	900	1.01	7.81	Pass	
5	87	900	0.96	7.73	Pass	2 Gallons @ Vapor Pipe
5	89	900	0.95	7.73	Pass	
5	91	900	1.01	7.58	Pass	
6	87	900	1.00	7.38	Pass	
6	89	900	0.99	7.21	Pass	
6	91	900	0.98	7.73	Pass	
7	87	900	0.99	6.00	Pass	2 Gallons @ Vapor Pipe
7	89	900	1.00	7.21	Pass	
7	91	900	0.98	7.81	Pass	
8	87	900	1.06	6.00	Pass	
8	89	900	1.02	6.15	Pass	
8	91	900	1.00	7.58	Pass	
NA						

Tester: Jeff Briggs

Test Date: 8/7/2014

Site:

TESTING COMPANY:

Site Name: Navy Exchange Auto Port  
Address: Building 161  
Point Mugu, CA 93042  
Phone: NA

Name: TMR Environmental Testing  
Address: P.O. Box 941983  
Simi Valley, CA 93094-1983  
Phone: 805-218-0360

**EXHIBIT 8**  
**ITEMS TO CONSIDER IN CONDUCTING TP-201.3**

The instructions below are required when conducting TP-201.3 for this system. The tester shall document that each step was followed as indicated below and shall include this page of the Exhibit with the submission of TP-201.3 test results. Note that districts may require use of an alternate form to meet these requirements, provided the alternate form includes the same minimum parameters.

- 1 Prior to conducting TP-201.3, all four ball valves on the Healy Clean Air Separator (CAS) shall be closed, as shown in Figure 1, to isolate it from the UST system to permit the pressurization of the UST system.
- 2 Conducting TP-201.3 with any dispenser piping test valve in the closed position is not permitted. Any dispenser with a dispenser piping test valve in the closed position while conducting TP-201.3 will bias the test towards compliance.
- 3 After conducting TP-201.3, the four ball valves on the Healy Clean Air Separator (CAS) shall be locked in their normal operating positions as shown in Figure 2B-5 of Exhibit 2.

Required Steps	Verification
1.All four CAS ball valves closed befor conducting TP-201.3	<b>Yes</b>
2. All dispenser piping test valves open before conducting TP-201.3	<b>Yes</b>
3. All four CAS ball valves in normal operating positions after conucting TP-201.3	<b>Yes</b>

Tester: Jeff Briggs

Test Date: 8/7/2014

## Data Form for Vapor Pressure Sensor Ambient Reference Test

DATE OF TEST:

8/7/2014

SERVICE COMPANY NAME: TMR Environmental Testing		SERVICE COMPANY'S TELEPHONE: 805-218-0360	
SERVICE TECHNICIAN:	Pramdeep Chase	VEEDER-ROOT TECH CERTIFICATION #: (as applicable)	B38354
SERVICE TECHNICIAN:	Jeff Briggs	ICC or DISTRICT TRAINING CERTIFICATION: (as applicable)	8161213-VT
STATION NAME: Navy Exchange Auto Port			
STATION ADDRESS: Building 161		CITY, STATE, ZIP: Point Mugu, CA 93042	

PRESSURE SENSOR LOCATION:	FP: 1/2	PRESSURE SENSOR SERIAL NUMBER:	<u>11431</u>
---------------------------	---------	--------------------------------	--------------

STEP 8.3	DIGITAL MANOMETER VALUE <u>2.22</u> inches WC
STEP 8.3	TLS 350 SENSOR VALUE <u>2.194</u> inches WC (OBTAIN VALUE USING TLS CONSOLE KEYPAD SEQUENCE SHOWN IN FIG. 8-4, Vapor Pressure)
STEP 8.4	TLS 350 Sensor Value within $\pm 0.2$ inches WC of Digital Manometer Value? Yes <u>XX</u> No _____  EXHIBIT 2.
STEP 8.5	MODE KEY PRESSED TO EXIT PMC DIAGNOSITC MENU? <u>Yes</u>



### Data Form for Vapor Pressure Sensor Ambient Reference Test

DATE OF TEST:

8/7/2014

SERVICE COMPANY NAME:	TMR Environmental Testing	SERVICE COMPANY'S TELEPHONE:	805-218-0360
SERVICE TECHNICIAN:	Pramdeep Chase	VEEDER-ROOT TECH CERTIFICATION #: (as applicable)	B38354
SERVICE TECHNICIAN:	Jeff Briggs	ICC or DISTRICT TRAINING CERTIFICATION: (as applicable)	8161213-VT
STATION NAME:	Navy Exchange Auto Port		
STATION ADDRESS:	Building 161	CITY, STATE, ZIP:	Point Mugu, CA 93042

STEP 9.1	Pressure Sensor Location:	FP: 1/2	PRESSURE SENSOR SERIAL NUMBER:	<u>11431</u>
----------	---------------------------	---------	--------------------------------	--------------

STEP 9.2	REFERENCE PORT CAP REMOVED? <u>Yes</u> VALVE SET TO AMBIENT REFERENCE PORT (PER FIG. 8-3)? <u>Yes</u>
STEP 9.3	NON-CALIBRATED SENSOR VALUE <u>-0.014</u> INCHES OF WATER COLUMN (OBTAIN VALUE USING TLS CONSOLE KEYPAD SEQUENCE SHOWN IN FIG. 8-4. Vapor pressure)
STEP 9.4	PRESSURE BETWEEN +0.20 & -0.20 (Y/N)? <u>Yes</u> IF NO: THE PRESSURE SENSOR IS NOT IN COMPLIANCE WITH THE PRESSURE SENSOR REQUIREMENTS OF EXHIBIT 2.
STEP 9.5	REFERENCE PORT CAP REPLACED <u>Yes</u> VALVE SET TO NORMAL VALVE POSITION (PER FIG 8-3?) <u>Yes</u>
STEP 6.	MODE KEY PRESSED TO EXIT CALIBRATE SMART SENSOR MENU? <u>Yes</u>

Veeder-Root In-Station Diagnostics (ISD)  
Vapor Flow Meter Operability Test Procedure

DATE OF TEST:	8/7/2014
---------------	----------

SERVICE COMPANY NAME:		TMR Environmental		SERVICE COMPANY'S TELEPHONE:		(805) 218 - 0360			
SERVICE TECHNICIAN:		Pramdeep Chase		VEEDER-ROOT TECH CERTIFICATION #: (as applicable)		B38354			
SERVICE TECHNICIAN:		Jeff Briggs		ICC or DISTRICT TRAINING CERTIFICATION: (as applicable)		8161213-VT			
STATION NAME:				Navy Exchange Auto Port		DISTRICT PERMIT #:		NA	
STATION ADDRESS:				Building 161		CITY, STATE, ZIP CODE: Point Mugu, CA 93042			
STEP 2.	VAPOR FLOW METER SERIAL NUMBER			56092		56093			
	DISPENSER FUELING POINT NUMBERS			FP #	1	FP #	3		
STEP 3.	LOW GRADE FUEL HOSE V/L RESULT #1 (ONE FP ONLY)			1.01		1.11			
STEP 4.	ISD A/L VALUE #1 CORRESPONDING TO RESULT IN STEP 3			1.00		1.00			
STEP 5.	STEP 4. VALUE MINUS STEP 3. VALUE			DIFF.	-0.01	DIFF.	0.11		
	PASS IF DIFFERENCE IS WITHIN +/- 0.15, LARGER DIFFERENCE, THEN CONTINUE TO STEP 6 (CIRCLE ONE)			PASS	CONTINUE TO STEP 6	PASS	CONTINUE TO STEP 6		
STEP 6.	LOW GRADE FUEL HOSE V/L RESULT #2			NA		NA			
	LOW GRADE FUEL HOSE V/L RESULT #3			NA		NA			
	AVERAGE OF 3 V/L RESULTS			AVG.	NA	AVG.	NA		
STEP 7.	ISD A/L VALUE #2			NA		NA			
	ISD A/L VALUE #3			NA		NA			
	AVERAGE OF 3 A/L VALUES			AVG.	NA	AVG.	NA		
STEP 8.	STEP 7. AVG MINUS STEP 6. AVG			DIFF.	NA	DIFF.	NA		
	PASS IF DIFFERENCE IS WITHIN +/- 0.15, IF LARGER DIFFERENCE, THEN CONTINUE TO STEP 9			NA	CONTINUE TO STEP 6	NA	CONTINUE TO STEP 6		
STEP 9	IF CONTINUE, REPEAT AT STEP 3. FOR 2ND FP USING 2ND FP COLUMN, ABOVE,								

STATION NAME:		Navy Exchange Auto Port		DISTRICT PERMIT #:		NA	
STATION ADDRESS:		Building 161		CITY:		STATE, ZIP:	
				Point Mugu, CA		93042	
STEP 2.	VAPOR FLOW METER SERIAL NUMBER	56302		56089			
	DISPENSER FUELING POINT NUMBERS	FP #	5	FP #	7		
STEP 3.	LOW GRADE FUEL HOSE V/L RESULT #1 (ONE FP ONLY)	0.96		0.99			
STEP 4.	ISD A/L VALUE #1 CORRESPONDING TO RESULT IN STEP 3	1.02		0.96			
STEP 5.	STEP 4. VALUE MINUS STEP 3. VALUE	DIFF.	0.06	DIFF.	-0.03		
	PASS IF DIFFERENCE IS WITHIN +/- 0.15, LARGER DIFFERENCE, THEN CONTINUE TO STEP 6 (CIRCLE ONE)	PASS	CONTINUE TO STEP 6	PASS	CONTINUE TO STEP 6		
STEP 6.	LOW GRADE FUEL HOSE V/L RESULT #2	NA		NA			
	LOW GRADE FUEL HOSE V/L RESULT #3	NA		NA			
	AVERAGE OF 3 V/L RESULTS	AVG.	NA	AVG.	NA		
STEP 7.	ISD A/L VALUE #2	NA		NA			
	ISD A/L VALUE #3	NA		NA			
	AVERAGE OF 3 A/L VALUES	AVG.	NA	AVG.	NA		
STEP 8.	STEP 7. AVG MINUS STEP 6. AVG	DIFF.	NA	DIFF.	NA		
	PASS IF DIFFERENCE IS WITHIN +/- 0.15, IF LARGER DIFFERENCE, THEN CONTINUE TO STEP 9	NA	CONTINUE TO STEP 6	NA	CONTINUE TO STEP 6		
STEP 9	IF CONTINUE, REPEAT AT STEP 3. FOR 2ND FP USING 2ND FP COLUMN, ABOVE,						

Required Data When Conducting the  
Liquid Condensate Trap Compliance Test Procedure

Liquid Condensate Trap Compliance Test Form

Testing Company

Site Name: Navy Exchange Auto Port  
Address: Building 161  
Point Mugu, CA 93042  
Phone: NA  
Date of Test: 8/7/2014

Name: TMR Environmental  
Address: P.O. Box 941983  
Simi Valley, CA 93094  
Phone: (805) 218 - 0360

Certification #'s (as applicable)  
District Permit #: NA  
ICC Cert. #: 8161213-VT

Healy Tech. Cert. #: 8453853704

Capacity of LCT in gallons: 9.9

Applicable Step Number	Requirement	Verification (please circle)	
STEP 3.2	Gasoline below 90 percent capacity level of UST?	<u>YES</u>	
STEP 5.3	Was tag with LCT capacity present above Fuel Entry Point?	<u>YES</u>	
STEP 6.2	Did Liquid Sensor activate an Audible Alarm as well as Visual Alarm at control panel within five minutes after adding gasoline? (Attach alarm/sensor status	<u>YES</u>	
STEP 6.3	Did LCT evacuate and Sensor Alarms clear? (Attach alarm/sensor status printout to this Form.)	<u>YES</u>	

Tester: Jeff Briggs

Test Date: 8/7/2014