

CRIMSON CALIFORNIA



February 14, 2017

Dan Searcy
Manager, Compliance Division
Ventura County Air Pollution Control District
669 County Square Drive
Ventura, CA 93003

VIA CERTIFIED MAIL
RETURN RECEIPT REQUESTED
CLAIM NO. 7016 1370 0001 2436 8225

**SUBJECT: 2017 TITLE V ANNUAL COMPLIANCE CERTIFICATION
VENTURA HARBOR STATION FACILITY ID 00082**

Dear Mr. Searcy:

Enclosed is the Title V Annual Compliance Certification for Crimson California Pipeline, L.P.'s Ventura Harbor Station Facility ID 00082. This report covers the compliance period of January 1, 2016 through December 31, 2016.

Should any questions arise feel free to contact Crimson Environmental at (562) 285-4040.

Respectfully,

Valerie Jackson
VP Engineering & Regulatory Affairs

CC: Mr. Gerardo Rios, Chief, EPA Region 9

Enclosures: Title V Annual Compliance Certification 1/1/2016 – 12/31/2016

RECEIVED
VENTURA COUNTY
2017 FEB 17 AM 9:30
A.P.C.D.



RECEIVED
VENTURA COUNTY
2017 FEB 17 AM 9:32
A.P.C.D.

VENTURA HARBOR STATION FACILITY ID 00082

**Ventura County Air Pollution Control District
Title V Annual Compliance Certification
January 1, 2016 – December 31, 2016**



Ventura County
Air Pollution
Control District

**ANNUAL COMPLIANCE CERTIFICATION
SIGNATURE COVER FORM**

A copy of each Annual Compliance Certification shall be submitted to EPA, Region 9, at the following address:



Mr. Gerardo Rios, Chief
Permits Office (AIR-3)
Office of Air Division
EPA Region 9
75 Hawthorne Street
San Francisco, CA 94105

Confidentiality

All information in a Part 70 permit compliance certification is public information. The Part 70 permit is also public information.

Certification by Responsible Official

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in this compliance certification are true, accurate, and complete.

<p>Signature and Title of Responsible Official:</p>  <p>Title: President</p>	<p>Date:</p> 
---	--

<p>Time Period Covered by Compliance Certification</p> <p><u>01</u> / <u>01</u> / <u>16</u> (MM/DD/YY) to <u>12</u> / <u>31</u> / <u>16</u> (MM/DD/YY)</p>
--



ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 16 (MM/DD/YY) to 12 / 31 / 16 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment No. 71.2N2</p>	<p>D. Frequency of monitoring: Annually</p>
<p>B. Description: External floating roof crude oil storage tank ≥ 40,000 gallons Rules 71.2B4, 71.2C.1, 71.2D, 71.2E.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable Rule 71.2 Inspection</p>
<p>C. Method of monitoring: Secondary seals were inspected on May 9, 2016. Primary seals last inspected on May 13, 2015.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment No. 71.4N1</p>	<p>D. Frequency of monitoring: Quarterly</p>
<p>B. Description: Sumps, pits, and ponds with covers. Fugitive emissions monitoring and integrity of cover.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable EPA Method 21</p>
<p>C. Method of monitoring: Quarterly fugitive emission (Rule 74.10) inspections were conducted on Feb 17, 2016; May 4, 2016; Jul 29, 2016; and Oct 7, 2016. The integrity of the cover was verified. No leaks greater than 10,000 ppm were discovered.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment No. 74.9N3</p>	<p>D. Frequency of monitoring: Quarterly</p>
<p>B. Description: Stationary natural gas fired - rich-burn internal combustion engine quarterly inspections and biennial source test.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable CARB Method 100</p>
<p>C. Method of monitoring: Quarterly Emissions testing conducted on Mar 10, 2016; Jun 23, 2016; Sep 8, 2016 (Enterprise only); and Nov 17, 2016 (Enterprise only). Caterpillar G-1 operated 2hrs during 3rd qtr and did not operate during 4th qtr. As a result Caterpillar G-1 was exempt per Rule 74.6B (5). Biennial source test last conducted on Jan 23, 2015.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 16 (MM/DD/YY) to 12 / 31 / 16 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment No. 40CFR63ZZZN5</p>	<p>D. Frequency of monitoring: Every 1,440 hours or annually, whichever comes first</p>
<p>B. Description: RICE MACT for non-emergency 4SRB =< 500HP oil and filter change maintenance.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Maintenance records, hours of operation.</p>	<p>F. Currently in Compliance? (Y or N): <u> Y </u></p> <p>G. Compliance Status? (C or I): <u> C </u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u> Y </u></p> <p><i>*If yes, attach Deviation Summary Form</i></p>

<p>A. Attachment # or Permit Condition #: Attach No. PO0082PC1 - Cond No. 1</p>	<p>D. Frequency of monitoring: Monthly</p>
<p>B. Description: Throughput and consumption limits.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Facility throughput and fuel consumption for engines and/or tanks recorded monthly.</p>	<p>F. Currently in Compliance? (Y or N): <u> Y </u></p> <p>G. Compliance Status? (C or I): <u> C </u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u> N </u></p> <p><i>*If yes, attach Deviation Summary Form</i></p>

<p>A. Attachment # or Permit Condition #: Attach No. PO0082PC1 - Cond No. 2</p>	<p>D. Frequency of monitoring: Intermittent</p>
<p>B. Description: Combustion equipment shall only burn natural gas.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Combustion equipment only burns natural gas.</p>	<p>F. Currently in Compliance? (Y or N): <u> Y </u></p> <p>G. Compliance Status? (C or I): <u> C </u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u> N </u></p> <p><i>*If yes, attach Deviation Summary Form</i></p>



ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 16 (MM/DD/YY) to 12 / 31 / 16 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attach No. PO0082PC1 - Cond No. 3</p>	<p>D. Frequency of monitoring: Monthly</p>
<p>B. Description: Solvent usage and exemptions.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Safety data sheets and additional information of any solvents used during this compliance period obtained and reviewed. Usage of required solvents logged monthly.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p><i>*If yes, attach Deviation Summary Form</i></p>

<p>A. Attachment # or Permit Condition #: Attachment No. PO0082PC2</p>	<p>D. Frequency of monitoring: Quarterly</p>
<p>B. Description: BACT for Caterpillar Engine G-1 - emissions limits (ROC, NOx, CO). Monitor Air:Fuel ratio controller readings quarterly.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable CARB Method 100</p>
<p>C. Method of monitoring: Biennial source test last conducted on Jan 23, 2015. Air:Fuel ratio controllers monitored on Engine Data Sheets.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p><i>*If yes, attach Deviation Summary Form</i></p>

<p>A. Attachment # or Permit Condition #: Attachment No. 50</p>	<p>D. Frequency of monitoring: Intermittent</p>
<p>B. Description: Opacity observation at the facility</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable EPA Method 9</p>
<p>C. Method of monitoring: Annual opacity conducted by AirX Testing Services, Inc. on Nov 17, 2016. Opacity surveillance and visual inspections of emissions conducted and recorded on fugitive emission log.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p><i>*If yes, attach Deviation Summary Form</i></p>



ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 16 (MM/DD/YY) to 12 / 31 / 16 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment No. 54.B.1</p>	<p>D. Frequency of monitoring: Intermittent</p>
<p>B. Description: Sulfur emissions from combustion operations at point of discharge; follow monitoring requirements under Rule 64.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Facility follows monitoring requirements under Rule 64. Only PUC grade natural gas combusted at this facility. No additional periodic monitoring required.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment No. 54.B.2</p>	<p>D. Frequency of monitoring: Intermittent</p>
<p>B. Description: Emission of sulfur compounds.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Only PUC grade natural gas combusted at this facility.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment No. 55</p>	<p>D. Frequency of monitoring: Intermittent</p>
<p>B. Description: Fugitive Dust.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: No dust generating activities were conducted at this facility during this compliance period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>



ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 16 (MM/DD/YY) to 12 / 31 / 16 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment No. 57.1</p>	<p>D. Frequency of monitoring: Intermittent</p>
<p>B. Description: Particulate matter emissions from fuel burning equipment.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: This facility does not have any fuel burning equipment such as boilers, steam generators, process heaters, water heaters, flares, and gas turbines. Internal combustion engines do not apply.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment No. 64.B.1</p>	<p>D. Frequency of monitoring: Intermittent</p>
<p>B. Description: Sulfur content of fuels - gaseous fuel requirements.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Only PUC grade natural gas combusted at this facility. No periodic monitoring required.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment No. 74.6</p>	<p>D. Frequency of monitoring: Intermittent</p>
<p>B. Description: Solvent cleaning activities</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: No reportable solvents used at this facility during this compliance period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>



ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 16 (MM/DD/YY) to 12 / 31 / 16 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment No. 74.10</p>	<p>D. Frequency of monitoring: Quarterly</p>
<p>B. Description: Fugitive leak and leak inspections.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable EPA Method 21</p>
<p>C. Method of monitoring: Quarterly component leak detection inspections conducted on Feb 17, 2016; May 4, 2016; Jul 29, 2016; and Oct 7, 2016. Routine surveillance at this unmanned facility recorded on fugitive emission log.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p><small>*If yes, attach Deviation Summary Form</small></p>

<p>A. Attachment # or Permit Condition #: Attachment No. 74.11.1</p>	<p>D. Frequency of monitoring: Intermittent</p>
<p>B. Description: Large water heaters and small boilers.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: This facility is not equipped with large water heaters or small boilers.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p><small>*If yes, attach Deviation Summary Form</small></p>

<p>A. Attachment # or Permit Condition #: Attachment No. 74.22</p>	<p>D. Frequency of monitoring: Intermittent</p>
<p>B. Description: Requirements for natural gas-fired fan-type central furnaces</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: This facility is not equipped with fan-type central furnaces.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p><small>*If yes, attach Deviation Summary Form</small></p>



ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 16 (MM/DD/YY) to 12 / 31 / 16 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment No. 74.1</p>	<p>D. Frequency of monitoring: Intermittent</p>
<p>B. Description: Abrasive blasting.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: No abrasive blasting activities were conducted at this facility during this compliance period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment No. 74.2</p>	<p>D. Frequency of monitoring: Intermittent</p>
<p>B. Description: Architectural coatings.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: No architectural coatings were applied at this facility during this compliance period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment No. 74.26</p>	<p>D. Frequency of monitoring: Intermittent</p>
<p>B. Description: Crude oil storage tank degassing operations.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: No crude oil storage tank degassing activities were conducted at this facility during this compliance period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>



ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 16 (MM/DD/YY) to 12 / 31 / 16 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment No. 74.29N3</p>	<p>D. Frequency of monitoring: Intermittent</p>
<p>B. Description: Soil decontamination operation.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: No soil decontamination activities were conducted at this facility during this compliance period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p><i>*If yes, attach Deviation Summary Form</i></p>

<p>A. Attachment # or Permit Condition #: Attachment No. 40 CFR.61.M</p>	<p>D. Frequency of monitoring: Intermittent</p>
<p>B. Description: National emission standards for asbestos</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: No asbestos removal, renovation, or demolition activities were conducted at this facility during this compliance period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p><i>*If yes, attach Deviation Summary Form</i></p>

<p>A. Attachment # or Permit Condition #:</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description:</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p>
<p>C. Method of monitoring:</p>	<p>F. Currently in Compliance? (Y or N): _____</p> <p>G. Compliance Status? (C or I): _____</p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): _____</p> <p><i>*If yes, attach Deviation Summary Form</i></p>



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION SOURCE TEST SUMMARY FORM

Period Covered by Compliance Certification: 01 / 01 / 16 (MM/DD/YY) to 12 / 31 / 16 (MM/DD/YY)

A. Emission Unit Description: 415 HP Caterpillar NG Rich Burn Engine G-1			B. Pollutant: NOx
C. Measured Emission Rate: 3.6 ppmv @ 15% O2	D. Limited Emission Rate: 9 ppmv @15% O2	E. Specific Source Test or Monitoring Record Citation: AirX Testing Services, Inc.	F. Test Date: Mar 3, 2016

A. Emission Unit Description: 415 HP Caterpillar NG Rich Burn Engine G-1			B. Pollutant: CO
C. Measured Emission Rate: 72 ppmv @ 15% O2	D. Limited Emission Rate: 1,000 ppmv @15% O2	E. Specific Source Test or Monitoring Record Citation: AirX Testing Services, Inc.	F. Test Date: Mar 3, 2016

A. Emission Unit Description: 465 HP Enterprise GSG-6 NG Rich Burn Engine G-3			B. Pollutant: NOx
C. Measured Emission Rate: 18.4 ppmv @ 15% O2	D. Limited Emission Rate: 25 ppmv @15% O2	E. Specific Source Test or Monitoring Record Citation: AirX Testing Services, Inc.	F. Test Date: Mar 3, 2016

A. Emission Unit Description: 465 HP Enterprise GSG-6 NG Rich Burn Engine G-3			B. Pollutant: CO
C. Measured Emission Rate: 2,975 ppmv @ 15% O2	D. Limited Emission Rate: 4,500 ppmv @ 15% O2	E. Specific Source Test or Monitoring Record Citation: AirX Testing Services, Inc.	F. Test Date: Mar 3, 2016

A. Emission Unit Description:			B. Pollutant:
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test or Monitoring Record Citation:	F. Test Date:



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION SOURCE TEST SUMMARY FORM

Period Covered by Compliance Certification: 01 / 01 / 16 (MM/DD/YY) to 12 / 31 / 16 (MM/DD/YY)

A. Emission Unit Description: 415 HP Caterpillar NG Rich Burn Engine G-1			B. Pollutant: NOx
C. Measured Emission Rate: 2.3 ppmv @ 15% O2	D. Limited Emission Rate: 9 ppmv @15% O2	E. Specific Source Test or Monitoring Record Citation: AirX Testing Services, Inc.	F. Test Date: Jun 23, 2016

A. Emission Unit Description: 415 HP Caterpillar NG Rich Burn Engine G-1			B. Pollutant: CO
C. Measured Emission Rate: 679 ppmv @ 15% O2	D. Limited Emission Rate: 1,000 ppmv @15% O2	E. Specific Source Test or Monitoring Record Citation: AirX Testing Services, Inc.	F. Test Date: Mar 3, 2016

A. Emission Unit Description: 465 HP Enterprise GSG-6 NG Rich Burn Engine G-3			B. Pollutant: NOx
C. Measured Emission Rate: 22.7 ppmv @ 15% O2	D. Limited Emission Rate: 25 ppmv @15% O2	E. Specific Source Test or Monitoring Record Citation: AirX Testing Services, Inc.	F. Test Date: Jun 23, 2016

A. Emission Unit Description: 465 HP Enterprise GSG-6 NG Rich Burn Engine G-3			B. Pollutant: CO
C. Measured Emission Rate: 1,640 ppmv @ 15% O2	D. Limited Emission Rate: 4,500 ppmv @ 15% O2	E. Specific Source Test or Monitoring Record Citation: AirX Testing Services, Inc.	F. Test Date: Jun 23, 2016

A. Emission Unit Description:			B. Pollutant:
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test or Monitoring Record Citation:	F. Test Date:



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION

SOURCE TEST SUMMARY FORM

Period Covered by Compliance Certification: 01 / 01 / 16 (MM/DD/YY) to 12 / 31 / 16 (MM/DD/YY)

A. Emission Unit Description: 415 HP Caterpillar NG Rich Burn Engine G-1			B. Pollutant: NOx
C. Measured Emission Rate: Exempt per Rule 74.9B(5) 3rd Qtr - Operated 2 hrs	D. Limited Emission Rate: 9 ppmv @15% O2	E. Specific Source Test or Monitoring Record Citation:	F. Test Date:

A. Emission Unit Description: 415 HP Caterpillar NG Rich Burn Engine G-1			B. Pollutant: CO
C. Measured Emission Rate: Exempt per Rule 74.9B(5) 3rd Qtr - Operated 2 hrs	D. Limited Emission Rate: 1,000 ppmv @15% O2	E. Specific Source Test or Monitoring Record Citation:	F. Test Date:

A. Emission Unit Description: 465 HP Enterprise GSG-6 NG Rich Burn Engine G-3			B. Pollutant: NOx
C. Measured Emission Rate: 6.1 ppmv @ 15% O2	D. Limited Emission Rate: 25 ppmv @15% O2	E. Specific Source Test or Monitoring Record Citation: AirX Testing Services, Inc.	F. Test Date: Sep 8, 2016

A. Emission Unit Description: 465 HP Enterprise GSG-6 NG Rich Burn Engine G-3			B. Pollutant: CO
C. Measured Emission Rate: 3,800 ppmv @ 15% O2	D. Limited Emission Rate: 4,500 ppmv @ 15% O2	E. Specific Source Test or Monitoring Record Citation: AirX Testing Services, Inc.	F. Test Date: Sep 8, 2016

A. Emission Unit Description:			B. Pollutant:
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test or Monitoring Record Citation:	F. Test Date:



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION

SOURCE TEST SUMMARY FORM

Period Covered by Compliance Certification: 01 / 01 / 16 (MM/DD/YY) to 12 / 31 / 16 (MM/DD/YY)

A. Emission Unit Description: 415 HP Caterpillar NG Rich Burn Engine G-1			B. Pollutant: NOx
C. Measured Emission Rate: Exempt per Rule 74.9B(5) 4th Qtr - Not operated	D. Limited Emission Rate: 9 ppmv @15% O2	E. Specific Source Test or Monitoring Record Citation:	F. Test Date:

A. Emission Unit Description: 415 HP Caterpillar NG Rich Burn Engine G-1			B. Pollutant: CO
C. Measured Emission Rate: Exempt per Rule 74.9B(5) 4th Qtr - Not operated	D. Limited Emission Rate: 1,000 ppmv @15% O2	E. Specific Source Test or Monitoring Record Citation:	F. Test Date:

A. Emission Unit Description: 465 HP Enterprise GSG-6 NG Rich Burn Engine G-3			B. Pollutant: NOx
C. Measured Emission Rate: 20.9 ppmv @ 15% O2	D. Limited Emission Rate: 25 ppmv @15% O2	E. Specific Source Test or Monitoring Record Citation: AirX Testing Services, Inc.	F. Test Date: Nov 17, 2016

A. Emission Unit Description: 465 HP Enterprise GSG-6 NG Rich Burn Engine G-3			B. Pollutant: CO
C. Measured Emission Rate: 2,925 ppmv @ 15% O2	D. Limited Emission Rate: 4,500 ppmv @ 15% O2	E. Specific Source Test or Monitoring Record Citation: AirX Testing Services, Inc.	F. Test Date: Nov 17, 2016

A. Emission Unit Description:			B. Pollutant:
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test or Monitoring Record Citation:	F. Test Date:



ANNUAL COMPLIANCE CERTIFICATION DEVIATION SUMMARY FORM

Period Covered by Compliance Certification: 01 / 01 / 16 (MM/DD/YY) to 12 / 31 / 16 (MM/DD/YY)

A. Attachment # or Permit Condition #: Attachment No. 40CFR63ZZZN5 RICE MACT	B. Equipment description: 415 HP Caterpillar NG Rich Burn Engine G-1	C. Deviation Period: Date & Time Begin: <u>Sep 4, 2016</u> End: <u>Feb 3, 2017</u> When Discovered: Date & Time <u>Jan 25, 2017 3:00pm</u>
D. Parameters monitored: Engine Oil & Filter Change	E. Limit: Every 1,440 hours or annually, whichever comes first	F. Actual: 17 months (operated 331 hours between inspections)
G. Probable Cause of Deviation: Awareness of annual maintenance requirement.		H. Corrective actions taken: Form updated to include the annual maintenance requirement. Engine hour and date of next required maintenance will be posted near engines to remind personnel on-site of upcoming maintenance.

A. Attachment # or Permit Condition #: Attachment No. 40CFR63ZZZN5 RICE MACT	B. Equipment description: 465 HP Enterprise GSG-6 NG Rich Burn Engine G-3	C. Deviation Period: Date & Time Begin: <u>Unknown</u> End: <u>Jun 15, 2016</u> When Discovered: Date & Time <u>Jun 13, 2016</u>
D. Parameters monitored: Engine Oil & Filter Change	E. Limit: Every 1,440 hours or annually, whichever comes first	F. Actual: 1,522 hours (exceeded by 82 hours)
G. Probable Cause of Deviation: Mistracking of engine hours.		H. Corrective actions taken: Engine hour and date of next required maintenance will be posted near engines to remind personnel on-site of upcoming maintenance.

A. Attachment # or Permit Condition #: 	B. Equipment description: 	C. Deviation Period: Date & Time Begin: _____ End: _____ When Discovered: Date & Time _____
D. Parameters monitored: 	E. Limit: 	F. Actual:
G. Probable Cause of Deviation: 		H. Corrective actions taken:

Ventura County Air Pollution Control District
 RULE 71.2 COMPLIANCE REPORT

PLEASE COMPLETE FORM LEGIBLY IN BLACK INK

Page 1 of 4

Tank No 150305 VCAPCD Permit No. 00082 Inspection Date 05 09 2016 Time 08:43
 Is This a Follow-up Inspection? No Yes If yes, Date of Previous Inspection _____

A. COMPANY INFORMATION:

Company Name Crimson Pipeline LLC
 Location Address 1200 SPINNAKER DR. City VENTURA Zip 93001
~~3760 Kilroy Airport Way, Suite 300~~ ~~Long Beach~~ ~~90806~~ *DMG*
 Mailing Address Same as above. 3760 KILROY AIRPORTWAY #300 City LONG BEACH Zip 90806
 Contact Person Donna M. Diaz Title Environmental Engineer
 Phone (562) 353-6952

B. INSPECTION CONDUCTED BY:

Name Sebastian Vidopol Title Inspector
 Company Name HMT Inspection Phone 3103651729
 Mailing Address 4075 E La Palma Ave., Suite M, City Anaheim Zip 92807

C. TANK INFORMATION:

Capacity 160000 (bbls) Installation Date 1951 Tank Diameter 150.00 (ft) Tank Height 50' 7" (ft)
 Product Type Crude Oil Product RVP NO DATA If Crude, H₂S Content NO DATA (ppm weight)
 Type of Tank: Riveted Welded Other (describe) _____
 Color of Shell TAN Color of Roof WHITE
 Roof Type: Pontoon Double Deck Other (describe) _____
 External floating roof Internal floating roof

D. GROUND LEVEL INSPECTION:

1) Product Temperature 67.2 °F 2) Product level 20 FT 4.750ⁱⁿ (ft)
 3) List type and location of leaks found in tank shell.
None
 4) List any discrepancies between the existing equipment and the equipment description on the Permit.
None
 5) Is tank in compliance with Permit conditions? No Yes If no, explain _____

E. INTERNAL FLOATING ROOF TANK:

1) Check vapor space between floating roof and fixed roof with explosimeter. N/A % LEL
 2) Conduct visual inspection of roofs and secondary seals, if applicable. N/A
 3) Are all roof openings covered? If no, explain in Comments section (J) and proceed to part (H)(6).

F. EXTERNAL FLOATING ROOF TANK:

- 1) On the diagram (below) indicate the location of the ladder, roof drain(s), anti-rotation device(s), platform, gauge well, and vents or other appurtenances. *Note information in relation to North (to the top of the worksheet).*
- 2) Describe any uncovered openings found on the roof in the Comments section J
- 3) Identify any tears in the seal fabric. Describe and indicate on diagram (below):

4) Secondary Seal Inspection

- a) Type of Secondary Seal: DOUBLE WIPER
- b) Does 1/2" probe drop past seal? No Yes if yes, measure length(s) and show on diagram
- c) Does 1/8" probe drop past seal? No Yes if yes, measure length(s) and show on diagram.
- d) Record dimensions of gap for gaps > 1/8" ∅ > 1/2" ∅

NOTE: Record the actual width and cumulative length of gaps in feet and inches.

(Do not include gaps > 1/2" in 1/8" measurements)


5) Primary Seal Inspection NOT INSPECTED AT THIS TIME

- a) Type of Primary Seal: Metallic Shoe; Tube; Other _____
- b) (shoe seal) does 1-1/2" probe drop past seal? No Yes ; if yes, measure length(s) and show on diagram.
- c) (shoe seal) does 1/2" probe drop past seal? No Yes if yes, measure length(s) and show on diagram.
- d) (tube seal) does 1/2" probe drop past seal? if yes, measure (length(s) and show on diagram.
- e) (all seal types) does 1/8" probe drop past seal? No Yes if yes, measure (length(s) and show on diagram.
- f) Record dimensions of gaps for gaps > 1/8" n/a > 1/2" n/a

> 1-1/2" n/a NOTE: Record the actual width and cumulative length of gaps in feet and inches.

(Do not include gaps > 1/2" in 1/8" measurements, or gaps > 1-1/2" in 1/2" measurements)

NOTE: Show defects using symbols. Show seal gaps and lengths.



LEGEND:

Equipment:

- ⌘ Antirotational device
- ⌘ Gauge well
- ⌘ Leg stand
- ⌘ Roof drain
- * Emergency roof drain
- 8 Vacuum breaker
- Vent
- ⌘ Platform & ladder

Defects:

- × Leg top
- × Leg pin
- ∨ Open hatch
- ∨ Torn seal
- |-P-| Primary seal gap
- |-S-| Secondary seal gap

Ventura County Air Pollution Control District
RULE 71.2 COMPLIANCE REPORT

****PLEASE COMPLETE FORM LEGIBLY IN BLACK INK****

Tank No. 150305 VCAPCD Permit No. 00082

Page 3 of 4

IF INTERNAL FLOATING ROOF TANK, PROCEED TO PART H(6).

G. CALCULATIONS - complete all applicable portions of the following:

Record dimensions of indicated gaps [from F(4)(d), F(5)(b), and F(5)(f)]. Record in feet and inches.

Gaps in primary seal between 1/8 and 1/2 inch: n/a

Gaps in primary seal between 1/2 and 1-1/2 inch: n/a

Gaps in primary seal greater than 1-1/2 inches: n/a

Gaps in secondary seal between 1/8 and 1/2 inch: Ø

Gaps in secondary seal greater than 1/2 inch: Ø

Multiply diameter (ft) of tank to determine appropriate gap limits: Diameter 150 feet

5% circumference = diameter X 0.157 = 23.55 60% circ. = diam. X 1.88 = _____

10% circumference = diameter X 0.314 = 47.1 90% circ. = diam. X 2.83 = _____

40% circumference = diameter X 0.942 = 188.4 95% circ. = diam. X 2.98 = _____

H. DETERMINE COMPLIANCE STATUS OF TANK:

- | | | | | |
|----|--|-----------------------------|--|---|
| 1) | Were any openings found on the roof? | <u>→ N/A</u> | No <input type="checkbox"/> | Yes <input type="checkbox"/> |
| 2) | Were any tears in the seals found: | <u>→ N/A</u> | No <input type="checkbox"/> | Yes <input type="checkbox"/> |
| 3) | Is the product level lower than the level at which the roof would be floating? | | No <input checked="" type="checkbox"/> | Yes <input type="checkbox"/> |
| 4) | Secondary Seal: | | | |
| | Did 1/2" probe drop between shell and seal? | | No <input checked="" type="checkbox"/> | Yes <input type="checkbox"/> |
| | Did cumulative 1/8" - 1/2" gap exceed 5% circumference length? | | No <input checked="" type="checkbox"/> | Yes <input type="checkbox"/> |
| 5) | Primary Seal | | | |
| | Shoe | | | |
| | Did 1-1/2" probe drop between shell and seal? | <u>N/A</u> | No <input type="checkbox"/> | Yes <input type="checkbox"/> |
| | Did cumulative 1/2" - 1-1/2" gap exceed 10% circumference length, and | <u>N/A</u> | | |
| | Did cumulative 1/8 - 1/2" gap exceed 40% circumference length? | <u>N/A</u> | No <input type="checkbox"/> | Yes <input type="checkbox"/> |
| | Did any single continuous 1/8" - 1-1/2" gap exceed 10% circ. length? | <u>N/A</u> | No <input type="checkbox"/> | Yes <input type="checkbox"/> |
| | Tube | | | |
| | Did 1/2" probe drop between shell and seal | <u>N/A</u> | N/A | |
| | Did cumulative 1/8" - 1/2" gap exceed 95% circumference length? | <u>N/A</u> | N/A | |
| 6) | Internal floating roof (installed before 6/1/84) did LEL exceed 50% | <u>N/A</u> | N/A | |
| | (installed after 6/1/84) did LEL exceed 30%? | | N/A | |
| 7) | Does tank have permit conditions? | <u>* FOR 2nd SEAL ONLY.</u> | No <input type="checkbox"/> | Yes <input checked="" type="checkbox"/> |
| | Does tank comply with these conditions? | | No <input type="checkbox"/> | Yes <input checked="" type="checkbox"/> |

I. IF INSPECTION WAS TERMINATED PRIOR TO COMPLETION FOR ANY REASON, PLEASE EXPLAIN:

J. COMMENTS:

Use this section to complete answers to above listed items and to describe repairs made to the tank; include date and time repairs were made.

- No primary seal inspection was performed at this time.

ONLY 2nd SEAL INSPECTED & FOUND ACCEPTABLE.

K. I(We) certify the foregoing information to be correct and complete to the best of my(our) knowledge.

Inspection completed by: [Signature] SN 001 Date: 05/09/2016

Compliance status by: [Signature] SN 001 Date: 05/09/2016

Company Representative: [Signature] Date: 05/09/2016

[Signature]

5/9/2016

SEND COMPLETED REPORT (Both Sheets) TO:

Ventura County Air Pollution Control District

FOR VCAPCD USE ONLY: Date received _____

Reviewed by: _____ Date reviewed _____
 (Signature) (Certification ID #)

Tank Status: in compliance in violation, Rule(s) _____

Comments: _____



Ventura County APCD
Rule 74.10 Component Leak Report

Q1/2016

Company Crimson Pipeline, LP
Facility Ventura Harbor Pump Station
1200 Spinnaker Dr., Ventura, CA 93003

District ID 00082
Contact Brad Seeley
(562) 285-4113

Component Group	Accessible	Inaccessible	Leaks	Percentage
Stuffing Box	0	0	0	0
Threaded Component	2	0	0	0
Valve	1	0	0	0
Flange	0	0	0	0
Compressor	0	0	0	0
Pump	0	0	0	0
Atmospheric PRD	0	0	0	0
Other	0	0	0	0

**No Reportable Leaks for this Quarter
Inspected on 02/17/2016**



Ventura County APCD
Rule 74.10 Component Leak Report

Q2/2016

Company Crimson Pipeline, LLC
Facility Ventura Harbor Pump Station
1200 Spinnaker Dr., Ventura, CA 93003

District ID 00082
Contact Brad Seeley
(562) 285-4113

Component Group	Accessible	Inaccessible	Leaks	Percentage
Stuffing Box	0	0	0	0
Threaded Component	2	0	0	0
Valve	1	0	0	0
Flange	0	0	0	0
Compressor	0	0	0	0
Pump	0	0	0	0
Atmospheric PRD	0	0	0	0
Other	0	0	0	0

No Reportable Leaks for this Quarter
Inspected on 05/04/2016



Ventura County APCD
Rule 74.10 Component Leak Report

Q3/2016

Company Crimson Pipeline, LLC
Facility Ventura Harbor Pump Station
1200 Spinnaker Dr., Ventura, CA 93003

District ID 00082
Contact Brad Seeley
(562) 285-4113

Component Group	Accessible	Inaccessible	Leaks	Percentage
Stuffing Box	0	0	0	0
Threaded Component	2	0	0	0
Valve	1	0	0	0
Flange	0	0	0	0
Compressor	0	0	0	0
Pump	0	0	0	0
Atmospheric PRD	0	0	0	0
Other	0	0	0	0

No Reportable Leaks for this Quarter
Inspected on 07/29/2016



Ventura County APCD
Rule 74.10 Component Leak Report

Q4/2016

Company Crimson Pipeline, LLC
Facility Ventura Harbor Pump Station
1200 Spinnaker Dr., Ventura, CA 93003

District ID 00082
Contact Brad Seeley
(562) 285-4113

Component Group	Accessible	Inaccessible	Leaks	Percentage
Stuffing Box	0	0	0	0
Threaded Component	2	0	0	0
Valve	1	0	0	0
Flange	0	0	0	0
Compressor	0	0	0	0
Pump	0	0	0	0
Atmospheric PRD	0	0	0	0
Other	0	0	0	0

No Reportable Leaks for this Quarter
Inspected on 10/07/2016



SUMMARY OF SOURCE TEST RESULTS
Crimson Pipeline
Harbor
Enterprise ICE
1/23/2015

<i>CONSTITUENTS</i>	<i>MEASURED VALUES</i>			<i>AVERAGE</i>	<i>Allowable</i>
	<i>Run #1</i>	<i>Run #2</i>	<i>Run #3</i>		
Oxides of Nitrogen					
ppmv	57.6	58.0	57.6	57.7	-
ppmv @ 15% O2	16.3	16.4	16.3	16.3	25
lb/hr	0.15	0.15	0.18	0.16	-
lb/MMBtu	0.060	0.060	0.060	0.060	-
gm/BHP-hr	0.17	0.17	0.19	0.18	-
Carbon Monoxide					
ppmv	8093	8596	9046	8578	-
ppmv @ 15% O2	2286	2429	2555	2423	4500
lb/hr	12.94	13.75	16.88	14.52	-
lb/MMBtu	5.12	5.44	5.73	5.43	-
gm/BHP-hr	14.15	15.04	18.47	15.89	-
Total Non-Methane/Ethane Hydrocarbons, as CH4					
ppmv, dry	-	-	-	3.7	-
ppmv @ 15% O2, dry	-	-	-	1.0	250
lb/hr	-	-	-	0.005	-
Oxygen, %	0.0	0.0	0.0	0.0	-
Stack Flowrate, dscfm	367	367	428	387	-
Moisture, %	17.9	17.9	17.9	17.9	-
Fuel Usage, cfm	40.1	40.1	46.8	42.3	-



SUMMARY OF SOURCE TEST RESULTS
 Crimson Pipeline
 Harbor
 CAT ICE
 1/23/2015

<i>CONSTITUENTS</i>	<i>MEASURED VALUES</i>			<i>AVERAGE</i>
	<i>Run #1</i>	<i>Run #2</i>	<i>Run #3</i>	
Oxides of Nitrogen				
ppmv	17.6	17.8	17.6	17.7
ppmv @ 15% O2	5.0	5.0	5.0	5.0
lb/hr	0.039	0.039	0.038	0.039
lb/MMBtu	0.018	0.018	0.018	0.018
gm/BHP-hr	0.042	0.043	0.042	0.042
Carbon Monoxide				
ppmv	289	357	324	323
ppmv @ 15% O2	81.6	101	91.3	91.2
lb/hr	0.38	0.48	0.43	0.43
lb/MMBtu	0.183	0.226	0.205	0.204
gm/BHP-hr	0.42	0.52	0.47	0.47
Total Non-Methane/Ethane Hydrocarbons, as CH4				
ppmv, dry	< 1.5	< 1.5	< 1.5	< 1.5
ppmv @ 15% O2, dry	< 0.4	< 0.4	< 0.4	< 0.4
lb/hr	< 0.0014	< 0.0014	< 0.0014	< 0.0014
Oxygen, %	0.0	0.0	0.0	0.0
Stack Flowrate, dscfm	305	305	305	305
Moisture, %	18.0	17.9	17.9	18.0
Fuel Usage, cfm	33.4	33.4	33.4	33.4



SUMMARY OF SOURCE TEST RESULTS
Quarterly Emission Testing
Crimson Pipeline
Ventura Pump Station
G-3

3/10/2016

		<i>Allowable</i>
Oxides of Nitrogen (NOx)		
ppmv	64.9	-
ppmv @ 15% O2	18.4	25
Carbon Monoxide (CO)		
ppmv	10475	-
ppmv @ 15% O2	2975	4500
Oxygen (O2), percent	0.1	-

Note: Reported values represent a 15 minute average.



SUMMARY OF SOURCE TEST RESULTS
Quarterly Emission Testing
Crimson Pipeline
Ventura Pump Station
CAT

3/10/2016

		<i>Allowable</i>
Oxides of Nitrogen (NOx)		
ppmv	12.6	-
ppmv @ 15% O2	3.6	9
Carbon Monoxide (CO)		
ppmv	255	-
ppmv @ 15% O2	72	1000
Oxygen (O2), percent	0.0	-

Note: Reported values represent a 15 minute average.



SUMMARY OF SOURCE TEST RESULTS
Quarterly Emission Testing
Crimson Pipeline
Ventura Harbor Pump Station
G-3

6/23/2016

		<i>Allowable</i>
Oxides of Nitrogen (NOx)		
ppmv	80.2	-
ppmv @ 15% O2	22.7	25
Carbon Monoxide (CO)		
ppmv	5786	-
ppmv @ 15% O2	1640	4500
Oxygen (O2), percent	0.1	-

Note: Reported values represent a 15 minute average.



SUMMARY OF SOURCE TEST RESULTS
Quarterly Emission Testing
Crimson Pipeline
Ventura Pump Station
CAT

6/23/2016

		<i>Allowable</i>
Oxides of Nitrogen (NOx)		
ppmv	8.0	-
ppmv @ 15% O2	2.3	9
Carbon Monoxide (CO)		
ppmv	2395	-
ppmv @ 15% O2	679	1000
Oxygen (O2), percent	0.1	-

Note: Reported values represent a 15 minute average.

SUMMARY OF SOURCE TEST RESULTS
Quarterly Emission Testing
Crimson Pipeline
Ventura Harbor Pump Station
G-3

9/8/2016

		<i>Allowable</i>
Oxides of Nitrogen (NOx)		
ppmv	21.6	-
ppmv @ 15% O2	6.1	25
Carbon Monoxide (CO)		
ppmv	13479	-
ppmv @ 15% O2	3800	4500
Oxygen (O2), percent	0.0	-

Note: Reported values represent a 15 minute average.

SUMMARY OF SOURCE TEST RESULTS
Quarterly Emission Testing
Crimson Pipeline
Ventura Harbor
G-3

11/17/2016

		<i>Allowable</i>
Oxides of Nitrogen (NOx)		
ppmv	73.7	-
ppmv @ 15% O2	20.9	25
Carbon Monoxide (CO)		
ppmv	10320	-
ppmv @ 15% O2	2925	4500
Oxygen (O2), percent	0.1	-
Opacity, %	0.0	10%

Note: Reported values represent a 15 minute average.



SUMMARY OF SOURCE TEST RESULTS
Quarterly Emission Testing
Crimson Pipeline
Ventura Pump Station
CATERPILLAR ICE

11/17/2016

		<i>Allowable</i>
Oxides of Nitrogen (NOx)		
ppmv	<i>NM</i>	-
ppmv @ 15% O2	<i>NM</i>	25
Carbon Monoxide (CO)		
ppmv	<i>NM</i>	-
ppmv @ 15% O2	<i>NM</i>	4500
Oxygen (O2), percent	<i>NM</i>	-
Opacity, %	0.0	10%

NM = Not Measured

Note: Reported values represent a 15 minute average.

**VENTURA STATION ENGINE DATA SHEET
CATERPILLAR G-1**

ENGINE G1

OPERATOR _____

SHIFT _____

DATE 1/11/16 - 1/18/16

ENGINE TIMER: START _____ FINISH _____ TOTAL HOURS _____

LUBE OIL LEVEL _____

OIL ADDED TO ENGINE _____

AIR PRESSURE _____

HOUR	10 MIN		20 MIN		Mon	Tue	Wed	Thur	Fri			
	10 MIN	20 MIN	1/11	1/12					1/15			
DISCHARGE PRESSURE				497					↓			
SUCTION PRESSURE				116					↓			
ENGINE RPM'S				738					↓			
ENGINE WATER PRESSURE				15					↓			
ENGINE WATER TEMP				90					↓			
HEAT EXCHANGER TEMP				130					↓			
AIR/FUEL PRESS				662					↓			
ENGINE OIL PRESSURE				60					↓			
ENGINE OIL TEMP				90					↓			
CONVERTER TEMP TC-1				731					DO 32			
CONVERTER TEMP TC-2				672					↑			
OXY. OUTPUT (mv)									↑			

CS

REMARK: _____

Turbine oil
68
132

VENTURA STATION ENGINE DATA SHEET ENTERPRISE G-3

ENGINE TIMER: START 16122 FINISH 16232 TOTAL HOURS 110

INITIALS	JP	CS	JP	JP	JP		
DATE	1/18	1/19	1/20	1/21	1/22		
DAY	1/18/2016 - 1/25/2016	MON	TUE	WED	THUR	FRI	SAT SUN
DISCHARGE PRESSURE	533.8	525			528		
SUCTION PRESSURE	112.1	110			111.8		
ENGINE RPM'S	380	380			380		
JACKET WATER PRESSURE	26	27			28		
JACKET WATER TEMP	167.7	164			166		
HEAT EXCHANGER TEMP	122	120			125		
INBOARD BEARING TEMP	119.8	118 107			116		
OUTBOARD BEARING TEMP	139.0	110			132		
AIR/FUEL PRESS - FRONT	.876	.894			.866		
AIR/FUEL PRESS - BACK	.157	.138			.152		
LUBE OIL LEVEL	1/2	3/8			1/2		
OIL ADDED TO ENGINE	206.1	—			106.1		
LUBE OIL ENG PRESS	57	58			57		
GEAR BOX OIL PRESSURE	10	10			11		
LUBE OIL FILTER	66	65			65		
CONVERTER TEMP TC-1	770	784			791		
CONVERTER TEMP TC-2	754	737		D	755	D	
CYLINDER #1	968	985		O	971	O	
CYLINDER #2	957	951		W	946	W	
CYLINDER #3	1032	971		N	973	N	
CYLINDER #4	1027	1007		↑	1018	↑	
CYLINDER #5	1019	1018			1023		
CYLINDER #6	1019	1013			1017		
AIR PRESSURE	200	210			205		
WATER MAKE-UP TANK	Full	Full			Full		
GAS METER READING							

VENTURA STATION ENGINE DATA SHEET
ENTERPRISE G-3

ENGINE TIMER: START 16349 FINISH 16484 TOTAL HOURS 135

INITIALS	JP	JP	JP	JP			
DATE	2-8	2-9	2-10	2-11			
DAY	2-8-16 / 2-15-16	MON	TUE	WED	THUR	FRI	SAT SUN
DISCHARGE PRESSURE	529	519			501	509	
SUCTION PRESSURE	113	111			110	109	
ENGINE RPM'S	378	378			371	373	
JACKET WATER PRESSURE	27	46 28			27	27	
JACKET WATER TEMP	167	167			167	166	
HEAT EXCHANGER TEMP	125 125	135			137	130	
INBOARD BEARING TEMP	125	128			126	119	
OUTBOARD BEARING TEMP	156	162			157	147	
AIR/FUEL PRESS - FRONT	.820	.818			.803	.800	
AIR/FUEL PRESS - BACK	.146	.139			.159	.149	
LUBE OIL LEVEL	1/2	1/2			1/2	1/2	
OIL ADDED TO ENGINE	20 Gals	0 Gal			0 Gal	18 Gal	
LUBE OIL ENG PRESS	54	53			54	54	
GEAR BOX OIL PRESSURE	9	8			8	8	
LUBE OIL FILTER	61	60			60	60	
CONVERTER TEMP TC-1	830	855	V		789	794	
CONVERTER TEMP TC-2	763	769	D		755	754	
CYLINDER #1	979	977	O		983	977	
CYLINDER #2	954	970	W		967	960	
CYLINDER #3	969	970	N		966	1056	
CYLINDER #4	1074	1063	A		1059	1063	
CYLINDER #5	1029	1021			1024	1022	
CYLINDER #6	1031	1017			1023	1016	
AIR PRESSURE	210	205			204	210	
WATER MAKE-UP TANK	Full	Full			Full	Full	
GAS METER READING	159553	155142			156030	156503	

00

VENTURA STATION ENGINE DATA SHEET
ENTERPRISE G-3

ENGINE TIMER: START 16784 FINISH 16856 TOTAL HOURS 72

INITIALS	SP	JP	R	SP	JP		
DATE	3-14 / 3-21	3-14	3-15	3-16	3-17	3-18	
DAY	MON	TUE	WED	THUR	FRI	SAT	SUN
DISCHARGE PRESSURE	506			519			
SUCTION PRESSURE	109			108			
ENGINE RPM'S	373			380			
JACKET WATER PRESSURE	27			28			
JACKET WATER TEMP	157			167			
HEAT EXCHANGER TEMP	150 118			132			
INBOARD BEARING TEMP	103			122			
OUTBOARD BEARING TEMP	104			150			
AIR/FUEL PRESS - FRONT	.849			.800			
AIR/FUEL PRESS - BACK	.789			.811			
LUBE OIL LEVEL	1/2			1/2			
OIL ADDED TO ENGINE	12 gal			12 gal			
LUBE OIL ENG PRESS	60			56			
GEAR BOX OIL PRESSURE	12			9			
LUBE OIL FILTER	66	↓	↓	61	↓		
CONVERTER TEMP TC-1	729	D	D	746	D		
CONVERTER TEMP TC-2	759	O	O	758	O		
CYLINDER #1	1002	W	W	992	W		
CYLINDER #2	1032	N	N	961	N		
CYLINDER #3	965	↑	↑	973	↑		
CYLINDER #4	1001			995			
CYLINDER #5	1001			999			
CYLINDER #6	1027			1026			
AIR PRESSURE	205			205			
WATER MAKE-UP TANK	Full			Full			
GAS METER READING	164897			165816			

VENTURA STATION ENGINE DATA SHEET
ENTERPRISE G-3

ENGINE TIMER: START 17156 FINISH 17299 TOTAL HOURS 143

INITIALS	JP	JP	ST	JP	JP		
DATE	4-18-16	4-19	4-20	4-21	4-22		
DAY	MON	TUE	WED	THUR	FRI	SAT	SUN
DISCHARGE PRESSURE		469	436.3		435		
SUCTION PRESSURE		109	108.6		110		
ENGINE RPM'S		358	343		342		
JACKET WATER PRESSURE		25	24		24		
JACKET WATER TEMP		166	176		166		
HEAT EXCHANGER TEMP		130	130		130		
INBOARD BEARING TEMP		121	118.4		120		
OUTBOARD BEARING TEMP		147	141.9		145		
AIR/FUEL PRESS - FRONT		.760	.751		.744		
AIR/FUEL PRESS - BACK		.820	.798		.801		
LUBE OIL LEVEL		1/2	1/2		1/2		
OIL ADDED TO ENGINE		0	0		136al		
LUBE OIL ENG PRESS		58	57		58		
GEAR BOX OIL PRESSURE	↓	8	8	↓	7		
LUBE OIL FILTER	D	64	63	D	64		
CONVERTER TEMP TC-1	0	714	693	0	688		
CONVERTER TEMP TC-2	W	724	691	W	681		
CYLINDER #1	N	971	959	N	956		
CYLINDER #2	↑	978	1007	↑	971		
CYLINDER #3		958	950		949		
CYLINDER #4		1022	998		959		
CYLINDER #5		975	969		951		
CYLINDER #6		1002	970		964		
AIR PRESSURE		210	210		215		
WATER MAKE-UP TANK		Full	FULL		Full		
GAS METER READING		17358	17440		17494		

VENTURA STATION ENGINE DATA SHEET
ENTERPRISE G-3

ENGINE TIMER: START 17609 FINISH 17675 TOTAL HOURS 66

INITIALS	JP	JP	JP	JP			
DATE	5-23-16	5-24	5-25	5-26			
DAY	MON	TUE	WED	THUR	FRI	SAT	SUN
DISCHARGE PRESSURE				519			
SUCTION PRESSURE				107			
ENGINE RPM'S				378			
JACKET WATER PRESSURE				27			
JACKET WATER TEMP				170			
HEAT EXCHANGER TEMP				130			
INBOARD BEARING TEMP				124			
OUTBOARD BEARING TEMP				149			
AIR/FUEL PRESS - FRONT				.803			
AIR/FUEL PRESS - BACK				.782			
LUBE OIL LEVEL				1/2			
OIL ADDED TO ENGINE				25gal	8gal		
LUBE OIL ENG PRESS				58			
GEAR BOX OIL PRESSURE				10			
LUBE OIL FILTER				65			
CONVERTER TEMP TC-1	↓	↓	↓	765	↓		
CONVERTER TEMP TC-2	D	D	D	772	D		
CYLINDER #1	O	O	O	1002	O		
CYLINDER #2	W	W	W	982	W		
CYLINDER #3	N	N	N	991	N		
CYLINDER #4	↑	↑	↑	1011	↑		
CYLINDER #5				1011			
CYLINDER #6				1036			
AIR PRESSURE				205			
WATER MAKE-UP TANK				Full			
GAS METER READING				183185			

VENTURA STATION ENGINE DATA SHEET
ENTERPRISE G-3

ENGINE TIMER: START 17939 FINISH 18036 TOTAL HOURS _____

INITIALS	SP	SP	SP		SP		
DATE	6-27	6-28	6-29		6-7-1		
DAY	MON	TUE	WED	THUR	FRI	SAT	SUN
DISCHARGE PRESSURE	411	411					
SUCTION PRESSURE	107	106					
ENGINE RPM'S	336	332					
JACKET WATER PRESSURE	24	23					
JACKET WATER TEMP	166	167					
HEAT EXCHANGER TEMP	135	135					
INBOARD BEARING TEMP	120	121					
OUTBOARD BEARING TEMP	147	148					
AIR/FUEL PRESS - FRONT	.758	.760					
AIR/FUEL PRESS - BACK	.763	.789					
LUBE OIL LEVEL	1/2	1/2					
OIL ADDED TO ENGINE	11	Ø					
LUBE OIL ENG PRESS	57	58					
GEAR BOX OIL PRESSURE	7	7					
LUBE OIL FILTER	64	62					
CONVERTER TEMP TC-1	686	691					
CONVERTER TEMP TC-2	669	677	↓		↓		
CYLINDER #1	913	930	D		D		
CYLINDER #2	932	947	O		O		
CYLINDER #3	932	922	W		W		
CYLINDER #4	931	1015	N		N		
CYLINDER #5	950	955	↑		↑		
CYLINDER #6	964	977					
AIR PRESSURE	205	205					
WATER MAKE-UP TANK	Full	Full					
GAS METER READING	190363	190816					

VENTURA STATION ENGINE DATA SHEET
ENTERPRISE G-3

ENGINE TIMER: START 18094 FINISH 18173 TOTAL HOURS 79

INITIALS	JP	JP	JP	JP	JP		
DATE	7-11-16 / 7-18-16		7-11	7-12	7-13	7-14	7-15
DAY	MON	TUE	WED	THUR	FRI	SAT	SUN
DISCHARGE PRESSURE		438			420		
SUCTION PRESSURE		111			107		
ENGINE RPM'S		340			338		
JACKET WATER PRESSURE		23			24		
JACKET WATER TEMP		167			166		
HEAT EXCHANGER TEMP		135			132		
INBOARD BEARING TEMP		123			121		
OUTBOARD BEARING TEMP		148			146		
AIR/FUEL PRESS - FRONT		.757			.752		
AIR/FUEL PRESS - BACK		.798			.793		
LUBE OIL LEVEL		1/2			1/2		
OIL ADDED TO ENGINE		20 local			0		
LUBE OIL ENG PRESS		58			57		
GEAR BOX OIL PRESSURE		7			7		
LUBE OIL FILTER		64			64		
CONVERTER TEMP TC-1		695			698		
CONVERTER TEMP TC-2	↓	687	↓	↓	688		
CYLINDER #1	D	945	D	D	945		
CYLINDER #2	O	952	O	O	940		
CYLINDER #3	W	748	W	w	940		
CYLINDER #4	N	1015	N	N	1026		
CYLINDER #5	↑	962	↑	↑	968		
CYLINDER #6		988			987		
AIR PRESSURE		210			220		
WATER MAKE-UP TANK		Full			Full		
GAS METER READING		193872			194515		

VENTURA STATION ENGINE DATA SHEET
ENTERPRISE G-3

ENGINE TIMER: START 184104 FINISH 185800 TOTAL HOURS 96

INITIALS	JP	SP	JP	SP	JP	SP	
DATE	8-22	8-23	8-24	8-25	8-26	8-27	
DAY	MON	TUE	WED	THUR	FRI	SAT	SUN
DISCHARGE PRESSURE		115	427	416			
SUCTION PRESSURE		111	110	108			
ENGINE RPM'S		336	339	336			
JACKET WATER PRESSURE		24	23	24			
JACKET WATER TEMP		167	167	167			
HEAT EXCHANGER TEMP		135	135	135			
INBOARD BEARING TEMP		120	122	121			
OUTBOARD BEARING TEMP		144	146	148			
AIR/FUEL PRESS - FRONT		.762	.761	.760			
AIR/FUEL PRESS - BACK		.793	.786	.788			
LUBE OIL LEVEL		1/2	1/2	1/2			
OIL ADDED TO ENGINE		20 gal	0	16 gal			
LUBE OIL ENG PRESS		58	57	57			
GEAR BOX OIL PRESSURE		8	7	8			
LUBE OIL FILTER		65	64	63			
CONVERTER TEMP TC-1		691	685	686			
CONVERTER TEMP TC-2	✓	672	665	669	✓		
CYLINDER #1	D	931	921 931	940	D		
CYLINDER #2	O	929	927 942	935	O		
CYLINDER #3	W	911	911 921	918	W		
CYLINDER #4	N	939	930 941	951	N		
CYLINDER #5	↑	939	939 941	950	↑		
CYLINDER #6		965	965 957	960			
AIR PRESSURE		215	210	220			
WATER MAKE-UP TANK		Full	Full	Full			
GAS METER READING		201861	202366	202838			

VENTURA STATION ENGINE DATA SHEET
ENTERPRISE G-3

ENGINE TIMER: START 18129 FINISH 18712 TOTAL HOURS 83

INITIALS	JP	JP	JP	JP	JP	S.T.	S.T.
DATE	9-5/9-12-16	9-6	9-7	9-8	9-9	9-10	9-11
DAY	MON	TUE	WED	THUR	FRI	SAT	SUN
DISCHARGE PRESSURE				405		411	427.8
SUCTION PRESSURE				108		106.2	108.1
ENGINE RPM'S				329		336	339
JACKET WATER PRESSURE				22		24	24
JACKET WATER TEMP				166		168.1	164
HEAT EXCHANGER TEMP				135		130	130
INBOARD BEARING TEMP				121		121.8	123.1
OUTBOARD BEARING TEMP				147		148.5	149.1
AIR/FUEL PRESS - FRONT				.027		.030	.012
AIR/FUEL PRESS - BACK				.786		.800	.799
LUBE OIL LEVEL				1/2		7/16	1/2
OIL ADDED TO ENGINE			25g	0		17g.	—
LUBE OIL ENG PRESS				58		57	57
GEAR BOX OIL PRESSURE				7		8	8
LUBE OIL FILTER				64		64	64
CONVERTER TEMP TC-1				689		709	709
CONVERTER TEMP TC-2				655		674	675
CYLINDER #1		✓	✓	923	✓	947	943
CYLINDER #2	D	D	D	940	D	954	957
CYLINDER #3		O	O	914	O	911	921
CYLINDER #4	O	W	W	936	W	931	953
CYLINDER #5	W	N	N	936	N	952	947
CYLINDER #6		↑	↑	954	↑	968	951
AIR PRESSURE	N			210		205	215
WATER MAKE-UP TANK	I			Full		Full	Full
GAS METER READING	I			205305		206020	206499

VENTURA STATION ENGINE DATA SHEET
ENTERPRISE G-3

ENGINE TIMER: START 18907 FINISH 18957 TOTAL HOURS 50

INITIALS	JP	JP	JP	JP	JP	JP	JP
DATE	10.3	10.4	10.5	10.6	10.7	10.8	10.9
DAY	MON	TUE	WED	THUR	FRI	SAT	SUN
DISCHARGE PRESSURE	466		472	447		442	
SUCTION PRESSURE	109		110	109		111	
ENGINE RPM'S	350		358	345		337	
JACKET WATER PRESSURE	26		26	25		24	
JACKET WATER TEMP	167		168	167		169	
HEAT EXCHANGER TEMP	135		135	125		135	
INBOARD BEARING TEMP	119		123	120		121	
OUTBOARD BEARING TEMP	143		147	143		145	
AIR/FUEL PRESS - FRONT	.092		.091	.000		.095	
AIR/FUEL PRESS - BACK	.0792		.796	.789		.779	
LUBE OIL LEVEL	1/2		1/2	1/2		1/2	
OIL ADDED TO ENGINE	0		126gal	0		15gal	
LUBE OIL ENG PRESS	57		58	58		59	
GEAR BOX OIL PRESSURE	8		9	8		9	
LUBE OIL FILTER	65		65	64		65	
CONVERTER TEMP TC-1	720	↓	749	714	↓	731	↓
CONVERTER TEMP TC-2	689	↓	715	679	↓	699	↓
CYLINDER #1	970	0	976	956	0	995	0
CYLINDER #2	962	0	969	966	0	963	0
CYLINDER #3	959	W	960	965	W	954	W
CYLINDER #4	1012	N	1015	965	N	1009	N
CYLINDER #5	1001	↑	993	985	↑	979	↑
CYLINDER #6	1014		1016	983		991	
AIR PRESSURE	204		205	215		220	
WATER MAKE-UP TANK	Full		Full	Full		Full	
GAS METER READING			210911	211383		211660	

**CRIMSON PIPELINE, L.P.
ENGINE SERVICE REPORT**

TYPE OF SERVICE REPAIR

DATE 1/5/16

APCD PERMIT NUMBER 0082

LOCATION Ventura Station

MAKE Caterpillar (G-1)

MODEL G-379

TYPE Natural Gas

ENGINE HOURS 07491

OPERATIONS PERFORMED

REPLACED OIL LINE TO WATER PUMP

REPLACED O₂ SENSORS

MECHANIC

J. Ows

DATE WORK COMPLETED

1/5/16

CRIMSON PIPELINE, L.P.
ENGINE SERVICE REPORT

TYPE OF SERVICE REPAIR

DATE 1/14/16

APCD PERMIT NUMBER 0082

LOCATION Ventura Station

MAKE Enterprise (G-3)

MODEL GSG-6

TYPE Natural Gas

ENGINE HOURS 16122

OPERATIONS PERFORMED

REPLACED NO. 2 HEAD AND HEAD GASKET
NEW SPARK PLUGS AND WIRES

MECHANIC 

DATE WORK COMPLETED 1/14/16

CRIMSON PIPELINE, L.P.
ENGINE SERVICE REPORT

TYPE OF SERVICE Repair

DATE 1/20/16

APCD PERMIT NUMBER 0082

LOCATION Ventura Station

MAKE Enterprise (G-3)

MODEL GSG-6


TYPE Natural Gas

ENGINE HOURS 16145

OPERATIONS PERFORMED

REPLACED WATER MANIFOLD AND O₂ SENSORS

MECHANIC



DATE WORK COMPLETED

1/20/16

**CRIMSON PIPELINE, L.P.
ENGINE SERVICE REPORT**

TYPE OF SERVICE Repair

DATE 6/3/16

APCD PERMIT NUMBER 0082

LOCATION Ventura Station

MAKE Enterprise (G-3)

MODEL GSG-6

TYPE Natural Gas


ENGINE HOURS 17707

OPERATIONS PERFORMED

- REPLACED O₂ SENSORS

- ENGINE RUNNING TO RICH -

MECHANIC



DATE WORK COMPLETED

6/3/16

CRIMSON PIPELINE, L.P.
ENGINE SERVICE REPORT

TYPE OF SERVICE REPAIR

DATE 8/10/16

APCD PERMIT NUMBER 0082

LOCATION Ventura Station

MAKE Enterprise (G-3)

MODEL GSG-6

TYPE Natural Gas


ENGINE HOURS 18362

OPERATIONS PERFORMED

42 CYLINDER HEAD CHANGE AND GASKETS

- NEW SPARK PLUGS & WIRES

MECHANIC



DATE WORK COMPLETED 8/10/16

CRIMSON PIPELINE, L.P.
ENGINE SERVICE REPORT

TYPE OF SERVICE REPAIR

DATE 10/13/16

APCD PERMIT NUMBER 0082

LOCATION Ventura Station

MAKE Enterprise (G-3)

MODEL GSG-6


TYPE Natural Gas

ENGINE HOURS 18968

OPERATIONS PERFORMED

WATER LEAK INSIDE #6 CYLINDER, REPLACED
O-RINGS AND CHANGED THE OIL

MECHANIC



DATE WORK COMPLETED

10/13/16

**CRIMSON PIPELINE, L.P.
ENGINE SERVICE REPORT**

TYPE OF SERVICE Service

DATE 12/6/16

APCD PERMIT NUMBER 0082

LOCATION Ventura Station

MAKE Enterprise (G-3)

MODEL GSG-6


TYPE Natural Gas

ENGINE HOURS 19445

OPERATIONS PERFORMED

REPLACED Air Cleaner, 2 SPARK PLUGS AND
O₂ SENSORS

MECHANIC



DATE WORK COMPLETED

12/6/16

CRIMSON PIPELINE LP

Engine 1440 Hr. Report

Operation Every 1440 Hrs.

Date 2/10/16

APCD PERMIT NUMBER 0082

LOCATION: HARBOE

MAKE ENTERPRISE

MODEL: 656-6

TYPE: NATURAL GAS

INSPECTION ENGINE HOURS 16392

NEXT INSPECTION HOURS DUE: 17832

INSPECTIONS PERFORMED

OIL ANALYSIS SAMPLE- OIL & FILTER CHANGE

Comment: WATER IN OIL

INSPECT SPARK PLUGS- REPLACED 2 SPARK PLUGS

Comment: WEEK SPARK

INSPECT ALL HOSES AND BELTS- GOOD

Comment: _____

MECHANIC John

DATE WORK COMPLETED 2/10/16

CRIMSON PIPELINE LP

Engine 1440 Hr. Report

Operation Every 1440 Hrs.

Date 6-15-16

APCD PERMIT NUMBER 0082

LOCATION: Venoma / Harbor

MAKE Enterprise

MODEL: 656-6

TYPE: NATURAL GAS

INSPECTION ENGINE HOURS 17914

NEXT INSPECTION HOURS DUE: 19354

INSPECTIONS PERFORMED

OIL ANALYSIS SAMPLE- OIL CHANGE

Comment: _____

INSPECT SPARK PLUGS- GOOD

Comment: _____

INSPECT ALL HOSES AND BELTS- GOOD

Comment: _____

MECHANIC [Signature]

DATE WORK COMPLETED 6/15/16

CRIMSON PIPELINE LLC IC ENGINES
FUEL USAGE
HARBOR STATION
PERMIT NUMBER 0082

VENTURA HARBOR STATION ROLLING FUEL 2016

Month	AVG#1	AVG#2	AVG#3	AVG#4	AVG#5	AVG#6	AVG#7	AVG#8	AVG#9	AVG#10	AVG#11	AVG#12
Feb-15	904,000											
Mar-15	982,700	982,700										
Apr-15	947,300	947,300	947,300									
May-15	849,200	849,200	849,200	849,200								
Jun-15	781,000	781,000	781,000	781,000	781,000							
Jul-15	711,100	711,100	711,100	711,100	711,100	711,100						
Aug-15	724,600	724,600	724,600	724,600	724,600	724,600	724,600					
Sep-15	763,100	763,100	763,100	763,100	763,100	763,100	763,100	763,100				
Oct-15	667,700	667,700	667,700	667,700	667,700	667,700	667,700	667,700	667,700			
Nov-15	582,800	582,800	582,800	582,800	582,800	582,800	582,800	582,800	582,800	582,800		
Dec-15	715,600	715,600	715,600	715,600	715,600	715,600	715,600	715,600	715,600	715,600	715,600	
Jan-16	856,700	856,700	856,700	856,700	856,700	856,700	856,700	856,700	856,700	856,700	856,700	856,700
Feb-16	813,400	813,400	813,400	813,400	813,400	813,400	813,400	813,400	813,400	813,400	813,400	813,400
Mar-16			837,100	837,100	837,100	837,100	837,100	837,100	837,100	837,100	837,100	837,100
Apr-16				712,100	712,100	712,100	712,100	712,100	712,100	712,100	712,100	712,100
May-16					759,800	759,800	759,800	759,800	759,800	759,800	759,800	759,800
Jun-16						701,600	701,600	701,600	701,600	701,600	701,600	701,600
Jul-16							653,900	653,900	653,900	653,900	653,900	653,900
Aug-16								603,200	603,200	603,200	603,200	603,200
Sep-16									576,100	576,100	576,100	576,100
Oct-16										528,100	528,100	528,100
Nov-16											684,300	684,300
Dec-16												880,300
CF/year	790,483	782,933	770,800	751,200	743,750	737,133	732,367	722,250	706,667	695,033	703,492	717,217

CRIMSON PIPELINE LLC

VENTURA HARBOR STATION 2016

<u>MONTH</u>	<u>*FUEL</u> (CUBIC FEET)	<u>BBLs.</u> (TANK THROUGHPUT)	<u>SOLVENT</u> (GALLONS)	<u>**PAINT</u> (GALLONS)
--------------	------------------------------	-----------------------------------	-----------------------------	-----------------------------

Jan-16	856,700	224,637	0	0
Feb-16	813,400	193,233	0	0
Mar-16	837,100	202,662	0	0
Apr-16	712,100	193,788	0	0
May-16	759,800	205,153	0	0
Jun-16	701,600	203,361	0	0
Jul-16	653,900	204,029	0	0
Aug-16	603,200	182,077	0	0
Sep-16	576,100	163,637	0	0
Oct-16	528,100	134,650	0	0
Nov-16	684,300	174,505	0	0
Dec-16	880,300	199,563	0	0
TOTAL				
	8,606,600	2,281,295	0	0

***ALSO REFER TO FUEL USE ROLLING TWELVE MONTH TABLE ATTACHED**

**PIPELINE L. P.
HARBOR STATION
WEEKLY
FUGITIVE EMISSION INSPECTION LOG**

INSPECTED BY	SP	SP	SP		SP	JO	TO
DATE 12-5/12-12/12	12-5	12-6	12-7		12-8	12/10	12/11
DAY	MON	TUES	WED	THUR	FRI	SAT	SUN

COMPONENT DESCRIPTION	LEAKING (Y/N)						
OPACITY G-1 - TIME	-	-	-		-	-	-
ANY VISUAL EMISSIONS	✓	-	-		-	-	-
OPACITY G-3 - TIME	-	-	-		-	0.800	-
ANY VISUAL EMISSIONS	-	-	-		-	N	-
G-1 PUMP SEAL	N	N	N		N	N	N
G-3 PUMP SEAL	N	N	N		N	N	N
STATION VALVES	N	N	N		N	N	N
TK 305 VALVES	N	N	N		N	N	N
SUMP	N	N	N		N	N	N
BOOSTER SEAL	N	N	N		N	N	N
MIXER SEAL	N	N	N		N	N	N
PIG LAUNCHER	N	N	N		N	N	N

STATION VISUAL SP SP SP SP JO JO

If any componet is leaking, minimize leak, notify Dist Foreman

Comments:
