



RECEIVED
VENTURA COUNTY
2019 FEB 15 AM 10:55
A.P.C.D.

February 8, 2019

Dan Searcy
Manager Compliance Division
Ventura County Air Pollution Control District
669 County Square Drive
Ventura, CA 93003

Via Certified Mail
Return Receipt Requested
Claim No. 7018 0680 0002 0160 5811

**Subject: 2019 Title V Annual Compliance Certification
Ventura Harbor Station, Facility ID 00082**

Dear Mr. Searcy:

Enclosed is the Title V Annual Compliance Certification for Crimson California Pipeline, L.P.'s Ventura Harbor Station Facility ID 00082. This report covers the compliance period of January 1, 2018 through December 31, 2018.

Should any questions arise, please do not hesitate to contact Crimson Environmental at (562) 285-4040.

Respectfully,

A handwritten signature in blue ink, appearing to read 'Valerie Muller'.

Valerie Muller
Environmental Specialist

CC: Mr. Gerardo Rios, Chief, EPA Region 9

Enclosures: Title V Annual Compliance Certification 1/1/2018 – 12/31/2018



Ventura County
Air Pollution
Control District

**ANNUAL COMPLIANCE CERTIFICATION
SIGNATURE COVER FORM**

A copy of each Annual Compliance Certification shall be submitted to EPA, Region 9, at the following address:

Mr. Gerardo Rios, Chief
Permits Office (AIR-3)
Office of Air Division
EPA Region 9
75 Hawthorne Street
San Francisco, CA 94105

Confidentiality

All information in a Part 70 permit compliance certification is public information. The Part 70 permit is also public information.

Certification by Responsible Official

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in this compliance certification are true, accurate, and complete.

Signature and Title of Responsible Official:  Title: President	Date: 2/14/2019
---	------------------------

Time Period Covered by Compliance Certification <u> 1 </u> / <u> 31 </u> / <u> 18 </u> (MM/DD/YY) to <u> 12 </u> / <u> 31 </u> / <u> 18 </u> (MM/DD/YY)
--

Permit Attachment Form



ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 18 (MM/DD/YY) to 12 / 31 / 18 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Att. No. 71.2N2, Rules 71.2.B.4, 71.2.C.1</p>	<p>D. Frequency of monitoring: Annually</p>
<p>B. Description: External floating roof crude oil storage tank ≥ 40,000 gallons Rules 71.2B4, 71.2C.1, 71.2D, 71.2E</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable Rule 71.2 Inspection</p>
<p>C. Method of monitoring: Primary and secondary seals were inspected on 6/13/2018.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>I</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>Y</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Att. No. 71.4N1, Rules 71.4.B.2, 71.4.C.2</p>	<p>D. Frequency of monitoring: Quarterly</p>
<p>B. Description: Sumps, pits, and ponds with covers. Fugitive emissions monitoring and integrity of cover</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable EPA Method 21</p>
<p>C. Method of monitoring: Quarterly fugitive emissions (Rule 74.10) inspections were conducted 2/21/2018; 6/21/2018; 9/19/2018; and 11/27/2018. The integrity of the cover was verified. No leaks greater than 10,000 ppm were discovered.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Att. No. 74.9N3, Rules 74.9.B.1 and B.2</p>	<p>D. Frequency of monitoring: Quarterly</p>
<p>B. Description: Stationary natural gas fired - rich-burn internal combustion engine quarterly inspections and biennial source test.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable CARB Method 100</p>
<p>C. Method of monitoring: Quarterly Emissions testing conducted on 2/22/2018 (G3 only); 6/20/2018; 9/26/2018 (G3 only); 10/31/2018 (G1 only) and 12/20/2018. G-1 was exempt for Q1 of 2018 as per Rule 74.9B(5). The Biennial Source Test was last conducted on 1/13/2017.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>I</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>Y</u> *If yes, attach Deviation Summary Form</p>



ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 18 (MM/DD/YY) to 12 / 31 / 18 (MM/DD/YY)

<p>A. Attachment # or Permit Condition # Att. No. 40CFR63ZZZN5</p>	<p>D. Frequency of monitoring: Every 1,440 hours or annually, whichever comes first</p>
<p>B. Description: RICE MACT for non-emergency 4SRB =< 500 HP oil and filter change maintenance.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Maintenance records, hours of operation.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> <small>*If yes, attach Deviation Summary Form</small></p>

<p>A. Attachment # or Permit Condition # Att. No. PO0082PC1 - Cond. No. 1, Rule 26</p>	<p>D. Frequency of monitoring: Monthly</p>
<p>B. Description: Throughput and consumption limits.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Facility throughput and fuel consumption for engines and/or tanks recorded monthly.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> <small>*If yes, attach Deviation Summary Form</small></p>

<p>A. Attachment # or Permit Condition # Att. No. PO0082PC1 - Cond. No. 2, Rule 26</p>	<p>D. Frequency of monitoring: Intermittent</p>
<p>B. Description: Combustion equipment shall burn only natural gas.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Combustion equipment only burns natural gas.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> <small>*If yes, attach Deviation Summary Form</small></p>



ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 18 (MM/DD/YY) to 12 / 31 / 18 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Att. No. PO0082PC1 - Cond. No. 3, Rule 29</p>	<p>D. Frequency of monitoring: Monthly</p>
<p>B. Description: Solvent usage and exemptions.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Safety data sheets and additional information of any solvents used during this compliance period obtained and reviewed. Usage of required solvents logged monthly.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Att. No. PO0082PC2, Rules 26 and 74.9</p>	<p>D. Frequency of monitoring: Quarterly</p>
<p>B. Description: BACT for Caterpillar Engine G-1 - emissions limits (ROC, NOx, CO). Monitor Air:Fuel ratio controller readings quarterly.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable CARB Method 100</p>
<p>C. Method of monitoring: Biennial source test last conducted on 1/13/2017. Air:Fuel ratio controllers monitored on Engine Data Sheets.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Att. No. 50, Rule 50</p>	<p>D. Frequency of monitoring: Intermittent</p>
<p>B. Description: Opacity observation at the facility.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable EPA Method 9</p>
<p>C. Method of monitoring: Opacity conducted by AirX Testing Services, Inc. on 1/13/2017. Opacity surveillance and visual inspections of emissions conducted and recorded on fugitive emission log.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 18 (MM/DD/YY) to 12 / 31 / 18 (MM/DD/YY)

<p>A. Attachment # or Permit Condition # Att. No. 54.B.1, Rule 54.B.1</p>	<p>D. Frequency of monitoring: Intermittent</p>
<p>B. Description: Sulfur emissions from combustion operations at point of discharge; follow monitoring requirements under Rule 64.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Facility follows monitoring requirements under Rule 64. Only PUC grade natural gas combusted at this facility. No additional periodic monitoring required.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition # Att. No. 54.B.2, Rule 54.B.2</p>	<p>D. Frequency of monitoring: Intermittent</p>
<p>B. Description: Emission of sulfur compounds.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Only PUC grade natural gas combusted at this facility.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition # Att. No. 55, Rule 55</p>	<p>D. Frequency of monitoring: Intermittent</p>
<p>B. Description: Fugitive Dust.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: No dust generating activities were conducted at this facility during this compliance period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 18 (MM/DD/YY) to 12 / 31 / 18 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Att. No. 57.1, Rule 57.1</p>	<p>D. Frequency of monitoring: Intermittent</p>
<p>B. Description: Particulate matter emissions from fuel burning equipment.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: This facility does not have any fuel burning equipment such as boilers, steam generators, process heaters, water heaters, flares, and gas turbines. Internal combustion engines do not apply.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Att. No. 64.B.1, Rule 64.B.1</p>	<p>D. Frequency of monitoring: Intermittent</p>
<p>B. Description: Sulfur content of fuels - gaseous fuel requirements.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Only PUC grade natural gas combusted at this facility. No periodic monitoring required.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Att. No. 74.6, Rule 74.6</p>	<p>D. Frequency of monitoring: Intermittent</p>
<p>B. Description: Solvent cleaning activities.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: No reportable solvents used at this facility during this compliance period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 18 (MM/DD/YY) to 12 / 31 / 18 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Att. No. 74.10, Rule 74.10</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Fugitive leak and leak inspections.</p>	<p>Quarterly</p>
<p>C. Method of monitoring: Quarterly component leak detection inspections conducted on 2/21/2018; 6/21/2018; 9/19/2018; and 11/27/2018. Routine surveillance at this unmanned facility recorded on fugitive emission log.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable EPA Method 21</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p>
	<p>G. Compliance Status? (C or I): <u>C</u></p>
	<p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Att. No. 74.11.1, Rule 74.11.1</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Large water heaters and small boilers.</p>	<p>Intermittent</p>
<p>C. Method of monitoring: This facility is not equipped with large water heaters or small boilers.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p>
	<p>G. Compliance Status? (C or I): <u>C</u></p>
	<p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Att. No. 74.22, Rule 74.22</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Requirements for natural gas-fired fan-type central furnaces,</p>	<p>Intermittent</p>
<p>C. Method of monitoring: This facility is not equipped with fan-type central furnaces.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p>
	<p>G. Compliance Status? (C or I): <u>C</u></p>
	<p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>



ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 18 (MM/DD/YY) to 12 / 31 / 18 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Att. No. 74.1, Rule 74.1</p>	<p>D. Frequency of monitoring: Intermittent</p>
<p>B. Description: Abrasive blasting.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: No abrasive blasting activities were conducted at this facility during this compliance period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Att. No. 74.2, Rule 74.2</p>	<p>D. Frequency of monitoring: Intermittent</p>
<p>B. Description: Architectural coatings.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: No architectural coatings were applied at this facility during this compliance period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Att. No. 74.26, Rule 74.26</p>	<p>D. Frequency of monitoring: Intermittent</p>
<p>B. Description: Crude oil storage tank degassing operations.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: No crude oil storage tank degassing activities were conducted at this facility during this compliance period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 18 (MM/DD/YY) to 12 / 31 / 18 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Att. No. 74.29N3, Rule 74.29</p>	<p>D. Frequency of monitoring: Intermittent</p>
<p>B. Description: Soil decontamination operation.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: No soil decontamination activities were conducted at this facility during this compliance period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Att. No. 40CFR.61.M, Rule 40 CFR Part 61, Subpart M</p>	<p>D. Frequency of monitoring: Intermittent</p>
<p>B. Description: National emission standards for asbestos.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: No asbestos removal, renovation, or demolition activities were conducted at this facility during this compliance period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #:</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description:</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p>
<p>C. Method of monitoring:</p>	<p>F. Currently in Compliance? (Y or N): _____ G. Compliance Status? (C or I): _____ H. *Excursions, exceedances, or other non-compliance? (Y or N): _____ *If yes, attach Deviation Summary Form</p>

Source Test Summary Form



ANNUAL COMPLIANCE CERTIFICATION SOURCE TEST SUMMARY FORM

Period Covered by Compliance Certification: 01 / 01 / 18 (MM/DD/YY) to 12 / 31 / 18 (MM/DD/YY)

A. Emission Unit Description: 415 HP Caterpillar NG Rich Burn Engine G-1			B. Pollutant: NOx
C. Measured Emission Rate: Exempt per Rule 74.9B(5)	D. Limited Emission Rate: 9 ppmv @ 15% O2	E. Specific Source Test or Monitoring Record Citation: N/A	F. Test Date: N/A

A. Emission Unit Description: 415 HP Caterpillar NG Rich Burn Engine G-1			B. Pollutant: CO
C. Measured Emission Rate: Exempt per Rule 74.9B(5)	D. Limited Emission Rate: 1,000 ppmv @ 15% O2	E. Specific Source Test or Monitoring Record Citation: N/A	F. Test Date: N/A

A. Emission Unit Description: 465 HP Enterprise GSG-6 NG Rich Burn Engine G-3			B. Pollutant: NOx
C. Measured Emission Rate: 18.3 ppmv @ 15% O2	D. Limited Emission Rate: 25 ppmv @ 15% O2	E. Specific Source Test or Monitoring Record Citation: AirX Testing Services, Inc.	F. Test Date: 2/22/2018

A. Emission Unit Description: 465 HP Enterprise GSG-6 NG Rich Burn Engine G-3			B. Pollutant: CO
C. Measured Emission Rate: 3,954 ppmv @ 15% O2	D. Limited Emission Rate: 4,500 ppmv @ 15% O2	E. Specific Source Test or Monitoring Record Citation: AirX Testing Services, Inc.	F. Test Date: 2/22/2018

A. Emission Unit Description:			B. Pollutant:
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test or Monitoring Record Citation:	F. Test Date:



ANNUAL COMPLIANCE CERTIFICATION SOURCE TEST SUMMARY FORM

Period Covered by Compliance Certification: 01 / 01 / 18 (MM/DD/YY) to 12 / 31 / 18 (MM/DD/YY)

A. Emission Unit Description: 415 HP Caterpillar NG Rich Burn Engine G-1			B. Pollutant: NOx
C. Measured Emission Rate: 3.5 ppmv @ 15% O2	D. Limited Emission Rate: 9 ppmv @ 15% O2	E. Specific Source Test or Monitoring Record Citation: AirX Testing Services, Inc.	F. Test Date: 6/20/2018

A. Emission Unit Description: 415 HP Caterpillar NG Rich Burn Engine G-1			B. Pollutant: CO
C. Measured Emission Rate: 759 ppmv @ 15% O2	D. Limited Emission Rate: 1,000 ppmv @ 15% O2	E. Specific Source Test or Monitoring Record Citation: AirX Testing Services, Inc.	F. Test Date: 6/20/2018

A. Emission Unit Description: 465 HP Enterprise GSG-6 NG Rich Burn Engine G-3			B. Pollutant: NOx
C. Measured Emission Rate: 11.9 ppmv @ 15% O2	D. Limited Emission Rate: 25 ppmv @ 15% O2	E. Specific Source Test or Monitoring Record Citation: AirX Testing Services, Inc.	F. Test Date: 6/20/2018

A. Emission Unit Description: 465 HP Enterprise GSG-6 NG Rich Burn Engine G-3			B. Pollutant: CO
C. Measured Emission Rate: 104 ppmv @ 15% O2	D. Limited Emission Rate: 4,500 ppmv @ 15% O2	E. Specific Source Test or Monitoring Record Citation: AirX Testing Services, Inc.	F. Test Date: 6/20/2018

A. Emission Unit Description:			B. Pollutant:
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test or Monitoring Record Citation:	F. Test Date:



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION SOURCE TEST SUMMARY FORM

Period Covered by Compliance Certification: 01 / 01 / 18 (MM/DD/YY) to 12 / 31 / 18 (MM/DD/YY)

A. Emission Unit Description: 415 HP Caterpillar NG Rich Burn Engine G-1			B. Pollutant: NOx
C. Measured Emission Rate: 4.8 ppmv @ 15% O2	D. Limited Emission Rate: 9 ppmv @ 15% O2	E. Specific Source Test or Monitoring Record Citation: AirX Testing Services, Inc.	F. Test Date: 9/26/2018

A. Emission Unit Description: 415 HP Caterpillar NG Rich Burn Engine G-1			B. Pollutant: CO
C. Measured Emission Rate: 246 ppmv @ 15% O2	D. Limited Emission Rate: 1,000 ppmv @ 15% O2	E. Specific Source Test or Monitoring Record Citation: AirX Testing Services, Inc.	F. Test Date: 9/26/2018

A. Emission Unit Description: 465 HP Enterprise GSG-6 NG Rich Burn Engine G-3			B. Pollutant: NOx
C. Measured Emission Rate: 23.0 ppmv @ 15% O2	D. Limited Emission Rate: 25 ppmv @ 15% O2	E. Specific Source Test or Monitoring Record Citation: AirX Testing Services, Inc.	F. Test Date: 10/31/2018

A. Emission Unit Description: 465 HP Enterprise GSG-6 NG Rich Burn Engine G-3			B. Pollutant: CO
C. Measured Emission Rate: 277 ppmv @ 15% O2	D. Limited Emission Rate: 4,500 ppmv @ 15% O2	E. Specific Source Test or Monitoring Record Citation: AirX Testing Services, Inc.	F. Test Date: 10/31/2018

A. Emission Unit Description:			B. Pollutant:
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test or Monitoring Record Citation:	F. Test Date:



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION SOURCE TEST SUMMARY FORM

Period Covered by Compliance Certification: 01 / 01 / 18 (MM/DD/YY) to 12 / 31 / 18 (MM/DD/YY)

A. Emission Unit Description: 415 HP Caterpillar NG Rich Burn Engine G-1			B. Pollutant: NOx
C. Measured Emission Rate: 3.2 ppmv @ 15% O2	D. Limited Emission Rate: 9 ppmv @ 15% O2	E. Specific Source Test or Monitoring Record Citation: AirX Testing Services, Inc.	F. Test Date: 12/20/2018

A. Emission Unit Description: 415 HP Caterpillar NG Rich Burn Engine G-1			B. Pollutant: CO
C. Measured Emission Rate: 221 ppmv @ 15% O2	D. Limited Emission Rate: 1,000 ppmv @ 15% O2	E. Specific Source Test or Monitoring Record Citation: AirX Testing Services, Inc.	F. Test Date: 12/20/2018

A. Emission Unit Description: 465 HP Enterprise GSG-6 NG Rich Burn Engine G-3			B. Pollutant: NOx
C. Measured Emission Rate: 5.6 ppmv @ 15% O2	D. Limited Emission Rate: 25 ppmv @ 15% O2	E. Specific Source Test or Monitoring Record Citation: AirX Testing Services, Inc.	F. Test Date: 12/20/2018

A. Emission Unit Description: 465 HP Enterprise GSG-6 NG Rich Burn Engine G-3			B. Pollutant: CO
C. Measured Emission Rate: 2,109 ppmv @ 15% O2	D. Limited Emission Rate: 4,500 ppmv @ 15% O2	E. Specific Source Test or Monitoring Record Citation: AirX Testing Services, Inc.	F. Test Date: 12/20/2018

A. Emission Unit Description:			B. Pollutant:
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test or Monitoring Record Citation:	F. Test Date:

Attachment 71.2N3

Annual Tank Seal Inspection Report

VENTURA COUNTY AIR POLLUTION CONTROL DISTRICT
RULE 71.2 INSPECTION REPORT

PLEASE COMPLETE FORM LEGIBLY IN BLACK INK

Created by Beacon Energy Services, Inc.

Tank No. 150305 Permit No. 00082 Inspection Date 6/8/2018 Time 7:10am
Is this a Follow-up Inspection? Yes No If yes, Date of Previous Inspection: _____

A. COMPANY INFORMATION:

Company Name Crimson Pipeline L.P.
Location Address 1200 Spinaker Road City Ventura Zip 93003
Mailing Address 210 North 12th Street City Santa Paula Zip 93060
Contact Person Greg Fussel Title Supervisor
Phone 805-223-6850

B. INSPECTION CONDUCTED BY:

Name Isaac Hernandez Title Inspector
Company Name Beacon Energy Services, Inc. Phone 562-997-3087
Mailing Address 2685 Temple ave City Signal Hill Zip 90755

C. TANK INFORMATION:

Capacity 150,000 Installation Date _____ Diameter 150' Ht. 51'
Product Type Crude Product RVP _____
Type of Tank Riveted Welded Other (Describe) _____
Color of Shell White Color of Roof White
Roof Type Pontoon Double Deck Other (Describe) _____
 External floating roof Internal floating roof

D. GROUND LEVEL INSPECTION:

1) Product Temperature 67 Product Level 10' - 4"
3) List type and location of leaks found in tank shell. _____
No leaks found in shell

E. INTERNAL FLOATING ROOF TANK:

NA 1) Check vapor space between floating roof and fixed roof with explosimeter. _____ % LEL
2) Conduct visual inspection of roofs and secondary seals, if applicable.
3) Are all roof openings covered? No Yes
If no, explain in comments section (J) and proceed to part (H)(6)

F. EXTERNAL FLOATING ROOF TANK:

1) On the diagram (attached) indicate the location of the ladder, roof drain(s), anti-rotation device(s), platform, gauge well, vents or other appurtenances. Note information relative to North (to the top of the worksheet)
2) Identify any tears in the seal fabric. Describe and indicate on diagram (attached)
The entire Secondary and Primary Apron is delaminated and is found with holes.
3) If this is an In-Service External Floating seal inspection, record the LEL% reading within 3 feet of the seal LEL 0%

**VENTURA COUNTY AIR POLLUTION CONTROL DISTRICT
RULE 71.2 INSPECTION REPORT**

Tank No. 150305 Permit No. 00082

I. CALCULATIONS - Complete all applicable portions of the following:

Gaps in <u>Primary Seal</u> between 1/8" and 1/2"	<u>0</u>	(feet)	<u>0</u>	(Inches)
Gaps in <u>Primary Seal</u> between 1/2" and 1-1/2"	<u>0</u>	(feet)	<u>0</u>	(Inches)
Gaps in <u>Primary Seal</u> greater than 1-1/2"	<u>0</u>	(feet)	<u>0</u>	(Inches)
Gaps in <u>Secondary Seal</u> between 1/8" and 1/2"	<u>0</u>	(feet)	<u>0</u>	(Inches)
Gaps in <u>Secondary Seal</u> > 1/2"	<u>0</u>	(feet)	<u>0</u>	(Inches)

Multiply diameter (ft) of tank to determine appropriate gap limits:

5% Circumference = Diameter X 0.157 =	<u>23.55</u>	60% Circ. = Diameter X 1.88 =	<u>282</u>
10% Circumference = Diameter X 0.314 =	<u>47.1</u>	90% Circ. = Diameter X 2.83 =	<u>424.5</u>
30% Circumference = Diameter X 0.942 =	<u>141.3</u>	95% Circ = Diameter X 2.98 =	<u>447</u>

J. DETERMINE COMPLIANCE STATUS OF TANK:

1) Were any openings found on the roof?	No	Yes	X	
2) Were any tears in the seals found?	No	Yes	X	
3) Is the product level lower than the level at which the roof would be floating?	No	X	Yes	
4) Secondary Seal:				
Did 1/2" probe drop between the shell and seal?	No	X	Yes	
Did cumulative 1/8" - 1/2" gap exceed 5% of the tank circumference length?	No	X	Yes	
5) Primary Seal:				
Shoe Did 1-1/2" probe drop between the shell and seal?	No	X	Yes	
Did cumulative 1/2" - 1-1/2" gap exceed 10% circumference length?	No	X	Yes	
Did cumulative 1/8" - 1/2" gap exceed 40% circumference length?	No	X	Yes	
Did any <u>single continuous</u> 1/8" - 1-1/2" gap exceed 10% circumference length?	No	X	Yes	
Tube Did 1/2" probe drop between the shell and seal?	No	Yes	NA	X
Did cumulative 1/8" - 1/2" gap exceed 95% circumference length?	No	Yes	NA	X
<i>If "yes" is checked for any of the above items the tank is Out of Compliance</i>				
<hr/>				
7) Does tank have permit conditions?	No	Yes	X	
Does tank comply with these conditions?	No	X	Yes	

1 IF INSPECTION WAS TERMINATED PRIOR TO COMPLETION FOR ANY REASON, PLEASE EXPLAIN

VENTURA COUNTY AIR POLLUTION CONTROL DISTRICT
RULE 71.2 INSPECTION REPORT



Tank No. 150305 Permit No. 00082

K. COMMENTS:

Use this section to complete answers to above listed items and to describe repairs made to the tank; include date and time repairs were made.

- 6/8/2018 Beacon found 100% of the Primary Apron delaminated and with tears and holes
 - 6/8/2018 Beacon found 100% of the Secondary Apron delaminated and with tears and holes
 - 6/8/2018 Beacon found holes in the floating roof on top of the pontoons at the foam dam.
 - 6/8/2018 Beacon found the Secondary Wiper Tip to be cracking and splitting
 - 6/8/2018 Beacon found 1 Leg Sock with worn holes
-
-
-
-
-
-
-
-


L. I (We) certify the foregoing information to be correct to the best of my (Our) knowledge.

Inspection completed by	Isaac Hernandez <u>ISAAC HERNANDEZ</u>	IH001	Date	6/8/2018
signature				
Compliance status by	Robert Hopperath <u>ROBERT HOPPERATH</u>	Cert ID	RH003	Date 6/8/2018
signature				
Company Representative		Cert ID		Date
signature				

A copy of this Inspection Report must be provided to the Ventura County APCD within 30 Calendar days after the inspection date. A copy of this report must be kept on-site and made available to Ventura County APCD upon request for a period of 4 Years.

BEACON ESI - TANK INSPECTION DIAGRAM

Facility	Crimson Pipeline - Ventura Harbor	Inspector	I. Hernandez
Tank Number	150305	Date	6/8/2018



EQUIPMENT		DEFECTS	
□	Anti-Rotation Device	∞	Torn Seal
	Ladder	[-P-]	Primary Seal Gap
O	Gauge Well	[-S-]	Secondary Seal Gap
T	Leg Stand		
X	Roof Drain		
•	Emergency Roof Drain		
∞	Vaccum Breaker		
△	Vent		

**VENTURA COUNTY AIR POLLUTION CONTROL DISTRICT
RULE 71.2 INSPECTION REPORT**

****PLEASE COMPLETE FORM LEGIBLY IN BLACK INK****

Created by Beacon Energy Services, Inc.

Tank No. 150305 Permit No. 00082 Inspection Date 6/13/2018 Time 4:00pm
 Is this a Follow-up Inspection? Yes No If yes, Date of Previous Inspection: 6/8/2018

A. COMPANY INFORMATION:

Company Name Crimson Pipeline L.P.
 Location Address 1200 Spinkar Road City Ventura Zip 93003
 Mailing Address 210 North 12th Street City Santa Paula Zip 93060
 Contact Person Tim Eggleston Title Supervisor
 Phone 805-525-6312

B. INSPECTION CONDUCTED BY:

Name Jose Macias Title Inspector
 Company Name Beacon Energy Services, Inc. Phone 562-997-3087
 Mailing Address 2685 Temple ave City Signal Hill Zip 90755

C. TANK INFORMATION:

Capacity 150,000 Installation Date _____ Diameter 150' Ht. 51'
 Product Type Crude Product RVP _____
 Type of Tank Riveted Welded Other (Describe) _____
 Color of Shell White Color of Roof White
 Roof Type Pontoon Double Deck Other (Describe) _____
 External floating roof Internal floating roof

D. GROUND LEVEL INSPECTION:

1) Product Temperature 72 Product Level 10' - 4"
 3) List type and location of leaks found in tank shell. _____
 No leaks found in shell _____

E. INTERNAL FLOATING ROOF TANK:

NA 1) Check vapor space between floating roof and fixed roof with explosimeter. _____ % LEL
 2) Conduct visual inspection of roofs and secondary seals, if applicable.
 3) Are all roof openings covered? No Yes
 If no, explain in comments section (J) and proceed to part (H)(6)

F. EXTERNAL FLOATING ROOF TANK:

1) On the diagram (attached) indicate the location of the ladder, roof drain(s), anti-rotation device(s), platform, gauge well, vents or other appurtenances. Note information relative to North (to the top of the worksheet)
 2) Identify any tears in the seal fabric. Describe and indicate on diagram (attached)
None
 3) If this is an In-Service External Floating seal inspection, record the LEL% reading within 3 feet of the seal LEL 0%

**VENTURA COUNTY AIR POLLUTION CONTROL DISTRICT
RULE 71.2 INSPECTION REPORT**

Tank No. 150305 Permit No. 00082

I. CALCULATIONS - Complete all applicable portions of the following:

Gaps in <u>Primary Seal</u> between 1/8" and 1/2"	<u>0</u>	(feet)	<u>0</u>	(Inches)
Gaps in <u>Primary Seal</u> between 1/2" and 1-1/2"	<u>0</u>	(feet)	<u>0</u>	(Inches)
Gaps in <u>Primary Seal</u> greater than 1-1/2"	<u>0</u>	(feet)	<u>0</u>	(Inches)
Gaps in <u>Secondary Seal</u> between 1/8" and 1/2"	<u>0</u>	(feet)	<u>0</u>	(Inches)
Gaps in <u>Secondary Seal</u> > 1/2"	<u>0</u>	(feet)	<u>0</u>	(Inches)

Multiply diameter (ft) of tank to determine appropriate gap limits:

5% Circumference = Diameter X 0.157 =	<u>23.55</u>	60% Circ. = Diameter X 1.88 =	<u>282</u>
10% Circumference = Diameter X 0.314 =	<u>47.1</u>	90% Circ. = Diameter X 2.83 =	<u>424.5</u>
30% Circumference = Diameter X 0.942 =	<u>141.3</u>	95% Circ = Diameter X 2.98 =	<u>447</u>

J. DETERMINE COMPLIANCE STATUS OF TANK:

1) Were any openings found on the roof?	No	<input checked="" type="checkbox"/>	Yes		
2) Were any tears in the seals found?	No	<input checked="" type="checkbox"/>	Yes		
3) Is the product level lower than the level at which the roof would be floating?	No	<input checked="" type="checkbox"/>	Yes		
4) <u>Secondary Seal:</u>					
Did 1/2" probe drop between the shell and seal?	No	<input checked="" type="checkbox"/>	Yes		
Did cumulative 1/8" - 1/2" gap exceed 5% of the tank circumference length?	No	<input checked="" type="checkbox"/>	Yes		
5) <u>Primary Seal:</u>					
Shoe Did 1-1/2" probe drop between the shell and seal?	No	<input checked="" type="checkbox"/>	Yes		
Did cumulative 1/2" - 1-1/2" gap exceed 10% circumference length?	No	<input checked="" type="checkbox"/>	Yes		
Did cumulative 1/8" - 1/2" gap exceed 40% circumference length?	No	<input checked="" type="checkbox"/>	Yes		
Did any <u>single continuous</u> 1/8" - 1-1/2" gap exceed 10% circumference length?	No	<input checked="" type="checkbox"/>	Yes		
Tube Did 1/2" probe drop between the shell and seal?	No		Yes	NA	<input checked="" type="checkbox"/>
Did cumulative 1/8" - 1/2" gap exceed 95% circumference length?	No		Yes	NA	<input checked="" type="checkbox"/>
<i>If "yes" is checked for any of the above items the tank is Out of Compliance</i>					
<hr/>					
7) Does tank have permit conditions?	No		Yes	<input checked="" type="checkbox"/>	
Does tank comply with these conditions?	No		Yes	<input checked="" type="checkbox"/>	

1 IF INSPECTION WAS TERMINATED PRIOR TO COMPLETION FOR ANY REASON, PLEASE EXPLAIN

**VENTURA COUNTY AIR POLLUTION CONTROL DISTRICT
RULE 71.2 INSPECTION REPORT**

Tank No. 150305 Permit No. 00082

K. COMMENTS:

Use this section to complete answers to above listed items and to describe repairs made to the tank; include date and time repairs were made.

6/8/2018 12:00 - 6:00pm Beacon begins removal of the Secondary Seal (50% complete No product exposure)

6/9/2018 7:00am - 6:00pm Beacon completes Secondary Seal removal, begins to remove Primary Seal Channels and install new Carriage Bolts (75% complete No product exposure)

6/10/2018 7:00am - 6:00pm Beacon completes removal of Primary Seal Channels and installation of new Carriage Bolts. Begin installation of New Primary Apron over the existing apron (50% complete No product exposure) Patched holes on on roof at the pontoons with bolt down flat bar.

6/11/2018 7:00am - 6:00pm Beacon completes installation of Primary Seal Apron and Channels (No product exposure)

6/12/2018 7:00am - 6:00pm Beacon begins installation of new Secondary Seal (50% complete No product exposure)

6/13/2018 7:00am - 4:00pm Beacon completes installation of New Secondary Seal (No product exposure)

TANK IS IN COMPLIANCE AT THIS TIME

L. I (We) certify the foregoing information to be correct to the best of my (Our) knowledge.

Inspection completed by	Jose Macias <u>JOSE MACIAS</u>	Cert ID	JM005	Date	6/13/2018
<i>signature</i>					
Compliance status by	Robert Hoppemath <u>[Signature]</u>	Cert ID	RH003	Date	6/13/2018
<i>signature</i>					
Company Representative		Cert ID		Date	
<i>signature</i>					

A copy of this Inspection Report must be provided to the Ventura County APCD within 30 Calendar days after the inspection date. A copy of this report must be kept on-site and made available to Ventura County APCD upon request for a period of 4 Years.

Attachment 71.4N1

Rule 74.10 Quarterly Component Leak Report

Company Crimson Pipeline, LLC
 Facility Ventura Harbor Pump Station
 1200 Spinnaker Dr., Ventura, CA 93003

District ID 00082
 Contact EH&S Department
 (562) 285-4113

Component Group	Accessible	Inaccessible	Leaks	Percentage
Stuffing Box	0	0	0	0
Threaded Component	2	0	0	0
Valve	1	0	0	0
Flange	0	0	0	0
Compressor	0	0	0	0
Pump	0	0	0	0
Atmospheric PRD	0	0	0	0
Other	0	0	0	0

No Reportable Leaks for this Quarter
 Inspected on 02/21/2018



Ventura County APCD
Rule 74.10 Component Leak Report

Q2/2018

Company Crimson Pipeline, LLC
Facility Ventura Harbor Pump Station
1200 Spinnaker Dr., Ventura, CA 93003

District ID 00082
Contact EH&S Department
(562) 285-4113

Component Group	Accessible	Inaccessible	Leaks	Percentage
Stuffing Box	0	0	0	0
Threaded Component	2	0	0	0
Valve	1	0	0	0
Flange	0	0	0	0
Compressor	0	0	0	0
Pump	0	0	0	0
Atmospheric PRD	0	0	0	0
Other	0	0	0	0

No Reportable Leaks for this Quarter
Inspected on 06/21/2018



Ventura County APCD
Rule 74.10 Component Leak Report

Q3/2018

Company Crimson Pipeline, LLC
Facility Ventura Harbor Pump Station
1200 Spinnaker Dr., Ventura, CA 93003

District ID 00082
Contact EH&S Department

Component Group	Accessible	Inaccessible	Leaks	Percentage
Stuffing Box	0	0	0	0
Threaded Component	2	0	0	0
Valve	1	0	0	0
Flange	0	0	0	0
Compressor	0	0	0	0
Pump	0	0	0	0
Atmospheric PRD	0	0	0	0
Other	0	0	0	0

No Reportable Leaks for this Quarter
Inspected on 09/19/2018



Ventura County APCD
Rule 74.10 Component Leak Report

Q4/2018

Company Crimson Pipeline, LLC
Facility Ventura Harbor Pump Station
1200 Spinnaker Dr., Ventura, CA 93003

District ID 00082
Contact EH&S Department

Component Group	Accessible	Inaccessible	Leaks	Percentage
Stuffing Box	0	0	0	0
Threaded Component	2	0	0	0
Valve	1	0	0	0
Flange	0	0	0	0
Compressor	0	0	0	0
Pump	0	0	0	0
Atmospheric PRD	0	0	0	0
Other	0	0	0	0

No Reportable Leaks for this Quarter
Inspected on 11/27/2018

Attachment 74.9N3

**Quarterly Emissions Screenings / Biennial Source
Test**

SUMMARY OF SOURCE TEST RESULTS
Quarterly Emission Testing
Crimson Pipeline
Ventura Harbor Pump Station
G-3

2/22/2018

		<i>Allowable</i>
Oxides of Nitrogen (NOx)		
ppmv	64.4	-
ppmv @ 15% O2	18.3	25
Carbon Monoxide (CO)		
ppmv	13925	-
ppmv @ 15% O2	3954	4500
Oxygen (O2), percent	0.1	-

Note: Reported values represent a 15 minute average.

CRIMSON CALIFORNIA



April 4, 2018

Ventura County Air Pollution Control District
669 County Square Drive
Ventura, CA 93003

VIA USPS PRIORITY MAIL
9114901496451814941528

**SUBJECT: 2018 FIRST QUARTER EMISSION TESTING EXEMPTION
415 HP CATERPILLAR NG RICH BURN ENGINE
VENTURA HARBOR STATION #00082**

To Whom It May Concern:

The following equipment was exempt from Rule 74.9B.5 quarterly emission testing requirements for the first quarter of 2018:

- 415 HP Caterpillar NG Rich Burn Engine, Ventura Harbor Station #00082

Per Rule 74.9B.5(b): "*the engine operated less than 32 hours in each of the three months of the applicable quarter, as measured by a non-resettable elapsed operating hour meter*".

The operating hours of the Caterpillar engine during the [quarter] quarter of [year] are as followed:

MONTH	HOURS
January	0
February	0
March	28
TOTAL	28

The remaining equipment was tested on February 22, 2018:

- Enterprise; Model GSG-8; 465 BHP; S/N 54050; Equipped with catalytic converter.

The above mentioned quarterly emission testing report was submitted by Crimson's contractor, AirX Testing Services, Inc. Should you have any questions, feel free to contact Crimson Environmental at (562) 285-4040 or environmental@crimsonpl.com.

Respectfully,

Laura Vik
EH&S Specialist



SUMMARY OF SOURCE TEST RESULTS
Quarterly Emission Testing
Crimson Pipeline
Ventura Harbor Pump Station
G-3

6/20/2018

		<i>Allowable</i>
Oxides of Nitrogen (NOx)		
ppmv	41.8	-
ppmv @ 15% O2	11.9	25
Carbon Monoxide (CO)		
ppmv	366	-
ppmv @ 15% O2	104	4500
Oxygen (O2), percent	0.2	-

Note: Reported values represent a 15 minute average.



SUMMARY OF SOURCE TEST RESULTS
Quarterly Emission Testing
Crimson Pipeline
Ventura Pump Station
CAT

6/20/2018

		<i>Allowable</i>
Oxides of Nitrogen (NOx)		
ppmv	12.5	-
ppmv @ 15% O2	3.5	9
Carbon Monoxide (CO)		
ppmv	2682	-
ppmv @ 15% O2	759	1000
Oxygen (O2), percent	0.0	-

Note: Reported values represent a 15 minute average.



SUMMARY OF SOURCE TEST RESULTS
Quarterly Emission Testing
Crimson Pipeline
Ventura Harbor Pump Station
Enterprise

10/31/2018

		<i>Allowable</i>
Oxides of Nitrogen (NOx)		
ppmv	79.6	-
ppmv @ 15% O2	23.0	25
Carbon Monoxide (CO)		
ppmv	956	-
ppmv @ 15% O2	277	4500
Oxygen (O2), percent	0.5	-

Note: Reported values represent a 6 minute average.

SUMMARY OF SOURCE TEST RESULTS
Quarterly Emission Testing
Crimson Pipeline
Ventura Harbor Pump Station
Caterpillar

9/26/2018

		<i>Allowable</i>
Oxides of Nitrogen (NOx)		
ppmv	17.1	-
ppmv @ 15% O2	4.8	25
Carbon Monoxide (CO)		
ppmv	871	-
ppmv @ 15% O2	246	4500
Oxygen (O2), percent	0.0	-

Note: Reported values represent a 15 minute average.

SUMMARY OF SOURCE TEST RESULTS
Quarterly Emission Testing
Crimson Pipeline
Harbor Pump Station
G-3

12/20/2018

			<i>Allowable</i>
Oxides of Nitrogen (NOx)			
	ppmv	<i>19.9</i>	-
	ppmv @ 15% O2	<i>5.6</i>	<i>25</i>
Carbon Monoxide (CO)			
	ppmv	<i>7459</i>	-
	ppmv @ 15% O2	<i>2109</i>	<i>4500</i>
Oxygen (O2),	percent	<i>0.0</i>	-
Opacity, %		<i>0.0</i>	<i>10%</i>

Note: Reported values represent a 15 minute average.

SUMMARY OF SOURCE TEST RESULTS
Quarterly Emission Testing
Crimson Pipeline
Ventura Pump Station
CAT

12/20/2018

			<i>Allowable</i>
Oxides of Nitrogen (NOx)			
	ppmv	<i>11.4</i>	-
	ppmv @ 15% O2	<i>3.2</i>	<i>9</i>
Carbon Monoxide (CO)			
	ppmv	<i>783</i>	-
	ppmv @ 15% O2	<i>221</i>	<i>1000</i>
Oxygen (O2),	percent	<i>0.0</i>	-
Opacity, %		<i>0.0</i>	<i>10%</i>

Note: Reported values represent a 15 minute average.

40 CFR 63ZZZN7

Maintenance Records and Hours of Operations



ENGINE SERVICE REPORT

LOCATION: Torrey #00385

Ventura Harbor #00082

A. ENGINE INFORMATION

ENGINE: G-1 Enterprise GSG-6

TYPE: Natural Gas

G-2 Enterprise GSG-6

ENGINE HOURS: 25469

G-3 Enterprise GSG-6

TYPE OF SERVICE: REPAIR


G-1 Caterpillar G-379

B. MAINTENANCE/SERVICE PERFORMED

- CHANGED HEAD & HEAD GASKETS ON NUMBER 1, 2, 5 CYLINDERS AND EXHAUST MANIFOLD ON THE FRONT OF THE ENGINE.

- REPLACED CONVERTOR PLATE

INSPECTED BY:



DATE:

10/31/18



ENGINE SERVICE REPORT

LOCATION: Torrey #00385

Ventura Harbor #00082

A. ENGINE INFORMATION

ENGINE: G-1 Enterprise GSG-6

TYPE: Natural Gas

G-2 Enterprise GSG-6

ENGINE HOURS: 24443

G-3 Enterprise GSG-6

TYPE OF SERVICE: REPLACE

G-1 Caterpillar G-379

B. MAINTENANCE/SERVICE PERFORMED

New O₂ Sensors and Air Filters

INSPECTED BY:

Joe [Signature]

DATE:

5/18/18



ENGINE DATA SHEET

LOCATION: V. Harbor #00082

ENGINE: Caterpillar G-1

Enterprise G-3

A. ENGINE TIMER							
START DATE:	<u>1.1.18</u>			FINISH DATE:	<u>1.7.18</u>		
ENGINE HOUR:	<u>23260</u>			ENGINE HOUR:	<u>23348</u>		
Within 200 hrs or 1 week of next required oil & filter change? <input type="checkbox"/> Yes <input type="checkbox"/> No							
If yes, notify Maintenance Lead							
B. INSPECTION	MON	TUES	WED	THUR	FRI	SAT	SUN
DISCHARGE PRESSURE (psi)				578	592	573	
SUCTION PRESSURE (psi)		0		124	121	115	
ENGINE RPM'S		0		386	372	370	
JACKET WATER PRESURE (psi)				27	27	27	
JACKET WATER TEMP (°F)		0		183	177	171	
HEAT EXCHANGER TEMP (°F)		0		149	142	136	
INBOARD BEARING TEMP (°F)				129	124	122	
OUTBOARD BEARING TEMP (°F)		W		156	151	152	
FRONT AIR/FUEL PRESSURE (psi)		W		.182	.221	.184	
REAR AIR/FUEL PRESSURE (psi)				.758	.751	.752	
LUBE OIL LEVEL				3/8	3/8	3/8	
OIL ADDED TO ENGINE (gal)		W		10 gal	12	—	
LUBE OIL ENG PRESS (psi)				61	60	60	
GEAR BOX OIL PRESSURE (psi)				7	8	8	
LUBE OIL FILTER				65	65	64	0
CONVERTER TEMP TC-1 (°F)				725	722	745	
CONVERTER TEMP TC-2 (°F)				740	727	759	0
CYLINDER #1 (°F)				1033	1021	1022	
CYLINDER #2 (°F)				1035	1034	1061	W
CYLINDER #3 (°F)				990	977	973	
CYLINDER #4 (°F)				1019	989	989	H
CYLINDER #5 (°F)				1035	1018	1021	
CYLINDER #6 (°F)				1057	1035	1049	
AIR PRESSURE (psi)				220	220	210	
WATER MAKE-UP TANK LEVEL			F	Full	full	Full	
GAS METER READING				—	—	—	
INITIAL:		SP		SP	SS	SS	SS
DATE:		1.2.18		1.4.18	1.5	1.6	1.7

218W



ENGINE DATA SHEET

LOCATION: V. Harbor #00082

ENGINE: Caterpillar G-1

Enterprise G-3

A. ENGINE TIMER

START DATE: 2-4-18 FINISH DATE: 2-11-18

ENGINE HOUR: 23581 ENGINE HOUR: 23640

Within 200 hrs or 1 week of next required oil & filter change? Yes No

****If yes, notify Maintenance Lead****

B. INSPECTION	MON	TUES	WED	THUR	FRI	SAT	SUN
DISCHARGE PRESSURE (psi)		451		436			
SUCTION PRESSURE (psi)		111		100			
ENGINE RPM'S		370		349			
JACKET WATER PRESURE (psi)		27		25			
JACKET WATER TEMP (°F)		170		168			
HEAT EXCHANGER TEMP (°F)		132		130			
INBOARD BEARING TEMP (°F)		117		115			
OUTBOARD BEARING TEMP (°F)		145		140			
FRONT AIR/FUEL PRESSURE (psi)		.165		.122			
REAR AIR/FUEL PRESSURE (psi)		.160		.762			
LUBE OIL LEVEL		1/2		3/8			
OIL ADDED TO ENGINE (gal)		-		20 gal			
LUBE OIL ENG PRESS (psi)		60		60			
GEAR BOX OIL PRESSURE (psi)		10		8			
LUBE OIL FILTER		65		65			
CONVERTER TEMP TC-1 (°F)	D	755	D	715	D	D	D
CONVERTER TEMP TC-2 (°F)	D	718	D	713	D	D	D
CYLINDER #1 (°F)	W	1010	W	1001	W	W	W
CYLINDER #2 (°F)	N	1004	N	1002	N	N	N
CYLINDER #3 (°F)		968		955			
CYLINDER #4 (°F)		1004		988			
CYLINDER #5 (°F)		1011		984			
CYLINDER #6 (°F)		1035		1012			
AIR PRESSURE (psi)		200		210			
WATER MAKE-UP TANK LEVEL		Full		Full			
GAS METER READING		-		-			

INITIAL: SA JO SS JP SP SP SP

DATE: 2-5-18 2/6 27 28 29 2-10 2-11



ENGINE DATA SHEET

LOCATION: V. Harbor #00082

ENGINE: Caterpillar G-1

Enterprise G-3

A. ENGINE TIMER

START DATE: 3-5-18 FINISH DATE: 3-11-18

ENGINE HOUR: 23820 ENGINE HOUR: 23894

Within 200 hrs or 1 week of next required oil & filter change? Yes No

****If yes, notify Maintenance Lead****

B. INSPECTION	MON	TUES	WED	THUR	FRI	SAT	SUN
DISCHARGE PRESSURE (psi)		468				445	
SUCTION PRESSURE (psi)		110				111	
ENGINE RPM'S		358				345	
JACKET WATER PRESURE (psi)		25				26	
JACKET WATER TEMP (°F)		168				169	
HEAT EXCHANGER TEMP (°F)		138				135	
INBOARD BEARING TEMP (°F)		120				116	
OUTBOARD BEARING TEMP (°F)		149				144	
FRONT AIR/FUEL PRESSURE (psi)		.049				.030	
REAR AIR/FUEL PRESSURE (psi)		.768				.776	
LUBE OIL LEVEL	D	78	A	A	A	3/8	A
OIL ADDED TO ENGINE (gal)	D	10991				0	0
LUBE OIL ENG PRESS (psi)	0	61	0	0	0	61	0
GEAR BOX OIL PRESSURE (psi)		8		W	W	8	W
LUBE OIL FILTER	W	65	W	W	W	65	
CONVERTER TEMP TC-1 (°F)		727		N	N	757	W
CONVERTER TEMP TC-2 (°F)	N	722	N	N	N	717	
CYLINDER #1 (°F)	N	947	N			920	
CYLINDER #2 (°F)		968				998	
CYLINDER #3 (°F)		954				973	
CYLINDER #4 (°F)		1011				1010	
CYLINDER #5 (°F)		1016				1020	
CYLINDER #6 (°F)		1032				1026	
AIR PRESSURE (psi)		210				210	
WATER MAKE-UP TANK LEVEL		Full				Full	
GAS METER READING		-				-	

INITIAL: ST JP SP SP SP SP SP SH

DATE: 3-5-18 3-6 3-7 3-8 3-9 3-10 3-11



ENGINE DATA SHEET

LOCATION: V. Harbor #00082

ENGINE: Caterpillar G-1

Enterprise G-3

A. ENGINE TIMER

START DATE: 4-2-18

FINISH DATE: 4-8-18

ENGINE HOUR: 7581

ENGINE HOUR: 7608

Within 200 hrs or 1 week of next required oil & filter change? Yes No

If yes, notify Maintenance Lead

B. INSPECTION	MON	TUES	WED	THUR	FRI	SAT	SUN
DISCHARGE PRESSURE (psi)		397			384		
SUCTION PRESSURE (psi)		110	0	0	116	0	0
ENGINE RPM'S		1013	0	0	891	0	0
JACKET WATER PRESURE (psi)		160	0	0	75	0	0
JACKET WATER TEMP (°F)		190			190		
HEAT EXCHANGER TEMP (°F)		145	W		150	W	W
INBOARD BEARING TEMP (°F)				W			
OUTBOARD BEARING TEMP (°F)			W	W		W	W
FRONT AIR/FUEL PRESSURE (psi)				W	483		
REAR AIR/FUEL PRESSURE (psi)					438		
LUBE OIL LEVEL		42			42		
OIL ADDED TO ENGINE (gal)		0			0		
LUBE OIL ENG PRESS (psi)		80			60		
GEAR BOX OIL PRESSURE (psi)					40		
LUBE OIL FILTER							
CONVERTER TEMP TC-1 (°F)		818			705		
CONVERTER TEMP TC-2 (°F)		765			697		
CYLINDER #1 (°F)							
CYLINDER #2 (°F)							
CYLINDER #3 (°F)							
CYLINDER #4 (°F)							
CYLINDER #5 (°F)							
CYLINDER #6 (°F)							
AIR PRESSURE (psi)		190			210		
WATER MAKE-UP TANK LEVEL		Full			Full		
GAS METER READING		-			-		
INITIAL:		SP	SP	SP	SP	SP	SP
DATE:		4-3	4-4	4-5	4-6	4-7	4-8



ENGINE DATA SHEET

LOCATION: V. Harbor #00082

ENGINE: Caterpillar G-1

Enterprise G-3

A. ENGINE TIMER							
START DATE:	<u>5.7.18</u>			FINISH DATE:	<u>5/13/18</u>		
ENGINE HOUR:	<u>24316</u>			ENGINE HOUR:	<u>24384</u>		
Within 200 hrs or 1 week of next required oil & filter change? <input type="checkbox"/> Yes <input type="checkbox"/> No							
If yes, notify Maintenance Lead							
B. INSPECTION	MON	TUES	WED	THUR	FRI	SAT	SUN
DISCHARGE PRESSURE (psi)			453	461			
SUCTION PRESSURE (psi)			104	104			
ENGINE RPM'S			358	359			
JACKET WATER PRESURE (psi)			25	26			
JACKET WATER TEMP (°F)			169	172			
HEAT EXCHANGER TEMP (°F)			135	140			
INBOARD BEARING TEMP (°F)			115	120			
OUTBOARD BEARING TEMP (°F)			129	143			
FRONT AIR/FUEL PRESSURE (psi)			+180	+036			
REAR AIR/FUEL PRESSURE (psi)			+214	+213			
LUBE OIL LEVEL	0	0	3/8	3/8			
OIL ADDED TO ENGINE (gal)	0	0	0	0			
LUBE OIL ENG PRESS (psi)			60	60			
GEAR BOX OIL PRESSURE (psi)			10	8			
LUBE OIL FILTER	W	W	65	65			
CONVERTER TEMP TC-1 (°F)			905	925			
CONVERTER TEMP TC-2 (°F)	N	N	742	751	D	D	D
CYLINDER #1 (°F)			1030	1025	0	0	0
CYLINDER #2 (°F)			1005	1024	W	W	W
CYLINDER #3 (°F)			970	961	W	W	W
CYLINDER #4 (°F)			976	988			
CYLINDER #5 (°F)			978	980			
CYLINDER #6 (°F)			776	780			
AIR PRESSURE (psi)			220	220			
WATER MAKE-UP TANK LEVEL			Full	Full			
GAS METER READING			-	-			
INITIAL:	JP	JP	JP	JP	JO	JO	JP
DATE:	5.7	5.8	5.9	5.10	5/11	5/12	5/13



ENGINE DATA SHEET

LOCATION: V. Harbor #00082

ENGINE: Caterpillar G-1

Enterprise G-3

A. ENGINE TIMER

START DATE: 6/4/18 FINISH DATE: 6/10/18

ENGINE HOUR: 24559 ENGINE HOUR: 24573

Within 200 hrs or 1 week of next required oil & filter change? Yes No

****If yes, notify Maintenance Lead****

B. INSPECTION	MON	TUES	WED	THUR	FRI	SAT	SUN
DISCHARGE PRESSURE (psi)							
SUCTION PRESSURE (psi)							
ENGINE RPM'S							
JACKET WATER PRESURE (psi)							
JACKET WATER TEMP (°F)							
HEAT EXCHANGER TEMP (°F)							
INBOARD BEARING TEMP (°F)							
OUTBOARD BEARING TEMP (°F)							
FRONT AIR/FUEL PRESSURE (psi)							
REAR AIR/FUEL PRESSURE (psi)							
LUBE OIL LEVEL							
OIL ADDED TO ENGINE (gal)							
LUBE OIL ENG PRESS (psi)							
GEAR BOX OIL PRESSURE (psi)							
LUBE OIL FILTER							
CONVERTER TEMP TC-1 (°F)	D	D	D	D	D	D	D
CONVERTER TEMP TC-2 (°F)	0	0	0	0	0	0	0
CYLINDER #1 (°F)	W	W	W	W	W	W	W
CYLINDER #2 (°F)	N	N	N	N	N	N	N
CYLINDER #3 (°F)							
CYLINDER #4 (°F)							
CYLINDER #5 (°F)							
CYLINDER #6 (°F)							
AIR PRESSURE (psi)							
WATER MAKE-UP TANK LEVEL							
GAS METER READING							

INITIAL: JD CH JP CH JP CS CS

DATE: 6/4 6/5 6/6 6/7 6/8 6-9 6-10



ENGINE DATA SHEET

LOCATION: V. Harbor #00082

ENGINE: Caterpillar G-1

Enterprise G-3

A. ENGINE TIMER							
START DATE: <u>7/2/18</u>				FINISH DATE: <u>7/18/18</u>			
ENGINE HOUR: <u>24874</u>				ENGINE HOUR: <u>24822</u>			
Within 200 hrs or 1 week of next required oil & filter change? <input type="checkbox"/> Yes <input type="checkbox"/> No							
If yes, notify Maintenance Lead							
B. INSPECTION	MON	TUES	WED	THUR	FRI	SAT	SUN
DISCHARGE PRESSURE (psi)							
SUCTION PRESSURE (psi)							
ENGINE RPM'S							
JACKET WATER PRESURE (psi)	D	D					
JACKET WATER TEMP (°F)	D	D					
HEAT EXCHANGER TEMP (°F)							
INBOARD BEARING TEMP (°F)	O	O					
OUTBOARD BEARING TEMP (°F)							
FRONT AIR/FUEL PRESSURE (psi)	W	W					
REAR AIR/FUEL PRESSURE (psi)							
LUBE OIL LEVEL							
OIL ADDED TO ENGINE (gal)	N	N					
LUBE OIL ENG PRESS (psi)							
GEAR BOX OIL PRESSURE (psi)				D	D	D	D
LUBE OIL FILTER				O	O	O	O
CONVERTER TEMP TC-1 (°F)				W	W	W	W
CONVERTER TEMP TC-2 (°F)				N	N	N	N
CYLINDER #1 (°F)							
CYLINDER #2 (°F)							
CYLINDER #3 (°F)							
CYLINDER #4 (°F)							
CYLINDER #5 (°F)							
CYLINDER #6 (°F)							
AIR PRESSURE (psi)							
WATER MAKE-UP TANK LEVEL							
GAS METER READING							
INITIAL:	SP	CH		JO	JA	SP	SP
DATE:	7-2	7-3		7/5	7/6	7/7	7/8



ENGINE DATA SHEET

LOCATION: V. Harbor #00082

ENGINE: Caterpillar G-1
 Enterprise G-3

A. ENGINE TIMER

START DATE: 8/6/18

FINISH DATE: 8/12/18

ENGINE HOUR: 25104

ENGINE HOUR: 25159

Within 200 hrs or 1 week of next required oil & filter change? Yes No

If yes, notify Maintenance Lead

B. INSPECTION	MON	TUES	WED	THUR	FRI	SAT	SUN
DISCHARGE PRESSURE (psi)				428.8	431.3		
SUCTION PRESSURE (psi)				108.9	107.6		
ENGINE RPM'S				339	342		
JACKET WATER PRESURE (psi)				24	24		
JACKET WATER TEMP (°F)				176.1	174.3		
HEAT EXCHANGER TEMP (°F)				142	140		
INBOARD BEARING TEMP (°F)				122.8	123.6		
OUTBOARD BEARING TEMP (°F)				148.2	148		
FRONT AIR/FUEL PRESSURE (psi)				.504	.504		
REAR AIR/FUEL PRESSURE (psi)				.503	.503		
LUBE OIL LEVEL				3/8	3/8		
OIL ADDED TO ENGINE (gal)				0	0		
LUBE OIL ENG PRESS (psi)	D	D	D	59	59		
GEAR BOX OIL PRESSURE (psi)	0	0	0	8	8	0	0
LUBE OIL FILTER	w	w	w	63	63	0	0
CONVERTER TEMP TC-1 (°F)	n	n	N	862	866	u	a
CONVERTER TEMP TC-2 (°F)				694	685	u	u
CYLINDER #1 (°F)				992	984		
CYLINDER #2 (°F)				974	984		
CYLINDER #3 (°F)				963	960		
CYLINDER #4 (°F)				980	960		
CYLINDER #5 (°F)				968	962		
CYLINDER #6 (°F)				964	946		
AIR PRESSURE (psi)				215	215		
WATER MAKE-UP TANK LEVEL	Full			Full	Full		
GAS METER READING		5		x	x		

INITIAL: CH SP CH CH CH DM DM
 DATE: 8/6/18 8/7/18 8/8/18 8-11-18 8-12-18



ENGINE DATA SHEET

LOCATION: V. Harbor #00082

ENGINE: Caterpillar G-1

Enterprise G-3

A. ENGINE TIMER							
START DATE: <u>9/4/18</u>				FINISH DATE: <u>9/9/18</u>			
ENGINE HOUR: <u>25340</u>				ENGINE HOUR: <u>25404</u>			
Within 200 hrs or 1 week of next required oil & filter change? <input type="checkbox"/> Yes <input type="checkbox"/> No							
If yes, notify Maintenance Lead							
B. INSPECTION	MON	TUES	WED	THUR	FRI	SAT	SUN
DISCHARGE PRESSURE (psi)			352	307	335	395	318 350
SUCTION PRESSURE (psi)		0	111		112	111	112
ENGINE RPM'S		0	201	0	287	320	318
JACKET WATER PRESURE (psi)		100	25		25	20	20
JACKET WATER TEMP (°F)		100	106	100	117	160	155
HEAT EXCHANGER TEMP (°F)			115	100	100	140	138
INBOARD BEARING TEMP (°F)			86		89	120	119
OUTBOARD BEARING TEMP (°F)			85		86	143	144
FRONT AIR/FUEL PRESSURE (psi)			.401		.504	.503	.504
REAR AIR/FUEL PRESSURE (psi)			.401		.504	.503	.503
LUBE OIL LEVEL			3/4		1/2	1/2	1/2
OIL ADDED TO ENGINE (gal)			2.2 gal		0	—	—
LUBE OIL ENG PRESS (psi)			60		60	58	60
GEAR BOX OIL PRESSURE (psi)			20		15	7	9
LUBE OIL FILTER			65		65	63	65
CONVERTER TEMP TC-1 (°F)			327		160	759	757
CONVERTER TEMP TC-2 (°F)			565		437	620	619
CYLINDER #1 (°F)			870		910	905	910
CYLINDER #2 (°F)			875		915	828	912
CYLINDER #3 (°F)			875		875	946	943
CYLINDER #4 (°F)			867		889	947	945
CYLINDER #5 (°F)			870		890	954	950
CYLINDER #6 (°F)			910		905	953	956
AIR PRESSURE (psi)			215		215	205	205
WATER MAKE-UP TANK LEVEL			Full		Full	Full	Full
GAS METER READING			—		—	—	—
INITIAL:		SP	SP	SP	SP	CS	CS
DATE:		9/4	9/5	9/6	9/7	9/8	9/9



ENGINE DATA SHEET

LOCATION: V. Harbor #00082

ENGINE: Caterpillar G-1

Enterprise G-3

A. ENGINE TIMER

START DATE: 10/1/18

FINISH DATE: _____

ENGINE HOUR: 07727

ENGINE HOUR: _____

Within 200 hrs or 1 week of next required oil & filter change? Yes No

If yes, notify Maintenance Lead

B. INSPECTION	MON	TUES	WED	THUR	FRI	SAT	SUN
DISCHARGE PRESSURE (psi)		359					
SUCTION PRESSURE (psi)		160					
ENGINE RPM'S							
JACKET WATER PRESURE (psi)		15					
JACKET WATER TEMP (°F)		80					
HEAT EXCHANGER TEMP (°F)		125					
INBOARD BEARING TEMP (°F)							
OUTBOARD BEARING TEMP (°F)							
FRONT AIR/FUEL PRESSURE (psi)	0	.505	0	0	0	0	0
REAR AIR/FUEL PRESSURE (psi)	0	.503	0	0	0	0	0
LUBE OIL LEVEL	0	Full	0	0	0	W	W
OIL ADDED TO ENGINE (gal)	0	1.5	W	W	W	W	W
LUBE OIL ENG PRESS (psi)	W	80	W	W	W		W
GEAR BOX OIL PRESSURE (psi)			W	W	W		
LUBE OIL FILTER	N						
CONVERTER TEMP TC-1 (°F)		459					
CONVERTER TEMP TC-2 (°F)		570					
CYLINDER #1 (°F)							
CYLINDER #2 (°F)							
CYLINDER #3 (°F)							
CYLINDER #4 (°F)							
CYLINDER #5 (°F)							
CYLINDER #6 (°F)							
AIR PRESSURE (psi)		210					
WATER MAKE-UP TANK LEVEL		Full					
GAS METER READING		-					
INITIAL:	SP	SP	SP	CH	CH	JD	JD
DATE:	10/1	10/2	10/3	10/4	10/5	10/6	10/7



ENGINE DATA SHEET

LOCATION: V. Harbor #00082

ENGINE: Caterpillar G-1

Enterprise G-3

A. ENGINE TIMER

START DATE: 11/4/2018 FINISH DATE: 11/11/18

ENGINE HOUR: 7229 25576 ENGINE HOUR: 25544

Within 200 hrs or 1 week of next required oil & filter change? Yes No

****If yes, notify Maintenance Lead****

B. INSPECTION	MON	TUES	WED	THUR	FRI	SAT	SUN
DISCHARGE PRESSURE (psi)				406			
SUCTION PRESSURE (psi)				109			
ENGINE RPM'S				324			
JACKET WATER PRESURE (psi)				25			
JACKET WATER TEMP (°F)				175			
HEAT EXCHANGER TEMP (°F)				135			
INBOARD BEARING TEMP (°F)				115			
OUTBOARD BEARING TEMP (°F)				140			
FRONT AIR/FUEL PRESSURE (psi)				844			
REAR AIR/FUEL PRESSURE (psi)				186			
LUBE OIL LEVEL				1/2			
OIL ADDED TO ENGINE (gal)				20gal			
LUBE OIL ENG PRESS (psi)				60			
GEAR BOX OIL PRESSURE (psi)	D	N	N	7	D	D	D
LUBE OIL FILTER	O	O	O	65	O	O	O
CONVERTER TEMP TC-1 (°F)	W	W	W	778	W	W	W
CONVERTER TEMP TC-2 (°F)	N	N	N	642	N	N	N
CYLINDER #1 (°F)				897			
CYLINDER #2 (°F)				885			
CYLINDER #3 (°F)				859			
CYLINDER #4 (°F)				956			
CYLINDER #5 (°F)				956			
CYLINDER #6 (°F)				944			
AIR PRESSURE (psi)				210			
WATER MAKE-UP TANK LEVEL	Full			Full			
GAS METER READING				-			

INITIAL: CH SP SP SP CH CH CH

DATE: 11/5/18 11/6/18 11/7 11/8 11/9/18 11/10/18 11/11/18



ENGINE DATA SHEET

LOCATION: V. Harbor #00082

ENGINE: Caterpillar G-1

Enterprise G-3

A. ENGINE TIMER

START DATE: 12/3/2018

FINISH DATE: 12/9/18

ENGINE HOUR: 25734

ENGINE HOUR: 25738

Within 200 hrs or 1 week of next required oil & filter change? Yes No

****If yes, notify Maintenance Lead****

B. INSPECTION	MON	TUES	WED	THUR	FRI	SAT	SUN
DISCHARGE PRESSURE (psi)			417.1				
SUCTION PRESSURE (psi)			106.5				
ENGINE RPM'S			336				
JACKET WATER PRESURE (psi)			23				
JACKET WATER TEMP (°F)			173.4				
HEAT EXCHANGER TEMP (°F)			115				
INBOARD BEARING TEMP (°F)			116.3				
OUTBOARD BEARING TEMP (°F)			142.7				
FRONT AIR/FUEL PRESSURE (psi)			.8524				
REAR AIR/FUEL PRESSURE (psi)			.1784				
LUBE OIL LEVEL			1/2				
OIL ADDED TO ENGINE (gal)	D	D	26				
LUBE OIL ENG PRESS (psi)	0	0	60				
GEAR BOX OIL PRESSURE (psi)	W	W	10		D	D	D
LUBE OIL FILTER	N	N	65		0	0	0
CONVERTER TEMP TC-1 (°F)		120	820		W	W	W
CONVERTER TEMP TC-2 (°F)		1099	1099		N	N	N
CYLINDER #1 (°F)			911				
CYLINDER #2 (°F)			912				
CYLINDER #3 (°F)			933				
CYLINDER #4 (°F)			961				
CYLINDER #5 (°F)			962				
CYLINDER #6 (°F)			964				
AIR PRESSURE (psi)			215				
WATER MAKE-UP TANK LEVEL			Full				
GAS METER READING			-				

INITIAL: CH CH CH CH CS CS
 DATE: 12/3/18 12/4/18 12/5/18 12/7/18 12/8 12/9



ENGINE HOUR REPORT

40 CFR 63 SUBPART ZZZZ

LOCATION: Torrey #00385

Inspection Interval: 2,160 hrs / annually

Ventura Harbor #00082

Inspection Interval: 1,440 hrs / annually

A. ENGINE INFORMATION	
ENGINE: <input type="checkbox"/> G-1 Enterprise G-SG6	DATE: <u>1/29/18</u>
<input type="checkbox"/> G-2 Enterprise G-SG6	ENGINE HOURS: <u>7549</u>
<input type="checkbox"/> G-3 Enterprise G-SG6	NEXT INSPECTION HOURS: <u>8989</u>
<input checked="" type="checkbox"/> G-1 Caterpillar G-379	OR ANNUALLY ON: <u>1/29/19</u>
TYPE: Natural Gas	(whichever comes first)
B. INSPECTION	
1. ENGINE OIL	
Oil Analysis Sample: <input type="checkbox"/> Good <input checked="" type="checkbox"/> Changed	
Filter: <input type="checkbox"/> Good <input type="checkbox"/> Changed	
Comments: _____	

2. SPARK PLUGS <input checked="" type="checkbox"/> Good <input type="checkbox"/> Replaced	
Comments: _____	

3. HOSES AND BELTS <input checked="" type="checkbox"/> Good <input type="checkbox"/> Replaced	
Comments: _____	

INSPECTED BY: 

DATE: 1/29/18



ENGINE HOUR REPORT

40 CFR 63 SUBPART ZZZZ

LOCATION: Torrey #00385

Inspection Interval: 2,160 hrs / annually

Ventura Harbor #00082

Inspection Interval: 1,440 hrs / annually

A. ENGINE INFORMATION	
ENGINE: <input type="checkbox"/> G-1 Enterprise G-SG6	DATE: <u>5/18/18</u>
<input type="checkbox"/> G-2 Enterprise G-SG6	ENGINE HOURS: <u>2443</u>
<input checked="" type="checkbox"/> G-3 Enterprise G-SG6	NEXT INSPECTION HOURS: <u>25883</u>
<input type="checkbox"/> G-1 Caterpillar G-379	OR ANNUALLY ON: <u>5/18/19</u>
TYPE: Natural Gas	(whichever comes first)
B. INSPECTION	
1. ENGINE OIL	
Oil Analysis Sample: <input type="checkbox"/> Good <input checked="" type="checkbox"/> Changed	
Filter: <input checked="" type="checkbox"/> Good <input type="checkbox"/> Changed	
Comments:	
2. SPARK PLUGS <input type="checkbox"/> Good <input checked="" type="checkbox"/> Replaced	
Comments: <u>REPLACED 3 PLUGS</u>	
3. HOSES AND BELTS <input checked="" type="checkbox"/> Good <input type="checkbox"/> Replaced	
Comments:	

INSPECTED BY:

[Signature]

DATE:

5/18/18



ENGINE HOUR REPORT

40 CFR 63 SUBPART ZZZZ

LOCATION: Torrey #00385

Inspection Interval: 2,160 hrs / annually

Ventura Harbor #00082

Inspection Interval: 1,440 hrs / annually

Directions: Engine Hour Report must be completed within one year from the last inspection OR at the next required engine hour, **whichever comes first**. This includes, but is not limited to, oil & filter change and the inspection of spark plugs, hoses, and belts.

A. ENGINE INFORMATION

TYPE: Natural Gas

DATE: 10/31/18

ENGINE: G-1 Enterprise G-SG6

ENGINE HOUR: 25469

G-2 Enterprise G-SG6

NEXT REQUIRED INSPECTION

G-3 Enterprise G-SG6

NEXT ANNUAL INSPECTION: 10/31/19

G-1 Caterpillar G-379

NEXT ENGINE HR INSPECTION: 26909

B. INSPECTION

1. ENGINE OIL

a) Oil: May either be changed or sampled at the time of required inspection.

Changed Sampled - Date Report Received: _____

Oil Change Required: Yes No

Date oil changed: _____

IF SAMPLED:

Pull sample and submit to laboratory.

When analysis report received: record date received and attach analysis report to form

If oil change is required per the analysis report:

- Oil must be changed within 2 days from when analysis report was received.

- If engine is NOT in operation when analysis report was received, oil must be changed within 2 days from when the report was received OR prior to operating the engine, whichever is later.

b) Filter: Good Changed

Comments: WATER IN LUBE OIL

2. SPARK PLUGS Good Replaced

Comments: _____

3. HOSES AND BELTS Good Replaced

Comments: _____

INSPECTED BY:

[Signature]

DATE:

10/31/18

Attachment P00386PC1

Monthly Throughput and Facility Fuel Consumption



HARBOR STATION FUEL USE & SEALS IN OPERATION 2018

MONTH	FUEL (CUBIC FEET) G1	YEAR %	FUEL (CUBIC FEET) G2	YEAR %	FUEL USE TOTAL (CUBIC FEET)	BBL'S. TANK THROUGHPUT	HOURS G1	YEAR %	HOURS G3	YEAR %	HOURS TOTAL	SOLVENT (GALLONS)	**PAINT (GALLONS)	HOURS TOTAL	SEALS IN OP YEAR %	BBL'S. TANK THROUGHPUT	1000 GAL THROUGHPUT YEAR %	1000 GAL THROUGHPUT YEAR
JAN	0	0.00%	680,100	12.79%	680,100	162,995	0	0.00%	302	9.97%	302	0	0	302	9.97%	162,995	7.99%	6,845.8
FEB	0	0.00%	484,800	9.12%	484,800	143,128	0	0.00%	223	7.36%	223	0	0	223	7.36%	143,128	6.98%	6,011.4
MAR	62,190	7.80%	521,110	9.80%	583,300	182,693	29	0.96%	243	8.03%	272	0	0	272	8.98%	182,693	8.91%	7,673.1
APR	115,625	14.50%	460,275	8.65%	575,900	188,492	52	1.72%	207	6.84%	259	0	0	259	8.55%	188,492	9.19%	7,916.7
MAY	0	0.00%	693,300	13.04%	693,300	221,803	0	0.00%	305	10.07%	305	0	0	305	10.07%	221,803	10.82%	9,315.7
JUN	2,173	0.27%	532,327	10.01%	534,500	177,426	1	0.03%	245	8.09%	246	0	0	246	8.12%	177,426	8.95%	7,451.9
JUL	0	0.00%	477,400	8.98%	477,400	168,064	0	0.00%	267	8.92%	267	0	0	267	8.82%	168,064	8.20%	7,058.7
AUG	0	0.00%	530,800	9.98%	530,800	189,650	0	0.00%	288	9.61%	288	0	0	288	9.51%	189,650	9.25%	7,965.3
SEP	196,838	24.66%	200,262	3.77%	397,100	162,522	115	3.80%	117	3.86%	232	0	0	232	7.66%	162,522	7.93%	6,825.9
OCT	304,722	38.20%	53,578	1.01%	358,300	165,750	182	6.01%	32	1.06%	214	0	0	214	7.07%	165,750	8.06%	6,961.5
NOV	0	0.00%	414,300	7.79%	414,300	157,240	0	0.00%	237	7.63%	237	0	0	237	7.83%	157,240	7.67%	6,604.1
DEC	116,101	14.56%	270,199	5.08%	386,300	130,814	55	1.82%	128	4.23%	183	0	0	183	6.04%	130,814	6.38%	5,494.2
TOTAL	797,649	100.00%	5,318,451	100.00%	6,116,100	2,050,577	434	14.33%	2594	86.67%	3028	0	0	3028	100.00%	2,050,577	100.00%	86,124.2

*ALSO REFER TO FUEL USE ROLLING TWELVE MONTH TABLE ATTACHED

Attachment Number 50

**Opacity Observation/Fugitive Emission Inspection
Logs**



**WEEKLY FUGITIVE EMISSION
INSPECTION LOG**

LOCATION: Ventura Harbor #00082

A. COMPONENT DESCRIPTION							
If any component is leaking, minimize leak, notify Supervisor							
DAY	MON	TUES	WED	THUR	FRI	SAT	SUN
COMPONENT	LEAKING (Y/N)						
G-1 PUMP SEAL		N	N	N	N	N	N
G-3 PUMP SEAL		N	N	N	N	N	N
STATION VALVES		N	N	N	N	N	N
TANK VALVES		N	N	N	N	N	N
SUMP		N	N	N	N	N	N
BOOSTER SEAL		N	N	N	N	N	N
MIXER SEAL		N	N	N	N	N	N
PIG LAUNCHER		N	N	N	N	N	N
INITIAL:	1-1-18	1-2-18	1-3-18	1-4-18	1-5-18	1-6-18	1-7-18
DATE:	1-1-18	21	21	21	21	21	21
B. OPACITY CHECK							
ENGINE	VISUAL EMISSIONS		DATE	TIME	INITIAL		
Caterpillar G-1	<input type="checkbox"/> Y	<input type="checkbox"/> N					
Enterprise G-3	<input type="checkbox"/> Y	<input checked="" type="checkbox"/> N	1-4-18	6:30	SP		
C. COMMENTS							



WEEKLY FUGITIVE EMISSION INSPECTION LOG

LOCATION: Ventura Harbor #00082

A. COMPONENT DESCRIPTION							
If any component is leaking, minimize leak, notify Supervisor							
DAY	MON	TUES	WED	THUR	FRI	SAT	SUN
COMPONENT	LEAKING (Y/N)						
G-1 PUMP SEAL	N	N	N	N	N	N	N
G-3 PUMP SEAL	N	N	N	N	N	N	N
STATION VALVES	N	N	N	N	N	N	N
TANK VALVES	N	N	N	N	N	N	N
SUMP	N	N	N	N	N	N	N
BOOSTER SEAL	N	N	N	N	N	N	N
MIXER SEAL	N	N	N	N	N	N	N
PIG LAUNCHER	N	N	N	N	N	N	N
INITIAL:	ST	JD	ST	JL	ST	SP	ST
2/5/18 DATE:	2-5-18	2/6	2-7	2/8	2-9	2-10	2-11
B. OPACITY CHECK							
ENGINE	VISUAL EMISSIONS		DATE	TIME	INITIAL		
Caterpillar G-1	<input type="checkbox"/> Y	<input type="checkbox"/> N					
Enterprise G-3	<input type="checkbox"/> Y	<input checked="" type="checkbox"/> N	2/6/18	1300	JD		
C. COMMENTS							



**WEEKLY FUGITIVE EMISSION
INSPECTION LOG**

LOCATION: Ventura Harbor #00082

A. COMPONENT DESCRIPTION							
If any component is leaking, minimize leak, notify Supervisor							
DAY	MON	TUES	WED	THUR	FRI	SAT	SUN
COMPONENT	LEAKING (Y/N)						
G-1 PUMP SEAL	N	N	N	N	N	N	N
G-3 PUMP SEAL	N	N	N	N	N	N	N
STATION VALVES	N	N	N	N	N	N	N
TANK VALVES	N	N	N	N	N	N	N
SUMP	N	N	N	N	N	N	N
BOOSTER SEAL	N	N	N	N	N	N	N
MIXER SEAL	N	N	N	N	N	N	N
PIG LAUNCHER	N	N	N	N	N	N	N
INITIAL:	ST	SP	SP	SP	SP	SP	SP
DATE:	3-5	3-6-18	3-7-18	3-8-18	3-9-18	3-10-18	3-11-18
B. OPACITY CHECK							
ENGINE	VISUAL EMISSIONS		DATE	TIME	INITIAL		
Caterpillar G-1	<input type="checkbox"/> Y	<input type="checkbox"/> N					
Enterprise G-3	<input type="checkbox"/> Y	<input checked="" type="checkbox"/> N	3-6-18	8:00 am	SP		
C. COMMENTS							



**WEEKLY FUGITIVE EMISSION
INSPECTION LOG**

LOCATION: Ventura Harbor #00082

A. COMPONENT DESCRIPTION							
If any component is leaking, minimize leak, notify Supervisor							
DAY	MON	TUES	WED	THUR	FRI	SAT	SUN
COMPONENT	LEAKING (Y/N)						
G-1 PUMP SEAL		N	N	N	N	N	N
G-3 PUMP SEAL		N	N	N	N	N	N
STATION VALVES		N	N	N	N	N	N
TANK VALVES		N	N	N	N	N	N
SUMP		N	N	N	N	N	N
BOOSTER SEAL		N	N	N	N	N	N
MIXER SEAL		N	N	N	N	N	N
PIG LAUNCHER		N	N	N	N	N	N
INITIAL:		SP	OP	SP	SP	SP	SP
4.2.18 DATE:		4.3	4.4	4.5	4.6	4.7	4.8
B. OPACITY CHECK							
ENGINE	VISUAL EMISSIONS		DATE	TIME	INITIAL		
Caterpillar G-1	<input type="checkbox"/> Y	<input checked="" type="checkbox"/> N	4.3	1:50	SP		
Enterprise G-3	<input type="checkbox"/> Y	<input type="checkbox"/> N					
C. COMMENTS							



**WEEKLY FUGITIVE EMISSION
INSPECTION LOG**

LOCATION: Ventura Harbor #00082

A. COMPONENT DESCRIPTION							
If any component is leaking, minimize leak, notify Supervisor							
DAY	MON	TUES	WED	THUR	FRI	SAT	SUN
COMPONENT	LEAKING (Y/N)						
G-1 PUMP SEAL	N	N	N	N	X	N	N
G-3 PUMP SEAL	N	N	N	N	N	N	N
STATION VALVES	N	N	N	N	N	N	N
TANK VALVES	N	N	N	N	N	N	N
SUMP	N	N	N	N	N	N	N
BOOSTER SEAL	N	N	N	N	N	N	N
MIXER SEAL	N	N	N	N	N	N	N
PIG LAUNCHER	N	N	N	N	N	N	N
INITIAL:	JP	JA	JP	JP	JD	JD	JP
5-7-18 DATE:	5-7-18	5-8	5-9-18	5-10-18	5/11	5/12	5/13
B. OPACITY CHECK							
ENGINE	VISUAL EMISSIONS		DATE	TIME	INITIAL		
Caterpillar G-1	<input type="checkbox"/> Y	<input type="checkbox"/> N					
Enterprise G-3	<input type="checkbox"/> Y	<input checked="" type="checkbox"/> N	5-9-18	9:00	JP		
C. COMMENTS							



**WEEKLY FUGITIVE EMISSION
INSPECTION LOG**

LOCATION: Ventura Harbor #00082

A. COMPONENT DESCRIPTION							
If any component is leaking, minimize leak, notify Supervisor							
DAY	MON	TUES	WED	THUR	FRI	SAT	SUN
COMPONENT	LEAKING (Y/N)						
G-1 PUMP SEAL	N	N	N	N	N	N	N
G-3 PUMP SEAL	N	N	N	N	N	N	N
STATION VALVES	N	N	N	N	N	N	N
TANK VALVES	N	N	N	N	N	N	N
SUMP	N	N	N	N	N	N	N
BOOSTER SEAL	N	N	N	N	N	N	N
MIXER SEAL	N	N	N	N	N	N	N
PIG LAUNCHER	N	N	N	N	N	N	N
INITIAL:	JO	CH	JP	CH	JP	CS	CS
6/4/13 DATE:	6/4	6/5	6/6	6/7	6/8	6-9	6-10
B. OPACITY CHECK							
ENGINE	VISUAL EMISSIONS		DATE	TIME	INITIAL		
Caterpillar G-1	<input type="checkbox"/> Y	<input type="checkbox"/> N					
Enterprise G-3	<input type="checkbox"/> Y	<input type="checkbox"/> N					
C. COMMENTS							



**WEEKLY FUGITIVE EMISSION
INSPECTION LOG**

LOCATION: Ventura Harbor #00082

A. COMPONENT DESCRIPTION							
If any component is leaking, minimize leak, notify Supervisor							
DAY	MON	TUES	WED	THUR	FRI	SAT	SUN
COMPONENT	LEAKING (Y/N)						
G-1 PUMP SEAL	N	N		N	N	N	N
G-3 PUMP SEAL	N	N		N	N	N	N
STATION VALVES	N	N		N	N	N	N
TANK VALVES	N	N		N	N	N	N
SUMP	N	N		N	N	N	N
BOOSTER SEAL	N	N		N	N	N	N
MIXER SEAL	N	N		N	N	N	N
PIG LAUNCHER	N	N		N	N	N	N
INITIAL:	SP	CH		JD	JP	JP	JP
7/2/18 DATE:	7/2	7/3		7/5	7/6	7/7	7/8
B. OPACITY CHECK							
ENGINE	VISUAL EMISSIONS		DATE	TIME	INITIAL		
Caterpillar G-1	<input type="checkbox"/> Y	<input type="checkbox"/> N					
Enterprise G-3	<input type="checkbox"/> Y	<input type="checkbox"/> N					
C. COMMENTS							



**WEEKLY FUGITIVE EMISSION
INSPECTION LOG**

LOCATION: Ventura Harbor #00082

A. COMPONENT DESCRIPTION							
If any component is leaking, minimize leak, notify Supervisor							
DAY	MON	TUES	WED	THUR	FRI	SAT	SUN
COMPONENT	LEAKING (Y/N)						
G-1 PUMP SEAL	OK	ok	OK	OK	OK	OK	OK
G-3 PUMP SEAL	OK	ok	OK	OK	OK	OK	OK
STATION VALVES	OK	ok	OK	OK	OK	OK	OK
TANK VALVES	OK	ok	OK	OK	OK	OK	OK
SUMP	OK	ok	OK	OK	OK	OK	OK
BOOSTER SEAL	OK	ok	OK	OK	OK	OK	OK
MIXER SEAL	OK	ok	OK	OK	OK	OK	OK
PIG LAUNCHER	OK	ok	OK	OK	OK	OK	OK
INITIAL:	CH	SP	CH	CH	CH	DM	DM
DATE:	8/6/18	8/7/18	8/9/18	8/9/18	8/10/18	8-11-8	8-12-8
B. OPACITY CHECK							
ENGINE	VISUAL EMISSIONS		DATE	TIME	INITIAL		
Caterpillar G-1	<input type="checkbox"/> Y	<input type="checkbox"/> N					
Enterprise G-3	<input type="checkbox"/> Y	<input checked="" type="checkbox"/> N	8/9	7:00	CH.		
C. COMMENTS							



**WEEKLY FUGITIVE EMISSION
INSPECTION LOG**

LOCATION: Ventura Harbor #00082

A. COMPONENT DESCRIPTION							
If any component is leaking, minimize leak, notify Supervisor							
DAY	MON	TUES	WED	THUR	FRI	SAT	SUN
COMPONENT	LEAKING (Y/N)						
G-1 PUMP SEAL	N	N	N	N		N	N
G-3 PUMP SEAL	N	N	N	N		N	N
STATION VALVES	N	N	N	N		N	N
TANK VALVES	N	N	N	N		N	N
SUMP	N	N	N	N		N	N
BOOSTER SEAL	N	N	N	N		N	N
MIXER SEAL	N	N	N	N		N	N
PIG LAUNCHER	N	N	N	N		N	N
INITIAL:	SP	SP	SP	SP		CS	CS
9/10/18 DATE:	9/10	9/11	9/12	9/13		9.15	9.16
B. OPACITY CHECK							
ENGINE	VISUAL EMISSIONS		DATE	TIME	INITIAL		
Caterpillar G-1	<input type="checkbox"/> Y	<input type="checkbox"/> N					
Enterprise G-3	<input type="checkbox"/> Y	<input checked="" type="checkbox"/> N	9/10	7:00	SP		
C. COMMENTS							



**WEEKLY FUGITIVE EMISSION
INSPECTION LOG**

LOCATION: Ventura Harbor #00082

A. COMPONENT DESCRIPTION							
If any component is leaking, minimize leak, notify Supervisor							
DAY	MON	TUES	WED	THUR	FRI	SAT	SUN
COMPONENT	LEAKING (Y/N)						
G-1 PUMP SEAL	N	N	N	N	N	N	N
G-3 PUMP SEAL	N	N	N	N	N	N	N
STATION VALVES	N	N	N	N	N	N	N
TANK VALVES	N	N	N	N	N	N	N
SUMP	N	N	N	N	N	N	N
BOOSTER SEAL	N	N	N	N	N	N	N
MIXER SEAL	N	N	N	N	N	N	N
PIG LAUNCHER	N	N	N	N	N	N	N
<i>10/1/18</i> INITIAL:	SP	SP	SP	CH	CH	JO	JO
DATE:	10/1/18	10/2/18	10/3/18	10/4/18	10/5	10/6	10/7
B. OPACITY CHECK							
ENGINE	VISUAL EMISSIONS		DATE	TIME	INITIAL		
Caterpillar G-1	<input type="checkbox"/> Y	<input checked="" type="checkbox"/> N	10/2	8:20	SP		
Enterprise G-3	<input type="checkbox"/> Y	<input type="checkbox"/> N					
C. COMMENTS							



**WEEKLY FUGITIVE EMISSION
INSPECTION LOG**

LOCATION: Ventura Harbor #00082

A. COMPONENT DESCRIPTION							
If any component is leaking, minimize leak, notify Supervisor							
DAY	MON	TUES	WED	THUR	FRI	SAT	SUN
COMPONENT	LEAKING (Y/N)						
G-1 PUMP SEAL	N	N	N	N	N	N	N
G-3 PUMP SEAL	N	N	N	N	N	N	N
STATION VALVES	N	N	N	N	N	N	N
TANK VALVES	N	N	N	N	N	N	N
SUMP	N	N	N	N	N	N	N
BOOSTER SEAL	N	N	N	N	N	N	N
MIXER SEAL	N	N	N	N	N	N	N
PIG LAUNCHER	N	N	N	N	N	N	N
INITIAL:	CH	SP	SP	SP	CH	CH	CH
DATE:	11/15/18	11/16/18	11/17/18	11/18/18	11/19/18	11/20/18	11/21/18
B. OPACITY CHECK							
ENGINE	VISUAL EMISSIONS		DATE	TIME	INITIAL		
Caterpillar G-1	<input type="checkbox"/> Y	<input type="checkbox"/> N					
Enterprise G-3	<input type="checkbox"/> Y	<input checked="" type="checkbox"/> N	11/8/18	6:30	SP		
C. COMMENTS							



**WEEKLY FUGITIVE EMISSION
INSPECTION LOG**

LOCATION: Ventura Harbor #00082

A. COMPONENT DESCRIPTION							
If any component is leaking, minimize leak, notify Supervisor							
DAY	MON	TUES	WED	THUR	FRI	SAT	SUN
COMPONENT	LEAKING (Y/N)						
G-1 PUMP SEAL	N	N	N		N	N	N
G-3 PUMP SEAL	N	N	N		N	N	N
STATION VALVES	N	N	N		N	N	N
TANK VALVES	N	N	N		N	N	N
SUMP	N	N	N		N	N	N
BOOSTER SEAL	N	N	N		N	N	N
MIXER SEAL	N	N	N		N	N	N
PIG LAUNCHER	N	N	N		N	N	N
INITIAL:	CH	CH	CH		CH	CS	CS
12/3/18 DATE:	12/3/18	12/4/18	12/5/18		12/7/18	12/8	12/9
B. OPACITY CHECK							
ENGINE	VISUAL EMISSIONS		DATE	TIME	INITIAL		
Caterpillar G-1	<input type="checkbox"/> Y	<input type="checkbox"/> N					
Enterprise G-3	<input type="checkbox"/> Y	<input type="checkbox"/> N					
C. COMMENTS							



ANNUAL COMPLIANCE CERTIFICATION DEVIATION SUMMARY FORM

Period Covered by Compliance Certification: 01 / 01 / 18 (MM/DD/YY) to 12 / 31 / 18 (MM/DD/YY)

A. Attachment # or Permit Condition #: Att. No. 71.2N2, Rules 71.2.B.4, 71.2.C.1	B. Equipment description: Tank 150305	C. Deviation Period: Date & Time Begin: <u>Unknown</u> End: <u>6/13/2018, 4:00pm</u> When Discovered: Date & Time <u>6/8/2018, 7:10am</u>
D. Parameters monitored: Floating Roof	E. Limit: Integrity	F. Actual: Damage
G. Probable Cause of Deviation: Oversight		H. Corrective actions taken: Repairs were performed upon discovery.

A. Attachment # or Permit Condition #: Att. No. 74.9N3, Rules 74.9.B.1 and B.2	B. Equipment description: Enterprise Engine G-3 (S/N 54050)	C. Deviation Period: Date & Time Begin: <u>9/31/2018, 11:59pm</u> End: <u>10/31/2018, unknown</u> When Discovered: Date & Time <u>9/25/2019</u>
D. Parameters monitored: Months	E. Limit: 3	F. Actual: 4
G. Probable Cause of Deviation: All head gaskets failed on 9/25/2018, and the engine was taken out of service. Replacements parts did not arrive until late October.		H. Corrective actions taken: Quarterly emissions screening was performed 10/31/2018, after replacement parts were installed.

A. Attachment # or Permit Condition #:	B. Equipment description:	C. Deviation Period: Date & Time Begin: _____ End: _____ When Discovered: Date & Time _____
D. Parameters monitored:	E. Limit:	F. Actual:
G. Probable Cause of Deviation:		H. Corrective actions taken: