



February 8, 2019

Mr. Dan Searcy  
Ventura County Air Pollution Control District  
669 County Square Drive  
Ventura, CA 93003

**RE: Annual Compliance Report - Platform Gail, Part 70 Permit No. 1494**

Dear Mr. Searcy:

Pursuant to the Part 70 Permit No. 1494 requirement for annual compliance reporting, please find the following information for the twelve-month period of January 2018 through December 2018:

- Completed Permit Attachment Forms for each applicable requirement or Part 70 permit condition.
- Completed Source Test Summary Forms for emission units that require compliance with a quantifiable emission rates (Stationary Gas Turbines G-01, G-02, and G-03).
- Additional supporting information to demonstrate compliance with specific permit conditions.

If you have any questions or comments regarding this Annual Compliance Report or need additional information, please call me at (805) 395-9676.

Sincerely,

  
John Garnett  
EHSR Advisor

Attach.

Cc: Gerardo Rios, EPA Region IX

RECEIVED  
VENTURA COUNTY  
2019 FEB 11 AM 8:15  
A.P.C.D.

Ventura County Air Pollution Control District  
COMPLIANCE CERTIFICATION PERMIT FORM

Cover Sheet

Form TVPF45/12-24-98 Page 2 of 2


Gerardo Rios  
Permits Office (AIR-3)  
Office of Air Division  
EPA Region IX  
75 Hawthorne Street  
San Francisco, CA 94105

**Confidentiality**

All information in a Part 70 permit compliance certification is public information. The Part 70 permit is also public information.

**Certification by Responsible Official**

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in this compliance certification are true, accurate, and complete.

Signature and Title of Responsible Official:		Date:
Title:	<i>Env. ETSK</i>	<i>2/8/2019</i>

Time Period Covered by Compliance Certification:

01 / 01 / 18 (MM/DD/YY) to 12 / 31 / 18 (MM/DD/YY)



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 2018 (MM/DD/YY) to 12 / 31 / 2018 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: <u>74.6</u></p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Surface cleaning and degreasing requirements including ROC content limits, application and storage requirements</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p>
<p>C. Method of monitoring: Records of current material list of ROC-containing material used in solvent cleaning activities are maintained. Routine surveillance of the applicable solvent cleaning activities is also performed. All cleaning solvents used have a ROC content of 25 g/l or less.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: <u>74.10</u></p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Fugitive leak and leak inspection requirements for components at crude oil production and processing facilities.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p>
<p>C. Method of monitoring: Weekly visual inspections of pumps, including but not limited to rod pumps and compressor pumps for liquid leaks. Quarterly monitoring of the following components for gaseous leaks using EPA Reference Method 21: valves, packing seals on dump lever arms connected to gas traps, separators, or vessels, hatches on non-vapor recovery tanks, and polished rod stuffing boxes. All other components not exempt are monitored annually. Routine surveillance of the applicable components is also performed and includes verification of proper operation and equipment and inspection requirements are met. Detected leaks are visibly tagged with the date leak is detected, and repaired no later than 21 days (critical components are at next scheduled shutdown, but no later than 3 months). Repair is reinspected within one week of repair. Updated Operator Management Plan was submitted to the District in May of 1999, and the recertification letter was submitted in January 2014. Records of the following are maintained: location, type, description of each leaking component inspected, and name of any operating unit where each leaking component is found; date of leak detection and method of detection; date that leak is repaired and date of re-check; identification of leaks from critical process units; number of components inspected, number and percentage of leaking components found, categorized by groups: hatches, polished rod stuffing boxes, dumplever arms, valves (not open-ended), open-ended lines, flanges (if designated as exempt), other components.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

A. Attachment # or Permit Condition #: <u>74.22</u>	D. Frequency of monitoring:
B. Description: Natural gas-fired, fan-type central furnaces – NO <sub>x</sub> limits and certification requirements	None
C. Method of monitoring: Annual certification including a formal survey identifying each furnace, whether it was installed before or after May 31, 1994, and for those installed after May 31, 1994, information indicating that the certification is contained on the furnace nameplate, or that the furnace is included on a District-provided list of certified furnaces. <b>Platform Gail does not have any natural gas-fired, fan-type central furnaces.</b>	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable  F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 2018 (MM/DD/YY) to 12 / 31 / 2018 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: <u>PO1494PC4</u></p>	<p>D. Frequency of monitoring:</p>
<p>B. Description:</p> <p>Detroit diesel backup generator operation requirement to not fire this engine simultaneously with any one of the three turbines, except during startup or shutdown transition periods not to exceed one hour, or to perform routine maintenance on the Detroit backup engine.</p>	<p>Periodic</p>
<p>C. Method of monitoring:</p> <p>Annual compliance certification that the diesel-fired backup generator was not fired simultaneously with any of the three turbines, except during startup or shutdown transition periods which did not exceed one hour, or during routine maintenance on the Detroit diesel backup engine.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p>
<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>	

<p>A. Attachment # or Permit Condition #: <u>50</u></p>	<p>D. Frequency of monitoring:</p>
<p>B. Description:</p> <p>Opacity requirements</p>	<p>Periodic</p>
<p>C. Method of monitoring:</p> <p>Routine surveillance and visual inspections are performed to ensure that opacity requirements are being maintained. Records including date, time, and identity of emissions unit of any occurrences of visible emissions not meeting Rule 50 opacity requirements are maintained. District notification within subsequent 24 hours if visible emissions problem cannot be corrected within first 24 hours. <b>Annual certification including an annual formal survey identifying the date, time, emissions unit, and verification that there were no visible emissions not meeting the Rule 50 opacity requirements is attached.</b></p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p>
<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>	

<p>A. Attachment # or Permit Condition #: <u>52</u></p>	<p>D. Frequency of monitoring:</p>
<p>B. Description:</p> <p>Particulate Matter – Concentration requirements (grain loading)</p>	<p>Periodic</p>
<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p>	

<p>C. Method of monitoring:</p> <p>Annual compliance certification that particulate matter was not discharged into the atmosphere from any source at the facility in excess of the concentration listed in the table shown in Rule 52. This is based on a reference to the District analysis of Rule 52 compliance based on EPA emission factors as being sufficient. Periodic monitoring is not necessary to certify compliance.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>
---	---



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 2018 (MM/DD/YY) to 12 / 31 / 2018 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: <u>71.1.C</u></p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Emissions of produced gas must be controlled at all times using a gas collection system that directs all gas to a fuel or sales gas system, or to a flare that combusts ROCs.</p>	<p>Periodic</p>
<p>C. Method of monitoring: Fugitive I&amp;M Program under Rule 74.10 for the gas collection system's gas and liquid piping connections; Annual compliance certification that the produced gas collection system is a closed system through a visual inspection. Flare is inspected on a quarterly basis. Records of visual and flare inspections are maintained at the facility.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p>
	<p>G. Compliance Status? (C or I): <u>C</u></p>
	<p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: <u>71.4.B.3</u></p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Well cellar storage prohibition</p>	<p>None</p>
<p>C. Method of monitoring: Annual certification including routine surveillance and visual inspections that no crude oil or petroleum material was stored in a well cellar except during periods of equipment maintenance or well workover, and in no case, no storage for more than 5 days. No well cellars are on Platform Gail.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p>
	<p>G. Compliance Status? (C or I): <u>C</u></p>
	<p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: <u>71.4.B.1</u></p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: First stage sump prohibition</p>	<p>None</p>
<p>C. Method of monitoring: Annual certification that there are no first stage production sumps at the facility.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p>
	<p>G. Compliance Status? (C or I): <u>C</u></p>
	<p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>





## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 2018 (MM/DD/YY) to 12 / 31 / 2018 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: <u>74.16N1494</u></p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: <b>Oilfield Drilling Operations</b></p>	<p>Periodic</p>
<p>C. Method of monitoring: Annual compliance certification that the turbines are used to supply electrical power during drilling operations.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: <u>40CFR61.M</u></p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: <b>National emission standard for asbestos</b></p>	<p>Periodic</p>
<p>C. Method of monitoring: Annual compliance certification that compliance with 40 CFR 61 Subpart M is met if an asbestos demolition or renovation activity occurs.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: <u>ATCM ENG.N3</u></p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: <b>Stationary compression ignition engines used solely on OCS platforms</b></p>	<p>Periodic</p>
<p>C. Method of monitoring: Annual certification that monthly fuel consumption records, hours of operation, and fuel type records are maintained. <b>ATCM emission standards are not federally enforceable.</b></p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>





## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 2018 (MM/DD/YY) to 12 / 31 / 2018 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: <u>71.1N1</u></p>	<p>D. Frequency of monitoring:</p> <p>Periodic</p>
<p>B. Description:</p> <p>Tanks that are equipped with vapor recovery.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p>
<p>C. Method of monitoring:</p> <p>Fugitive I&amp;M Program under Rule 74.10 for the tank hatches and other inlet and outlet gas and liquid piping connections; storage tank vapor recovery system for each applicable tank is monitored on a quarterly basis which includes inspection of the gas compressor, hatches, relief valves, pressure regulators, and flare; dated records of the quarterly inspections and tank maintenance activities are maintained at the facility; verbal notice of maintenance activities; Annual compliance certification verifying tanks are equipped with vapor recovery</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: <u>71.1N6</u></p>	<p>D. Frequency of monitoring:</p> <p>Periodic</p>
<p>B. Description:</p> <p>Portable tank requirements - tanks must be equipped with both a closed cover that is impermeable to ROC vapors and a pressure-vacuum valve set by the mfr or according to the mfr.'s recommendations.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p>
<p>C. Method of monitoring:</p> <p>Fugitive I&amp;M Program for the tank hatches and other inlet and outlet gas and liquid piping connections; annual compliance certification including verification of the integrity of the roof and pressure-vacuum relief valve.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: <u>71.5N1</u></p>	<p>D. Frequency of monitoring:</p> <p>Periodic</p>
<p>B. Description:</p> <p>Glycol dehydrators – closed pipe control system to fuel gas or sales gas system. Requirement to control the ROC emissions from the regenerator vent by a condenser/vapor disposal system that collects and condenses ROC emissions and directs all uncondensed ROC emissions to a vapor recovery/disposal system.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p>

C. Method of monitoring:

Fugitive I&M Program under Rule 74.10 for the inlet and outlet gas and liquid piping connections; records maintained on site which include facility name, APCD permit no., location and size of glycol reboiler, amount of gas dehydrated, and type of glycol used, description of any installed ROC control system, flow diagram of the dehydrator and any ROC controls, and maintenance records of the ROC control system; Annual compliance certification including a visual inspection assuring that the glycol dehydrator emission control system is a closed system, that the tank storing the condensed hydrocarbon liquid is a closed tank, and that the glycol unit is leak-free.

F. Currently in Compliance? (Y or N): Y

G. Compliance Status? (C or I): C

H. \*Excursions, exceedances, or other non-compliance? (Y or N): N

\*If yes, attach Deviation Summary Form



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 2018 (MM/DD/YY) to 12 / 31 / 2018 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: <u>PO1494PC1 Condition No. 5</u></p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Platform Gail Additional Requirements - Crew boat and work boat emission limits</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p>
<p>C. Method of monitoring: Monthly records of fuel consumption from the crew and work boats are maintained. Monthly emissions are calculated for the crew and work boats and are maintained in 12-month rolling records. Annual compliance certification that these records are maintained.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: <u>PO1494PC1 Condition No. 6 and 7</u></p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Platform Gail Additional Requirements - Crew boat and work boat permitted engines</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p>
<p>C. Method of monitoring: Only one crew boat and one work boat was used at any given time. Records are maintained showing the days and hours that each crew boat and work boat was in service. Annual compliance certification that these records are maintained.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: <u>PO1494PC1 Condition No. 8</u></p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Platform Gail Additional Requirements - Solvent Recordkeeping</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p>
<p>C. Method of monitoring: Records of solvent purchase and usage, along with records of solvent that is recycled or disposed of are maintained for solvents used in solvent cleaning activities, including wipe cleaning. Annual compliance certification that these records are maintained. All cleaning solvents used have a ROC content of 25 g/l or less.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 2018 (MM/DD/YY) to 12 / 31 / 2018 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: <u>74.23N2/1494</u></p>	<p>D. Frequency of monitoring:</p> <p>Continuous, Annually</p>
<p>B. Description:</p> <p>Stationary gas turbines – NO<sub>x</sub> emission limits (water-to-fuel ratios) for three 3.4 MW Allison 501-K turbines, except at loads of 1000 kW or less, and during thermal stabilization period associated with a start-up, planned shutdown, or unplanned load change.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p>
<p>C. Method of monitoring:</p> <p>Annual source tests of the turbines conducted at 30, 50, 75, and 100 % loads using the following methods: EPA Method 20 for NO<sub>x</sub>, ARB Method 100 for oxygen content, ASTM Method D 240-87 for fuel oil heating value, ASTM Method 1826-88 for gaseous fuel heating value. Records of the following on a continuous basis: water-to-fuel ratio, type and amount of fuel consumed at all loads and at loads less than 1000 kW, elapsed time of operation, and turbine section inlet temperature. Observation per shift of ratios to check for any excursion outside the acceptable ratio. Report submitted every 6 months containing actual annual fuel consumption of each turbine at all loads and at loads less than 1000 kW. <b>Report containing fuel consumption is attached.</b></p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>I</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>Y*</u></p> <p>*If yes, attach Deviation Summary Form</p> <p><b>Breakdown for ammonia loss on 8/14/18</b></p>

<p>A. Attachment # or Permit Condition #: <u>NSPS GG</u></p>	<p>D. Frequency of monitoring:</p> <p>Continuous</p>
<p>B. Description:</p> <p>Standards of performance, NO<sub>x</sub> limits, and SO<sub>2</sub> limits, limits of sulfur content of fuel, continuous monitoring requirements for stationary gas turbines.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p>
<p>C. Method of monitoring:</p> <p>Continuous monitoring system that records fuel consumption and the ratio of water-to-fuel accurate within ±5.0%. Reports of excess emissions every one-hour period which the ratio's below the required ratio, records of all CEM measurements/information, and performance tests, records of occurrence and duration of any startup, shutdown, or malfunction in operation of an affected facility or air pollution control equipment, any periods during which a continuous monitoring system is inoperative. Records of sulfur content of liquid fuels using ASTM D 2880-71 for each fuel transfer to the storage tank from any other source. Note that <b>Fuel supplier's certifications containing fuel sulfur content by weight for each fuel delivery are maintained and are also referenced to the TVPF46 Compliance Certification Permit Form – Attach. 64.B.2.</b> Records of sulfur content of gaseous fuels every 6 months using ASTM D-3588-91, which is the equivalent of ASTM D 4084-82.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>Y*</u></p> <p>*If yes, attach Deviation Summary Form</p>

--	--

<p>A. Attachment # or Permit Condition #: PO1494PC1 Condition No. 1</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description:</p> <p>Platform Gail Additional Requirements - 12-month rolling records of throughput and consumption as provided in the Permitted Throughput and Consumption Limits Table in Section No. 3 of the Permit.</p>	<p>Periodic</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p>
<p>C. Method of monitoring:</p> <p>Monthly records of fuel consumption for the flares, turbines (at all loads and at loads &lt; 1000 kW), back-up generator, starter engines, cranes, boom boat, and crew and supply boats are maintained in 12-month rolling records. Monthly emissions for the crew and work boats, and wipe cleaning solvents are calculated and are maintained in 12-month rolling records. Annual compliance certification that these records are maintained.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 2016 (MM/DD/YY) to 12 / 31 / 2016 (MM/DD/YY)

<b>A. Attachment # or Permit Condition #:</b> PO1494PC2 Conditions 1&4	<b>D. Frequency of monitoring:</b>  <b>Continuous</b>
<b>B. Description:</b>  Flare fuel consumption	<b>E. Source test reference method, if applicable.</b> Attach Source Test Summary Form, if applicable
<b>C. Method of monitoring:</b>  Each flare has individual fuel meter installed to record the amount of natural gas consumed. Monthly records of volume of gas combusted in flare are maintained in 12-month rolling records. Records also differentiate between emergency (unplanned) usage and non-emergency (planned) usage. Annual compliance certification that these records are maintained.	<b>F. Currently in Compliance?</b> (Y or N): <u>Y</u> <b>G. Compliance Status?</b> (C or I): <u>C</u> <b>H. *Excursions, exceedances, or other non-compliance?</b> (Y or N): <u>N</u> *If yes, attach Deviation Summary Form

<b>A. Attachment # or Permit Condition #:</b> PO1494PC2 Conditions 2&3	<b>D. Frequency of monitoring:</b>  <b>Periodic</b>
<b>B. Description:</b>  Flare ignition system operation – each flare is equipped and maintained with a continuous pilot or autoignition system to ensure combustion disposal of all excess produced or recovered gases.	<b>E. Source test reference method, if applicable.</b> Attach Source Test Summary Form, if applicable
<b>C. Method of monitoring:</b>  Flare’s ignition system is tested monthly and monthly records of the flare’s ignition system tests and maintenance activities are maintained. Annual compliance certification that these records are maintained.	<b>F. Currently in Compliance?</b> (Y or N): <u>Y</u> <b>G. Compliance Status?</b> (C or I): <u>C</u> <b>H. *Excursions, exceedances, or other non-compliance?</b> (Y or N): <u>N</u> *If yes, attach Deviation Summary Form

<b>A. Attachment # or Permit Condition #:</b> PO1494PC3	<b>D. Frequency of monitoring:</b>  <b>Periodic</b>
<b>B. Description:</b>  Drain pit operation exemption from Rule 71.4 requirements since its function is to act as a containment berm.	<b>E. Source test reference method, if applicable.</b> Attach Source Test Summary Form, if applicable

<p>C. Method of monitoring: Annual compliance certification that the 7.07 square foot deck drain pit (T-21) acts as a containment berm.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>
---	--





## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 2018 (MM/DD/YY) to 12 / 31 / 2018 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: <u>PO1494PC1 Condition No. 2</u></p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Platform Gail Additional Requirements - Maximum number of oil wells (30).</p>	<p>Periodic</p>
<p>C. Method of monitoring: Authority to Construct will be obtained prior to drilling any wells, unless the activity is a redrill. Annual compliance certification that there was no increase in the maximum number of wells. Permit was revised to account for a maximum of 30 wells.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: <u>PO1494PC1 Condition No. 3</u></p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Platform Gail Additional Requirements - BACT requirements for well operations.</p>	<p>Periodic</p>
<p>C. Method of monitoring: Annual compliance certification that Wells E-9 Short, E-11 Short, E-11 Long, E-12 Short, E-12 Long, E-22 Short, E-22 Long, are free-flowing or operated with electric motor-driven artificial equipment. Compliance with this requirement is determined monthly and written documentation is reported to the MMS. Note: E-9 Long and E-21 are not currently producing and have been converted to water injection wells.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: <u>PO1494PC1 Condition No. 4</u></p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Platform Gail Additional Requirements - Maximum sulfur content of diesel fuel consumed in the crane engines, turbines, turbine starter engines, backup generator engine, and the boats.</p>	<p>Periodic</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p>

<p>C. Method of monitoring: Records of certifications from the fuel supplier documenting the sulfur content of each diesel fuel delivery are maintained.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>
--	--



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 2018 (MM/DD/YY) to 12 / 31 / 2018 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: 40CFR63ZZZZ3</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: RICE MACT for emergency diesel engines – oil change and inspections</p>	<p>Periodic</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p>
<p>C. Method of monitoring: Annual compliance certification that maintenance records are maintained and engines are equipped with non-resettable hour meters.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: 40CFR63ZZZZ4</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: RICE MACT for non-emergency diesel engines less than or equal to 300 HP – oil change and inspections</p>	
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p>
<p>C. Method of monitoring: Annual compliance certification that maintenance records are maintained.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: 40CFR63ZZZZ6</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: RICE MACT for non-emergency diesel engines greater than 500 HP – CO ppm limit</p>	<p>Periodic</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p>
<p>C. Method of monitoring: Annual certification that the South Crane CO source testing will be conducted every 8760 hours of operation or every three years, whichever comes first. Catalyst temperatures are monitored using a CPMS. Initial source testing conducted in March 2014.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 2018 (MM/DD/YY) to 12 / 31 / 2018 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: <u>74.11.1</u></p> <p>B. Description: Large Water Heaters and Small Boilers</p>	<p>D. Frequency of monitoring: None</p> <p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p>
<p>C. Method of monitoring: Annual certification including a formal survey identifying each large water heater or small boiler, whether it was installed before or after December 31, 1999, or December 31, 2000 and for those installed after December 31, 1999, or December 31, 2000, information indicating that the certification is contained on the unit's nameplate, or that the unit is included on a District-provided list of certified water heaters, boilers, steam generators and process heaters. <b>Platform Gail does not have any of the applicable units.</b></p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: <u>74.1</u></p> <p>B. Description: Abrasive blasting requirements</p>	<p>D. Frequency of monitoring: Periodic</p> <p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p>
<p>C. Method of monitoring: Routine surveillance including assuring that operation and equipment requirements are being met, and visual inspections to ensure there are no opacity violations of each abrasive blasting operation are performed. Records including date of operation, type of abrasive blasting media used, identity, size, and location of item blasted, whether the operation was conducted inside or outside a permanent building, and CARB certifications for the abrasives used are maintained.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: <u>74.2</u></p> <p>B. Description: Architectural coating requirements</p>	<p>D. Frequency of monitoring: Periodic</p> <p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p>
---	---

<p>C. Method of monitoring:</p> <p>Routine surveillance and records including specifying the usage of compliant coatings and maintaining VOC records of coatings used (MSDSs are maintained). VOC content of coatings are measured using EPA Method 24, VOC content of exempt organic compounds are measured using CARB Method 432, and acid content of pretreatment wash primers are measured using ASTM Method D 1613-85, and metal content of metallic pigmented coatings are measured using SCAQMD Method 311-91.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>
---	---



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 2018 (MM/DD/YY) to 12 / 31 / 2018 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: <u>54.B.1 (OCS)</u></p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Sulfur Compounds – Sulfur emission concentration requirements at point of discharge</p>	<p>Periodic</p>
<p>C. Method of monitoring: Records of each flaring event are maintained. Unplanned flaring event reports are provided to the District within one week if they exceed 1 hour. The District is notified 72 hours prior to planned flaring. Records of planned flaring is maintained and includes the date, time, duration, flare volume, and estimated sulfur emissions during the entire event. An annual written report of excess emissions was previously submitted to the District on 01/15/19. A representative fuel analysis is being maintained.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: <u>54.B.2 (OCS)</u></p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Sulfur Compounds – Sulfur emission concentration requirements at ground level</p>	<p>Periodic</p>
<p>C. Method of monitoring: Records of each flaring event are maintained. Unplanned flaring event reports are provided to the District within one week if they exceed 1 hour. The District is notified 72 hours prior to planned flaring. Records of planned flaring is maintained and includes the date, time, duration, flare volume, and estimated sulfur emissions during the entire event. A representative fuel analysis is being maintained.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: <u>57.B</u></p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Combustion contaminants requirements – Specific – Fuel burning equipment</p>	<p>None</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p>

C. Method of monitoring:

Annual compliance certification that combustion contaminants were not discharged into the atmosphere from any fuel-burning equipment at the facility in excess of the concentration at the point of discharge, 0.1 grain per cubic foot of gas calculated to 12% CO<sub>2</sub> at standard conditions. This is based on a reference to the District analysis of Rule 57.B compliance based on EPA emission factors and a representative source test as being sufficient. Periodic monitoring is not necessary to certify compliance.

F. Currently in Compliance? (Y or N): Y

G. Compliance Status? (C or I): C

H. \*Excursions, exceedances, or other non-compliance? (Y or N): N

\*If yes, attach Deviation Summary Form





# ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 2018 (MM/DD/YY) to 12 / 31 / 2018 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: <u>64.B.1</u></p>	<p>D. Frequency of monitoring:</p>
<p>B. Description:</p> <p>Gaseous fuel sulfur compounds concentration requirements for all combustion emissions units at this facility combusting gaseous fuel.</p>	<p>Annually</p>
<p>C. Method of monitoring:</p> <p>Annual fuel analysis of the sulfur content of the fuel using South Coast AQMD Method 307-91.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: <u>64.B.2</u></p>	<p>D. Frequency of monitoring:</p>
<p>B. Description:</p> <p>Solid or liquid fuel sulfur compounds concentration requirements for all combustion emissions units at this facility combusting solid or liquid fuel.</p>	<p>Periodic</p>
<p>C. Method of monitoring:</p> <p>Fuel supplier's certifications containing fuel sulfur content by weight for each fuel delivery are maintained.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: <u>68</u></p>	<p>D. Frequency of monitoring:</p>
<p>B. Description:</p> <p>Carbon Monoxide concentration requirements for external combustion equipment</p>	<p>None</p>
<p>C. Method of monitoring:</p> <p>Annual compliance certification that carbon monoxide (CO) was not discharged into the atmosphere from any natural gas-fired or fuel oil-fired external combustion equipment at the facility in excess of 2000 ppmv measured on a dry basis at standard conditions. This is based on a reference to the District analysis of Rule 68 compliance based on EPA emission factors as being sufficient. Periodic monitoring is not necessary to certify compliance.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

--	--



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 2018 (MM/DD/YY) to 12 / 31 / 2018 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: <u>74.9N8</u></p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Stationary diesel-fired internal combustion engines with permitted capacity factor of 15% or less.</p>	<p>Periodic</p>
<p>C. Method of monitoring: Records containing data for each engine verifying the manufacturer's specified maximum hourly fuel consumption, data specifying the actual annual usage (e.g., fuel consumption or operating hours), and data for each engine including the engine manufacturer, model no., operator identification no., and location of each engine. A report of the engine's hours of operation is submitted to the District every 6 months. <b>A report of the engine's hours of operation is attached.</b></p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: <u>74.9N9</u></p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Stationary diesel-fired internal combustion engines used to power cranes and welding equipment</p>	<p>Periodic</p>
<p>C. Method of monitoring: Records containing data for each engine including the function (usage) of the engine, manufacturer, model number, operator identification number, and location of each engine. Routine surveillance of the diesel-fired engine to ensure that compliance is being maintained.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: <u>74.9N7</u></p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Emergency Standby Stationary Internal Combustion Engines Operated During Either an Emergency or Maintenance Operation</p>	<p>Periodic</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p>

<p>C. Method of monitoring: Records of operating hours. Date, time, duration, and reason for emergency operation. Records of engine data. Compliance is determined by logged hours of annual operation to ensure less than 50 hours per year.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>
---	--



# ANNUAL COMPLIANCE CERTIFICATION DEVIATION SUMMARY FORM

Period Covered by Compliance Certification: 01 / 01 / 18 (MM/DD/YY) to 12 / 31 / 18 (MM/DD/YY)

A. Attachment # or Permit Condition #:  <b>None to report</b>	B. Equipment description:	C. Deviation Period: Date & Time Begin: End: When Discovered: Date & Time
D. Parameters monitored:	E. Limit:	F. Actual:
G. Probable Cause of Deviation:		H. Corrective actions taken:



Ventura County  
Air Pollution  
Control District

## ANNUAL COMPLIANCE CERTIFICATION SOURCE TEST SUMMARY FORM

Period Covered by Compliance Certification: 01/01/18 (MM/DD/YY) to 12/31/18 (MM/DD/YY)

<b>A. Emission Unit Description:</b> Turbine G-01 @ 30% Load (Gas)			<b>B. Pollutant:</b> NO <sub>x</sub>
<b>C. Measured Emission Rate:</b> 2.0 ppmv @ 15% O <sub>2</sub>	<b>D. Limited Emission Rate:</b> 5 ppmv @ 15% O <sub>2</sub>	<b>E. Specific Source Test or Monitoring Record Citation:</b> AIR-x Job No. 22012	<b>F. Test Date:</b> February 19-20, 2018

<b>A. Emission Unit Description:</b> Turbine G-01 @ 30% Load (Gas)			<b>B. Pollutant:</b> NH <sub>3</sub>
<b>C. Measured Emission Rate:</b> 11.5 ppmv @ 15% O <sub>2</sub>	<b>D. Limited Emission Rate:</b> 20 ppmv @ 15% O <sub>2</sub>	<b>E. Specific Source Test or Monitoring Record Citation:</b> AIR-x Job No. 22012	<b>F. Test Date:</b> February 19-20, 2018

<b>A. Emission Unit Description:</b> Turbine G-01 @ 30% Load (Diesel)			<b>B. Pollutant:</b> NO <sub>x</sub>
<b>C. Measured Emission Rate:</b> 2.9 ppmv @ 15% O <sub>2</sub>	<b>D. Limited Emission Rate:</b> 13 ppmv @ 15% O <sub>2</sub>	<b>E. Specific Source Test or Monitoring Record Citation:</b> AIR-x Job No. 22012	<b>F. Test Date:</b> February 19-20, 2018

<b>A. Emission Unit Description:</b> Turbine G-01 @ 30% Load (Diesel)			<b>B. Pollutant:</b> NH <sub>3</sub>
<b>C. Measured Emission Rate:</b> 12.2 ppmv @ 15% O <sub>2</sub>	<b>D. Limited Emission Rate:</b> 20 ppmv @ 15% O <sub>2</sub>	<b>E. Specific Source Test or Monitoring Record Citation:</b> AIR-x Job No. 22012	<b>F. Test Date:</b> February 19-20, 2018

<b>A. Emission Unit Description:</b>			<b>B. Pollutant:</b>
<b>C. Measured Emission Rate:</b>	<b>D. Limited Emission Rate:</b>	<b>E. Specific Source Test or Monitoring Record Citation:</b>	<b>F. Test Date:</b>



Ventura County  
Air Pollution  
Control District

# ANNUAL COMPLIANCE CERTIFICATION

## SOURCE TEST SUMMARY FORM

Period Covered by Compliance Certification: 01/01/18 (MM/DD/YY) to 12/31/18 (MM/DD/YY)

A. Emission Unit Description: Turbine G-01 @ 50% Load (Gas)			B. Pollutant: NO <sub>x</sub>
C. Measured Emission Rate: 1.0 ppmv @ 15% O <sub>2</sub>	D. Limited Emission Rate: 2.5 ppmv @ 15% O <sub>2</sub>	E. Specific Source Test or Monitoring Record Citation: AIR-x Job No. 22012	F. Test Date: February 19-20, 2018

A. Emission Unit Description: Turbine G-01 @ 50% Load (Gas)			B. Pollutant: NH <sub>3</sub>
C. Measured Emission Rate: 15.8 ppmv @ 15% O <sub>2</sub>	D. Limited Emission Rate: 20 ppmv @ 15% O <sub>2</sub>	E. Specific Source Test or Monitoring Record Citation: AIR-x Job No. 22012	F. Test Date: February 19-20, 2018

A. Emission Unit Description: Turbine G-01 @ 50% Load (Diesel)			B. Pollutant: NO <sub>x</sub>
C. Measured Emission Rate: 1.4 ppmv @ 15% O <sub>2</sub>	D. Limited Emission Rate: 6.5 ppmv @ 15% O <sub>2</sub>	E. Specific Source Test or Monitoring Record Citation: AIR-x Job No. 22012	F. Test Date: February 19-20, 2018

A. Emission Unit Description: Turbine G-01 @ 50% Load (Diesel)			B. Pollutant: NH <sub>3</sub>
C. Measured Emission Rate: 9.2 ppmv @ 15% O <sub>2</sub>	D. Limited Emission Rate: 20 ppmv @ 15% O <sub>2</sub>	E. Specific Source Test or Monitoring Record Citation: AIR-x Job No. 22012	F. Test Date: February 19-20, 2018

A. Emission Unit Description:			B. Pollutant:
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test or Monitoring Record Citation:	F. Test Date:





## ANNUAL COMPLIANCE CERTIFICATION SOURCE TEST SUMMARY FORM

Period Covered by Compliance Certification: 01/01/18 (MM/DD/YY) to 12/31/18 (MM/DD/YY)

A. Emission Unit Description: Turbine G-02 @ 30% Load (Gas)			B. Pollutant: NO <sub>x</sub>
C. Measured Emission Rate: 2.8 ppmv @ 15% O <sub>2</sub>	D. Limited Emission Rate: 5 ppmv @ 15% O <sub>2</sub>	E. Specific Source Test or Monitoring Record Citation: AIR-x Job No. 22012	F. Test Date: February 19-20, 2018

A. Emission Unit Description: Turbine G-02 @ 30% Load (Gas)			B. Pollutant: NH <sub>3</sub>
C. Measured Emission Rate: 9.3 ppmv @ 15% O <sub>2</sub>	D. Limited Emission Rate: 20 ppmv @ 15% O <sub>2</sub>	E. Specific Source Test or Monitoring Record Citation: AIR-x Job No. 22012	F. Test Date: February 19-20, 2018

A. Emission Unit Description: Turbine G-02 @ 30% Load (Diesel)			B. Pollutant: NO <sub>x</sub>
C. Measured Emission Rate: 5.9 ppmv @ 15% O <sub>2</sub>	D. Limited Emission Rate: 13 ppmv @ 15% O <sub>2</sub>	E. Specific Source Test or Monitoring Record Citation: AIR-x Job No. 22012	F. Test Date: February 19-20, 2018

A. Emission Unit Description: Turbine G-02 @ 30% Load (Diesel)			B. Pollutant: NH <sub>3</sub>
C. Measured Emission Rate: 11.5 ppmv @ 15% O <sub>2</sub>	D. Limited Emission Rate: 20 ppmv @ 15% O <sub>2</sub>	E. Specific Source Test or Monitoring Record Citation: AIR-x Job No. 22012	F. Test Date: February 19-20, 2018

A. Emission Unit Description:			B. Pollutant:
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test or Monitoring Record Citation:	F. Test Date:



Ventura County  
Air Pollution  
Control District

# ANNUAL COMPLIANCE CERTIFICATION

## SOURCE TEST SUMMARY FORM

Period Covered by Compliance Certification: 01/01/18 (MM/DD/YY) to 06/30/18 (MM/DD/YY)

A. Emission Unit Description: Turbine G-02 @ 50% Load (Gas)			B. Pollutant: NO <sub>x</sub>
C. Measured Emission Rate: 1.8 ppmv @ 15% O <sub>2</sub>	D. Limited Emission Rate: 2.5 ppmv @ 15% O <sub>2</sub>	E. Specific Source Test or Monitoring Record Citation: AIR-x Job No. 22012	F. Test Date: February 19-20, 2018

A. Emission Unit Description: Turbine G-02 @ 50% Load (Gas)			B. Pollutant: NH <sub>3</sub>
C. Measured Emission Rate: 12.4 ppmv @ 15% O <sub>2</sub>	D. Limited Emission Rate: 20 ppmv @ 15% O <sub>2</sub>	E. Specific Source Test or Monitoring Record Citation: AIR-x Job No. 22012	F. Test Date: February 19-20, 2018

A. Emission Unit Description: Turbine G-02 @ 50% Load (Diesel)			B. Pollutant: NO <sub>x</sub>
C. Measured Emission Rate: 3.3 ppmv @ 15% O <sub>2</sub>	D. Limited Emission Rate: 6.5 ppmv @ 15% O <sub>2</sub>	E. Specific Source Test or Monitoring Record Citation: AIR-x Job No. 22012	F. Test Date: February 19-20, 2018

A. Emission Unit Description: Turbine G-02 @ 50% Load (Diesel)			B. Pollutant: NH <sub>3</sub>
C. Measured Emission Rate: 11.5 ppmv @ 15% O <sub>2</sub>	D. Limited Emission Rate: 20 ppmv @ 15% O <sub>2</sub>	E. Specific Source Test or Monitoring Record Citation: AIR-x Job No. 22012	F. Test Date: February 19-20, 2018

A. Emission Unit Description:			B. Pollutant:
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test or Monitoring Record Citation:	F. Test Date:



# ANNUAL COMPLIANCE CERTIFICATION

## SOURCE TEST SUMMARY FORM

Period Covered by Compliance Certification: 01/01/18 (MM/DD/YY) to 06/30/18 (MM/DD/YY)

A. Emission Unit Description: Turbine G-03 @ 30% Load (Gas)			B. Pollutant: NO <sub>x</sub>
C. Measured Emission Rate: 1.6 ppmv @ 15% O <sub>2</sub>	D. Limited Emission Rate: 5 ppmv @ 15% O <sub>2</sub>	E. Specific Source Test or Monitoring Record Citation: AIR-x Job No. 22012	F. Test Date: February 19-20, 2018

A. Emission Unit Description: Turbine G-03 @ 30% Load (Gas)			B. Pollutant: NH <sub>3</sub>
C. Measured Emission Rate: 12.8 ppmv @ 15% O <sub>2</sub>	D. Limited Emission Rate: 20 ppmv @ 15% O <sub>2</sub>	E. Specific Source Test or Monitoring Record Citation: AIR-x Job No. 22012	F. Test Date: February 19-20, 2018

A. Emission Unit Description: Turbine G-03 @ 30% Load (Diesel)			B. Pollutant: NO <sub>x</sub>
C. Measured Emission Rate: 4.9 ppmv @ 15% O <sub>2</sub>	D. Limited Emission Rate: 13 ppmv @ 15% O <sub>2</sub>	E. Specific Source Test or Monitoring Record Citation: AIR-x Job No. 22012	F. Test Date: February 19-20, 2018

A. Emission Unit Description: Turbine G-03 @ 30% Load (Diesel)			B. Pollutant: NH <sub>3</sub>
C. Measured Emission Rate: 13.5 ppmv @ 15% O <sub>2</sub>	D. Limited Emission Rate: 20 ppmv @ 15% O <sub>2</sub>	E. Specific Source Test or Monitoring Record Citation: AIR-x Job No. 22012	F. Test Date: February 19-20, 2018

A. Emission Unit Description:			B. Pollutant:
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test or Monitoring Record Citation:	F. Test Date:



## ANNUAL COMPLIANCE CERTIFICATION SOURCE TEST SUMMARY FORM

Period Covered by Compliance Certification: 01/01/18 (MM/DD/YY) to 12/31/18 (MM/DD/YY)

A. Emission Unit Description: Turbine G-03 @ 50% Load (Gas)			B. Pollutant: NO <sub>x</sub>
C. Measured Emission Rate: 1.0 ppmv @ 15% O <sub>2</sub>	D. Limited Emission Rate: 2.5 ppmv @ 15% O <sub>2</sub>	E. Specific Source Test or Monitoring Record Citation: AIR-x Job No. 22012	F. Test Date: February 19-20, 2018

A. Emission Unit Description: Turbine G-03 @ 50% Load (Gas)			B. Pollutant: NH <sub>3</sub>
C. Measured Emission Rate: 11.7 ppmv @ 15% O <sub>2</sub>	D. Limited Emission Rate: 20 ppmv @ 15% O <sub>2</sub>	E. Specific Source Test or Monitoring Record Citation: AIR-x Job No. 22012	F. Test Date: February 19-20, 2018

A. Emission Unit Description: Turbine G-03 @ 50% Load (Diesel)			B. Pollutant: NO <sub>x</sub>
C. Measured Emission Rate: 2.5 ppmv @ 15% O <sub>2</sub>	D. Limited Emission Rate: 6.5 ppmv @ 15% O <sub>2</sub>	E. Specific Source Test or Monitoring Record Citation: AIR-x Job No. 22012	F. Test Date: February 19-20, 2018

A. Emission Unit Description: Turbine G-03 @ 50% Load (Diesel)			B. Pollutant: NH <sub>3</sub>
C. Measured Emission Rate: 11.7 ppmv @ 15% O <sub>2</sub>	D. Limited Emission Rate: 20 ppmv @ 15% O <sub>2</sub>	E. Specific Source Test or Monitoring Record Citation: AIR-x Job No. 22012	F. Test Date: February 19-20, 2018

A. Emission Unit Description:			B. Pollutant:
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test or Monitoring Record Citation:	F. Test Date:









40 CFR PART 63 SUBPART ZZZZ  
MAINTENANCE PLAN

PLATFORM GAIL  
G-2 TURBINE STARTER ENGINE SERVICE  
DETROIT DIESEL, 140 HP

DATE 02/03/18  
HOURS: 692  
MECHANIC: MATT ESK

**ANNUAL SERVICE (OR 500 HOURS)<sup>A</sup>**

INSPECT/CHANGE HOSES AND BELTS:

COMMENTS: OK

CHANGE OIL & FUEL FILTERS:

COMMENTS:

CHANGE CRANK CASE OIL:

COMMENTS:

REPLACE AIR FILTERS:

COMMENTS: CLEANED OIL BATH FILTERS

**2000 HOUR SERVICE<sup>B</sup>**

INSPECT/CLEAN/CALIBRATE SPEED/TIMING SENSORS:

COMMENTS:

INSPECT/ADJUST VALVE LASH:

COMMENTS:

INSPECT/REPLACE VALVE ROTATORS:

COMMENTS:

**ADDITIONAL MAINTENANCE**

SIGNATURE MATT ESK

(A) IF 500 OPERATING HOURS ATTAINED PRIOR TO 12 MONTHS SINCE LAST SERVICE, PERFORM SERVICE AT 500 HOURS

(B) CLEAN, CALIBRATE, ADJUST, REPLACE AS NECESSARY.

40 CFR PART 63 SUBPART ZZZZ  
MAINTENANCE PLAN

PLATFORM GAIL  
G-3 TURBINE STARTER ENGINE SERVICE  
DETROIT DIESEL, 140 HP

DATE 02/16/18  
HOURS: 636  
MECHANIC: MATT ELEX

**ANNUAL SERVICE (OR 500 HOURS)<sup>A</sup>**

INSPECT/CHANGE HOSES AND BELTS:

COMMENTS: OK

CHANGE OIL & FUEL FILTERS:

COMMENTS:

CHANGE CRANK CASE OIL:

COMMENTS:

REPLACE AIR FILTERS:

COMMENTS: CLEANED OIL BATH FILTERS

**2000 HOUR SERVICE<sup>B</sup>**

INSPECT/CLEAN/CALIBRATE SPEED/TIMING SENSORS:

COMMENTS:

INSPECT/ADJUST VALVE LASH:

COMMENTS:

INSPECT/REPLACE VALVE ROTATORS:

COMMENTS:

**ADDITIONAL MAINTENANCE**

SIGNATURE MATT ELEX

(A) IF 500 OPERATING HOURS ATTAINED PRIOR TO 12 MONTHS SINCE LAST SERVICE, PERFORM SERVICE AT 500 HOURS

(B) CLEAN, CALIBRATE, ADJUST, REPLACE AS NECESSARY.

40 CFR PART 63 SUBPART ZZZZ  
MAINTENANCE PLAN

PLATFORM GAIL  
EMERGENCY GENERATOR SERVICE  
6-04

DATE 3/16/18  
HOURS: 3915.60  
MECHANIC: Kirk Hofmeister / Matt Elek

**ANNUAL SERVICE (OR 250 HOURS)<sup>A</sup>**

INSPECT/CHANGE HOSES AND BELTS:

COMMENTS: OK

CHANGE OIL & FUEL FILTERS:

COMMENTS: OK OIL FUEL

CHANGE CRANK CASE OIL:

COMMENTS: OK

REPLACE AIR FILTERS:

COMMENTS: CLEAN

**2000 HOUR SERVICE<sup>B</sup>**

INSPECT/CLEAN/CALIBRATE SPEED/TIMING SENSORS:

COMMENTS: \_\_\_\_\_

INSPECT/ADJUST VALVE LASH:

COMMENTS: \_\_\_\_\_


INSPECT/REPLACE VALVE ROTATORS:

COMMENTS: \_\_\_\_\_

**ADDITIONAL MAINTENANCE**

Changed fuel filters.

SIGNATURE



(A) IF 250 OPERATING HOURS ATTAINED PRIOR TO 12 MONTHS SINCE LAST SERVICE, PERFORM SERVICE AT 250 HOURS

(B) CLEAN, CALIBRATE, ADJUST, REPLACE AS NECESSARY.

40 CFR PART 63 SUBPART ZZZZ  
MAINTENANCE PLAN

PLATFORM GAIL  
NORTH CRANE ENGINE SERVICE  
CATERPILLER 3306, 225 HP

DATE 4/23/18  
HOURS: 803  
MECHANIC: SETH McBEATH

**ANNUAL SERVICE (OR 500 HOURS)<sup>A</sup>**

INSPECT/CHANGE HOSES AND BELTS:

COMMENTS: OK

CHANGE OIL & FUEL FILTERS:

COMMENTS:

CHANGE CRANK CASE OIL:

COMMENTS:

REPLACE AIR FILTERS: NO

COMMENTS:

**2000 HOUR SERVICE<sup>B</sup>**

INSPECT/CLEAN/CALIBRATE SPEED/TIMING SENSORS:

COMMENTS:

INSPECT/ADJUST VALVE LASH:

COMMENTS:

INSPECT/REPLACE VALVE ROTATORS:

COMMENTS:

**ADDITIONAL MAINTENANCE**

SIGNATURE SETH McBEATH

(A) IF 500 OPERATING HOURS ATTAINED PRIOR TO 12 MONTHS SINCE LAST SERVICE, PERFORM SERVICE AT 500 HOURS

(B) CLEAN, CALIBRATE, ADJUST, REPLACE AS NECESSARY.

40 CFR PART 63 SUBPART ZZZZ  
MAINTENANCE PLAN

PLATFORM GAIL  
SOUTH CRANE ENGINE SERVICE  
CATERPILLER 3412, 545 HP

DATE 5/20/18  
HOURS: 7661  
MECHANIC: SETH McBEATH

**ANNUAL SERVICE (OR 500 HOURS)<sup>A</sup>**

INSPECT/CHANGE HOSES AND BELTS:

COMMENTS: OK

CHANGE OIL & FUEL FILTERS:

COMMENTS: \_\_\_\_\_

CHANGE CRANK CASE OIL:

COMMENTS: \_\_\_\_\_

REPLACE AIR FILTERS:

COMMENTS: REPLACED INNER AIR FILTER

**2000 HOUR SERVICE<sup>B</sup>**

INSPECT/CLEAN/CALIBRATE SPEED/TIMING SENSORS:

COMMENTS: \_\_\_\_\_

INSPECT/ADJUST VALVE LASH:

COMMENTS: \_\_\_\_\_

INSPECT/REPLACE VALVE ROTATORS:

COMMENTS: \_\_\_\_\_

**ADDITIONAL MAINTENANCE**

REPLACED CRANK CASE VENT FILTER

SIGNATURE SETH McBEATH

(A) IF 500 OPERATING HOURS ATTAINED PRIOR TO 12 MONTHS SINCE LAST SERVICE, PERFORM SERVICE AT 500 HOURS

(B) CLEAN, CALIBRATE, ADJUST, REPLACE AS NECESSARY.



**40 CFR PART 63 SUBPART ZZZZ  
MAINTENANCE PLAN**

**PLATFORM GRACE  
EMERGENCY GENERATOR SERVICE  
G-02 CATERPILLAR D379, 600 HP**

DATE 10-JUN

HOURS: 2474

MECHANIC: SCOTT BING/JOHNNY BLOCK

**ANNUAL SERVICE (OR 250 HOURS)<sup>A</sup>**

INSPECT/CHANGE HOSES AND BELTS:  YES  NO

COMMENTS: \_\_\_\_\_

CHANGE OIL & FUEL FILTERS:  YES  NO

COMMENTS: \_\_\_\_\_

CHANGE CRANK CASE OIL:  YES  NO

COMMENTS: \_\_\_\_\_

REPLACE AIR FILTERS:  YES  NO

COMMENTS: \_\_\_\_\_

**2000 HOUR SERVICE<sup>B</sup>**

INSPECT/CLEAN/CALIBRATE SPEED/TIMING SENSORS:  YES  NO

COMMENTS: \_\_\_\_\_

INSPECT/ADJUST VALVE LASH:  YES  NO

COMMENTS: \_\_\_\_\_

INSPECT/REPLACE VALVE ROTATORS:  YES  NO

COMMENTS: \_\_\_\_\_

**ADDITIONAL MAINTENANCE**

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

SIGNATURE Scott Bing

(A) IF 250 OPERATING HOURS ATTAINED PRIOR TO 12 MONTHS SINCE LAST SERVICE, PERFORM SERVICE AT 250 HOURS

(B) CLEAN, CALIBRATE, ADJUST, REPLACE AS NECESSARY.

**40 CFR PART 63 SUBPART ZZZZ  
MAINTENANCE PLAN**

**PLATFORM GRACE  
EMERGENCY FIREWATER PUMP ENGINE SERVICE  
P-19 JOHN DEERE MODEL# 6359, 145 HP  
SERIAL# CD6359A750208**

DATE 10-JUN  
HOURS: 524.17  
MECHANIC: DOUG ARCHER

**ANNUAL SERVICE (OR 250 HOURS)<sup>A</sup>**

INSPECT/CHANGE HOSES AND BELTS:  YES  NO  
COMMENTS: \_\_\_\_\_  
CHANGE OIL FILTERS:  YES  NO  
COMMENTS: \_\_\_\_\_  
CHANGE CRANK CASE OIL:  YES  NO  
COMMENTS: \_\_\_\_\_  
REPLACE AIR FILTERS:  YES  NO  
COMMENTS: \_\_\_\_\_

**2000 HOUR SERVICE<sup>B</sup>**

INSPECT/CLEAN/CALIBRATE SPEED/TIMING SENSORS:  YES  NO  
COMMENTS: \_\_\_\_\_  
INSPECT/ADJUST VALVE LASH:  YES  NO  
COMMENTS: \_\_\_\_\_  
INSPECT/REPLACE VALVE ROTATORS:  YES  NO  
COMMENTS: \_\_\_\_\_

**ADDITIONAL MAINTENANCE**

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

\_\_\_\_\_  
SIGNATURE Doug Archer

(A) IF 250 OPERATING HOURS ATTAINED PRIOR TO 12 MONTHS SINCE LAST SERVICE, PERFORM SERVICE AT 250 HOURS  
(B) CLEAN, CALIBRATE, ADJUST, REPLACE AS NECESSARY.





**40 CFR PART 63 SUBPART ZZZZ  
MAINTENANCE PLAN**

**PLATFORM GRACE  
NORTH CRANE ENGINE SERVICE  
DETROIT DIESEL MODEL 8V92, 300 HP**

DATE 25-FEB-18

HOURS: 1582

MECHANIC: LARRY HAYES

**ANNUAL SERVICE (OR 500 HOURS)<sup>A</sup>**

INSPECT/CHANGE HOSES AND BELTS:

YES  NO

COMMENTS: \_\_\_\_\_

CHANGE OIL & FUEL FILTERS:

YES  NO

COMMENTS: \_\_\_\_\_

CHANGE CRANK CASE OIL:

YES  NO

COMMENTS: \_\_\_\_\_

REPLACE AIR FILTERS:

YES  NO

COMMENTS: \_\_\_\_\_

**2000 HOUR SERVICE<sup>B</sup>**

INSPECT/CLEAN/CALIBRATE SPEED/TIMING SENSORS:

YES  NO

COMMENTS: \_\_\_\_\_

INSPECT/ADJUST VALVE LASH:

YES  NO

COMMENTS: \_\_\_\_\_

INSPECT/REPLACE VALVE ROTATORS:

YES  NO

COMMENTS: \_\_\_\_\_

**ADDITIONAL MAINTENANCE**

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

SIGNATURE Larry Hayes

(A) IF 500 OPERATING HOURS ATTAINED PRIOR TO 12 MONTHS SINCE LAST SERVICE, PERFORM SERVICE AT 500 HOURS

(B) CLEAN, CALIBRATE, ADJUST, REPLACE AS NECESSARY.

40 CFR PART 63 SUBPART ZZZZ  
MAINTENANCE PLAN

PLATFORM GRACE  
SOUTH CRANE ENGINE SERVICE  
DETROIT DIESEL MODEL 8V92, 300 HP

DATE 6/12/2018

HOURS: 1594

MECHANIC: S. MARKLEIN / D. EDMONDSON

**ANNUAL SERVICE (OR 500 HOURS)<sup>A</sup>**

INSPECT/CHANGE HOSES AND BELTS: X

COMMENTS: \_\_\_\_\_

CHANGE OIL & FUEL FILTERS: X

COMMENTS: \_\_\_\_\_

CHANGE CRANK CASE OIL: X

COMMENTS: \_\_\_\_\_

REPLACE AIR FILTERS:

COMMENTS: \_\_\_\_\_

**2000 HOUR SERVICE<sup>B</sup>**

INSPECT/CLEAN/CALIBRATE SPEED/TIMING SENSORS:

COMMENTS: \_\_\_\_\_

INSPECT/ADJUST VALVE LASH:

COMMENTS: \_\_\_\_\_

INSPECT/REPLACE VALVE ROTATORS:

COMMENTS: \_\_\_\_\_

**ADDITIONAL MAINTENANCE**

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

\_\_\_\_\_  
**SIGNATURE** \_\_\_\_\_

(A) IF 500 OPERATING HOURS ATTAINED PRIOR TO 12 MONTHS SINCE LAST SERVICE, PERFORM SERVICE AT 500 HOURS

(B) CLEAN, CALIBRATE, ADJUST, REPLACE AS NECESSARY.

40 CFR PART 63 SUBPART ZZZZ  
MAINTENANCE PLAN

PLATFORM GAIL  
P-18 FIRE WATER PUMP  
481 BHP CATIPILLAR

DATE 3/18/18  
HOURS: 677  
MECHANIC: MART KLEK / KYLE HOFMEISTER

**ANNUAL SERVICE (OR 500 HOURS)<sup>A</sup>**

INSPECT/CHANGE HOSES AND BELTS: X

COMMENTS: OK

CHANGE OIL & FUEL FILTERS: X

COMMENTS: OK OIL, FUEL

CHANGE CRANK CASE OIL: X

COMMENTS: OK

REPLACE AIR FILTERS: X

COMMENTS: CLEAN-NEW

**2000 HOUR SERVICE<sup>B</sup>**

INSPECT/CLEAN/CALIBRATE SPEED/TIMING SENSORS:

COMMENTS: \_\_\_\_\_

INSPECT/ADJUST VALVE LASH:

COMMENTS: \_\_\_\_\_

INSPECT/REPLACE VALVE ROTATORS:

COMMENTS: \_\_\_\_\_

**ADDITIONAL MAINTENANCE**

LUBED FAN BEARINGS, DRIVE SHAFT U-JOINTS AND SLIP YOKE

SIGNATURE K. K. H.

(A) IF 500 OPERATING HOURS ATTAINED PRIOR TO 12 MONTHS SINCE LAST SERVICE, PERFORM SERVICE AT 500 HOURS

(B) CLEAN, CALIBRATE, ADJUST, REPLACE AS NECESSARY.



**Platform Gail**  
**PTO No. 1494 Equipment Usage**  
**Rolling 12-Months Ending:**  
**Jan-18**

Equipment	Feb-17	Mar-17	Apr-17	May-17	Jun-17	Jul-17	Aug-17	Sep-17	Oct-17	Nov-17	Dec-17	Jan-18	Monthly Units	12-Month Total	Permit Limit	12-Mo & Permit Units
Gas Consumption:																
HP Planned	2.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	164.0	MSCF/mo	0.17	N/A	MMSCF/yr
HP Pilot/Purge	92.1	92.1	92.1	92.1	92.1	92.1	92.1	92.1	92.1	92.1	92.1	92.1	MSCF/mo	1.10	N/A	MMSCF/yr
HP Planned & PIP	94.1	92.1	92.1	92.1	92.1	92.1	92.1	92.1	92.1	92.1	92.1	256.1	MSCF/mo	1.27	4.9	MMSCF/yr
HP Unplanned	346.0	21.0	148.0	0.0	183.0	233.0	48.0	100.0	560.0	1,041.0	860.0	0.0	MSCF/mo	3.53	Exempt	MMSCF/yr
LP Planned	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	0.00	N/A	MMSCF/yr
LP Pilot/Purge	144.8	144.8	144.8	144.8	144.8	144.8	144.8	144.8	144.8	144.8	144.8	144.8	MSCF/mo	1.74	N/A	MMSCF/yr
LP Planned & PIP	144.8	144.8	144.8	144.8	144.8	144.8	144.8	144.8	144.8	144.8	144.8	144.8	MSCF/mo	1.74	2.31	MMSCF/yr
LP Unplanned	240.0	14.0	241.0	173.0	136.0	140.0	185.0	474.0	2,932.0	658.0	0.0	0.0	MSCF/mo	5.19	Exempt	MMSCF/yr
Gas Consumption:																
Turbines: G1	24.2	27.6	24.9	26.4	25.4	26.4	26.7	24.8	23.6	11.4	1.3	0.0	MMSCF/mo	242.73	N/A	MMSCF/yr
G2	24.6	26.1	25.2	26.4	25.1	26.9	27.5	24.9	25.3	12.1	5.8	0.6	MMSCF/mo	252.56	N/A	MMSCF/yr
G3	23.5	27.7	26.3	26.8	25.6	26.3	26.9	23.6	24.9	18.6	6.7	13.7	MMSCF/mo	270.74	N/A	MMSCF/yr
Turbines @ all loads	72.3	83.4	76.5	79.5	75.2	79.6	81.1	73.4	73.9	42.2	13.8	14.3	MMSCF/mo	766.04	850	MMSCF/yr
Turbine@<1000 KW	0.20	0.02	0.04	0.1	0.02	0.04	0.03	0.0	0.1	7.9	13.66	14.29	MMSCF/mo	36.39	250.0	MMSCF/yr
Diesel Use:																
Turbines: G1	2.37	0.05	0.59	0.07	0.14	0.20	0.05	0.15	0.00	0.06	0.002	0.000	MGal/mo	3.69	N/A	MGal/yr
G2	2.65	0.07	0.70	0.20	0.37	0.96	0.07	0.75	0.83	0.000	0.000	0.002	MGal/mo	16.35	N/A	MGal/yr
G3	2.15	0.06	0.47	0.19	0.47	1.35	0.10	0.00	0.07	0.16	0.000	0.0023	MGal/mo	5.02	N/A	MGal/yr
Turbines @ all loads	7.2	0.2	1.8	0.5	1.0	2.5	0.2	0.9	0.2	0.2	0.2	0.2	MGal/mo	25.05	335	MGal/yr
Turbine@<1000 KW	2.19	0.11	0.97	0.26	0.28	1.13	0.11	0.19	0.27	0.11	9.75	0.0045	MGal/mo	15.37	150	MGal/yr
Back-up Generator:G4	0.46	0.24	0.32	0.40	0.31	0.65	0.00	0.70	1.01	0.25	0.42	0.33	MGal/mo	5.09	32.13	MGal/yr
North Crane	198.00	145.00	0.00	76.00	37.00	31.00	68.00	39.00	49.00	71.00	0.00	52.00	Gal/mo	766.0	N/A	Gal/yr
South Crane	0.00	488.00	570.00	495.00	291.00	415.00	331.00	309.00	527.00	348.00	508.00	287.00	Gal/mo	4,549.0	N/A	Gal/yr
Crane Total	198.00	633.00	570.00	571.00	328.00	448.00	399.00	348.00	576.00	419.00	508.00	339.00	Gal/mo	5,315	21,389	Gal/yr
Turbine Starter Engines	5.80	2.89	4.02	2.89	2.63	5.45	3.37	8.26	10.57	0.68	3.22	0.78	Hrs/mo	390.1	960	Gal/yr at 7.7 gal/hr
Boom Boat (VP)	0.80	1.40	1.00	1.00	5.90	5.90	0.40	0.70	0.50	7.20	0.60	0.50	Gal/mo	25.9	1,405	Gal/yr
P-18 -Em FW Pump	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	Hrs/mo	9.0	50	Hrs/yr
Tank Throughputs:																
V.06	46,803.0	53,471.3	48,675.6	49,260.5	46,707.0	44,298.8	45,174.9	44,080.9	47,230.0	25,277.0	0.0	0.0	Bbls/mo	450,878.9	N/A	Bbls/yr
Produced Gas	46,836.0	53,725.5	39,608.0	36,811.2	31,936.4	30,666.6	29,678.4	29,895.5	36,777.0	14,720.0	263.0	0.0	MSCF/mo	353.04	N/A	MMSCF/yr
Solvent Usage:																
Envirosol 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lbs/gal
87 RE													Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lbs/gal
Z-Sol													Gal/mo	0.00	N/A	Tons/yr ROC at 0.17 lbs/gal
Transform Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lbs/gal
Sigma Thinner 90-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lbs/gal
Sigma Thinner 91-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lbs/gal
Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lbs/gal
Solvent Total	26.96	10.13	17.60	3.33	9.99	2.20	1.13	2.25	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.89	Tons/yr ROC
Coatings Total													Gal/mo	73.81	N/A	Gal/yr
Boats:																
Crew Boat Fuel:	2,130	2,260	2,790	1,740	4,104	2,106	1,802	2,266	1,531	1,687	2,192	1,284	Gal/mo	25,952	N/A	Gal/yr
Work Boat Fuel:	2,308	2,470	3,023	3,770	650	2,262	1,953	2,467	1,659	1,828	2,374	1,402	Gal/mo	26,204	N/A	Gal/yr
Total Boats Fuel	4,438	4,750	5,813	5,510	4,754	4,368	3,755	4,733	3,190	3,515	4,566	2,686	Gal/mo	52,156	167,100	Gal/yr
Boat Emissions:																
ROC	0.07	0.08	0.10	0.09	0.08	0.07	0.06	0.06	0.05	0.06	0.06	0.04	Tons/mo	0.86	2.77	Tons/yr at 33.15 lbs/MGal
NOx	1.24	1.33	1.63	1.55	1.33	1.23	1.05	1.34	0.89	0.99	1.28	0.76	Tons/mo	14.63	46.87	Tons/yr at 561.00 lbs/MGal
PM	0.07	0.08	0.10	0.09	0.08	0.07	0.06	0.06	0.05	0.06	0.06	0.05	Tons/mo	0.87	2.80	Tons/yr at 33.50 lbs/MGal
SOx	0.02	0.02	0.02	0.02	0.02	0.02	0.01	0.02	0.01	0.01	0.02	0.01	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal
CO	0.23	0.24	0.30	0.28	0.24	0.22	0.19	0.24	0.16	0.18	0.23	0.14	Tons/mo	2.66	8.52	Tons/yr at 102.00 lbs/MGal



**Platform Gail**  
**PTO No. 1494 Equipment Usage**  
**Rolling 12-Months Ending:**  
**Feb-18**

Equipment	Mar-17	Apr-17	May-17	Jun-17	Jul-17	Aug-17	Sep-17	Oct-17	Nov-17	Dec-17	Jan-18	Feb-18	Monthly Units	12-month Total	Permit Limit	12-Mo & Permit Units																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
Gas Consumption:																	HP Planned	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	184.0	0.0	MSCF/mo	0.30	N/A	MMSCF/yr	HP Pilot/Purge	92.1	92.1	92.1	92.1	92.1	92.1	92.1	92.1	92.1	92.1	92.1	92.1	MSCF/mo	1.10	N/A	MMSCF/yr	HP Planned & P/P	92.1	92.1	92.1	92.1	92.1	92.1	92.1	92.1	92.1	92.1	256.1	214.2	MSCF/mo	1.39	4.9	MMSCF/yr	HP Unplanned	21.0	148.0	0.0	183.0	223.0	48.0	100.0	580.0	1,041.0	860.0	0.0	0.0	MSCF/mo	3.18	Exempt	MMSCF/yr	LP Planned	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	0.00	N/A	MMSCF/yr	LP Pilot/Purge	144.8	144.8	144.8	144.8	144.8	144.8	144.8	144.8	144.8	144.8	144.8	144.8	MSCF/mo	1.72	N/A	MMSCF/yr	LP Planned & P/P	144.8	144.8	144.8	144.8	144.8	144.8	144.8	144.8	144.8	144.8	144.8	144.8	MSCF/mo	1.72	2.31	MMSCF/yr	LP Unplanned	14.0	241.0	173.0	138.0	140.0	185.0	474.0	2,932.0	658.0	0.0	0.0	0.0	MSCF/mo	4.95	Exempt	MMSCF/yr	Gas Consumption:																	Turbines: G1	27.6	24.9	26.4	25.4	26.4	26.7	24.8	23.6	11.4	1.3	0.0	0.4	MMSCF/mo	218.93	N/A	MMSCF/yr	Turbines: G2	28.1	25.2	26.4	25.1	26.9	27.5	24.9	25.3	12.1	5.8	0.6	7.5	MMSCF/mo	235.44	N/A	MMSCF/yr	Turbines: G3	27.7	26.3	26.8	26.3	26.9	26.9	23.6	24.9	18.6	6.7	13.7	4.3	MMSCF/mo	251.49	N/A	MMSCF/yr	Turbines @ all loads	83.4	76.5	79.5	76.2	79.6	81.1	73.4	73.9	42.2	13.6	14.3	12.1	MMSCF/mo	705.86	850	MMSCF/yr	Turbines @ <1000 KW	0.02	0.04	0.05	0.0	0.04	0.03	0.03	0.1	7.9	13.7	14.29	11.88	MMSCF/mo	48.07	250.0	MMSCF/yr	Diesel Use:																	Turbines: G1	0.05	0.59	0.07	0.14	0.20	0.05	0.15	0.00	0.06	0.00	0.00	0.845	MGal/mo	2.16	N/A	MGal/yr	Turbines: G2	0.07	0.70	0.20	0.37	0.68	0.07	0.75	0.83	0.00	9.742	0.00	1.245	MGal/mo	14.94	N/A	MGal/yr	Turbines: G3	0.08	0.47	0.19	0.47	1.35	0.10	0.00	0.07	0.16	0.00	0.002	0.9220	MGal/mo	3.79	N/A	MGal/yr	Turbines @ all loads	0.2	1.8	0.5	1.0	2.5	0.2	0.9	0.9	0.2	9.7	0.00	3.0122	MGal/mo	20.89	335	MGal/yr	Turbines @ <1000 KW	0.11	0.97	0.26	0.26	1.13	0.11	0.19	0.27	0.11	9.75	0.00	1.0332	MGal/mo	14.21	150	MGal/yr	Back-up Generator/G4	0.24	0.32	0.40	0.31	0.65	0.00	0.70	1.01	0.25	0.42	0.33	0.23	MGal/mo	4.66	32.13	MGal/yr	North Crane	145.00	0.00	76.00	37.00	31.00	68.00	39.00	49.00	71.00	0.00	52.00	0.00	Gal/mo	568.0	N/A	Gal/yr	South Crane	468.00	570.00	495.00	291.00	415.00	331.00	309.00	527.00	348.00	508.00	287.00	0.00	Gal/mo	4,549.0	N/A	Gal/yr	Crane Total	613.00	570.00	571.00	328.00	446.00	389.00	348.00	576.00	419.00	508.00	339.00	0.00	Gal/mo	5,117	21,309	Gal/yr	Turbine Starter Engines	2.69	4.02	2.89	2.63	5.45	3.37	8.26	10.57	0.68	3.22	0.78	2.11	Hrs/mo	360.9	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	1.40	1.00	1.00	5.90	5.90	0.40	0.70	0.50	7.20	0.60	0.50	0.50	Gal/mo	25.5	1,406	Gal/yr	P-18 -Em FW Pump	1.00	1.00	1.00	0.00	1.00	1.00	1.00	1.00	1.00	1.00	0.00	3.00	Hrs/mo	11.0	50	Hrs/yr	Tank Throughputs:																	V-06	53,471.3	48,675.6	49,260.5	46,707.0	44,298.8	45,174.9	44,080.9	47,230.0	25,277.0	0.0	0.0	0.0	Bbls/mo	404,175.9	N/A	Bbls/yr	Produced Gas	53,725.5	39,608.0	36,811.2	31,938.4	30,666.6	29,678.4	29,685.5	36,777.0	14,720.0	263.0	0.0	0.0	MSCF/mo	304.10	N/A	MMSCF/yr	Solvent Usage																	Envirosol 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal	87 RE													Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lb/gal	Z-Sol													Gal/mo	0.00	N/A	Tons/yr ROC at 0.17 lb/gal	Transbeam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal	Sigma Thinner 80-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal	Sigma Thinner 91-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal	Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal	Solvent Total	10.13	17.80	3.33	9.99	2.20	1.13	2.25	0.00	0.00	0.00	0.00	0.00	Gal/mo	46.83	9.39	Tons/yr ROC	Coatings Total																	Boats:																	Crew Boat Fuel:	2,280	2,790	1,740	4,104	2,106	1,802	2,266	1,531	1,687	2,192	1,284	1,352	Gal/mo	25,174	N/A	Gal/yr	Work Boat Fuel:	2,470	3,023	3,770	650	2,282	1,953	2,487	1,659	1,828	2,374	1,402	1,465	Gal/mo	25,361	N/A	Gal/yr	Total Boats Fuel	4,750	5,813	5,510	4,754	4,388	3,755	4,753	3,190	3,515	4,566	2,686	2,818	Gal/mo	50,536	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.10	0.09	0.08	0.07	0.06	0.08	0.05	0.06	0.08	0.04	0.05	Tons/mo	0.84	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.33	1.63	1.55	1.33	1.23	1.05	1.34	0.89	0.99	1.28	0.76	0.79	Tons/mo	14.19	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.10	0.09	0.08	0.07	0.06	0.08	0.05	0.06	0.08	0.05	0.05	Tons/mo	0.85	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.02	0.02	0.02	0.02	0.01	0.02	0.01	0.01	0.02	0.01	0.01	Tons/mo	0.19	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.30	0.28	0.24	0.22	0.19	0.24	0.18	0.18	0.23	0.14	0.14	Tons/mo	2.98	8.52	Tons/yr at 102.00 lbs/MGal
HP Planned	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	184.0	0.0	MSCF/mo	0.30	N/A	MMSCF/yr																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
HP Pilot/Purge	92.1	92.1	92.1	92.1	92.1	92.1	92.1	92.1	92.1	92.1	92.1	92.1	MSCF/mo	1.10	N/A	MMSCF/yr																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
HP Planned & P/P	92.1	92.1	92.1	92.1	92.1	92.1	92.1	92.1	92.1	92.1	256.1	214.2	MSCF/mo	1.39	4.9	MMSCF/yr																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
HP Unplanned	21.0	148.0	0.0	183.0	223.0	48.0	100.0	580.0	1,041.0	860.0	0.0	0.0	MSCF/mo	3.18	Exempt	MMSCF/yr																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
LP Planned	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	0.00	N/A	MMSCF/yr																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
LP Pilot/Purge	144.8	144.8	144.8	144.8	144.8	144.8	144.8	144.8	144.8	144.8	144.8	144.8	MSCF/mo	1.72	N/A	MMSCF/yr																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
LP Planned & P/P	144.8	144.8	144.8	144.8	144.8	144.8	144.8	144.8	144.8	144.8	144.8	144.8	MSCF/mo	1.72	2.31	MMSCF/yr																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
LP Unplanned	14.0	241.0	173.0	138.0	140.0	185.0	474.0	2,932.0	658.0	0.0	0.0	0.0	MSCF/mo	4.95	Exempt	MMSCF/yr																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
Gas Consumption:																	Turbines: G1	27.6	24.9	26.4	25.4	26.4	26.7	24.8	23.6	11.4	1.3	0.0	0.4	MMSCF/mo	218.93	N/A	MMSCF/yr	Turbines: G2	28.1	25.2	26.4	25.1	26.9	27.5	24.9	25.3	12.1	5.8	0.6	7.5	MMSCF/mo	235.44	N/A	MMSCF/yr	Turbines: G3	27.7	26.3	26.8	26.3	26.9	26.9	23.6	24.9	18.6	6.7	13.7	4.3	MMSCF/mo	251.49	N/A	MMSCF/yr	Turbines @ all loads	83.4	76.5	79.5	76.2	79.6	81.1	73.4	73.9	42.2	13.6	14.3	12.1	MMSCF/mo	705.86	850	MMSCF/yr	Turbines @ <1000 KW	0.02	0.04	0.05	0.0	0.04	0.03	0.03	0.1	7.9	13.7	14.29	11.88	MMSCF/mo	48.07	250.0	MMSCF/yr	Diesel Use:																	Turbines: G1	0.05	0.59	0.07	0.14	0.20	0.05	0.15	0.00	0.06	0.00	0.00	0.845	MGal/mo	2.16	N/A	MGal/yr	Turbines: G2	0.07	0.70	0.20	0.37	0.68	0.07	0.75	0.83	0.00	9.742	0.00	1.245	MGal/mo	14.94	N/A	MGal/yr	Turbines: G3	0.08	0.47	0.19	0.47	1.35	0.10	0.00	0.07	0.16	0.00	0.002	0.9220	MGal/mo	3.79	N/A	MGal/yr	Turbines @ all loads	0.2	1.8	0.5	1.0	2.5	0.2	0.9	0.9	0.2	9.7	0.00	3.0122	MGal/mo	20.89	335	MGal/yr	Turbines @ <1000 KW	0.11	0.97	0.26	0.26	1.13	0.11	0.19	0.27	0.11	9.75	0.00	1.0332	MGal/mo	14.21	150	MGal/yr	Back-up Generator/G4	0.24	0.32	0.40	0.31	0.65	0.00	0.70	1.01	0.25	0.42	0.33	0.23	MGal/mo	4.66	32.13	MGal/yr	North Crane	145.00	0.00	76.00	37.00	31.00	68.00	39.00	49.00	71.00	0.00	52.00	0.00	Gal/mo	568.0	N/A	Gal/yr	South Crane	468.00	570.00	495.00	291.00	415.00	331.00	309.00	527.00	348.00	508.00	287.00	0.00	Gal/mo	4,549.0	N/A	Gal/yr	Crane Total	613.00	570.00	571.00	328.00	446.00	389.00	348.00	576.00	419.00	508.00	339.00	0.00	Gal/mo	5,117	21,309	Gal/yr	Turbine Starter Engines	2.69	4.02	2.89	2.63	5.45	3.37	8.26	10.57	0.68	3.22	0.78	2.11	Hrs/mo	360.9	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	1.40	1.00	1.00	5.90	5.90	0.40	0.70	0.50	7.20	0.60	0.50	0.50	Gal/mo	25.5	1,406	Gal/yr	P-18 -Em FW Pump	1.00	1.00	1.00	0.00	1.00	1.00	1.00	1.00	1.00	1.00	0.00	3.00	Hrs/mo	11.0	50	Hrs/yr	Tank Throughputs:																	V-06	53,471.3	48,675.6	49,260.5	46,707.0	44,298.8	45,174.9	44,080.9	47,230.0	25,277.0	0.0	0.0	0.0	Bbls/mo	404,175.9	N/A	Bbls/yr	Produced Gas	53,725.5	39,608.0	36,811.2	31,938.4	30,666.6	29,678.4	29,685.5	36,777.0	14,720.0	263.0	0.0	0.0	MSCF/mo	304.10	N/A	MMSCF/yr	Solvent Usage																	Envirosol 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal	87 RE													Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lb/gal	Z-Sol													Gal/mo	0.00	N/A	Tons/yr ROC at 0.17 lb/gal	Transbeam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal	Sigma Thinner 80-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal	Sigma Thinner 91-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal	Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal	Solvent Total	10.13	17.80	3.33	9.99	2.20	1.13	2.25	0.00	0.00	0.00	0.00	0.00	Gal/mo	46.83	9.39	Tons/yr ROC	Coatings Total																	Boats:																	Crew Boat Fuel:	2,280	2,790	1,740	4,104	2,106	1,802	2,266	1,531	1,687	2,192	1,284	1,352	Gal/mo	25,174	N/A	Gal/yr	Work Boat Fuel:	2,470	3,023	3,770	650	2,282	1,953	2,487	1,659	1,828	2,374	1,402	1,465	Gal/mo	25,361	N/A	Gal/yr	Total Boats Fuel	4,750	5,813	5,510	4,754	4,388	3,755	4,753	3,190	3,515	4,566	2,686	2,818	Gal/mo	50,536	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.10	0.09	0.08	0.07	0.06	0.08	0.05	0.06	0.08	0.04	0.05	Tons/mo	0.84	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.33	1.63	1.55	1.33	1.23	1.05	1.34	0.89	0.99	1.28	0.76	0.79	Tons/mo	14.19	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.10	0.09	0.08	0.07	0.06	0.08	0.05	0.06	0.08	0.05	0.05	Tons/mo	0.85	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.02	0.02	0.02	0.02	0.01	0.02	0.01	0.01	0.02	0.01	0.01	Tons/mo	0.19	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.30	0.28	0.24	0.22	0.19	0.24	0.18	0.18	0.23	0.14	0.14	Tons/mo	2.98	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																									
Turbines: G1	27.6	24.9	26.4	25.4	26.4	26.7	24.8	23.6	11.4	1.3	0.0	0.4	MMSCF/mo	218.93	N/A	MMSCF/yr																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
Turbines: G2	28.1	25.2	26.4	25.1	26.9	27.5	24.9	25.3	12.1	5.8	0.6	7.5	MMSCF/mo	235.44	N/A	MMSCF/yr																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
Turbines: G3	27.7	26.3	26.8	26.3	26.9	26.9	23.6	24.9	18.6	6.7	13.7	4.3	MMSCF/mo	251.49	N/A	MMSCF/yr																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
Turbines @ all loads	83.4	76.5	79.5	76.2	79.6	81.1	73.4	73.9	42.2	13.6	14.3	12.1	MMSCF/mo	705.86	850	MMSCF/yr																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
Turbines @ <1000 KW	0.02	0.04	0.05	0.0	0.04	0.03	0.03	0.1	7.9	13.7	14.29	11.88	MMSCF/mo	48.07	250.0	MMSCF/yr																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
Diesel Use:																	Turbines: G1	0.05	0.59	0.07	0.14	0.20	0.05	0.15	0.00	0.06	0.00	0.00	0.845	MGal/mo	2.16	N/A	MGal/yr	Turbines: G2	0.07	0.70	0.20	0.37	0.68	0.07	0.75	0.83	0.00	9.742	0.00	1.245	MGal/mo	14.94	N/A	MGal/yr	Turbines: G3	0.08	0.47	0.19	0.47	1.35	0.10	0.00	0.07	0.16	0.00	0.002	0.9220	MGal/mo	3.79	N/A	MGal/yr	Turbines @ all loads	0.2	1.8	0.5	1.0	2.5	0.2	0.9	0.9	0.2	9.7	0.00	3.0122	MGal/mo	20.89	335	MGal/yr	Turbines @ <1000 KW	0.11	0.97	0.26	0.26	1.13	0.11	0.19	0.27	0.11	9.75	0.00	1.0332	MGal/mo	14.21	150	MGal/yr	Back-up Generator/G4	0.24	0.32	0.40	0.31	0.65	0.00	0.70	1.01	0.25	0.42	0.33	0.23	MGal/mo	4.66	32.13	MGal/yr	North Crane	145.00	0.00	76.00	37.00	31.00	68.00	39.00	49.00	71.00	0.00	52.00	0.00	Gal/mo	568.0	N/A	Gal/yr	South Crane	468.00	570.00	495.00	291.00	415.00	331.00	309.00	527.00	348.00	508.00	287.00	0.00	Gal/mo	4,549.0	N/A	Gal/yr	Crane Total	613.00	570.00	571.00	328.00	446.00	389.00	348.00	576.00	419.00	508.00	339.00	0.00	Gal/mo	5,117	21,309	Gal/yr	Turbine Starter Engines	2.69	4.02	2.89	2.63	5.45	3.37	8.26	10.57	0.68	3.22	0.78	2.11	Hrs/mo	360.9	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	1.40	1.00	1.00	5.90	5.90	0.40	0.70	0.50	7.20	0.60	0.50	0.50	Gal/mo	25.5	1,406	Gal/yr	P-18 -Em FW Pump	1.00	1.00	1.00	0.00	1.00	1.00	1.00	1.00	1.00	1.00	0.00	3.00	Hrs/mo	11.0	50	Hrs/yr	Tank Throughputs:																	V-06	53,471.3	48,675.6	49,260.5	46,707.0	44,298.8	45,174.9	44,080.9	47,230.0	25,277.0	0.0	0.0	0.0	Bbls/mo	404,175.9	N/A	Bbls/yr	Produced Gas	53,725.5	39,608.0	36,811.2	31,938.4	30,666.6	29,678.4	29,685.5	36,777.0	14,720.0	263.0	0.0	0.0	MSCF/mo	304.10	N/A	MMSCF/yr	Solvent Usage																	Envirosol 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal	87 RE													Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lb/gal	Z-Sol													Gal/mo	0.00	N/A	Tons/yr ROC at 0.17 lb/gal	Transbeam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal	Sigma Thinner 80-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal	Sigma Thinner 91-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal	Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal	Solvent Total	10.13	17.80	3.33	9.99	2.20	1.13	2.25	0.00	0.00	0.00	0.00	0.00	Gal/mo	46.83	9.39	Tons/yr ROC	Coatings Total																	Boats:																	Crew Boat Fuel:	2,280	2,790	1,740	4,104	2,106	1,802	2,266	1,531	1,687	2,192	1,284	1,352	Gal/mo	25,174	N/A	Gal/yr	Work Boat Fuel:	2,470	3,023	3,770	650	2,282	1,953	2,487	1,659	1,828	2,374	1,402	1,465	Gal/mo	25,361	N/A	Gal/yr	Total Boats Fuel	4,750	5,813	5,510	4,754	4,388	3,755	4,753	3,190	3,515	4,566	2,686	2,818	Gal/mo	50,536	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.10	0.09	0.08	0.07	0.06	0.08	0.05	0.06	0.08	0.04	0.05	Tons/mo	0.84	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.33	1.63	1.55	1.33	1.23	1.05	1.34	0.89	0.99	1.28	0.76	0.79	Tons/mo	14.19	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.10	0.09	0.08	0.07	0.06	0.08	0.05	0.06	0.08	0.05	0.05	Tons/mo	0.85	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.02	0.02	0.02	0.02	0.01	0.02	0.01	0.01	0.02	0.01	0.01	Tons/mo	0.19	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.30	0.28	0.24	0.22	0.19	0.24	0.18	0.18	0.23	0.14	0.14	Tons/mo	2.98	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																															
Turbines: G1	0.05	0.59	0.07	0.14	0.20	0.05	0.15	0.00	0.06	0.00	0.00	0.845	MGal/mo	2.16	N/A	MGal/yr																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
Turbines: G2	0.07	0.70	0.20	0.37	0.68	0.07	0.75	0.83	0.00	9.742	0.00	1.245	MGal/mo	14.94	N/A	MGal/yr																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
Turbines: G3	0.08	0.47	0.19	0.47	1.35	0.10	0.00	0.07	0.16	0.00	0.002	0.9220	MGal/mo	3.79	N/A	MGal/yr																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
Turbines @ all loads	0.2	1.8	0.5	1.0	2.5	0.2	0.9	0.9	0.2	9.7	0.00	3.0122	MGal/mo	20.89	335	MGal/yr																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
Turbines @ <1000 KW	0.11	0.97	0.26	0.26	1.13	0.11	0.19	0.27	0.11	9.75	0.00	1.0332	MGal/mo	14.21	150	MGal/yr																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
Back-up Generator/G4	0.24	0.32	0.40	0.31	0.65	0.00	0.70	1.01	0.25	0.42	0.33	0.23	MGal/mo	4.66	32.13	MGal/yr																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
North Crane	145.00	0.00	76.00	37.00	31.00	68.00	39.00	49.00	71.00	0.00	52.00	0.00	Gal/mo	568.0	N/A	Gal/yr																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
South Crane	468.00	570.00	495.00	291.00	415.00	331.00	309.00	527.00	348.00	508.00	287.00	0.00	Gal/mo	4,549.0	N/A	Gal/yr																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
Crane Total	613.00	570.00	571.00	328.00	446.00	389.00	348.00	576.00	419.00	508.00	339.00	0.00	Gal/mo	5,117	21,309	Gal/yr																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
Turbine Starter Engines	2.69	4.02	2.89	2.63	5.45	3.37	8.26	10.57	0.68	3.22	0.78	2.11	Hrs/mo	360.9	960	Gal/yr at 7.7 gal/hr																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
Boom Boat (VP)	1.40	1.00	1.00	5.90	5.90	0.40	0.70	0.50	7.20	0.60	0.50	0.50	Gal/mo	25.5	1,406	Gal/yr																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
P-18 -Em FW Pump	1.00	1.00	1.00	0.00	1.00	1.00	1.00	1.00	1.00	1.00	0.00	3.00	Hrs/mo	11.0	50	Hrs/yr																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
Tank Throughputs:																	V-06	53,471.3	48,675.6	49,260.5	46,707.0	44,298.8	45,174.9	44,080.9	47,230.0	25,277.0	0.0	0.0	0.0	Bbls/mo	404,175.9	N/A	Bbls/yr	Produced Gas	53,725.5	39,608.0	36,811.2	31,938.4	30,666.6	29,678.4	29,685.5	36,777.0	14,720.0	263.0	0.0	0.0	MSCF/mo	304.10	N/A	MMSCF/yr	Solvent Usage																	Envirosol 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal	87 RE													Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lb/gal	Z-Sol													Gal/mo	0.00	N/A	Tons/yr ROC at 0.17 lb/gal	Transbeam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal	Sigma Thinner 80-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal	Sigma Thinner 91-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal	Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal	Solvent Total	10.13	17.80	3.33	9.99	2.20	1.13	2.25	0.00	0.00	0.00	0.00	0.00	Gal/mo	46.83	9.39	Tons/yr ROC	Coatings Total																	Boats:																	Crew Boat Fuel:	2,280	2,790	1,740	4,104	2,106	1,802	2,266	1,531	1,687	2,192	1,284	1,352	Gal/mo	25,174	N/A	Gal/yr	Work Boat Fuel:	2,470	3,023	3,770	650	2,282	1,953	2,487	1,659	1,828	2,374	1,402	1,465	Gal/mo	25,361	N/A	Gal/yr	Total Boats Fuel	4,750	5,813	5,510	4,754	4,388	3,755	4,753	3,190	3,515	4,566	2,686	2,818	Gal/mo	50,536	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.10	0.09	0.08	0.07	0.06	0.08	0.05	0.06	0.08	0.04	0.05	Tons/mo	0.84	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.33	1.63	1.55	1.33	1.23	1.05	1.34	0.89	0.99	1.28	0.76	0.79	Tons/mo	14.19	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.10	0.09	0.08	0.07	0.06	0.08	0.05	0.06	0.08	0.05	0.05	Tons/mo	0.85	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.02	0.02	0.02	0.02	0.01	0.02	0.01	0.01	0.02	0.01	0.01	Tons/mo	0.19	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.30	0.28	0.24	0.22	0.19	0.24	0.18	0.18	0.23	0.14	0.14	Tons/mo	2.98	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																												
V-06	53,471.3	48,675.6	49,260.5	46,707.0	44,298.8	45,174.9	44,080.9	47,230.0	25,277.0	0.0	0.0	0.0	Bbls/mo	404,175.9	N/A	Bbls/yr																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
Produced Gas	53,725.5	39,608.0	36,811.2	31,938.4	30,666.6	29,678.4	29,685.5	36,777.0	14,720.0	263.0	0.0	0.0	MSCF/mo	304.10	N/A	MMSCF/yr																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
Solvent Usage																	Envirosol 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal	87 RE													Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lb/gal	Z-Sol													Gal/mo	0.00	N/A	Tons/yr ROC at 0.17 lb/gal	Transbeam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal	Sigma Thinner 80-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal	Sigma Thinner 91-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal	Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal	Solvent Total	10.13	17.80	3.33	9.99	2.20	1.13	2.25	0.00	0.00	0.00	0.00	0.00	Gal/mo	46.83	9.39	Tons/yr ROC	Coatings Total																	Boats:																	Crew Boat Fuel:	2,280	2,790	1,740	4,104	2,106	1,802	2,266	1,531	1,687	2,192	1,284	1,352	Gal/mo	25,174	N/A	Gal/yr	Work Boat Fuel:	2,470	3,023	3,770	650	2,282	1,953	2,487	1,659	1,828	2,374	1,402	1,465	Gal/mo	25,361	N/A	Gal/yr	Total Boats Fuel	4,750	5,813	5,510	4,754	4,388	3,755	4,753	3,190	3,515	4,566	2,686	2,818	Gal/mo	50,536	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.10	0.09	0.08	0.07	0.06	0.08	0.05	0.06	0.08	0.04	0.05	Tons/mo	0.84	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.33	1.63	1.55	1.33	1.23	1.05	1.34	0.89	0.99	1.28	0.76	0.79	Tons/mo	14.19	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.10	0.09	0.08	0.07	0.06	0.08	0.05	0.06	0.08	0.05	0.05	Tons/mo	0.85	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.02	0.02	0.02	0.02	0.01	0.02	0.01	0.01	0.02	0.01	0.01	Tons/mo	0.19	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.30	0.28	0.24	0.22	0.19	0.24	0.18	0.18	0.23	0.14	0.14	Tons/mo	2.98	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																															
Envirosol 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
87 RE													Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lb/gal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
Z-Sol													Gal/mo	0.00	N/A	Tons/yr ROC at 0.17 lb/gal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
Transbeam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
Sigma Thinner 80-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
Sigma Thinner 91-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
Solvent Total	10.13	17.80	3.33	9.99	2.20	1.13	2.25	0.00	0.00	0.00	0.00	0.00	Gal/mo	46.83	9.39	Tons/yr ROC																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
Coatings Total																	Boats:																	Crew Boat Fuel:	2,280	2,790	1,740	4,104	2,106	1,802	2,266	1,531	1,687	2,192	1,284	1,352	Gal/mo	25,174	N/A	Gal/yr	Work Boat Fuel:	2,470	3,023	3,770	650	2,282	1,953	2,487	1,659	1,828	2,374	1,402	1,465	Gal/mo	25,361	N/A	Gal/yr	Total Boats Fuel	4,750	5,813	5,510	4,754	4,388	3,755	4,753	3,190	3,515	4,566	2,686	2,818	Gal/mo	50,536	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.10	0.09	0.08	0.07	0.06	0.08	0.05	0.06	0.08	0.04	0.05	Tons/mo	0.84	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.33	1.63	1.55	1.33	1.23	1.05	1.34	0.89	0.99	1.28	0.76	0.79	Tons/mo	14.19	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.10	0.09	0.08	0.07	0.06	0.08	0.05	0.06	0.08	0.05	0.05	Tons/mo	0.85	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.02	0.02	0.02	0.02	0.01	0.02	0.01	0.01	0.02	0.01	0.01	Tons/mo	0.19	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.30	0.28	0.24	0.22	0.19	0.24	0.18	0.18	0.23	0.14	0.14	Tons/mo	2.98	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																								
Boats:																	Crew Boat Fuel:	2,280	2,790	1,740	4,104	2,106	1,802	2,266	1,531	1,687	2,192	1,284	1,352	Gal/mo	25,174	N/A	Gal/yr	Work Boat Fuel:	2,470	3,023	3,770	650	2,282	1,953	2,487	1,659	1,828	2,374	1,402	1,465	Gal/mo	25,361	N/A	Gal/yr	Total Boats Fuel	4,750	5,813	5,510	4,754	4,388	3,755	4,753	3,190	3,515	4,566	2,686	2,818	Gal/mo	50,536	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.10	0.09	0.08	0.07	0.06	0.08	0.05	0.06	0.08	0.04	0.05	Tons/mo	0.84	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.33	1.63	1.55	1.33	1.23	1.05	1.34	0.89	0.99	1.28	0.76	0.79	Tons/mo	14.19	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.10	0.09	0.08	0.07	0.06	0.08	0.05	0.06	0.08	0.05	0.05	Tons/mo	0.85	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.02	0.02	0.02	0.02	0.01	0.02	0.01	0.01	0.02	0.01	0.01	Tons/mo	0.19	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.30	0.28	0.24	0.22	0.19	0.24	0.18	0.18	0.23	0.14	0.14	Tons/mo	2.98	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																									
Crew Boat Fuel:	2,280	2,790	1,740	4,104	2,106	1,802	2,266	1,531	1,687	2,192	1,284	1,352	Gal/mo	25,174	N/A	Gal/yr																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
Work Boat Fuel:	2,470	3,023	3,770	650	2,282	1,953	2,487	1,659	1,828	2,374	1,402	1,465	Gal/mo	25,361	N/A	Gal/yr																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
Total Boats Fuel	4,750	5,813	5,510	4,754	4,388	3,755	4,753	3,190	3,515	4,566	2,686	2,818	Gal/mo	50,536	167,100	Gal/yr																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
Boat Emissions																	ROC	0.08	0.10	0.09	0.08	0.07	0.06	0.08	0.05	0.06	0.08	0.04	0.05	Tons/mo	0.84	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.33	1.63	1.55	1.33	1.23	1.05	1.34	0.89	0.99	1.28	0.76	0.79	Tons/mo	14.19	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.10	0.09	0.08	0.07	0.06	0.08	0.05	0.06	0.08	0.05	0.05	Tons/mo	0.85	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.02	0.02	0.02	0.02	0.01	0.02	0.01	0.01	0.02	0.01	0.01	Tons/mo	0.19	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.30	0.28	0.24	0.22	0.19	0.24	0.18	0.18	0.23	0.14	0.14	Tons/mo	2.98	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																													
ROC	0.08	0.10	0.09	0.08	0.07	0.06	0.08	0.05	0.06	0.08	0.04	0.05	Tons/mo	0.84	2.77	Tons/yr at 33.15 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
NOx	1.33	1.63	1.55	1.33	1.23	1.05	1.34	0.89	0.99	1.28	0.76	0.79	Tons/mo	14.19	46.87	Tons/yr at 561.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
PM	0.06	0.10	0.09	0.08	0.07	0.06	0.08	0.05	0.06	0.08	0.05	0.05	Tons/mo	0.85	2.80	Tons/yr at 33.50 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
SOx	0.02	0.02	0.02	0.02	0.02	0.01	0.02	0.01	0.01	0.02	0.01	0.01	Tons/mo	0.19	0.63	Tons/yr at 7.50 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
CO	0.24	0.30	0.28	0.24	0.22	0.19	0.24	0.18	0.18	0.23	0.14	0.14	Tons/mo	2.98	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		



**Platform Gail**  
**PTO No. 1494 Equipment Usage**  
**Rolling 12-Months Ending:**  
**Mar-18**

Equipment	Apr-17	May-17	Jun-17	Jul-17	Aug-17	Sep-17	Oct-17	Nov-17	Dec-17	Jan-18	Feb-18	Mar-18	Monthly Units	12-month Total	Permit Limit	12-Mo & Permit Units
Gas Consumption:																
HP Planned	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	164.0	131.0	0.0	MSCF/mo	0.30	N/A	MMSCF/yr
HP Pload/Purge	92.1	92.1	92.1	92.1	92.1	92.1	92.1	92.1	92.1	92.1	92.1	92.1	MSCF/mo	1.10	N/A	MMSCF/yr
<b>HP Planned &amp; PIP</b>	<b>92.1</b>	<b>92.1</b>	<b>92.1</b>	<b>92.1</b>	<b>92.1</b>	<b>92.1</b>	<b>92.1</b>	<b>92.1</b>	<b>92.1</b>	<b>256.1</b>	<b>214.2</b>	<b>92.1</b>	<b>MSCF/mo</b>	<b>1.39</b>	<b>4.9</b>	<b>MMSCF/yr</b>
HP Unplanned	148.0	0.0	183.0	223.0	46.0	100.0	560.0	1,041.0	880.0	0.0	0.0	0.0	MSCF/mo	3.16	Exempt	MMSCF/yr
LP Planned	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	0.00	N/A	MMSCF/yr
LP Pload/Purge	144.8	144.8	144.8	144.8	144.8	144.8	144.8	144.8	144.8	144.8	130.8	144.8	MSCF/mo	1.72	N/A	MMSCF/yr
<b>LP Planned &amp; PIP</b>	<b>144.8</b>	<b>144.8</b>	<b>144.8</b>	<b>144.8</b>	<b>144.8</b>	<b>144.8</b>	<b>144.8</b>	<b>144.8</b>	<b>144.8</b>	<b>144.8</b>	<b>130.8</b>	<b>144.8</b>	<b>MSCF/mo</b>	<b>1.72</b>	<b>2.31</b>	<b>MMSCF/yr</b>
LP Unplanned	241.0	173.0	136.0	140.0	165.0	474.0	2,932.0	656.0	0.0	0.0	0.0	0.0	MSCF/mo	4.64	Exempt	MMSCF/yr
Gas Consumption:																
Turbines: G1	24.9	25.4	25.4	26.4	26.7	24.8	23.6	11.4	1.3	0.0	0.4	12.3	MMSCF/mo	203.57	N/A	MMSCF/yr
Turbines: G2	25.2	26.4	25.1	26.9	27.5	24.9	25.3	12.1	5.8	0.6	7.5	0.0	MMSCF/mo	207.36	N/A	MMSCF/yr
Turbines: G3	26.3	26.8	26.8	26.3	26.9	23.6	24.9	18.6	6.7	13.7	4.3	1.1	MMSCF/mo	224.83	N/A	MMSCF/yr
<b>Turbines @ all loads</b>	<b>76.5</b>	<b>79.5</b>	<b>76.2</b>	<b>76.2</b>	<b>81.1</b>	<b>73.4</b>	<b>73.9</b>	<b>42.2</b>	<b>13.8</b>	<b>14.3</b>	<b>12.1</b>	<b>13.3</b>	<b>MMSCF/mo</b>	<b>635.76</b>	<b>850</b>	<b>MMSCF/yr</b>
Turbine@<1000 KW	0.04	0.05	0.02	0.0	0.03	0.03	0.06	7.9	13.7	14.3	11.88	13.33	MMSCF/mo	61.38	250.0	MMSCF/yr
Diesel Use:																
Turbines: G1	0.59	0.07	0.14	0.20	0.05	0.15	0.00	0.06	0.00	0.00	0.845	0.008	MGal/mo	2.12	N/A	MGal/yr
Turbines: G2	0.70	0.20	0.37	0.96	0.07	0.75	0.83	0.00	9.74	0.002	1.25	0.000	MGal/mo	14.87	N/A	MGal/yr
Turbines: G3	0.47	0.19	0.47	1.35	0.10	0.00	0.07	0.16	0.00	0.00	0.922	0.000	MGal/mo	3.73	N/A	MGal/yr
<b>Turbines @ all loads</b>	<b>1.8</b>	<b>0.5</b>	<b>1.0</b>	<b>2.5</b>	<b>0.2</b>	<b>0.9</b>	<b>0.2</b>	<b>0.9</b>	<b>0.0</b>	<b>0.0</b>	<b>3.0</b>	<b>0.0079</b>	<b>MGal/mo</b>	<b>20.71</b>	<b>335</b>	<b>MGal/yr</b>
Turbine@<1000 KW	0.97	0.26	0.26	1.13	0.11	0.19	0.27	0.11	9.75	0.00	1.03	0.0070	MGal/mo	14.11	150	MGal/yr
Back-up Generator:G4	0.32	0.40	0.31	0.65	0.00	0.70	1.01	0.25	0.42	0.33	0.23	0.30	MGal/mo	4.92	32.13	MGal/yr
North Crane	0.00	76.00	37.00	31.00	68.00	39.00	49.00	71.00	0.00	52.00	0.00	59.00	Gal/mo	482.0	N/A	Gal/yr
South Crane	570.00	485.00	291.00	415.00	331.00	309.00	527.00	348.00	508.00	287.00	0.00	151.00	Gal/mo	4,232.0	N/A	Gal/yr
<b>Crane Total</b>	<b>570.00</b>	<b>571.00</b>	<b>328.00</b>	<b>448.00</b>	<b>399.00</b>	<b>348.00</b>	<b>576.00</b>	<b>419.00</b>	<b>508.00</b>	<b>339.00</b>	<b>0.00</b>	<b>210.00</b>	<b>Gal/mo</b>	<b>4,714</b>	<b>21,339</b>	<b>Gal/yr</b>
Turbine Starter Engines	4.02	2.89	2.63	5.45	3.37	8.26	10.57	0.88	3.22	0.78	2.11	0.17	Hrs/mo	340.0	960	Gal/yr at 7.7 gal/hr
Boom Boat (VP)	1.00	1.00	5.90	5.90	0.40	0.70	0.50	7.20	0.80	0.50	0.50	2.00	Gal/mo	26.2	1,406	Gal/yr
<b>P-18-Em FW Pump</b>	<b>1.00</b>	<b>1.00</b>	<b>0.00</b>	<b>1.00</b>	<b>1.00</b>	<b>1.00</b>	<b>1.00</b>	<b>0.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>Hrs/mo</b>	<b>11.0</b>	<b>50</b>	<b>Hrs/yr</b>
Tank Throughputs:																
V.08	48,675.6	49,260.5	46,707.0	44,298.8	45,174.9	44,090.9	47,230.0	25,277.0	0.0	0.0	0.0	0.0	Bbls/mo	350,704.6	N/A	Bbls/yr
Produced Gas	39,608.0	36,811.2	31,938.4	30,666.6	29,676.4	29,885.5	36,777.0	14,720.0	263.0	0.0	0.0	0.0	MSCF/mo	250.38	N/A	MMSCF/yr
Solvent Usage:																
Envirosol 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal
87 RB	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lb/gal
Z-Sol	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 0.17 lb/gal
Transform Plus	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal
Sigma Thinner 90-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal
Sigma Thinner 91-57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal
Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal
<b>Solvent Total</b>	<b>17.80</b>	<b>3.33</b>	<b>9.99</b>	<b>2.20</b>	<b>1.13</b>	<b>2.25</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>9.59</b>	<b>Tons/yr ROC</b>
Coatings Total	2,780	1,740	4,104	2,106	1,602	2,298	1,531	1,687	2,192	1,294	1,352	1,968	Gal/mo	24,860	N/A	Gal/yr
Crew Boat Fuel:	3,023	3,770	650	2,282	1,953	2,487	1,659	1,828	2,374	1,402	1,455	2,129	Gal/mo	25,020	N/A	Gal/yr
<b>Total Boats Fuel</b>	<b>5,813</b>	<b>5,510</b>	<b>4,754</b>	<b>4,388</b>	<b>3,755</b>	<b>4,783</b>	<b>3,190</b>	<b>3,515</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>Gal/mo</b>	<b>49,880</b>	<b>167,100</b>	<b>Gal/yr</b>
Boat Emissions:																
ROC	0.10	0.09	0.08	0.07	0.06	0.06	0.05	0.06	0.06	0.04	0.05	0.07	Tons/mo	0.83	2.77	Tons/yr at 33.15 lbs/MGal
NOx	1.63	1.55	1.33	1.23	1.05	1.34	0.89	0.99	1.28	0.76	0.79	1.15	Tons/mo	13.99	46.87	Tons/yr at 561.00 lbs/MGal
PM	0.10	0.09	0.08	0.07	0.06	0.08	0.05	0.06	0.08	0.05	0.05	0.07	Tons/mo	0.84	2.80	Tons/yr at 33.50 lbs/MGal
SOx	0.02	0.02	0.02	0.02	0.01	0.02	0.01	0.01	0.02	0.01	0.01	0.02	Tons/mo	0.19	0.63	Tons/yr at 7.50 lbs/MGal
CO	0.30	0.28	0.24	0.22	0.19	0.24	0.16	0.18	0.23	0.14	0.14	0.21	Tons/mo	2.54	8.42	Tons/yr at 102.00 lbs/MGal



**Platform Gall**  
**PTO No. 1494 Equipment Usage**  
**Rolling 12-Months Ending:**  
**Apr-18**

Equipment	May-17	Jun-17	Jul-17	Aug-17	Sep-17	Oct-17	Nov-17	Dec-17	Jan-18	Feb-18	Mar-18	Apr-18	Monthly Units	12-Month Total	Permit Limit	12-Mo & Permit Units
Gas Consumption:																
HP Planned	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	164.0	131.0	0.0	0.0	MSCF/mo	0.39	N/A	MMSCF/yr
HP Pilot/Purge	92.1	92.1	92.1	92.1	92.1	92.1	92.1	92.1	92.1	83.2	92.1	89.1	MSCF/mo	1.09	N/A	MMSCF/yr
HP Planned & PIP	92.1	92.1	92.1	92.1	92.1	92.1	92.1	92.1	256.1	214.2	92.1	163.1	MSCF/mo	1.48	N/A	MMSCF/yr
HP Unplanned	0.0	183.0	223.0	48.0	100.0	590.0	1,041.0	860.0	0.0	0.0	0.0	0.0	MSCF/mo	3.02	Exempt	MMSCF/yr
LP Planned	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	0.00	N/A	MMSCF/yr
LP Pilot/Purge	144.8	144.8	144.8	144.8	144.8	144.8	144.8	144.8	144.8	130.8	144.8	140.1	MSCF/mo	1.72	N/A	MMSCF/yr
LP Planned & PIP	144.8	144.8	144.8	144.8	144.8	144.8	144.8	144.8	144.8	130.8	144.8	140.1	MSCF/mo	1.72	N/A	MMSCF/yr
LP Unplanned	173.0	139.0	140.0	185.0	474.0	2,932.0	658.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	4.70	Exempt	MMSCF/yr
Gas Consumption:																
Turbines: G1	26.4	25.4	26.4	26.7	24.6	23.6	11.4	1.3	0.0	0.4	12.3	13.2	MMSCF/mo	191.60	N/A	MMSCF/yr
Turbines: G2	26.4	25.1	26.9	27.5	24.9	25.3	12.1	5.8	0.6	7.5	0.0	0.0	MMSCF/mo	182.14	N/A	MMSCF/yr
Turbines: G3	26.8	25.6	26.3	26.9	23.8	24.9	18.6	6.7	13.7	4.3	1.1	0.0	MMSCF/mo	198.53	N/A	MMSCF/yr
Turbines @ all loads	79.5	76.2	79.6	81.1	73.4	73.9	42.2	13.8	14.3	12.1	13.3	13.2	MMSCF/mo	572.83	850	MMSCF/yr
Turbine@<1000 KW	0.05	0.02	0.04	0.0	0.03	0.05	7.93	13.7	14.3	11.9	13.33	13.22	MMSCF/mo	74.57	250.0	MMSCF/yr
Diesel Use:																
Turbines: G1	0.07	0.14	0.20	0.05	0.15	0.00	0.06	0.00	0.00	0.85	0.008	0.000	MGal/mo	1.53	N/A	MGal/yr
Turbines: G2	0.20	0.37	0.96	0.07	0.75	0.63	0.00	9.74	0.00	1.245	0.000	0.000	MGal/mo	14.17	N/A	MGal/yr
Turbines: G3	0.19	0.47	1.35	0.10	0.00	0.07	0.16	0.00	0.00	0.92	0.000	0.0000	MGal/mo	3.26	N/A	MGal/yr
Turbines @ all loads	0.5	1.0	2.5	0.2	0.9	0.7	0.2	9.7	0.0	3.0	0.01	0.0000	MGal/mo	18.96	335	MGal/yr
Turbine@<1000 KW	0.26	0.26	1.13	0.11	0.19	0.27	0.11	9.75	0.00	1.03	0.01	0.0000	MGal/mo	13.14	150	MGal/yr
Back-up Generator:G4	0.40	0.31	0.65	0.00	0.70	1.01	0.25	0.42	0.33	0.23	0.30	0.27	MGal/mo	4.86	32.13	MGal/yr
North Crane	76.00	37.00	31.00	68.00	39.00	49.00	71.00	0.00	52.00	0.00	59.00	0.00	Gal/mo	482.0	N/A	Gal/yr
South Crane	465.00	291.00	415.00	331.00	309.00	527.00	348.00	508.00	287.00	0.00	151.00	195.00	Gal/mo	3,857.0	N/A	Gal/yr
Crane Total	571.00	328.00	448.00	399.00	348.00	578.00	419.00	508.00	339.00	0.00	210.00	195.00	Gal/mo	4,339	21,399	Gal/yr
Turbine Starter Engines	2.89	2.63	5.45	3.37	8.26	10.57	0.68	3.22	0.78	2.11	0.17	0.00	Hrs/mo	309.0	960	Gal/yr at 7.7 gal/hr
Boom Boat (VP)	1.00	5.90	5.90	0.40	0.70	0.50	7.20	0.60	0.50	0.50	2.00	0.00	Gal/mo	25.2	1,406	Gal/yr
P-19 Jem FW Pump	1.00	1.00	1.00	1.00	1.00	1.00	0.00	1.00	0.00	3.00	1.00	0.00	Hrs/mo	10.0	50	Hrs/yr
Tank Throughputs:																
V-08	49,260.5	46,707.0	44,298.8	45,174.9	44,060.9	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	302,029.0	N/A	Bbls/yr
Produced Gas	36,811.2	31,938.4	30,666.6	29,678.4	29,885.5	36,777.0	14,720.0	293.0	0.0	0.0	0.0	0.0	MSCF/mo	210.77	N/A	MMSCF/yr
Solvent Usage:																
Envirosol 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal
87 RB	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lb/gal
Z-Sol	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 0.17 lb/gal
Transbam Plus	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal
Sigma Thinner 80-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal
Sigma Thinner 81-57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal
Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal
Solvent Total	3.33	9.99	2.20	1.13	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.99	Tons/yr ROC
Coatings Total													Gal/mo	18.90	N/A	Gal/yr
Boats:																
Crew Boat Fuel:	1,740	4,104	2,106	1,802	2,296	1,531	1,687	2,192	1,294	1,352	1,966	1,605	Gal/mo	23,675	N/A	Gal/yr
Work Boat Fuel:	3,770	650	2,282	1,953	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	Gal/mo	23,737	N/A	Gal/yr
Total Boats Fuel	5,510	4,754	4,388	3,755	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	Gal/mo	47,412	167,100	Gal/yr
Boat Emissions:																
ROC	0.09	0.08	0.07	0.06	0.06	0.05	0.06	0.06	0.04	0.05	0.07	0.06	Tons/mo	0.79	2.77	Tons/yr at 33.15 lbs/MGal
NOx	1.55	1.33	1.23	1.05	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.94	Tons/mo	13.30	46.87	Tons/yr at 561.00 lbs/MGal
PM	0.09	0.08	0.07	0.06	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	Tons/mo	0.79	2.80	Tons/yr at 33.50 lbs/MGal
SOx	0.02	0.02	0.02	0.01	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal
CO	0.28	0.24	0.22	0.19	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	Tons/mo	2.42	8.52	Tons/yr at 102.00 lbs/MGal



**Platform Gail**  
**PTO No. 1494 Equipment Usage**  
**Rolling 12-Months Ending:**  
**May-18**

Equipment	Jun-17	Jul-17	Aug-17	Sep-17	Oct-17	Nov-17	Dec-17	Jan-18	Feb-18	Mar-18	Apr-18	May-18	Monthly Units	12-month Total	Permit Limit	12-Mo & Permit Units
Gas Consumption:																
HP Planned	0.0	0.0	0.0	0.0	0.0	0.0	0.0	164.0	131.0	0.0	94.0	90.0	MSCF/mo	0.48	N/A	MMSCF/yr
HP Pilot/Purge	92.1	92.1	92.1	92.1	92.1	92.1	92.1	92.1	83.2	92.1	89.1	92.1	MSCF/mo	1.09	N/A	MMSCF/yr
<b>HP Planned &amp; PIP</b>	<b>92.1</b>	<b>92.1</b>	<b>92.1</b>	<b>92.1</b>	<b>92.1</b>	<b>92.1</b>	<b>92.1</b>	<b>256.1</b>	<b>214.2</b>	<b>92.1</b>	<b>183.1</b>	<b>182.1</b>	<b>MSCF/mo</b>	<b>1.87</b>	<b>4.9</b>	<b>MMSCF/yr</b>
HP Unplanned	183.0	223.0	48.0	100.0	580.0	1,041.0	880.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	3.02	Exempt	MMSCF/yr
LP Planned	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	0.00	N/A	MMSCF/yr
LP Pilot/Purge	144.8	144.8	144.8	144.8	144.8	144.8	144.8	144.8	130.8	144.8	140.1	79.4	MSCF/mo	1.65	N/A	MMSCF/yr
<b>LP Planned &amp; PIP</b>	<b>144.8</b>	<b>144.8</b>	<b>144.8</b>	<b>144.8</b>	<b>144.8</b>	<b>144.8</b>	<b>144.8</b>	<b>144.8</b>	<b>130.8</b>	<b>144.8</b>	<b>140.1</b>	<b>79.4</b>	<b>MSCF/mo</b>	<b>1.68</b>	<b>2.31</b>	<b>MMSCF/yr</b>
LP Unplanned	138.0	140.0	185.0	474.0	2,932.0	658.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	4.53	Exempt	MMSCF/yr
Gas Consumption:																
Turbines: G1	25.4	28.4	28.7	24.8	23.6	11.4	1.3	0.0	0.4	12.3	13.2	13.7	MMSCF/mo	179.18	N/A	MMSCF/yr
Turbines: G2	25.1	23.9	27.5	24.9	25.3	12.1	5.8	0.8	7.5	0.0	0.0	0.0	MMSCF/mo	155.79	N/A	MMSCF/yr
Turbines: G3	25.8	26.3	26.9	23.6	24.9	18.6	6.7	13.7	4.3	1.1	0.0	0.0	MMSCF/mo	171.74	N/A	MMSCF/yr
<b>Turbines @ all loads</b>	<b>76.2</b>	<b>79.6</b>	<b>81.1</b>	<b>73.4</b>	<b>73.9</b>	<b>42.2</b>	<b>13.8</b>	<b>14.3</b>	<b>12.1</b>	<b>13.3</b>	<b>13.2</b>	<b>13.7</b>	<b>MMSCF/mo</b>	<b>506.71</b>	<b>850</b>	<b>MMSCF/yr</b>
Turbine@<1000 KW	0.02	0.04	0.03	0.00	0.05	7.93	13.68	14.3	11.9	13.3	13.22	13.69	MMSCF/mo	88.20	250.0	MMSCF/yr
Back-up Generator:G4																
Diesel Use:																
Turbines: G1	0.14	0.20	0.05	0.15	0.00	0.06	0.00	0.00	0.85	0.01	0.000	0.000	MGal/mo	1.46	N/A	MGal/yr
Turbines: G2	0.37	0.96	0.07	0.75	0.83	0.00	9.74	0.00	1.25	0.000	0.000	0.000	MGal/mo	13.97	N/A	MGal/yr
Turbines: G3	0.47	1.35	0.10	0.00	0.07	0.16	0.00	0.92	0.92	0.000	0.000	0.000	MGal/mo	3.07	N/A	MGal/yr
<b>Turbines @ all loads</b>	<b>1.0</b>	<b>2.5</b>	<b>0.2</b>	<b>0.9</b>	<b>0.9</b>	<b>0.2</b>	<b>9.7</b>	<b>0.9</b>	<b>3.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>MGal/mo</b>	<b>18.50</b>	<b>335</b>	<b>MGal/yr</b>
Turbine@<1000 KW	0.28	1.13	0.11	0.19	0.27	0.11	9.75	0.00	1.03	0.01	0.00	0.000	MGal/mo	12.87	150	MGal/yr
Back-up Generator:G4	0.31	0.85	0.00	0.70	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	MGal/mo	4.71	32.13	MGal/yr
North Crane	37.00	31.00	68.00	39.00	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	Gal/mo	406.0	N/A	Gal/yr
South Crane	291.00	415.00	331.00	309.00	527.00	348.00	508.00	287.00	0.00	151.00	195.00	189.00	Gal/mo	3,551.0	N/A	Gal/yr
Crane Total	328.00	446.00	399.00	348.00	576.00	419.00	508.00	339.00	0.00	210.00	195.00	189.00	Gal/mo	3,957	21,339	Gal/yr
Turbine Starter Engines	2.63	5.45	3.37	8.26	10.57	0.68	3.22	0.78	2.11	0.17	0.00	0.00	Hrs/mo	286.7	960	Gal/yr at 7.7 gal/hr
Boom Boat (VP)	5.90	5.90	0.40	0.70	0.50	7.20	0.60	0.50	0.50	2.00	0.00	1.30	Gal/mo	25.5	1,406	Gal/yr
<b>P-18 -Em FW Pump</b>	<b>0.00</b>	<b>1.00</b>	<b>1.00</b>	<b>1.00</b>	<b>1.00</b>	<b>0.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>Hrs/mo</b>	<b>12.0</b>	<b>50</b>	<b>Hrs/yr</b>
Tank Throughputs:																
V:08	46,707.0	44,298.8	45,174.9	44,080.9	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	252,768.5	N/A	Bbls/yr
Produced Gas	31,938.4	30,868.8	29,678.4	29,865.5	36,777.0	14,720.0	283.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	173.96	N/A	MMSCF/yr
Solvent Usage																
Envirosol 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal
87 RB													Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lb/gal
Z-Sol													Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lb/gal
Transbeam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal
Sigma Thinner 90-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal
Sigma Thinner 91-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal
Carbolite Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal
<b>Solvent Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>9.59</b>	<b>Tons/yr ROC</b>
Coatings Total	9.99	2.20	1.13	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	15.67	N/A	Gal/yr
Boats:																
Crew Boat Fuel:	4,104	2,106	1,802	2,296	1,531	1,687	2,192	1,284	1,352	1,966	1,605	1,990	Gal/mo	23,825	N/A	Gal/yr
Work Boat Fuel:	650	2,382	1,953	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	Gal/mo	24,279	N/A	Gal/yr
<b>Total Boats Fuel</b>	<b>4,754</b>	<b>4,388</b>	<b>3,755</b>	<b>4,783</b>	<b>3,190</b>	<b>3,515</b>	<b>4,566</b>	<b>2,686</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>Gal/mo</b>	<b>48,204</b>	<b>167,100</b>	<b>Gal/yr</b>
Boat Emissions:																
ROC	0.08	0.07	0.06	0.08	0.05	0.06	0.06	0.04	0.05	0.07	0.06	0.10	Tons/mo	0.80	2.77	Tons/yr at 33.15 lbs/MGal
NOx	1.33	1.23	1.05	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.94	1.77	Tons/mo	13.52	46.87	Tons/yr at 561.00 lbs/MGal
PM	0.08	0.07	0.06	0.08	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	Tons/mo	0.81	2.80	Tons/yr at 33.50 lbs/MGal
SOx	0.02	0.02	0.01	0.02	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal
CO	0.24	0.22	0.19	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	Tons/mo	2.46	8.52	Tons/yr at 102.00 lbs/MGal



**Platform Gail**  
**PTO No. 1494 Equipment Usage**  
**Rolling 12-Months Ending:**  
**Jun-18**

Equipment	Jul-17	Aug-17	Sep-17	Oct-17	Nov-17	Dec-17	Jan-18	Feb-18	Mar-18	Apr-18	May-18	Jun-18	Monthly Units	12-month Total	Permit Limit	12-Mo & Permit Units
Gas Consumption:																
HP Planned	0.0	0.0	0.0	0.0	0.0	0.0	164.0	131.0	0.0	94.0	90.0	0.0	MSCF/mo	0.48	N/A	MMSCF/yr
HP Pilot/Purge	92.1	92.1	92.1	92.1	92.1	92.1	92.1	83.2	92.1	89.1	92.1	89.1	MSCF/mo	1.09	N/A	MMSCF/yr
HP Planned & PIP	92.1	92.1	92.1	92.1	92.1	92.1	256.1	214.2	92.1	183.1	182.1	89.1	MSCF/mo	1.87	4.9	MMSCF/yr
HP Unplanned	223.0	48.0	100.0	560.0	1,041.0	860.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	2.83	Exempt	MMSCF/yr
LP Planned	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	0.00	N/A	MMSCF/yr
LP Pilot/Purge	144.8	144.8	144.8	144.8	144.8	144.8	144.8	130.8	144.8	140.1	140.1	79.4	MSCF/mo	1.51	N/A	MMSCF/yr
LP Planned & PIP	144.8	144.8	144.8	144.8	144.8	144.8	144.8	130.8	144.8	140.1	140.1	79.4	MSCF/mo	1.51	N/A	MMSCF/yr
LP Unplanned	140.0	185.0	474.0	2,932.0	658.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	4.39	Exempt	MMSCF/yr
Gas Consumption:																
Turbines: G1	26.4	26.7	24.8	23.6	11.4	1.3	0.0	0.4	12.3	13.2	13.7	13.3	MMSCF/mo	167.06	N/A	MMSCF/yr
G2	26.9	27.5	24.9	25.3	12.1	5.8	0.6	7.5	0.0	0.0	0.0	0.0	MMSCF/mo	130.87	N/A	MMSCF/yr
G3	26.3	26.9	23.8	24.9	18.8	8.7	13.7	4.3	1.1	0.0	0.0	0.0	MMSCF/mo	146.11	N/A	MMSCF/yr
Turbines @ all loads	79.6	81.1	73.4	73.9	42.2	13.8	14.3	12.1	13.3	13.2	13.7	13.3	MMSCF/mo	443.85	950	MMSCF/yr
Turbine@<1000 KW	0.04	0.03	0.03	0.1	7.93	13.68	14.29	11.9	13.3	13.2	13.69	13.33	MMSCF/mo	101.81	250.0	MMSCF/yr
Diesel Use:																
Turbines: G1	0.20	0.05	0.15	0.00	0.06	0.00	0.00	0.85	0.01	0.00	0.00	0.00	MGal/mo	1.31	N/A	MGal/yr
G2	0.86	0.07	0.75	0.83	0.00	9.74	0.00	1.25	0.00	0.000	0.00	0.017	MGal/mo	13.61	N/A	MGal/yr
G3	1.35	0.10	0.00	0.07	0.18	0.00	0.00	0.92	0.00	0.00	0.000	0.000	MGal/mo	2.60	N/A	MGal/yr
Turbines @ all loads	2.5	0.2	0.9	0.9	0.2	9.7	0.0	3.0	0.0	0.0	0.0	0.0173	MGal/mo	17.53	335	MGal/yr
Turbine@<1000 KW	1.13	0.11	0.19	0.27	0.11	9.75	0.00	1.03	0.01	0.00	0.00	0.0173	MGal/mo	12.62	150	MGal/yr
Back-up Generator:G4	0.65	0.00	0.70	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	MGal/mo	4.74	32.13	MGal/yr
North Crane	31.00	68.00	39.00	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	68.00	Gal/yr	435.0	N/A	Gal/yr
South Crane	415.00	331.00	309.00	527.00	348.00	508.00	287.00	0.00	151.00	195.00	189.00	78.00	Gal/yr	3,338.0	N/A	Gal/yr
Crane Total	446.00	399.00	348.00	576.00	419.00	508.00	339.00	0.00	210.00	195.00	189.00	144.00	Gal/yr	3,773	21,339	Gal/yr
Turbine Starter Engines	5.45	3.37	8.26	10.57	0.68	3.22	0.78	2.11	0.17	0.00	0.00	0.49	Hrs/mo	270.3	960	Gal/yr at 7.7 gal/hr
Boom Boat (VP)	5.90	0.40	0.70	0.50	7.20	0.60	0.50	0.50	2.00	0.00	1.30	0.55	Gal/mo	20.2	1,408	Gal/yr
P-18 -Em FW Pump	1.00	1.00	1.00	1.00	1.00	1.00	0.00	3.00	1.00	0.00	3.00	1.00	Hrs/mo	13.0	50	Hrs/yr
Tank Throughputs:																
V-08	44,298.8	45,174.9	44,080.9	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	206,061.5	N/A	Bbls/yr
Produced Gas	30,868.6	29,678.4	29,895.5	36,777.0	14,720.0	293.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	142.02	N/A	MMSCF/yr
Solvent Usage																
Envirosol 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lbs/gal
87 RB													Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lbs/gal
Z-Sol													Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lbs/gal
Transbeam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lbs/gal
Sigma Thinner 90-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lbs/gal
Sigma Thinner 91-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lbs/gal
Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lbs/gal
Solvent Total	2.20	1.13	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.59	Tons/yr ROC
Coatings Total													Gal/mo	5.98	N/A	Gal/yr
Boats:																
Crew Boat Fuel:	2,108	1,802	2,296	1,531	1,687	2,182	1,284	1,352	1,966	1,605	1,990	1,856	Gal/mo	21,677	N/A	Gal/yr
Work Boat Fuel:	2,282	1,953	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	Gal/mo	25,640	N/A	Gal/yr
Total Boats Fuel	4,388	3,755	4,783	3,190	3,515	4,556	2,686	2,818	4,095	3,344	6,302	3,868	Gal/mo	47,317	167,100	Gal/yr
Boat Emissions																
ROC	0.07	0.06	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	Tons/mo	0.78	2.77	Tons/yr at 33.15 lbs/MGal
NOx	1.23	1.05	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.94	1.17	1.08	Tons/mo	13.27	46.87	Tons/yr at 561.00 lbs/MGal
PM	0.07	0.06	0.08	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	Tons/mo	0.79	2.80	Tons/yr at 33.50 lbs/MGal
SOx	0.02	0.01	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal
CO	0.22	0.19	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	Tons/mo	2.41	8.52	Tons/yr at 102.00 lbs/MGal



**Platform Gail**  
**PTO No. 1494 Equipment Usage**  
**Rolling 12-Months Ending:**  
**Jul-18**

Equipment	Aug-17	Sep-17	Oct-17	Nov-17	Dec-17	Jan-18	Feb-18	Mar-18	Apr-18	May-18	Jun-18	Jul-18	Monthly Units	12-month Total	Permit Limit	12-Mo & Permit Units
Gas Consumption:																
HP Planned	0.0	0.0	0.0	0.0	0.0	164.0	131.0	0.0	94.0	90.0	0.0	0.0	MSCF/mo	0.48	N/A	MMSCF/yr
HP Pilot/Purge	92.1	92.1	92.1	92.1	92.1	92.1	89.1	92.1	89.1	92.1	92.1	92.1	MSCF/mo	1.09	N/A	MMSCF/yr
<b>HP Planned &amp; PIP</b>	<b>92.1</b>	<b>92.1</b>	<b>92.1</b>	<b>92.1</b>	<b>92.1</b>	<b>256.1</b>	<b>214.2</b>	<b>92.1</b>	<b>163.1</b>	<b>162.1</b>	<b>89.1</b>	<b>92.1</b>	<b>MSCF/mo</b>	<b>1.57</b>	<b>4.9</b>	<b>MMSCF/yr</b>
HP Unplanned	48.0	100.0	560.0	1,041.0	860.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	2.61	Exempt	MMSCF/yr
LP Planned	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	0.00	N/A	MMSCF/yr
LP Pilot/Purge	144.8	144.8	144.8	144.8	144.8	144.8	130.8	144.8	140.1	79.4	0.0	0.0	MSCF/mo	1.36	N/A	MMSCF/yr
<b>LP Planned &amp; PIP</b>	<b>144.8</b>	<b>144.8</b>	<b>144.8</b>	<b>144.8</b>	<b>144.8</b>	<b>144.8</b>	<b>130.8</b>	<b>144.8</b>	<b>140.1</b>	<b>79.4</b>	<b>0.0</b>	<b>0.0</b>	<b>MSCF/mo</b>	<b>1.36</b>	<b>2.31</b>	<b>MMSCF/yr</b>
LP Unplanned	185.0	474.0	2,932.0	658.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	4.25	Exempt	MMSCF/yr
Gas Consumption:																
Turbines: G1	26.7	24.8	23.6	11.4	1.3	0.0	0.4	12.3	13.2	13.7	13.3	13.8	MMSCF/mo	154.51	N/A	MMSCF/yr
Turbines: G2	27.5	24.9	25.3	12.1	5.8	0.6	7.5	0.0	0.0	0.0	0.0	0.0	MMSCF/mo	103.76	N/A	MMSCF/yr
Turbines: G3	28.9	23.6	24.9	18.8	6.7	13.7	4.3	1.1	0.0	0.0	0.0	0.0	MMSCF/mo	119.62	N/A	MMSCF/yr
<b>Turbines @ all loads</b>	<b>81.1</b>	<b>73.4</b>	<b>73.9</b>	<b>42.2</b>	<b>13.8</b>	<b>14.3</b>	<b>12.1</b>	<b>13.3</b>	<b>13.2</b>	<b>13.7</b>	<b>13.3</b>	<b>13.8</b>	<b>MMSCF/mo</b>	<b>378.10</b>	<b>850</b>	<b>MMSCF/yr</b>
<b>Turbines @ &lt;1000 KW</b>	<b>0.03</b>	<b>0.03</b>	<b>0.05</b>	<b>7.9</b>	<b>13.68</b>	<b>14.29</b>	<b>11.88</b>	<b>13.3</b>	<b>13.2</b>	<b>13.7</b>	<b>13.33</b>	<b>13.64</b>	<b>MMSCF/mo</b>	<b>115.31</b>	<b>260.0</b>	<b>MMSCF/yr</b>
Diesel Use:																
Turbines: G1	0.05	0.15	0.00	0.06	0.00	0.00	0.85	0.01	0.00	0.00	0.00	0.00	MGal/mo	1.20	N/A	MGal/yr
Turbines: G2	0.07	0.75	0.83	0.00	9.74	0.00	1.25	0.00	0.00	0.00	0.02	0.00	MGal/mo	12.65	N/A	MGal/yr
Turbines: G3	0.10	0.00	0.07	0.16	0.00	0.00	0.92	0.00	0.00	0.00	0.00	0.00	MGal/mo	1.27	N/A	MGal/yr
<b>Turbines @ all loads</b>	<b>0.22</b>	<b>0.91</b>	<b>0.90</b>	<b>0.22</b>	<b>9.74</b>	<b>0.00</b>	<b>3.00</b>	<b>0.01</b>	<b>0.00</b>	<b>0.00</b>	<b>0.02</b>	<b>0.00</b>	<b>MGal/mo</b>	<b>15.12</b>	<b>335</b>	<b>MGal/yr</b>
<b>Turbines @ &lt;1000 KW</b>	<b>0.11</b>	<b>0.19</b>	<b>0.27</b>	<b>0.11</b>	<b>9.75</b>	<b>0.00</b>	<b>1.03</b>	<b>0.01</b>	<b>0.00</b>	<b>0.00</b>	<b>0.02</b>	<b>0.00</b>	<b>MGal/mo</b>	<b>11.59</b>	<b>150</b>	<b>MGal/yr</b>
Back-up generator:G4	0.00	0.70	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	MGal/mo	4.19	32.13	MGal/yr
North Crane	68.00	39.00	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	Gal/mo	404.0	N/A	Gal/yr
South Crane	331.00	306.00	527.00	348.00	508.00	267.00	0.00	151.00	195.00	189.00	78.00	295.00	Gal/mo	3,216.0	N/A	Gal/yr
Crane Total	399.00	345.00	576.00	419.00	508.00	339.00	0.00	210.00	195.00	189.00	144.00	295.00	Gal/mo	3,622	21,339	Gal/yr
Turbine Starter Engines	3.37	8.26	10.57	0.68	3.22	0.78	2.11	0.17	0.00	0.00	0.49	0.61	Hrs/mo	233.0	960	Gal/yr at 7.7 gal/hr
Boom Boat (VP)	0.40	0.70	0.50	7.20	0.60	0.50	0.50	2.00	0.00	1.30	0.35	0.30	Gal/mo	14.6	1,406	Gal/yr
P-18 -Em FW Pump	1.00	1.00	1.00	0.00	1.00	0.00	3.00	1.00	0.00	3.00	1.00	2.00	Hrs/mo	14.0	50	Hrs/yr
Tank Throughputs:																
V:08	45,174.9	44,060.9	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	161,762.7	N/A	Bbls/yr
Produced Gas	29,678.4	29,855.5	36,777.0	14,720.0	293.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	111.35	N/A	MMSCF/yr
Solvent Usage:																
Envirosol 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal
87 RB													Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lb/gal
Z-Sol													Gal/mo	0.00	N/A	Tons/yr ROC at 0.17 lb/gal
Transfoam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal
Sigma Thinner 90-53													Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal
Sigma Thinner 91-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal
Carboline Thinner													Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal
<b>Solvent Total</b>	<b>1.13</b>	<b>2.25</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.00</b>	<b>9.99</b>	<b>Tons/yr ROC</b>
Coatings Total													Gal/mo	3.38	N/A	Gal/yr
Boats:																
Crew Boat Fuel:	1,802	2,296	1,531	1,687	2,192	1,294	1,362	1,966	1,605	1,990	1,856	2,779	Gal/mo	22,351	N/A	Gal/yr
Work Boat Fuel:	1,953	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	Gal/mo	25,245	N/A	Gal/yr
<b>Total Boats Fuel</b>	<b>3,755</b>	<b>4,783</b>	<b>3,190</b>	<b>3,515</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,668</b>	<b>Gal/mo</b>	<b>47,595</b>	<b>167,100</b>	<b>Gal/yr</b>
Boat Emissions:																
ROC	0.08	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	Tons/mo	0.79	2.77	Tons/yr at 33.15 lbs/MGal
NOx	1.05	1.34	0.89	0.99	1.26	0.76	0.79	1.15	0.84	1.17	1.08	1.31	Tons/mo	13.35	46.87	Tons/yr at 561.00 lbs/MGal
PM	0.06	0.08	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.08	Tons/mo	0.80	2.80	Tons/yr at 33.50 lbs/MGal
SOx	0.01	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal
CO	0.19	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	Tons/mo	2.43	8.52	Tons/yr at 102.00 lbs/MGal



**Platform Gail**  
**PTO No. 1494 Equipment Usage**  
**Rolling 12-Months Ending:**  
**Aug-18**

Equipment	Sep-17	Oct-17	Nov-17	Dec-17	Jan-18	Feb-18	Mar-18	Apr-18	May-18	Jun-18	Jul-18	Aug-18	Monthly Units	12-Month Total	Permit Limit	12-Mo & Permit Units																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																			
Gas Consumption:																	HP Planned	0.0	0.0	0.0	0.0	164.0	131.0	0.0	84.0	90.0	0.0	0.0	88.0	MSCF/mo	0.57	N/A	MMSCF/yr	HP Pilot/Purge	92.1	92.1	92.1	92.1	92.1	83.2	92.1	89.1	92.1	89.1	92.1	92.1	MSCF/mo	1.09	N/A	MMSCF/yr	HP Planned & PIP	92.1	92.1	92.1	92.1	256.1	214.2	92.1	163.1	182.1	89.1	92.1	180.1	MSCF/mo	1.66	4.9	MMSCF/yr	HP Unplanned	100.0	560.0	1,041.0	860.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	2.56	Exempt	MMSCF/yr	LP Planned	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	0.00	N/A	MMSCF/yr	LP Pilot/Purge	144.8	144.8	144.8	144.8	144.8	130.8	144.8	140.1	79.4	0.0	0.0	0.0	MSCF/mo	1.22	N/A	MMSCF/yr	LP Planned & PIP	144.8	144.8	144.8	144.8	144.8	130.8	144.8	140.1	79.4	0.0	0.0	0.0	MSCF/mo	1.22	2.31	MMSCF/yr	LP Unplanned	474.0	2,932.0	658.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	4.06	Exempt	MMSCF/yr	Gas Consumption:																	Turbines: G1	24.8	23.6	11.4	1.3	0.0	0.4	12.3	13.2	13.7	13.3	13.8	14.0	MMSCF/mo	141.83	N/A	MMSCF/yr	Turbines: G2	24.9	25.3	12.1	5.8	0.8	7.5	0.0	0.0	0.0	0.0	0.0	0.0	MMSCF/mo	76.25	N/A	MMSCF/yr	Turbines: G3	23.6	24.9	18.6	6.7	13.7	4.3	1.1	0.0	0.0	0.0	0.0	0.0	MMSCF/mo	92.92	N/A	MMSCF/yr	Turbines @ all loads	73.4	73.9	42.2	13.8	14.3	12.1	13.3	13.2	13.7	13.3	13.8	14.0	MMSCF/mo	311.01	850	MMSCF/yr	Turbine@<1000 KW	0.03	0.05	7.93	13.7	14.29	11.68	13.33	13.2	13.7	13.3	13.84	14.02	MMSCF/mo	129.30	260.0	MMSCF/yr	Back-up Generator:G4																	Diesel Use:																	Turbines: G1	0.15	0.00	0.06	0.00	0.00	0.85	0.01	0.00	0.00	0.00	0.085	0.000	MGal/mo	1.15	N/A	MGal/yr	Turbines: G2	0.75	0.83	0.00	9.74	0.00	1.25	0.00	0.00	0.00	0.017	0.000	0.000	MGal/mo	12.59	N/A	MGal/yr	Turbines: G3	0.00	0.07	0.16	0.00	0.00	0.92	0.00	0.00	0.00	0.00	0.012	0.0000	MGal/mo	1.17	N/A	MGal/yr	Turbines @ all loads	0.9	0.9	0.2	9.7	0.0	3.0	0.0	0.0	0.0	0.0	0.10	0.0000	MGal/mo	14.91	335	MGal/yr	Turbine@<1000 KW	0.19	0.27	0.11	9.75	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.0000	MGal/mo	11.48	150	MGal/yr	Back-up Generator:G4	0.70	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	MGal/mo	4.27	32.13	MGal/yr	North Crane	39.00	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	Gal/mo	373.0	N/A	Gal/yr	South Crane	309.00	527.00	348.00	508.00	267.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	Gal/mo	3,190.0	N/A	Gal/yr	Crane Total	348.00	576.00	419.00	508.00	339.00	0.00	210.00	195.00	189.00	144.00	295.00	349.00	Gal/mo	3,572	21,339	Gal/yr	Turbine Starter Engines	8.26	10.57	0.68	3.22	0.78	2.11	0.17	0.00	0.00	0.49	0.61	0.72	Hrs/mo	212.6	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.70	0.50	7.20	0.60	0.50	0.50	2.00	0.00	1.30	0.55	0.30	1.70	Gal/mo	15.9	1,406	Gal/yr	P-18 -Em FW Pump	1.00	1.00	0.00	1.00	0.00	3.00	1.00	0.00	3.00	1.00	2.00	2.00	Hrs/mo	15.0	90	Hrs/yr	Tank Throughputs:																	V-08	44,080.9	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	116,587.9	N/A	Bbls/yr	Produced Gas	29,895.5	36,777.0	14,720.0	283.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	81.66	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal	87 RB													Gal/mo	0.00	N/A	Tons/yr ROC at 8.64 lb/gal	Z-Sol													Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lb/gal	Transbeam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal	Sigma Thinner 80-53													Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal	Sigma Thinner 81-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal	Carboline Thinner													Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal	Solvent Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.59	Tons/yr ROC	Coatings Total	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	2.25	N/A	Gal/yr	Boats:																	Crew Boat Fuel:	2,286	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,980	1,856	2,779	2,563	Gal/mo	23,141	N/A	Gal/yr	Work Boat Fuel:	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	2,809	Gal/mo	28,101	N/A	Gal/yr	Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal
HP Planned	0.0	0.0	0.0	0.0	164.0	131.0	0.0	84.0	90.0	0.0	0.0	88.0	MSCF/mo	0.57	N/A	MMSCF/yr	HP Pilot/Purge	92.1	92.1	92.1	92.1	92.1	83.2	92.1	89.1	92.1	89.1	92.1	92.1	MSCF/mo	1.09	N/A	MMSCF/yr	HP Planned & PIP	92.1	92.1	92.1	92.1	256.1	214.2	92.1	163.1	182.1	89.1	92.1	180.1	MSCF/mo	1.66	4.9	MMSCF/yr	HP Unplanned	100.0	560.0	1,041.0	860.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	2.56	Exempt	MMSCF/yr	LP Planned	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	0.00	N/A	MMSCF/yr	LP Pilot/Purge	144.8	144.8	144.8	144.8	144.8	130.8	144.8	140.1	79.4	0.0	0.0	0.0	MSCF/mo	1.22	N/A	MMSCF/yr	LP Planned & PIP	144.8	144.8	144.8	144.8	144.8	130.8	144.8	140.1	79.4	0.0	0.0	0.0	MSCF/mo	1.22	2.31	MMSCF/yr	LP Unplanned	474.0	2,932.0	658.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	4.06	Exempt	MMSCF/yr	Gas Consumption:																	Turbines: G1	24.8	23.6	11.4	1.3	0.0	0.4	12.3	13.2	13.7	13.3	13.8	14.0	MMSCF/mo	141.83	N/A	MMSCF/yr	Turbines: G2	24.9	25.3	12.1	5.8	0.8	7.5	0.0	0.0	0.0	0.0	0.0	0.0	MMSCF/mo	76.25	N/A	MMSCF/yr	Turbines: G3	23.6	24.9	18.6	6.7	13.7	4.3	1.1	0.0	0.0	0.0	0.0	0.0	MMSCF/mo	92.92	N/A	MMSCF/yr	Turbines @ all loads	73.4	73.9	42.2	13.8	14.3	12.1	13.3	13.2	13.7	13.3	13.8	14.0	MMSCF/mo	311.01	850	MMSCF/yr	Turbine@<1000 KW	0.03	0.05	7.93	13.7	14.29	11.68	13.33	13.2	13.7	13.3	13.84	14.02	MMSCF/mo	129.30	260.0	MMSCF/yr	Back-up Generator:G4																	Diesel Use:																	Turbines: G1	0.15	0.00	0.06	0.00	0.00	0.85	0.01	0.00	0.00	0.00	0.085	0.000	MGal/mo	1.15	N/A	MGal/yr	Turbines: G2	0.75	0.83	0.00	9.74	0.00	1.25	0.00	0.00	0.00	0.017	0.000	0.000	MGal/mo	12.59	N/A	MGal/yr	Turbines: G3	0.00	0.07	0.16	0.00	0.00	0.92	0.00	0.00	0.00	0.00	0.012	0.0000	MGal/mo	1.17	N/A	MGal/yr	Turbines @ all loads	0.9	0.9	0.2	9.7	0.0	3.0	0.0	0.0	0.0	0.0	0.10	0.0000	MGal/mo	14.91	335	MGal/yr	Turbine@<1000 KW	0.19	0.27	0.11	9.75	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.0000	MGal/mo	11.48	150	MGal/yr	Back-up Generator:G4	0.70	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	MGal/mo	4.27	32.13	MGal/yr	North Crane	39.00	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	Gal/mo	373.0	N/A	Gal/yr	South Crane	309.00	527.00	348.00	508.00	267.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	Gal/mo	3,190.0	N/A	Gal/yr	Crane Total	348.00	576.00	419.00	508.00	339.00	0.00	210.00	195.00	189.00	144.00	295.00	349.00	Gal/mo	3,572	21,339	Gal/yr	Turbine Starter Engines	8.26	10.57	0.68	3.22	0.78	2.11	0.17	0.00	0.00	0.49	0.61	0.72	Hrs/mo	212.6	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.70	0.50	7.20	0.60	0.50	0.50	2.00	0.00	1.30	0.55	0.30	1.70	Gal/mo	15.9	1,406	Gal/yr	P-18 -Em FW Pump	1.00	1.00	0.00	1.00	0.00	3.00	1.00	0.00	3.00	1.00	2.00	2.00	Hrs/mo	15.0	90	Hrs/yr	Tank Throughputs:																	V-08	44,080.9	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	116,587.9	N/A	Bbls/yr	Produced Gas	29,895.5	36,777.0	14,720.0	283.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	81.66	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal	87 RB													Gal/mo	0.00	N/A	Tons/yr ROC at 8.64 lb/gal	Z-Sol													Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lb/gal	Transbeam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal	Sigma Thinner 80-53													Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal	Sigma Thinner 81-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal	Carboline Thinner													Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal	Solvent Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.59	Tons/yr ROC	Coatings Total	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	2.25	N/A	Gal/yr	Boats:																	Crew Boat Fuel:	2,286	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,980	1,856	2,779	2,563	Gal/mo	23,141	N/A	Gal/yr	Work Boat Fuel:	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	2,809	Gal/mo	28,101	N/A	Gal/yr	Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																	
HP Pilot/Purge	92.1	92.1	92.1	92.1	92.1	83.2	92.1	89.1	92.1	89.1	92.1	92.1	MSCF/mo	1.09	N/A	MMSCF/yr	HP Planned & PIP	92.1	92.1	92.1	92.1	256.1	214.2	92.1	163.1	182.1	89.1	92.1	180.1	MSCF/mo	1.66	4.9	MMSCF/yr	HP Unplanned	100.0	560.0	1,041.0	860.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	2.56	Exempt	MMSCF/yr	LP Planned	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	0.00	N/A	MMSCF/yr	LP Pilot/Purge	144.8	144.8	144.8	144.8	144.8	130.8	144.8	140.1	79.4	0.0	0.0	0.0	MSCF/mo	1.22	N/A	MMSCF/yr	LP Planned & PIP	144.8	144.8	144.8	144.8	144.8	130.8	144.8	140.1	79.4	0.0	0.0	0.0	MSCF/mo	1.22	2.31	MMSCF/yr	LP Unplanned	474.0	2,932.0	658.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	4.06	Exempt	MMSCF/yr	Gas Consumption:																	Turbines: G1	24.8	23.6	11.4	1.3	0.0	0.4	12.3	13.2	13.7	13.3	13.8	14.0	MMSCF/mo	141.83	N/A	MMSCF/yr	Turbines: G2	24.9	25.3	12.1	5.8	0.8	7.5	0.0	0.0	0.0	0.0	0.0	0.0	MMSCF/mo	76.25	N/A	MMSCF/yr	Turbines: G3	23.6	24.9	18.6	6.7	13.7	4.3	1.1	0.0	0.0	0.0	0.0	0.0	MMSCF/mo	92.92	N/A	MMSCF/yr	Turbines @ all loads	73.4	73.9	42.2	13.8	14.3	12.1	13.3	13.2	13.7	13.3	13.8	14.0	MMSCF/mo	311.01	850	MMSCF/yr	Turbine@<1000 KW	0.03	0.05	7.93	13.7	14.29	11.68	13.33	13.2	13.7	13.3	13.84	14.02	MMSCF/mo	129.30	260.0	MMSCF/yr	Back-up Generator:G4																	Diesel Use:																	Turbines: G1	0.15	0.00	0.06	0.00	0.00	0.85	0.01	0.00	0.00	0.00	0.085	0.000	MGal/mo	1.15	N/A	MGal/yr	Turbines: G2	0.75	0.83	0.00	9.74	0.00	1.25	0.00	0.00	0.00	0.017	0.000	0.000	MGal/mo	12.59	N/A	MGal/yr	Turbines: G3	0.00	0.07	0.16	0.00	0.00	0.92	0.00	0.00	0.00	0.00	0.012	0.0000	MGal/mo	1.17	N/A	MGal/yr	Turbines @ all loads	0.9	0.9	0.2	9.7	0.0	3.0	0.0	0.0	0.0	0.0	0.10	0.0000	MGal/mo	14.91	335	MGal/yr	Turbine@<1000 KW	0.19	0.27	0.11	9.75	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.0000	MGal/mo	11.48	150	MGal/yr	Back-up Generator:G4	0.70	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	MGal/mo	4.27	32.13	MGal/yr	North Crane	39.00	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	Gal/mo	373.0	N/A	Gal/yr	South Crane	309.00	527.00	348.00	508.00	267.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	Gal/mo	3,190.0	N/A	Gal/yr	Crane Total	348.00	576.00	419.00	508.00	339.00	0.00	210.00	195.00	189.00	144.00	295.00	349.00	Gal/mo	3,572	21,339	Gal/yr	Turbine Starter Engines	8.26	10.57	0.68	3.22	0.78	2.11	0.17	0.00	0.00	0.49	0.61	0.72	Hrs/mo	212.6	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.70	0.50	7.20	0.60	0.50	0.50	2.00	0.00	1.30	0.55	0.30	1.70	Gal/mo	15.9	1,406	Gal/yr	P-18 -Em FW Pump	1.00	1.00	0.00	1.00	0.00	3.00	1.00	0.00	3.00	1.00	2.00	2.00	Hrs/mo	15.0	90	Hrs/yr	Tank Throughputs:																	V-08	44,080.9	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	116,587.9	N/A	Bbls/yr	Produced Gas	29,895.5	36,777.0	14,720.0	283.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	81.66	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal	87 RB													Gal/mo	0.00	N/A	Tons/yr ROC at 8.64 lb/gal	Z-Sol													Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lb/gal	Transbeam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal	Sigma Thinner 80-53													Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal	Sigma Thinner 81-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal	Carboline Thinner													Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal	Solvent Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.59	Tons/yr ROC	Coatings Total	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	2.25	N/A	Gal/yr	Boats:																	Crew Boat Fuel:	2,286	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,980	1,856	2,779	2,563	Gal/mo	23,141	N/A	Gal/yr	Work Boat Fuel:	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	2,809	Gal/mo	28,101	N/A	Gal/yr	Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																		
HP Planned & PIP	92.1	92.1	92.1	92.1	256.1	214.2	92.1	163.1	182.1	89.1	92.1	180.1	MSCF/mo	1.66	4.9	MMSCF/yr	HP Unplanned	100.0	560.0	1,041.0	860.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	2.56	Exempt	MMSCF/yr	LP Planned	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	0.00	N/A	MMSCF/yr	LP Pilot/Purge	144.8	144.8	144.8	144.8	144.8	130.8	144.8	140.1	79.4	0.0	0.0	0.0	MSCF/mo	1.22	N/A	MMSCF/yr	LP Planned & PIP	144.8	144.8	144.8	144.8	144.8	130.8	144.8	140.1	79.4	0.0	0.0	0.0	MSCF/mo	1.22	2.31	MMSCF/yr	LP Unplanned	474.0	2,932.0	658.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	4.06	Exempt	MMSCF/yr	Gas Consumption:																	Turbines: G1	24.8	23.6	11.4	1.3	0.0	0.4	12.3	13.2	13.7	13.3	13.8	14.0	MMSCF/mo	141.83	N/A	MMSCF/yr	Turbines: G2	24.9	25.3	12.1	5.8	0.8	7.5	0.0	0.0	0.0	0.0	0.0	0.0	MMSCF/mo	76.25	N/A	MMSCF/yr	Turbines: G3	23.6	24.9	18.6	6.7	13.7	4.3	1.1	0.0	0.0	0.0	0.0	0.0	MMSCF/mo	92.92	N/A	MMSCF/yr	Turbines @ all loads	73.4	73.9	42.2	13.8	14.3	12.1	13.3	13.2	13.7	13.3	13.8	14.0	MMSCF/mo	311.01	850	MMSCF/yr	Turbine@<1000 KW	0.03	0.05	7.93	13.7	14.29	11.68	13.33	13.2	13.7	13.3	13.84	14.02	MMSCF/mo	129.30	260.0	MMSCF/yr	Back-up Generator:G4																	Diesel Use:																	Turbines: G1	0.15	0.00	0.06	0.00	0.00	0.85	0.01	0.00	0.00	0.00	0.085	0.000	MGal/mo	1.15	N/A	MGal/yr	Turbines: G2	0.75	0.83	0.00	9.74	0.00	1.25	0.00	0.00	0.00	0.017	0.000	0.000	MGal/mo	12.59	N/A	MGal/yr	Turbines: G3	0.00	0.07	0.16	0.00	0.00	0.92	0.00	0.00	0.00	0.00	0.012	0.0000	MGal/mo	1.17	N/A	MGal/yr	Turbines @ all loads	0.9	0.9	0.2	9.7	0.0	3.0	0.0	0.0	0.0	0.0	0.10	0.0000	MGal/mo	14.91	335	MGal/yr	Turbine@<1000 KW	0.19	0.27	0.11	9.75	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.0000	MGal/mo	11.48	150	MGal/yr	Back-up Generator:G4	0.70	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	MGal/mo	4.27	32.13	MGal/yr	North Crane	39.00	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	Gal/mo	373.0	N/A	Gal/yr	South Crane	309.00	527.00	348.00	508.00	267.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	Gal/mo	3,190.0	N/A	Gal/yr	Crane Total	348.00	576.00	419.00	508.00	339.00	0.00	210.00	195.00	189.00	144.00	295.00	349.00	Gal/mo	3,572	21,339	Gal/yr	Turbine Starter Engines	8.26	10.57	0.68	3.22	0.78	2.11	0.17	0.00	0.00	0.49	0.61	0.72	Hrs/mo	212.6	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.70	0.50	7.20	0.60	0.50	0.50	2.00	0.00	1.30	0.55	0.30	1.70	Gal/mo	15.9	1,406	Gal/yr	P-18 -Em FW Pump	1.00	1.00	0.00	1.00	0.00	3.00	1.00	0.00	3.00	1.00	2.00	2.00	Hrs/mo	15.0	90	Hrs/yr	Tank Throughputs:																	V-08	44,080.9	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	116,587.9	N/A	Bbls/yr	Produced Gas	29,895.5	36,777.0	14,720.0	283.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	81.66	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal	87 RB													Gal/mo	0.00	N/A	Tons/yr ROC at 8.64 lb/gal	Z-Sol													Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lb/gal	Transbeam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal	Sigma Thinner 80-53													Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal	Sigma Thinner 81-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal	Carboline Thinner													Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal	Solvent Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.59	Tons/yr ROC	Coatings Total	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	2.25	N/A	Gal/yr	Boats:																	Crew Boat Fuel:	2,286	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,980	1,856	2,779	2,563	Gal/mo	23,141	N/A	Gal/yr	Work Boat Fuel:	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	2,809	Gal/mo	28,101	N/A	Gal/yr	Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																			
HP Unplanned	100.0	560.0	1,041.0	860.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	2.56	Exempt	MMSCF/yr	LP Planned	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	0.00	N/A	MMSCF/yr	LP Pilot/Purge	144.8	144.8	144.8	144.8	144.8	130.8	144.8	140.1	79.4	0.0	0.0	0.0	MSCF/mo	1.22	N/A	MMSCF/yr	LP Planned & PIP	144.8	144.8	144.8	144.8	144.8	130.8	144.8	140.1	79.4	0.0	0.0	0.0	MSCF/mo	1.22	2.31	MMSCF/yr	LP Unplanned	474.0	2,932.0	658.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	4.06	Exempt	MMSCF/yr	Gas Consumption:																	Turbines: G1	24.8	23.6	11.4	1.3	0.0	0.4	12.3	13.2	13.7	13.3	13.8	14.0	MMSCF/mo	141.83	N/A	MMSCF/yr	Turbines: G2	24.9	25.3	12.1	5.8	0.8	7.5	0.0	0.0	0.0	0.0	0.0	0.0	MMSCF/mo	76.25	N/A	MMSCF/yr	Turbines: G3	23.6	24.9	18.6	6.7	13.7	4.3	1.1	0.0	0.0	0.0	0.0	0.0	MMSCF/mo	92.92	N/A	MMSCF/yr	Turbines @ all loads	73.4	73.9	42.2	13.8	14.3	12.1	13.3	13.2	13.7	13.3	13.8	14.0	MMSCF/mo	311.01	850	MMSCF/yr	Turbine@<1000 KW	0.03	0.05	7.93	13.7	14.29	11.68	13.33	13.2	13.7	13.3	13.84	14.02	MMSCF/mo	129.30	260.0	MMSCF/yr	Back-up Generator:G4																	Diesel Use:																	Turbines: G1	0.15	0.00	0.06	0.00	0.00	0.85	0.01	0.00	0.00	0.00	0.085	0.000	MGal/mo	1.15	N/A	MGal/yr	Turbines: G2	0.75	0.83	0.00	9.74	0.00	1.25	0.00	0.00	0.00	0.017	0.000	0.000	MGal/mo	12.59	N/A	MGal/yr	Turbines: G3	0.00	0.07	0.16	0.00	0.00	0.92	0.00	0.00	0.00	0.00	0.012	0.0000	MGal/mo	1.17	N/A	MGal/yr	Turbines @ all loads	0.9	0.9	0.2	9.7	0.0	3.0	0.0	0.0	0.0	0.0	0.10	0.0000	MGal/mo	14.91	335	MGal/yr	Turbine@<1000 KW	0.19	0.27	0.11	9.75	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.0000	MGal/mo	11.48	150	MGal/yr	Back-up Generator:G4	0.70	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	MGal/mo	4.27	32.13	MGal/yr	North Crane	39.00	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	Gal/mo	373.0	N/A	Gal/yr	South Crane	309.00	527.00	348.00	508.00	267.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	Gal/mo	3,190.0	N/A	Gal/yr	Crane Total	348.00	576.00	419.00	508.00	339.00	0.00	210.00	195.00	189.00	144.00	295.00	349.00	Gal/mo	3,572	21,339	Gal/yr	Turbine Starter Engines	8.26	10.57	0.68	3.22	0.78	2.11	0.17	0.00	0.00	0.49	0.61	0.72	Hrs/mo	212.6	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.70	0.50	7.20	0.60	0.50	0.50	2.00	0.00	1.30	0.55	0.30	1.70	Gal/mo	15.9	1,406	Gal/yr	P-18 -Em FW Pump	1.00	1.00	0.00	1.00	0.00	3.00	1.00	0.00	3.00	1.00	2.00	2.00	Hrs/mo	15.0	90	Hrs/yr	Tank Throughputs:																	V-08	44,080.9	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	116,587.9	N/A	Bbls/yr	Produced Gas	29,895.5	36,777.0	14,720.0	283.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	81.66	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal	87 RB													Gal/mo	0.00	N/A	Tons/yr ROC at 8.64 lb/gal	Z-Sol													Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lb/gal	Transbeam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal	Sigma Thinner 80-53													Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal	Sigma Thinner 81-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal	Carboline Thinner													Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal	Solvent Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.59	Tons/yr ROC	Coatings Total	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	2.25	N/A	Gal/yr	Boats:																	Crew Boat Fuel:	2,286	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,980	1,856	2,779	2,563	Gal/mo	23,141	N/A	Gal/yr	Work Boat Fuel:	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	2,809	Gal/mo	28,101	N/A	Gal/yr	Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																				
LP Planned	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	0.00	N/A	MMSCF/yr	LP Pilot/Purge	144.8	144.8	144.8	144.8	144.8	130.8	144.8	140.1	79.4	0.0	0.0	0.0	MSCF/mo	1.22	N/A	MMSCF/yr	LP Planned & PIP	144.8	144.8	144.8	144.8	144.8	130.8	144.8	140.1	79.4	0.0	0.0	0.0	MSCF/mo	1.22	2.31	MMSCF/yr	LP Unplanned	474.0	2,932.0	658.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	4.06	Exempt	MMSCF/yr	Gas Consumption:																	Turbines: G1	24.8	23.6	11.4	1.3	0.0	0.4	12.3	13.2	13.7	13.3	13.8	14.0	MMSCF/mo	141.83	N/A	MMSCF/yr	Turbines: G2	24.9	25.3	12.1	5.8	0.8	7.5	0.0	0.0	0.0	0.0	0.0	0.0	MMSCF/mo	76.25	N/A	MMSCF/yr	Turbines: G3	23.6	24.9	18.6	6.7	13.7	4.3	1.1	0.0	0.0	0.0	0.0	0.0	MMSCF/mo	92.92	N/A	MMSCF/yr	Turbines @ all loads	73.4	73.9	42.2	13.8	14.3	12.1	13.3	13.2	13.7	13.3	13.8	14.0	MMSCF/mo	311.01	850	MMSCF/yr	Turbine@<1000 KW	0.03	0.05	7.93	13.7	14.29	11.68	13.33	13.2	13.7	13.3	13.84	14.02	MMSCF/mo	129.30	260.0	MMSCF/yr	Back-up Generator:G4																	Diesel Use:																	Turbines: G1	0.15	0.00	0.06	0.00	0.00	0.85	0.01	0.00	0.00	0.00	0.085	0.000	MGal/mo	1.15	N/A	MGal/yr	Turbines: G2	0.75	0.83	0.00	9.74	0.00	1.25	0.00	0.00	0.00	0.017	0.000	0.000	MGal/mo	12.59	N/A	MGal/yr	Turbines: G3	0.00	0.07	0.16	0.00	0.00	0.92	0.00	0.00	0.00	0.00	0.012	0.0000	MGal/mo	1.17	N/A	MGal/yr	Turbines @ all loads	0.9	0.9	0.2	9.7	0.0	3.0	0.0	0.0	0.0	0.0	0.10	0.0000	MGal/mo	14.91	335	MGal/yr	Turbine@<1000 KW	0.19	0.27	0.11	9.75	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.0000	MGal/mo	11.48	150	MGal/yr	Back-up Generator:G4	0.70	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	MGal/mo	4.27	32.13	MGal/yr	North Crane	39.00	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	Gal/mo	373.0	N/A	Gal/yr	South Crane	309.00	527.00	348.00	508.00	267.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	Gal/mo	3,190.0	N/A	Gal/yr	Crane Total	348.00	576.00	419.00	508.00	339.00	0.00	210.00	195.00	189.00	144.00	295.00	349.00	Gal/mo	3,572	21,339	Gal/yr	Turbine Starter Engines	8.26	10.57	0.68	3.22	0.78	2.11	0.17	0.00	0.00	0.49	0.61	0.72	Hrs/mo	212.6	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.70	0.50	7.20	0.60	0.50	0.50	2.00	0.00	1.30	0.55	0.30	1.70	Gal/mo	15.9	1,406	Gal/yr	P-18 -Em FW Pump	1.00	1.00	0.00	1.00	0.00	3.00	1.00	0.00	3.00	1.00	2.00	2.00	Hrs/mo	15.0	90	Hrs/yr	Tank Throughputs:																	V-08	44,080.9	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	116,587.9	N/A	Bbls/yr	Produced Gas	29,895.5	36,777.0	14,720.0	283.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	81.66	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal	87 RB													Gal/mo	0.00	N/A	Tons/yr ROC at 8.64 lb/gal	Z-Sol													Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lb/gal	Transbeam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal	Sigma Thinner 80-53													Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal	Sigma Thinner 81-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal	Carboline Thinner													Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal	Solvent Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.59	Tons/yr ROC	Coatings Total	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	2.25	N/A	Gal/yr	Boats:																	Crew Boat Fuel:	2,286	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,980	1,856	2,779	2,563	Gal/mo	23,141	N/A	Gal/yr	Work Boat Fuel:	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	2,809	Gal/mo	28,101	N/A	Gal/yr	Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																					
LP Pilot/Purge	144.8	144.8	144.8	144.8	144.8	130.8	144.8	140.1	79.4	0.0	0.0	0.0	MSCF/mo	1.22	N/A	MMSCF/yr	LP Planned & PIP	144.8	144.8	144.8	144.8	144.8	130.8	144.8	140.1	79.4	0.0	0.0	0.0	MSCF/mo	1.22	2.31	MMSCF/yr	LP Unplanned	474.0	2,932.0	658.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	4.06	Exempt	MMSCF/yr	Gas Consumption:																	Turbines: G1	24.8	23.6	11.4	1.3	0.0	0.4	12.3	13.2	13.7	13.3	13.8	14.0	MMSCF/mo	141.83	N/A	MMSCF/yr	Turbines: G2	24.9	25.3	12.1	5.8	0.8	7.5	0.0	0.0	0.0	0.0	0.0	0.0	MMSCF/mo	76.25	N/A	MMSCF/yr	Turbines: G3	23.6	24.9	18.6	6.7	13.7	4.3	1.1	0.0	0.0	0.0	0.0	0.0	MMSCF/mo	92.92	N/A	MMSCF/yr	Turbines @ all loads	73.4	73.9	42.2	13.8	14.3	12.1	13.3	13.2	13.7	13.3	13.8	14.0	MMSCF/mo	311.01	850	MMSCF/yr	Turbine@<1000 KW	0.03	0.05	7.93	13.7	14.29	11.68	13.33	13.2	13.7	13.3	13.84	14.02	MMSCF/mo	129.30	260.0	MMSCF/yr	Back-up Generator:G4																	Diesel Use:																	Turbines: G1	0.15	0.00	0.06	0.00	0.00	0.85	0.01	0.00	0.00	0.00	0.085	0.000	MGal/mo	1.15	N/A	MGal/yr	Turbines: G2	0.75	0.83	0.00	9.74	0.00	1.25	0.00	0.00	0.00	0.017	0.000	0.000	MGal/mo	12.59	N/A	MGal/yr	Turbines: G3	0.00	0.07	0.16	0.00	0.00	0.92	0.00	0.00	0.00	0.00	0.012	0.0000	MGal/mo	1.17	N/A	MGal/yr	Turbines @ all loads	0.9	0.9	0.2	9.7	0.0	3.0	0.0	0.0	0.0	0.0	0.10	0.0000	MGal/mo	14.91	335	MGal/yr	Turbine@<1000 KW	0.19	0.27	0.11	9.75	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.0000	MGal/mo	11.48	150	MGal/yr	Back-up Generator:G4	0.70	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	MGal/mo	4.27	32.13	MGal/yr	North Crane	39.00	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	Gal/mo	373.0	N/A	Gal/yr	South Crane	309.00	527.00	348.00	508.00	267.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	Gal/mo	3,190.0	N/A	Gal/yr	Crane Total	348.00	576.00	419.00	508.00	339.00	0.00	210.00	195.00	189.00	144.00	295.00	349.00	Gal/mo	3,572	21,339	Gal/yr	Turbine Starter Engines	8.26	10.57	0.68	3.22	0.78	2.11	0.17	0.00	0.00	0.49	0.61	0.72	Hrs/mo	212.6	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.70	0.50	7.20	0.60	0.50	0.50	2.00	0.00	1.30	0.55	0.30	1.70	Gal/mo	15.9	1,406	Gal/yr	P-18 -Em FW Pump	1.00	1.00	0.00	1.00	0.00	3.00	1.00	0.00	3.00	1.00	2.00	2.00	Hrs/mo	15.0	90	Hrs/yr	Tank Throughputs:																	V-08	44,080.9	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	116,587.9	N/A	Bbls/yr	Produced Gas	29,895.5	36,777.0	14,720.0	283.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	81.66	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal	87 RB													Gal/mo	0.00	N/A	Tons/yr ROC at 8.64 lb/gal	Z-Sol													Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lb/gal	Transbeam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal	Sigma Thinner 80-53													Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal	Sigma Thinner 81-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal	Carboline Thinner													Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal	Solvent Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.59	Tons/yr ROC	Coatings Total	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	2.25	N/A	Gal/yr	Boats:																	Crew Boat Fuel:	2,286	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,980	1,856	2,779	2,563	Gal/mo	23,141	N/A	Gal/yr	Work Boat Fuel:	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	2,809	Gal/mo	28,101	N/A	Gal/yr	Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																						
LP Planned & PIP	144.8	144.8	144.8	144.8	144.8	130.8	144.8	140.1	79.4	0.0	0.0	0.0	MSCF/mo	1.22	2.31	MMSCF/yr	LP Unplanned	474.0	2,932.0	658.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	4.06	Exempt	MMSCF/yr	Gas Consumption:																	Turbines: G1	24.8	23.6	11.4	1.3	0.0	0.4	12.3	13.2	13.7	13.3	13.8	14.0	MMSCF/mo	141.83	N/A	MMSCF/yr	Turbines: G2	24.9	25.3	12.1	5.8	0.8	7.5	0.0	0.0	0.0	0.0	0.0	0.0	MMSCF/mo	76.25	N/A	MMSCF/yr	Turbines: G3	23.6	24.9	18.6	6.7	13.7	4.3	1.1	0.0	0.0	0.0	0.0	0.0	MMSCF/mo	92.92	N/A	MMSCF/yr	Turbines @ all loads	73.4	73.9	42.2	13.8	14.3	12.1	13.3	13.2	13.7	13.3	13.8	14.0	MMSCF/mo	311.01	850	MMSCF/yr	Turbine@<1000 KW	0.03	0.05	7.93	13.7	14.29	11.68	13.33	13.2	13.7	13.3	13.84	14.02	MMSCF/mo	129.30	260.0	MMSCF/yr	Back-up Generator:G4																	Diesel Use:																	Turbines: G1	0.15	0.00	0.06	0.00	0.00	0.85	0.01	0.00	0.00	0.00	0.085	0.000	MGal/mo	1.15	N/A	MGal/yr	Turbines: G2	0.75	0.83	0.00	9.74	0.00	1.25	0.00	0.00	0.00	0.017	0.000	0.000	MGal/mo	12.59	N/A	MGal/yr	Turbines: G3	0.00	0.07	0.16	0.00	0.00	0.92	0.00	0.00	0.00	0.00	0.012	0.0000	MGal/mo	1.17	N/A	MGal/yr	Turbines @ all loads	0.9	0.9	0.2	9.7	0.0	3.0	0.0	0.0	0.0	0.0	0.10	0.0000	MGal/mo	14.91	335	MGal/yr	Turbine@<1000 KW	0.19	0.27	0.11	9.75	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.0000	MGal/mo	11.48	150	MGal/yr	Back-up Generator:G4	0.70	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	MGal/mo	4.27	32.13	MGal/yr	North Crane	39.00	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	Gal/mo	373.0	N/A	Gal/yr	South Crane	309.00	527.00	348.00	508.00	267.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	Gal/mo	3,190.0	N/A	Gal/yr	Crane Total	348.00	576.00	419.00	508.00	339.00	0.00	210.00	195.00	189.00	144.00	295.00	349.00	Gal/mo	3,572	21,339	Gal/yr	Turbine Starter Engines	8.26	10.57	0.68	3.22	0.78	2.11	0.17	0.00	0.00	0.49	0.61	0.72	Hrs/mo	212.6	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.70	0.50	7.20	0.60	0.50	0.50	2.00	0.00	1.30	0.55	0.30	1.70	Gal/mo	15.9	1,406	Gal/yr	P-18 -Em FW Pump	1.00	1.00	0.00	1.00	0.00	3.00	1.00	0.00	3.00	1.00	2.00	2.00	Hrs/mo	15.0	90	Hrs/yr	Tank Throughputs:																	V-08	44,080.9	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	116,587.9	N/A	Bbls/yr	Produced Gas	29,895.5	36,777.0	14,720.0	283.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	81.66	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal	87 RB													Gal/mo	0.00	N/A	Tons/yr ROC at 8.64 lb/gal	Z-Sol													Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lb/gal	Transbeam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal	Sigma Thinner 80-53													Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal	Sigma Thinner 81-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal	Carboline Thinner													Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal	Solvent Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.59	Tons/yr ROC	Coatings Total	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	2.25	N/A	Gal/yr	Boats:																	Crew Boat Fuel:	2,286	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,980	1,856	2,779	2,563	Gal/mo	23,141	N/A	Gal/yr	Work Boat Fuel:	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	2,809	Gal/mo	28,101	N/A	Gal/yr	Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																							
LP Unplanned	474.0	2,932.0	658.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	4.06	Exempt	MMSCF/yr	Gas Consumption:																	Turbines: G1	24.8	23.6	11.4	1.3	0.0	0.4	12.3	13.2	13.7	13.3	13.8	14.0	MMSCF/mo	141.83	N/A	MMSCF/yr	Turbines: G2	24.9	25.3	12.1	5.8	0.8	7.5	0.0	0.0	0.0	0.0	0.0	0.0	MMSCF/mo	76.25	N/A	MMSCF/yr	Turbines: G3	23.6	24.9	18.6	6.7	13.7	4.3	1.1	0.0	0.0	0.0	0.0	0.0	MMSCF/mo	92.92	N/A	MMSCF/yr	Turbines @ all loads	73.4	73.9	42.2	13.8	14.3	12.1	13.3	13.2	13.7	13.3	13.8	14.0	MMSCF/mo	311.01	850	MMSCF/yr	Turbine@<1000 KW	0.03	0.05	7.93	13.7	14.29	11.68	13.33	13.2	13.7	13.3	13.84	14.02	MMSCF/mo	129.30	260.0	MMSCF/yr	Back-up Generator:G4																	Diesel Use:																	Turbines: G1	0.15	0.00	0.06	0.00	0.00	0.85	0.01	0.00	0.00	0.00	0.085	0.000	MGal/mo	1.15	N/A	MGal/yr	Turbines: G2	0.75	0.83	0.00	9.74	0.00	1.25	0.00	0.00	0.00	0.017	0.000	0.000	MGal/mo	12.59	N/A	MGal/yr	Turbines: G3	0.00	0.07	0.16	0.00	0.00	0.92	0.00	0.00	0.00	0.00	0.012	0.0000	MGal/mo	1.17	N/A	MGal/yr	Turbines @ all loads	0.9	0.9	0.2	9.7	0.0	3.0	0.0	0.0	0.0	0.0	0.10	0.0000	MGal/mo	14.91	335	MGal/yr	Turbine@<1000 KW	0.19	0.27	0.11	9.75	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.0000	MGal/mo	11.48	150	MGal/yr	Back-up Generator:G4	0.70	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	MGal/mo	4.27	32.13	MGal/yr	North Crane	39.00	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	Gal/mo	373.0	N/A	Gal/yr	South Crane	309.00	527.00	348.00	508.00	267.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	Gal/mo	3,190.0	N/A	Gal/yr	Crane Total	348.00	576.00	419.00	508.00	339.00	0.00	210.00	195.00	189.00	144.00	295.00	349.00	Gal/mo	3,572	21,339	Gal/yr	Turbine Starter Engines	8.26	10.57	0.68	3.22	0.78	2.11	0.17	0.00	0.00	0.49	0.61	0.72	Hrs/mo	212.6	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.70	0.50	7.20	0.60	0.50	0.50	2.00	0.00	1.30	0.55	0.30	1.70	Gal/mo	15.9	1,406	Gal/yr	P-18 -Em FW Pump	1.00	1.00	0.00	1.00	0.00	3.00	1.00	0.00	3.00	1.00	2.00	2.00	Hrs/mo	15.0	90	Hrs/yr	Tank Throughputs:																	V-08	44,080.9	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	116,587.9	N/A	Bbls/yr	Produced Gas	29,895.5	36,777.0	14,720.0	283.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	81.66	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal	87 RB													Gal/mo	0.00	N/A	Tons/yr ROC at 8.64 lb/gal	Z-Sol													Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lb/gal	Transbeam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal	Sigma Thinner 80-53													Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal	Sigma Thinner 81-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal	Carboline Thinner													Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal	Solvent Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.59	Tons/yr ROC	Coatings Total	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	2.25	N/A	Gal/yr	Boats:																	Crew Boat Fuel:	2,286	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,980	1,856	2,779	2,563	Gal/mo	23,141	N/A	Gal/yr	Work Boat Fuel:	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	2,809	Gal/mo	28,101	N/A	Gal/yr	Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																								
Gas Consumption:																	Turbines: G1	24.8	23.6	11.4	1.3	0.0	0.4	12.3	13.2	13.7	13.3	13.8	14.0	MMSCF/mo	141.83	N/A	MMSCF/yr	Turbines: G2	24.9	25.3	12.1	5.8	0.8	7.5	0.0	0.0	0.0	0.0	0.0	0.0	MMSCF/mo	76.25	N/A	MMSCF/yr	Turbines: G3	23.6	24.9	18.6	6.7	13.7	4.3	1.1	0.0	0.0	0.0	0.0	0.0	MMSCF/mo	92.92	N/A	MMSCF/yr	Turbines @ all loads	73.4	73.9	42.2	13.8	14.3	12.1	13.3	13.2	13.7	13.3	13.8	14.0	MMSCF/mo	311.01	850	MMSCF/yr	Turbine@<1000 KW	0.03	0.05	7.93	13.7	14.29	11.68	13.33	13.2	13.7	13.3	13.84	14.02	MMSCF/mo	129.30	260.0	MMSCF/yr	Back-up Generator:G4																	Diesel Use:																	Turbines: G1	0.15	0.00	0.06	0.00	0.00	0.85	0.01	0.00	0.00	0.00	0.085	0.000	MGal/mo	1.15	N/A	MGal/yr	Turbines: G2	0.75	0.83	0.00	9.74	0.00	1.25	0.00	0.00	0.00	0.017	0.000	0.000	MGal/mo	12.59	N/A	MGal/yr	Turbines: G3	0.00	0.07	0.16	0.00	0.00	0.92	0.00	0.00	0.00	0.00	0.012	0.0000	MGal/mo	1.17	N/A	MGal/yr	Turbines @ all loads	0.9	0.9	0.2	9.7	0.0	3.0	0.0	0.0	0.0	0.0	0.10	0.0000	MGal/mo	14.91	335	MGal/yr	Turbine@<1000 KW	0.19	0.27	0.11	9.75	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.0000	MGal/mo	11.48	150	MGal/yr	Back-up Generator:G4	0.70	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	MGal/mo	4.27	32.13	MGal/yr	North Crane	39.00	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	Gal/mo	373.0	N/A	Gal/yr	South Crane	309.00	527.00	348.00	508.00	267.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	Gal/mo	3,190.0	N/A	Gal/yr	Crane Total	348.00	576.00	419.00	508.00	339.00	0.00	210.00	195.00	189.00	144.00	295.00	349.00	Gal/mo	3,572	21,339	Gal/yr	Turbine Starter Engines	8.26	10.57	0.68	3.22	0.78	2.11	0.17	0.00	0.00	0.49	0.61	0.72	Hrs/mo	212.6	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.70	0.50	7.20	0.60	0.50	0.50	2.00	0.00	1.30	0.55	0.30	1.70	Gal/mo	15.9	1,406	Gal/yr	P-18 -Em FW Pump	1.00	1.00	0.00	1.00	0.00	3.00	1.00	0.00	3.00	1.00	2.00	2.00	Hrs/mo	15.0	90	Hrs/yr	Tank Throughputs:																	V-08	44,080.9	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	116,587.9	N/A	Bbls/yr	Produced Gas	29,895.5	36,777.0	14,720.0	283.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	81.66	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal	87 RB													Gal/mo	0.00	N/A	Tons/yr ROC at 8.64 lb/gal	Z-Sol													Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lb/gal	Transbeam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal	Sigma Thinner 80-53													Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal	Sigma Thinner 81-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal	Carboline Thinner													Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal	Solvent Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.59	Tons/yr ROC	Coatings Total	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	2.25	N/A	Gal/yr	Boats:																	Crew Boat Fuel:	2,286	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,980	1,856	2,779	2,563	Gal/mo	23,141	N/A	Gal/yr	Work Boat Fuel:	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	2,809	Gal/mo	28,101	N/A	Gal/yr	Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																									
Turbines: G1	24.8	23.6	11.4	1.3	0.0	0.4	12.3	13.2	13.7	13.3	13.8	14.0	MMSCF/mo	141.83	N/A	MMSCF/yr	Turbines: G2	24.9	25.3	12.1	5.8	0.8	7.5	0.0	0.0	0.0	0.0	0.0	0.0	MMSCF/mo	76.25	N/A	MMSCF/yr	Turbines: G3	23.6	24.9	18.6	6.7	13.7	4.3	1.1	0.0	0.0	0.0	0.0	0.0	MMSCF/mo	92.92	N/A	MMSCF/yr	Turbines @ all loads	73.4	73.9	42.2	13.8	14.3	12.1	13.3	13.2	13.7	13.3	13.8	14.0	MMSCF/mo	311.01	850	MMSCF/yr	Turbine@<1000 KW	0.03	0.05	7.93	13.7	14.29	11.68	13.33	13.2	13.7	13.3	13.84	14.02	MMSCF/mo	129.30	260.0	MMSCF/yr	Back-up Generator:G4																	Diesel Use:																	Turbines: G1	0.15	0.00	0.06	0.00	0.00	0.85	0.01	0.00	0.00	0.00	0.085	0.000	MGal/mo	1.15	N/A	MGal/yr	Turbines: G2	0.75	0.83	0.00	9.74	0.00	1.25	0.00	0.00	0.00	0.017	0.000	0.000	MGal/mo	12.59	N/A	MGal/yr	Turbines: G3	0.00	0.07	0.16	0.00	0.00	0.92	0.00	0.00	0.00	0.00	0.012	0.0000	MGal/mo	1.17	N/A	MGal/yr	Turbines @ all loads	0.9	0.9	0.2	9.7	0.0	3.0	0.0	0.0	0.0	0.0	0.10	0.0000	MGal/mo	14.91	335	MGal/yr	Turbine@<1000 KW	0.19	0.27	0.11	9.75	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.0000	MGal/mo	11.48	150	MGal/yr	Back-up Generator:G4	0.70	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	MGal/mo	4.27	32.13	MGal/yr	North Crane	39.00	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	Gal/mo	373.0	N/A	Gal/yr	South Crane	309.00	527.00	348.00	508.00	267.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	Gal/mo	3,190.0	N/A	Gal/yr	Crane Total	348.00	576.00	419.00	508.00	339.00	0.00	210.00	195.00	189.00	144.00	295.00	349.00	Gal/mo	3,572	21,339	Gal/yr	Turbine Starter Engines	8.26	10.57	0.68	3.22	0.78	2.11	0.17	0.00	0.00	0.49	0.61	0.72	Hrs/mo	212.6	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.70	0.50	7.20	0.60	0.50	0.50	2.00	0.00	1.30	0.55	0.30	1.70	Gal/mo	15.9	1,406	Gal/yr	P-18 -Em FW Pump	1.00	1.00	0.00	1.00	0.00	3.00	1.00	0.00	3.00	1.00	2.00	2.00	Hrs/mo	15.0	90	Hrs/yr	Tank Throughputs:																	V-08	44,080.9	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	116,587.9	N/A	Bbls/yr	Produced Gas	29,895.5	36,777.0	14,720.0	283.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	81.66	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal	87 RB													Gal/mo	0.00	N/A	Tons/yr ROC at 8.64 lb/gal	Z-Sol													Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lb/gal	Transbeam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal	Sigma Thinner 80-53													Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal	Sigma Thinner 81-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal	Carboline Thinner													Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal	Solvent Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.59	Tons/yr ROC	Coatings Total	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	2.25	N/A	Gal/yr	Boats:																	Crew Boat Fuel:	2,286	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,980	1,856	2,779	2,563	Gal/mo	23,141	N/A	Gal/yr	Work Boat Fuel:	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	2,809	Gal/mo	28,101	N/A	Gal/yr	Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																										
Turbines: G2	24.9	25.3	12.1	5.8	0.8	7.5	0.0	0.0	0.0	0.0	0.0	0.0	MMSCF/mo	76.25	N/A	MMSCF/yr	Turbines: G3	23.6	24.9	18.6	6.7	13.7	4.3	1.1	0.0	0.0	0.0	0.0	0.0	MMSCF/mo	92.92	N/A	MMSCF/yr	Turbines @ all loads	73.4	73.9	42.2	13.8	14.3	12.1	13.3	13.2	13.7	13.3	13.8	14.0	MMSCF/mo	311.01	850	MMSCF/yr	Turbine@<1000 KW	0.03	0.05	7.93	13.7	14.29	11.68	13.33	13.2	13.7	13.3	13.84	14.02	MMSCF/mo	129.30	260.0	MMSCF/yr	Back-up Generator:G4																	Diesel Use:																	Turbines: G1	0.15	0.00	0.06	0.00	0.00	0.85	0.01	0.00	0.00	0.00	0.085	0.000	MGal/mo	1.15	N/A	MGal/yr	Turbines: G2	0.75	0.83	0.00	9.74	0.00	1.25	0.00	0.00	0.00	0.017	0.000	0.000	MGal/mo	12.59	N/A	MGal/yr	Turbines: G3	0.00	0.07	0.16	0.00	0.00	0.92	0.00	0.00	0.00	0.00	0.012	0.0000	MGal/mo	1.17	N/A	MGal/yr	Turbines @ all loads	0.9	0.9	0.2	9.7	0.0	3.0	0.0	0.0	0.0	0.0	0.10	0.0000	MGal/mo	14.91	335	MGal/yr	Turbine@<1000 KW	0.19	0.27	0.11	9.75	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.0000	MGal/mo	11.48	150	MGal/yr	Back-up Generator:G4	0.70	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	MGal/mo	4.27	32.13	MGal/yr	North Crane	39.00	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	Gal/mo	373.0	N/A	Gal/yr	South Crane	309.00	527.00	348.00	508.00	267.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	Gal/mo	3,190.0	N/A	Gal/yr	Crane Total	348.00	576.00	419.00	508.00	339.00	0.00	210.00	195.00	189.00	144.00	295.00	349.00	Gal/mo	3,572	21,339	Gal/yr	Turbine Starter Engines	8.26	10.57	0.68	3.22	0.78	2.11	0.17	0.00	0.00	0.49	0.61	0.72	Hrs/mo	212.6	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.70	0.50	7.20	0.60	0.50	0.50	2.00	0.00	1.30	0.55	0.30	1.70	Gal/mo	15.9	1,406	Gal/yr	P-18 -Em FW Pump	1.00	1.00	0.00	1.00	0.00	3.00	1.00	0.00	3.00	1.00	2.00	2.00	Hrs/mo	15.0	90	Hrs/yr	Tank Throughputs:																	V-08	44,080.9	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	116,587.9	N/A	Bbls/yr	Produced Gas	29,895.5	36,777.0	14,720.0	283.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	81.66	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal	87 RB													Gal/mo	0.00	N/A	Tons/yr ROC at 8.64 lb/gal	Z-Sol													Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lb/gal	Transbeam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal	Sigma Thinner 80-53													Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal	Sigma Thinner 81-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal	Carboline Thinner													Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal	Solvent Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.59	Tons/yr ROC	Coatings Total	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	2.25	N/A	Gal/yr	Boats:																	Crew Boat Fuel:	2,286	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,980	1,856	2,779	2,563	Gal/mo	23,141	N/A	Gal/yr	Work Boat Fuel:	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	2,809	Gal/mo	28,101	N/A	Gal/yr	Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																											
Turbines: G3	23.6	24.9	18.6	6.7	13.7	4.3	1.1	0.0	0.0	0.0	0.0	0.0	MMSCF/mo	92.92	N/A	MMSCF/yr	Turbines @ all loads	73.4	73.9	42.2	13.8	14.3	12.1	13.3	13.2	13.7	13.3	13.8	14.0	MMSCF/mo	311.01	850	MMSCF/yr	Turbine@<1000 KW	0.03	0.05	7.93	13.7	14.29	11.68	13.33	13.2	13.7	13.3	13.84	14.02	MMSCF/mo	129.30	260.0	MMSCF/yr	Back-up Generator:G4																	Diesel Use:																	Turbines: G1	0.15	0.00	0.06	0.00	0.00	0.85	0.01	0.00	0.00	0.00	0.085	0.000	MGal/mo	1.15	N/A	MGal/yr	Turbines: G2	0.75	0.83	0.00	9.74	0.00	1.25	0.00	0.00	0.00	0.017	0.000	0.000	MGal/mo	12.59	N/A	MGal/yr	Turbines: G3	0.00	0.07	0.16	0.00	0.00	0.92	0.00	0.00	0.00	0.00	0.012	0.0000	MGal/mo	1.17	N/A	MGal/yr	Turbines @ all loads	0.9	0.9	0.2	9.7	0.0	3.0	0.0	0.0	0.0	0.0	0.10	0.0000	MGal/mo	14.91	335	MGal/yr	Turbine@<1000 KW	0.19	0.27	0.11	9.75	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.0000	MGal/mo	11.48	150	MGal/yr	Back-up Generator:G4	0.70	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	MGal/mo	4.27	32.13	MGal/yr	North Crane	39.00	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	Gal/mo	373.0	N/A	Gal/yr	South Crane	309.00	527.00	348.00	508.00	267.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	Gal/mo	3,190.0	N/A	Gal/yr	Crane Total	348.00	576.00	419.00	508.00	339.00	0.00	210.00	195.00	189.00	144.00	295.00	349.00	Gal/mo	3,572	21,339	Gal/yr	Turbine Starter Engines	8.26	10.57	0.68	3.22	0.78	2.11	0.17	0.00	0.00	0.49	0.61	0.72	Hrs/mo	212.6	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.70	0.50	7.20	0.60	0.50	0.50	2.00	0.00	1.30	0.55	0.30	1.70	Gal/mo	15.9	1,406	Gal/yr	P-18 -Em FW Pump	1.00	1.00	0.00	1.00	0.00	3.00	1.00	0.00	3.00	1.00	2.00	2.00	Hrs/mo	15.0	90	Hrs/yr	Tank Throughputs:																	V-08	44,080.9	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	116,587.9	N/A	Bbls/yr	Produced Gas	29,895.5	36,777.0	14,720.0	283.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	81.66	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal	87 RB													Gal/mo	0.00	N/A	Tons/yr ROC at 8.64 lb/gal	Z-Sol													Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lb/gal	Transbeam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal	Sigma Thinner 80-53													Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal	Sigma Thinner 81-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal	Carboline Thinner													Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal	Solvent Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.59	Tons/yr ROC	Coatings Total	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	2.25	N/A	Gal/yr	Boats:																	Crew Boat Fuel:	2,286	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,980	1,856	2,779	2,563	Gal/mo	23,141	N/A	Gal/yr	Work Boat Fuel:	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	2,809	Gal/mo	28,101	N/A	Gal/yr	Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																												
Turbines @ all loads	73.4	73.9	42.2	13.8	14.3	12.1	13.3	13.2	13.7	13.3	13.8	14.0	MMSCF/mo	311.01	850	MMSCF/yr	Turbine@<1000 KW	0.03	0.05	7.93	13.7	14.29	11.68	13.33	13.2	13.7	13.3	13.84	14.02	MMSCF/mo	129.30	260.0	MMSCF/yr	Back-up Generator:G4																	Diesel Use:																	Turbines: G1	0.15	0.00	0.06	0.00	0.00	0.85	0.01	0.00	0.00	0.00	0.085	0.000	MGal/mo	1.15	N/A	MGal/yr	Turbines: G2	0.75	0.83	0.00	9.74	0.00	1.25	0.00	0.00	0.00	0.017	0.000	0.000	MGal/mo	12.59	N/A	MGal/yr	Turbines: G3	0.00	0.07	0.16	0.00	0.00	0.92	0.00	0.00	0.00	0.00	0.012	0.0000	MGal/mo	1.17	N/A	MGal/yr	Turbines @ all loads	0.9	0.9	0.2	9.7	0.0	3.0	0.0	0.0	0.0	0.0	0.10	0.0000	MGal/mo	14.91	335	MGal/yr	Turbine@<1000 KW	0.19	0.27	0.11	9.75	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.0000	MGal/mo	11.48	150	MGal/yr	Back-up Generator:G4	0.70	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	MGal/mo	4.27	32.13	MGal/yr	North Crane	39.00	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	Gal/mo	373.0	N/A	Gal/yr	South Crane	309.00	527.00	348.00	508.00	267.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	Gal/mo	3,190.0	N/A	Gal/yr	Crane Total	348.00	576.00	419.00	508.00	339.00	0.00	210.00	195.00	189.00	144.00	295.00	349.00	Gal/mo	3,572	21,339	Gal/yr	Turbine Starter Engines	8.26	10.57	0.68	3.22	0.78	2.11	0.17	0.00	0.00	0.49	0.61	0.72	Hrs/mo	212.6	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.70	0.50	7.20	0.60	0.50	0.50	2.00	0.00	1.30	0.55	0.30	1.70	Gal/mo	15.9	1,406	Gal/yr	P-18 -Em FW Pump	1.00	1.00	0.00	1.00	0.00	3.00	1.00	0.00	3.00	1.00	2.00	2.00	Hrs/mo	15.0	90	Hrs/yr	Tank Throughputs:																	V-08	44,080.9	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	116,587.9	N/A	Bbls/yr	Produced Gas	29,895.5	36,777.0	14,720.0	283.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	81.66	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal	87 RB													Gal/mo	0.00	N/A	Tons/yr ROC at 8.64 lb/gal	Z-Sol													Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lb/gal	Transbeam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal	Sigma Thinner 80-53													Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal	Sigma Thinner 81-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal	Carboline Thinner													Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal	Solvent Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.59	Tons/yr ROC	Coatings Total	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	2.25	N/A	Gal/yr	Boats:																	Crew Boat Fuel:	2,286	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,980	1,856	2,779	2,563	Gal/mo	23,141	N/A	Gal/yr	Work Boat Fuel:	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	2,809	Gal/mo	28,101	N/A	Gal/yr	Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																													
Turbine@<1000 KW	0.03	0.05	7.93	13.7	14.29	11.68	13.33	13.2	13.7	13.3	13.84	14.02	MMSCF/mo	129.30	260.0	MMSCF/yr	Back-up Generator:G4																	Diesel Use:																	Turbines: G1	0.15	0.00	0.06	0.00	0.00	0.85	0.01	0.00	0.00	0.00	0.085	0.000	MGal/mo	1.15	N/A	MGal/yr	Turbines: G2	0.75	0.83	0.00	9.74	0.00	1.25	0.00	0.00	0.00	0.017	0.000	0.000	MGal/mo	12.59	N/A	MGal/yr	Turbines: G3	0.00	0.07	0.16	0.00	0.00	0.92	0.00	0.00	0.00	0.00	0.012	0.0000	MGal/mo	1.17	N/A	MGal/yr	Turbines @ all loads	0.9	0.9	0.2	9.7	0.0	3.0	0.0	0.0	0.0	0.0	0.10	0.0000	MGal/mo	14.91	335	MGal/yr	Turbine@<1000 KW	0.19	0.27	0.11	9.75	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.0000	MGal/mo	11.48	150	MGal/yr	Back-up Generator:G4	0.70	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	MGal/mo	4.27	32.13	MGal/yr	North Crane	39.00	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	Gal/mo	373.0	N/A	Gal/yr	South Crane	309.00	527.00	348.00	508.00	267.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	Gal/mo	3,190.0	N/A	Gal/yr	Crane Total	348.00	576.00	419.00	508.00	339.00	0.00	210.00	195.00	189.00	144.00	295.00	349.00	Gal/mo	3,572	21,339	Gal/yr	Turbine Starter Engines	8.26	10.57	0.68	3.22	0.78	2.11	0.17	0.00	0.00	0.49	0.61	0.72	Hrs/mo	212.6	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.70	0.50	7.20	0.60	0.50	0.50	2.00	0.00	1.30	0.55	0.30	1.70	Gal/mo	15.9	1,406	Gal/yr	P-18 -Em FW Pump	1.00	1.00	0.00	1.00	0.00	3.00	1.00	0.00	3.00	1.00	2.00	2.00	Hrs/mo	15.0	90	Hrs/yr	Tank Throughputs:																	V-08	44,080.9	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	116,587.9	N/A	Bbls/yr	Produced Gas	29,895.5	36,777.0	14,720.0	283.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	81.66	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal	87 RB													Gal/mo	0.00	N/A	Tons/yr ROC at 8.64 lb/gal	Z-Sol													Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lb/gal	Transbeam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal	Sigma Thinner 80-53													Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal	Sigma Thinner 81-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal	Carboline Thinner													Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal	Solvent Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.59	Tons/yr ROC	Coatings Total	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	2.25	N/A	Gal/yr	Boats:																	Crew Boat Fuel:	2,286	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,980	1,856	2,779	2,563	Gal/mo	23,141	N/A	Gal/yr	Work Boat Fuel:	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	2,809	Gal/mo	28,101	N/A	Gal/yr	Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																														
Back-up Generator:G4																	Diesel Use:																	Turbines: G1	0.15	0.00	0.06	0.00	0.00	0.85	0.01	0.00	0.00	0.00	0.085	0.000	MGal/mo	1.15	N/A	MGal/yr	Turbines: G2	0.75	0.83	0.00	9.74	0.00	1.25	0.00	0.00	0.00	0.017	0.000	0.000	MGal/mo	12.59	N/A	MGal/yr	Turbines: G3	0.00	0.07	0.16	0.00	0.00	0.92	0.00	0.00	0.00	0.00	0.012	0.0000	MGal/mo	1.17	N/A	MGal/yr	Turbines @ all loads	0.9	0.9	0.2	9.7	0.0	3.0	0.0	0.0	0.0	0.0	0.10	0.0000	MGal/mo	14.91	335	MGal/yr	Turbine@<1000 KW	0.19	0.27	0.11	9.75	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.0000	MGal/mo	11.48	150	MGal/yr	Back-up Generator:G4	0.70	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	MGal/mo	4.27	32.13	MGal/yr	North Crane	39.00	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	Gal/mo	373.0	N/A	Gal/yr	South Crane	309.00	527.00	348.00	508.00	267.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	Gal/mo	3,190.0	N/A	Gal/yr	Crane Total	348.00	576.00	419.00	508.00	339.00	0.00	210.00	195.00	189.00	144.00	295.00	349.00	Gal/mo	3,572	21,339	Gal/yr	Turbine Starter Engines	8.26	10.57	0.68	3.22	0.78	2.11	0.17	0.00	0.00	0.49	0.61	0.72	Hrs/mo	212.6	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.70	0.50	7.20	0.60	0.50	0.50	2.00	0.00	1.30	0.55	0.30	1.70	Gal/mo	15.9	1,406	Gal/yr	P-18 -Em FW Pump	1.00	1.00	0.00	1.00	0.00	3.00	1.00	0.00	3.00	1.00	2.00	2.00	Hrs/mo	15.0	90	Hrs/yr	Tank Throughputs:																	V-08	44,080.9	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	116,587.9	N/A	Bbls/yr	Produced Gas	29,895.5	36,777.0	14,720.0	283.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	81.66	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal	87 RB													Gal/mo	0.00	N/A	Tons/yr ROC at 8.64 lb/gal	Z-Sol													Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lb/gal	Transbeam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal	Sigma Thinner 80-53													Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal	Sigma Thinner 81-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal	Carboline Thinner													Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal	Solvent Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.59	Tons/yr ROC	Coatings Total	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	2.25	N/A	Gal/yr	Boats:																	Crew Boat Fuel:	2,286	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,980	1,856	2,779	2,563	Gal/mo	23,141	N/A	Gal/yr	Work Boat Fuel:	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	2,809	Gal/mo	28,101	N/A	Gal/yr	Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																															
Diesel Use:																	Turbines: G1	0.15	0.00	0.06	0.00	0.00	0.85	0.01	0.00	0.00	0.00	0.085	0.000	MGal/mo	1.15	N/A	MGal/yr	Turbines: G2	0.75	0.83	0.00	9.74	0.00	1.25	0.00	0.00	0.00	0.017	0.000	0.000	MGal/mo	12.59	N/A	MGal/yr	Turbines: G3	0.00	0.07	0.16	0.00	0.00	0.92	0.00	0.00	0.00	0.00	0.012	0.0000	MGal/mo	1.17	N/A	MGal/yr	Turbines @ all loads	0.9	0.9	0.2	9.7	0.0	3.0	0.0	0.0	0.0	0.0	0.10	0.0000	MGal/mo	14.91	335	MGal/yr	Turbine@<1000 KW	0.19	0.27	0.11	9.75	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.0000	MGal/mo	11.48	150	MGal/yr	Back-up Generator:G4	0.70	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	MGal/mo	4.27	32.13	MGal/yr	North Crane	39.00	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	Gal/mo	373.0	N/A	Gal/yr	South Crane	309.00	527.00	348.00	508.00	267.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	Gal/mo	3,190.0	N/A	Gal/yr	Crane Total	348.00	576.00	419.00	508.00	339.00	0.00	210.00	195.00	189.00	144.00	295.00	349.00	Gal/mo	3,572	21,339	Gal/yr	Turbine Starter Engines	8.26	10.57	0.68	3.22	0.78	2.11	0.17	0.00	0.00	0.49	0.61	0.72	Hrs/mo	212.6	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.70	0.50	7.20	0.60	0.50	0.50	2.00	0.00	1.30	0.55	0.30	1.70	Gal/mo	15.9	1,406	Gal/yr	P-18 -Em FW Pump	1.00	1.00	0.00	1.00	0.00	3.00	1.00	0.00	3.00	1.00	2.00	2.00	Hrs/mo	15.0	90	Hrs/yr	Tank Throughputs:																	V-08	44,080.9	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	116,587.9	N/A	Bbls/yr	Produced Gas	29,895.5	36,777.0	14,720.0	283.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	81.66	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal	87 RB													Gal/mo	0.00	N/A	Tons/yr ROC at 8.64 lb/gal	Z-Sol													Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lb/gal	Transbeam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal	Sigma Thinner 80-53													Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal	Sigma Thinner 81-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal	Carboline Thinner													Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal	Solvent Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.59	Tons/yr ROC	Coatings Total	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	2.25	N/A	Gal/yr	Boats:																	Crew Boat Fuel:	2,286	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,980	1,856	2,779	2,563	Gal/mo	23,141	N/A	Gal/yr	Work Boat Fuel:	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	2,809	Gal/mo	28,101	N/A	Gal/yr	Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																
Turbines: G1	0.15	0.00	0.06	0.00	0.00	0.85	0.01	0.00	0.00	0.00	0.085	0.000	MGal/mo	1.15	N/A	MGal/yr	Turbines: G2	0.75	0.83	0.00	9.74	0.00	1.25	0.00	0.00	0.00	0.017	0.000	0.000	MGal/mo	12.59	N/A	MGal/yr	Turbines: G3	0.00	0.07	0.16	0.00	0.00	0.92	0.00	0.00	0.00	0.00	0.012	0.0000	MGal/mo	1.17	N/A	MGal/yr	Turbines @ all loads	0.9	0.9	0.2	9.7	0.0	3.0	0.0	0.0	0.0	0.0	0.10	0.0000	MGal/mo	14.91	335	MGal/yr	Turbine@<1000 KW	0.19	0.27	0.11	9.75	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.0000	MGal/mo	11.48	150	MGal/yr	Back-up Generator:G4	0.70	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	MGal/mo	4.27	32.13	MGal/yr	North Crane	39.00	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	Gal/mo	373.0	N/A	Gal/yr	South Crane	309.00	527.00	348.00	508.00	267.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	Gal/mo	3,190.0	N/A	Gal/yr	Crane Total	348.00	576.00	419.00	508.00	339.00	0.00	210.00	195.00	189.00	144.00	295.00	349.00	Gal/mo	3,572	21,339	Gal/yr	Turbine Starter Engines	8.26	10.57	0.68	3.22	0.78	2.11	0.17	0.00	0.00	0.49	0.61	0.72	Hrs/mo	212.6	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.70	0.50	7.20	0.60	0.50	0.50	2.00	0.00	1.30	0.55	0.30	1.70	Gal/mo	15.9	1,406	Gal/yr	P-18 -Em FW Pump	1.00	1.00	0.00	1.00	0.00	3.00	1.00	0.00	3.00	1.00	2.00	2.00	Hrs/mo	15.0	90	Hrs/yr	Tank Throughputs:																	V-08	44,080.9	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	116,587.9	N/A	Bbls/yr	Produced Gas	29,895.5	36,777.0	14,720.0	283.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	81.66	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal	87 RB													Gal/mo	0.00	N/A	Tons/yr ROC at 8.64 lb/gal	Z-Sol													Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lb/gal	Transbeam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal	Sigma Thinner 80-53													Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal	Sigma Thinner 81-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal	Carboline Thinner													Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal	Solvent Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.59	Tons/yr ROC	Coatings Total	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	2.25	N/A	Gal/yr	Boats:																	Crew Boat Fuel:	2,286	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,980	1,856	2,779	2,563	Gal/mo	23,141	N/A	Gal/yr	Work Boat Fuel:	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	2,809	Gal/mo	28,101	N/A	Gal/yr	Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																	
Turbines: G2	0.75	0.83	0.00	9.74	0.00	1.25	0.00	0.00	0.00	0.017	0.000	0.000	MGal/mo	12.59	N/A	MGal/yr	Turbines: G3	0.00	0.07	0.16	0.00	0.00	0.92	0.00	0.00	0.00	0.00	0.012	0.0000	MGal/mo	1.17	N/A	MGal/yr	Turbines @ all loads	0.9	0.9	0.2	9.7	0.0	3.0	0.0	0.0	0.0	0.0	0.10	0.0000	MGal/mo	14.91	335	MGal/yr	Turbine@<1000 KW	0.19	0.27	0.11	9.75	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.0000	MGal/mo	11.48	150	MGal/yr	Back-up Generator:G4	0.70	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	MGal/mo	4.27	32.13	MGal/yr	North Crane	39.00	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	Gal/mo	373.0	N/A	Gal/yr	South Crane	309.00	527.00	348.00	508.00	267.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	Gal/mo	3,190.0	N/A	Gal/yr	Crane Total	348.00	576.00	419.00	508.00	339.00	0.00	210.00	195.00	189.00	144.00	295.00	349.00	Gal/mo	3,572	21,339	Gal/yr	Turbine Starter Engines	8.26	10.57	0.68	3.22	0.78	2.11	0.17	0.00	0.00	0.49	0.61	0.72	Hrs/mo	212.6	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.70	0.50	7.20	0.60	0.50	0.50	2.00	0.00	1.30	0.55	0.30	1.70	Gal/mo	15.9	1,406	Gal/yr	P-18 -Em FW Pump	1.00	1.00	0.00	1.00	0.00	3.00	1.00	0.00	3.00	1.00	2.00	2.00	Hrs/mo	15.0	90	Hrs/yr	Tank Throughputs:																	V-08	44,080.9	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	116,587.9	N/A	Bbls/yr	Produced Gas	29,895.5	36,777.0	14,720.0	283.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	81.66	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal	87 RB													Gal/mo	0.00	N/A	Tons/yr ROC at 8.64 lb/gal	Z-Sol													Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lb/gal	Transbeam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal	Sigma Thinner 80-53													Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal	Sigma Thinner 81-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal	Carboline Thinner													Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal	Solvent Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.59	Tons/yr ROC	Coatings Total	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	2.25	N/A	Gal/yr	Boats:																	Crew Boat Fuel:	2,286	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,980	1,856	2,779	2,563	Gal/mo	23,141	N/A	Gal/yr	Work Boat Fuel:	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	2,809	Gal/mo	28,101	N/A	Gal/yr	Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																		
Turbines: G3	0.00	0.07	0.16	0.00	0.00	0.92	0.00	0.00	0.00	0.00	0.012	0.0000	MGal/mo	1.17	N/A	MGal/yr	Turbines @ all loads	0.9	0.9	0.2	9.7	0.0	3.0	0.0	0.0	0.0	0.0	0.10	0.0000	MGal/mo	14.91	335	MGal/yr	Turbine@<1000 KW	0.19	0.27	0.11	9.75	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.0000	MGal/mo	11.48	150	MGal/yr	Back-up Generator:G4	0.70	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	MGal/mo	4.27	32.13	MGal/yr	North Crane	39.00	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	Gal/mo	373.0	N/A	Gal/yr	South Crane	309.00	527.00	348.00	508.00	267.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	Gal/mo	3,190.0	N/A	Gal/yr	Crane Total	348.00	576.00	419.00	508.00	339.00	0.00	210.00	195.00	189.00	144.00	295.00	349.00	Gal/mo	3,572	21,339	Gal/yr	Turbine Starter Engines	8.26	10.57	0.68	3.22	0.78	2.11	0.17	0.00	0.00	0.49	0.61	0.72	Hrs/mo	212.6	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.70	0.50	7.20	0.60	0.50	0.50	2.00	0.00	1.30	0.55	0.30	1.70	Gal/mo	15.9	1,406	Gal/yr	P-18 -Em FW Pump	1.00	1.00	0.00	1.00	0.00	3.00	1.00	0.00	3.00	1.00	2.00	2.00	Hrs/mo	15.0	90	Hrs/yr	Tank Throughputs:																	V-08	44,080.9	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	116,587.9	N/A	Bbls/yr	Produced Gas	29,895.5	36,777.0	14,720.0	283.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	81.66	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal	87 RB													Gal/mo	0.00	N/A	Tons/yr ROC at 8.64 lb/gal	Z-Sol													Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lb/gal	Transbeam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal	Sigma Thinner 80-53													Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal	Sigma Thinner 81-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal	Carboline Thinner													Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal	Solvent Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.59	Tons/yr ROC	Coatings Total	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	2.25	N/A	Gal/yr	Boats:																	Crew Boat Fuel:	2,286	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,980	1,856	2,779	2,563	Gal/mo	23,141	N/A	Gal/yr	Work Boat Fuel:	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	2,809	Gal/mo	28,101	N/A	Gal/yr	Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																			
Turbines @ all loads	0.9	0.9	0.2	9.7	0.0	3.0	0.0	0.0	0.0	0.0	0.10	0.0000	MGal/mo	14.91	335	MGal/yr	Turbine@<1000 KW	0.19	0.27	0.11	9.75	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.0000	MGal/mo	11.48	150	MGal/yr	Back-up Generator:G4	0.70	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	MGal/mo	4.27	32.13	MGal/yr	North Crane	39.00	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	Gal/mo	373.0	N/A	Gal/yr	South Crane	309.00	527.00	348.00	508.00	267.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	Gal/mo	3,190.0	N/A	Gal/yr	Crane Total	348.00	576.00	419.00	508.00	339.00	0.00	210.00	195.00	189.00	144.00	295.00	349.00	Gal/mo	3,572	21,339	Gal/yr	Turbine Starter Engines	8.26	10.57	0.68	3.22	0.78	2.11	0.17	0.00	0.00	0.49	0.61	0.72	Hrs/mo	212.6	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.70	0.50	7.20	0.60	0.50	0.50	2.00	0.00	1.30	0.55	0.30	1.70	Gal/mo	15.9	1,406	Gal/yr	P-18 -Em FW Pump	1.00	1.00	0.00	1.00	0.00	3.00	1.00	0.00	3.00	1.00	2.00	2.00	Hrs/mo	15.0	90	Hrs/yr	Tank Throughputs:																	V-08	44,080.9	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	116,587.9	N/A	Bbls/yr	Produced Gas	29,895.5	36,777.0	14,720.0	283.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	81.66	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal	87 RB													Gal/mo	0.00	N/A	Tons/yr ROC at 8.64 lb/gal	Z-Sol													Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lb/gal	Transbeam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal	Sigma Thinner 80-53													Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal	Sigma Thinner 81-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal	Carboline Thinner													Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal	Solvent Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.59	Tons/yr ROC	Coatings Total	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	2.25	N/A	Gal/yr	Boats:																	Crew Boat Fuel:	2,286	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,980	1,856	2,779	2,563	Gal/mo	23,141	N/A	Gal/yr	Work Boat Fuel:	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	2,809	Gal/mo	28,101	N/A	Gal/yr	Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																				
Turbine@<1000 KW	0.19	0.27	0.11	9.75	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.0000	MGal/mo	11.48	150	MGal/yr	Back-up Generator:G4	0.70	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	MGal/mo	4.27	32.13	MGal/yr	North Crane	39.00	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	Gal/mo	373.0	N/A	Gal/yr	South Crane	309.00	527.00	348.00	508.00	267.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	Gal/mo	3,190.0	N/A	Gal/yr	Crane Total	348.00	576.00	419.00	508.00	339.00	0.00	210.00	195.00	189.00	144.00	295.00	349.00	Gal/mo	3,572	21,339	Gal/yr	Turbine Starter Engines	8.26	10.57	0.68	3.22	0.78	2.11	0.17	0.00	0.00	0.49	0.61	0.72	Hrs/mo	212.6	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.70	0.50	7.20	0.60	0.50	0.50	2.00	0.00	1.30	0.55	0.30	1.70	Gal/mo	15.9	1,406	Gal/yr	P-18 -Em FW Pump	1.00	1.00	0.00	1.00	0.00	3.00	1.00	0.00	3.00	1.00	2.00	2.00	Hrs/mo	15.0	90	Hrs/yr	Tank Throughputs:																	V-08	44,080.9	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	116,587.9	N/A	Bbls/yr	Produced Gas	29,895.5	36,777.0	14,720.0	283.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	81.66	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal	87 RB													Gal/mo	0.00	N/A	Tons/yr ROC at 8.64 lb/gal	Z-Sol													Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lb/gal	Transbeam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal	Sigma Thinner 80-53													Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal	Sigma Thinner 81-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal	Carboline Thinner													Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal	Solvent Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.59	Tons/yr ROC	Coatings Total	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	2.25	N/A	Gal/yr	Boats:																	Crew Boat Fuel:	2,286	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,980	1,856	2,779	2,563	Gal/mo	23,141	N/A	Gal/yr	Work Boat Fuel:	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	2,809	Gal/mo	28,101	N/A	Gal/yr	Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																					
Back-up Generator:G4	0.70	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	MGal/mo	4.27	32.13	MGal/yr	North Crane	39.00	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	Gal/mo	373.0	N/A	Gal/yr	South Crane	309.00	527.00	348.00	508.00	267.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	Gal/mo	3,190.0	N/A	Gal/yr	Crane Total	348.00	576.00	419.00	508.00	339.00	0.00	210.00	195.00	189.00	144.00	295.00	349.00	Gal/mo	3,572	21,339	Gal/yr	Turbine Starter Engines	8.26	10.57	0.68	3.22	0.78	2.11	0.17	0.00	0.00	0.49	0.61	0.72	Hrs/mo	212.6	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.70	0.50	7.20	0.60	0.50	0.50	2.00	0.00	1.30	0.55	0.30	1.70	Gal/mo	15.9	1,406	Gal/yr	P-18 -Em FW Pump	1.00	1.00	0.00	1.00	0.00	3.00	1.00	0.00	3.00	1.00	2.00	2.00	Hrs/mo	15.0	90	Hrs/yr	Tank Throughputs:																	V-08	44,080.9	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	116,587.9	N/A	Bbls/yr	Produced Gas	29,895.5	36,777.0	14,720.0	283.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	81.66	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal	87 RB													Gal/mo	0.00	N/A	Tons/yr ROC at 8.64 lb/gal	Z-Sol													Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lb/gal	Transbeam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal	Sigma Thinner 80-53													Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal	Sigma Thinner 81-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal	Carboline Thinner													Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal	Solvent Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.59	Tons/yr ROC	Coatings Total	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	2.25	N/A	Gal/yr	Boats:																	Crew Boat Fuel:	2,286	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,980	1,856	2,779	2,563	Gal/mo	23,141	N/A	Gal/yr	Work Boat Fuel:	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	2,809	Gal/mo	28,101	N/A	Gal/yr	Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																						
North Crane	39.00	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	Gal/mo	373.0	N/A	Gal/yr	South Crane	309.00	527.00	348.00	508.00	267.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	Gal/mo	3,190.0	N/A	Gal/yr	Crane Total	348.00	576.00	419.00	508.00	339.00	0.00	210.00	195.00	189.00	144.00	295.00	349.00	Gal/mo	3,572	21,339	Gal/yr	Turbine Starter Engines	8.26	10.57	0.68	3.22	0.78	2.11	0.17	0.00	0.00	0.49	0.61	0.72	Hrs/mo	212.6	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.70	0.50	7.20	0.60	0.50	0.50	2.00	0.00	1.30	0.55	0.30	1.70	Gal/mo	15.9	1,406	Gal/yr	P-18 -Em FW Pump	1.00	1.00	0.00	1.00	0.00	3.00	1.00	0.00	3.00	1.00	2.00	2.00	Hrs/mo	15.0	90	Hrs/yr	Tank Throughputs:																	V-08	44,080.9	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	116,587.9	N/A	Bbls/yr	Produced Gas	29,895.5	36,777.0	14,720.0	283.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	81.66	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal	87 RB													Gal/mo	0.00	N/A	Tons/yr ROC at 8.64 lb/gal	Z-Sol													Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lb/gal	Transbeam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal	Sigma Thinner 80-53													Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal	Sigma Thinner 81-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal	Carboline Thinner													Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal	Solvent Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.59	Tons/yr ROC	Coatings Total	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	2.25	N/A	Gal/yr	Boats:																	Crew Boat Fuel:	2,286	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,980	1,856	2,779	2,563	Gal/mo	23,141	N/A	Gal/yr	Work Boat Fuel:	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	2,809	Gal/mo	28,101	N/A	Gal/yr	Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																							
South Crane	309.00	527.00	348.00	508.00	267.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	Gal/mo	3,190.0	N/A	Gal/yr	Crane Total	348.00	576.00	419.00	508.00	339.00	0.00	210.00	195.00	189.00	144.00	295.00	349.00	Gal/mo	3,572	21,339	Gal/yr	Turbine Starter Engines	8.26	10.57	0.68	3.22	0.78	2.11	0.17	0.00	0.00	0.49	0.61	0.72	Hrs/mo	212.6	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.70	0.50	7.20	0.60	0.50	0.50	2.00	0.00	1.30	0.55	0.30	1.70	Gal/mo	15.9	1,406	Gal/yr	P-18 -Em FW Pump	1.00	1.00	0.00	1.00	0.00	3.00	1.00	0.00	3.00	1.00	2.00	2.00	Hrs/mo	15.0	90	Hrs/yr	Tank Throughputs:																	V-08	44,080.9	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	116,587.9	N/A	Bbls/yr	Produced Gas	29,895.5	36,777.0	14,720.0	283.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	81.66	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal	87 RB													Gal/mo	0.00	N/A	Tons/yr ROC at 8.64 lb/gal	Z-Sol													Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lb/gal	Transbeam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal	Sigma Thinner 80-53													Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal	Sigma Thinner 81-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal	Carboline Thinner													Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal	Solvent Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.59	Tons/yr ROC	Coatings Total	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	2.25	N/A	Gal/yr	Boats:																	Crew Boat Fuel:	2,286	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,980	1,856	2,779	2,563	Gal/mo	23,141	N/A	Gal/yr	Work Boat Fuel:	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	2,809	Gal/mo	28,101	N/A	Gal/yr	Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																								
Crane Total	348.00	576.00	419.00	508.00	339.00	0.00	210.00	195.00	189.00	144.00	295.00	349.00	Gal/mo	3,572	21,339	Gal/yr	Turbine Starter Engines	8.26	10.57	0.68	3.22	0.78	2.11	0.17	0.00	0.00	0.49	0.61	0.72	Hrs/mo	212.6	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.70	0.50	7.20	0.60	0.50	0.50	2.00	0.00	1.30	0.55	0.30	1.70	Gal/mo	15.9	1,406	Gal/yr	P-18 -Em FW Pump	1.00	1.00	0.00	1.00	0.00	3.00	1.00	0.00	3.00	1.00	2.00	2.00	Hrs/mo	15.0	90	Hrs/yr	Tank Throughputs:																	V-08	44,080.9	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	116,587.9	N/A	Bbls/yr	Produced Gas	29,895.5	36,777.0	14,720.0	283.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	81.66	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal	87 RB													Gal/mo	0.00	N/A	Tons/yr ROC at 8.64 lb/gal	Z-Sol													Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lb/gal	Transbeam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal	Sigma Thinner 80-53													Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal	Sigma Thinner 81-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal	Carboline Thinner													Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal	Solvent Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.59	Tons/yr ROC	Coatings Total	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	2.25	N/A	Gal/yr	Boats:																	Crew Boat Fuel:	2,286	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,980	1,856	2,779	2,563	Gal/mo	23,141	N/A	Gal/yr	Work Boat Fuel:	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	2,809	Gal/mo	28,101	N/A	Gal/yr	Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																									
Turbine Starter Engines	8.26	10.57	0.68	3.22	0.78	2.11	0.17	0.00	0.00	0.49	0.61	0.72	Hrs/mo	212.6	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.70	0.50	7.20	0.60	0.50	0.50	2.00	0.00	1.30	0.55	0.30	1.70	Gal/mo	15.9	1,406	Gal/yr	P-18 -Em FW Pump	1.00	1.00	0.00	1.00	0.00	3.00	1.00	0.00	3.00	1.00	2.00	2.00	Hrs/mo	15.0	90	Hrs/yr	Tank Throughputs:																	V-08	44,080.9	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	116,587.9	N/A	Bbls/yr	Produced Gas	29,895.5	36,777.0	14,720.0	283.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	81.66	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal	87 RB													Gal/mo	0.00	N/A	Tons/yr ROC at 8.64 lb/gal	Z-Sol													Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lb/gal	Transbeam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal	Sigma Thinner 80-53													Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal	Sigma Thinner 81-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal	Carboline Thinner													Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal	Solvent Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.59	Tons/yr ROC	Coatings Total	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	2.25	N/A	Gal/yr	Boats:																	Crew Boat Fuel:	2,286	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,980	1,856	2,779	2,563	Gal/mo	23,141	N/A	Gal/yr	Work Boat Fuel:	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	2,809	Gal/mo	28,101	N/A	Gal/yr	Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																										
Boom Boat (VP)	0.70	0.50	7.20	0.60	0.50	0.50	2.00	0.00	1.30	0.55	0.30	1.70	Gal/mo	15.9	1,406	Gal/yr	P-18 -Em FW Pump	1.00	1.00	0.00	1.00	0.00	3.00	1.00	0.00	3.00	1.00	2.00	2.00	Hrs/mo	15.0	90	Hrs/yr	Tank Throughputs:																	V-08	44,080.9	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	116,587.9	N/A	Bbls/yr	Produced Gas	29,895.5	36,777.0	14,720.0	283.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	81.66	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal	87 RB													Gal/mo	0.00	N/A	Tons/yr ROC at 8.64 lb/gal	Z-Sol													Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lb/gal	Transbeam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal	Sigma Thinner 80-53													Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal	Sigma Thinner 81-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal	Carboline Thinner													Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal	Solvent Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.59	Tons/yr ROC	Coatings Total	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	2.25	N/A	Gal/yr	Boats:																	Crew Boat Fuel:	2,286	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,980	1,856	2,779	2,563	Gal/mo	23,141	N/A	Gal/yr	Work Boat Fuel:	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	2,809	Gal/mo	28,101	N/A	Gal/yr	Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																											
P-18 -Em FW Pump	1.00	1.00	0.00	1.00	0.00	3.00	1.00	0.00	3.00	1.00	2.00	2.00	Hrs/mo	15.0	90	Hrs/yr	Tank Throughputs:																	V-08	44,080.9	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	116,587.9	N/A	Bbls/yr	Produced Gas	29,895.5	36,777.0	14,720.0	283.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	81.66	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal	87 RB													Gal/mo	0.00	N/A	Tons/yr ROC at 8.64 lb/gal	Z-Sol													Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lb/gal	Transbeam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal	Sigma Thinner 80-53													Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal	Sigma Thinner 81-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal	Carboline Thinner													Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal	Solvent Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.59	Tons/yr ROC	Coatings Total	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	2.25	N/A	Gal/yr	Boats:																	Crew Boat Fuel:	2,286	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,980	1,856	2,779	2,563	Gal/mo	23,141	N/A	Gal/yr	Work Boat Fuel:	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	2,809	Gal/mo	28,101	N/A	Gal/yr	Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																												
Tank Throughputs:																	V-08	44,080.9	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	116,587.9	N/A	Bbls/yr	Produced Gas	29,895.5	36,777.0	14,720.0	283.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	81.66	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal	87 RB													Gal/mo	0.00	N/A	Tons/yr ROC at 8.64 lb/gal	Z-Sol													Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lb/gal	Transbeam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal	Sigma Thinner 80-53													Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal	Sigma Thinner 81-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal	Carboline Thinner													Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal	Solvent Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.59	Tons/yr ROC	Coatings Total	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	2.25	N/A	Gal/yr	Boats:																	Crew Boat Fuel:	2,286	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,980	1,856	2,779	2,563	Gal/mo	23,141	N/A	Gal/yr	Work Boat Fuel:	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	2,809	Gal/mo	28,101	N/A	Gal/yr	Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																													
V-08	44,080.9	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	116,587.9	N/A	Bbls/yr	Produced Gas	29,895.5	36,777.0	14,720.0	283.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	81.66	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal	87 RB													Gal/mo	0.00	N/A	Tons/yr ROC at 8.64 lb/gal	Z-Sol													Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lb/gal	Transbeam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal	Sigma Thinner 80-53													Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal	Sigma Thinner 81-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal	Carboline Thinner													Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal	Solvent Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.59	Tons/yr ROC	Coatings Total	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	2.25	N/A	Gal/yr	Boats:																	Crew Boat Fuel:	2,286	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,980	1,856	2,779	2,563	Gal/mo	23,141	N/A	Gal/yr	Work Boat Fuel:	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	2,809	Gal/mo	28,101	N/A	Gal/yr	Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																														
Produced Gas	29,895.5	36,777.0	14,720.0	283.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	81.66	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal	87 RB													Gal/mo	0.00	N/A	Tons/yr ROC at 8.64 lb/gal	Z-Sol													Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lb/gal	Transbeam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal	Sigma Thinner 80-53													Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal	Sigma Thinner 81-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal	Carboline Thinner													Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal	Solvent Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.59	Tons/yr ROC	Coatings Total	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	2.25	N/A	Gal/yr	Boats:																	Crew Boat Fuel:	2,286	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,980	1,856	2,779	2,563	Gal/mo	23,141	N/A	Gal/yr	Work Boat Fuel:	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	2,809	Gal/mo	28,101	N/A	Gal/yr	Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																															
Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal	87 RB													Gal/mo	0.00	N/A	Tons/yr ROC at 8.64 lb/gal	Z-Sol													Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lb/gal	Transbeam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal	Sigma Thinner 80-53													Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal	Sigma Thinner 81-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal	Carboline Thinner													Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal	Solvent Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.59	Tons/yr ROC	Coatings Total	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	2.25	N/A	Gal/yr	Boats:																	Crew Boat Fuel:	2,286	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,980	1,856	2,779	2,563	Gal/mo	23,141	N/A	Gal/yr	Work Boat Fuel:	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	2,809	Gal/mo	28,101	N/A	Gal/yr	Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																
Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal	87 RB													Gal/mo	0.00	N/A	Tons/yr ROC at 8.64 lb/gal	Z-Sol													Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lb/gal	Transbeam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal	Sigma Thinner 80-53													Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal	Sigma Thinner 81-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal	Carboline Thinner													Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal	Solvent Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.59	Tons/yr ROC	Coatings Total	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	2.25	N/A	Gal/yr	Boats:																	Crew Boat Fuel:	2,286	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,980	1,856	2,779	2,563	Gal/mo	23,141	N/A	Gal/yr	Work Boat Fuel:	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	2,809	Gal/mo	28,101	N/A	Gal/yr	Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																	
87 RB													Gal/mo	0.00	N/A	Tons/yr ROC at 8.64 lb/gal	Z-Sol													Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lb/gal	Transbeam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal	Sigma Thinner 80-53													Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal	Sigma Thinner 81-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal	Carboline Thinner													Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal	Solvent Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.59	Tons/yr ROC	Coatings Total	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	2.25	N/A	Gal/yr	Boats:																	Crew Boat Fuel:	2,286	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,980	1,856	2,779	2,563	Gal/mo	23,141	N/A	Gal/yr	Work Boat Fuel:	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	2,809	Gal/mo	28,101	N/A	Gal/yr	Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
Z-Sol													Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lb/gal	Transbeam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal	Sigma Thinner 80-53													Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal	Sigma Thinner 81-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal	Carboline Thinner													Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal	Solvent Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.59	Tons/yr ROC	Coatings Total	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	2.25	N/A	Gal/yr	Boats:																	Crew Boat Fuel:	2,286	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,980	1,856	2,779	2,563	Gal/mo	23,141	N/A	Gal/yr	Work Boat Fuel:	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	2,809	Gal/mo	28,101	N/A	Gal/yr	Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																			
Transbeam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal	Sigma Thinner 80-53													Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal	Sigma Thinner 81-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal	Carboline Thinner													Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal	Solvent Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.59	Tons/yr ROC	Coatings Total	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	2.25	N/A	Gal/yr	Boats:																	Crew Boat Fuel:	2,286	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,980	1,856	2,779	2,563	Gal/mo	23,141	N/A	Gal/yr	Work Boat Fuel:	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	2,809	Gal/mo	28,101	N/A	Gal/yr	Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																				
Sigma Thinner 80-53													Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal	Sigma Thinner 81-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal	Carboline Thinner													Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal	Solvent Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.59	Tons/yr ROC	Coatings Total	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	2.25	N/A	Gal/yr	Boats:																	Crew Boat Fuel:	2,286	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,980	1,856	2,779	2,563	Gal/mo	23,141	N/A	Gal/yr	Work Boat Fuel:	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	2,809	Gal/mo	28,101	N/A	Gal/yr	Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																					
Sigma Thinner 81-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal	Carboline Thinner													Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal	Solvent Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.59	Tons/yr ROC	Coatings Total	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	2.25	N/A	Gal/yr	Boats:																	Crew Boat Fuel:	2,286	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,980	1,856	2,779	2,563	Gal/mo	23,141	N/A	Gal/yr	Work Boat Fuel:	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	2,809	Gal/mo	28,101	N/A	Gal/yr	Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																						
Carboline Thinner													Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal	Solvent Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.59	Tons/yr ROC	Coatings Total	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	2.25	N/A	Gal/yr	Boats:																	Crew Boat Fuel:	2,286	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,980	1,856	2,779	2,563	Gal/mo	23,141	N/A	Gal/yr	Work Boat Fuel:	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	2,809	Gal/mo	28,101	N/A	Gal/yr	Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																							
Solvent Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.59	Tons/yr ROC	Coatings Total	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	2.25	N/A	Gal/yr	Boats:																	Crew Boat Fuel:	2,286	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,980	1,856	2,779	2,563	Gal/mo	23,141	N/A	Gal/yr	Work Boat Fuel:	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	2,809	Gal/mo	28,101	N/A	Gal/yr	Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																								
Coatings Total	2.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	2.25	N/A	Gal/yr	Boats:																	Crew Boat Fuel:	2,286	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,980	1,856	2,779	2,563	Gal/mo	23,141	N/A	Gal/yr	Work Boat Fuel:	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	2,809	Gal/mo	28,101	N/A	Gal/yr	Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																									
Boats:																	Crew Boat Fuel:	2,286	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,980	1,856	2,779	2,563	Gal/mo	23,141	N/A	Gal/yr	Work Boat Fuel:	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	2,809	Gal/mo	28,101	N/A	Gal/yr	Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																										
Crew Boat Fuel:	2,286	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,980	1,856	2,779	2,563	Gal/mo	23,141	N/A	Gal/yr	Work Boat Fuel:	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	2,809	Gal/mo	28,101	N/A	Gal/yr	Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																											
Work Boat Fuel:	2,487	1,659	1,828	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,896	2,809	Gal/mo	28,101	N/A	Gal/yr	Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																												
Total Boats Fuel	4,783	3,190	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	Gal/mo	49,242	167,100	Gal/yr	Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																													
Boat Emissions																	ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																														
ROC	0.08	0.05	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	Tons/mo	0.82	2.77	Tons/yr at 33.15 lbs/MGal	NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																															
NOx	1.34	0.89	0.99	1.28	0.76	0.79	1.15	0.84	1.11	1.06	1.31	1.52	Tons/mo	13.81	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																
PM	0.06	0.05	0.06	0.06	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	Tons/mo	0.82	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																	
SOx	0.02	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	Tons/mo	0.18	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
CO	0.24	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	Tons/mo	2.51	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																			



**Platform Gail**  
**PTO No. 1494 Equipment Usage**  
**Rolling 12-Months Ending:**  
**Sep-18**

Equipment	Oct-17	Nov-17	Dec-17	Jan-18	Feb-18	Mar-18	Apr-18	May-18	Jun-18	Jul-18	Aug-18	Sep-18	Monthly Units	12-month Total	Permit Limit	12-Mo & Permit Units																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
Gas Consumption:																	HP Planned	0.0	0.0	0.0	184.0	131.0	0.0	94.0	90.0	0.0	0.0	88.0	0.0	MSCF/mo	0.57	N/A	MMSCF/yr	HP Pload/Purge	92.1	92.1	92.1	83.2	83.2	92.1	89.1	92.1	89.1	92.1	89.1	89.1	MSCF/mo	1.09	N/A	MMSCF/yr	<b>HP Planned &amp; PIP</b>	<b>92.1</b>	<b>92.1</b>	<b>92.1</b>	<b>256.1</b>	<b>214.2</b>	<b>92.1</b>	<b>183.1</b>	<b>182.1</b>	<b>89.1</b>	<b>92.1</b>	<b>180.1</b>	<b>89.1</b>	<b>MSCF/mo</b>	<b>1.65</b>	<b>4.9</b>	<b>MMSCF/yr</b>	HP Unplanned	560.0	1,041.0	860.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	2.46	Exempt	MMSCF/yr	LP Planned	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	0.00	N/A	MMSCF/yr	LP Pload/Purge	144.8	144.8	144.8	144.8	130.8	144.8	140.1	79.4	0.0	0.0	0.0	0.0	MSCF/mo	1.07	N/A	MMSCF/yr	<b>LP Planned &amp; PIP</b>	<b>144.8</b>	<b>144.8</b>	<b>144.8</b>	<b>144.8</b>	<b>130.8</b>	<b>144.8</b>	<b>140.1</b>	<b>79.4</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>MSCF/mo</b>	<b>1.07</b>	<b>2.31</b>	<b>MMSCF/yr</b>	LP Unplanned	2,932.0	659.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	3.59	Exempt	MMSCF/yr	Gas Consumption:																	Turbines: G1	23.6	11.4	1.3	0.0	0.4	12.3	13.2	13.7	13.3	13.8	14.0	1.6	MMSCF/mo	118.56	N/A	MMSCF/yr	Turbines: G2	25.3	12.1	5.8	0.6	7.5	0.0	0.0	0.0	0.0	0.0	0.0	1.7	MMSCF/mo	52.96	N/A	MMSCF/yr	Turbines: G3	24.9	18.6	6.7	13.7	4.3	1.1	0.0	0.0	0.0	0.0	0.0	10.0	MMSCF/mo	79.33	N/A	MMSCF/yr	<b>Turbines @ all loads</b>	<b>73.9</b>	<b>42.2</b>	<b>13.6</b>	<b>14.3</b>	<b>12.1</b>	<b>13.3</b>	<b>13.2</b>	<b>13.7</b>	<b>13.3</b>	<b>13.8</b>	<b>14.0</b>	<b>13.2</b>	<b>MMSCF/mo</b>	<b>250.85</b>	<b>850</b>	<b>MMSCF/yr</b>	Turbine@<1000 KW	0.05	7.93	13.68	14.3	11.68	13.33	13.22	13.7	13.3	13.8	14.02	13.20	MMSCF/mo	142.46	250.0	MMSCF/yr	Diesel Use:																	Turbines: G1	0.00	0.06	0.00	0.00	0.65	0.01	0.00	0.00	0.00	0.08	0.000	0.003	MGal/mo	1.00	N/A	MGal/yr	Turbines: G2	0.83	0.00	9.74	0.00	1.25	0.00	0.00	0.00	0.02	0.000	0.000	0.029	MGal/mo	11.67	N/A	MGal/yr	Turbines: G3	0.07	0.16	0.00	0.00	0.92	0.00	0.00	0.00	0.00	0.01	0.000	0.0031	MGal/mo	1.17	N/A	MGal/yr	<b>Turbines @ all loads</b>	<b>0.9</b>	<b>0.2</b>	<b>9.7</b>	<b>0.0</b>	<b>3.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.1</b>	<b>0.00</b>	<b>0.0355</b>	<b>MGal/mo</b>	<b>14.04</b>	<b>335</b>	<b>MGal/yr</b>	Turbine@<1000 KW	0.27	0.11	9.75	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.00	0.0355	MGal/mo	11.33	160	MGal/yr	Back-up Generator:G4	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	0.08	MGal/mo	3.64	32.13	MGal/yr	North Crane	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	0.00	Gal/mo	334.0	N/A	Gal/yr	South Crane	527.00	348.00	508.00	287.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	345.00	Gal/mo	3,235.0	N/A	Gal/yr	<b>Crane Total</b>	<b>576.00</b>	<b>419.00</b>	<b>508.00</b>	<b>339.00</b>	<b>0.00</b>	<b>210.00</b>	<b>195.00</b>	<b>189.00</b>	<b>144.00</b>	<b>295.00</b>	<b>349.00</b>	<b>345.00</b>	<b>Gal/mo</b>	<b>3,569</b>	<b>21,339</b>	<b>Gal/yr</b>	Turbine Starter Engines	10.57	0.68	3.22	0.76	2.11	0.17	0.00	0.00	0.49	0.61	0.72	0.97	Hrs/mo	156.5	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.50	7.20	0.60	0.50	0.30	2.00	0.00	1.30	0.55	1.70	1.70	9.10	Gal/mo	24.3	1,406	Gal/yr	<b>P-18 -Em FW Pump</b>	<b>1.00</b>	<b>0.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>2.00</b>	<b>2.00</b>	<b>3.00</b>	<b>Hrs/mo</b>	<b>17.0</b>	<b>50</b>	<b>Hrs/yr</b>	Tank Throughputs																	V-08	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	72,507.0	N/A	Bbls/yr	Produced Gas	36,777.0	14,720.0	293.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	51.79	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lbs/gal	87 RB	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lbs/gal	Z-Sol	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lbs/gal	Transfoam Plus	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lbs/gal	Sigma Thinner 90-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.59 lbs/gal	Sigma Thinner 91-57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lbs/gal	Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lbs/gal	<b>Solvent Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>9.89</b>	<b>Tons/yr ROC</b>	<b>Coatings Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>N/A</b>	<b>Gal/yr</b>	Boats:																	Crew Boat Fuel:	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,990	1,856	2,779	2,593	3,829	Gal/mo	24,674	N/A	Gal/yr	Work Boat Fuel:	1,659	1,628	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,866	2,809	4,148	Gal/mo	27,762	N/A	Gal/yr	<b>Total Boats Fuel</b>	<b>3,190</b>	<b>3,315</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,646</b>	<b>5,402</b>	<b>7,977</b>	<b>Gal/mo</b>	<b>52,437</b>	<b>167,100</b>	<b>Gal/yr</b>	Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal
HP Planned	0.0	0.0	0.0	184.0	131.0	0.0	94.0	90.0	0.0	0.0	88.0	0.0	MSCF/mo	0.57	N/A	MMSCF/yr	HP Pload/Purge	92.1	92.1	92.1	83.2	83.2	92.1	89.1	92.1	89.1	92.1	89.1	89.1	MSCF/mo	1.09	N/A	MMSCF/yr	<b>HP Planned &amp; PIP</b>	<b>92.1</b>	<b>92.1</b>	<b>92.1</b>	<b>256.1</b>	<b>214.2</b>	<b>92.1</b>	<b>183.1</b>	<b>182.1</b>	<b>89.1</b>	<b>92.1</b>	<b>180.1</b>	<b>89.1</b>	<b>MSCF/mo</b>	<b>1.65</b>	<b>4.9</b>	<b>MMSCF/yr</b>	HP Unplanned	560.0	1,041.0	860.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	2.46	Exempt	MMSCF/yr	LP Planned	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	0.00	N/A	MMSCF/yr	LP Pload/Purge	144.8	144.8	144.8	144.8	130.8	144.8	140.1	79.4	0.0	0.0	0.0	0.0	MSCF/mo	1.07	N/A	MMSCF/yr	<b>LP Planned &amp; PIP</b>	<b>144.8</b>	<b>144.8</b>	<b>144.8</b>	<b>144.8</b>	<b>130.8</b>	<b>144.8</b>	<b>140.1</b>	<b>79.4</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>MSCF/mo</b>	<b>1.07</b>	<b>2.31</b>	<b>MMSCF/yr</b>	LP Unplanned	2,932.0	659.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	3.59	Exempt	MMSCF/yr	Gas Consumption:																	Turbines: G1	23.6	11.4	1.3	0.0	0.4	12.3	13.2	13.7	13.3	13.8	14.0	1.6	MMSCF/mo	118.56	N/A	MMSCF/yr	Turbines: G2	25.3	12.1	5.8	0.6	7.5	0.0	0.0	0.0	0.0	0.0	0.0	1.7	MMSCF/mo	52.96	N/A	MMSCF/yr	Turbines: G3	24.9	18.6	6.7	13.7	4.3	1.1	0.0	0.0	0.0	0.0	0.0	10.0	MMSCF/mo	79.33	N/A	MMSCF/yr	<b>Turbines @ all loads</b>	<b>73.9</b>	<b>42.2</b>	<b>13.6</b>	<b>14.3</b>	<b>12.1</b>	<b>13.3</b>	<b>13.2</b>	<b>13.7</b>	<b>13.3</b>	<b>13.8</b>	<b>14.0</b>	<b>13.2</b>	<b>MMSCF/mo</b>	<b>250.85</b>	<b>850</b>	<b>MMSCF/yr</b>	Turbine@<1000 KW	0.05	7.93	13.68	14.3	11.68	13.33	13.22	13.7	13.3	13.8	14.02	13.20	MMSCF/mo	142.46	250.0	MMSCF/yr	Diesel Use:																	Turbines: G1	0.00	0.06	0.00	0.00	0.65	0.01	0.00	0.00	0.00	0.08	0.000	0.003	MGal/mo	1.00	N/A	MGal/yr	Turbines: G2	0.83	0.00	9.74	0.00	1.25	0.00	0.00	0.00	0.02	0.000	0.000	0.029	MGal/mo	11.67	N/A	MGal/yr	Turbines: G3	0.07	0.16	0.00	0.00	0.92	0.00	0.00	0.00	0.00	0.01	0.000	0.0031	MGal/mo	1.17	N/A	MGal/yr	<b>Turbines @ all loads</b>	<b>0.9</b>	<b>0.2</b>	<b>9.7</b>	<b>0.0</b>	<b>3.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.1</b>	<b>0.00</b>	<b>0.0355</b>	<b>MGal/mo</b>	<b>14.04</b>	<b>335</b>	<b>MGal/yr</b>	Turbine@<1000 KW	0.27	0.11	9.75	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.00	0.0355	MGal/mo	11.33	160	MGal/yr	Back-up Generator:G4	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	0.08	MGal/mo	3.64	32.13	MGal/yr	North Crane	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	0.00	Gal/mo	334.0	N/A	Gal/yr	South Crane	527.00	348.00	508.00	287.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	345.00	Gal/mo	3,235.0	N/A	Gal/yr	<b>Crane Total</b>	<b>576.00</b>	<b>419.00</b>	<b>508.00</b>	<b>339.00</b>	<b>0.00</b>	<b>210.00</b>	<b>195.00</b>	<b>189.00</b>	<b>144.00</b>	<b>295.00</b>	<b>349.00</b>	<b>345.00</b>	<b>Gal/mo</b>	<b>3,569</b>	<b>21,339</b>	<b>Gal/yr</b>	Turbine Starter Engines	10.57	0.68	3.22	0.76	2.11	0.17	0.00	0.00	0.49	0.61	0.72	0.97	Hrs/mo	156.5	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.50	7.20	0.60	0.50	0.30	2.00	0.00	1.30	0.55	1.70	1.70	9.10	Gal/mo	24.3	1,406	Gal/yr	<b>P-18 -Em FW Pump</b>	<b>1.00</b>	<b>0.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>2.00</b>	<b>2.00</b>	<b>3.00</b>	<b>Hrs/mo</b>	<b>17.0</b>	<b>50</b>	<b>Hrs/yr</b>	Tank Throughputs																	V-08	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	72,507.0	N/A	Bbls/yr	Produced Gas	36,777.0	14,720.0	293.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	51.79	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lbs/gal	87 RB	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lbs/gal	Z-Sol	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lbs/gal	Transfoam Plus	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lbs/gal	Sigma Thinner 90-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.59 lbs/gal	Sigma Thinner 91-57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lbs/gal	Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lbs/gal	<b>Solvent Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>9.89</b>	<b>Tons/yr ROC</b>	<b>Coatings Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>N/A</b>	<b>Gal/yr</b>	Boats:																	Crew Boat Fuel:	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,990	1,856	2,779	2,593	3,829	Gal/mo	24,674	N/A	Gal/yr	Work Boat Fuel:	1,659	1,628	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,866	2,809	4,148	Gal/mo	27,762	N/A	Gal/yr	<b>Total Boats Fuel</b>	<b>3,190</b>	<b>3,315</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,646</b>	<b>5,402</b>	<b>7,977</b>	<b>Gal/mo</b>	<b>52,437</b>	<b>167,100</b>	<b>Gal/yr</b>	Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																	
HP Pload/Purge	92.1	92.1	92.1	83.2	83.2	92.1	89.1	92.1	89.1	92.1	89.1	89.1	MSCF/mo	1.09	N/A	MMSCF/yr	<b>HP Planned &amp; PIP</b>	<b>92.1</b>	<b>92.1</b>	<b>92.1</b>	<b>256.1</b>	<b>214.2</b>	<b>92.1</b>	<b>183.1</b>	<b>182.1</b>	<b>89.1</b>	<b>92.1</b>	<b>180.1</b>	<b>89.1</b>	<b>MSCF/mo</b>	<b>1.65</b>	<b>4.9</b>	<b>MMSCF/yr</b>	HP Unplanned	560.0	1,041.0	860.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	2.46	Exempt	MMSCF/yr	LP Planned	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	0.00	N/A	MMSCF/yr	LP Pload/Purge	144.8	144.8	144.8	144.8	130.8	144.8	140.1	79.4	0.0	0.0	0.0	0.0	MSCF/mo	1.07	N/A	MMSCF/yr	<b>LP Planned &amp; PIP</b>	<b>144.8</b>	<b>144.8</b>	<b>144.8</b>	<b>144.8</b>	<b>130.8</b>	<b>144.8</b>	<b>140.1</b>	<b>79.4</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>MSCF/mo</b>	<b>1.07</b>	<b>2.31</b>	<b>MMSCF/yr</b>	LP Unplanned	2,932.0	659.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	3.59	Exempt	MMSCF/yr	Gas Consumption:																	Turbines: G1	23.6	11.4	1.3	0.0	0.4	12.3	13.2	13.7	13.3	13.8	14.0	1.6	MMSCF/mo	118.56	N/A	MMSCF/yr	Turbines: G2	25.3	12.1	5.8	0.6	7.5	0.0	0.0	0.0	0.0	0.0	0.0	1.7	MMSCF/mo	52.96	N/A	MMSCF/yr	Turbines: G3	24.9	18.6	6.7	13.7	4.3	1.1	0.0	0.0	0.0	0.0	0.0	10.0	MMSCF/mo	79.33	N/A	MMSCF/yr	<b>Turbines @ all loads</b>	<b>73.9</b>	<b>42.2</b>	<b>13.6</b>	<b>14.3</b>	<b>12.1</b>	<b>13.3</b>	<b>13.2</b>	<b>13.7</b>	<b>13.3</b>	<b>13.8</b>	<b>14.0</b>	<b>13.2</b>	<b>MMSCF/mo</b>	<b>250.85</b>	<b>850</b>	<b>MMSCF/yr</b>	Turbine@<1000 KW	0.05	7.93	13.68	14.3	11.68	13.33	13.22	13.7	13.3	13.8	14.02	13.20	MMSCF/mo	142.46	250.0	MMSCF/yr	Diesel Use:																	Turbines: G1	0.00	0.06	0.00	0.00	0.65	0.01	0.00	0.00	0.00	0.08	0.000	0.003	MGal/mo	1.00	N/A	MGal/yr	Turbines: G2	0.83	0.00	9.74	0.00	1.25	0.00	0.00	0.00	0.02	0.000	0.000	0.029	MGal/mo	11.67	N/A	MGal/yr	Turbines: G3	0.07	0.16	0.00	0.00	0.92	0.00	0.00	0.00	0.00	0.01	0.000	0.0031	MGal/mo	1.17	N/A	MGal/yr	<b>Turbines @ all loads</b>	<b>0.9</b>	<b>0.2</b>	<b>9.7</b>	<b>0.0</b>	<b>3.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.1</b>	<b>0.00</b>	<b>0.0355</b>	<b>MGal/mo</b>	<b>14.04</b>	<b>335</b>	<b>MGal/yr</b>	Turbine@<1000 KW	0.27	0.11	9.75	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.00	0.0355	MGal/mo	11.33	160	MGal/yr	Back-up Generator:G4	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	0.08	MGal/mo	3.64	32.13	MGal/yr	North Crane	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	0.00	Gal/mo	334.0	N/A	Gal/yr	South Crane	527.00	348.00	508.00	287.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	345.00	Gal/mo	3,235.0	N/A	Gal/yr	<b>Crane Total</b>	<b>576.00</b>	<b>419.00</b>	<b>508.00</b>	<b>339.00</b>	<b>0.00</b>	<b>210.00</b>	<b>195.00</b>	<b>189.00</b>	<b>144.00</b>	<b>295.00</b>	<b>349.00</b>	<b>345.00</b>	<b>Gal/mo</b>	<b>3,569</b>	<b>21,339</b>	<b>Gal/yr</b>	Turbine Starter Engines	10.57	0.68	3.22	0.76	2.11	0.17	0.00	0.00	0.49	0.61	0.72	0.97	Hrs/mo	156.5	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.50	7.20	0.60	0.50	0.30	2.00	0.00	1.30	0.55	1.70	1.70	9.10	Gal/mo	24.3	1,406	Gal/yr	<b>P-18 -Em FW Pump</b>	<b>1.00</b>	<b>0.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>2.00</b>	<b>2.00</b>	<b>3.00</b>	<b>Hrs/mo</b>	<b>17.0</b>	<b>50</b>	<b>Hrs/yr</b>	Tank Throughputs																	V-08	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	72,507.0	N/A	Bbls/yr	Produced Gas	36,777.0	14,720.0	293.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	51.79	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lbs/gal	87 RB	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lbs/gal	Z-Sol	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lbs/gal	Transfoam Plus	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lbs/gal	Sigma Thinner 90-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.59 lbs/gal	Sigma Thinner 91-57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lbs/gal	Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lbs/gal	<b>Solvent Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>9.89</b>	<b>Tons/yr ROC</b>	<b>Coatings Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>N/A</b>	<b>Gal/yr</b>	Boats:																	Crew Boat Fuel:	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,990	1,856	2,779	2,593	3,829	Gal/mo	24,674	N/A	Gal/yr	Work Boat Fuel:	1,659	1,628	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,866	2,809	4,148	Gal/mo	27,762	N/A	Gal/yr	<b>Total Boats Fuel</b>	<b>3,190</b>	<b>3,315</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,646</b>	<b>5,402</b>	<b>7,977</b>	<b>Gal/mo</b>	<b>52,437</b>	<b>167,100</b>	<b>Gal/yr</b>	Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																		
<b>HP Planned &amp; PIP</b>	<b>92.1</b>	<b>92.1</b>	<b>92.1</b>	<b>256.1</b>	<b>214.2</b>	<b>92.1</b>	<b>183.1</b>	<b>182.1</b>	<b>89.1</b>	<b>92.1</b>	<b>180.1</b>	<b>89.1</b>	<b>MSCF/mo</b>	<b>1.65</b>	<b>4.9</b>	<b>MMSCF/yr</b>	HP Unplanned	560.0	1,041.0	860.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	2.46	Exempt	MMSCF/yr	LP Planned	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	0.00	N/A	MMSCF/yr	LP Pload/Purge	144.8	144.8	144.8	144.8	130.8	144.8	140.1	79.4	0.0	0.0	0.0	0.0	MSCF/mo	1.07	N/A	MMSCF/yr	<b>LP Planned &amp; PIP</b>	<b>144.8</b>	<b>144.8</b>	<b>144.8</b>	<b>144.8</b>	<b>130.8</b>	<b>144.8</b>	<b>140.1</b>	<b>79.4</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>MSCF/mo</b>	<b>1.07</b>	<b>2.31</b>	<b>MMSCF/yr</b>	LP Unplanned	2,932.0	659.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	3.59	Exempt	MMSCF/yr	Gas Consumption:																	Turbines: G1	23.6	11.4	1.3	0.0	0.4	12.3	13.2	13.7	13.3	13.8	14.0	1.6	MMSCF/mo	118.56	N/A	MMSCF/yr	Turbines: G2	25.3	12.1	5.8	0.6	7.5	0.0	0.0	0.0	0.0	0.0	0.0	1.7	MMSCF/mo	52.96	N/A	MMSCF/yr	Turbines: G3	24.9	18.6	6.7	13.7	4.3	1.1	0.0	0.0	0.0	0.0	0.0	10.0	MMSCF/mo	79.33	N/A	MMSCF/yr	<b>Turbines @ all loads</b>	<b>73.9</b>	<b>42.2</b>	<b>13.6</b>	<b>14.3</b>	<b>12.1</b>	<b>13.3</b>	<b>13.2</b>	<b>13.7</b>	<b>13.3</b>	<b>13.8</b>	<b>14.0</b>	<b>13.2</b>	<b>MMSCF/mo</b>	<b>250.85</b>	<b>850</b>	<b>MMSCF/yr</b>	Turbine@<1000 KW	0.05	7.93	13.68	14.3	11.68	13.33	13.22	13.7	13.3	13.8	14.02	13.20	MMSCF/mo	142.46	250.0	MMSCF/yr	Diesel Use:																	Turbines: G1	0.00	0.06	0.00	0.00	0.65	0.01	0.00	0.00	0.00	0.08	0.000	0.003	MGal/mo	1.00	N/A	MGal/yr	Turbines: G2	0.83	0.00	9.74	0.00	1.25	0.00	0.00	0.00	0.02	0.000	0.000	0.029	MGal/mo	11.67	N/A	MGal/yr	Turbines: G3	0.07	0.16	0.00	0.00	0.92	0.00	0.00	0.00	0.00	0.01	0.000	0.0031	MGal/mo	1.17	N/A	MGal/yr	<b>Turbines @ all loads</b>	<b>0.9</b>	<b>0.2</b>	<b>9.7</b>	<b>0.0</b>	<b>3.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.1</b>	<b>0.00</b>	<b>0.0355</b>	<b>MGal/mo</b>	<b>14.04</b>	<b>335</b>	<b>MGal/yr</b>	Turbine@<1000 KW	0.27	0.11	9.75	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.00	0.0355	MGal/mo	11.33	160	MGal/yr	Back-up Generator:G4	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	0.08	MGal/mo	3.64	32.13	MGal/yr	North Crane	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	0.00	Gal/mo	334.0	N/A	Gal/yr	South Crane	527.00	348.00	508.00	287.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	345.00	Gal/mo	3,235.0	N/A	Gal/yr	<b>Crane Total</b>	<b>576.00</b>	<b>419.00</b>	<b>508.00</b>	<b>339.00</b>	<b>0.00</b>	<b>210.00</b>	<b>195.00</b>	<b>189.00</b>	<b>144.00</b>	<b>295.00</b>	<b>349.00</b>	<b>345.00</b>	<b>Gal/mo</b>	<b>3,569</b>	<b>21,339</b>	<b>Gal/yr</b>	Turbine Starter Engines	10.57	0.68	3.22	0.76	2.11	0.17	0.00	0.00	0.49	0.61	0.72	0.97	Hrs/mo	156.5	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.50	7.20	0.60	0.50	0.30	2.00	0.00	1.30	0.55	1.70	1.70	9.10	Gal/mo	24.3	1,406	Gal/yr	<b>P-18 -Em FW Pump</b>	<b>1.00</b>	<b>0.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>2.00</b>	<b>2.00</b>	<b>3.00</b>	<b>Hrs/mo</b>	<b>17.0</b>	<b>50</b>	<b>Hrs/yr</b>	Tank Throughputs																	V-08	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	72,507.0	N/A	Bbls/yr	Produced Gas	36,777.0	14,720.0	293.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	51.79	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lbs/gal	87 RB	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lbs/gal	Z-Sol	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lbs/gal	Transfoam Plus	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lbs/gal	Sigma Thinner 90-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.59 lbs/gal	Sigma Thinner 91-57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lbs/gal	Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lbs/gal	<b>Solvent Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>9.89</b>	<b>Tons/yr ROC</b>	<b>Coatings Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>N/A</b>	<b>Gal/yr</b>	Boats:																	Crew Boat Fuel:	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,990	1,856	2,779	2,593	3,829	Gal/mo	24,674	N/A	Gal/yr	Work Boat Fuel:	1,659	1,628	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,866	2,809	4,148	Gal/mo	27,762	N/A	Gal/yr	<b>Total Boats Fuel</b>	<b>3,190</b>	<b>3,315</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,646</b>	<b>5,402</b>	<b>7,977</b>	<b>Gal/mo</b>	<b>52,437</b>	<b>167,100</b>	<b>Gal/yr</b>	Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																			
HP Unplanned	560.0	1,041.0	860.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	2.46	Exempt	MMSCF/yr	LP Planned	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	0.00	N/A	MMSCF/yr	LP Pload/Purge	144.8	144.8	144.8	144.8	130.8	144.8	140.1	79.4	0.0	0.0	0.0	0.0	MSCF/mo	1.07	N/A	MMSCF/yr	<b>LP Planned &amp; PIP</b>	<b>144.8</b>	<b>144.8</b>	<b>144.8</b>	<b>144.8</b>	<b>130.8</b>	<b>144.8</b>	<b>140.1</b>	<b>79.4</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>MSCF/mo</b>	<b>1.07</b>	<b>2.31</b>	<b>MMSCF/yr</b>	LP Unplanned	2,932.0	659.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	3.59	Exempt	MMSCF/yr	Gas Consumption:																	Turbines: G1	23.6	11.4	1.3	0.0	0.4	12.3	13.2	13.7	13.3	13.8	14.0	1.6	MMSCF/mo	118.56	N/A	MMSCF/yr	Turbines: G2	25.3	12.1	5.8	0.6	7.5	0.0	0.0	0.0	0.0	0.0	0.0	1.7	MMSCF/mo	52.96	N/A	MMSCF/yr	Turbines: G3	24.9	18.6	6.7	13.7	4.3	1.1	0.0	0.0	0.0	0.0	0.0	10.0	MMSCF/mo	79.33	N/A	MMSCF/yr	<b>Turbines @ all loads</b>	<b>73.9</b>	<b>42.2</b>	<b>13.6</b>	<b>14.3</b>	<b>12.1</b>	<b>13.3</b>	<b>13.2</b>	<b>13.7</b>	<b>13.3</b>	<b>13.8</b>	<b>14.0</b>	<b>13.2</b>	<b>MMSCF/mo</b>	<b>250.85</b>	<b>850</b>	<b>MMSCF/yr</b>	Turbine@<1000 KW	0.05	7.93	13.68	14.3	11.68	13.33	13.22	13.7	13.3	13.8	14.02	13.20	MMSCF/mo	142.46	250.0	MMSCF/yr	Diesel Use:																	Turbines: G1	0.00	0.06	0.00	0.00	0.65	0.01	0.00	0.00	0.00	0.08	0.000	0.003	MGal/mo	1.00	N/A	MGal/yr	Turbines: G2	0.83	0.00	9.74	0.00	1.25	0.00	0.00	0.00	0.02	0.000	0.000	0.029	MGal/mo	11.67	N/A	MGal/yr	Turbines: G3	0.07	0.16	0.00	0.00	0.92	0.00	0.00	0.00	0.00	0.01	0.000	0.0031	MGal/mo	1.17	N/A	MGal/yr	<b>Turbines @ all loads</b>	<b>0.9</b>	<b>0.2</b>	<b>9.7</b>	<b>0.0</b>	<b>3.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.1</b>	<b>0.00</b>	<b>0.0355</b>	<b>MGal/mo</b>	<b>14.04</b>	<b>335</b>	<b>MGal/yr</b>	Turbine@<1000 KW	0.27	0.11	9.75	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.00	0.0355	MGal/mo	11.33	160	MGal/yr	Back-up Generator:G4	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	0.08	MGal/mo	3.64	32.13	MGal/yr	North Crane	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	0.00	Gal/mo	334.0	N/A	Gal/yr	South Crane	527.00	348.00	508.00	287.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	345.00	Gal/mo	3,235.0	N/A	Gal/yr	<b>Crane Total</b>	<b>576.00</b>	<b>419.00</b>	<b>508.00</b>	<b>339.00</b>	<b>0.00</b>	<b>210.00</b>	<b>195.00</b>	<b>189.00</b>	<b>144.00</b>	<b>295.00</b>	<b>349.00</b>	<b>345.00</b>	<b>Gal/mo</b>	<b>3,569</b>	<b>21,339</b>	<b>Gal/yr</b>	Turbine Starter Engines	10.57	0.68	3.22	0.76	2.11	0.17	0.00	0.00	0.49	0.61	0.72	0.97	Hrs/mo	156.5	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.50	7.20	0.60	0.50	0.30	2.00	0.00	1.30	0.55	1.70	1.70	9.10	Gal/mo	24.3	1,406	Gal/yr	<b>P-18 -Em FW Pump</b>	<b>1.00</b>	<b>0.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>2.00</b>	<b>2.00</b>	<b>3.00</b>	<b>Hrs/mo</b>	<b>17.0</b>	<b>50</b>	<b>Hrs/yr</b>	Tank Throughputs																	V-08	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	72,507.0	N/A	Bbls/yr	Produced Gas	36,777.0	14,720.0	293.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	51.79	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lbs/gal	87 RB	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lbs/gal	Z-Sol	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lbs/gal	Transfoam Plus	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lbs/gal	Sigma Thinner 90-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.59 lbs/gal	Sigma Thinner 91-57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lbs/gal	Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lbs/gal	<b>Solvent Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>9.89</b>	<b>Tons/yr ROC</b>	<b>Coatings Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>N/A</b>	<b>Gal/yr</b>	Boats:																	Crew Boat Fuel:	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,990	1,856	2,779	2,593	3,829	Gal/mo	24,674	N/A	Gal/yr	Work Boat Fuel:	1,659	1,628	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,866	2,809	4,148	Gal/mo	27,762	N/A	Gal/yr	<b>Total Boats Fuel</b>	<b>3,190</b>	<b>3,315</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,646</b>	<b>5,402</b>	<b>7,977</b>	<b>Gal/mo</b>	<b>52,437</b>	<b>167,100</b>	<b>Gal/yr</b>	Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																				
LP Planned	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	0.00	N/A	MMSCF/yr	LP Pload/Purge	144.8	144.8	144.8	144.8	130.8	144.8	140.1	79.4	0.0	0.0	0.0	0.0	MSCF/mo	1.07	N/A	MMSCF/yr	<b>LP Planned &amp; PIP</b>	<b>144.8</b>	<b>144.8</b>	<b>144.8</b>	<b>144.8</b>	<b>130.8</b>	<b>144.8</b>	<b>140.1</b>	<b>79.4</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>MSCF/mo</b>	<b>1.07</b>	<b>2.31</b>	<b>MMSCF/yr</b>	LP Unplanned	2,932.0	659.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	3.59	Exempt	MMSCF/yr	Gas Consumption:																	Turbines: G1	23.6	11.4	1.3	0.0	0.4	12.3	13.2	13.7	13.3	13.8	14.0	1.6	MMSCF/mo	118.56	N/A	MMSCF/yr	Turbines: G2	25.3	12.1	5.8	0.6	7.5	0.0	0.0	0.0	0.0	0.0	0.0	1.7	MMSCF/mo	52.96	N/A	MMSCF/yr	Turbines: G3	24.9	18.6	6.7	13.7	4.3	1.1	0.0	0.0	0.0	0.0	0.0	10.0	MMSCF/mo	79.33	N/A	MMSCF/yr	<b>Turbines @ all loads</b>	<b>73.9</b>	<b>42.2</b>	<b>13.6</b>	<b>14.3</b>	<b>12.1</b>	<b>13.3</b>	<b>13.2</b>	<b>13.7</b>	<b>13.3</b>	<b>13.8</b>	<b>14.0</b>	<b>13.2</b>	<b>MMSCF/mo</b>	<b>250.85</b>	<b>850</b>	<b>MMSCF/yr</b>	Turbine@<1000 KW	0.05	7.93	13.68	14.3	11.68	13.33	13.22	13.7	13.3	13.8	14.02	13.20	MMSCF/mo	142.46	250.0	MMSCF/yr	Diesel Use:																	Turbines: G1	0.00	0.06	0.00	0.00	0.65	0.01	0.00	0.00	0.00	0.08	0.000	0.003	MGal/mo	1.00	N/A	MGal/yr	Turbines: G2	0.83	0.00	9.74	0.00	1.25	0.00	0.00	0.00	0.02	0.000	0.000	0.029	MGal/mo	11.67	N/A	MGal/yr	Turbines: G3	0.07	0.16	0.00	0.00	0.92	0.00	0.00	0.00	0.00	0.01	0.000	0.0031	MGal/mo	1.17	N/A	MGal/yr	<b>Turbines @ all loads</b>	<b>0.9</b>	<b>0.2</b>	<b>9.7</b>	<b>0.0</b>	<b>3.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.1</b>	<b>0.00</b>	<b>0.0355</b>	<b>MGal/mo</b>	<b>14.04</b>	<b>335</b>	<b>MGal/yr</b>	Turbine@<1000 KW	0.27	0.11	9.75	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.00	0.0355	MGal/mo	11.33	160	MGal/yr	Back-up Generator:G4	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	0.08	MGal/mo	3.64	32.13	MGal/yr	North Crane	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	0.00	Gal/mo	334.0	N/A	Gal/yr	South Crane	527.00	348.00	508.00	287.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	345.00	Gal/mo	3,235.0	N/A	Gal/yr	<b>Crane Total</b>	<b>576.00</b>	<b>419.00</b>	<b>508.00</b>	<b>339.00</b>	<b>0.00</b>	<b>210.00</b>	<b>195.00</b>	<b>189.00</b>	<b>144.00</b>	<b>295.00</b>	<b>349.00</b>	<b>345.00</b>	<b>Gal/mo</b>	<b>3,569</b>	<b>21,339</b>	<b>Gal/yr</b>	Turbine Starter Engines	10.57	0.68	3.22	0.76	2.11	0.17	0.00	0.00	0.49	0.61	0.72	0.97	Hrs/mo	156.5	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.50	7.20	0.60	0.50	0.30	2.00	0.00	1.30	0.55	1.70	1.70	9.10	Gal/mo	24.3	1,406	Gal/yr	<b>P-18 -Em FW Pump</b>	<b>1.00</b>	<b>0.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>2.00</b>	<b>2.00</b>	<b>3.00</b>	<b>Hrs/mo</b>	<b>17.0</b>	<b>50</b>	<b>Hrs/yr</b>	Tank Throughputs																	V-08	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	72,507.0	N/A	Bbls/yr	Produced Gas	36,777.0	14,720.0	293.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	51.79	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lbs/gal	87 RB	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lbs/gal	Z-Sol	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lbs/gal	Transfoam Plus	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lbs/gal	Sigma Thinner 90-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.59 lbs/gal	Sigma Thinner 91-57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lbs/gal	Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lbs/gal	<b>Solvent Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>9.89</b>	<b>Tons/yr ROC</b>	<b>Coatings Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>N/A</b>	<b>Gal/yr</b>	Boats:																	Crew Boat Fuel:	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,990	1,856	2,779	2,593	3,829	Gal/mo	24,674	N/A	Gal/yr	Work Boat Fuel:	1,659	1,628	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,866	2,809	4,148	Gal/mo	27,762	N/A	Gal/yr	<b>Total Boats Fuel</b>	<b>3,190</b>	<b>3,315</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,646</b>	<b>5,402</b>	<b>7,977</b>	<b>Gal/mo</b>	<b>52,437</b>	<b>167,100</b>	<b>Gal/yr</b>	Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																					
LP Pload/Purge	144.8	144.8	144.8	144.8	130.8	144.8	140.1	79.4	0.0	0.0	0.0	0.0	MSCF/mo	1.07	N/A	MMSCF/yr	<b>LP Planned &amp; PIP</b>	<b>144.8</b>	<b>144.8</b>	<b>144.8</b>	<b>144.8</b>	<b>130.8</b>	<b>144.8</b>	<b>140.1</b>	<b>79.4</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>MSCF/mo</b>	<b>1.07</b>	<b>2.31</b>	<b>MMSCF/yr</b>	LP Unplanned	2,932.0	659.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	3.59	Exempt	MMSCF/yr	Gas Consumption:																	Turbines: G1	23.6	11.4	1.3	0.0	0.4	12.3	13.2	13.7	13.3	13.8	14.0	1.6	MMSCF/mo	118.56	N/A	MMSCF/yr	Turbines: G2	25.3	12.1	5.8	0.6	7.5	0.0	0.0	0.0	0.0	0.0	0.0	1.7	MMSCF/mo	52.96	N/A	MMSCF/yr	Turbines: G3	24.9	18.6	6.7	13.7	4.3	1.1	0.0	0.0	0.0	0.0	0.0	10.0	MMSCF/mo	79.33	N/A	MMSCF/yr	<b>Turbines @ all loads</b>	<b>73.9</b>	<b>42.2</b>	<b>13.6</b>	<b>14.3</b>	<b>12.1</b>	<b>13.3</b>	<b>13.2</b>	<b>13.7</b>	<b>13.3</b>	<b>13.8</b>	<b>14.0</b>	<b>13.2</b>	<b>MMSCF/mo</b>	<b>250.85</b>	<b>850</b>	<b>MMSCF/yr</b>	Turbine@<1000 KW	0.05	7.93	13.68	14.3	11.68	13.33	13.22	13.7	13.3	13.8	14.02	13.20	MMSCF/mo	142.46	250.0	MMSCF/yr	Diesel Use:																	Turbines: G1	0.00	0.06	0.00	0.00	0.65	0.01	0.00	0.00	0.00	0.08	0.000	0.003	MGal/mo	1.00	N/A	MGal/yr	Turbines: G2	0.83	0.00	9.74	0.00	1.25	0.00	0.00	0.00	0.02	0.000	0.000	0.029	MGal/mo	11.67	N/A	MGal/yr	Turbines: G3	0.07	0.16	0.00	0.00	0.92	0.00	0.00	0.00	0.00	0.01	0.000	0.0031	MGal/mo	1.17	N/A	MGal/yr	<b>Turbines @ all loads</b>	<b>0.9</b>	<b>0.2</b>	<b>9.7</b>	<b>0.0</b>	<b>3.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.1</b>	<b>0.00</b>	<b>0.0355</b>	<b>MGal/mo</b>	<b>14.04</b>	<b>335</b>	<b>MGal/yr</b>	Turbine@<1000 KW	0.27	0.11	9.75	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.00	0.0355	MGal/mo	11.33	160	MGal/yr	Back-up Generator:G4	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	0.08	MGal/mo	3.64	32.13	MGal/yr	North Crane	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	0.00	Gal/mo	334.0	N/A	Gal/yr	South Crane	527.00	348.00	508.00	287.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	345.00	Gal/mo	3,235.0	N/A	Gal/yr	<b>Crane Total</b>	<b>576.00</b>	<b>419.00</b>	<b>508.00</b>	<b>339.00</b>	<b>0.00</b>	<b>210.00</b>	<b>195.00</b>	<b>189.00</b>	<b>144.00</b>	<b>295.00</b>	<b>349.00</b>	<b>345.00</b>	<b>Gal/mo</b>	<b>3,569</b>	<b>21,339</b>	<b>Gal/yr</b>	Turbine Starter Engines	10.57	0.68	3.22	0.76	2.11	0.17	0.00	0.00	0.49	0.61	0.72	0.97	Hrs/mo	156.5	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.50	7.20	0.60	0.50	0.30	2.00	0.00	1.30	0.55	1.70	1.70	9.10	Gal/mo	24.3	1,406	Gal/yr	<b>P-18 -Em FW Pump</b>	<b>1.00</b>	<b>0.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>2.00</b>	<b>2.00</b>	<b>3.00</b>	<b>Hrs/mo</b>	<b>17.0</b>	<b>50</b>	<b>Hrs/yr</b>	Tank Throughputs																	V-08	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	72,507.0	N/A	Bbls/yr	Produced Gas	36,777.0	14,720.0	293.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	51.79	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lbs/gal	87 RB	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lbs/gal	Z-Sol	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lbs/gal	Transfoam Plus	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lbs/gal	Sigma Thinner 90-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.59 lbs/gal	Sigma Thinner 91-57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lbs/gal	Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lbs/gal	<b>Solvent Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>9.89</b>	<b>Tons/yr ROC</b>	<b>Coatings Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>N/A</b>	<b>Gal/yr</b>	Boats:																	Crew Boat Fuel:	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,990	1,856	2,779	2,593	3,829	Gal/mo	24,674	N/A	Gal/yr	Work Boat Fuel:	1,659	1,628	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,866	2,809	4,148	Gal/mo	27,762	N/A	Gal/yr	<b>Total Boats Fuel</b>	<b>3,190</b>	<b>3,315</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,646</b>	<b>5,402</b>	<b>7,977</b>	<b>Gal/mo</b>	<b>52,437</b>	<b>167,100</b>	<b>Gal/yr</b>	Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																						
<b>LP Planned &amp; PIP</b>	<b>144.8</b>	<b>144.8</b>	<b>144.8</b>	<b>144.8</b>	<b>130.8</b>	<b>144.8</b>	<b>140.1</b>	<b>79.4</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>MSCF/mo</b>	<b>1.07</b>	<b>2.31</b>	<b>MMSCF/yr</b>	LP Unplanned	2,932.0	659.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	3.59	Exempt	MMSCF/yr	Gas Consumption:																	Turbines: G1	23.6	11.4	1.3	0.0	0.4	12.3	13.2	13.7	13.3	13.8	14.0	1.6	MMSCF/mo	118.56	N/A	MMSCF/yr	Turbines: G2	25.3	12.1	5.8	0.6	7.5	0.0	0.0	0.0	0.0	0.0	0.0	1.7	MMSCF/mo	52.96	N/A	MMSCF/yr	Turbines: G3	24.9	18.6	6.7	13.7	4.3	1.1	0.0	0.0	0.0	0.0	0.0	10.0	MMSCF/mo	79.33	N/A	MMSCF/yr	<b>Turbines @ all loads</b>	<b>73.9</b>	<b>42.2</b>	<b>13.6</b>	<b>14.3</b>	<b>12.1</b>	<b>13.3</b>	<b>13.2</b>	<b>13.7</b>	<b>13.3</b>	<b>13.8</b>	<b>14.0</b>	<b>13.2</b>	<b>MMSCF/mo</b>	<b>250.85</b>	<b>850</b>	<b>MMSCF/yr</b>	Turbine@<1000 KW	0.05	7.93	13.68	14.3	11.68	13.33	13.22	13.7	13.3	13.8	14.02	13.20	MMSCF/mo	142.46	250.0	MMSCF/yr	Diesel Use:																	Turbines: G1	0.00	0.06	0.00	0.00	0.65	0.01	0.00	0.00	0.00	0.08	0.000	0.003	MGal/mo	1.00	N/A	MGal/yr	Turbines: G2	0.83	0.00	9.74	0.00	1.25	0.00	0.00	0.00	0.02	0.000	0.000	0.029	MGal/mo	11.67	N/A	MGal/yr	Turbines: G3	0.07	0.16	0.00	0.00	0.92	0.00	0.00	0.00	0.00	0.01	0.000	0.0031	MGal/mo	1.17	N/A	MGal/yr	<b>Turbines @ all loads</b>	<b>0.9</b>	<b>0.2</b>	<b>9.7</b>	<b>0.0</b>	<b>3.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.1</b>	<b>0.00</b>	<b>0.0355</b>	<b>MGal/mo</b>	<b>14.04</b>	<b>335</b>	<b>MGal/yr</b>	Turbine@<1000 KW	0.27	0.11	9.75	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.00	0.0355	MGal/mo	11.33	160	MGal/yr	Back-up Generator:G4	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	0.08	MGal/mo	3.64	32.13	MGal/yr	North Crane	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	0.00	Gal/mo	334.0	N/A	Gal/yr	South Crane	527.00	348.00	508.00	287.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	345.00	Gal/mo	3,235.0	N/A	Gal/yr	<b>Crane Total</b>	<b>576.00</b>	<b>419.00</b>	<b>508.00</b>	<b>339.00</b>	<b>0.00</b>	<b>210.00</b>	<b>195.00</b>	<b>189.00</b>	<b>144.00</b>	<b>295.00</b>	<b>349.00</b>	<b>345.00</b>	<b>Gal/mo</b>	<b>3,569</b>	<b>21,339</b>	<b>Gal/yr</b>	Turbine Starter Engines	10.57	0.68	3.22	0.76	2.11	0.17	0.00	0.00	0.49	0.61	0.72	0.97	Hrs/mo	156.5	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.50	7.20	0.60	0.50	0.30	2.00	0.00	1.30	0.55	1.70	1.70	9.10	Gal/mo	24.3	1,406	Gal/yr	<b>P-18 -Em FW Pump</b>	<b>1.00</b>	<b>0.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>2.00</b>	<b>2.00</b>	<b>3.00</b>	<b>Hrs/mo</b>	<b>17.0</b>	<b>50</b>	<b>Hrs/yr</b>	Tank Throughputs																	V-08	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	72,507.0	N/A	Bbls/yr	Produced Gas	36,777.0	14,720.0	293.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	51.79	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lbs/gal	87 RB	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lbs/gal	Z-Sol	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lbs/gal	Transfoam Plus	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lbs/gal	Sigma Thinner 90-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.59 lbs/gal	Sigma Thinner 91-57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lbs/gal	Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lbs/gal	<b>Solvent Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>9.89</b>	<b>Tons/yr ROC</b>	<b>Coatings Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>N/A</b>	<b>Gal/yr</b>	Boats:																	Crew Boat Fuel:	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,990	1,856	2,779	2,593	3,829	Gal/mo	24,674	N/A	Gal/yr	Work Boat Fuel:	1,659	1,628	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,866	2,809	4,148	Gal/mo	27,762	N/A	Gal/yr	<b>Total Boats Fuel</b>	<b>3,190</b>	<b>3,315</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,646</b>	<b>5,402</b>	<b>7,977</b>	<b>Gal/mo</b>	<b>52,437</b>	<b>167,100</b>	<b>Gal/yr</b>	Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																							
LP Unplanned	2,932.0	659.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	3.59	Exempt	MMSCF/yr	Gas Consumption:																	Turbines: G1	23.6	11.4	1.3	0.0	0.4	12.3	13.2	13.7	13.3	13.8	14.0	1.6	MMSCF/mo	118.56	N/A	MMSCF/yr	Turbines: G2	25.3	12.1	5.8	0.6	7.5	0.0	0.0	0.0	0.0	0.0	0.0	1.7	MMSCF/mo	52.96	N/A	MMSCF/yr	Turbines: G3	24.9	18.6	6.7	13.7	4.3	1.1	0.0	0.0	0.0	0.0	0.0	10.0	MMSCF/mo	79.33	N/A	MMSCF/yr	<b>Turbines @ all loads</b>	<b>73.9</b>	<b>42.2</b>	<b>13.6</b>	<b>14.3</b>	<b>12.1</b>	<b>13.3</b>	<b>13.2</b>	<b>13.7</b>	<b>13.3</b>	<b>13.8</b>	<b>14.0</b>	<b>13.2</b>	<b>MMSCF/mo</b>	<b>250.85</b>	<b>850</b>	<b>MMSCF/yr</b>	Turbine@<1000 KW	0.05	7.93	13.68	14.3	11.68	13.33	13.22	13.7	13.3	13.8	14.02	13.20	MMSCF/mo	142.46	250.0	MMSCF/yr	Diesel Use:																	Turbines: G1	0.00	0.06	0.00	0.00	0.65	0.01	0.00	0.00	0.00	0.08	0.000	0.003	MGal/mo	1.00	N/A	MGal/yr	Turbines: G2	0.83	0.00	9.74	0.00	1.25	0.00	0.00	0.00	0.02	0.000	0.000	0.029	MGal/mo	11.67	N/A	MGal/yr	Turbines: G3	0.07	0.16	0.00	0.00	0.92	0.00	0.00	0.00	0.00	0.01	0.000	0.0031	MGal/mo	1.17	N/A	MGal/yr	<b>Turbines @ all loads</b>	<b>0.9</b>	<b>0.2</b>	<b>9.7</b>	<b>0.0</b>	<b>3.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.1</b>	<b>0.00</b>	<b>0.0355</b>	<b>MGal/mo</b>	<b>14.04</b>	<b>335</b>	<b>MGal/yr</b>	Turbine@<1000 KW	0.27	0.11	9.75	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.00	0.0355	MGal/mo	11.33	160	MGal/yr	Back-up Generator:G4	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	0.08	MGal/mo	3.64	32.13	MGal/yr	North Crane	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	0.00	Gal/mo	334.0	N/A	Gal/yr	South Crane	527.00	348.00	508.00	287.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	345.00	Gal/mo	3,235.0	N/A	Gal/yr	<b>Crane Total</b>	<b>576.00</b>	<b>419.00</b>	<b>508.00</b>	<b>339.00</b>	<b>0.00</b>	<b>210.00</b>	<b>195.00</b>	<b>189.00</b>	<b>144.00</b>	<b>295.00</b>	<b>349.00</b>	<b>345.00</b>	<b>Gal/mo</b>	<b>3,569</b>	<b>21,339</b>	<b>Gal/yr</b>	Turbine Starter Engines	10.57	0.68	3.22	0.76	2.11	0.17	0.00	0.00	0.49	0.61	0.72	0.97	Hrs/mo	156.5	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.50	7.20	0.60	0.50	0.30	2.00	0.00	1.30	0.55	1.70	1.70	9.10	Gal/mo	24.3	1,406	Gal/yr	<b>P-18 -Em FW Pump</b>	<b>1.00</b>	<b>0.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>2.00</b>	<b>2.00</b>	<b>3.00</b>	<b>Hrs/mo</b>	<b>17.0</b>	<b>50</b>	<b>Hrs/yr</b>	Tank Throughputs																	V-08	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	72,507.0	N/A	Bbls/yr	Produced Gas	36,777.0	14,720.0	293.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	51.79	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lbs/gal	87 RB	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lbs/gal	Z-Sol	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lbs/gal	Transfoam Plus	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lbs/gal	Sigma Thinner 90-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.59 lbs/gal	Sigma Thinner 91-57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lbs/gal	Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lbs/gal	<b>Solvent Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>9.89</b>	<b>Tons/yr ROC</b>	<b>Coatings Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>N/A</b>	<b>Gal/yr</b>	Boats:																	Crew Boat Fuel:	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,990	1,856	2,779	2,593	3,829	Gal/mo	24,674	N/A	Gal/yr	Work Boat Fuel:	1,659	1,628	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,866	2,809	4,148	Gal/mo	27,762	N/A	Gal/yr	<b>Total Boats Fuel</b>	<b>3,190</b>	<b>3,315</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,646</b>	<b>5,402</b>	<b>7,977</b>	<b>Gal/mo</b>	<b>52,437</b>	<b>167,100</b>	<b>Gal/yr</b>	Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																								
Gas Consumption:																	Turbines: G1	23.6	11.4	1.3	0.0	0.4	12.3	13.2	13.7	13.3	13.8	14.0	1.6	MMSCF/mo	118.56	N/A	MMSCF/yr	Turbines: G2	25.3	12.1	5.8	0.6	7.5	0.0	0.0	0.0	0.0	0.0	0.0	1.7	MMSCF/mo	52.96	N/A	MMSCF/yr	Turbines: G3	24.9	18.6	6.7	13.7	4.3	1.1	0.0	0.0	0.0	0.0	0.0	10.0	MMSCF/mo	79.33	N/A	MMSCF/yr	<b>Turbines @ all loads</b>	<b>73.9</b>	<b>42.2</b>	<b>13.6</b>	<b>14.3</b>	<b>12.1</b>	<b>13.3</b>	<b>13.2</b>	<b>13.7</b>	<b>13.3</b>	<b>13.8</b>	<b>14.0</b>	<b>13.2</b>	<b>MMSCF/mo</b>	<b>250.85</b>	<b>850</b>	<b>MMSCF/yr</b>	Turbine@<1000 KW	0.05	7.93	13.68	14.3	11.68	13.33	13.22	13.7	13.3	13.8	14.02	13.20	MMSCF/mo	142.46	250.0	MMSCF/yr	Diesel Use:																	Turbines: G1	0.00	0.06	0.00	0.00	0.65	0.01	0.00	0.00	0.00	0.08	0.000	0.003	MGal/mo	1.00	N/A	MGal/yr	Turbines: G2	0.83	0.00	9.74	0.00	1.25	0.00	0.00	0.00	0.02	0.000	0.000	0.029	MGal/mo	11.67	N/A	MGal/yr	Turbines: G3	0.07	0.16	0.00	0.00	0.92	0.00	0.00	0.00	0.00	0.01	0.000	0.0031	MGal/mo	1.17	N/A	MGal/yr	<b>Turbines @ all loads</b>	<b>0.9</b>	<b>0.2</b>	<b>9.7</b>	<b>0.0</b>	<b>3.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.1</b>	<b>0.00</b>	<b>0.0355</b>	<b>MGal/mo</b>	<b>14.04</b>	<b>335</b>	<b>MGal/yr</b>	Turbine@<1000 KW	0.27	0.11	9.75	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.00	0.0355	MGal/mo	11.33	160	MGal/yr	Back-up Generator:G4	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	0.08	MGal/mo	3.64	32.13	MGal/yr	North Crane	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	0.00	Gal/mo	334.0	N/A	Gal/yr	South Crane	527.00	348.00	508.00	287.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	345.00	Gal/mo	3,235.0	N/A	Gal/yr	<b>Crane Total</b>	<b>576.00</b>	<b>419.00</b>	<b>508.00</b>	<b>339.00</b>	<b>0.00</b>	<b>210.00</b>	<b>195.00</b>	<b>189.00</b>	<b>144.00</b>	<b>295.00</b>	<b>349.00</b>	<b>345.00</b>	<b>Gal/mo</b>	<b>3,569</b>	<b>21,339</b>	<b>Gal/yr</b>	Turbine Starter Engines	10.57	0.68	3.22	0.76	2.11	0.17	0.00	0.00	0.49	0.61	0.72	0.97	Hrs/mo	156.5	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.50	7.20	0.60	0.50	0.30	2.00	0.00	1.30	0.55	1.70	1.70	9.10	Gal/mo	24.3	1,406	Gal/yr	<b>P-18 -Em FW Pump</b>	<b>1.00</b>	<b>0.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>2.00</b>	<b>2.00</b>	<b>3.00</b>	<b>Hrs/mo</b>	<b>17.0</b>	<b>50</b>	<b>Hrs/yr</b>	Tank Throughputs																	V-08	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	72,507.0	N/A	Bbls/yr	Produced Gas	36,777.0	14,720.0	293.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	51.79	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lbs/gal	87 RB	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lbs/gal	Z-Sol	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lbs/gal	Transfoam Plus	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lbs/gal	Sigma Thinner 90-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.59 lbs/gal	Sigma Thinner 91-57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lbs/gal	Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lbs/gal	<b>Solvent Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>9.89</b>	<b>Tons/yr ROC</b>	<b>Coatings Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>N/A</b>	<b>Gal/yr</b>	Boats:																	Crew Boat Fuel:	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,990	1,856	2,779	2,593	3,829	Gal/mo	24,674	N/A	Gal/yr	Work Boat Fuel:	1,659	1,628	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,866	2,809	4,148	Gal/mo	27,762	N/A	Gal/yr	<b>Total Boats Fuel</b>	<b>3,190</b>	<b>3,315</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,646</b>	<b>5,402</b>	<b>7,977</b>	<b>Gal/mo</b>	<b>52,437</b>	<b>167,100</b>	<b>Gal/yr</b>	Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																									
Turbines: G1	23.6	11.4	1.3	0.0	0.4	12.3	13.2	13.7	13.3	13.8	14.0	1.6	MMSCF/mo	118.56	N/A	MMSCF/yr	Turbines: G2	25.3	12.1	5.8	0.6	7.5	0.0	0.0	0.0	0.0	0.0	0.0	1.7	MMSCF/mo	52.96	N/A	MMSCF/yr	Turbines: G3	24.9	18.6	6.7	13.7	4.3	1.1	0.0	0.0	0.0	0.0	0.0	10.0	MMSCF/mo	79.33	N/A	MMSCF/yr	<b>Turbines @ all loads</b>	<b>73.9</b>	<b>42.2</b>	<b>13.6</b>	<b>14.3</b>	<b>12.1</b>	<b>13.3</b>	<b>13.2</b>	<b>13.7</b>	<b>13.3</b>	<b>13.8</b>	<b>14.0</b>	<b>13.2</b>	<b>MMSCF/mo</b>	<b>250.85</b>	<b>850</b>	<b>MMSCF/yr</b>	Turbine@<1000 KW	0.05	7.93	13.68	14.3	11.68	13.33	13.22	13.7	13.3	13.8	14.02	13.20	MMSCF/mo	142.46	250.0	MMSCF/yr	Diesel Use:																	Turbines: G1	0.00	0.06	0.00	0.00	0.65	0.01	0.00	0.00	0.00	0.08	0.000	0.003	MGal/mo	1.00	N/A	MGal/yr	Turbines: G2	0.83	0.00	9.74	0.00	1.25	0.00	0.00	0.00	0.02	0.000	0.000	0.029	MGal/mo	11.67	N/A	MGal/yr	Turbines: G3	0.07	0.16	0.00	0.00	0.92	0.00	0.00	0.00	0.00	0.01	0.000	0.0031	MGal/mo	1.17	N/A	MGal/yr	<b>Turbines @ all loads</b>	<b>0.9</b>	<b>0.2</b>	<b>9.7</b>	<b>0.0</b>	<b>3.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.1</b>	<b>0.00</b>	<b>0.0355</b>	<b>MGal/mo</b>	<b>14.04</b>	<b>335</b>	<b>MGal/yr</b>	Turbine@<1000 KW	0.27	0.11	9.75	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.00	0.0355	MGal/mo	11.33	160	MGal/yr	Back-up Generator:G4	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	0.08	MGal/mo	3.64	32.13	MGal/yr	North Crane	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	0.00	Gal/mo	334.0	N/A	Gal/yr	South Crane	527.00	348.00	508.00	287.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	345.00	Gal/mo	3,235.0	N/A	Gal/yr	<b>Crane Total</b>	<b>576.00</b>	<b>419.00</b>	<b>508.00</b>	<b>339.00</b>	<b>0.00</b>	<b>210.00</b>	<b>195.00</b>	<b>189.00</b>	<b>144.00</b>	<b>295.00</b>	<b>349.00</b>	<b>345.00</b>	<b>Gal/mo</b>	<b>3,569</b>	<b>21,339</b>	<b>Gal/yr</b>	Turbine Starter Engines	10.57	0.68	3.22	0.76	2.11	0.17	0.00	0.00	0.49	0.61	0.72	0.97	Hrs/mo	156.5	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.50	7.20	0.60	0.50	0.30	2.00	0.00	1.30	0.55	1.70	1.70	9.10	Gal/mo	24.3	1,406	Gal/yr	<b>P-18 -Em FW Pump</b>	<b>1.00</b>	<b>0.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>2.00</b>	<b>2.00</b>	<b>3.00</b>	<b>Hrs/mo</b>	<b>17.0</b>	<b>50</b>	<b>Hrs/yr</b>	Tank Throughputs																	V-08	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	72,507.0	N/A	Bbls/yr	Produced Gas	36,777.0	14,720.0	293.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	51.79	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lbs/gal	87 RB	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lbs/gal	Z-Sol	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lbs/gal	Transfoam Plus	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lbs/gal	Sigma Thinner 90-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.59 lbs/gal	Sigma Thinner 91-57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lbs/gal	Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lbs/gal	<b>Solvent Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>9.89</b>	<b>Tons/yr ROC</b>	<b>Coatings Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>N/A</b>	<b>Gal/yr</b>	Boats:																	Crew Boat Fuel:	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,990	1,856	2,779	2,593	3,829	Gal/mo	24,674	N/A	Gal/yr	Work Boat Fuel:	1,659	1,628	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,866	2,809	4,148	Gal/mo	27,762	N/A	Gal/yr	<b>Total Boats Fuel</b>	<b>3,190</b>	<b>3,315</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,646</b>	<b>5,402</b>	<b>7,977</b>	<b>Gal/mo</b>	<b>52,437</b>	<b>167,100</b>	<b>Gal/yr</b>	Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																										
Turbines: G2	25.3	12.1	5.8	0.6	7.5	0.0	0.0	0.0	0.0	0.0	0.0	1.7	MMSCF/mo	52.96	N/A	MMSCF/yr	Turbines: G3	24.9	18.6	6.7	13.7	4.3	1.1	0.0	0.0	0.0	0.0	0.0	10.0	MMSCF/mo	79.33	N/A	MMSCF/yr	<b>Turbines @ all loads</b>	<b>73.9</b>	<b>42.2</b>	<b>13.6</b>	<b>14.3</b>	<b>12.1</b>	<b>13.3</b>	<b>13.2</b>	<b>13.7</b>	<b>13.3</b>	<b>13.8</b>	<b>14.0</b>	<b>13.2</b>	<b>MMSCF/mo</b>	<b>250.85</b>	<b>850</b>	<b>MMSCF/yr</b>	Turbine@<1000 KW	0.05	7.93	13.68	14.3	11.68	13.33	13.22	13.7	13.3	13.8	14.02	13.20	MMSCF/mo	142.46	250.0	MMSCF/yr	Diesel Use:																	Turbines: G1	0.00	0.06	0.00	0.00	0.65	0.01	0.00	0.00	0.00	0.08	0.000	0.003	MGal/mo	1.00	N/A	MGal/yr	Turbines: G2	0.83	0.00	9.74	0.00	1.25	0.00	0.00	0.00	0.02	0.000	0.000	0.029	MGal/mo	11.67	N/A	MGal/yr	Turbines: G3	0.07	0.16	0.00	0.00	0.92	0.00	0.00	0.00	0.00	0.01	0.000	0.0031	MGal/mo	1.17	N/A	MGal/yr	<b>Turbines @ all loads</b>	<b>0.9</b>	<b>0.2</b>	<b>9.7</b>	<b>0.0</b>	<b>3.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.1</b>	<b>0.00</b>	<b>0.0355</b>	<b>MGal/mo</b>	<b>14.04</b>	<b>335</b>	<b>MGal/yr</b>	Turbine@<1000 KW	0.27	0.11	9.75	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.00	0.0355	MGal/mo	11.33	160	MGal/yr	Back-up Generator:G4	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	0.08	MGal/mo	3.64	32.13	MGal/yr	North Crane	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	0.00	Gal/mo	334.0	N/A	Gal/yr	South Crane	527.00	348.00	508.00	287.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	345.00	Gal/mo	3,235.0	N/A	Gal/yr	<b>Crane Total</b>	<b>576.00</b>	<b>419.00</b>	<b>508.00</b>	<b>339.00</b>	<b>0.00</b>	<b>210.00</b>	<b>195.00</b>	<b>189.00</b>	<b>144.00</b>	<b>295.00</b>	<b>349.00</b>	<b>345.00</b>	<b>Gal/mo</b>	<b>3,569</b>	<b>21,339</b>	<b>Gal/yr</b>	Turbine Starter Engines	10.57	0.68	3.22	0.76	2.11	0.17	0.00	0.00	0.49	0.61	0.72	0.97	Hrs/mo	156.5	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.50	7.20	0.60	0.50	0.30	2.00	0.00	1.30	0.55	1.70	1.70	9.10	Gal/mo	24.3	1,406	Gal/yr	<b>P-18 -Em FW Pump</b>	<b>1.00</b>	<b>0.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>2.00</b>	<b>2.00</b>	<b>3.00</b>	<b>Hrs/mo</b>	<b>17.0</b>	<b>50</b>	<b>Hrs/yr</b>	Tank Throughputs																	V-08	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	72,507.0	N/A	Bbls/yr	Produced Gas	36,777.0	14,720.0	293.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	51.79	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lbs/gal	87 RB	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lbs/gal	Z-Sol	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lbs/gal	Transfoam Plus	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lbs/gal	Sigma Thinner 90-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.59 lbs/gal	Sigma Thinner 91-57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lbs/gal	Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lbs/gal	<b>Solvent Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>9.89</b>	<b>Tons/yr ROC</b>	<b>Coatings Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>N/A</b>	<b>Gal/yr</b>	Boats:																	Crew Boat Fuel:	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,990	1,856	2,779	2,593	3,829	Gal/mo	24,674	N/A	Gal/yr	Work Boat Fuel:	1,659	1,628	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,866	2,809	4,148	Gal/mo	27,762	N/A	Gal/yr	<b>Total Boats Fuel</b>	<b>3,190</b>	<b>3,315</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,646</b>	<b>5,402</b>	<b>7,977</b>	<b>Gal/mo</b>	<b>52,437</b>	<b>167,100</b>	<b>Gal/yr</b>	Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																											
Turbines: G3	24.9	18.6	6.7	13.7	4.3	1.1	0.0	0.0	0.0	0.0	0.0	10.0	MMSCF/mo	79.33	N/A	MMSCF/yr	<b>Turbines @ all loads</b>	<b>73.9</b>	<b>42.2</b>	<b>13.6</b>	<b>14.3</b>	<b>12.1</b>	<b>13.3</b>	<b>13.2</b>	<b>13.7</b>	<b>13.3</b>	<b>13.8</b>	<b>14.0</b>	<b>13.2</b>	<b>MMSCF/mo</b>	<b>250.85</b>	<b>850</b>	<b>MMSCF/yr</b>	Turbine@<1000 KW	0.05	7.93	13.68	14.3	11.68	13.33	13.22	13.7	13.3	13.8	14.02	13.20	MMSCF/mo	142.46	250.0	MMSCF/yr	Diesel Use:																	Turbines: G1	0.00	0.06	0.00	0.00	0.65	0.01	0.00	0.00	0.00	0.08	0.000	0.003	MGal/mo	1.00	N/A	MGal/yr	Turbines: G2	0.83	0.00	9.74	0.00	1.25	0.00	0.00	0.00	0.02	0.000	0.000	0.029	MGal/mo	11.67	N/A	MGal/yr	Turbines: G3	0.07	0.16	0.00	0.00	0.92	0.00	0.00	0.00	0.00	0.01	0.000	0.0031	MGal/mo	1.17	N/A	MGal/yr	<b>Turbines @ all loads</b>	<b>0.9</b>	<b>0.2</b>	<b>9.7</b>	<b>0.0</b>	<b>3.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.1</b>	<b>0.00</b>	<b>0.0355</b>	<b>MGal/mo</b>	<b>14.04</b>	<b>335</b>	<b>MGal/yr</b>	Turbine@<1000 KW	0.27	0.11	9.75	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.00	0.0355	MGal/mo	11.33	160	MGal/yr	Back-up Generator:G4	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	0.08	MGal/mo	3.64	32.13	MGal/yr	North Crane	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	0.00	Gal/mo	334.0	N/A	Gal/yr	South Crane	527.00	348.00	508.00	287.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	345.00	Gal/mo	3,235.0	N/A	Gal/yr	<b>Crane Total</b>	<b>576.00</b>	<b>419.00</b>	<b>508.00</b>	<b>339.00</b>	<b>0.00</b>	<b>210.00</b>	<b>195.00</b>	<b>189.00</b>	<b>144.00</b>	<b>295.00</b>	<b>349.00</b>	<b>345.00</b>	<b>Gal/mo</b>	<b>3,569</b>	<b>21,339</b>	<b>Gal/yr</b>	Turbine Starter Engines	10.57	0.68	3.22	0.76	2.11	0.17	0.00	0.00	0.49	0.61	0.72	0.97	Hrs/mo	156.5	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.50	7.20	0.60	0.50	0.30	2.00	0.00	1.30	0.55	1.70	1.70	9.10	Gal/mo	24.3	1,406	Gal/yr	<b>P-18 -Em FW Pump</b>	<b>1.00</b>	<b>0.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>2.00</b>	<b>2.00</b>	<b>3.00</b>	<b>Hrs/mo</b>	<b>17.0</b>	<b>50</b>	<b>Hrs/yr</b>	Tank Throughputs																	V-08	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	72,507.0	N/A	Bbls/yr	Produced Gas	36,777.0	14,720.0	293.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	51.79	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lbs/gal	87 RB	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lbs/gal	Z-Sol	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lbs/gal	Transfoam Plus	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lbs/gal	Sigma Thinner 90-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.59 lbs/gal	Sigma Thinner 91-57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lbs/gal	Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lbs/gal	<b>Solvent Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>9.89</b>	<b>Tons/yr ROC</b>	<b>Coatings Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>N/A</b>	<b>Gal/yr</b>	Boats:																	Crew Boat Fuel:	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,990	1,856	2,779	2,593	3,829	Gal/mo	24,674	N/A	Gal/yr	Work Boat Fuel:	1,659	1,628	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,866	2,809	4,148	Gal/mo	27,762	N/A	Gal/yr	<b>Total Boats Fuel</b>	<b>3,190</b>	<b>3,315</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,646</b>	<b>5,402</b>	<b>7,977</b>	<b>Gal/mo</b>	<b>52,437</b>	<b>167,100</b>	<b>Gal/yr</b>	Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																												
<b>Turbines @ all loads</b>	<b>73.9</b>	<b>42.2</b>	<b>13.6</b>	<b>14.3</b>	<b>12.1</b>	<b>13.3</b>	<b>13.2</b>	<b>13.7</b>	<b>13.3</b>	<b>13.8</b>	<b>14.0</b>	<b>13.2</b>	<b>MMSCF/mo</b>	<b>250.85</b>	<b>850</b>	<b>MMSCF/yr</b>	Turbine@<1000 KW	0.05	7.93	13.68	14.3	11.68	13.33	13.22	13.7	13.3	13.8	14.02	13.20	MMSCF/mo	142.46	250.0	MMSCF/yr	Diesel Use:																	Turbines: G1	0.00	0.06	0.00	0.00	0.65	0.01	0.00	0.00	0.00	0.08	0.000	0.003	MGal/mo	1.00	N/A	MGal/yr	Turbines: G2	0.83	0.00	9.74	0.00	1.25	0.00	0.00	0.00	0.02	0.000	0.000	0.029	MGal/mo	11.67	N/A	MGal/yr	Turbines: G3	0.07	0.16	0.00	0.00	0.92	0.00	0.00	0.00	0.00	0.01	0.000	0.0031	MGal/mo	1.17	N/A	MGal/yr	<b>Turbines @ all loads</b>	<b>0.9</b>	<b>0.2</b>	<b>9.7</b>	<b>0.0</b>	<b>3.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.1</b>	<b>0.00</b>	<b>0.0355</b>	<b>MGal/mo</b>	<b>14.04</b>	<b>335</b>	<b>MGal/yr</b>	Turbine@<1000 KW	0.27	0.11	9.75	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.00	0.0355	MGal/mo	11.33	160	MGal/yr	Back-up Generator:G4	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	0.08	MGal/mo	3.64	32.13	MGal/yr	North Crane	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	0.00	Gal/mo	334.0	N/A	Gal/yr	South Crane	527.00	348.00	508.00	287.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	345.00	Gal/mo	3,235.0	N/A	Gal/yr	<b>Crane Total</b>	<b>576.00</b>	<b>419.00</b>	<b>508.00</b>	<b>339.00</b>	<b>0.00</b>	<b>210.00</b>	<b>195.00</b>	<b>189.00</b>	<b>144.00</b>	<b>295.00</b>	<b>349.00</b>	<b>345.00</b>	<b>Gal/mo</b>	<b>3,569</b>	<b>21,339</b>	<b>Gal/yr</b>	Turbine Starter Engines	10.57	0.68	3.22	0.76	2.11	0.17	0.00	0.00	0.49	0.61	0.72	0.97	Hrs/mo	156.5	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.50	7.20	0.60	0.50	0.30	2.00	0.00	1.30	0.55	1.70	1.70	9.10	Gal/mo	24.3	1,406	Gal/yr	<b>P-18 -Em FW Pump</b>	<b>1.00</b>	<b>0.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>2.00</b>	<b>2.00</b>	<b>3.00</b>	<b>Hrs/mo</b>	<b>17.0</b>	<b>50</b>	<b>Hrs/yr</b>	Tank Throughputs																	V-08	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	72,507.0	N/A	Bbls/yr	Produced Gas	36,777.0	14,720.0	293.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	51.79	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lbs/gal	87 RB	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lbs/gal	Z-Sol	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lbs/gal	Transfoam Plus	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lbs/gal	Sigma Thinner 90-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.59 lbs/gal	Sigma Thinner 91-57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lbs/gal	Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lbs/gal	<b>Solvent Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>9.89</b>	<b>Tons/yr ROC</b>	<b>Coatings Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>N/A</b>	<b>Gal/yr</b>	Boats:																	Crew Boat Fuel:	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,990	1,856	2,779	2,593	3,829	Gal/mo	24,674	N/A	Gal/yr	Work Boat Fuel:	1,659	1,628	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,866	2,809	4,148	Gal/mo	27,762	N/A	Gal/yr	<b>Total Boats Fuel</b>	<b>3,190</b>	<b>3,315</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,646</b>	<b>5,402</b>	<b>7,977</b>	<b>Gal/mo</b>	<b>52,437</b>	<b>167,100</b>	<b>Gal/yr</b>	Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																													
Turbine@<1000 KW	0.05	7.93	13.68	14.3	11.68	13.33	13.22	13.7	13.3	13.8	14.02	13.20	MMSCF/mo	142.46	250.0	MMSCF/yr	Diesel Use:																	Turbines: G1	0.00	0.06	0.00	0.00	0.65	0.01	0.00	0.00	0.00	0.08	0.000	0.003	MGal/mo	1.00	N/A	MGal/yr	Turbines: G2	0.83	0.00	9.74	0.00	1.25	0.00	0.00	0.00	0.02	0.000	0.000	0.029	MGal/mo	11.67	N/A	MGal/yr	Turbines: G3	0.07	0.16	0.00	0.00	0.92	0.00	0.00	0.00	0.00	0.01	0.000	0.0031	MGal/mo	1.17	N/A	MGal/yr	<b>Turbines @ all loads</b>	<b>0.9</b>	<b>0.2</b>	<b>9.7</b>	<b>0.0</b>	<b>3.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.1</b>	<b>0.00</b>	<b>0.0355</b>	<b>MGal/mo</b>	<b>14.04</b>	<b>335</b>	<b>MGal/yr</b>	Turbine@<1000 KW	0.27	0.11	9.75	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.00	0.0355	MGal/mo	11.33	160	MGal/yr	Back-up Generator:G4	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	0.08	MGal/mo	3.64	32.13	MGal/yr	North Crane	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	0.00	Gal/mo	334.0	N/A	Gal/yr	South Crane	527.00	348.00	508.00	287.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	345.00	Gal/mo	3,235.0	N/A	Gal/yr	<b>Crane Total</b>	<b>576.00</b>	<b>419.00</b>	<b>508.00</b>	<b>339.00</b>	<b>0.00</b>	<b>210.00</b>	<b>195.00</b>	<b>189.00</b>	<b>144.00</b>	<b>295.00</b>	<b>349.00</b>	<b>345.00</b>	<b>Gal/mo</b>	<b>3,569</b>	<b>21,339</b>	<b>Gal/yr</b>	Turbine Starter Engines	10.57	0.68	3.22	0.76	2.11	0.17	0.00	0.00	0.49	0.61	0.72	0.97	Hrs/mo	156.5	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.50	7.20	0.60	0.50	0.30	2.00	0.00	1.30	0.55	1.70	1.70	9.10	Gal/mo	24.3	1,406	Gal/yr	<b>P-18 -Em FW Pump</b>	<b>1.00</b>	<b>0.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>2.00</b>	<b>2.00</b>	<b>3.00</b>	<b>Hrs/mo</b>	<b>17.0</b>	<b>50</b>	<b>Hrs/yr</b>	Tank Throughputs																	V-08	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	72,507.0	N/A	Bbls/yr	Produced Gas	36,777.0	14,720.0	293.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	51.79	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lbs/gal	87 RB	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lbs/gal	Z-Sol	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lbs/gal	Transfoam Plus	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lbs/gal	Sigma Thinner 90-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.59 lbs/gal	Sigma Thinner 91-57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lbs/gal	Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lbs/gal	<b>Solvent Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>9.89</b>	<b>Tons/yr ROC</b>	<b>Coatings Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>N/A</b>	<b>Gal/yr</b>	Boats:																	Crew Boat Fuel:	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,990	1,856	2,779	2,593	3,829	Gal/mo	24,674	N/A	Gal/yr	Work Boat Fuel:	1,659	1,628	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,866	2,809	4,148	Gal/mo	27,762	N/A	Gal/yr	<b>Total Boats Fuel</b>	<b>3,190</b>	<b>3,315</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,646</b>	<b>5,402</b>	<b>7,977</b>	<b>Gal/mo</b>	<b>52,437</b>	<b>167,100</b>	<b>Gal/yr</b>	Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																														
Diesel Use:																	Turbines: G1	0.00	0.06	0.00	0.00	0.65	0.01	0.00	0.00	0.00	0.08	0.000	0.003	MGal/mo	1.00	N/A	MGal/yr	Turbines: G2	0.83	0.00	9.74	0.00	1.25	0.00	0.00	0.00	0.02	0.000	0.000	0.029	MGal/mo	11.67	N/A	MGal/yr	Turbines: G3	0.07	0.16	0.00	0.00	0.92	0.00	0.00	0.00	0.00	0.01	0.000	0.0031	MGal/mo	1.17	N/A	MGal/yr	<b>Turbines @ all loads</b>	<b>0.9</b>	<b>0.2</b>	<b>9.7</b>	<b>0.0</b>	<b>3.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.1</b>	<b>0.00</b>	<b>0.0355</b>	<b>MGal/mo</b>	<b>14.04</b>	<b>335</b>	<b>MGal/yr</b>	Turbine@<1000 KW	0.27	0.11	9.75	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.00	0.0355	MGal/mo	11.33	160	MGal/yr	Back-up Generator:G4	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	0.08	MGal/mo	3.64	32.13	MGal/yr	North Crane	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	0.00	Gal/mo	334.0	N/A	Gal/yr	South Crane	527.00	348.00	508.00	287.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	345.00	Gal/mo	3,235.0	N/A	Gal/yr	<b>Crane Total</b>	<b>576.00</b>	<b>419.00</b>	<b>508.00</b>	<b>339.00</b>	<b>0.00</b>	<b>210.00</b>	<b>195.00</b>	<b>189.00</b>	<b>144.00</b>	<b>295.00</b>	<b>349.00</b>	<b>345.00</b>	<b>Gal/mo</b>	<b>3,569</b>	<b>21,339</b>	<b>Gal/yr</b>	Turbine Starter Engines	10.57	0.68	3.22	0.76	2.11	0.17	0.00	0.00	0.49	0.61	0.72	0.97	Hrs/mo	156.5	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.50	7.20	0.60	0.50	0.30	2.00	0.00	1.30	0.55	1.70	1.70	9.10	Gal/mo	24.3	1,406	Gal/yr	<b>P-18 -Em FW Pump</b>	<b>1.00</b>	<b>0.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>2.00</b>	<b>2.00</b>	<b>3.00</b>	<b>Hrs/mo</b>	<b>17.0</b>	<b>50</b>	<b>Hrs/yr</b>	Tank Throughputs																	V-08	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	72,507.0	N/A	Bbls/yr	Produced Gas	36,777.0	14,720.0	293.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	51.79	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lbs/gal	87 RB	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lbs/gal	Z-Sol	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lbs/gal	Transfoam Plus	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lbs/gal	Sigma Thinner 90-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.59 lbs/gal	Sigma Thinner 91-57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lbs/gal	Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lbs/gal	<b>Solvent Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>9.89</b>	<b>Tons/yr ROC</b>	<b>Coatings Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>N/A</b>	<b>Gal/yr</b>	Boats:																	Crew Boat Fuel:	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,990	1,856	2,779	2,593	3,829	Gal/mo	24,674	N/A	Gal/yr	Work Boat Fuel:	1,659	1,628	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,866	2,809	4,148	Gal/mo	27,762	N/A	Gal/yr	<b>Total Boats Fuel</b>	<b>3,190</b>	<b>3,315</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,646</b>	<b>5,402</b>	<b>7,977</b>	<b>Gal/mo</b>	<b>52,437</b>	<b>167,100</b>	<b>Gal/yr</b>	Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																															
Turbines: G1	0.00	0.06	0.00	0.00	0.65	0.01	0.00	0.00	0.00	0.08	0.000	0.003	MGal/mo	1.00	N/A	MGal/yr	Turbines: G2	0.83	0.00	9.74	0.00	1.25	0.00	0.00	0.00	0.02	0.000	0.000	0.029	MGal/mo	11.67	N/A	MGal/yr	Turbines: G3	0.07	0.16	0.00	0.00	0.92	0.00	0.00	0.00	0.00	0.01	0.000	0.0031	MGal/mo	1.17	N/A	MGal/yr	<b>Turbines @ all loads</b>	<b>0.9</b>	<b>0.2</b>	<b>9.7</b>	<b>0.0</b>	<b>3.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.1</b>	<b>0.00</b>	<b>0.0355</b>	<b>MGal/mo</b>	<b>14.04</b>	<b>335</b>	<b>MGal/yr</b>	Turbine@<1000 KW	0.27	0.11	9.75	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.00	0.0355	MGal/mo	11.33	160	MGal/yr	Back-up Generator:G4	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	0.08	MGal/mo	3.64	32.13	MGal/yr	North Crane	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	0.00	Gal/mo	334.0	N/A	Gal/yr	South Crane	527.00	348.00	508.00	287.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	345.00	Gal/mo	3,235.0	N/A	Gal/yr	<b>Crane Total</b>	<b>576.00</b>	<b>419.00</b>	<b>508.00</b>	<b>339.00</b>	<b>0.00</b>	<b>210.00</b>	<b>195.00</b>	<b>189.00</b>	<b>144.00</b>	<b>295.00</b>	<b>349.00</b>	<b>345.00</b>	<b>Gal/mo</b>	<b>3,569</b>	<b>21,339</b>	<b>Gal/yr</b>	Turbine Starter Engines	10.57	0.68	3.22	0.76	2.11	0.17	0.00	0.00	0.49	0.61	0.72	0.97	Hrs/mo	156.5	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.50	7.20	0.60	0.50	0.30	2.00	0.00	1.30	0.55	1.70	1.70	9.10	Gal/mo	24.3	1,406	Gal/yr	<b>P-18 -Em FW Pump</b>	<b>1.00</b>	<b>0.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>2.00</b>	<b>2.00</b>	<b>3.00</b>	<b>Hrs/mo</b>	<b>17.0</b>	<b>50</b>	<b>Hrs/yr</b>	Tank Throughputs																	V-08	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	72,507.0	N/A	Bbls/yr	Produced Gas	36,777.0	14,720.0	293.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	51.79	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lbs/gal	87 RB	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lbs/gal	Z-Sol	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lbs/gal	Transfoam Plus	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lbs/gal	Sigma Thinner 90-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.59 lbs/gal	Sigma Thinner 91-57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lbs/gal	Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lbs/gal	<b>Solvent Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>9.89</b>	<b>Tons/yr ROC</b>	<b>Coatings Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>N/A</b>	<b>Gal/yr</b>	Boats:																	Crew Boat Fuel:	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,990	1,856	2,779	2,593	3,829	Gal/mo	24,674	N/A	Gal/yr	Work Boat Fuel:	1,659	1,628	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,866	2,809	4,148	Gal/mo	27,762	N/A	Gal/yr	<b>Total Boats Fuel</b>	<b>3,190</b>	<b>3,315</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,646</b>	<b>5,402</b>	<b>7,977</b>	<b>Gal/mo</b>	<b>52,437</b>	<b>167,100</b>	<b>Gal/yr</b>	Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																
Turbines: G2	0.83	0.00	9.74	0.00	1.25	0.00	0.00	0.00	0.02	0.000	0.000	0.029	MGal/mo	11.67	N/A	MGal/yr	Turbines: G3	0.07	0.16	0.00	0.00	0.92	0.00	0.00	0.00	0.00	0.01	0.000	0.0031	MGal/mo	1.17	N/A	MGal/yr	<b>Turbines @ all loads</b>	<b>0.9</b>	<b>0.2</b>	<b>9.7</b>	<b>0.0</b>	<b>3.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.1</b>	<b>0.00</b>	<b>0.0355</b>	<b>MGal/mo</b>	<b>14.04</b>	<b>335</b>	<b>MGal/yr</b>	Turbine@<1000 KW	0.27	0.11	9.75	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.00	0.0355	MGal/mo	11.33	160	MGal/yr	Back-up Generator:G4	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	0.08	MGal/mo	3.64	32.13	MGal/yr	North Crane	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	0.00	Gal/mo	334.0	N/A	Gal/yr	South Crane	527.00	348.00	508.00	287.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	345.00	Gal/mo	3,235.0	N/A	Gal/yr	<b>Crane Total</b>	<b>576.00</b>	<b>419.00</b>	<b>508.00</b>	<b>339.00</b>	<b>0.00</b>	<b>210.00</b>	<b>195.00</b>	<b>189.00</b>	<b>144.00</b>	<b>295.00</b>	<b>349.00</b>	<b>345.00</b>	<b>Gal/mo</b>	<b>3,569</b>	<b>21,339</b>	<b>Gal/yr</b>	Turbine Starter Engines	10.57	0.68	3.22	0.76	2.11	0.17	0.00	0.00	0.49	0.61	0.72	0.97	Hrs/mo	156.5	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.50	7.20	0.60	0.50	0.30	2.00	0.00	1.30	0.55	1.70	1.70	9.10	Gal/mo	24.3	1,406	Gal/yr	<b>P-18 -Em FW Pump</b>	<b>1.00</b>	<b>0.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>2.00</b>	<b>2.00</b>	<b>3.00</b>	<b>Hrs/mo</b>	<b>17.0</b>	<b>50</b>	<b>Hrs/yr</b>	Tank Throughputs																	V-08	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	72,507.0	N/A	Bbls/yr	Produced Gas	36,777.0	14,720.0	293.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	51.79	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lbs/gal	87 RB	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lbs/gal	Z-Sol	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lbs/gal	Transfoam Plus	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lbs/gal	Sigma Thinner 90-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.59 lbs/gal	Sigma Thinner 91-57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lbs/gal	Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lbs/gal	<b>Solvent Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>9.89</b>	<b>Tons/yr ROC</b>	<b>Coatings Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>N/A</b>	<b>Gal/yr</b>	Boats:																	Crew Boat Fuel:	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,990	1,856	2,779	2,593	3,829	Gal/mo	24,674	N/A	Gal/yr	Work Boat Fuel:	1,659	1,628	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,866	2,809	4,148	Gal/mo	27,762	N/A	Gal/yr	<b>Total Boats Fuel</b>	<b>3,190</b>	<b>3,315</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,646</b>	<b>5,402</b>	<b>7,977</b>	<b>Gal/mo</b>	<b>52,437</b>	<b>167,100</b>	<b>Gal/yr</b>	Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																	
Turbines: G3	0.07	0.16	0.00	0.00	0.92	0.00	0.00	0.00	0.00	0.01	0.000	0.0031	MGal/mo	1.17	N/A	MGal/yr	<b>Turbines @ all loads</b>	<b>0.9</b>	<b>0.2</b>	<b>9.7</b>	<b>0.0</b>	<b>3.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.1</b>	<b>0.00</b>	<b>0.0355</b>	<b>MGal/mo</b>	<b>14.04</b>	<b>335</b>	<b>MGal/yr</b>	Turbine@<1000 KW	0.27	0.11	9.75	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.00	0.0355	MGal/mo	11.33	160	MGal/yr	Back-up Generator:G4	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	0.08	MGal/mo	3.64	32.13	MGal/yr	North Crane	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	0.00	Gal/mo	334.0	N/A	Gal/yr	South Crane	527.00	348.00	508.00	287.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	345.00	Gal/mo	3,235.0	N/A	Gal/yr	<b>Crane Total</b>	<b>576.00</b>	<b>419.00</b>	<b>508.00</b>	<b>339.00</b>	<b>0.00</b>	<b>210.00</b>	<b>195.00</b>	<b>189.00</b>	<b>144.00</b>	<b>295.00</b>	<b>349.00</b>	<b>345.00</b>	<b>Gal/mo</b>	<b>3,569</b>	<b>21,339</b>	<b>Gal/yr</b>	Turbine Starter Engines	10.57	0.68	3.22	0.76	2.11	0.17	0.00	0.00	0.49	0.61	0.72	0.97	Hrs/mo	156.5	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.50	7.20	0.60	0.50	0.30	2.00	0.00	1.30	0.55	1.70	1.70	9.10	Gal/mo	24.3	1,406	Gal/yr	<b>P-18 -Em FW Pump</b>	<b>1.00</b>	<b>0.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>2.00</b>	<b>2.00</b>	<b>3.00</b>	<b>Hrs/mo</b>	<b>17.0</b>	<b>50</b>	<b>Hrs/yr</b>	Tank Throughputs																	V-08	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	72,507.0	N/A	Bbls/yr	Produced Gas	36,777.0	14,720.0	293.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	51.79	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lbs/gal	87 RB	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lbs/gal	Z-Sol	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lbs/gal	Transfoam Plus	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lbs/gal	Sigma Thinner 90-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.59 lbs/gal	Sigma Thinner 91-57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lbs/gal	Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lbs/gal	<b>Solvent Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>9.89</b>	<b>Tons/yr ROC</b>	<b>Coatings Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>N/A</b>	<b>Gal/yr</b>	Boats:																	Crew Boat Fuel:	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,990	1,856	2,779	2,593	3,829	Gal/mo	24,674	N/A	Gal/yr	Work Boat Fuel:	1,659	1,628	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,866	2,809	4,148	Gal/mo	27,762	N/A	Gal/yr	<b>Total Boats Fuel</b>	<b>3,190</b>	<b>3,315</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,646</b>	<b>5,402</b>	<b>7,977</b>	<b>Gal/mo</b>	<b>52,437</b>	<b>167,100</b>	<b>Gal/yr</b>	Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																		
<b>Turbines @ all loads</b>	<b>0.9</b>	<b>0.2</b>	<b>9.7</b>	<b>0.0</b>	<b>3.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.1</b>	<b>0.00</b>	<b>0.0355</b>	<b>MGal/mo</b>	<b>14.04</b>	<b>335</b>	<b>MGal/yr</b>	Turbine@<1000 KW	0.27	0.11	9.75	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.00	0.0355	MGal/mo	11.33	160	MGal/yr	Back-up Generator:G4	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	0.08	MGal/mo	3.64	32.13	MGal/yr	North Crane	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	0.00	Gal/mo	334.0	N/A	Gal/yr	South Crane	527.00	348.00	508.00	287.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	345.00	Gal/mo	3,235.0	N/A	Gal/yr	<b>Crane Total</b>	<b>576.00</b>	<b>419.00</b>	<b>508.00</b>	<b>339.00</b>	<b>0.00</b>	<b>210.00</b>	<b>195.00</b>	<b>189.00</b>	<b>144.00</b>	<b>295.00</b>	<b>349.00</b>	<b>345.00</b>	<b>Gal/mo</b>	<b>3,569</b>	<b>21,339</b>	<b>Gal/yr</b>	Turbine Starter Engines	10.57	0.68	3.22	0.76	2.11	0.17	0.00	0.00	0.49	0.61	0.72	0.97	Hrs/mo	156.5	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.50	7.20	0.60	0.50	0.30	2.00	0.00	1.30	0.55	1.70	1.70	9.10	Gal/mo	24.3	1,406	Gal/yr	<b>P-18 -Em FW Pump</b>	<b>1.00</b>	<b>0.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>2.00</b>	<b>2.00</b>	<b>3.00</b>	<b>Hrs/mo</b>	<b>17.0</b>	<b>50</b>	<b>Hrs/yr</b>	Tank Throughputs																	V-08	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	72,507.0	N/A	Bbls/yr	Produced Gas	36,777.0	14,720.0	293.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	51.79	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lbs/gal	87 RB	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lbs/gal	Z-Sol	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lbs/gal	Transfoam Plus	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lbs/gal	Sigma Thinner 90-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.59 lbs/gal	Sigma Thinner 91-57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lbs/gal	Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lbs/gal	<b>Solvent Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>9.89</b>	<b>Tons/yr ROC</b>	<b>Coatings Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>N/A</b>	<b>Gal/yr</b>	Boats:																	Crew Boat Fuel:	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,990	1,856	2,779	2,593	3,829	Gal/mo	24,674	N/A	Gal/yr	Work Boat Fuel:	1,659	1,628	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,866	2,809	4,148	Gal/mo	27,762	N/A	Gal/yr	<b>Total Boats Fuel</b>	<b>3,190</b>	<b>3,315</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,646</b>	<b>5,402</b>	<b>7,977</b>	<b>Gal/mo</b>	<b>52,437</b>	<b>167,100</b>	<b>Gal/yr</b>	Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																			
Turbine@<1000 KW	0.27	0.11	9.75	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.00	0.0355	MGal/mo	11.33	160	MGal/yr	Back-up Generator:G4	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	0.08	MGal/mo	3.64	32.13	MGal/yr	North Crane	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	0.00	Gal/mo	334.0	N/A	Gal/yr	South Crane	527.00	348.00	508.00	287.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	345.00	Gal/mo	3,235.0	N/A	Gal/yr	<b>Crane Total</b>	<b>576.00</b>	<b>419.00</b>	<b>508.00</b>	<b>339.00</b>	<b>0.00</b>	<b>210.00</b>	<b>195.00</b>	<b>189.00</b>	<b>144.00</b>	<b>295.00</b>	<b>349.00</b>	<b>345.00</b>	<b>Gal/mo</b>	<b>3,569</b>	<b>21,339</b>	<b>Gal/yr</b>	Turbine Starter Engines	10.57	0.68	3.22	0.76	2.11	0.17	0.00	0.00	0.49	0.61	0.72	0.97	Hrs/mo	156.5	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.50	7.20	0.60	0.50	0.30	2.00	0.00	1.30	0.55	1.70	1.70	9.10	Gal/mo	24.3	1,406	Gal/yr	<b>P-18 -Em FW Pump</b>	<b>1.00</b>	<b>0.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>2.00</b>	<b>2.00</b>	<b>3.00</b>	<b>Hrs/mo</b>	<b>17.0</b>	<b>50</b>	<b>Hrs/yr</b>	Tank Throughputs																	V-08	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	72,507.0	N/A	Bbls/yr	Produced Gas	36,777.0	14,720.0	293.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	51.79	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lbs/gal	87 RB	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lbs/gal	Z-Sol	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lbs/gal	Transfoam Plus	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lbs/gal	Sigma Thinner 90-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.59 lbs/gal	Sigma Thinner 91-57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lbs/gal	Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lbs/gal	<b>Solvent Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>9.89</b>	<b>Tons/yr ROC</b>	<b>Coatings Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>N/A</b>	<b>Gal/yr</b>	Boats:																	Crew Boat Fuel:	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,990	1,856	2,779	2,593	3,829	Gal/mo	24,674	N/A	Gal/yr	Work Boat Fuel:	1,659	1,628	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,866	2,809	4,148	Gal/mo	27,762	N/A	Gal/yr	<b>Total Boats Fuel</b>	<b>3,190</b>	<b>3,315</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,646</b>	<b>5,402</b>	<b>7,977</b>	<b>Gal/mo</b>	<b>52,437</b>	<b>167,100</b>	<b>Gal/yr</b>	Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																				
Back-up Generator:G4	1.01	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	0.08	MGal/mo	3.64	32.13	MGal/yr	North Crane	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	0.00	Gal/mo	334.0	N/A	Gal/yr	South Crane	527.00	348.00	508.00	287.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	345.00	Gal/mo	3,235.0	N/A	Gal/yr	<b>Crane Total</b>	<b>576.00</b>	<b>419.00</b>	<b>508.00</b>	<b>339.00</b>	<b>0.00</b>	<b>210.00</b>	<b>195.00</b>	<b>189.00</b>	<b>144.00</b>	<b>295.00</b>	<b>349.00</b>	<b>345.00</b>	<b>Gal/mo</b>	<b>3,569</b>	<b>21,339</b>	<b>Gal/yr</b>	Turbine Starter Engines	10.57	0.68	3.22	0.76	2.11	0.17	0.00	0.00	0.49	0.61	0.72	0.97	Hrs/mo	156.5	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.50	7.20	0.60	0.50	0.30	2.00	0.00	1.30	0.55	1.70	1.70	9.10	Gal/mo	24.3	1,406	Gal/yr	<b>P-18 -Em FW Pump</b>	<b>1.00</b>	<b>0.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>2.00</b>	<b>2.00</b>	<b>3.00</b>	<b>Hrs/mo</b>	<b>17.0</b>	<b>50</b>	<b>Hrs/yr</b>	Tank Throughputs																	V-08	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	72,507.0	N/A	Bbls/yr	Produced Gas	36,777.0	14,720.0	293.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	51.79	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lbs/gal	87 RB	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lbs/gal	Z-Sol	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lbs/gal	Transfoam Plus	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lbs/gal	Sigma Thinner 90-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.59 lbs/gal	Sigma Thinner 91-57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lbs/gal	Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lbs/gal	<b>Solvent Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>9.89</b>	<b>Tons/yr ROC</b>	<b>Coatings Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>N/A</b>	<b>Gal/yr</b>	Boats:																	Crew Boat Fuel:	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,990	1,856	2,779	2,593	3,829	Gal/mo	24,674	N/A	Gal/yr	Work Boat Fuel:	1,659	1,628	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,866	2,809	4,148	Gal/mo	27,762	N/A	Gal/yr	<b>Total Boats Fuel</b>	<b>3,190</b>	<b>3,315</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,646</b>	<b>5,402</b>	<b>7,977</b>	<b>Gal/mo</b>	<b>52,437</b>	<b>167,100</b>	<b>Gal/yr</b>	Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																					
North Crane	49.00	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	0.00	Gal/mo	334.0	N/A	Gal/yr	South Crane	527.00	348.00	508.00	287.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	345.00	Gal/mo	3,235.0	N/A	Gal/yr	<b>Crane Total</b>	<b>576.00</b>	<b>419.00</b>	<b>508.00</b>	<b>339.00</b>	<b>0.00</b>	<b>210.00</b>	<b>195.00</b>	<b>189.00</b>	<b>144.00</b>	<b>295.00</b>	<b>349.00</b>	<b>345.00</b>	<b>Gal/mo</b>	<b>3,569</b>	<b>21,339</b>	<b>Gal/yr</b>	Turbine Starter Engines	10.57	0.68	3.22	0.76	2.11	0.17	0.00	0.00	0.49	0.61	0.72	0.97	Hrs/mo	156.5	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.50	7.20	0.60	0.50	0.30	2.00	0.00	1.30	0.55	1.70	1.70	9.10	Gal/mo	24.3	1,406	Gal/yr	<b>P-18 -Em FW Pump</b>	<b>1.00</b>	<b>0.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>2.00</b>	<b>2.00</b>	<b>3.00</b>	<b>Hrs/mo</b>	<b>17.0</b>	<b>50</b>	<b>Hrs/yr</b>	Tank Throughputs																	V-08	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	72,507.0	N/A	Bbls/yr	Produced Gas	36,777.0	14,720.0	293.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	51.79	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lbs/gal	87 RB	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lbs/gal	Z-Sol	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lbs/gal	Transfoam Plus	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lbs/gal	Sigma Thinner 90-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.59 lbs/gal	Sigma Thinner 91-57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lbs/gal	Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lbs/gal	<b>Solvent Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>9.89</b>	<b>Tons/yr ROC</b>	<b>Coatings Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>N/A</b>	<b>Gal/yr</b>	Boats:																	Crew Boat Fuel:	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,990	1,856	2,779	2,593	3,829	Gal/mo	24,674	N/A	Gal/yr	Work Boat Fuel:	1,659	1,628	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,866	2,809	4,148	Gal/mo	27,762	N/A	Gal/yr	<b>Total Boats Fuel</b>	<b>3,190</b>	<b>3,315</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,646</b>	<b>5,402</b>	<b>7,977</b>	<b>Gal/mo</b>	<b>52,437</b>	<b>167,100</b>	<b>Gal/yr</b>	Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																						
South Crane	527.00	348.00	508.00	287.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	345.00	Gal/mo	3,235.0	N/A	Gal/yr	<b>Crane Total</b>	<b>576.00</b>	<b>419.00</b>	<b>508.00</b>	<b>339.00</b>	<b>0.00</b>	<b>210.00</b>	<b>195.00</b>	<b>189.00</b>	<b>144.00</b>	<b>295.00</b>	<b>349.00</b>	<b>345.00</b>	<b>Gal/mo</b>	<b>3,569</b>	<b>21,339</b>	<b>Gal/yr</b>	Turbine Starter Engines	10.57	0.68	3.22	0.76	2.11	0.17	0.00	0.00	0.49	0.61	0.72	0.97	Hrs/mo	156.5	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.50	7.20	0.60	0.50	0.30	2.00	0.00	1.30	0.55	1.70	1.70	9.10	Gal/mo	24.3	1,406	Gal/yr	<b>P-18 -Em FW Pump</b>	<b>1.00</b>	<b>0.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>2.00</b>	<b>2.00</b>	<b>3.00</b>	<b>Hrs/mo</b>	<b>17.0</b>	<b>50</b>	<b>Hrs/yr</b>	Tank Throughputs																	V-08	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	72,507.0	N/A	Bbls/yr	Produced Gas	36,777.0	14,720.0	293.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	51.79	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lbs/gal	87 RB	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lbs/gal	Z-Sol	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lbs/gal	Transfoam Plus	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lbs/gal	Sigma Thinner 90-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.59 lbs/gal	Sigma Thinner 91-57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lbs/gal	Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lbs/gal	<b>Solvent Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>9.89</b>	<b>Tons/yr ROC</b>	<b>Coatings Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>N/A</b>	<b>Gal/yr</b>	Boats:																	Crew Boat Fuel:	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,990	1,856	2,779	2,593	3,829	Gal/mo	24,674	N/A	Gal/yr	Work Boat Fuel:	1,659	1,628	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,866	2,809	4,148	Gal/mo	27,762	N/A	Gal/yr	<b>Total Boats Fuel</b>	<b>3,190</b>	<b>3,315</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,646</b>	<b>5,402</b>	<b>7,977</b>	<b>Gal/mo</b>	<b>52,437</b>	<b>167,100</b>	<b>Gal/yr</b>	Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																							
<b>Crane Total</b>	<b>576.00</b>	<b>419.00</b>	<b>508.00</b>	<b>339.00</b>	<b>0.00</b>	<b>210.00</b>	<b>195.00</b>	<b>189.00</b>	<b>144.00</b>	<b>295.00</b>	<b>349.00</b>	<b>345.00</b>	<b>Gal/mo</b>	<b>3,569</b>	<b>21,339</b>	<b>Gal/yr</b>	Turbine Starter Engines	10.57	0.68	3.22	0.76	2.11	0.17	0.00	0.00	0.49	0.61	0.72	0.97	Hrs/mo	156.5	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.50	7.20	0.60	0.50	0.30	2.00	0.00	1.30	0.55	1.70	1.70	9.10	Gal/mo	24.3	1,406	Gal/yr	<b>P-18 -Em FW Pump</b>	<b>1.00</b>	<b>0.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>2.00</b>	<b>2.00</b>	<b>3.00</b>	<b>Hrs/mo</b>	<b>17.0</b>	<b>50</b>	<b>Hrs/yr</b>	Tank Throughputs																	V-08	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	72,507.0	N/A	Bbls/yr	Produced Gas	36,777.0	14,720.0	293.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	51.79	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lbs/gal	87 RB	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lbs/gal	Z-Sol	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lbs/gal	Transfoam Plus	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lbs/gal	Sigma Thinner 90-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.59 lbs/gal	Sigma Thinner 91-57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lbs/gal	Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lbs/gal	<b>Solvent Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>9.89</b>	<b>Tons/yr ROC</b>	<b>Coatings Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>N/A</b>	<b>Gal/yr</b>	Boats:																	Crew Boat Fuel:	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,990	1,856	2,779	2,593	3,829	Gal/mo	24,674	N/A	Gal/yr	Work Boat Fuel:	1,659	1,628	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,866	2,809	4,148	Gal/mo	27,762	N/A	Gal/yr	<b>Total Boats Fuel</b>	<b>3,190</b>	<b>3,315</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,646</b>	<b>5,402</b>	<b>7,977</b>	<b>Gal/mo</b>	<b>52,437</b>	<b>167,100</b>	<b>Gal/yr</b>	Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																								
Turbine Starter Engines	10.57	0.68	3.22	0.76	2.11	0.17	0.00	0.00	0.49	0.61	0.72	0.97	Hrs/mo	156.5	960	Gal/yr at 7.7 gal/hr	Boom Boat (VP)	0.50	7.20	0.60	0.50	0.30	2.00	0.00	1.30	0.55	1.70	1.70	9.10	Gal/mo	24.3	1,406	Gal/yr	<b>P-18 -Em FW Pump</b>	<b>1.00</b>	<b>0.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>2.00</b>	<b>2.00</b>	<b>3.00</b>	<b>Hrs/mo</b>	<b>17.0</b>	<b>50</b>	<b>Hrs/yr</b>	Tank Throughputs																	V-08	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	72,507.0	N/A	Bbls/yr	Produced Gas	36,777.0	14,720.0	293.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	51.79	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lbs/gal	87 RB	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lbs/gal	Z-Sol	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lbs/gal	Transfoam Plus	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lbs/gal	Sigma Thinner 90-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.59 lbs/gal	Sigma Thinner 91-57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lbs/gal	Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lbs/gal	<b>Solvent Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>9.89</b>	<b>Tons/yr ROC</b>	<b>Coatings Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>N/A</b>	<b>Gal/yr</b>	Boats:																	Crew Boat Fuel:	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,990	1,856	2,779	2,593	3,829	Gal/mo	24,674	N/A	Gal/yr	Work Boat Fuel:	1,659	1,628	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,866	2,809	4,148	Gal/mo	27,762	N/A	Gal/yr	<b>Total Boats Fuel</b>	<b>3,190</b>	<b>3,315</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,646</b>	<b>5,402</b>	<b>7,977</b>	<b>Gal/mo</b>	<b>52,437</b>	<b>167,100</b>	<b>Gal/yr</b>	Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																									
Boom Boat (VP)	0.50	7.20	0.60	0.50	0.30	2.00	0.00	1.30	0.55	1.70	1.70	9.10	Gal/mo	24.3	1,406	Gal/yr	<b>P-18 -Em FW Pump</b>	<b>1.00</b>	<b>0.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>2.00</b>	<b>2.00</b>	<b>3.00</b>	<b>Hrs/mo</b>	<b>17.0</b>	<b>50</b>	<b>Hrs/yr</b>	Tank Throughputs																	V-08	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	72,507.0	N/A	Bbls/yr	Produced Gas	36,777.0	14,720.0	293.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	51.79	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lbs/gal	87 RB	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lbs/gal	Z-Sol	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lbs/gal	Transfoam Plus	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lbs/gal	Sigma Thinner 90-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.59 lbs/gal	Sigma Thinner 91-57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lbs/gal	Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lbs/gal	<b>Solvent Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>9.89</b>	<b>Tons/yr ROC</b>	<b>Coatings Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>N/A</b>	<b>Gal/yr</b>	Boats:																	Crew Boat Fuel:	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,990	1,856	2,779	2,593	3,829	Gal/mo	24,674	N/A	Gal/yr	Work Boat Fuel:	1,659	1,628	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,866	2,809	4,148	Gal/mo	27,762	N/A	Gal/yr	<b>Total Boats Fuel</b>	<b>3,190</b>	<b>3,315</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,646</b>	<b>5,402</b>	<b>7,977</b>	<b>Gal/mo</b>	<b>52,437</b>	<b>167,100</b>	<b>Gal/yr</b>	Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																										
<b>P-18 -Em FW Pump</b>	<b>1.00</b>	<b>0.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>2.00</b>	<b>2.00</b>	<b>3.00</b>	<b>Hrs/mo</b>	<b>17.0</b>	<b>50</b>	<b>Hrs/yr</b>	Tank Throughputs																	V-08	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	72,507.0	N/A	Bbls/yr	Produced Gas	36,777.0	14,720.0	293.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	51.79	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lbs/gal	87 RB	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lbs/gal	Z-Sol	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lbs/gal	Transfoam Plus	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lbs/gal	Sigma Thinner 90-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.59 lbs/gal	Sigma Thinner 91-57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lbs/gal	Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lbs/gal	<b>Solvent Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>9.89</b>	<b>Tons/yr ROC</b>	<b>Coatings Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>N/A</b>	<b>Gal/yr</b>	Boats:																	Crew Boat Fuel:	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,990	1,856	2,779	2,593	3,829	Gal/mo	24,674	N/A	Gal/yr	Work Boat Fuel:	1,659	1,628	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,866	2,809	4,148	Gal/mo	27,762	N/A	Gal/yr	<b>Total Boats Fuel</b>	<b>3,190</b>	<b>3,315</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,646</b>	<b>5,402</b>	<b>7,977</b>	<b>Gal/mo</b>	<b>52,437</b>	<b>167,100</b>	<b>Gal/yr</b>	Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																											
Tank Throughputs																	V-08	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	72,507.0	N/A	Bbls/yr	Produced Gas	36,777.0	14,720.0	293.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	51.79	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lbs/gal	87 RB	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lbs/gal	Z-Sol	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lbs/gal	Transfoam Plus	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lbs/gal	Sigma Thinner 90-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.59 lbs/gal	Sigma Thinner 91-57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lbs/gal	Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lbs/gal	<b>Solvent Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>9.89</b>	<b>Tons/yr ROC</b>	<b>Coatings Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>N/A</b>	<b>Gal/yr</b>	Boats:																	Crew Boat Fuel:	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,990	1,856	2,779	2,593	3,829	Gal/mo	24,674	N/A	Gal/yr	Work Boat Fuel:	1,659	1,628	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,866	2,809	4,148	Gal/mo	27,762	N/A	Gal/yr	<b>Total Boats Fuel</b>	<b>3,190</b>	<b>3,315</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,646</b>	<b>5,402</b>	<b>7,977</b>	<b>Gal/mo</b>	<b>52,437</b>	<b>167,100</b>	<b>Gal/yr</b>	Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																												
V-08	47,230.0	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	72,507.0	N/A	Bbls/yr	Produced Gas	36,777.0	14,720.0	293.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	51.79	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lbs/gal	87 RB	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lbs/gal	Z-Sol	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lbs/gal	Transfoam Plus	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lbs/gal	Sigma Thinner 90-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.59 lbs/gal	Sigma Thinner 91-57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lbs/gal	Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lbs/gal	<b>Solvent Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>9.89</b>	<b>Tons/yr ROC</b>	<b>Coatings Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>N/A</b>	<b>Gal/yr</b>	Boats:																	Crew Boat Fuel:	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,990	1,856	2,779	2,593	3,829	Gal/mo	24,674	N/A	Gal/yr	Work Boat Fuel:	1,659	1,628	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,866	2,809	4,148	Gal/mo	27,762	N/A	Gal/yr	<b>Total Boats Fuel</b>	<b>3,190</b>	<b>3,315</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,646</b>	<b>5,402</b>	<b>7,977</b>	<b>Gal/mo</b>	<b>52,437</b>	<b>167,100</b>	<b>Gal/yr</b>	Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																													
Produced Gas	36,777.0	14,720.0	293.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	51.79	N/A	MMSCF/yr	Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lbs/gal	87 RB	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lbs/gal	Z-Sol	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lbs/gal	Transfoam Plus	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lbs/gal	Sigma Thinner 90-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.59 lbs/gal	Sigma Thinner 91-57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lbs/gal	Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lbs/gal	<b>Solvent Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>9.89</b>	<b>Tons/yr ROC</b>	<b>Coatings Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>N/A</b>	<b>Gal/yr</b>	Boats:																	Crew Boat Fuel:	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,990	1,856	2,779	2,593	3,829	Gal/mo	24,674	N/A	Gal/yr	Work Boat Fuel:	1,659	1,628	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,866	2,809	4,148	Gal/mo	27,762	N/A	Gal/yr	<b>Total Boats Fuel</b>	<b>3,190</b>	<b>3,315</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,646</b>	<b>5,402</b>	<b>7,977</b>	<b>Gal/mo</b>	<b>52,437</b>	<b>167,100</b>	<b>Gal/yr</b>	Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																														
Solvent Usage																	Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lbs/gal	87 RB	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lbs/gal	Z-Sol	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lbs/gal	Transfoam Plus	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lbs/gal	Sigma Thinner 90-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.59 lbs/gal	Sigma Thinner 91-57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lbs/gal	Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lbs/gal	<b>Solvent Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>9.89</b>	<b>Tons/yr ROC</b>	<b>Coatings Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>N/A</b>	<b>Gal/yr</b>	Boats:																	Crew Boat Fuel:	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,990	1,856	2,779	2,593	3,829	Gal/mo	24,674	N/A	Gal/yr	Work Boat Fuel:	1,659	1,628	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,866	2,809	4,148	Gal/mo	27,762	N/A	Gal/yr	<b>Total Boats Fuel</b>	<b>3,190</b>	<b>3,315</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,646</b>	<b>5,402</b>	<b>7,977</b>	<b>Gal/mo</b>	<b>52,437</b>	<b>167,100</b>	<b>Gal/yr</b>	Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																															
Enviroseal 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lbs/gal	87 RB	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lbs/gal	Z-Sol	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lbs/gal	Transfoam Plus	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lbs/gal	Sigma Thinner 90-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.59 lbs/gal	Sigma Thinner 91-57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lbs/gal	Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lbs/gal	<b>Solvent Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>9.89</b>	<b>Tons/yr ROC</b>	<b>Coatings Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>N/A</b>	<b>Gal/yr</b>	Boats:																	Crew Boat Fuel:	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,990	1,856	2,779	2,593	3,829	Gal/mo	24,674	N/A	Gal/yr	Work Boat Fuel:	1,659	1,628	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,866	2,809	4,148	Gal/mo	27,762	N/A	Gal/yr	<b>Total Boats Fuel</b>	<b>3,190</b>	<b>3,315</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,646</b>	<b>5,402</b>	<b>7,977</b>	<b>Gal/mo</b>	<b>52,437</b>	<b>167,100</b>	<b>Gal/yr</b>	Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																
87 RB	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lbs/gal	Z-Sol	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lbs/gal	Transfoam Plus	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lbs/gal	Sigma Thinner 90-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.59 lbs/gal	Sigma Thinner 91-57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lbs/gal	Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lbs/gal	<b>Solvent Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>9.89</b>	<b>Tons/yr ROC</b>	<b>Coatings Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>N/A</b>	<b>Gal/yr</b>	Boats:																	Crew Boat Fuel:	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,990	1,856	2,779	2,593	3,829	Gal/mo	24,674	N/A	Gal/yr	Work Boat Fuel:	1,659	1,628	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,866	2,809	4,148	Gal/mo	27,762	N/A	Gal/yr	<b>Total Boats Fuel</b>	<b>3,190</b>	<b>3,315</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,646</b>	<b>5,402</b>	<b>7,977</b>	<b>Gal/mo</b>	<b>52,437</b>	<b>167,100</b>	<b>Gal/yr</b>	Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																	
Z-Sol	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lbs/gal	Transfoam Plus	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lbs/gal	Sigma Thinner 90-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.59 lbs/gal	Sigma Thinner 91-57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lbs/gal	Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lbs/gal	<b>Solvent Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>9.89</b>	<b>Tons/yr ROC</b>	<b>Coatings Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>N/A</b>	<b>Gal/yr</b>	Boats:																	Crew Boat Fuel:	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,990	1,856	2,779	2,593	3,829	Gal/mo	24,674	N/A	Gal/yr	Work Boat Fuel:	1,659	1,628	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,866	2,809	4,148	Gal/mo	27,762	N/A	Gal/yr	<b>Total Boats Fuel</b>	<b>3,190</b>	<b>3,315</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,646</b>	<b>5,402</b>	<b>7,977</b>	<b>Gal/mo</b>	<b>52,437</b>	<b>167,100</b>	<b>Gal/yr</b>	Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
Transfoam Plus	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lbs/gal	Sigma Thinner 90-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.59 lbs/gal	Sigma Thinner 91-57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lbs/gal	Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lbs/gal	<b>Solvent Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>9.89</b>	<b>Tons/yr ROC</b>	<b>Coatings Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>N/A</b>	<b>Gal/yr</b>	Boats:																	Crew Boat Fuel:	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,990	1,856	2,779	2,593	3,829	Gal/mo	24,674	N/A	Gal/yr	Work Boat Fuel:	1,659	1,628	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,866	2,809	4,148	Gal/mo	27,762	N/A	Gal/yr	<b>Total Boats Fuel</b>	<b>3,190</b>	<b>3,315</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,646</b>	<b>5,402</b>	<b>7,977</b>	<b>Gal/mo</b>	<b>52,437</b>	<b>167,100</b>	<b>Gal/yr</b>	Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																			
Sigma Thinner 90-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.59 lbs/gal	Sigma Thinner 91-57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lbs/gal	Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lbs/gal	<b>Solvent Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>9.89</b>	<b>Tons/yr ROC</b>	<b>Coatings Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>N/A</b>	<b>Gal/yr</b>	Boats:																	Crew Boat Fuel:	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,990	1,856	2,779	2,593	3,829	Gal/mo	24,674	N/A	Gal/yr	Work Boat Fuel:	1,659	1,628	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,866	2,809	4,148	Gal/mo	27,762	N/A	Gal/yr	<b>Total Boats Fuel</b>	<b>3,190</b>	<b>3,315</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,646</b>	<b>5,402</b>	<b>7,977</b>	<b>Gal/mo</b>	<b>52,437</b>	<b>167,100</b>	<b>Gal/yr</b>	Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																				
Sigma Thinner 91-57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lbs/gal	Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lbs/gal	<b>Solvent Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>9.89</b>	<b>Tons/yr ROC</b>	<b>Coatings Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>N/A</b>	<b>Gal/yr</b>	Boats:																	Crew Boat Fuel:	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,990	1,856	2,779	2,593	3,829	Gal/mo	24,674	N/A	Gal/yr	Work Boat Fuel:	1,659	1,628	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,866	2,809	4,148	Gal/mo	27,762	N/A	Gal/yr	<b>Total Boats Fuel</b>	<b>3,190</b>	<b>3,315</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,646</b>	<b>5,402</b>	<b>7,977</b>	<b>Gal/mo</b>	<b>52,437</b>	<b>167,100</b>	<b>Gal/yr</b>	Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																					
Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lbs/gal	<b>Solvent Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>9.89</b>	<b>Tons/yr ROC</b>	<b>Coatings Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>N/A</b>	<b>Gal/yr</b>	Boats:																	Crew Boat Fuel:	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,990	1,856	2,779	2,593	3,829	Gal/mo	24,674	N/A	Gal/yr	Work Boat Fuel:	1,659	1,628	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,866	2,809	4,148	Gal/mo	27,762	N/A	Gal/yr	<b>Total Boats Fuel</b>	<b>3,190</b>	<b>3,315</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,646</b>	<b>5,402</b>	<b>7,977</b>	<b>Gal/mo</b>	<b>52,437</b>	<b>167,100</b>	<b>Gal/yr</b>	Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																						
<b>Solvent Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>9.89</b>	<b>Tons/yr ROC</b>	<b>Coatings Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>N/A</b>	<b>Gal/yr</b>	Boats:																	Crew Boat Fuel:	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,990	1,856	2,779	2,593	3,829	Gal/mo	24,674	N/A	Gal/yr	Work Boat Fuel:	1,659	1,628	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,866	2,809	4,148	Gal/mo	27,762	N/A	Gal/yr	<b>Total Boats Fuel</b>	<b>3,190</b>	<b>3,315</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,646</b>	<b>5,402</b>	<b>7,977</b>	<b>Gal/mo</b>	<b>52,437</b>	<b>167,100</b>	<b>Gal/yr</b>	Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																							
<b>Coatings Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>N/A</b>	<b>Gal/yr</b>	Boats:																	Crew Boat Fuel:	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,990	1,856	2,779	2,593	3,829	Gal/mo	24,674	N/A	Gal/yr	Work Boat Fuel:	1,659	1,628	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,866	2,809	4,148	Gal/mo	27,762	N/A	Gal/yr	<b>Total Boats Fuel</b>	<b>3,190</b>	<b>3,315</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,646</b>	<b>5,402</b>	<b>7,977</b>	<b>Gal/mo</b>	<b>52,437</b>	<b>167,100</b>	<b>Gal/yr</b>	Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																								
Boats:																	Crew Boat Fuel:	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,990	1,856	2,779	2,593	3,829	Gal/mo	24,674	N/A	Gal/yr	Work Boat Fuel:	1,659	1,628	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,866	2,809	4,148	Gal/mo	27,762	N/A	Gal/yr	<b>Total Boats Fuel</b>	<b>3,190</b>	<b>3,315</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,646</b>	<b>5,402</b>	<b>7,977</b>	<b>Gal/mo</b>	<b>52,437</b>	<b>167,100</b>	<b>Gal/yr</b>	Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																									
Crew Boat Fuel:	1,531	1,687	2,192	1,294	1,352	1,966	1,605	1,990	1,856	2,779	2,593	3,829	Gal/mo	24,674	N/A	Gal/yr	Work Boat Fuel:	1,659	1,628	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,866	2,809	4,148	Gal/mo	27,762	N/A	Gal/yr	<b>Total Boats Fuel</b>	<b>3,190</b>	<b>3,315</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,646</b>	<b>5,402</b>	<b>7,977</b>	<b>Gal/mo</b>	<b>52,437</b>	<b>167,100</b>	<b>Gal/yr</b>	Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																										
Work Boat Fuel:	1,659	1,628	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,866	2,809	4,148	Gal/mo	27,762	N/A	Gal/yr	<b>Total Boats Fuel</b>	<b>3,190</b>	<b>3,315</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,646</b>	<b>5,402</b>	<b>7,977</b>	<b>Gal/mo</b>	<b>52,437</b>	<b>167,100</b>	<b>Gal/yr</b>	Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																											
<b>Total Boats Fuel</b>	<b>3,190</b>	<b>3,315</b>	<b>4,566</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,646</b>	<b>5,402</b>	<b>7,977</b>	<b>Gal/mo</b>	<b>52,437</b>	<b>167,100</b>	<b>Gal/yr</b>	Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																												
Boat Emissions																	ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																													
ROC	0.05	0.06	0.08	0.04	0.05	0.07	0.09	0.10	0.06	0.06	0.09	0.13	Tons/mo	0.87	2.77	Tons/yr at 33.15 lbs/MGal	NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																														
NOx	0.89	0.99	1.26	0.76	0.79	1.15	0.94	1.77	1.09	1.31	1.52	2.24	Tons/mo	14.71	46.87	Tons/yr at 561.00 lbs/MGal	PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																															
PM	0.05	0.06	0.08	0.05	0.05	0.07	0.06	0.11	0.06	0.06	0.08	0.13	Tons/mo	0.88	2.80	Tons/yr at 33.50 lbs/MGal	SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																
SOx	0.01	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.03	0.03	Tons/mo	0.20	0.63	Tons/yr at 7.50 lbs/MGal	CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																	
CO	0.16	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	Tons/mo	2.67	8.52	Tons/yr at 102.00 lbs/MGal																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		



**Platform Gail**  
**PTO No. 1494 Equipment Usage**  
**Rolling 12-Months Ending:**  
**Oct-18**

Equipment	Nov-17	Dec-17	Jan-18	Feb-18	Mar-18	Apr-18	May-18	Jun-18	Jul-18	Aug-18	Sep-18	Oct-18	Monthly Units	12-Month Total	Permit Limit	12-Mo & Permit Units
Gas Consumption:																
HP Planned	0.0	0.0	184.0	131.0	0.0	84.0	80.0	0.0	0.0	88.0	0.0	53.0	MSCF/mo	0.82	N/A	MMSCF/yr
HP Pilot/Purge	92.1	92.1	82.1	82.1	89.1	89.1	92.1	92.1	92.1	92.1	89.1	92.1	MSCF/mo	1.09	N/A	MMSCF/yr
HP Planned & PIP	92.1	92.1	256.1	214.2	92.1	183.1	182.1	89.1	92.1	180.1	89.1	145.1	MSCF/mo	1.71	Exempt	MMSCF/yr
HP Unplanned	1,041.0	860.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	1.90	Exempt	MMSCF/yr
LP Planned	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	0.00	N/A	MMSCF/yr
LP Pilot/Purge	144.8	144.8	144.8	130.8	144.8	140.1	79.4	0.0	0.0	0.0	0.0	0.0	MSCF/mo	0.93	N/A	MMSCF/yr
LP Planned & PIP	144.8	144.8	144.8	130.8	144.8	140.1	79.4	0.0	0.0	0.0	0.0	0.0	MSCF/mo	0.93	Exempt	MMSCF/yr
LP Unplanned	658.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	0.66	Exempt	MMSCF/yr
Gas Consumption:																
Turbines: G1	11.4	1.3	0.0	0.4	12.3	13.2	13.7	13.3	13.8	14.0	16.0	0.0	MMSCF/mo	94.94	N/A	MMSCF/yr
Turbines: G2	12.1	5.8	0.6	7.5	0.0	0.0	0.0	0.0	0.0	0.0	1.7	0.5	MMSCF/mo	28.14	N/A	MMSCF/yr
Turbines: G3	18.6	6.7	13.7	4.3	1.1	0.0	0.0	0.0	0.0	0.0	10.0	13.0	MMSCF/mo	67.37	N/A	MMSCF/yr
Turbines @ all loads	42.2	13.8	14.3	12.1	13.3	13.2	13.7	13.3	13.8	14.0	13.2	13.5	MMSCF/mo	190.48	850	MMSCF/yr
Turbines @ <1000 KW	7.93	13.66	14.29	11.9	13.33	13.22	13.69	13.3	13.8	14.0	13.20	13.48	MMSCF/mo	155.89	250.0	MMSCF/yr
Diesel Use:																
Turbines: G1	0.06	0.00	0.00	0.85	0.01	0.00	0.00	0.00	0.06	0.00	0.00	0.00	MGal/mo	1.00	N/A	MGal/yr
Turbines: G2	0.00	9.74	0.00	0.00	0.00	0.00	0.00	0.02	0.00	0.00	0.00	0.00	MGal/mo	11.05	N/A	MGal/yr
Turbines: G3	0.16	0.00	0.00	0.92	0.00	0.00	0.00	0.00	0.01	0.00	0.00	0.00	MGal/mo	1.11	N/A	MGal/yr
Turbines @ all loads	0.22	9.74	0.00	3.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MGal/mo	13.16	335	MGal/yr
Turbines @ <1000 KW	0.11	9.75	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.00	0.04	0.0191	MGal/mo	11.07	150	MGal/yr
Back-up Generator G4	0.25	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	0.08	0.05	MGal/mo	2.69	32.13	MGal/yr
North Crane	71.00	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	0.00	0.00	Gal/mo	285.0	N/A	Gal/yr
South Crane	348.00	508.00	287.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	345.00	495.00	Gal/mo	3,203.0	N/A	Gal/yr
Crane Total	419.00	508.00	339.00	0.00	210.00	195.00	189.00	144.00	295.00	349.00	345.00	495.00	Gal/mo	3,488	21,359	Gal/yr
Turbine Starter Engines	0.68	3.22	0.78	2.11	0.17	0.00	0.00	0.49	0.61	0.72	0.97	0.46	Hrs/mo	78.6	960	Gal/yr at 7.7 gal/hr
Boom Boat (VP)	7.20	0.60	0.50	0.50	2.00	0.00	1.30	0.55	0.30	1.70	9.10	0.80	Gal/mo	24.6	1,406	Gal/yr
P-18 -Em FW Pump	0.00	1.00	0.00	3.00	1.00	0.00	3.00	1.00	2.00	2.00	3.00	1.00	Hrs/mo	17.0	50	Hrs/yr
Tank Throughputs:																
V-06	25,277.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	25,277.0	N/A	Bbls/yr
Produced Gas	14,720.0	293.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	15.01	N/A	MMSCF/yr
Solvent Usage:																
Envirosol 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal
87 RB	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lb/gal
Z-Sol	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 0.17 lb/gal
Transfoam Plus	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal
Sigma Thinner 80-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal
Sigma Thinner 91-57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal
Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.10 lb/gal
Solvent Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.59	Tons/yr ROC
Coatings Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Gal/yr
Boats:																
Crew Boat Fuel:	1,687	2,192	1,294	1,352	1,966	1,605	1,990	1,856	2,779	2,593	3,829	3,300	Gal/mo	28,443	N/A	Gal/yr
Work Boat Fuel:	1,628	2,374	1,402	1,465	2,129	1,739	4,312	2,011	1,866	2,809	4,145	3,575	Gal/mo	29,678	N/A	Gal/yr
Total Boats Fuel	3,515	4,566	2,696	2,818	4,095	3,344	6,302	3,868	4,666	5,402	7,977	6,875	Gal/mo	58,122	187,100	Gal/yr
Boat Emissions:																
ROC	0.06	0.08	0.04	0.05	0.07	0.06	0.10	0.06	0.08	0.09	0.13	0.11	Tons/mo	0.93	2.77	Tons/yr at 33.15 lbs/MGal
NOx	0.99	1.28	0.76	0.79	1.15	0.94	1.77	1.08	1.52	2.24	1.93	1.93	Tons/mo	15.74	46.87	Tons/yr at 961.00 lbs/MGal
PM	0.05	0.08	0.05	0.05	0.06	0.11	0.06	0.03	0.03	0.09	0.13	0.12	Tons/mo	0.94	2.80	Tons/yr at 33.50 lbs/MGal
SOx	0.01	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	0.03	0.03	Tons/mo	0.21	0.63	Tons/yr at 7.50 lbs/MGal
CO	0.18	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	0.35	Tons/mo	2.86	8.52	Tons/yr at 102.00 lbs/MGal



**Platform Gail**  
**PTO No. 1494 Equipment Usage**  
**Rolling 12-Months Ending:**  
**Nov-18**

Equipment	Dec-17	Jan-18	Feb-18	Mar-18	Apr-18	May-18	Jun-18	Jul-18	Aug-18	Sep-18	Oct-18	Nov-18	Monthly Units	12-Month Total	Permit Limit	12-Mo & Permit Units
Gas Consumption																
HP Planned	0.0	164.0	131.0	0.0	94.0	90.0	0.0	0.0	86.0	0.0	53.0	46.0	MSCF/mo	0.67	N/A	MMSCF/yr
HP Pilot/Purge	92.1	82.1	83.2	92.1	89.1	92.1	89.1	92.1	89.1	89.1	92.1	89.1	MSCF/mo	1.08	N/A	MMSCF/yr
HP Planned & PIP	92.1	256.1	214.2	92.1	183.1	182.1	89.1	92.1	180.1	89.1	145.1	135.1	MSCF/mo	1.79	4.9	MMSCF/yr
HP Unplanned	860.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	0.66	Exempt	MMSCF/yr
LP Planned	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	0.00	N/A	MMSCF/yr
LP Pilot/Purge	144.8	144.8	130.8	144.8	140.1	79.4	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	0.78	N/A	MMSCF/yr
LP Planned & PIP	144.8	144.8	130.8	144.8	140.1	79.4	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	0.78	2.31	MMSCF/yr
LP Unplanned	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	0.00	Exempt	MMSCF/yr
Gas Consumption:																
Turbines: G1	1.3	0.0	0.4	12.3	13.2	13.7	13.3	13.8	14.0	1.6	0.0	0.0	MMSCF/mo	83.55	N/A	MMSCF/yr
G2	5.8	0.8	7.5	0.0	0.0	0.0	0.0	0.0	0.0	1.7	0.5	1.0	MMSCF/mo	17.01	N/A	MMSCF/yr
G3	6.7	13.7	4.3	1.1	0.0	0.0	0.0	0.0	10.0	13.0	13.0	12.0	MMSCF/mo	60.77	N/A	MMSCF/yr
Turbines @ all loads	13.8	14.3	12.1	13.3	13.2	13.7	13.3	13.8	14.0	13.2	13.5	13.0	MMSCF/mo	161.33	850	MMSCF/yr
Turbine@<1000 KW	13.68	14.29	11.86	13.3	13.22	13.69	13.33	13.8	14.0	13.2	13.48	13.03	MMSCF/mo	160.98	250.0	MMSCF/yr
Diesel Use:																
Turbines: G1	0.00	0.00	0.85	0.01	0.00	0.00	0.00	0.08	0.00	0.00	0.00	0.00	MGal/mo	0.94	N/A	MGal/yr
G2	9.74	0.00	1.25	0.00	0.00	0.00	0.02	0.00	0.00	0.029	0.02	0.017	MGal/mo	11.07	N/A	MGal/yr
G3	0.00	0.00	0.92	0.00	0.00	0.00	0.00	0.01	0.00	0.00	0.003	0.0047	MGal/mo	0.95	N/A	MGal/yr
Turbines @ all loads	9.74	0.00	3.0	0.01	0.00	0.00	0.1	0.09	0.00	0.03	0.02	0.0217	MGal/mo	12.96	335	MGal/yr
Turbine@<1000 KW	9.75	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.00	0.04	0.02	0.0217	MGal/mo	10.98	150	MGal/yr
Back-up Generator:G4	0.42	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	0.08	0.05	0.15	MGal/mo	2.59	32.13	MGal/yr
North Crane	0.00	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	0.00	0.00	113.00	Gal/mo	327.0	N/A	Gal/yr
South Crane	508.00	287.00	0.00	151.00	195.00	189.00	78.00	295.00	312.00	345.00	495.00	828.00	Gal/mo	3,681.0	N/A	Gal/yr
Crane Total	508.00	339.00	0.00	210.00	195.00	189.00	144.00	295.00	349.00	345.00	495.00	939.00	Gal/mo	4,008	21,339	Gal/yr
Turbine Starter Engines	3.22	0.76	2.11	0.17	0.00	0.00	0.49	0.61	0.72	0.97	0.46	0.44	Hrs/mo	76.8	960	Gallyr at 7.7 gal/hr
Boom Boat (VP)	0.60	0.50	0.50	2.00	0.00	1.30	0.55	0.30	1.70	9.10	0.80	5.20	Gal/mo	22.6	1,406	Gallyr
P-18 -Em FW Pump	1.00	0.00	3.00	1.00	0.00	3.00	1.00	2.00	2.00	3.00	1.00	3.00	Hrs/mo	20.0	50	Hrs/yr
Tank Throughputs:																
V-08	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	0.0	N/A	Bbls/yr
Produced Gas	293.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	0.29	N/A	MMSCF/yr
Solvent Usage																
Envirosol 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal
87 RB													Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lb/gal
Z-Sol													Gal/mo	0.000	N/A	Tons/yr ROC at 0.17 lb/gal
Transfoam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal
Sigma Thinner 90-53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal
Sigma Thinner 91-57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal
Carboline Thinner	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	N/A	Tons/yr ROC at 7.10 lb/gal
Solvent Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.000	9.59	Tons/yr ROC
Coatings Total																
Boats:																
Crew Boat Fuel:	2.182	1.294	1.352	1.968	1.605	1.960	1.856	2.779	2.593	3.829	3.300	2.760	Gal/mo	27.518	N/A	Gallyr
Work Boat Fuel:	2.374	1.402	1.465	2.129	1.739	4.312	2.011	1.898	2.809	4.148	3.575	2.960	Gal/mo	30.841	N/A	Gallyr
Total Boats Fuel	4.556	2.696	2.818	4.095	3.344	6.302	3.868	4.696	5.402	7.977	6.875	5.750	Gal/mo	58.357	167,100	Gallyr
Boat Emissions:																
ROC	0.08	0.04	0.05	0.07	0.08	0.10	0.08	0.08	0.09	0.13	0.11	0.10	Tons/mo	0.97	2.77	Tons/yr at 33.15 lbs/MGal
NOx	1.28	0.76	0.79	1.15	0.94	1.77	1.08	1.31	1.52	2.24	1.93	1.61	Tons/mo	16.37	46.87	Tons/yr at 561.00 lbs/MGal
PM	0.08	0.05	0.05	0.07	0.08	0.11	0.08	0.09	0.09	0.13	0.12	0.10	Tons/mo	0.98	2.80	Tons/yr at 33.50 lbs/MGal
SOx	0.02	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	0.03	0.03	0.02	Tons/mo	0.22	0.63	Tons/yr at 7.50 lbs/MGal
CO	0.23	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	0.35	0.29	Tons/mo	2.98	8.52	Tons/yr at 102.00 lbs/MGal



**Platform Gail**  
**PTO No. 1494 Equipment Usage**  
**Rolling 12-Months Ending:**  
**Dec-18**

Equipment	Jan-18	Feb-18	Mar-18	Apr-18	May-18	Jun-18	Jul-18	Aug-18	Sep-18	Oct-18	Nov-18	Dec-18	Monthly Units	12-month Total	Permit Limit	12-Mo & Permit Units
Gas Consumption:																
HP Planned	164.0	131.0	0.0	94.0	90.0	0.0	0.0	86.0	0.0	53.0	46.0	0.0	MSCF/mo	0.67	N/A	MMSCF/yr
HP Pilot/Purge	92.1	83.2	92.1	89.1	92.1	89.1	92.1	92.1	89.1	92.1	89.1	92.1	MSCF/mo	1.08	N/A	MMSCF/yr
<b>HP Planned &amp; P/P</b>	<b>256.1</b>	<b>214.2</b>	<b>184.1</b>	<b>183.1</b>	<b>182.1</b>	<b>89.1</b>	<b>92.1</b>	<b>180.1</b>	<b>89.1</b>	<b>145.1</b>	<b>135.1</b>	<b>92.1</b>	<b>MSCF/mo</b>	<b>1.76</b>	<b>4.9</b>	<b>MMSCF/yr</b>
HP Unplanned	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	0.00	Exempt	MMSCF/yr
LP Planned	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	0.00	N/A	MMSCF/yr
LP Pilot/Purge	144.8	130.8	144.8	140.1	79.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	0.64	N/A	MMSCF/yr
<b>LP Planned &amp; P/P</b>	<b>144.8</b>	<b>130.8</b>	<b>144.8</b>	<b>140.1</b>	<b>79.4</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>MSCF/mo</b>	<b>0.64</b>	<b>2.31</b>	<b>MMSCF/yr</b>
LP Unplanned	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	0.00	Exempt	MMSCF/yr
Gas Consumption:																
Turbines: G1	0.0	0.4	12.3	13.2	13.7	13.3	13.8	14.0	1.6	0.0	0.0	0.0	MMSCF/mo	62.27	N/A	MMSCF/yr
Turbines: G2	0.6	7.5	0.0	0.0	0.0	0.0	0.0	1.7	0.5	0.5	1.0	6.5	MMSCF/mo	17.67	N/A	MMSCF/yr
Turbines: G3	13.7	4.3	1.1	0.0	0.0	0.0	0.0	10.0	13.0	13.0	12.0	7.1	MMSCF/mo	61.23	N/A	MMSCF/yr
<b>Turbines @ all loads</b>	<b>14.3</b>	<b>12.1</b>	<b>13.3</b>	<b>13.2</b>	<b>13.7</b>	<b>13.3</b>	<b>13.8</b>	<b>14.0</b>	<b>13.2</b>	<b>13.5</b>	<b>13.0</b>	<b>13.6</b>	<b>MMSCF/mo</b>	<b>161.17</b>	<b>850</b>	<b>MMSCF/yr</b>
Turbine@<1000 KW	14.29	11.88	13.33	13.2	13.69	13.33	13.64	14.0	13.2	13.5	13.03	13.60	MMSCF/mo	160.90	250.0	MMSCF/yr
Diesel Use:																
Turbines: G1	0.00	0.85	0.01	0.00	0.00	0.00	0.04	0.00	0.00	0.00	0.00	0.00	MGal/mo	0.94	N/A	MGal/yr
Turbines: G2	0.00	1.25	0.00	0.00	0.00	0.02	0.00	0.00	0.03	0.016	0.02	0.006	MGal/mo	1.33	N/A	MGal/yr
Turbines: G3	0.00	0.92	0.00	0.00	0.00	0.00	0.01	0.00	0.00	0.00	0.005	0.0072	MGal/mo	0.95	N/A	MGal/yr
<b>Turbines @ all loads</b>	<b>0.00</b>	<b>3.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>MGal/mo</b>	<b>3.23</b>	<b>335</b>	<b>MGal/yr</b>
Turbine@<1000 KW	0.00	1.03	0.01	0.00	0.00	0.02	0.10	0.00	0.04	0.02	0.02	0.0135	MGal/mo	1.25	150	MGal/yr
Back-up Generator/G4	0.33	0.23	0.30	0.27	0.24	0.34	0.11	0.08	0.08	0.05	0.15	0.14	MGal/mo	2.31	32.13	MGal/yr
North Crane	52.00	0.00	59.00	0.00	0.00	66.00	0.00	37.00	0.00	0.00	113.00	59.00	Gal/mo	386.0	N/A	Gal/yr
South Crane	287.00	0.00	151.00	195.00	169.00	78.00	295.00	312.00	345.00	495.00	626.00	333.00	Gal/mo	3,506.0	N/A	Gal/yr
<b>Crane Total</b>	<b>339.00</b>	<b>0.00</b>	<b>210.00</b>	<b>195.00</b>	<b>169.00</b>	<b>144.00</b>	<b>295.00</b>	<b>349.00</b>	<b>345.00</b>	<b>495.00</b>	<b>939.00</b>	<b>392.00</b>	<b>Gal/mo</b>	<b>3,892</b>	<b>21,359</b>	<b>Gal/yr</b>
Turbine Starter Engines	0.78	2.11	0.17	0.00	0.00	0.49	0.61	0.72	0.97	0.46	0.44	0.52	Hrs/mo	56.0	960	Gal/yr at 7.7 gal/hr
Boom Boat (VP)	0.50	0.50	2.00	0.00	1.30	0.55	0.30	1.70	9.10	0.80	5.20	0.40	Gal/mo	22.4	1,406	Gal/yr
<b>P-18 -Em FW Pump</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>0.00</b>	<b>3.00</b>	<b>1.00</b>	<b>2.00</b>	<b>2.00</b>	<b>3.00</b>	<b>1.00</b>	<b>3.00</b>	<b>1.00</b>	<b>Hrs/mo</b>	<b>20.0</b>	<b>50</b>	<b>Hrs/yr</b>
Tank Throughputs:																
V.08	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Bbls/mo	0.0	N/A	Bbls/yr
Produced Gas	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	MSCF/mo	0.00	N/A	MMSCF/yr
Solvent Usage:																
Envirosol 2000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Tons/yr ROC
87 RB													Gal/mo	0.00	N/A	Tons/yr ROC at 1.64 lb/gal
Z-Sol													Gal/mo	0.00	N/A	Tons/yr ROC at 6.64 lb/gal
Transfoam Plus													Gal/mo	0.00	N/A	Tons/yr ROC at 0.17 lb/gal
Sigma Thinner 80-53													Gal/mo	0.00	N/A	Tons/yr ROC at 0.64 lb/gal
Sigma Thinner 91-57													Gal/mo	0.00	N/A	Tons/yr ROC at 7.39 lb/gal
Carboline Thinner													Gal/mo	0.00	N/A	Tons/yr ROC at 7.28 lb/gal
<b>Solvent Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>Gal/mo</b>	<b>0.000</b>	<b>9.89</b>	<b>Tons/yr ROC</b>
Coatings Total	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	Gal/mo	0.00	N/A	Gal/yr
Boats:																
Crew Boat Fuel:	1,294	1,352	1,968	1,605	1,990	1,856	2,779	2,593	3,829	3,300	2,780	3,403	Gal/mo	28,728	N/A	Gal/yr
Work Boat Fuel:	1,402	1,405	2,129	1,739	4,312	2,011	1,865	2,808	4,148	3,575	2,990	2,127	Gal/mo	30,593	N/A	Gal/yr
<b>Total Boats Fuel</b>	<b>2,696</b>	<b>2,818</b>	<b>4,095</b>	<b>3,344</b>	<b>6,302</b>	<b>3,868</b>	<b>4,644</b>	<b>5,402</b>	<b>7,977</b>	<b>6,875</b>	<b>5,750</b>	<b>5,530</b>	<b>Gal/mo</b>	<b>59,321</b>	<b>167,100</b>	<b>Gal/yr</b>
Boat Emissions:																
ROC	0.04	0.05	0.07	0.08	0.10	0.06	0.08	0.09	0.13	0.11	0.10	0.09	Tons/mo	0.98	2.77	Tons/yr at 33.15 lbs/MGal
NOx	0.76	0.79	1.15	0.94	1.77	1.08	1.31	1.52	2.24	1.93	1.81	1.55	Tons/mo	16.64	46.87	Tons/yr at 561.00 lbs/MGal
PM	0.05	0.05	0.07	0.06	0.11	0.06	0.08	0.09	0.13	0.12	0.10	0.09	Tons/mo	0.99	2.80	Tons/yr at 33.50 lbs/MGal
SOx	0.01	0.01	0.02	0.01	0.02	0.01	0.02	0.02	0.03	0.03	0.02	0.02	Tons/mo	0.22	0.63	Tons/yr at 7.50 lbs/MGal
CO	0.14	0.14	0.21	0.17	0.32	0.20	0.24	0.28	0.41	0.35	0.29	0.28	Tons/mo	3.03	8.52	Tons/yr at 102.00 lbs/MGal



**CLIENT** Oilfield Environmental Compliance  
**PROJECT NO:** 1802779  
**LABORATORY NO:** 18-642  
**SAMPLING DATE:** July 2, 2018  
**RECEIVING DATE:** July 3, 2018  
**ANALYSIS DATE:** July 3, 2018  
**REPORT DATE:** July 6, 2018

**Laboratory Analysis Report**

<b>Analysis Method</b>	SCAQMD 307-91				
<b>Detection Limits</b>	0.05 PPMV				
Analyte	<b>Client ID</b>	<b>Pit. Gail Fuel Gas</b>	<b>Pit. Gail Fuel Gas Duplicate</b>	<b>Pit. Grace Fuel Gas</b>	<b>Pit. Grace Fuel Gas Duplicate</b>
	<b>Sample ID No</b>	1802779-01	1802779-02	1802779-03	1802779-04
	<b>Sampling Date</b>	7/2/2018	7/2/2018	7/2/2018	7/2/2018
	<b>Sampling Time</b>	1000	1005	1020	1025
	<b>Lab ID</b>	18418-8	18418-9	18418-10	18418-11
	<b>Units</b>	<b>PPMV</b>	<b>PPMV</b>	<b>PPMV</b>	<b>PPMV</b>
	<b>Hydrogen Sulfide</b>	<0.05	<0.05	<0.05	<0.05
<b>Carbonyl Sulfide</b>	<0.05	<0.05	<0.05	<0.05	
<b>Methyl Mercaptan</b>	<0.05	<0.05	<0.05	<0.05	
<b>Ethyl Mercaptan</b>	<0.05	<0.05	<0.05	<0.05	
<b>Un-Identified S Compounds</b>	0.74	0.86	0.66	0.81	
<b>TRS as H<sub>2</sub>S</b>	<b>0.74</b>	<b>0.86</b>	<b>0.66</b>	<b>0.81</b>	

TRS: Total Reduced Sulfur as Hydrogen Sulfide

\*Sample was diluted for analysis



Dr. Andrew Kitto  
President

<b>CLIENT</b>	<b>Oilfield Environmental Compliance</b>
<b>PROJECT NO:</b>	<b>1802779</b>
<b>LABORATORY NO:</b>	<b>18-642</b>
<b>SAMPLING DATE:</b>	July 2, 2018
<b>RECEIVING DATE:</b>	July 3, 2018
<b>ANALYSIS DATE:</b>	July 3, 2018
<b>REPORT DATE:</b>	July 6, 2018

### Quality Assurance Report


Sample ID: Ptt. Grace Fuel Gas Duplicate on 7/2/2018

Lab ID: 18418-11

Analysis Method		SCAQMD 307-91		
Detection Limit		0.05 PPMV		
Analyte	Aver. Conc. PPMV	Dil. Factor Ambient Air	DF* A/CF PPMV	% Sample† Recovery
Hydrogen Sulfide	<0.05	1.0	<0.05	N/A
Carbonyl Sulfide	<0.05	1.0	<0.05	N/A
Methyl Mercaptan	<0.05	1.0	<0.05	N/A
Ethyl Mercaptan	<0.05	1.0	<0.05	N/A
Unidentified S Compounds	0.82	1.0	0.83	101
TRS as H2S	0.82	1.0	0.83	101

NA: Not Applicable

†Must be ±10%



 Dr. Andrew Kitto  
 President



## Letter of Conformance

January 14, 2019

This is to certify that the CARB Ultra Low sulfur dyed Diesel Fuel sold and delivered to Beacon West Energy Group, LLC Platform Gail & Grace from 1/1/2018-12/31/2018.

Was in compliance with South Coast Air Quality Management District requirements for Ventura and Santa Barbara Counties. The test Results meet ASTM D-5453 and are Typical of all CARB Ultra Low Sulfur Dyed Diesel Fuel sold by SC Fuels. The sulfur Content is guaranteed to be less than .0015%. (15PPM) The high heat content is typically in the 19,950-20,200 BTU per pound range.

*Terri Merritt*

Account Manager  
SC Fuels  
Oxnard Division  
Office (805)299-1217  
merrittt@scfuels.com

