



Ventura County  
Air Pollution  
Control District

**ANNUAL COMPLIANCE CERTIFICATION  
SIGNATURE COVER FORM**

A copy of each Annual Compliance Certification shall be submitted to EPA, Region 9, at the following address:

Mr. Gerardo Rios, Chief  
Permits Office (AIR-3)  
Office of Air Division  
EPA Region 9  
75 Hawthorne Street  
San Francisco, CA 94105

RECEIVED  
 VERMONT AIR QUALITY  
 2020 FEB 14 AM 9:47  
 A.P.C.D.

**Confidentiality**

All information in a Part 70 permit compliance certification is public information. The Part 70 permit is also public information.

**Certification by Responsible Official**

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in this compliance certification are true, accurate, and complete.

Signature and Title of Responsible Official:  Title: <i>Dan Shalch</i> <i>Principal Manager</i>	Date: <i>2/6/20</i>
--	---------------------

Time Period Covered by Compliance Certification <i>01 / 01 / 19</i> (MM/DD/YY) to <i>12 / 31 / 19</i> (MM/DD/YY)
---



February 13, 2020

Mr. Keith Macias  
Manager, Compliance Division  
Ventura County Air Pollution Control District  
669 County Square Drive  
Ventura, CA 93003.

**Subject: Submission of Part 70 Permit Annual Compliance Certification  
McGrath Peaker Generating Station, Permit No. 07891**

Dear Mr. Macias,

Southern California Edison Company is submitting the Part 70 Permit Annual Compliance Certification for McGrath Peaker Generating Station, Permit #07891, for the period between January 1, 2019 and December 31, 2019.

During the subject period, this facility experienced one excess carbon monoxide emissions deviation on 1/29/2019, which was attributed to the high rate of water injection into the combustion turbine combustor. An excess emissions report for the incident was submitted to the District on 02/01/2019, and additional information was also provided to Mr. Edward Swede in a follow-up email on 02/20/2019. A Deviation Summary Form for the incident is included with this report.

Also, please find enclosed the Annual Compliance Certification Signature Cover Form, Permit Attachment Forms, Source Test Summary Form, and supporting documents.

If you have any questions regarding these reports, please contact me at (909) 809-4368.

Sincerely,

A handwritten signature in black ink, appearing to read "Chijioke Akunyili".

Chijioke Akunyili, PE  
Environmental Science Advisor  
Environmental Services Department

Enclosures

cc: Mr. Gerardo Rios, Chief  
Permits office (AIR-3)  
Office of Air Division  
USEPA Region 9  
75 Hawthorne Street  
San Francisco, CA 94105



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 19 (MM/DD/YY) to 12 / 31 / 19 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: <b>7891-T1-161 Conditions # 1-5</b></p>	<p>D. Frequency of monitoring: Annual Source Test and Continuous Emissions Monitoring</p>
<p>B. Description: Gas Turbine Emissions Limits: - NOx emissions shall not exceed 2.5 ppmvd @ 15% O2 - NOx emissions shall not exceed 25 ppm @ 15% O2 (4-hr rolling avg) - ROG emissions shall not exceed 2.0 ppmvd @ 15% O2 - CO emissions shall not exceed 6.0 ppmvd @ 15% O2 - NH3 emissions shall not exceed 5.0 ppmvd @ 15% O2</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable <b>Source Test Summary Form attached.</b></p>
<p>C. Method of monitoring: <b>Continuous Emissions Monitoring. Annual source test performed on 7/8/2019.</b></p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>I</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>Y</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: <b>7891-T1-161 Conditions # 6-12</b></p>	<p>D. Frequency of monitoring: Continuous monitoring</p>
<p>B. Description: Continuous Emissions Monitor - Permittee shall: -Install, Operate, Maintain, and Calibrate CEMS pursuant to Rule 74.23; Rule 103, NSPS KKKK and 40 CFR 75. -Promptly report emission violations as indicated by the CEMS -Maintain permanent CEMS records. -Maintain records of all maintenance activities</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable <b>N/A</b></p>
<p>C. Method of monitoring: Attachment #1: CEMS emissions and natural gas usage records. Attachment #2: CEMS maintenance record. Attachment #3: CEMS calibrations record. Attachment #4: SCR and CO catalyst temperature and pressure devices calibrations records. Attachment #5: Fuel and Ammonia flow-meters calibrations records.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: <b>7891-T1-161 Conditions # 13,14</b></p>	<p>D. Frequency of monitoring: Continuous monitoring</p>
<p>B. Description: Permittee shall submit operating records pursuant to Rule 74.23.E of: -Actual fuel consumption or operating hour records for the past 12 months; -Annual source test and control system operating parameters Permittee shall submit excess emissions and monitor report every 6 months pursuant to 40 CFR 60, Subpart KKKK, including 4-hour rolling NOx average</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable Source Test Summary Form attached</p>
<p>C. Method of monitoring: An in-line fuel flow meter is used to monitor actual fuel consumption. Attachment #1 is rolling twelve months total gas consumption. Compliance source test was performed on 7/8/19, test report has been submitted to the District. Excess emissions and monitoring systems reports have been submitted to the District</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 19 (MM/DD/YY) to 12 / 31 / 19 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: 7891-T2 Conditions # 1-2</p>	<p>D. Frequency of monitoring: N/A</p>
<p>B. Description: 40 CFR 60 KKKK: SO2 emissions shall not exceed 0.9 lbs/MW-hr or total sulfur in fuel shall not exceed 0.06 lbs/MMBTU heat input</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Only PUC quality gas supplied by Southern California Gas Co. is combusted in the turbine, therefore the facility is in compliance with Rule 64 and 40 CFR 60 Subpart KKKK pursuant to 7891-T2 condition #2.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: 7891-T2 Conditions # 3,4</p>	<p>D. Frequency of monitoring: None for PUC quality gas</p>
<p>B. Description: Pursuant to Rule 54.B.1, no person shall discharge sulfur compounds calculated as SO2 in excess of (a) 300 ppmv at point of discharge; (b) 0.25 ppmv, 1-hr average and/or 0.04 ppmv, 24-hr average at ground or sea level.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Combustion of PUC quality natural gas ensures compliance with this requirement. No additional monitoring was required pursuant to 07891-T2 condition #3. No source testing pursuant to condition #4 is required.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: 07891-Engine-161 Condition #1</p>	<p>D. Frequency of monitoring: Continuous</p>
<p>B. Description: The permitted emissions for the 924 BHP Waukesha engine are based on a NOx emission level of 1.25 grams/BHP-hr. Permittee shall maintain manufacturer's emission documentation that the engine meets this emission level.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Attachment #6 is the generator and engine specification. Emissions Performance vs load curve on page 7 of the attachment shows the engine complies with NOx emissions level of 1.25 grams/BHP-hr.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>





## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 19 (MM/DD/YY) to 12 / 31 / 19 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: 07891-Engine-161 Conditions 2 &amp; 7</p>	<p>D. Frequency of monitoring: <b>Monthly</b></p>
<p>B. Description: -Engine shall be used only when electrical power fails, except for testing and maintenance; -Engine recordkeeping requirement</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable <b>N/A</b></p>
<p>C. Method of monitoring: Attachment #7, engine operating log is used to document all engine operations including emergency use hours and testing/maintenance use hours. The log shows the engine in question operated 2.4 hours in 2019.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> <small>*If yes, attach Deviation Summary Form</small></p>

<p>A. Attachment # or Permit Condition #: 07891-Engine-161 Conditions # 3, 4, 5, 6 &amp; 7</p>	<p>D. Frequency of monitoring: <b>Monthly</b></p>
<p>B. Description: -Engine shall not operate more than 200 hrs/yr; -Engine shall be equipped with a non-resettable time meter; -Annual compliance certification shall include engine mfr., model number, operator ID and location. -Total engine hours shall be reported annually.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable <b>N/A</b></p>
<p>C. Method of monitoring: Engine operating log is used to document all engine operations including emergency use hours and testing/maintenance use hours. (Attachment #7, engine operating log indicates manufacturer, model number, operator ID and location of use). The engine operated 2.4 hours in 2019.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> <small>*If yes, attach Deviation Summary Form</small></p>

<p>A. Attachment # or Permit Condition #: PO07891PC-111 Condition 1</p>	<p>D. Frequency of monitoring: <b>Continuous monitoring</b></p>
<p>B. Description: Annual natural gas limit for turbine operation shall not exceed 1,667 MMSCF/yr.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable <b>N/A</b></p>
<p>C. Method of monitoring: An in-line fuel flow meter calibrated annually is used to monitor natural gas combusted in the turbine. Attachment #1 shows the rolling 12-month natural gas consumption for turbine operation and it indicated only 192.5 mmscf of natural gas was combusted in the gas turbine in 2019.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> <small>*If yes, attach Deviation Summary Form</small></p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 19 (MM/DD/YY) to 12 / 31 / 19 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: <b>PO07891PC1-111 Condition 2</b></p> <p>B. Description: Turbine annual NOx emissions shall not exceed 4.81 tons/yr. Facility annual NOx emissions shall not exceed 4.99 tons/yr.  A rolling 12-month record shall be maintained.</p> <p>C. Method of monitoring: Continuous Emissions Monitoring, Attachment #1 contains the rolling 12-month NOx emissions for 2019 and it indicate 1.03 tons of NOx were emitted from the gas turbine. Attachment 7 indicate 0.0031 tons of NOx was emitted from the blackstart generator engine.</p>	<p>D. Frequency of monitoring: <b>Continuous Monitoring</b></p> <p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable <b>N/A</b></p> <p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>
--	---

<p>A. Attachment # or Permit Condition #: <b>PO07891PC1-111 Condition 3</b></p> <p>B. Description: The 924 BHP Waukesha natural gas engine shall not be used for more than 200 hours per year.</p> <p>C. Method of monitoring: A totalizing hour meter documents engine operated hours. All engine operation is documented in an operation log. Attachment #7, engine operating log showed the engine operated 2.4 hours in 2019.</p>	<p>D. Frequency of monitoring: <b>Monthly</b></p> <p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable <b>N/A</b></p> <p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>
---	---

<p>A. Attachment # or Permit Condition #: <b>PO07891PC1-111 Condition 4</b></p> <p>B. Description: The LM-6000 SPRINT gas turbine and the 924 BHP Waukesha engine shall be fired on PUC regulated natural gas.</p> <p>C. Method of monitoring: Southern California Gas Company supplies only PUC quality natural gas to McGrath Generating Station.</p>	<p>D. Frequency of monitoring: <b>N/A</b></p> <p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable <b>N/A</b></p> <p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>
---	---



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 19 (MM/DD/YY) to 12 / 31 / 19 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: <b>PO07891PC1-111 Condition 5</b></p>	<p>D. Frequency of monitoring:</p> <p style="text-align: center;"><b>N/A</b></p>
<p>B. Description:</p> <p>The 10,500 gallon ammonia storage tank shall be equipped with a pressure vacuum relief valve set at 50 psig and shall be vented to the vessel from which it is being filled during all filling operations.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p style="text-align: center;"><b>N/A</b></p>
<p>C. Method of monitoring:</p> <p>-Visual observation during filling to verify the tank is vented to the filling vessel. -Attachment #8 is the pressure vacuum relief valve calibration sheet.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p><small>*If yes, attach Deviation Summary Form</small></p>

<p>A. Attachment # or Permit Condition #: <b>PO07891-111 Condition 6</b></p>	<p>D. Frequency of monitoring:</p> <p style="text-align: center;"><b>N/A</b></p>
<p>B. Description:</p> <p>Exempt solvents, coatings, adhesives, and lubricants.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p style="text-align: center;"><b>N/A</b></p>
<p>C. Method of monitoring:</p> <p>A list of all solvents and coatings used at the facility is maintained. Attachment #9 is the coating and solvent usage record for 2019.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p><small>*If yes, attach Deviation Summary Form</small></p>

<p>A. Attachment # or Permit Condition #: <b>VCAPCD Rule 50</b></p>	<p>D. Frequency of monitoring:</p> <p>Routine surveillance, annual certification</p>
<p>B. Description:</p> <p>Rule 50 - Opacity: No visible emissions for a period or periods greater than 3 minutes in any one hour which are as dark or darker in shade as No. 1 on the Ringelmann Chart, or equivalent to 20% opacity or greater.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p style="text-align: center;"><b>EPA Method 9</b></p>
<p>C. Method of monitoring:</p> <p>Annual certification indicating emissions unit at the facility comply with applicable sections of Rule 50. Attachment #10 is a copy of the 2019 opacity survey for the gas turbine performed on July 8, 2019. Engine opacity survey was not performed because the engine was inoperable.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p><small>*If yes, attach Deviation Summary Form</small></p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 19 (MM/DD/YY) to 12 / 31 / 19 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: <b>VCAPCD Rules 54.B.1 &amp; 54.B.2</b></p>	<p>D. Frequency of monitoring:</p> <p style="font-size: 1.2em;"><b>Upon request</b></p>
<p>B. Description:</p> <p>-Stationary IC engine &amp; gas turbine operators shall not discharge sulfur compounds in excess of 300 ppm by vol (SO<sub>2</sub>) at 15% O<sub>2</sub>. -Sulfur concentration at ground level or at any point at or beyond property line shall not exceed 0.25 ppmv 1-hr average or 0.04 ppmv 24-hr average.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p>EPA Method 6, 6A, 6C, 8, 15, 16A, 16B, or SCAQMD method 307-91</p>
<p>C. Method of monitoring:</p> <p>-Only PUC quality gas is combusted at the facility in compliance with Rule 64 and by extension Rule 54.B.1; -Sulfur concentration at point of discharge and ground level concentration of SO<sub>2</sub> shall be monitored upon District's request.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: <b>VCAPCD Rule 55 - Fugitive Dust</b></p>	<p>D. Frequency of monitoring:</p> <p style="font-size: 1.2em;"><b>Routine Surveillance</b></p>
<p>B. Description:</p> <p>Fugitive dust emissions resulting from any operation, disturbed surface area or man made conditions shall not be visible beyond the midpoint of an adjacent street. Opacity shall be less than 20 percent and track out shall be less than 25 feet.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p style="font-size: 1.5em;"><b>N/A</b></p>
<p>C. Method of monitoring:</p> <p>On site operations monitoring: All applicable sources of dust at the facility are operating in compliance with Rule 55. Facility imported 200 tons/160 cu.yrd of gravel in 2019 for landscaping purpose.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: <b>VCAPCD Rule 57.1</b></p>	<p>D. Frequency of monitoring:</p> <p style="font-size: 1.2em;"><b>Upon request</b></p>
<p>B. Description:</p> <p>Particulate Matter emission from fuel burning equipment shall not exceed 0.12 lbs. per million BTU.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p style="font-size: 1.5em;"><b>CARB Method 5</b></p>
<p>C. Method of monitoring:</p> <p>-Per District Analysis dated Dec. 3rd, 1997, Gas Turbine emission factors was determined to be 0.0419 lb./MMBTU, less than 0.12 lbs./MMBTU limit specified in Rule 57.1 -PM source test will be conducted upon request by the District.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>



**ANNUAL COMPLIANCE CERTIFICATION  
PERMIT ATTACHMENT FORM**

Period Covered by Compliance Certification: 01 / 01 / 19 (MM/DD/YY) to 12 / 31 / 19 (MM/DD/YY)

A. Attachment # or Permit Condition #: <b>VCAPCD Rule 64.B.1</b>	D. Frequency of monitoring:
B. Description: Sulfur content of fuels: No person shall burn gaseous fuel containing sulfur compounds in excess of 50 grains per 100 cubic feet of fuel (788 ppmv).	<b>None for PUC quality gas</b>
C. Method of monitoring: Southern California Gas Company supplies only PUC quality natural gas to McGrath Peaker. No additional monitoring required.	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable <b>N/A</b> F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form

A. Attachment # or Permit Condition #: <b>VCAPCD Rule 74.6</b>	D. Frequency of monitoring:
B. Description: Surface Cleaning and Degreasing: S-34 NG Cleaner VOC 0.21 lb/gal and Simple Green VOC 0.042 lbs/gal are used at the facility. Quantity of non-refillable aerosol solvent used at the facility is less than 160 oz per day.	<b>N/A</b>
C. Method of monitoring: An annual log is used to document surface cleaning and degreasing activities. Attachment 9 is the coating, solvent, adhesive, and aerosol usage log.	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable <b>N/A</b> F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form

A. Attachment # or Permit Condition #: <b>VCAPCD Rule 74.11.1</b>	D. Frequency of monitoring:
B. Description: Large Water Heaters and Small Boilers: comply with NOx emission limits for subject equipment. Maintain list of equipment.	<b>N/A</b>
C. Method of monitoring: There are no large water heaters or small boilers installed at the facility	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable <b>N/A</b> F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 19 (MM/DD/YY) to 12 / 31 / 19 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: <b>VCAPCD Rule 74.22</b></p>	<p>D. Frequency of monitoring:</p> <p style="font-size: 24pt; text-align: center;">N/A</p>
<p>B. Description: <b>Natural Gas Fired Fan-Type Central Furnaces: comply with NOx emission limits for subject equipment. Maintain list of equipment.</b></p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p style="font-size: 24pt; text-align: center;">N/A</p>
<p>C. Method of monitoring: <b>There are no natural gas fired fan-type central furnaces installed at the facility.</b></p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p><small>*If yes, attach Deviation Summary Form</small></p>

<p>A. Attachment # or Permit Condition #: <b>VCAPCD Rule 74.1</b></p>	<p>D. Frequency of monitoring:</p> <p style="font-size: 24pt; text-align: center;">N/A</p>
<p>B. Description: <b>Abrasive Blasting: Comply with visible emissions standards and methods for abrasive blasting operations. Maintain records.</b></p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p style="font-size: 24pt; text-align: center;">N/A</p>
<p>C. Method of monitoring: <b>No abrasive blasting operation was performed at McGrath Peaker in 2019.</b></p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p><small>*If yes, attach Deviation Summary Form</small></p>

<p>A. Attachment # or Permit Condition #: <b>VCAPCD Rule 74.2</b></p>	<p>D. Frequency of monitoring:</p> <p style="font-size: 24pt; text-align: center;">N/A</p>
<p>B. Description: <b>Architectural Coatings: Comply with VOC content limits and maintain records for architectural coating use.</b></p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p style="font-size: 24pt; text-align: center;">N/A</p>
<p>C. Method of monitoring: <b>Coatings used at the facility in 2019 were for industrial maintenance of steel structures and for transformer metal parts, which were in compliance with the VOC content limits. Attachment 9 is the coating and solvent usage log for 2019.</b></p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p><small>*If yes, attach Deviation Summary Form</small></p>



Ventura County  
Air Pollution  
Control District

## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 19 (MM/DD/YY) to 12 / 31 / 19 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: <b>VCAPCD Rule 74.4.D</b></p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: <b>Cutback Asphalt: Comply with organic compound limit (0.5%) for road oils applied for street paving or maintenance.</b></p>	<p><b>N/A</b></p>
<p>C. Method of monitoring: <b>Cut back asphalt activities were not performed at the facility in 2019.</b></p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p><b>N/A</b></p> <p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: <b>40 CFR Part 61, Subpart M</b></p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: <b>National Emission Standards for Asbestos: Comply with applicable requirements for demolition/renovation activities.</b></p>	<p><b>N/A</b></p>
<p>C. Method of monitoring: <b>Asbestos demolition/renovation activities were not performed at the facility in 2019.</b></p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p><b>N/A</b></p> <p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #:</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description:</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p>
<p>C. Method of monitoring:</p>	<p>F. Currently in Compliance? (Y or N): _____</p> <p>G. Compliance Status? (C or I): _____</p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): _____</p> <p>*If yes, attach Deviation Summary Form</p>



Ventura County  
Air Pollution  
Control District

## ANNUAL COMPLIANCE CERTIFICATION DEVIATION SUMMARY FORM

Period Covered by Compliance Certification: 01 / 01 / 19 (MM/DD/YY) to 12 / 31 / 19 (MM/DD/YY)

<b>A. Attachment # or Permit Condition #:</b> <b>7891-T1-161</b> <b>Condition 1B</b>	<b>B. Equipment description:</b> <b>GE LM-6000 PC SPRINT Gas Turbine</b>	<b>C. Deviation Period: Date &amp; Time</b> Begin: <u>1/29/19, 8:46 PM</u> End: <u>1/29/19, 9:29 PM</u> When Discovered: Date & Time <u>1/29/19 8:46 PM</u>
<b>D. Parameters monitored:</b> <b>Carbon Monoxide (CO)</b>	<b>E. Limit:</b> <b>6.0 ppmvd @ 15%O2</b>	<b>F. Actual:</b> <b>6.9 ppmvd @ 15%O2</b>
<b>G. Probable Cause of Deviation:</b> Excessive water injection into the turbine combustor reduced the combustion temperature and caused the CO emissions to increase above the permit limit. The excessive water injection was due to a high water injection bias from a previous run, which was not adjusted during the current run.		<b>H. Corrective actions taken:</b> Upon discovery the turbine was shut down. The water injection bias was manually adjusted during the subsequent run to maintain compliance levels.

<b>A. Attachment # or Permit Condition #:</b>	<b>B. Equipment description:</b>	<b>C. Deviation Period: Date &amp; Time</b> Begin: _____ End: _____ When Discovered: Date & Time _____
<b>D. Parameters monitored:</b>	<b>E. Limit:</b>	<b>F. Actual:</b>
<b>G. Probable Cause of Deviation:</b>		<b>H. Corrective actions taken:</b>

<b>A. Attachment # or Permit Condition #:</b>	<b>B. Equipment description:</b>	<b>C. Deviation Period: Date &amp; Time</b> Begin: _____ End: _____ When Discovered: Date & Time _____
<b>D. Parameters monitored:</b>	<b>E. Limit:</b>	<b>F. Actual:</b>
<b>G. Probable Cause of Deviation:</b>		<b>H. Corrective actions taken:</b>





Ventura County  
Air Pollution  
Control District

## ANNUAL COMPLIANCE CERTIFICATION

### SOURCE TEST SUMMARY FORM

Period Covered by Compliance Certification: 01 / 01 / 19 (MM/DD/YY) to 12 / 31 / 19 (MM/DD/YY)

A. Emission Unit Description: <b>GE LM-6000 PC SPRINT Gas Turbine</b>			B. Pollutant: <b>NOx</b>
C. Measured Emission Rate: 2.30 ppm @15% O2 3.87 lbs/hr	D. Limited Emission Rate: 2.5 ppm @ 15%O2 50 lbs/hr	E. Specific Source Test or Monitoring Record Citation: 07891-T1-161, Condition 1a	F. Test Date: 7/8/19

A. Emission Unit Description: <b>GE LM-6000 PC SPRINT Gas Turbine</b>			B. Pollutant: <b>ROC</b>
C. Measured Emission Rate: 1.02 ppm @15% O2 0.60 lbs/hr	D. Limited Emission Rate: 2.0 ppm @ 15%O2 1.38 lbs/hr	E. Specific Source Test or Monitoring Record Citation: 07891-T1-161, Condition 1b	F. Test Date: 7/8/19

A. Emission Unit Description: <b>GE LM-6000 PC SPRINT Gas Turbine</b>			B. Pollutant: <b>CO</b>
C. Measured Emission Rate: 3.80 ppm @15% O2 3.89 lbs/hr	D. Limited Emission Rate: 6.0 ppm @ 15%O2 15.80 lbs/hr	E. Specific Source Test or Monitoring Record Citation: 07891-T1-161, Condition 1c	F. Test Date: 7/8/19

A. Emission Unit Description: <b>GE LM-6000 PC SPRINT Gas Turbine</b>			B. Pollutant: <b>NH3</b>
C. Measured Emission Rate: 2.4 ppm @15% O2 1.5 lbs/hr	D. Limited Emission Rate: 5.0 ppm @ 15%O2 3.44 lbs/hr	E. Specific Source Test or Monitoring Record Citation: 07891-T1-161, Condition 1d	F. Test Date: 7/8/19

A. Emission Unit Description:			B. Pollutant:
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test or Monitoring Record Citation:	F. Test Date:

**Attachment 1**  
**Emissions and natural gas usage record**

Babcock & Wilcox Power Generation Group NetDAR#e

Monthly Emissions - Averages & Totals Report  
 Southern California Edison - McGrath Beach Substation  
 251 N. Harbor Blvd., Oxnard, Ca 93035  
 Report Period 1/1/2019 00:00 to 12/30/2019 23:59  
 Generated: 2/11/2020

Monthly Summary - worksheet 1

Source: Simple Cycle Combustion Turbine  
 CEMS ID NO.:

MM/YYYY	Process On Mo-To-Date (Hours/mo)	NOx Mo-To-Date (lbs/mo)	CO Mo-To-Date (lbs/mo)	PM10 Mo-To-Date (lbs/mo)	ROC Mo-To-Date (lbs/mo)	SOX Mo-To-Date (lbs/mo)	Gas Flow Mo-To-Date (MMcf/mo)	Gross MW Mo-To-Date (MWh/mo)
Jan 2019	22.28	154.63	132.88	100	26	6	9,460	1008.3
Feb 2019	37.97	203.82	183.59	176	45	10	16,647	1806.7
Mar 2019	44.32	219.17	208.82	206	53	12	19,542	2115.8
Apr 2019	26.57	157.58	122.06	120	31	7	11,400	1216.5
May 2019	1.18	8.15	7.53	5	1	0	0.441	45.3
Jun 2019	14.00	59.86	54.76	64	16	4	6,051	651.8
Jul 2019	48.67	193.30	224.95	228	58	13	21,573	2316.1
Aug 2019	46.52	191.85	208.60	216	55	12	20,443	2183.1
Sep 2019	19.30	79.75	87.41	87	22	5	8,241	876.5
Oct 2019	60.72	265.58	307.94	272	70	15	25,792	2741.9
Nov 2019	108.40	458.31	359.83	498	127	28	47,151	5048.4
Dec 2019	13.20	59.24	60.41	61	15	3	5,734	624.0
<b>Final Values</b>	<b>443.13</b>	<b>2051.24</b>	<b>2148.78</b>	<b>2033.00</b>	<b>519.00</b>	<b>115.00</b>	<b>192.48</b>	<b>20634.40</b>
		<b>1.03 Tons</b>	<b>1.07 Tons</b>	<b>1.02 Tons</b>	<b>0.26 Tons</b>	<b>0.06 Tons</b>		

Babcock & Wilcox Power Generation Group NELDAR#6

Monthly Emissions - Averages & Totals Report  
 Southern California Edison - McGrath Beach Substation  
 251 N. Harbor Blvd., Oxnard, Ca 93035  
 Report Period 1/1/2018 00:00 to 12/31/2018 23:59  
 Generated: 2/4/2019

Source: Simple Cycle Combustion Turbine

CEMS ID NO.:

MM/YYYY	NOx		CO		PMD		ROC		SOX		Gas Flow	
	12mo Total	(lbs/12mo)	12mo Total	(lbs/12mo)	12mo Total	(lbs/12mo)	12mo Total	(lbs/12mo)	12mo Total	(lbs/12mo)	12mo Total	(MMcf/12mo)
Jan 2018	4327		4270		4182		1069		238		395.989	
Feb 2018	4030		4033		3977		1017		226		376.575	
Mar 2018	3851		3870		3826		978		217		362.300	
Apr 2018	3491		3515		3497		894		199		331.139	
May 2018	2879		2931		2954		755		168		279.749	
Jun 2018	2309		2380		2376		607		135		224.992	
Jul 2018	2437		2692		2585		661		147		244.829	
Aug 2018	2004		2264		2101		537		119		198.956	
Sep 2018	2228		2506		2274		581		129		215.336	
Oct 2018	2318		2763		2522		645		143		238.835	
Nov 2018	2795		3066		2765		707		157		261.823	
Dec 2018	2523		2773		2461		629		140		233.071	
<b>Final Values</b>	<b>2523</b>	<b>L</b>	<b>2773</b>	<b>L</b>	<b>2461</b>	<b>L</b>	<b>629</b>	<b>L</b>	<b>140</b>	<b>L</b>	<b>233.071</b>	<b>L</b>

**Attachment 2**  
**CEMS Maintenance Records**

# Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station

Quality Control/Quality Assurance Plan  
Checklist for CEMS Shelter Inspection

ANNUAL QA/QC INSPECTIONS	
Parameters to Check	Values/Status
<b>TECO MODEL 4211-LS NOx</b>	
Clean the lens in the reaction chamber s needed	✓
Perform a NOx converter check. Replace the converter as necessary	Replaced
Inspect and Clean cooler fins on PMT cooler	✓
Check sample pump A - Replace diaphragm and disk as needed	✓
Check sample pump B - Replace diaphragm and disk as needed	✓
Replace capillaries and O-rings	✓
<b>SERVOMEX MODEL 1440D O2 Analyzer</b>	
Check filter element at Flow Control Device, replace as needed	✓
Check for leaks	✓
<b>TECO MODEL 481 CO Analyzer</b>	
Replace IR Source (as needed)	✓
Clean correlation wheel, optics, and measuring cell, as necessary	✓
Check for leaks around fittings	✓
Check pump diaphragm and replace as necessary	✓
Replace capillary	✓
Clean fan filter	✓
<b>Sample System Checks</b>	
Check sample pump A tubing - Replace diaphragm and disk as needed	✓
Check sample pump B tubing - Replace diaphragm and disk as needed	✓
Perform probe maintenance, inspect filter and O-rings and replace as necessary	✓
Adjust 4-20 mA outputs (analog) to match LED display for all analyzers	✓
Replace ammonia scrubber media	✓
Replace petistaltic pump diaphragm	✓
Replace dry air dessicant	✓
<b>REMARKS:</b>	

Mark as either Acceptable "✓", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By: \_\_\_\_\_ Date: \_\_\_\_\_

# Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station

Quality Control/Quality Assurance Plan  
Checklist for CEMS Shelter Inspection

QUARTERLY QA/QC INSPECTIONS				
	First Quarter	Second Quarter	Third Quarter	Fourth Quarter
Date	3/25/19	6/15/19	9/13/19	12/16/19
Technician's Initial:	JSD	JSD	JSD	JSD
Parameters to Check				
<b>SAMPLE SYSTEMS CHECK:</b>				
Inspect sample gas pressure. If sample gas pressure shows a decline, perform one or more of the following:	✓	✓	✓	✓
Perform probe maintenance	-	-	-	-
Relace filter element and clean the filter chamber	-	-	-	-
Verify if probe box heater is operating	✓	✓	✓	✓
If flow is low check sample pump	-	-	-	-
Perform CEMS sample system leak check	-	-	-	-
Perform general housekeeping duties. Dust/clean all equipment surfaces.	✓	✓	✓	✓
<b>Analyzzer Checks</b>				
<b>All Analyzers:</b>				
Visually check for obvious defects such as loose connectors, loose fittings, cracked or clogged teflon lines, and excessive dust or dirt accumulation. Dirt accumulation can cause overheating or component failure and may provide conducting path for electricity	✓	✓	✓	✓
Clean inside of each instrument by vacuuming	✓	✓	✓	✓
Clean all analyzer cooling fans	✓	✓	✓	✓
Caution: Observe all safety warning from manufacturers manual	✓	✓	✓	✓
<b>REMARKS:</b>				

Mark as either Acceptable "✓", Corrective action Required "X", or Actual Readings, where required  
Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By: \_\_\_\_\_ Date: \_\_\_\_\_

Barnes/Center/Grapeland/Miraflores/McGrath Peaker Generating Station

Quality Control/Quality Assurance Plan  
Checklist for CEMS Shelter Inspection

Data	MONTHLY QA/QC INSPECTIONS											
	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC
Parameters to Check	1/31/14	2/26/14	3/25/14	4/29/14	5/28/14	6/24/14	7/21/14	8/26/14	9/23/14	10/29/14	11/20/14	12/11/14
Technician's Initial	SS	SS	SS	SS	SS	SS	SS	SS	SS	SS	SS	SS
User ID Number	SS	SS	SS	SS	SS	SS	SS	SS	SS	SS	SS	SS
Sample System Checks	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
Check NDI analyzer desiccant media. Replace as necessary	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
Check filter on shelter HVAC system. Clean or replace as needed	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
Plan for the upcoming January CEMS. Check gas boiler pressures >500 psig. Also check expansion drain. Other new gas boiler as needed keeping in mind the lead time may be several weeks	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
Check incoming instrument air filter	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
NDI Analyzer												
Motherboard - Voltages - Check status and ensure normal operation	-676.4	-676.0	-676.4	-676.8	-676.7	-676.4	-676.4	-676.4	-676.4	-676.4	-676.4	-676.4
Interface Board - Voltages - Check status and ensure normal operation	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
PMT Voltage	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
IO Board - Voltages - Check status and ensure normal operation	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
Set Point/Range	36.5	35.7	34.9	35.2	35.6	36.5	36.7	36.5	36.3	36.2	36.2	36.2
Temperatures:	50.2	49.8	50.7	50.1	50.0	50.7	50.7	50.1	50.2	50.2	50.2	50.2
Internal	-2.9	-2.9	-3.1	-2.9	-3.0	-3.1	-3.1	-3.0	-2.9	-2.9	-2.9	-2.9
Chamber	625.8	625.6	626.6	619.8	627.1	623.5	623.7	621.9	621.4	622.4	624.8	624.2
Cooler	136.5	149.7	158.7	138.3	152.7	151.4	155.6	153.8	153.5	157.6	150.8	151.5
NDI Converter	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK
Chamber Pressure	NONE	NONE	NONE	NONE	NONE	NONE	NONE	NONE	NONE	NONE	NONE	NONE
Orionator Flow	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
Alarms Detected	-110.7	-110.7	-110.7	-110.7	-110.8	-110.8	-110.8	-110.8	-110.7	-110.7	-110.8	-110.7
CO Analyzer												
Motherboard - Voltages - Check status and ensure normal operation	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
Interface Board - Voltages - Check status and ensure normal operation	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
Gas Supply Voltage	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
IO Board - Voltages - Check status and ensure normal operation	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
Set Point/Range	33.1	32.5	31.7	33.1	32.8	33.2	33.2	33.1	33.8	33.8	33.8	33.8
Temperatures:	48.5	47.9	48.7	47.9	47.8	47.9	48.5	48.2	48.1	48.1	48.1	48.5
Internal	747.0	749.1	751.3	745.8	741.9	746.4	747.9	746.1	746.0	746.7	737.8	751.5
Bench	0.917	0.912	0.912	0.901	0.925	0.907	0.901	0.996	0.982	0.989	0.976	0.989
Other	1.157070	1.157000	1.157000	1.157000	1.172100	1.176100	1.175300	1.175300	1.174700	1.174700	1.174200	1.171400
Analyzer Pressure	198.715	199.166	199.119	199.267	199.897	198.728	198.319	198.578	198.611	198.619	198.943	198.677
Sample Flow Rate	100	100	100	100	100	100	100	100	100	100	100	100
AGC Intensity	NONE	NONE	NONE	NONE	NONE	NONE	NONE	NONE	NONE	NONE	NONE	NONE
Motor Speed	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
Alarms Detected	-600.8	-601.3	-600.9	-601.3	-601.3	-600.9	-601.3	-601.3	-601.3	-601.3	-601.3	-601.3
NOx/NO3 Analyzer												
Motherboard - Voltages - Check status and ensure normal operation	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
Interface Board - Voltages - Check status and ensure normal operation	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
PMT Voltage	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
IO Board - Voltages - Check status and ensure normal operation	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
Set Point/Range	32.5	32.7	32.7	33.1	33.0	32.9	33.0	32.9	33.9	33.1	33.2	33.0
Temperatures:	50.1	50.1	50.2	50.3	50.9	50.3	49.9	49.8	50.1	50.2	50.2	50.2
Internal	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1	-7.1
Chamber	625.6	625.4	625.2	625.6	627.2	623.5	624.1	622.2	625.8	622.2	622.4	621.9
Cooler	162.3	162.9	163.5	161.7	169.1	169.1	170.3	165.7	169.7	168.8	167.0	161.7
NDI Converter	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK
Chamber Pressure	NONE	NONE	NONE	NONE	NONE	NONE	NONE	NONE	NONE	NONE	NONE	NONE
Orionator Flow	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
Alarms Detected	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓

Mark as either Acceptable "X", Corrective Action Required "X", or Actual Readings, where required  
Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By: \_\_\_\_\_  
Date: \_\_\_\_\_



**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station  
Daily Quality Control/Quality Assurance Plan  
Checklist for CEMS Shelter Inspection**

Parameter to Check	Tag ID	Unit	Mon	Tue	Wed	Thu	Fri	Sat	Sun
<b>Data</b>									
Technician's Initial						1/3/17			
Please enter readings and notify the Maintenance Manager when it is time to re-order.									
Calibration Gas Pressures									
O2/CO High Span, NOX Zero	SV1	>150 psi				111.0			
NOX Low Span/CO Low Span	SV2	>150 psi				173.0			
NOX High Span, O2/CO Zero	SV3	>150 psi				36.0			
Please enter readings									
Stack Sample Line									
Sample Line Temperature	TC1	250°F				250			
Sample NH3 Temperature	TC2	760°F				760			
Sample Line Pressure/Vacuum	PI-1	6.0 Hg				6.7			
Sample Line Pressure/Vacuum	PI-2	8.0 Hg				6.6			
Sample Line Pressure/Vacuum	PI-4	7.5 Hg				6.6			
Sample Line Pressure	PI-5	8 Psi				51.6			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)				✓			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)				✓			
<b>Visual Checks</b>									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F				68.0			
Moisture Sensor A/Filler	MS-1	Clean and dry. If filler shows buildup and flow levels are dropping, replace filler				✓			
Moisture Sensor B/Filler	MS-2	Check if ok				✓			
Operational Status of Sample Pumps (2)		Check if ok				✓			
Operational Status of Condensate Drain Pumps (2)		Check if ok				✓			
Check LED status of Sample Cooler		Check if ok				✓			
NH3 Scrubber Drain	HV-4	Drain as needed				✓			
Please enter readings									
Analyzer Sample Flow Meter Readings									
System Flow	FM-1	3-5 LPM				4.3			
O2 Analyzer	FM-2	1.2 - 1.7 LPM				1.45			
NOx Analyzer	FM-3	1.2 - 1.7 LPM				1.4			
NOX By-Pass	FM-4	1.2 - 1.7 LPM				1.45			
CO Analyzer	FM-5	1.2 - 1.7 LPM				1.55			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7				4.2			
System Flow	FM-7	3-5 LPM				1.1			
NOX/NH3 Analyzer	FM-8	1.5 LPM				1.55			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM				1.55			
NOX Dry Air	FM-10	500-700 CCM				580			
<b>DAHS Checks</b>									
Check DAHS for normal operation. Is system logging data?						✓			
Check Alarms in DAHS.						✓			
Check chart recorder for normal operation						✓			
Check analyzer calibration drift. Did all calibrations pass?						✓			
Check printer status						✓			
<b>REMARKS:</b>									

Mark as either Acceptable "✓", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_

**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station  
Daily Quality Control/Quality Assurance Plan  
Checklist for CEMS Shelter Inspection**

Date	Technician's Initial	Time ID	Limit	Mon	Tue	Wed	Thu	Fri	Sat	Sun
Calibration Gas Pressures				17/19	18/19	19/19	11/17	11/13		
OZCO High Span, NOX Zero			> 150 psi	1000	970	940	940	910		
NOX Low Span/OZCO Low Span			> 150 psi	1400	1680	1680	1680	1480		
NOX High Span, OZCO Zero			> 150 psi	340	330	320	320	320		
Stack Sample Line				Please enter readings						
Sample Line Temperature			250F	250	250	250	250	250		
Sample NH3 Temperature			760F	760	760	760	760	760		
Sample Line Pressure/Vacuum			60" Hg	64	63	62	62	62		
Sample Line Pressure/Vacuum			8.0" Hg	4.8	4.7	4.7	4.6	4.6		
Sample Line Pressure/Vacuum			7.5" Hg	6.6	6.6	6.6	6.6	6.6		
Sample Line Pressure			8 Psi	5.5	5.5	5.5	5.5	5.5		
Verify Functionality of Sample Pump A Flow Switch			5-7 LPM (set point)	✓	✓	✓	✓	✓		
Verify Functionality of Sample Pump B Flow Switch			5-7 LPM (set point)	✓	✓	✓	✓	✓		
Visual Checks										
Room Enclosure Temperature			72 F (+/-5) F	68.5	68.5	68.0	68.0	68.0		
Moisture Sensor A/Filter			Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	✓	✓	✓	✓	✓		
Moisture Sensor B/Filter			Check if ok	✓	✓	✓	✓	✓		
Operational Status of Sample Pumps (2)			Check if ok	✓	✓	✓	✓	✓		
Operational Status of Condensate Drain Pumps (2)			Check if ok	✓	✓	✓	✓	✓		
Check LED status of Sample Cooler			Check if ok	✓	✓	✓	✓	✓		
NH3 Scrubber Drain			Drain as needed	✓	✓	✓	✓	✓		
Analyzer Sample Flow Meter Readings				Please enter readings						
System Flow			3-5 LPM	4.4	4.4	4.4	4.4	4.3		
O2 Analyzer			1.2 - 1.7 LPM	1.4	1.4	1.4	1.4	1.45		
NOx Analyzer			1.2 - 1.7 LPM	1.6	1.6	1.6	1.6	1.6		
NOx By-Pass			1.2 - 1.7 LPM	1.45	1.4	1.4	1.35	1.35		
CO Analyzer			1.2 - 1.7 LPM	1.55	1.55	1.55	1.55	1.45		
Cal Gas Flow (only during Calibration)			> than FM-1 & FM-7	4.2	4.2	4.2	4.2	4.2		
System Flow			3-5 LPM	1.6	1.6	1.6	1.6	1.6		
NOX/NH3 Analyzer			1.5 LPM	1.5	1.5	1.5	1.5	1.5		
NOX/NH3 Analyzer By-Pass			1.2 - 1.5 LPM	1.5	1.5	1.5	1.5	1.5		
NOX Dry Air			500-700 CCM	570	570	570	570	570		
DAHHS Checks				✓	✓	✓	✓	✓		
Check DAHS for normal operation. Is system logging data?				✓	✓	✓	✓	✓		
Check Alarms in DAHS.				✓	✓	✓	✓	✓		
Check chart recorder for normal operation				✓	✓	✓	✓	✓		
Check analyzer calibration drift. Did all calibrations pass?				✓	✓	✓	✓	✓		
Check printer status				✓	✓	✓	✓	✓		
REMARKS:										

Mark as either Acceptable "✓", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_

**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station  
Daily Quality Control/Quality Assurance Plan  
Checklist for CEMS Shelter Inspection**

Parameter to Check	Tag ID	Units	Mon	Tue	Wed	Thu	Fri	Sat	Sun
<b>Dates</b>									
Technician's Initial			1/15/19	1/15/19	1/16/19	1/17/19			
Calibration Gas Pressures									
O2/CO High Span, NOX Zero	SV1	>150 psi	760	730	700				
NOX Low Span/CO Low Span	SV2	>150 psi	1620	1580	1440				
NOX High Span, O2/CO Zero	SV3	>150 psi	1820	1800	1810				
Stack Sample Line									
Sample Line Temperature	TC1	250°F	250	250	250				
Sample NH3 Temperature	TC2	760°F	760	760	760				
Sample Line Pressure/Vacuum	PI-1	60 "Hg	6.5	6.7	6.1				
Sample Line Pressure/Vacuum	PI-2	80 "Hg	4.2	4.7	4.8				
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg	7.0	6.6	6.6				
Sample Line Pressure	PI-5	8 PSI	5.2	5.5	5.5				
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	✓	✓	✓				
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	✓	✓	✓				
<b>Visual Checks</b>									
Room Enclosure Temperature	72 F (+/-5) F		68.8	68.5	66.5	67.5			
Moisture Sensor A/Filler	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	✓	✓	✓				
Moisture Sensor B/Filter	MS-2	Check if ok	✓	✓	✓				
Operational Status of Sample Pumps (2)		Check if ok	✓	✓	✓				
Operational Status of Condensate Drain Pumps (2)		Check if ok	✓	✓	✓				
Check LED status of Sample Cooler		Check if ok	✓	✓	✓				
NH3 Scrubber Drain	HV-4	Drain as needed	✓	✓	✓				
<b>Analyzer Sample Flow Meter Readings</b>									
System Flow	FM-1	3-5 LPM	4.1	4.4	5.4	4.4			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.4	1.5	1.5	1.5			
NOx Analyzer	FM-3	1.2 - 1.7 LPM	1.5	1.6	1.6	1.6			
NOX By-Press	FM-4	1.2 - 1.7 LPM	1.5	1.4	1.4	1.4			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.5	1.5	1.5	1.5			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	3.9	4.2	4.2	4.2			
System Flow	FM-7	3-5 LPM	4.6	4.6	4.6	4.6			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.5	1.5	1.5	1.5			
NOX/NH3 Analyzer By-Press	FM-9	1.2 - 1.5 LPM	1.5	1.5	1.5	1.5			
NOX Dry Air	FM-10	500-700 CCM	570	570	570	570			
<b>DAHs Checks</b>									
Check DAHS for normal operation. Is system logging data?		✓	✓	✓	✓				
Check Alarms in DAHS.		✓	✓	✓	✓				
Check chart recorder for normal operation		✓	✓	✓	✓				
Check analyzer calibration drift. Did all calibrations pass?		✓	✓	✓	✓				
Check printer status		✓	✓	✓	✓				
<b>REMARKS:</b>									

Mark as either Acceptable "✓", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.  
 Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_

**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station  
Daily Quality Control/Quality Assurance Plan  
Checklist for CEMS Shelter Inspection**

Parameters to Check	Tag ID	Limits	Room	Thu	Wed	Thu	Fri	Sat	Sun
<b>Dates</b>				1/22/19	1/23/19	1/24/19			
Technician's Initial				JD	JD	JD			
Calibration Gas Pressures				Please enter readings and notify the Maintenance Manager when it is time to re-order.					
O2/CO High Span, NOX Zero	SV1	>150 psi		600	590	510			
NOX Low Span/CO Low Span	SV2	>150 psi		1340	1380	1310			
NOX High Span, O2/CO Zero	SV3	>150 psi		1710	1740	1680			
<b>Stack Sample Line</b>				Please enter readings					
Sample Line Temperature	TC1	250°F		250	250	250			
Sample NH3 Temperature	TC2	760°F		760	760	760			
Sample Line Pressure/Vacuum	PI-1	6.0 "Hg		6.1	6.1	6.1			
Sample Line Pressure/Vacuum	PI-2	8.0 "Hg		4.9	4.9	4.7			
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg		6.6	6.6	6.5			
Sample Line Pressure	PI-5	8 Psi		5.6	5.6	5.5			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)		✓	✓	✓			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)		✓	✓	✓			
<b>Visual Checks</b>									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F		67.5	66.5	67.5			
Moisture Sensor A/Filler	MS-1	Clean and dry. If filter shows buildup and flow levels are dropping, replace filter		✓	✓	✓			
Moisture Sensor B/Filler	MS-2	Check if ok		✓	✓	✓			
Operational Status of Sample Pumps (2)		Check if ok		✓	✓	✓			
Operational Status of Condensate Drain Pumps (2)		Check if ok		✓	✓	✓			
Check LED status of Sample Cooler		Check if ok		✓	✓	✓			
NH3 Scrubber Drain	HV-4	Drain as needed		✓	✓	✓			
<b>Analyzer Sample Flow Meter Readings</b>				Please enter readings					
System Flow	FM-1	3-5 LPM		4.4	4.4	4.4			
O2 Analyzer	FM-2	1.2 - 1.7 LPM		1.45	1.4	1.45			
NOx Analyzer	FM-3	1.2 - 1.7 LPM		1.6	1.6	1.6			
NOX By-Pass	FM-4	1.2 - 1.7 LPM		1.35	1.45	1.4			
CO Analyzer	FM-5	1.2 - 1.7 LPM		1.55	1.55	1.55			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7		4.2	4.2	4.2			
System Flow	FM-7	3-5 LPM		1.6	1.6	1.6			
NOX/NH3 Analyzer	FM-8	1.5 LPM		1.5	1.5	1.5			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM		650	650	650			
NOX Dry Air	FM-10	500-700 CCM		✓	✓	✓			
<b>DAHS Checks</b>									
Check DAHS for normal operation. Is system logging data?				✓	✓	✓			
Check Alarms in DAHS				✓	✓	✓			
Check chart recorder for normal operation				✓	✓	✓			
Check analyzer calibration unit. Did all calibrations pass?				✓	✓	✓			
Check printer status				✓	✓	✓			
<b>REMARKS:</b>									

Mark as either Acceptable "Y", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.  
 Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_

**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station  
Daily Quality Control/Quality Assurance Plan  
Checklist for CEMS Shelter Inspection**

Date	Technician's Initial	Mon	Tue	Wed	Thu	Fri	Sat	Sun
SV1	> 150 psi	1/23/19	1/23/19	1/23/19	1/23/19	1/23/19		
SV2	> 150 psi	4.4	4.6	4.1	4.2			
SV3	> 150 psi	11.4	12.7	11.6	11.7			
TC1	250F	15.3	16.0	15.1	15.2			
TC2	760F	2.5	2.5	2.5	2.5			
PI-1	6.0 "Hg	7.1	7.1	7.0	7.1			
PI-2	8.0 "Hg	6.8	6.5	6.4	6.4			
PI-3	7.5 "Hg	4.3	4.5	4.4	4.4			
PI-4	8.0 "Hg	7.3	6.7	6.7	6.7			
FS-1	5-7 LPM (set point)	5.3	5.4	5.3	5.4			
FS-2	5-7 LPM (set point)	✓	✓	✓	✓			
MS-1	72 F (+/-5) F	68.0	69.0	67.0	68.0			
MS-2	Clean and dry. If filter shows buildup and flow levels are dropping, replace filter	✓	✓	✓	✓			
HV-4	Check if ok	✓	✓	✓	✓			
FM-1	3-5 LPM	4.7	4.7	4.3	4.3			
FM-2	1.2 - 1.7 LPM	1.4	1.4	1.5	1.5			
FM-3	1.2 - 1.7 LPM	1.5	1.6	1.5	1.5			
FM-4	1.2 - 1.7 LPM	1.3	1.4	1.3	1.3			
FM-5	1.2 - 1.7 LPM	1.5	1.5	1.5	1.5			
FM-6	> than FM-1 & FM-7	4.1	4.2	4.2	4.2			
FM-7	3-5 LPM	1.6	1.6	1.6	1.6			
FM-8	1.5 LPM	1.5	1.5	1.5	1.5			
FM-9	1.2 - 1.5 LPM	1.5	1.5	1.5	1.5			
FM-10	500-700 CCM	6.5	6.5	6.5	6.5			
DAHS Checks	Check DAHS for normal operation. Is system logging data?	✓	✓	✓	✓			
	Check Alarms in DAHS.	✓	✓	✓	✓			
	Check chart recorder for normal operation	✓	✓	✓	✓			
	Check analyzer calibration drift. Did all calibrations pass?	✓	✓	✓	✓			
	Check printer status	✓	✓	✓	✓			
REMARKS:								

Mark as either Acceptable "✓", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_



**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station  
Daily Quality Control/Quality Assurance Plan  
Checklist for CEMS Shelter Inspection**

Parameter to Check	Test ID	Limits	Mon	Tue	Wed	Thu	Fri	Sat	Sun
Dates			2/4/17	2/5/17	2/6/17	2/7/17			
Technician's Initial									
Calibration Gas Pressures									
O2/CO High Span, NOX Zero	SV1	>150 psi	310	210	270	1997			
NOX Low Span/CO Low Span	SV2	>150 psi	1140	1000	1040	1010			
NOX High Span, O2/CO Zero	SV3	>150 psi	1510	1500	1410	1370			
Stack Sample Line									
Sample Line Temperature	TC1	250F	250	250	250	250			
Sample NH3 Temperature	TC2	760F	760	760	760	760			
Sample Line Pressure/Vacuum	PI-1	6.0 Hg	6.5	7.2	7.1	6.5			
Sample Line Pressure/Vacuum	PI-2	6.0 Hg	6.4	7.6	7.2	6.2			
Sample Line Pressure/Vacuum	PI-4	7.5 Hg	6.7	7.4	6.6	6.9			
Sample Line Pressure	PI-5	8 Psi	5.2	5.02	5.5	5.3			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	✓	✓	✓	✓			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	✓	✓	✓	✓			
Visual Checks									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	67.5	69.0	67.0	70.0			
Moisture Sensor A/Filler	MS-1	Clean and dry. If filter shows buildup and flow levels are dropping, replace filter	✓	✓	✓	✓			
Moisture Sensor B/Filler	MS-2	Check if ok	✓	✓	✓	✓			
Operational Status of Sample Pumps (2)		Check if ok	✓	✓	✓	✓			
Operational Status of Condensate Drain Pumps (2)		Check if ok	✓	✓	✓	✓			
Check LED status of Sample Cooler		Check if ok	✓	✓	✓	✓			
NH3 Scrubber Drain	HV-4	Drain as needed	✓	✓	✓	✓			
Analyzer Sample Flow Meter Readings									
System Flow	FM-1	3-5 LPM	4.7	4.2	4.5	4.5			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.4	1.4	1.4	1.45			
NOx Analyzer	FM-3	1.2 - 1.7 LPM	1.5	1.55	1.7	1.65			
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.3	1.3	1.5	1.55			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.55	1.55	1.5	1.55			
Cat Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	4.2	3.9	4.2	4.2			
System Flow	FM-7	3-5 LPM	4.6	4.6	4.6	4.6			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.5	1.5	1.5	1.5			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.5	1.5	1.5	1.5			
NOX Dry Air	FM-10	500-700 CCM	650	650	650	660			
DAHs Checks									
Check DAHS for normal operation. Is system logging data?			✓	✓	✓	✓			
Check Alarms in DAHS			✓	✓	✓	✓			
Check chart recorder for normal operation			✓	✓	✓	✓			
Check analyzer calibration drift. Did all calibrations pass?			✓	✓	✓	✓			
Check printer status			✓	✓	✓	✓			
REMARKS:									

Mark as either Acceptable "✓", Corrective action Required "X", or Actual Readings, where required  
Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_

**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station  
Daily Quality Control/Quality Assurance Plan  
Checklist for CEMS Shelter Inspection**

Parameters to Check	Tag ID	Limits	Mon	Tue	Wed	Thu	Fri	Sat	Sun
<b>Dates</b>									
Technician's Initial			2/11/17	2/12/17	2/13/17	2/14/17			
Calibration Gas Pressures									
O2/CO High Span, NOX Zero	SV1	>150 psi	130	140	120	140			
NOX Low Span/CO Low Span	SV2	>150 psi	1000	980	980	980			
NOX High Span, O2/CO Zero	SV3	>150 psi	1360	1320	1320	1330			
Stack Sample Line									
Sample Line Temperature	TC1	250F	250	250	250	250			
Sample NH3 Temperature	TC2	760F	760	760	760	760			
Sample Line Pressure/Vacuum	PI-1	6.0 "Hg	6.4	6.4	6.3	6.6			
Sample Line Pressure/Vacuum	PI-2	8.0 "Hg	6.7	6.7	6.7	6.0			
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg	6.7	6.7	6.6	6.9			
Sample Line Pressure	PI-5	8 Psi	5.5	5.4	5.4	5.2			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	✓	✓	✓	✓			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	✓	✓	✓	✓			
<b>Visual Checks</b>									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	70.0	68.5	67.0	65.5			
Moisture Sensor A/Filter	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	✓	✓	✓	✓			
Moisture Sensor B/Filter	MS-2	Operational Status of Sample Pumps (2)	✓	✓	✓	✓			
Operational Status of Condensate Drain Pumps (2)		Operational Status of Sample Cooler	✓	✓	✓	✓			
Check LED status of Sample Cooler		Check if ok	✓	✓	✓	✓			
NH3 Scrubber Drain	HV-4	Check if ok	✓	✓	✓	✓			
		Drain as needed	✓	✓	✓	✓			
<b>Analyze Sample Flow Meter Readings</b>									
System Flow	FM-1	3-5 LPM	4.5	4.5	4.5	4.5			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.45	1.45	1.5	1.55			
NOx Analyzer	FM-3	1.2 - 1.7 LPM	1.7	1.7	1.65	1.65			
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.55	1.6	1.55	1.45			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.5	1.5	1.5	1.5			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	4.2	4.2	4.2	4.2			
System Flow	FM-7	3-5 LPM	4.2	4.2	4.2	4.2			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.6	1.6	1.6	1.6			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.5	1.5	1.5	1.5			
NOX Dry Air	FM-10	500-700 CCM	660	660	660	660			
<b>DAHS Checks</b>									
Check DAHS for normal operation. Is system logging data?			✓	✓	✓	✓			
Check Alarms in DAHS.			✓	✓	✓	✓			
Check chart recorder for normal operation			✓	✓	✓	✓			
Check analyzer calibration drift. Did all calibrations pass?			✓	✓	✓	✓			
Check printer status			✓	✓	✓	✓			
<b>REMARKS:</b>									

Mark as either Acceptable "✓", Corrective action Required "X", or Actual Readings, where required  
Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_

**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station  
Daily Quality Control/Quality Assurance Plan  
Checklist for CEMS Shelter Inspection**

Date	Technician's Initial	Tag ID	Limit	Tue	Wed	Thu	Fri	Sat	Sun
Please enter readings and notify the Maintenance Manager when it is time to re-order									
Calibration Gas Pressures				2/19/19	2/20/19	2/21/19			
O2/CO High Span, NOX Zero		SV1	> 150 psi	1480	1330	1380			
NOX Low Span/CO Low Span		SV2	> 150 psi	470	880	410			
NOX High Span, O2/CO Zero		SV3	> 150 psi	1300	1210	1210			
Please enter readings									
Stack Sample Line				250	250	250			
Sample Line Temperature		TC1	250°F	710	760	760			
Sample NH3 Temperature		TC2	760°F	6.2	6.3	6.6			
Sample Line Pressure/Vacuum		PI-1	6.0 "Hg	5.2	5.2	5.0			
Sample Line Pressure/Vacuum		PI-2	8.0 "Hg	6.6	6.6	6.8			
Sample Line Pressure/Vacuum		PI-4	7.5 "Hg	5.3	5.4	5.1			
Sample Line Pressure		PI-5	8 Psi	✓	✓	✓			
Verify Functionality of Sample Pump A Flow Switch		FS-1	5-7 LPM (set point)	✓	✓	✓			
Verify Functionality of Sample Pump B Flow Switch		FS-2	5-7 LPM (set point)	✓	✓	✓			
Visual Checks									
Room Enclosure Temperature		Check HVAC controls	72 F (+/-5) F	68.5	68.0	68.5			
Moisture Sensor A/Filter		MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	✓	✓	✓			
Moisture Sensor B/Filter		MS-2	Check if ok	✓	✓	✓			
Operational Status of Sample Pumps (2)			Check if ok	✓	✓	✓			
Operational Status of Condensate Drain Pumps (2)			Check if ok	✓	✓	✓			
Check LED status of Sample Cooler			Check if ok	✓	✓	✓			
NH3 Scrubber Drain		HV-4	Drain as needed	✓	✓	✓			
Analyzer Sample Flow Meter Readings									
System Flow		FM-1	3-5 LPM	4.5	4.5	4.5			
O2 Analyzer		FM-2	1.2 - 1.7 LPM	1.45	1.5	1.55			
NOx Analyzer		FM-3	1.2 - 1.7 LPM	1.65	1.65	1.65			
NOX By-Pass		FM-4	1.2 - 1.7 LPM	1.45	1.55	1.45			
CO Analyzer		FM-5	1.2 - 1.7 LPM	1.5	1.5	1.5			
Cal Gas Flow (only during Calibration)		FM-6	> than FM-1 & FM-7	4.2	4.2	4.2			
System Flow		FM-7	3-5 LPM	1.6	1.6	1.6			
NOX/NH3 Analyzer		FM-8	1.5 LPM	1.5	1.5	1.5			
NOX/NH3 Analyzer By-Pass		FM-9	1.2 - 1.5 LPM	6.0	6.0	6.0			
NOX Dry Air		FM-10	500-700 CCM	✓	✓	✓			
DAHMS Checks									
Check DAHS for normal operation. Is system logging data?				✓	✓	✓			
Check Alarms in DAHS				✓	✓	✓			
Check chart recorder for normal operation				✓	✓	✓			
Check analyzer calibration drift. Did all calibrations pass?				✓	✓	✓			
Check printer status				✓	✓	✓			
REMARKS:									

Mark as either Acceptable "✓", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.  
 Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_



**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station  
Daily Quality Control/Quality Assurance Plan  
Checklist for CEMS Shelter Inspection**

Parameter to Check	Tag ID	Limits	Mon	Tue	Wed	Thu	Fri	Sat	Sun
<b>Dates</b>									
Technician's Initial			2/25/14	2/26/14	2/27/14	2/28/14			
Calibration Gas Pressures									
O2/CO High Span, NOX Zero	SV1	>150 psi	17.60	17.10	117.0	116.0			
NOX Low Span/CO Low Span	SV2	>150 psi	89.0	85.0	83.0	82.0			
NOX High Span, O2/CO Zero	SV3	>150 psi	124.3	12.0	12.0	12.0			
Stack Sample Line									
Sample Line Temperature	TC1	250°F	250	250	350	250			
Sample NH3 Temperature -	TC2	760°F	760	760	760	760			
Sample Line Pressure/Vacuum	PI-1	8.0 Hg	6.4	6.4	6.3	6.4			
Sample Line Pressure/Vacuum	PI-2	8.0 Hg	4.3	4.2	4.4	4.3			
Sample Line Pressure/Vacuum	PI-4	7.5 Hg	6.6	6.6	6.6	6.8			
Sample Line Pressure	PI-5	8 Psi	5.4	5.4	5.4	5.4			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	✓	✓	✓	✓			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	✓	✓	✓	✓			
Visual Checks									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	68.5	67.0	65.2	69.0			
Moisture Sensor A/Filler	MS-1	Clean and dry. If filter shows buildup and flow levels are dropping, replace filter	✓	✓	✓	✓			
Moisture Sensor B/Filler	MS-2	Check if ok	✓	✓	✓	✓			
Operational Status of Sample Pumps (2)		Check if ok	✓	✓	✓	✓			
Operational Status of Condensate Drain Pumps (2)		Check if ok	✓	✓	✓	✓			
Check LED status of Sample Cooler		Check if ok	✓	✓	✓	✓			
NH3 Scrubber Drain	HV-4	Drain as needed	✓	✓	✓	✓			
Analyzer Sample Flow Meter Readings									
System Flow	FM-1	3-5 LPM	4.5	4.5	4.5	4.4			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.5	1.5	1.65	1.55			
NOX Analyzer	FM-3	1.2 - 1.7 LPM	1.65	1.65	1.65	1.65			
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.65	1.65	1.6	1.55			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.5	1.5	1.5	1.5			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	4.2	4.2	4.2	4.2			
System Flow	FM-7	3-5 LPM	4.5	4.5	4.5	4.4			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.6	1.6	1.6	1.6			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.5	1.5	1.5	1.5			
NOX Dry Air	FM-10	500-700 CCM	660	660	660	660			
DAHIS Checks									
Check DAHS for normal operation. Is system logging data?			✓	✓	✓	✓			
Check Alarms in DAHS.			✓	✓	✓	✓			
Check chart recorder for normal operation			✓	✓	✓	✓			
Check analyzer calibration drift. Did all calibrations pass?			✓	✓	✓	✓			
Check printer status			✓	✓	✓	✓			
REMARKS:									

Mark as either Acceptable "✓", Corrective action Required "X", or Actual Readings, where required  
Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_

**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station  
Daily Quality Control/Quality Assurance Plan  
Checklist for CEMS Shelter Inspection**

Parameters to Check	Tag ID	Limits	Mon	Tue	Wed	Thu	Fri	Sat	Sun
<b>Details</b>									
Technician's Initial			3/5/19	3/5/19	3/6/19	3/7/19			
Calibration Gas Pressures									
O2/CO High Span, NOX Zero	SV1	>150 psi	1070	940	930	920			
NOX Low Span/CO Low Span	SV2	>150 psi	800	680	660	680			
NOX High Span, O2/CO Zero	SV3	>150 psi	1160	1020	1000	1000			
Stack Sample Line									
Sample Line Temperature	TC1	250F	250	250	250	250			
Sample NH3 Temperature	TC2	760F	760	760	760	760			
Sample Line Pressure/Vacuum	PI-1	6.0 Hg	6.4	6.4	6.3	6.3			
Sample Line Pressure/Vacuum	PI-2	8.0 Hg	4.1	4.2	4.2	4.3			
Sample Line Pressure/Vacuum	PI-4	7.5 Hg	6.6	6.6	6.7	6.7			
Sample Line Pressure	PI-5	8 Psi	5.4	5.4	5.4	5.4			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	✓	✓	✓	✓			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	✓	✓	✓	✓			
<b>Visual Checks</b>									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	69.0	68.0	69.0	69.0			
Moisture Sensor A/Filter	MS-1	Clean and dry. If filter shows buildup and flow levels are dropping, replace filter	✓	✓	✓	✓			
Moisture Sensor B/Filter	MS-2	Check if ok	✓	✓	✓	✓			
Operational Status of Sample Pumps (2)		Check if ok	✓	✓	✓	✓			
Operational Status of Condensate Drain Pumps (2)		Check if ok	✓	✓	✓	✓			
Check LED status of Sample Cooler		Check if ok	✓	✓	✓	✓			
NH3 Scrubber Drain	HV-4	Drain as needed	✓	✓	✓	✓			
<b>Analyzer Sample Flow Meter Readings</b>									
System Flow	FM-1	3-5 LPM	4.5	4.5	4.5	4.5			
Ox Analyzer	FM-2	1.2 - 1.7 LPM	1.5	1.5	1.65	1.65			
NOx Analyzer	FM-3	1.2 - 1.7 LPM	1.65	1.65	1.65	1.65			
NOx By-Pass	FM-4	1.2 - 1.7 LPM	1.45	1.5	1.45	1.35			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.5	1.45	1.5	1.5			
Cal Gas Flow (only during Calibration)	FM-6	> 1 liter FM-1 & FM-7	4.2	4.1	4.1	4.1			
System Flow	FM-7	3-5 LPM	4.2	4.1	4.1	4.1			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.6	1.6	1.6	1.6			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.5	1.5	1.5	1.5			
NOX Dry Air	FM-10	500- 700 CCM	59.2	58.0	58.0	58.0			
<b>DAHS Checks</b>									
Check DAHS for normal operation. Is system logging data?			✓	✓	✓	✓			
Check Alarms in DAHS.			✓	✓	✓	✓			
Check chart recorder for normal operation			✓	✓	✓	✓			
Check analyzer calibration drift. Did all calibrations pass?			✓	✓	✓	✓			
Check printer status			✓	✓	✓	✓			
<b>REMARKS:</b>									

Mark as either Acceptable "✓", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.  
 Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_

**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station  
Daily Quality Control/Quality Assurance Plan  
Checklist for CEMS Shelter Inspection**

Parameters to Check	Tag ID	Units	Mon	Tue	Wed	Thu	Fri	Sat	Sun
<p><b>Dates</b>                      Technician's Initial: <u>3/11/19</u> <u>3/12/19</u> <u>3/13/19</u> <u>3/14/19</u>                      Calibration Gas Pressures: <u>850</u> <u>830</u> <u>800</u> <u>800</u>                      O2/CO High Span, NOX Zero: <u>640</u> <u>630</u> <u>610</u> <u>620</u>                      NOX Low Span/CO Low Span: <u>970</u> <u>970</u> <u>950</u> <u>970</u>                      NOX High Span, O2/CO Zero: <u>250</u> <u>250</u> <u>250</u> <u>250</u>                      Stack Sample Line: <u>760</u> <u>6.7</u> <u>4.1</u> <u>4.4</u>                      Sample Line Pressure/Vacuum: <u>6.6</u> <u>6.8</u> <u>6.6</u> <u>6.6</u>                      Sample Line Pressure: <u>5.4</u> <u>5.3</u> <u>5.4</u> <u>5.5</u>                      Verify Functionality of Sample Pump A Flow Switch: <u>✓</u> <u>✓</u> <u>✓</u> <u>✓</u>                      Verify Functionality of Sample Pump B Flow Switch: <u>✓</u> <u>✓</u> <u>✓</u> <u>✓</u></p>									
<p><b>Visual Checks</b>                      Room Enclosure Temperature: <u>72 F (+/-5) F</u>                      Moisture Sensor A/Filler: <u>✓</u>                      Moisture Sensor B/Filter: <u>✓</u>                      Operational Status of Sample Pumps (2): <u>✓</u>                      Operational Status of Condensate Drain Pumps (2): <u>✓</u>                      Check LED status of Sample Cooler: <u>✓</u>                      NH3 Scrubber Drain: <u>✓</u></p>									
<p><b>Analyzer Sample Flow Meter Readings</b>                      System Flow: <u>4.5</u> <u>4.5</u> <u>4.5</u> <u>4.5</u>                      O2 Analyzer: <u>1.5</u> <u>1.5</u> <u>1.5</u> <u>1.5</u>                      NOx Analyzer: <u>1.65</u> <u>1.65</u> <u>1.65</u> <u>1.65</u>                      NOX By-Pass: <u>1.3</u> <u>1.3</u> <u>1.3</u> <u>1.3</u>                      CO Analyzer: <u>1.5</u> <u>1.5</u> <u>1.5</u> <u>1.5</u>                      Cal Gas Flow (only during Calibration): <u>5.1</u> <u>4.1</u> <u>4.1</u> <u>4.1</u>                      System Flow: <u>1.6</u> <u>1.6</u> <u>1.6</u> <u>1.6</u>                      NOX/NH3 Analyzer: <u>1.5</u> <u>1.5</u> <u>1.5</u> <u>1.5</u>                      NOX/NH3 Analyzer By-Pass: <u>5.0</u> <u>5.0</u> <u>5.0</u> <u>5.0</u>                      NOX Dry Air: <u>✓</u> <u>✓</u> <u>✓</u> <u>✓</u></p>									
<p><b>DAHs Checks</b>                      Check DAHS for normal operation. Is system logging data? <u>✓</u>                      Check Alarms in DAHS: <u>✓</u>                      Check chart recorder for normal operation: <u>✓</u>                      Check analyzer calibration drift. Did all calibrations pass? <u>✓</u>                      Check printer status: <u>✓</u></p>									
<p><b>REMARKS:</b>                      Please enter readings                      Please enter readings                      Please enter readings                      Please enter readings</p>									

Mark as either Acceptable "✓", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_

**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station**  
**Daily Quality Control/Quality Assurance Plan**  
**Checklist for CEMS Shelter Inspection**

Parameters to Check	Tag ID	Units	Mon	Tue	Wed	Thu	FT	Sat	Sun
Dates			3/18/19	3/19/19	3/20/19	3/21/19			
Technician's Initial			SS	SS	SS	SS			
Calibration Gas Pressures			Please enter readings and notify the Maintenance Manager when it is time to re-order						
O2/CO High Span, NOX Zero	SV1	>150 psi	760	700	700	700			
NOX Low Span/CO Low Span	SV2	>150 psi	590	530	550	530			
NOX High Span, O2/CO Zero	SV3	>150 psi	530	590	500	900			
Stack Sample Line			Please enter readings						
Sample Line Temperature	TC1	250°F	750	750	750	750			
Sample NH3 Temperature -	TC2	760°F	760	760	760	760			
Sample Line Pressure/Vacuum	PI-1	6.0 "Hg	6.4	6.5	6.3	6.4			
Sample Line Pressure/Vacuum	PI-2	8.0 "Hg	6.1	6.4	6.3	6.4			
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg	6.7	6.7	6.6	6.6			
Sample Line Pressure	PI-5	8 Psi	5.4	5.7	5.4	5.4			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	✓	✓	✓	✓			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	✓	✓	✓	✓			
Visual Checks									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	70.0	70.0	68.0	68.5			
Moisture Sensor A/Filer	MS-1	Clean and dry, if filler shows buildup and flow levels are dropping, replace filter	✓	✓	✓	✓			
Moisture Sensor B/Filer	MS-2	Check if ok	✓	✓	✓	✓			
Operational Status of Sample Pumps (2)		Check if ok	✓	✓	✓	✓			
Operational Status of Condensate Drain Pumps (2)		Check if ok	✓	✓	✓	✓			
Check LED status of Sample Cooler		Check if ok	✓	✓	✓	✓			
NH3 Scrubber Drain	HV-4	Drain as needed	✓	✓	✓	✓			
Analyzer Sample Flow Meter Readings			Please enter readings						
System Flow	FM-1	3-5 LPM	4.5	4.6	4.4	4.5			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.5	1.65	1.6	1.6			
NOx Analyzer	FM-3	1.2 - 1.7 LPM	1.65	1.65	1.65	1.65			
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.3	1.65	1.5	1.35			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.45	1.5	1.5	1.5			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	4.1	4.1	4.1	4.1			
System Flow	FM-7	3-5 LPM	✓	✓	✓	✓			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.6	1.6	1.6	1.6			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.5	1.5	1.5	1.5			
NOX Dry Air	FM-10	500-700 CCM	580	580	580	580			
DAHs Checks									
Check DAHS for normal operation. Is system logging data?			✓	✓	✓	✓			
Check Alarms in DAHS.			✓	✓	✓	✓			
Check chart recorder for normal operation			✓	✓	✓	✓			
Check analyzer calibration drift. Did all calibrations pass?			✓	✓	✓	✓			
Check printer status			✓	✓	✓	✓			
REMARKS:									

Mark as either Acceptable "✓", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_

**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station  
Daily Quality Control/Quality Assurance Plan  
Checklist for CEMS Shelter Inspection**

Parameter to Check	Thu 10	Limits	Mon	Tue	Wed	Thu	PH	Set	Sun
Dates	3/25/19		3/26/19	3/27/19	3/28/19	3/28/19			
Technician's Initial									
Calibration Gas Pressures									
O2/CO High Span, NOX Zero	660	>150 psi	660	670	570	570			
NOX Low Span/CO Low Span	520	>150 psi	520	510	470	430			
NOX High Span, O2/CO Zero	890	>150 psi	890	870	830	830			
Stack Sample Line									
Sample Line Temperature	250	250°F	250	250	250	250			
Sample NH3 Temperature	760	760°F	760	760	760	760			
Sample Line Pressure/Vacuum	6.5	6.0 "Hg	6.4	6.7	6.5	6.5			
Sample Line Pressure/Vacuum	6.7	8.0 "Hg	6.4	6.1	6.5	6.5			
Sample Line Pressure/Vacuum	6.7	7.5 "Hg	6.4	6.9	6.7	6.7			
Sample Line Pressure	5.4	8 PSI	5.4	5.2	5.4	5.4			
Verify Functionality of Sample Pump A Flow Switch	✓	5-7 LPM (set point)	✓	✓	✓	✓			
Verify Functionality of Sample Pump B Flow Switch	✓	5-7 LPM (set point)	✓	✓	✓	✓			
Visual Checks									
Room Endorse Temperature	68.0	72 F (+/-5) F	68.0	68.0	69.0	67.5			
Moisture Sensor A/Filter	✓	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	✓	✓	✓	✓			
Moisture Sensor B/Filter	✓	Check if ok	✓	✓	✓	✓			
Operational Status of Sample Pumps (2)	✓	Check if ok	✓	✓	✓	✓			
Operational Status of Condensate Drain Pumps (2)	✓	Check if ok	✓	✓	✓	✓			
Check LED status of Sample Cooler	✓	Drain as needed	✓	✓	✓	✓			
NH3 Scrubber Drain	✓		✓	✓	✓	✓			
Analyzer Sample Flow Meter Readings									
System Flow	4.5	3-5 LPM	4.5	4.5	4.5	4.6			
O2 Analyzer	1.5	1.2 - 1.7 LPM	1.5	1.5	1.5	1.5			
NOx Analyzer	1.65	1.2 - 1.7 LPM	1.65	1.65	1.65	1.7			
NOX By-Pass	1.6	1.2 - 1.7 LPM	1.6	1.65	1.65	1.7			
CO Analyzer	1.5	1.2 - 1.7 LPM	1.5	1.5	1.5	1.5			
Cal Gas Flow (only during Calibration)	4.1	> than FM-1 & FM-7	4.1	4.1	4.0	4.1			
System Flow	1.6	3-5 LPM	1.6	1.6	1.6	1.6			
NOX/NH3 Analyzer	1.5	1.5 LPM	1.5	1.5	1.5	1.5			
NOX/NH3 Analyzer By-Pass	580	1.2 - 1.5 LPM	580	570	570	570			
NOX Dry Air		500-700 CCM							
DAHIS Checks									
Check DAHS for normal operation. Is system logging data?	✓		✓	✓	✓	✓			
Check Alarms in DAHS	✓		✓	✓	✓	✓			
Check chart recorder for normal operation	✓		✓	✓	✓	✓			
Check analyzer calibration diff. Did all calibrations pass?	✓		✓	✓	✓	✓			
Check printer status	✓		✓	✓	✓	✓			
REMARKS:									

Mark as either Acceptable "A", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_



**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station**  
**Daily Quality Control/Quality Assurance Plan**  
**Checklist for CEMS Shelter Inspection**

Parameters to Check	Tag ID	Units	Mon	Tue	Wed	Thu	Fri	Sat	Sun
Date			7/1/14	4/2/14	4/2/14	4/2/14	4/2/14		
Technician's Initial			SO						
Calibration Gas Pressures									
O2/CO High Span, NOX Zero	SV1	>150 psi	520	510	520	2010			
NOX Low Span/CO Low Span	SV2	>150 psi	400	370	380	1510			
NOX High Span, O2/CO Zero	SV3	>150 psi	400	370	380	730			
Stack Sample Line			Please enter readings						
Sample Line Temperature	TC1	250°F	250	250	250	250			
Sample NH3 Temperature	TC2	760°F	740	740	740	740			
Sample Line Pressure/Vacuum	PI-1	6.0" Hg	4.5	4.5	4.4	4.4			
Sample Line Pressure/Vacuum	PI-2	8.0" Hg	4.5	4.4	4.4	4.4			
Sample Line Pressure/Vacuum	PI-4	7.5" Hg	4.7	4.7	4.6	4.7			
Sample Line Pressure	PI-5	8 Psi	4.7	4.7	4.6	4.7			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	4.7	4.7	4.6	4.7			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	4.7	4.7	4.6	4.7			
Visual Checks									
Room Enclosure Temperature		72 F (+/-5) F	67.5	68.0	67.5	67.5			
Moisture Sensor A/Filter	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	✓	✓	✓	✓			
Moisture Sensor B/Filter	MS-2	Check if ok	✓	✓	✓	✓			
Operational Status of Sample Pumps (2)		Check if ok	✓	✓	✓	✓			
Operational Status of Condensate Drain Pumps (2)		Check if ok	✓	✓	✓	✓			
Check LED status of Sample Cooler		Check if ok	✓	✓	✓	✓			
NH3 Scrubber Drain	HV-4	Drain as needed	✓	✓	✓	✓			
Analyzer Sample Flow Meter Readings			Please enter readings						
System Flow	FM-1	3-5 LPM	4.5	4.5	4.5	4.5			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.5	1.5	1.5	1.5			
NOx Analyzer	FM-3	1.2 - 1.7 LPM	1.5	1.5	1.5	1.5			
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.5	1.5	1.5	1.5			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.5	1.5	1.5	1.5			
Cell Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	4.1	4.1	4.1	4.1			
System Flow	FM-7	3-5 LPM	4.1	4.1	4.1	4.1			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.6	1.6	1.6	1.6			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.5	1.5	1.5	1.5			
NOX Dry Air	FM-10	500-700 CCM	550	550	550	550			
DAHIS Checks									
Check DAHS for normal operation. Is system logging data?			✓	✓	✓	✓			
Check Alarms in DAHS			✓	✓	✓	✓			
Check chart recorder for normal operation			✓	✓	✓	✓			
Check analyzer calibration unit. Did all calibrations pass?			✓	✓	✓	✓			
Check printer status			✓	✓	✓	✓			
REMARKS:									

Mark as either Acceptable "✓", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_

**Barre/Center/Graveland/Miraloma/McGrath Peaker Generating Station**  
**Daily Quality Control/Quality Assurance Plan**  
**Checklist for CEMS Shelter Inspection**

Parameters to Check	Yard ID	Units	Mon	Tue	Wed	Thu	Fri	Sat	Sun
Dates						7/11/17			
Technician's Initial						MS			
Please enter readings and notify the Maintenance Manager when it is time to re-order									
Calibration Gas Pressures									
O2/CO High Span, NOX Zero	SV1	>150 psi				1880			
NOX Low Span/CO Low Span	SV2	>150 PSI				1870			
NOX High Span, O2/CO Zero	SV3	>150 psi				690			
Please enter readings									
Stack Sample Line									
Sample Line Temperature	TC1	250°F				750			
Sample NH3 Temperature	TC2	760°F				760			
Sample Line Pressure/Vacuum	PI-1	6.0 "Hg				6.1			
Sample Line Pressure/Vacuum	PI-2	8.0 "Hg				8.0			
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg				7.6			
Sample Line Pressure	PI-5	8 Psi				8.3			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)				✓			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)				✓			
Visual Checks									
Room Enclosure Temperature	Check HVAC controls	72 F (±1.5) F				69.0			
Moisture Sensor A/Filter	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter				✓			
Moisture Sensor B/Filter	MS-2	Check if ok				✓			
Operational Status of Sample Pumps (2)		Check if ok				✓			
Operational Status of Condensate Drain Pumps (2)		Check if ok				✓			
Check LED status of Sample Cooler		Check if ok				✓			
NH3 Scrubber Drain	HV-4	Drain as needed				✓			
Please enter readings									
Analyzer Sample Flow Meter Readings									
System Flow	FM-1	3-5 LPM				4.3			
O2 Analyzer	FM-2	1.2 - 1.7 LPM				1.4			
NOx Analyzer	FM-3	1.2 - 1.7 LPM				1.63			
NOX By-Pass	FM-4	1.2 - 1.7 LPM				1.35			
CO Analyzer	FM-5	1.2 - 1.7 LPM				1.45			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7				4.1			
System Flow	FM-7	3-5 LPM				1.6			
NOX/NH3 Analyzer	FM-8	1.5 LPM				1.5			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM				650			
NOX Dry Air	FM-10	500-700 CCM				✓			
DAHS Checks									
Check DAHS for normal operation. Is system logging data?						✓			
Check Alarms in DAHS.						✓			
Check chart recorder for normal operation						✓			
Check analyzer calibration drift. Did all calibrations pass?						✓			
Check printer status						✓			
REMARKS:									

Mark as either Acceptable "A", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_

**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station  
Daily Quality Control/Quality Assurance Plan  
Checklist for CEMS Shelter Inspection**

Parameters to Check	Tag ID	Units	Mon	Tue	Wed	Thu	Fri	Sat	Sun
<b>Data</b>									
Technician's Initial			4/15/19	4/16/19	4/17/19	4/18/19			
Calibration Gas Pressures			250	250	250	250			
O2/CO High Span, NOX Zero	SV1	>150 psi	1660	1450	1630	1630			
NOX Low Span/CO Low Span	SV2	>150 psi	1710	1730	1730	1760			
NOX High Span, O2/CO Zero	SV3	>150 psi	580	580	580	580			
Please enter readings and notify the Maintenance Manager when it is time to re-order.									
Stack Sample Line									
Sample Line Temperature	TC1	250°F	250	250	250	250			
Sample NH3 Temperature	TC2	760°F	760	760	760	760			
Sample Line Pressure/Vacuum	PI-1	6.0"Hg	6.5	6.2	6.2	6.7			
Sample Line Pressure/Vacuum	PI-2	8.0"Hg	4.0	4.2	4.3	4.2			
Sample Line Pressure/Vacuum	PI-4	7.5"Hg	6.8	6.6	6.6	6.6			
Sample Line Pressure	PI-5	8 Psi	5.4	5.4	5.4	5.4			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	✓	✓	✓	✓			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	✓	✓	✓	✓			
Visual Checks									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	67.0	67.5	67.5	70.0			
Moisture Sensor A/Filter	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	✓	✓	✓	✓			
Moisture Sensor B/Filter	MS-2	Check if ok	✓	✓	✓	✓			
Operational Status of Condensate Drain Pumps (2)		Check if ok	✓	✓	✓	✓			
Check LED status of Sample Cooler		Check if ok	✓	✓	✓	✓			
NH3 Scrubber Drain	HV-4	Drain as needed	✓	✓	✓	✓			
Analyzer Sample Flow Meter Readings									
System Flow	FM-1	3-5 LPM	4.5	4.5	4.5	4.5			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.5	1.5	1.5	1.5			
NOx Analyzer	FM-3	1.2 - 1.7 LPM	1.65	1.65	1.65	1.62			
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.35	1.35	1.45	1.35			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.45	1.45	1.45	1.4			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7							
System Flow	FM-7	3-5 LPM	4.1	4.1	4.1	4.1			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.6	1.6	1.6	1.6			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.5	1.5	1.5	1.5			
NOX Dry Air	FM-10	500-700 CCM	650	650	650	650			
DAHS Checks									
Check DAHS for normal operation, is system logging data?			✓	✓	✓	✓			
Check Alarms in DAHS			✓	✓	✓	✓			
Check chart recorder for normal operation			✓	✓	✓	✓			
Check analyzer calibration drift, did all calibrations pass?			✓	✓	✓	✓			
Check printer status			✓	✓	✓	✓			
<b>REMARKS:</b>									

Mark as either Acceptable "✓", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.  
 Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_



**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station**  
**Daily Quality Control/Quality Assurance Plan**  
**Checklist for CEMS Shelter Inspection**

Parameters to Check	Tag ID	Limits	Mon	Tue	Wed	Thu	Fri	Sat	Sun
Dates			4/22/19	4/23/19	4/24/19	4/25/19			
Technician's Initial			SD	SD	SD	SD			
Calibration Gas Pressures									
O2/CO High Span, NOX Zero	SV1	>150 psi	1480	1500	1460	1410			
NOX Low Span/CO Low Span	SV2	>150 psi	1630	1680	1630	1610			
NOX High Span, O2/CO Zero	SV3	>150 psi	520	500	500	480			
Stack Sample Line			Please enter readings						
Sample Line Temperature	TC1	250F	250	250	250	250			
Sample NH3 Temperature	TC2	750F	760	760	740	760			
Sample Line Pressure/Vacuum	PI-1	6.0 Hg	6.2	6.1	6.2	6.3			
Sample Line Pressure/Vacuum	PI-2	8.0 Hg	4.1	4.1	4.1	4.1			
Sample Line Pressure/Vacuum	PI-4	7.5 Hg	6.6	6.6	6.6	6.6			
Sample Line Pressure	PI-5	8 Psi	5.4	5.4	5.4	5.4			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	✓	✓	✓	✓			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	✓	✓	✓	✓			
Visual Checks									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	67.5	68.0	68.5	69.5			
Moisture Sensor A/Filler	MS-1	Clean and dry, if filler shows buildup and flow levels are dropping, replace filler	✓	✓	✓	✓			
Moisture Sensor B/Filler	MS-2	Check if ok	✓	✓	✓	✓			
Operational Status of Sample Pumps (2)		Check if ok	✓	✓	✓	✓			
Operational Status of Condensate Drain Pumps (2)		Check if ok	✓	✓	✓	✓			
Check LED status of Sample Cooler		Check if ok	✓	✓	✓	✓			
NH3 Scrubber Drain	HV-4	Drain as needed	✓	✓	✓	✓			
Analyzer Sample Flow Meter Readings			Please enter readings						
System Flow	FM-1	3-5 LPM	4.3	4.4	4.4	4.5			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.45	1.45	1.4	1.45			
NOx Analyzer	FM-3	1.2 - 1.7 LPM	1.65	1.65	1.65	1.65			
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.45	1.35	1.4	1.37			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.4	1.4	1.4	1.4			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	4.1	4.1	4.1	4.1			
System Flow	FM-7	3-5 LPM	1.6	1.6	1.6	1.6			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.5	1.5	1.5	1.5			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.5	1.5	1.5	1.5			
NOX Dry Air	FM-10	500-700 CCM	650	650	650	650			
DAHS Checks									
Check DAHS for normal operation. Is system logging data?			✓	✓	✓	✓			
Check Alarms in DAHS.			✓	✓	✓	✓			
Check chart recorder for normal operation			✓	✓	✓	✓			
Check analyzer calibration drift. Did all calibrations pass?			✓	✓	✓	✓			
Check printer status			✓	✓	✓	✓			
REMARKS:									

Mark as either Acceptable "✓", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_

**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station**  
**Daily Quality Control/Quality Assurance Plan**  
**Checklist for CEMS Shelter Inspection**

Parameters to Check	Tag ID	Units	Mon	Tue	Wed	Thu	Fri	Sat	Sun
Dates			4/29/14	4/30/14	5/1/14	5/2/14			
Technician's Initial			JD	JD	JD	JD			
Calibration Gas Pressures									
O2/CO High Span, NOX Zero	SV1	>150 psi	1700	1320	1260	1260			
NOX Low Span/CO Low Span	SV2	>150 psi	1570	1570	1500	1560			
NOX High Span, O2/CO Zero	SV3	>150 psi	420	420	380	380			
Stack Sample Line									
Sample Line Temperature	TC1	250°F	250	250	250	250			
Sample NH3 Temperature	TC2	780°F	760	760	760	760			
Sample Line Pressure/Vacuum	PI-1	6.0" Hg	6.4	6.7	6.4	6.4			
Sample Line Pressure/Vacuum	PI-2	8.0" Hg	4.7	4.7	4.7	4.7			
Sample Line Pressure/Vacuum	PI-4	7.5" Hg	6.7	6.6	6.6	6.6			
Sample Line Pressure	PI-5	8 Psi	5.4	5.5	5.5	5.4			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	✓	✓	✓	✓			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	✓	✓	✓	✓			
Visual Checks									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	68.0	68.0	68.0	67.5			
Moisture Sensor A/Filter	MS-1	Clean and dry. If filler flow levels are dropping, replace filter	✓	✓	✓	✓			
Moisture Sensor B/Filter	MS-2	Check if ok	✓	✓	✓	✓			
Operational Status of Sample Pumps (2)		Check if ok	✓	✓	✓	✓			
Operational Status of Condensate Drain Pumps (2)		Check if ok	✓	✓	✓	✓			
Check LED status of Sample Cooler		Check if ok	✓	✓	✓	✓			
NH3 Scrubber Drain	HV-4	Drain as needed	✓	✓	✓	✓			
Analyzer Sample Flow Meter Readings									
System Flow	FM-1	3-5 LPM	4.5	4.5	4.5	4.5			
Oz Analyzer	FM-2	1.2 - 1.7 LPM	1.7	1.7	1.7	1.7			
NOx Analyzer	FM-3	1.2 - 1.7 LPM	1.65	1.65	1.65	1.65			
NOx By-Pass	FM-4	1.2 - 1.7 LPM	1.45	1.45	1.45	1.45			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.4	1.4	1.4	1.4			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7							
System Flow	FM-7	3-5 LPM	4.2	4.2	4.2	4.2			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.6	1.6	1.6	1.6			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.5	1.5	1.5	1.5			
NOX Dry Air	FM-10	500-700 CCM	650	650	650	650			
DAHIS Checks									
Check DAHS for normal operation. Is system logging data?			✓	✓	✓	✓			
Check Alarms in DAHS.			✓	✓	✓	✓			
Check chart recorder for normal operation			✓	✓	✓	✓			
Check analyzer calibration drift. Did all calibrations pass?			✓	✓	✓	✓			
Check printer status			✓	✓	✓	✓			
REMARKS:									

Mark as either Acceptable "✓", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_

**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station  
Daily Quality Control/Quality Assurance Plan  
Checklist for CEMS Shelter Inspection**

Parameters to Check	Tag ID	Limits	Mon	Tue	Wed	Thu	Fri	Sat	Sun
<b>Dates</b>									
Technician's Initial			5/16/19	5/17/19					
Calibration Gas Pressures									
O2/CO High Span, NOX Zero	SV1	>150 psi	1220	1170					
NOX Low Span/CO Low Span	SV2	>150 psi	1500	1440					
NOX High Span, O2/CO Zero	SV3	>150 psi	2020	1970					
Please enter readings									
Stack Sample Line									
Sample Line Temperature	TC1	250°F	250	250					
Sample NH3 Temperature	TC2	760°F	760	760					
Sample Line Pressure/Vacuum	PI-1	6.0" Hg	6.1	6.1					
Sample Line Pressure/Vacuum	PI-2	8.0" Hg	4.3	4.3					
Sample Line Pressure/Vacuum	PI-4	7.5" Hg	6.6	6.6					
Sample Line Pressure	PI-5	8 Psi	5.4	5.4					
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	✓	✓					
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	✓	✓					
<b>Visual Checks</b>									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	67.5	68.5					
Moisture Sensor A/Filter	MS-1	Clean and dry, if filler flow levels are dropping, replace filter	✓	✓					
Moisture Sensor B/Filter	MS-2	Check if ok	✓	✓					
Operational Status of Sample Pumps (2)		Check if ok	✓	✓					
Operational Status of Condensate Drain Pumps (2)		Check if ok	✓	✓					
Check LED status of Sample Cooler		Check if ok	✓	✓					
NH3 Scrubber Drain	HV-4	Drain as needed	✓	✓					
<b>Analyzer Sample Flow Meter Readings</b>									
System Flow	FM-1	3-5 LPM	4.5	4.4					
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.75	1.75					
NOx Analyzer	FM-3	1.2 - 1.7 LPM	1.65	1.65					
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.55	1.55					
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.4	1.5					
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	4.2	4.2					
System Flow	FM-7	3-5 LPM	4.6	4.6					
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.5	1.5					
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.5	1.5					
NOX Dry Air	FM-10	500-700 CCM	650	650					
<b>DAHS Checks</b>									
Check DAHS for normal operation. Is system logging data?			✓	✓					
Check Alarms in DAHS.			✓	✓					
Check chart recorder for normal operation			✓	✓					
Check analyzer calibration drift. Did all calibrations pass?			✓	✓					
Check printer status			✓	✓					
<b>REMARKS:</b>									

Mark as either Acceptable "✓", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator Immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_

# Barre/Center/Graveland/Miraloma/McGrath Peaker Generating Station

## Daily Quality Control/Quality Assurance Plan

### Checklist for CEMS Shelter Inspection

Parameters to Check	Tag ID	Limits	Mon	Tue	Wed	Thu	Fri	Sat	Sun
Dates			5/10/19	5/14/19					
Technician's Initial									
Please enter readings and notify the Maintenance Manager when it is time to re-order.									
Calibration Gas Pressures									
O2/CO High Span, NOX Zero	SV1	>150 psi	130	110					
NOX Low Span/CO Low Span	SV2	>150 psi	1450	1430					
NOX High Span, O2/CO Zero	SV3	>150 psi	1990	1980					
Please enter readings									
Stack Sample Line									
Sample Line Temperature	TC1	250°F	250	250					
Sample NH3 Temperature	TC2	760°F	760	760					
Sample Line Pressure/Vacuum	PI-1	6.0 Hg	6.1	6.3					
Sample Line Pressure/Vacuum	PI-2	8.0 Hg	8.0	8.0					
Sample Line Pressure/Vacuum	PI-4	7.5 Hg	8.6	8.7					
Sample Line Pressure	PI-5	8 Psi	8.8	8.7					
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	✓	✓					
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	✓	✓					
Please enter readings									
Visual Checks									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	68.5	68.5					
Moisture Sensor A/Filter	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	✓	✓					
Moisture Sensor B/Filter	MS-2	Check if ok	✓	✓					
Operational Status of Sample Pumps (2)		Check if ok	✓	✓					
Operational Status of Condensate Drain Pumps (2)		Check if ok	✓	✓					
Check LED status of Sample Cooler		Check if ok	✓	✓					
NH3 Scrubber Drain	HV-4	Drain as needed	✓	✓					
Please enter readings									
Analyzer Sample Flow Meter Readings									
System Flow	FM-1	3-5 LPM	4.3	4.4					
O2 Analyzer	FM-2	12 - 17 LPM	1.7	1.75					
NOx Analyzer	FM-3	12 - 17 LPM	1.6	1.6					
NOX By-Pass	FM-4	12 - 17 LPM	1.45	1.45					
CO Analyzer	FM-5	12 - 17 LPM	1.5	1.45					
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	4.3	4.2					
System Flow	FM-7	3-5 LPM	6.6	6.55					
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.5	1.5					
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.5	1.5					
NOX Dry Air	FM-10	500-700 CCM	650	650					
Please enter readings									
DAHS Checks									
Check DAHS for normal operation. Is system logging data?			✓	✓					
Check Alarms in DAHS.			✓	✓					
Check chart recorder for normal operation			✓	✓					
Check analyzer calibration drift. Did all calibrations pass?			✓	✓					
Check printer status			✓	✓					
REMARKS:									

Mark as either Acceptable "V", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_

**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station**  
**Daily Quality Control/Quality Assurance Plan**  
**Checklist for CEMS Shelter Inspection**

Parameters to Check	Tag ID	Limits	Mon	Tue	Wed	Thu	Fri	Sat	Sun
<b>Dates</b>									
Technician's Initial			CPD/A	5/21/17	6/23/17	5/23/17			
Calibration Gas Pressures									
O2/CO High Span, NOX Zero	SV1	>150 psi	1970	901	900	480			
NOX Low Span/CO Low Span	SV2	>150 psi	1320	1330	1280	1280			
NOX High Span, O2/CO Zero	SV3	>150 psi	1830	1800	1790	1800			
Stack Sample Line									
Sample Line Temperature	TC1	250°F	250	250	250	250			
Sample NH3 Temperature -	TC2	760°F	760	760	760	760			
Sample Line Pressure/Vacuum	PI-1	6.0 "Hg	6.2	6.4	6.2	6.0			
Sample Line Pressure/Vacuum	PI-2	8.0 "Hg	6.7	6.1	5.5	5.1			
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg	6.6	6.6	6.6	6.6			
Sample Line Pressure	PI-5	8 Psi	7.2	6.2	7.3	7.4			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	✓	✓	✓	✓			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	✓	✓	✓	✓			
<b>Visual Checks</b>									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	68.5	68.5	69.0	68.5			
Moisture Sensor A/Filter	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	✓	✓	✓	✓			
Moisture Sensor B/Filter	MS-2	Check if ok	✓	✓	✓	✓			
Operational Status of Condensate Drain Pumps (2)		Check if ok	✓	✓	✓	✓			
Check LED status of Sample Cooler		Check if ok	✓	✓	✓	✓			
NH3 Scrubber Drain	HV-4	Drain as needed	✓	✓	✓	✓			
<b>Analyzer Sample Flow Meter Readings</b>									
System Flow	FM-1	3-5 LPM	4.0	4.0	4.1	4.1			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.4	1.4	1.4	1.35			
NOx Analyzer	FM-3	1.2 - 1.7 LPM	1.5	1.5	1.5	1.5			
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.2	1.2	1.2	1.2			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.4	1.4	1.45	1.4			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	4.1	4.2	4.2	4.2			
System Flow	FM-7	3-5 LPM	4.1	4.2	4.2	4.2			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.55	1.45	1.45	1.45			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.35	1.35	1.35	1.35			
NOX Dry Air	FM-10	500-700 CCM	560	540	550	550			
<b>DAHS Checks</b>									
Check DAHS for normal operation. Is system logging data?			✓	✓	✓	✓			
Check Alarms in DAHS			✓	✓	✓	✓			
Check chart recorder for normal operation			✓	✓	✓	✓			
Check analyzer calibration drift. Did all calibrations pass?			✓	✓	✓	✓			
Check printer status			✓	✓	✓	✓			
<b>REMARKS:</b>									
Please enter readings									
Please enter readings									

Mark as either Acceptable "✓", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.  
 Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_



**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station**  
**Daily Quality Control/Quality Assurance Plan**  
**Checklist for CEMS Shelter Inspection**

Parameter to Check	Tag ID	Units	Mon	Tue	Wed	Thu	Fri	Sat	Sun
<b>Dates</b>				5/23/19	5/24/19				
Technician's Initial									
Calibration Gas Pressures									
O2/CO High Span, NOX Zero	SV1	>150 psi		830	800				
NOX Low Span/CO Low Span	SV2	>150 psi		1210	1220				
NOX High Span, O2/CO Zero	SV3	>150 psi		1780	1740				
<b>Stack Sample Line</b>				Please enter readings					
Sample Line Temperature	TC1	250°F		250	250				
Sample NH3 Temperature	TC2	760°F		760	760				
Sample Line Pressure/Vacuum	PI-1	6.0 "Hg		6.0	6.0				
Sample Line Pressure/Vacuum	PI-2	8.0 "Hg		8.0	8.0				
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg		6.6	6.6				
Sample Line Pressure	PI-5	8 Psi		7.4	7.4				
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)		✓	✓				
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)		✓	✓				
<b>Visual Checks</b>									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F		67.5	67.0				
Moisture Sensor A/Filter	MS-1	Clean and dry. If filter shows buildup and flow levels are dropping, replace filter		✓	✓				
Moisture Sensor B/Filter	MS-2	Check if ok		✓	✓				
Operational Status of Condensate Drain Pumps (2)		Check if ok		✓	✓				
Check LED status of Sample Cooler		Check if ok		✓	✓				
NH3 Scrubber Drain	HV-4	Drain as needed		✓	✓				
<b>Analyzer Sample Flow Meter Readings</b>				Please enter readings					
System Flow	FM-1	3-5 LPM		3.9	3.9				
Oz Analyzer	FM-2	1.2 - 1.7 LPM		1.35	1.35				
NOx Analyzer	FM-3	1.2 - 1.7 LPM		1.45	1.45				
NOX By-Pass	FM-4	1.2 - 1.7 LPM		1.7	1.7				
CO Analyzer	FM-5	1.2 - 1.7 LPM		1.4	1.4				
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7		4.2	4.1				
System Flow	FM-7	3-5 LPM		1.45	1.45				
NOX/NH3 Analyzer	FM-8	1.5 LPM		1.35	1.35				
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM		1.35	1.35				
NOX Dry Air	FM-10	500-700 CCM		650	650				
<b>DAHS Checks</b>									
Check DAHS for normal operation. Is system logging data?				✓	✓				
Check Alarms in DAHS.				✓	✓				
Check chart recorder for normal operation				✓	✓				
Check analyzer calibration drift. Did all calibrations pass?				✓	✓				
Check printer status				✓	✓				
<b>REMARKS:</b>									

Mark as either Acceptable "✓", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.  
 Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_

**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station**  
**Daily Quality Control/Quality Assurance Plan**  
**Checklist for CEMS Shelter Inspection**

Parameters to Check	Temp (F)	Limits	Mon	Tue	Wed	Thurs	Fri	Sat	Sun
<b>Dates</b>			6/3/19	6/4/19	6/5/19	6/6/19			
Technician's Initial			SD	SD	SD	SD			
Calibration Gas Pressures			Please enter readings and notify the Maintenance Manager when it is time to re-order						
OZCO High Span, NOX Zero	SV1	>150 psi	770	700	690	690			
NOX Low Span/CO Low Span	SV2	>150 psi	1730	1170	160	1160			
NOX High Span, OZCO Zero	SV3	>150 psi	1760	1730	1730	1730			
<b>Stack Sample Line</b>			Please enter readings						
Sample Line Temperature	TC1	250°F	750	250	750	250			
Sample NH3 Temperature	TC2	760°F	710	760	760	760			
Sample Line Pressure/Vacuum	PI-1	6.0 "Hg	6.1	6.2	6.2	6.1			
Sample Line Pressure/Vacuum	PI-2	8.0 "Hg	5.7	5.9	5.7	5.3			
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg	6.6	6.6	6.4	6.4			
Sample Line Pressure	PI-5	8 Psi	7.4	7.4	7.4	7.4			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	✓	✓	✓	✓			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	✓	✓	✓	✓			
<b>Visual Checks</b>									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	67.5	68.0	69.0	69.0			
Moisture Sensor A/Filter	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	✓	✓	✓	✓			
Moisture Sensor B/Filler	MS-2	Check if ok	✓	✓	✓	✓			
Operational Status of Sample Pumps (2)		Check if ok	✓	✓	✓	✓			
Operational Status of Condensate Drain Pumps (2)		Check if ok	✓	✓	✓	✓			
Check LED status of Sample Cooler		Check if ok	✓	✓	✓	✓			
NH3 Scrubber Drain	HV-4	Drain as needed	✓	✓	✓	✓			
<b>Analyzer Sample Flow Meter Readings</b>			Please enter readings						
System Flow	FM-1	3-5 LPM	4.0	4.3	4.2	4.1			
Oz Analyzer	FM-2	1.2 - 1.7 LPM	1.45	1.6	1.55	1.5			
NOx Analyzer	FM-3	1.2 - 1.7 LPM	1.5	1.5	1.5	1.5			
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.25	1.3	1.3	1.25			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.4	1.35	1.5	1.5			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7							
System Flow	FM-7	3-5 LPM	4.2	4.1	4.2	4.1			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.45	1.45	1.45	1.45			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.35	1.35	1.4	1.35			
NOX Dry Air	FM-10	500-700 CCM	600	600	600	600			
<b>DAHIS Checks</b>									
Check DAHS for normal operation. Is system logging data?			✓	✓	✓	✓			
Check Alarms in DAHS.			✓	✓	✓	✓			
Check chart recorder for normal operation			✓	✓	✓	✓			
Check analyzer calibration drift. Did all calibrations pass?			✓	✓	✓	✓			
Check printer status			✓	✓	✓	✓			
<b>REMARKS:</b>									

Mark as either Acceptable "✓", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator Immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_

**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station**  
**Daily Quality Control/Quality Assurance Plan**  
**Checklist for CEMS Shelter Inspection**

Parameters to Check	Test ID	Limits	Mon	Tue	Wed	Thu	Fri	Sat	Sun
<b>Dates</b>									
Technician's Initial					6/21/18	6/21/18			
Calibration Gas Pressures									
O2/CO High Span, NOX Zero	SV1	> 150 psi			650	650			
NOX Low Span/CO Low Span	SV2	> 150 psi			1100	1120			
NOX High Span, O2/CO Zero	SV3	> 150 psi			1700	1710			
Stack Sample Line									
Sample Line Temperature	TC1	250F			250	250			
Sample NH3 Temperature	TC2	760F			760	760			
Sample Line Pressure/Vacuum	PI-1	6.0 Hg			6.1	6.7			
Sample Line Pressure/Vacuum	PI-2	8.0 Hg			5.7	5.4			
Sample Line Pressure/Vacuum	PI-4	7.5 Hg			6.6	6.6			
Sample Line Pressure	PI-5	8 Psi			7.6	7.4			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)			✓	✓			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)			✓	✓			
<b>Visual Checks</b>									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F			66.5	68.5			
Moisture Sensor A/Filler	MS-1	Clean and dry. If filler shows buildup and flow levels are dropping, replace filter			✓	✓			
Moisture Sensor B/Filler	MS-2	Check if ok			✓	✓			
Operational Status of Sample Pumps (2)		Check if ok			✓	✓			
Operational Status of Condensate Drain Pumps (2)		Check if ok			✓	✓			
Check LED status of Sample Cooler		Check if ok			✓	✓			
NH3 Scrubber Drain	HV-4	Drain as needed			✓	✓			
<b>Analyzer Sample Flow Meter Readings</b>									
System Flow	FM-1	3-5 LPM			4.0	4.1			
O2 Analyzer	FM-2	1.2 - 1.7 LPM			1.45	1.45			
NOx Analyzer	FM-3	1.2 - 1.7 LPM			1.5	1.5			
NOX By-Pass	FM-4	1.2 - 1.7 LPM			1.35	1.35			
CO Analyzer	FM-5	1.2 - 1.7 LPM			1.45	1.45			
Cal Gas Flow (only during Calibration)	FM-6	> 1lbm FM-1 & FM-7			4.1	4.1			
System Flow	FM-7	3-5 LPM			1.45	1.45			
NOX/NH3 Analyzer	FM-8	1.5 LPM			1.75	1.75			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM			5.80	5.80			
NOX Dry Air	FM-10	500-700 CCM							
<b>DAHS Checks</b>									
Check DAHS for normal operation. Is system logging data?					✓	✓			
Check Alarms in DAHS.					✓	✓			
Check chart recorder for normal operation					✓	✓			
Check analyzer calibration drift. Did all calibrations pass?					✓	✓			
Check printer status					✓	✓			
<b>REMARKS:</b>									

Mark as either Acceptable "✓", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_



**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station  
Daily Quality Control/Quality Assurance Plan  
Checklist for CEMS Shelter Inspection**

Parameter to Check	Tag ID	Limits	Min	Max	Unit	ES1	ES2	ES3
<b>Date:</b>								
<b>Technician's Initial</b>								
<b>Calibration Gas Pressures</b>								
O2/CO High Span, NOX Zero	SV1	> 150 psi	600	1050	psi			
NOX Low Span/CO Low Span	SV2	> 150 psi	1050	1050	psi			
NOX High Span, O2/CO Zero	SV3	> 150 psi	1470	1470	psi			
<b>Stack Sample Line</b>								
Sample Line Temperature	TC1	250°F	250	250	°F			
Sample NH3 Temperature -	TC2	780°F	740	740	°F			
Sample Line Pressure/Vacuum	PI-1	6.0"Hg	6.2	6.2	"Hg			
Sample Line Pressure/Vacuum	PI-2	8.0"Hg	5.7	5.7	"Hg			
Sample Line Pressure/Vacuum	PI-4	7.5"Hg	6.6	6.6	"Hg			
Sample Line Pressure	PI-5	8 Psi	7.4	7.4	Psi			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	✓	✓	LPM			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	✓	✓	LPM			
<b>Visual Checks</b>								
Room Enclosure Temperature	Check HVAC controls	72 F (±1.5) F	69.5	68.5	F			
Moisture Sensor A/Filler	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	✓	✓				
Moisture Sensor B/Filler	MS-2	Check if ok	✓	✓				
Operational Status of Condensate Drain Pumps (2)		Check if ok	✓	✓				
Check LED status of Sample Cooler		Check if ok	✓	✓				
NH3 Scrubber Drain	HV-4	Drain as needed	✓	✓				
<b>Analyzer Sample Flow Meter Readings</b>								
System Flow	FM-1	3-5 LPM	4.1	4.1	LPM			
Oz Analyzer	FM-2	1.2 - 1.7 LPM	1.5	1.5	LPM			
NOx Analyzer	FM-3	1.2 - 1.7 LPM	1.5	1.5	LPM			
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.25	1.25	LPM			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.45	1.45	LPM			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	4.1	4.1	LPM			
System Flow	FM-7	3-5 LPM	1.45	1.45	LPM			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.35	1.35	LPM			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	590	590	CCM			
NOX Dry Air	FM-10	500-700 CCM	✓	✓	CCM			
<b>DAHS Checks</b>								
Check DAHS for normal operation. Is system logging data?			✓	✓				
Check Alarms in DAHS.			✓	✓				
Check chart recorder for normal operation			✓	✓				
Check analyzer calibration drift. Did all calibrations pass?			✓	✓				
Check printer status			✓	✓				
<b>REMARKS:</b>								

Mark as either Acceptable "✓", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_

**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station  
Daily Quality Control/Quality Assurance Plan  
Checklist for CEMS Shelter Inspection**

Parameter to Check	Tag ID	Units	Mon	Tue	Wed	Thu	Fri	Sat	Sun
<b>Datas</b>									
Technician's Initial			7/11/17	7/12/17	7/13/17				
Calibration Gas Pressures									
O2/CO High Span, NOX Zero	SV1	> 150 psi	560	570	560				
NOX Low Span/CO Low Span	SV2	> 150 psi	1030	1030	1030				
NOX High Span, O2/CO Zero	SV3	> 150 psi	1630	1660	1660				
Please enter readings and notify the Maintenance Manager when it is time to re-order									
<b>Stack Sample Line</b>									
Sample Line Temperature	TC1	250°F	250	250	250				
Sample NH3 Temperature -	TC2	760°F	760	760	760				
Sample Line Pressure/Vacuum	PI-1	6.0"Hg	6.2	6.2	6.2				
Sample Line Pressure/Vacuum	PI-2	8.0"Hg	8.4	8.2	8.3				
Sample Line Pressure/Vacuum	PI-4	7.5"Hg	6.4	6.4	6.0				
Sample Line Pressure	PI-5	8 Psi	7.4	7.4	7.4				
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	✓	✓	✓				
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	✓	✓	✓				
Please enter readings									
<b>Visual Checks</b>									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	68.5	70.0	69.5				
Moisture Sensor A/Filler	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	✓	✓	✓				
Moisture Sensor B/Filler	MS-2	Check if ok	✓	✓	✓				
Operational Status of Sample Pumps (2)		Check if ok	✓	✓	✓				
Operational Status of Condensate Drain Pumps (2)		Check if ok	✓	✓	✓				
Check LED status of Sample Cooler		Check if ok	✓	✓	✓				
NH3 Scrubber Drain	HV-4	Drain as needed	✓	✓	✓				
<b>Analyzer Sample Flow Meter Readings</b>									
System Flow	FM-1	3-5 LPM	4.1	4.1	4.0				
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.5	1.45	1.45				
NOx Analyzer	FM-3	1.2 - 1.7 LPM	1.5	1.5	1.5				
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.25	1.25	1.25				
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.45	1.5	1.5				
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	4.1	4.1	4.1				
System Flow	FM-7	3-5 LPM	4.1	4.1	4.1				
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.45	1.45	1.45				
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.4	1.4	1.35				
NOX Dry Air	FM-10	500-700 CCM	580	670	590				
<b>DAHS Checks</b>									
Check DAHS for normal operation. Is system logging data?			✓	✓	✓				
Check Alarms in DAHS			✓	✓	✓				
Check chart recorder for normal operation			✓	✓	✓				
Check analyzer calibration drift. Did all calibrations pass?			✓	✓	✓				
Check printer status			✓	✓	✓				
<b>REMARKS:</b>									

Mark as either Acceptable "X", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_

**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station  
Daily Quality Control/Quality Assurance Plan  
Checklist for CEMS Shelter Inspection**

Parameters to Check	Tue	Wed	Thu	Fri	Sat	Sun
Dates						
Technician's Initial	7/15/17					
Calibration Gas Pressures	Please enter readings and notify the Maintenance Manager when it is time to re-order					
O2/CO High Span, NOX Zero	SV1	>150 psi				
NOX Low Span/CO Low Span	SV2	>150 psi				
NOX High Span, O2/CO Zero	SV3	14.10				
Stack Sample Line	Please enter readings					
Sample Line Temperature	TC1	250F				
Sample NH3 Temperature -	TC2	780F				
Sample Line Pressure/Vacuum	PI-1	6.0 Hg				
Sample Line Pressure/Vacuum	PI-2	8.0 Hg				
Sample Line Pressure/Vacuum	PI-4	7.5 Hg				
Sample Line Pressure	PI-5	6.6				
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)				
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)				
Visual Checks						
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F				
Moisture Sensor A/Filter	MS-1	Clean and dry. If filter shows buildup and flow levels are dropping, replace filter				
Moisture Sensor B/Filter	MS-2	Check if ok				
Operational Status of Sample Pumps (2)		Check if ok				
Operational Status of Condensate Drain Pumps (2)		Check if ok				
Check LED status of Sample Cooler		Check if ok				
NH3 Scrubber Drain	HV-4	Drain as needed				
Analyzer Sample Flow Meter Readings	Please enter readings					
System Flow	FM-1	3-5 LPM				
Oz Analyzer	FM-2	12 - 1.7 LPM	3.9			
NOx Analyzer	FM-3	12 - 1.7 LPM	1.45			
NOx By-Pass	FM-4	12 - 1.7 LPM	1.4			
CO Analyzer	FM-5	12 - 1.7 LPM	6.2			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	1.5			
System Flow	FM-7	3-5 LPM	4.7			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.45			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.35			
NOX Dry Air	FM-10	500-700 CCM	650			
DAHIS Checks						
Check DAHS for normal operation. Is system logging data?						
Check Alarms in DAHS						
Check chart recorder for normal operation						
Check analyzer calibration drift. Did all calibrations pass?						
Check printer status						
REMARKS:						

Mark as either Acceptable "-"; Corrective action Required "X"; or Actual Readings, where required  
Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_

**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station  
Daily Quality Control/Quality Assurance Plan  
Checklist for CEMS Shelter Inspection**

Planned to be checked	Tue	Wed	Thu	Fri	Sat	Sun
<b>Dates</b>	7/15/19	7/16/19	7/17/19			
<b>Technician's Initial</b>						
<b>Calibration Gas Pressures</b>						
O2/CO High Span, NOX Zero	570	510	490	470		
NOX Low Span/CO Low Span	970	990	980	980		
NOX High Span, O2/CO Zero	1620	1620	1600	1600		
Please enter readings and notify the Maintenance Manager when it is time to re-order						
<b>Stack Sample Line</b>	Please enter readings					
Sample Line Temperature	250	250	250	250		
Sample NH3 Temperature	760	760	760	760		
Sample Line Pressure/Vacuum	6.1	6.1	6.1	6.1		
Sample Line Pressure/Vacuum	5.4	5.2	5.2	5.3		
Sample Line Pressure/Vacuum	6.6	6.6	6.6	6.6		
Sample Line Pressure	7.4	7.4	7.4	7.4		
Verify Functionality of Sample Pump A Flow Switch	✓	✓	✓	✓		
Verify Functionality of Sample Pump B Flow Switch	✓	✓	✓	✓		
<b>Visual Checks</b>						
Room Enclosure Temperature	68.0	69.5	68.0	68.0		
Moisture Sensor A/Filter	✓	✓	✓	✓		
Moisture Sensor B/Filter	✓	✓	✓	✓		
Operational Status of Sample Pumps (2)	✓	✓	✓	✓		
Operational Status of Condensate Drain Pumps (2)	✓	✓	✓	✓		
Check LED status of Sample Cooler	✓	✓	✓	✓		
NH3 Scrubber Drain	✓	✓	✓	✓		
<b>Analyzer Sample Flow Meter Readings</b>	Please enter readings					
System Flow	4.1	4.0	4.0	4.0		
Oz Analyzer	1.5	1.5	1.45	1.45		
NOx Analyzer	1.5	1.5	1.5	1.5		
NOX By-Pass	1.2	1.25	1.25	1.25		
CO Analyzer	6.5	6.55	6.55	6.55		
Cal Gas Flow (only during Calibration)						
System Flow	4.1	4.1	4.1	4.1		
NOX/NH3 Analyzer	1.45	1.45	1.45	1.45		
NOX/NH3 Analyzer By-Pass	1.4	1.4	1.4	1.4		
NOX Dry Air	6.4	6.4	6.5	6.5		
<b>DAHS Checks</b>						
Check DAHS for normal operation. Is system logging data?	✓	✓	✓	✓		
Check Alarms in DAHS	✓	✓	✓	✓		
Check chart recorder for normal operation	✓	✓	✓	✓		
Check analyzer calibration drift. Did all calibrations pass?	✓	✓	✓	✓		
Check printer status	✓	✓	✓	✓		
<b>REMARKS:</b>						

Mark as either Acceptable "✓", Corrective action Required "X", or Actual Readings, where required  
Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Superv/Isor. Date: \_\_\_\_\_

**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station  
Daily Quality Control/Quality Assurance Plan  
Checklist for CEMS Shelter Inspection**

Parameter to Check	Tag ID	Units	Mon	Tue	Wed	Thu	Fri	Sat	Sun
<b>Dates</b>									
Technician's Initial			7/22/16	7/23/16	7/24/16	7/25/16			
Calibration Gas Pressures									
O2/CO High Span, NOx Zero	SV1	>150 psi	440	380	380	360			
NOx Low Span/CO Low Span	SV2	>150 psi	920	840	840	810			
NOx High Span, O2/CO Zero	SV3	>150 psi	1520	1510	1440	1430			
Stack Sample Line									
Sample Line Temperature	TC1	250F	250	250	250	250			
Sample NH3 Temperature	TC2	760F	760	760	760	760			
Sample Line Pressure/Vacuum	PI-1	6.0 Hg	6.1	6.7	6.1	6.1			
Sample Line Pressure/Vacuum	PI-2	8.0 Hg	5.2	5.0	5.4	5.3			
Sample Line Pressure/Vacuum	PI-4	7.5 Hg	6.6	6.4	6.4	6.6			
Sample Line Pressure	PI-5	8 Psi	7.4	7.4	7.4	7.4			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	✓	✓	✓	✓			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	✓	✓	✓	✓			
<b>Visual Checks</b>									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	69.0	68.0	68.1	70.0			
Moisture Sensor A/Filter	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	✓	✓	✓	✓			
Moisture Sensor B/Filter	MS-2	Check if ok	✓	✓	✓	✓			
Operational Status of Sample Pumps (2)		Check if ok	✓	✓	✓	✓			
Operational Status of Condensate Drain Pumps (2)		Check if ok	✓	✓	✓	✓			
Check LED status of Sample Cooler		Check if ok	✓	✓	✓	✓			
NH3 Scrubber Drain	HV-4	Drain as needed	✓	✓	✓	✓			
<b>Analyzer Sample Flow Meter Readings</b>									
System Flow	FM-1	3-5 LPM	4	4.0	4.0	4.1			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.45	1.45	1.5	1.5			
NOx Analyzer	FM-3	1.2 - 1.7 LPM	1.45	1.45	1.5	1.5			
NOx By-Pass	FM-4	1.2 - 1.7 LPM	1.35	1.2	1.25	1.25			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.5	1.5	1.45	1.55			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	4.1	3.8	4.1	4.1			
System Flow	FM-7	3-5 LPM	4.45	4.45	4.45	4.45			
NOx/NH3 Analyzer	FM-8	1.5 LPM	1.35	1.4	1.35	1.35			
NOx/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.36	1.4	1.35	1.35			
NOx Dry Air	FM-10	500-700 CCM	590	590	580	580			
<b>DAHS Checks</b>									
Check DAHS for normal operation. Is system logging data?			✓	✓	✓	✓			
Check Alarms in DAHS			✓	✓	✓	✓			
Check chart recorder for normal operation			✓	✓	✓	✓			
Check analyzer calibration drift. Did all calibrations pass?			✓	✓	✓	✓			
Check printer status			✓	✓	✓	✓			
<b>REMARKS:</b>									

Mark as either Acceptable "✓", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_



**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station  
Daily Quality Control/Quality Assurance Plan  
Checklist for CEMS Shelter Inspection**

Parameter to Check	Tag ID	Units	Mon	Tue	Wed	Thu	Fri	Sat	Sun
<b>Dates</b>									
Technician's Initial			7/28/19	7/30/19	7/31/19	8/1/19			
Please enter readings and notify the Maintenance Manager when it is time to re-order.									
Calibration Gas Pressures									
O2/CO High Span, NOX Zero	SV1	> 150 psi	3.0	3.0	3.1	14.00			
NOX Low Span/CO Low Span	SV2	> 150 psi	8.0	7.9	7.7	7.5			
NOX High Span, O2/CO Zero	SV3	> 150 psi	14.1	14.0	13.9	13.8			
Stack Sample Line									
Sample Line Temperature	TC1	250°F	25.0	25.0	25.0	25.0			
Sample NH3 Temperature	TC2	760°F	71.0	71.0	71.0	71.0			
Sample Line Pressure/Vacuum	PI-1	6.0 "Hg	6.1	6.3	6.4	6.2			
Sample Line Pressure/Vacuum	PI-2	8.0 "Hg	5.4	5.5	5.7	5.5			
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg	6.4	6.6	6.6	6.6			
Sample Line Pressure	PI-5	8 Psi	7.4	7.4	7.4	7.4			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	✓	✓	✓	✓			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	✓	✓	✓	✓			
<b>Visual Checks</b>									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	67.0	70.0	68.5	67.5			
Moisture Sensor A/Filter	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	✓	✓	✓	✓			
Moisture Sensor B/Filter	MS-2	Check if ok	✓	✓	✓	✓			
Operational Status of Condensate Drain Pumps (2)		Check if ok	✓	✓	✓	✓			
Check LED status of Sample Cooler		Check if ok	✓	✓	✓	✓			
NH3 Scrubber Drain	HV-4	Drain as needed	✓	✓	✓	✓			
<b>Analyzer Sample Flow Meter Readings</b>									
System Flow	FM-1	3-5 LPM	4.0	4.1	4.1	4.1			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.55	1.5	1.5	1.5			
NOx Analyzer	FM-3	1.2 - 1.7 LPM	1.55	1.55	1.55	1.55			
NOx By-Pass	FM-4	1.2 - 1.7 LPM	1.25	1.25	1.25	1.3			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.55	1.6	1.55	1.6			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	4.1	4.1	4.1	3.6			
System Flow	FM-7	3-5 LPM	1.7	1.65	1.65	1.45			
NOx/NH3 Analyzer	FM-8	1.5 LPM	1.6	1.5	1.5	1.35			
NOx/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	5.0	5.0	5.0	5.0			
NOx Dry Air	FM-10	500-700 CCM	✓	✓	✓	✓			
<b>DAHS Checks</b>									
Check DAHS for normal operation. Is system logging data?			✓	✓	✓	✓			
Check Alarms in DAHS.			✓	✓	✓	✓			
Check chart recorder for normal operation			✓	✓	✓	✓			
Check analyzer calibration drift. Did all calibrations pass?			✓	✓	✓	✓			
Check printer status			✓	✓	✓	✓			
<b>REMARKS:</b>									

Mark as either Acceptable "✓", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_

**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station  
Daily Quality Control/Quality Assurance Plan  
Checklist for CEMS Shelter Inspection**

Parameters to Check	Tag ID	Limits	Mon	Tue	Wed	THU	Fri	Sat	Sun
Dates			5/5/19	5/6/19	5/7/19	5/8/19			
Technician's Initial			SS	SS	SS	SS			
Calibration Gas Pressures									
O2/CO High Span, NOX Zero	SV1	>150 psi	1400	1400	1400	1400			
NOX Low Span/CO Low Span	SV2	>150 psi	700	690	670	670			
NOX High Span, O2/CO Zero	SV3	>150 psi	1310	1290	1300	1210			
Stack Sample Line			Please enter readings						
Sample Line Temperature	TC1	250°F	250	250	250	250			
Sample NH3 Temperature	TC2	760°F	760	760	760	760			
Sample Line Pressure/Vacuum	PI-1	6.0 Hg	6.5	6.4	6.4	6.4			
Sample Line Pressure/Vacuum	PI-2	8.0 Hg	5.4	5.4	5.4	5.5			
Sample Line Pressure/Vacuum	PI-4	7.5 Hg	6.6	6.6	6.6	6.6			
Sample Line Pressure	PI-5	8 Psi	5.9	5.9	5.9	6.0			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	✓	✓	✓	✓			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	✓	✓	✓	✓			
Visual Checks									
Room Enclosure Temperature	Check HVAC controls	72 F (±5) F	68.5	76.0	65.5	68.5			
Moisture Sensor A/Filter	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	✓	✓	✓	✓			
Moisture Sensor B/Filter	MS-2	flow levels are dropping, replace filter	✓	✓	✓	✓			
Operational Status of Sample Pumps (2)		Check if ok	✓	✓	✓	✓			
Operational Status of Condensate Drain Pumps (2)		Check if ok	✓	✓	✓	✓			
Check LED status of Sample Cooler		Check if ok	✓	✓	✓	✓			
NH3 Scrubber Drain	HV-4	Drain as needed	✓	✓	✓	✓			
Analyzer Sample Flow Meter Readings			Please enter readings						
System Flow	FM-1	3-5 LPM	4.2	4.2	4.2	4.2			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.5	1.4	1.5	1.5			
NOx Analyzer	FM-3	1.2 - 1.7 LPM	1.55	1.55	1.55	1.55			
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.3	1.3	1.3	1.3			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.55	1.6	1.6	1.6			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7							
System Flow	FM-7	3-5 LPM	4.5	4.5	4.5	4.5			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.45	1.45	1.45	1.45			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.35	1.35	1.35	1.35			
NOX Dry Air	FM-10	500-700 CCM	650	650	650	650			
DAHs Checks									
Check DAHS for normal operation. Is system logging data?			✓	✓	✓	✓			
Check Alarms in DAHS			✓	✓	✓	✓			
Check chart recorder for normal operation			✓	✓	✓	✓			
Check analyzer calibration drift. Did all calibrations pass?			✓	✓	✓	✓			
Check printer status			✓	✓	✓	✓			
REMARKS:									

Mark as either Acceptable "✓", Corrective action Required "X", or Actual Readings, where required  
Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_



**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station**  
**Daily Quality Control/Quality Assurance Plan**  
**Checklist for CEMS Shelter Inspection**

Parameters to Check	Test ID	Limits	Mon	Tue	Wed	Thu	Fri	Sat	Sun
<p><b>Dates</b>            Technician's Initial: <u>                    </u>            Calibration Gas Pressures: <u>                    </u>            O2/CO High Span, NOX Zero: <u>                    </u>            NOX Low Span/CO Low Span: <u>                    </u>            NOX High Span, O2/CO Zero: <u>                    </u></p>									
Stack Sample Line	SV1	> 150 psi	18.10	17.80	17.30	11.80	11.80	11.70	
Sample Line Temperature	TC1	250°F	250	250	250	250	250	250	
Sample NH3 Temperature	TC2	760°F	740	740	740	740	740	740	
Sample Line Pressure/Vacuum	PI-1	6.0" Hg	6.4	6.4	6.4	6.4	6.4	6.4	
Sample Line Pressure/Vacuum	PI-2	8.0" Hg	5.0	5.5	5.5	5.6	5.6	5.6	
Sample Line Pressure/Vacuum	PI-4	7.5" Hg	6.3	6.6	6.6	6.6	6.6	6.6	
Sample Line Pressure	PI-5	8 Psi	5.8	6.0	6.0	6.0	6.0	6.0	
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	✓	✓	✓	✓	✓	✓	
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	✓	✓	✓	✓	✓	✓	
<p align="center">Please enter readings</p>									
<b>Visual Checks</b>	Check HVAC controls	72 F (+/-5) F	70.0	70.0	69.5	68.0	68.0	68.0	
Room Enclosure Temperature	MS-1	Clean and dry. If filter shows buildup and flow levels are dropping, replace filter	✓	✓	✓	✓	✓	✓	
Moisture Sensor A/Filter	MS-2	Check if ok	✓	✓	✓	✓	✓	✓	
Moisture Sensor B/Filter	MS-2	Check if ok	✓	✓	✓	✓	✓	✓	
Operational Status of Sample Pumps (2)	MS-2	Check if ok	✓	✓	✓	✓	✓	✓	
Operational Status of Condensate Drain Pumps (2)	MS-2	Check if ok	✓	✓	✓	✓	✓	✓	
Check LED status of Sample Cooler	MS-2	Check if ok	✓	✓	✓	✓	✓	✓	
NH3 Scrubber Drain	HV-4	Drain as needed	✓	✓	✓	✓	✓	✓	
<p align="center">Please enter readings</p>									
<b>Analyzer Sample Flow Meter Readings</b>	FM-1	3-5 LPM	4.0	4.2	4.2	4.1	4.1	4.1	
System Flow	FM-2	1.2 - 1.7 LPM	1.45	1.5	1.5	1.5	1.5	1.5	
O2 Analyzer	FM-3	1.2 - 1.7 LPM	1.5	1.55	1.55	1.55	1.55	1.55	
NOX Analyzer	FM-4	1.2 - 1.7 LPM	1.3	1.3	1.3	1.3	1.3	1.3	
NOX By-Pass	FM-5	1.2 - 1.7 LPM	1.55	1.6	1.6	1.55	1.55	1.55	
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.55	1.6	1.6	1.55	1.55	1.55	
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	4.2	4.5	4.5	4.5	4.5	4.5	
System Flow	FM-7	3-5 LPM	4.2	4.5	4.5	4.5	4.5	4.5	
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.4	1.45	1.45	1.45	1.45	1.45	
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.35	1.35	1.35	1.35	1.35	1.35	
NOX Dry Air	FM-10	500-700 CCM	650	650	650	650	650	650	
<p align="center">Please enter readings</p>									
<b>DAHS Checks</b>	DAHS Checks		✓	✓	✓	✓	✓	✓	
Check DAHS for normal operation. Is system logging data?			✓	✓	✓	✓	✓	✓	
Check Alarms in DAHS.			✓	✓	✓	✓	✓	✓	
Check chart recorder for normal operation			✓	✓	✓	✓	✓	✓	
Check analyzer calibration drift. Did all calibrations pass?			✓	✓	✓	✓	✓	✓	
Check printer status			✓	✓	✓	✓	✓	✓	
<p><b>REMARKS:</b></p>									

Mark as either Acceptable "✓", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_

**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station**  
**Daily Quality Control/Quality Assurance Plan**  
**Checklist for CEMS Shelter Inspection**

Parameter to Check	Tag ID	Units	Mon	Tue	Wed	THU	Fri	Sat	Sun
<b>Dates</b>									
Technician's Initial					9/21/19	8/22/19			
Calibration Gas Pressures					50				
O2/CO High Span, NOX Zero	SV1	>150 psi				1540	1510		
NOX Low Span/CO Low Span	SV2	>150 psi			480	480			
NOX High Span, O2/CO Zero	SV3	>150 psi			1090	1090			
<b>Stack Sample Line</b>									
Sample Line Temperature	TC1	250°F			750	750			
Sample NH3 Temperature	TC2	760°F			710	710			
Sample Line Pressure/Vacuum	PI-1	6.0 "Hg			6.6	6.6			
Sample Line Pressure/Vacuum	PI-2	8.0 "Hg			5.5	5.5			
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg			6.6	6.6			
Sample Line Pressure	PI-5	8 Psi			5.9	5.9			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)			✓	✓			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)			✓	✓			
<b>Visual Checks</b>									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F			67.5	68.0			
Moisture Sensor A/Filter	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter			✓	✓			
Moisture Sensor B/Filter	MS-2	Check if ok			✓	✓			
Operational Status of Sample Pumps (2)		Check if ok			✓	✓			
Operational Status of Condensate Drain Pumps (2)		Check if ok			✓	✓			
Check LED status of Sample Cooler		Check if ok			✓	✓			
NH3 Scubber Drain	HV-4	Drain as needed			✓	✓			
<b>Analyzer Sample Flow Meter Readings</b>									
System Flow	FM-1	3-5 LPM			4.2	4.2			
O2 Analyzer	FM-2	1.2 - 1.7 LPM			1.55	1.5			
NOx Analyzer	FM-3	1.2 - 1.7 LPM			1.55	1.55			
NOX By-Pass	FM-4	1.2 - 1.7 LPM			1.2	1.3			
CO Analyzer	FM-5	1.2 - 1.7 LPM			1.2	1.6			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7			4.5	4.5			
System Flow	FM-7	3-5 LPM			1.45	1.55			
NOX/NH3 Analyzer	FM-8	1.5 LPM			1.35	1.35			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM			6.00	6.00			
NOX Dry Air	FM-10	500-700 CCM			✓	✓			
<b>DAHIS Checks</b>									
Check DAHS for normal operation. Is system logging data?					✓	✓			
Check Alarms in DAHS.					✓	✓			
Check chart recorder for normal operation					✓	✓			
Check analyzer calibration drift. Did all calibrations pass?					✓	✓			
Check printer status					✓	✓			
<b>REMARKS:</b>									

Mark as either Acceptable "✓", Corrective action Required "X", or Actual Readings, where required

Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_

**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station  
Daily Quality Control/Quality Assurance Plan  
Checklist for CEMS Shelter Inspection**

Parameters to Check	Tag ID	Units	Mon	Tue	Wed	Thu	Fri	Sat	Sun
<b>Dates</b>									
Technician's Initial			8/26/19	9/27/19	9/28/19	9/29/19	8/29/19		
Please enter readings and notify the Maintenance Manager when it is time to re-order.									
Calibration Gas Pressures									
O2/CO High Span, NOX Zero	SV1	>150 psi	1470	1460	1580	1500			
NOX Low Span/CO Low Span	SV2	>150 psi	310	300	310	310			
NOX High Span, O2/CO Zero	SV3	>150 psi	1030	1030	1030	1030			
Please enter readings									
Stack Sample Line									
Sample Line Temperature	TC1	250F	250	250	250	250			
Sample NH3 Temperature	TC2	760F	760	760	760	760			
Sample Line Pressure/Vacuum	PI-1	6.0 Hg	6.7	6.7	6.5	6.4			
Sample Line Pressure/Vacuum	PI-2	8.0 Hg	5.4	5.4	5.5	5.5			
Sample Line Pressure/Vacuum	PI-4	7.5 Hg	6.6	6.6	6.6	6.6			
Sample Line Pressure	PI-5	8 Psi	5.9	5.9	6.0	6.0			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	✓	✓	✓	✓			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	✓	✓	✓	✓			
<b>Visual Checks</b>									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	69.5	69.5	70.0	68.5			
Moisture Sensor AF Filter	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	✓	✓	✓	✓			
Moisture Sensor BF Filter	MS-2	Check if ok	✓	✓	✓	✓			
Operational Status of Sample Pumps (2)		Check if ok	✓	✓	✓	✓			
Operational Status of Condensate Drain Pumps (2)		Check if ok	✓	✓	✓	✓			
Check LED status of Sample Cooler		Check if ok	✓	✓	✓	✓			
NH3 Scrubber Drain	HV-4	Drain as needed	✓	✓	✓	✓			
<b>Analyzer Sample Flow Meter Readings</b>									
Please enter readings									
System Flow	FM-1	3-5 LPM	4.2	4.2	4.7	4.1			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.5	1.5	1.5	1.5			
NOx Analyzer	FM-3	1.2 - 1.7 LPM	1.55	1.55	1.55	1.55			
NOx By-Pass	FM-4	1.2 - 1.7 LPM	1.3	1.3	1.3	1.3			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.55	1.6	1.6	1.65			
Cal Gas Flow (only during Calibration)	FM-6	> (than FM-1 & FM-7)	4.4	4.5	4.5	4.5			
System Flow	FM-7	3-5 LPM	4.4	4.5	4.5	4.5			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.4	1.45	1.45	1.45			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.35	1.35	1.35	1.35			
NOX Dry Air	FM-10	500-700 CCM	590	550	590	590			
<b>DAHS Checks</b>									
Check DAHS for normal operation. Is system logging data?			✓	✓	✓	✓			
Check Alarms in DAHS			✓	✓	✓	✓			
Check chart recorder for normal operation			✓	✓	✓	✓			
Check analyzer calibration drift. Did all calibrations pass?			✓	✓	✓	✓			
Check printer status			✓	✓	✓	✓			
<b>REMARKS:</b>									

Mark as either Acceptable "✓", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_

**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station**  
**Daily Quality Control/Quality Assurance Plan**  
**Checklist for CEMS Shelter Inspection**

Parameters to Check	Tag ID	Limits	Mon	Tue	Wed	Thu	Fri	Sat	Sun
<b>Dates</b> Technician's Initial: <u>9/19/19</u> <u>9/19/19</u> <u>9/19/19</u>									
Calibration Gas Pressures O2/CO High Span, NOX Zero: <u>1300</u> <u>1300</u> <u>1300</u> <u>1340</u> <u>1340</u> <u>1340</u>									
NOX Low Span/CO Low Span: <u>300</u> <u>300</u> <u>300</u> <u>300</u> <u>300</u> <u>300</u>									
NOX High Span, O2/CO Zero: <u>980</u> <u>980</u> <u>980</u> <u>980</u> <u>980</u> <u>980</u>									
<b>Stack Sample Line</b> Please enter readings and notify the Maintenance Manager when it is time to re-order.									
Sample Line Temperature	TC1	250°F	<u>250</u>	<u>250</u>	<u>250</u>	<u>250</u>	<u>250</u>	<u>250</u>	<u>250</u>
Sample NH3 Temperature	TC2	760°F	<u>760</u>	<u>760</u>	<u>760</u>	<u>760</u>	<u>760</u>	<u>760</u>	<u>760</u>
Sample Line Pressure/Vacuum	PI-1	6.0" Hg	<u>6.5</u>	<u>6.5</u>	<u>6.6</u>	<u>6.5</u>	<u>6.5</u>	<u>6.5</u>	<u>6.5</u>
Sample Line Pressure/Vacuum	PI-2	8.0" Hg	<u>5.4</u>	<u>5.4</u>	<u>5.4</u>	<u>5.0</u>	<u>5.0</u>	<u>5.0</u>	<u>5.0</u>
Sample Line Pressure/Vacuum	PI-4	7.5" Hg	<u>6.6</u>	<u>6.6</u>	<u>6.6</u>	<u>6.8</u>	<u>6.8</u>	<u>6.8</u>	<u>6.8</u>
Sample Line Pressure	PI-5	8 Psi	<u>6.0</u>	<u>6.0</u>	<u>6.0</u>	<u>5.9</u>	<u>5.9</u>	<u>5.9</u>	<u>5.9</u>
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>
<b>Visual Checks</b> Room Enclosure Temperature: <u>72 F (+/- 5) F</u>									
Moisture Sensor A/Filter	MS-1	Clean and dry. If filter shows buildup and flow levels are dropping, replace filter	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>
Moisture Sensor B/Filter	MS-2	flow levels are dropping, replace filter	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>
Operational Status of Sample Pumps (2)		Check if ok	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>
Operational Status of Condensate Drain Pumps (2)		Check if ok	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>
Check LED status of Sample Cooler		Check if ok	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>
NH3 Scrubber Drain	HV-4	Drain as needed	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>
<b>Analyzer Sample Flow Meter Readings</b> Please enter readings									
System Flow	FM-1	3-5 LPM	<u>4.2</u>	<u>4.2</u>	<u>4.2</u>	<u>4.0</u>	<u>4.0</u>	<u>4.0</u>	<u>4.0</u>
O2 Analyzer	FM-2	1.2 - 1.7 LPM	<u>1.5</u>	<u>1.5</u>	<u>1.5</u>	<u>1.5</u>	<u>1.5</u>	<u>1.5</u>	<u>1.5</u>
NOx Analyzer	FM-3	1.2 - 1.7 LPM	<u>1.55</u>	<u>1.55</u>	<u>1.55</u>	<u>1.5</u>	<u>1.5</u>	<u>1.5</u>	<u>1.5</u>
NOX By-Pass	FM-4	1.2 - 1.7 LPM	<u>1.3</u>	<u>1.3</u>	<u>1.3</u>	<u>1.3</u>	<u>1.3</u>	<u>1.3</u>	<u>1.3</u>
CO Analyzer	FM-5	1.2 - 1.7 LPM	<u>1.6</u>	<u>1.6</u>	<u>1.6</u>	<u>1.6</u>	<u>1.6</u>	<u>1.6</u>	<u>1.6</u>
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	<u>4.4</u>	<u>4.4</u>	<u>4.4</u>	<u>4.2</u>	<u>4.2</u>	<u>4.2</u>	<u>4.2</u>
System Flow	FM-7	3-5 LPM	<u>1.4</u>	<u>1.4</u>	<u>1.4</u>	<u>1.45</u>	<u>1.45</u>	<u>1.45</u>	<u>1.45</u>
NOX/NH3 Analyzer	FM-8	1.5 LPM	<u>1.35</u>	<u>1.35</u>	<u>1.35</u>	<u>1.35</u>	<u>1.35</u>	<u>1.35</u>	<u>1.35</u>
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	<u>5.80</u>	<u>5.80</u>	<u>5.80</u>	<u>6.50</u>	<u>6.50</u>	<u>6.50</u>	<u>6.50</u>
NOX Dry Air	FM-10	500-700 CCM	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>
<b>DAHIS Checks</b> Check DAHS for normal operation. Is system logging data? <u>✓</u>									
Check Alarms in DAHS <u>✓</u>									
Check chart recorder for normal operation <u>✓</u>									
Check analyzer calibration dnt. Did all calibrations pass? <u>✓</u>									
Check printer status <u>✓</u>									
<b>REMARKS:</b> _____ _____ _____									

Mark as either Acceptable "✓", Corrective action Required "X", or Actual Readings, where required.  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_

**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station  
Daily Quality Control/Quality Assurance Plan  
Checklist for CEMS Shelter Inspection**

Parameters to Check	Tag ID	Limits	Mon	Tue	Wed	Thu	Fri	Sat	Sun
Dates			9/19/19	9/20/19	9/21/19	9/22/19			
Technician's Initial									
Calibration Gas Pressures									
O2/CO High Span, NOX Zero	SV1	>150 psi	116.0	118.0	117.0	120.0			
NOX Low Span/CO Low Span	SV2	>150 psi	174.0	173.0	173.0	174.0			
NOX High Span, O2/CO Zero	SV3	>150 psi	84.0	83.0	83.0	84.0			
Stack Sample Line			Please enter readings.						
Sample Line Temperature	TC1	250°F	250	250	250	250			
Sample NH3 Temperature -	TC2	760°F	76.0	74.0	76.0	76.0			
Sample Line Pressure/Vacuum	PI-1	6.0"Hg	6.8	6.6	6.6	6.5			
Sample Line Pressure/Vacuum	PI-2	8.0"Hg	5.5	5.5	5.1	5.6			
Sample Line Pressure/Vacuum	PI-4	7.5"Hg	6.6	6.6	6.6	6.6			
Sample Line Pressure	PI-5	8 psi	5.4	5.9	6.0	6.0			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	✓	✓	✓	✓			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	✓	✓	✓	✓			
Visual Checks									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	69.5	69.0	68.0	70.0			
Moisture Sensor A/Filter	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	✓	✓	✓	✓			
Moisture Sensor B/Filter	MS-2	Check if ok	✓	✓	✓	✓			
Operational Status of Sample Pumps (2)		Check if ok	✓	✓	✓	✓			
Operational Status of Condensate Drain Pumps (2)		Check if ok	✓	✓	✓	✓			
Check LED status of Sample Cooler		Check if ok	✓	✓	✓	✓			
NH3 Scrubber Drain	HV-4	Drain as needed	✓	✓	✓	✓			
Analyzer Sample Flow Meter Readings			Please enter readings						
System Flow	FM-1	3-5 LPM	6.2	4.7	4.2	4.2			
O2 Analyzer	FM-2	12 - 17 LPM	1.55	1.5	1.55	1.55			
NOx Analyzer	FM-3	12 - 17 LPM	1.55	1.55	1.35	1.55			
NOX By-Pass	FM-4	12 - 17 LPM	1.3	1.3	1.3	1.3			
CO Analyzer	FM-5	12 - 17 LPM	1.6	1.6	1.65	1.65			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	4.4	4.4	4.4	4.4			
System Flow	FM-7	3-5 LPM	4.4	4.4	4.4	4.4			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.95	1.45	1.45	1.45			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.35	1.35	1.35	1.35			
NOX Dry Air	FM-10	500-700 CCM	6.50	6.50	6.50	6.50			
DAHs Checks			✓	✓	✓	✓			
Check DAHS for normal operation. Is system logging data?			✓	✓	✓	✓			
Check Alarms in DAHS.			✓	✓	✓	✓			
Check chart recorder for normal operation			✓	✓	✓	✓			
Check analyzer calibration drift. Did all calibrations pass?			✓	✓	✓	✓			
Check printer status			✓	✓	✓	✓			
REMARKS:									

Mark as either Acceptable "✓", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_



**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station  
Daily Quality Control/Quality Assurance Plan  
Checklist for CEMS Shelter Inspection**

Parameters to Check	Tue	Wed	Thu	Fri	Sat	Sun
<b>Data</b>						
Technician's Initial	9/18/19	9/18/19	9/19/19			
Calibration Gas Pressures						
O2/CO High Span, NOX Zero	1150	1130	1100			
NOX Low Span/CO Low Span	740	730	710			
NOX High Span, O2/CO Zero	820	820	810			
<b>Stack Sample Line</b>						
Sample Line Temperature	250	250	250			
Sample NH3 Temperature	760	760	760			
Sample Line Pressure/Vacuum	6.6	6.6	6.7			
Sample Line Pressure/Vacuum	5.6	5.5	5.5			
Sample Line Pressure/Vacuum	6.6	6.6	6.6			
Sample Line Pressure	6.0	5.9	5.4			
Verify Functionality of Sample Pump A Flow Switch	✓	✓	✓			
Verify Functionality of Sample Pump B Flow Switch	✓	✓	✓			
<b>Visual Checks</b>						
Room Enclosure Temperature	68.0	69.5	70.0	69.5		
Moisture Sensor A/Filter	✓	✓	✓	✓		
Moisture Sensor B/Filter	✓	✓	✓	✓		
Operational Status of Sample Pumps (2)	✓	✓	✓	✓		
Operational Status of Condensate Drain Pumps (2)	✓	✓	✓	✓		
Check LED status of Sample Cooler	✓	✓	✓	✓		
NH3 Scrubber Drain	✓	✓	✓	✓		
<b>Analyzer Sample Flow Meter Readings</b>						
System Flow	4.2	4.3	4.2	4.2		
O2 Analyzer	1.55	1.55	1.55	1.55		
NOx Analyzer	1.55	1.55	1.55	1.55		
NOX By-Pass	1.3	1.3	1.3	1.3		
CO Analyzer	1.65	1.65	1.65	1.65		
Cal Gas Flow (only during Calibration)						
System Flow	4.5	4.5	4.5	4.5		
NOX/NH3 Analyzer	1.65	1.65	1.65	1.65		
NOX/NH3 Analyzer By-Pass	1.35	1.35	1.35	1.35		
NOX Dry Air	6.0	6.0	6.0	6.0		
<b>DAHS Checks</b>						
Check DAHS for normal operation. Is system logging data?	✓	✓	✓	✓		
Check Alarms in DAHS	✓	✓	✓	✓		
Check chart recorder for normal operation	✓	✓	✓	✓		
Check analyzer calibration drift. Did all calibrations pass?	✓	✓	✓	✓		
Check printer status	✓	✓	✓	✓		
<b>REMARKS:</b>						

Mark as either Acceptable "✓", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.  
 Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_

**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station  
Daily Quality Control/Quality Assurance Plan  
Checklist for CEMS Shelter Inspection**

Parameters to Check	Tag ID	Limits	Mon	Tue	Wed	Thu	Fri	Sat	Sun
<b>Dates</b>									
Technician's Initial			9/23/19	9/24/19	9/25/19	9/26/19			
Please enter readings and notify the Maintenance Manager when it is time to re-order.									
Calibration Gas Pressures									
OZICO High Span, NOX Zero	SV1	> 150 psi	1020	1010	1020	1010			
NOX Low Span/CO Low Span	SV2	> 150 psi	1580	1600	1590	1580			
NOX High Span, OZICO Zero	SV3	> 150 psi	740	760	760	740			
Stack Sample Line									
Sample Line Temperature	TC1	250F	250	250	250	250			
Sample NH3 Temperature	TC2	760F	760	760	760	760			
Sample Line Pressure/Vacuum	PI-1	6.0 Hg	6.7	6.7	6.7	6.7			
Sample Line Pressure/Vacuum	PI-2	8.0 Hg	5.6	5.6	5.4	5.5			
Sample Line Pressure/Vacuum	PI-4	7.5 Hg	6.6	6.6	6.6	6.6			
Sample Line Pressure	PI-5	8 Psi	5.9	5.9	5.9	5.9			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	✓	✓	✓	✓			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	✓	✓	✓	✓			
<b>Visual Checks</b>									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	69.5	69.5	69.0	70.0			
Moisture Sensor A/Filter	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	✓	✓	✓	✓			
Moisture Sensor B/Filter	MS-2	Check if ok	✓	✓	✓	✓			
Operational Status of Sample Pumps (2)		Check if ok	✓	✓	✓	✓			
Operational Status of Condensate Drain Pumps (2)		Check if ok	✓	✓	✓	✓			
Check LED status of Sample Cooler		Check if ok	✓	✓	✓	✓			
NH3 Scrubber Drain	HV-4	Drain as needed	✓	✓	✓	✓			
<b>Analyzer Sample Flow Meter Readings</b>									
System Flow	FM-1	3-5 LPM	4.2	4.7	4.2	4.2			
O <sub>2</sub> Analyzer	FM-2	1.2 - 1.7 LPM	1.55	1.65	1.5	1.55			
NO <sub>x</sub> Analyzer	FM-3	1.2 - 1.7 LPM	1.55	1.65	1.55	1.6			
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.3	1.3	1.3	1.3			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.6	1.65	1.6	1.65			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	4.5	4.5	4.5	4.5			
System Flow	FM-7	3-5 LPM	4.5	4.5	4.5	4.5			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.45	1.45	1.4	1.45			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.35	1.35	1.35	1.35			
NOX Dry Air	FM-10	500-700 CCM	590	590	580	580			
<b>DAHs Checks</b>									
Check DAHS for normal operation. Is system logging data?			✓	✓	✓	✓			
Check Alarms in DAHS.			✓	✓	✓	✓			
Check chart recorder for normal operation			✓	✓	✓	✓			
Check analyzer calibration drift. Did all calibrations pass?			✓	✓	✓	✓			
Check printer status			✓	✓	✓	✓			
<b>REMARKS:</b>									

Mark as either Acceptable "✓", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.  
 Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_



**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station  
Daily Quality Control/Quality Assurance Plan  
Checklist for CEMS Shelter Inspection**

Parameter to Check	Tag ID	Units	Mon	Tue	Wed	Thu	Fri	Sat	Sun
Dates			9/20/19	10/1/19	10/17/19	10/31/19			
Technician's Initial									
Calibration Gas Pressures									
O2/CO High Span, NOX Zero	SV1	>150 psi	980	970	940	980			
NOX Low Span/CO Low Span	SV2	>150 psi	1580	1580	1480	1430			
NOX High Span, O2/CO Zero	SV3	>150 psi	720	730	610	690			
Stack Sample Line									
Sample Line Temperature	TC1	250F	250	250	250	250			
Sample NH3 Temperature	TC2	760F	760	760	760	760			
Sample Line Pressure/Vacuum	PI-1	6.0"Hg	6.7	6.7	6.6	6.7			
Sample Line Pressure/Vacuum	PI-2	8.0"Hg	5.6	5.6	5.6	5.6			
Sample Line Pressure/Vacuum	PI-4	7.5"Hg	6.6	6.6	6.6	6.6			
Sample Line Pressure	PI-5	8 Psi	5.9	5.9	5.9	5.9			
Vent Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	✓	✓	✓	✓			
Vent Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	✓	✓	✓	✓			
Visual Checks									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	69.0	68.0	69.5	69.0			
Moisture Sensor A/Filter	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	✓	✓	✓	✓			
Moisture Sensor B/Filter	MS-2	Check if ok	✓	✓	✓	✓			
Operational Status of Sample Pumps (2)		Check if ok	✓	✓	✓	✓			
Operational Status of Condensate Drain Pumps (2)		Check if ok	✓	✓	✓	✓			
Check LED status of Sample Cooler		Check if ok	✓	✓	✓	✓			
NH3 Scrubber Drain	HV-4	Drain as needed	✓	✓	✓	✓			
Analyzer Sample Flow Meter Readings									
System Flow	FM-1	3-5 LPM	4.7	4.7	4.7	4.7			
O2 Analyzer	FM-2	1.2-1.7 LPM	1.55	1.55	1.55	1.55			
NOx Analyzer	FM-3	1.2-1.7 LPM	1.6	1.6	1.6	1.6			
NOX By-Pass	FM-4	1.2-1.7 LPM	1.3	1.3	1.3	1.3			
CO Analyzer	FM-5	1.2-1.7 LPM	1.6	1.65	1.65	1.6			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	4.5	4.5	4.5	4.5			
System Flow	FM-7	3-5 LPM	1.45	1.45	1.45	1.45			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.35	1.35	1.35	1.35			
NOX/NH3 Analyzer By-Pass	FM-9	1.2-1.5 LPM	1.35	1.35	1.35	1.35			
NOX Dry Air	FM-10	500-700 CCM	650	650	650	650			
DAHS Checks									
Check DAHS for normal operation, is system logging data?			✓	✓	✓	✓			
Check Alarms in DAHS			✓	✓	✓	✓			
Check chart recorder for normal operation			✓	✓	✓	✓			
Check analyzer calibration drift. Did all calibrations pass?			✓	✓	✓	✓			
Check printer status			✓	✓	✓	✓			
REMARKS:									
Please enter readings and notify the Maintenance Manager when it is time to re-order									

Mark as either Acceptable "✓", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book

Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_

**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station  
Daily Quality Control/Quality Assurance Plan  
Checklist for CEMS Shelter Inspection**

Parameters to Check	Tue	Wed	Thu	Fri	Sat	Sun
<b>Dates</b>	10/7/19	10/8/19	10/9/19	10/10/19		
Technician's Initial	SD	SD	SD	SD		
Calibration Gas Pressures	Please enter readings and notify the Maintenance Manager when it is time to re-order					
O2CO High Span, NOX Zero	82.0	78.0	76.0	80.0		
NOX Low Span/CO Low Span	133.0	130.0	130.0	134.0		
NOX High Span, O2CO Zero	63.0	61.0	59.0	67.0		
<b>Stack Sample Line</b>	Please enter readings					
Sample Line Temperature	25.0	25.0	25.0	25.0		
Sample NH3 Temperature	76.0	76.0	76.0	76.0		
Sample Line Pressure/Vacuum	6.6	6.9	6.3	6.4		
Sample Line Pressure/Vacuum	5.6	5.5	5.5	5.6		
Sample Line Pressure/Vacuum	6.6	6.6	6.6	6.6		
Sample Line Pressure	6.0	5.9	5.9	6.2		
Verify Functionality of Sample Pump A Flow Switch	✓	✓	✓	✓		
Verify Functionality of Sample Pump B Flow Switch	✓	✓	✓	✓		
<b>Visual Checks</b>						
Room Enclosure Temperature	69.5	70.0	70.0	67.5		
Check HVAC controls	✓	✓	✓	✓		
Moisture Sensor A/Filler	✓	✓	✓	✓		
Moisture Sensor B/Filter	✓	✓	✓	✓		
Operational Status of Sample Pumps (2)	✓	✓	✓	✓		
Operational Status of Condensate Drain Pumps (2)	✓	✓	✓	✓		
Check LED status of Sample Cooler	✓	✓	✓	✓		
NH3 Scrubber Drain	✓	✓	✓	✓		
<b>Analyzer Sample Flow Meter Readings</b>	Please enter readings					
System Flow	4.2	4.2	4.2	4.2		
O2 Analyzer	1.55	1.55	1.55	1.55		
NOx Analyzer	1.6	1.6	1.6	1.6		
NOX By-Pass	1.3	1.3	1.3	1.3		
CO Analyzer	1.6	1.6	1.6	1.6		
Cal Gas Flow (only during Calibration)	4.5	4.5	4.5	4.5		
System Flow	1.45	1.45	1.45	1.45		
NOX/NH3 Analyzer	1.35	1.35	1.35	1.35		
NOX/NH3 Analyzer By-Pass	6.2	6.1	6.1	6.0		
NOX Dry Air						
<b>DAHS Checks</b>						
Check DAHS for normal operation. Is system logging data?	✓	✓	✓	✓		
Check Alarms in DAHS	✓	✓	✓	✓		
Check chart recorder for normal operation	✓	✓	✓	✓		
Check analyzer calibration dnt. Did all calibrations pass?	✓	✓	✓	✓		
Check printer status	✓	✓	✓	✓		
<b>REMARKS:</b>						

Mark as either Acceptable "✓", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_

**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station  
Daily Quality Control/Quality Assurance Plan  
Checklist for CEMS Shelter Inspection**

Parameters to Check	Tag ID	Limits	Mon	Tue	Wed	Thu	Fri	Sat	Sun
<b>Dates</b>									
Technician's Initial			10/14/19	10/15/19	10/16/19	10/17/19			
Please enter readings and notify the Maintenance Manager when it is time to re-order									
Calibration Gas Pressures									
O2/CO High Span, NOX Zero	SV1	> 150 psi	750	710	170	170			
NOX Low Span/CO Low Span	SV2	> 150 psi	1300	1750	1730	1710			
NOX High Span, O2/CO Zero	SV3	> 150 psi	600	580	520	520			
Stack Sample Line									
Sample Line Temperature	TC1	250F	750	750	750	750			
Sample NH3 Temperature	TC2	760F	760	760	760	760			
Sample Line Pressure/Vacuum	PI-1	6.0 Hg	6.6	6.7	6.6	6.7			
Sample Line Pressure/Vacuum	PI-2	8.0 Hg	5.6	5.6	5.6	5.4			
Sample Line Pressure/Vacuum	PI-4	7.5 Hg	6.6	6.6	6.6	6.6			
Sample Line Pressure	PI-5	8 Psi	6.1	6.1	6.0	6.0			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	✓	✓	✓	✓			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	✓	✓	✓	✓			
<b>Visual Checks</b>									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	68.5	67.2	69.0	67.5			
Moisture Sensor A/Filter	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	✓	✓	✓	✓			
Moisture Sensor B/Filter	MS-2	Check if ok	✓	✓	✓	✓			
Operational Status of Sample Pumps (2)		Check if ok	✓	✓	✓	✓			
Operational Status of Condensate Drain Pumps (2)		Check if ok	✓	✓	✓	✓			
Check LED status of Sample Cooler		Check if ok	✓	✓	✓	✓			
NH3 Scrubber Drain	HV-4	Drain as needed	✓	✓	✓	✓			
<b>Analyzer Sample Flow Meter Readings</b>									
System Flow	FM-1	3-5 LPM	4.7	4.7	4.3	4.3			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.55	1.55	1.55	1.55			
NOx Analyzer	FM-3	1.2 - 1.7 LPM	1.6	1.6	1.6	1.6			
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.35	1.35	1.35	1.35			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.65	1.6	1.6	1.65			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	4.5	4.5	4.5	4.5			
System Flow	FM-7	3-5 LPM	1.5	1.5	1.5	1.5			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.4	1.4	1.4	1.4			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.4	1.4	1.4	1.4			
NOX Dry Air	FM-10	500-700 CCM	600	600	600	580			
<b>DAHS Checks</b>									
Check DAHS for normal operation. Is system logging data?			✓	✓	✓	✓			
Check Alarms in DAHS			✓	✓	✓	✓			
Check chart recorder for normal operation			✓	✓	✓	✓			
Check analyzer calibration dnt. Did all calibrations pass?			✓	✓	✓	✓			
Check printer status			✓	✓	✓	✓			
<b>REMARKS:</b>									

Mark as either Acceptable "✓", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_

**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station  
Daily Quality Control/Quality Assurance Plan  
Checklist for CEMS Shelter Inspection**

Parameters to Check	Tag ID	Limits	Mon	Tue	Wed	Thu	Fri	Sat	Sun
Dates			10/21/19	10/22/19	10/23/19	10/24/19			
Technician's Initial									
Calibration Gas Pressures			Please enter readings and notify the Maintenance Manager when it is time to re-order						
O2/CO High Span, NOX Zero	SV1	> 150 psi	56.0	57.0	50.0	47.0			
NOX Low Span/CO Low Span	SV2	> 150 psi	103.0	57.0	104.0	98.0			
NOX High Span, O2/CO Zero	SV3	> 150 psi	40.0	38.0	34.0	21.0			
Stack Sample Line			Please enter readings						
Sample Line Temperature	TC1	250°F	250	250	250	250			
Sample NH3 Temperature	TC2	760°F	760	760	760	760			
Sample Line Pressure/Vacuum	PI-1	6.0 "Hg	6.6	6.6	7.3	6.7			
Sample Line Pressure/Vacuum	PI-2	8.0 "Hg	5.7	5.6	5.0	5.7			
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg	6.6	6.6	6.9	6.6			
Sample Line Pressure	PI-5	8 Psi	6.0	6.1	5.7	6.0			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	✓	✓	✓	✓			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	✓	✓	✓	✓			
Visual Checks									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	68.0	69.5	70.0	68.5			
Moisture Sensor A/Filter	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	✓	✓	✓	✓			
Moisture Sensor B/Filter	MS-2	Check if ok	✓	✓	✓	✓			
Operational Status of Sample Pumps (2)		Check if ok	✓	✓	✓	✓			
Operational Status of Condensate Drain Pumps (2)		Check if ok	✓	✓	✓	✓			
Check LED status of Sample Cooler		Check if ok	✓	✓	✓	✓			
NH3 Scrubber Drain	HV-4	Drain as needed	✓	✓	✓	✓			
Analyzer Sample Flow Meter Readings			Please enter readings						
System Flow	FM-1	3-5 LPM	4.3	4.3	4.6	4.1			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.35	1.35	1.6	1.6			
NOx Analyzer	FM-3	1.2 - 1.7 LPM	1.6	1.6	1.35	1.6			
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.3	1.3	1.3	1.3			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.6	1.6	1.6	1.6			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	4.5	4.5	4.2	4.5			
System Flow	FM-7	3-5 LPM	4.5	4.5	4.5	4.5			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.5	1.5	1.45	1.5			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.4	1.4	1.35	1.4			
NOX Dry Air	FM-10	500-700 CCM	650	660	650	650			
DAHs Checks									
Check DAHS for normal operation. Is system logging data?			✓	✓	✓	✓			
Check Alarms in DAHS.			✓	✓	✓	✓			
Check chart recorder for normal operation			✓	✓	✓	✓			
Check analyzer calibration drift. Did all calibrations pass?			✓	✓	✓	✓			
Check printer status			✓	✓	✓	✓			
REMARKS:									

Mark as either Acceptable "✓", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_

**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station**  
**Daily Quality Control/Quality Assurance Plan**  
**Checklist for CEMS Shelter Inspection**

Parameters to Check	Tag ID	Limits	Min	Max	Thu	Fri	Sat	Sun
Dates					10/23/19	10/23/19	10/30/19	
Technician's Initial								
Calibration Gas Pressures								
O2/CO High Span, NOX Zero	SV1	> 150 psi	340	2050				
NOX Low Span/CO Low Span	SV2	> 150 psi	500	750				
NOX High Span, O2/CO Zero	SV3	> 150 psi	2000	2010				
Stack Sample Line								
Sample Line Temperature	TC1	250°F	250	250				
Sample NH3 Temperature	TC2	780°F	760	760				
Sample Line Pressure/Vacuum	PI-1	6.0"Hg	6.6	6.7				
Sample Line Pressure/Vacuum	PI-2	8.0"Hg	5.6	5.6				
Sample Line Pressure/Vacuum	PI-4	7.5"Hg	6.6	6.6				
Sample Line Pressure	PI-5	8 Psi	6.1	6.0				
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	✓	✓				
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	✓	✓				
Visual Checks								
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	65.0	69.5	67.5			
Moisture Sensor A/Filter	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	✓	✓				
Moisture Sensor B/Filter	MS-2	Check if ok	✓	✓				
Operational Status of Sample Pumps (2)		Check if ok	✓	✓				
Operational Status of Condensate Drain Pumps (2)		Check if ok	✓	✓				
Check LED status of Sample Cooler		Check if ok	✓	✓				
NH3 Scrubber Drain	HV-4	Drain as needed	✓	✓				
Analyzer Sample Flow Meter Readings								
System Flow	FM-1	3-5 LPM	4.3	4.3	4.3			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.55	1.55	1.55			
NOx Analyzer	FM-3	1.2 - 1.7 LPM	1.6	1.55	1.6			
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.3	1.3	1.3			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.65	1.6	1.65			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	4.4	4.4	4.4			
System Flow	FM-7	3-5 LPM	1.45	1.45	1.45			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.35	1.4	1.4			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.35	1.4	1.4			
NOX Dry Air	FM-10	500-700 CCM	650	660	660			
DAHS Checks								
Check DAHS for normal operation. Is system logging data?			✓	✓	✓			
Check Alarms in DAHS			✓	✓	✓			
Check chart recorder for normal operation			✓	✓	✓			
Check analyzer calibration drift. Did all calibrations pass?			✓	✓	✓			
Check printer status			✓	✓	✓			
REMARKS:								

Mark as either Acceptable "✓", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_



**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station  
Daily Quality Control/Quality Assurance Plan  
Checklist for CEMS Shelter Inspection**

Parameters to Check	Mon	Tue	Wed	Thu	Est	564	Sum
Dates	11/4/15	11/5/15	11/6/15	11/7/15			
Technician's Initial	SD	SD	SD	SD			
Calibration Gas Pressures							
O2/CO High Span, NOX Zero	1700	1700	1540	1500			
NOX Low Span/CO Low Span	600	590	510	500			
NOX High Span, O2/CO Zero	1800	1800	1700	1680			
Stack Sample Line	Please enter readings						
Sample Line Temperature	250	250	250	250			
Sample NH3 Temperature	74.0	74.0	74.0	74.0			
Sample Line Pressure/Vacuum	6.5	6.6	6.6	6.6			
Sample Line Pressure/Vacuum	5.1	5.6	5.6	5.6			
Sample Line Pressure/Vacuum	7.1	6.5	6.6	6.6			
Sample Line Pressure	5.9	6.0	6.0	6.0			
Verify Functionality of Sample Pump A Flow Switch	✓	✓	✓	✓			
Verify Functionality of Sample Pump B Flow Switch	✓	✓	✓	✓			
Visual Checks							
Room Enclosure Temperature	69.5	67.5	67.5	70.0			
Moisture Sensor A/Filter	✓	✓	✓	✓			
Moisture Sensor B/Filter	✓	✓	✓	✓			
Operational Status of Sample Pumps (2)	✓	✓	✓	✓			
Operational Status of Condensate Drain Pumps (2)	✓	✓	✓	✓			
Check LED status of Sample Cooler	✓	✓	✓	✓			
NH3 Scrubber Drain	✓	✓	✓	✓			
Analyzer Sample Flow Meter Readings	Please enter readings						
System Flow	4.7	4.7	4.3	4.3			
O2 Analyzer	6.5	6.5	6.5	6.5			
NOx Analyzer	1.55	1.55	1.55	1.6			
NOx By-Pass	1.7	1.7	1.7	1.7			
CO Analyzer	1.6	1.6	1.65	1.65			
Cal Gas Flow (only during Calibration)	4.2	4.5	4.4	4.4			
System Flow	1.45	1.45	1.45	1.45			
NOXNH3 Analyzer	1.4	1.4	1.4	1.4			
NOXNH3 Analyzer By-Pass	6.0	6.0	6.0	6.0			
NOX Dry Air							
DAHs Checks							
Check DAHS for normal operation. Is system logging data?	✓	✓	✓	✓			
Check Alarms in DAHS.	✓	✓	✓	✓			
Check chart recorder for normal operation	✓	✓	✓	✓			
Check analyzer calibration drift. Did all calibrations pass?	✓	✓	✓	✓			
Check printer status	✓	✓	✓	✓			
REMARKS:							

Mark as either Acceptable "✓", Corrective Action Required "X", or Actual Readings, where required  
Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_

**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station  
Daily Quality Control/Quality Assurance Plan  
Checklist for CEMS Shelter Inspection**

Parameters to Check	Tue	Wed	Thu	Fri	Sat	Sun
<b>Dates</b>	11/13/19	11/13/19	11/14/19			
Technician's Initial	SPD					
Calibration Gas Pressures	Please enter readings and notify the Maintenance Manager when it is time to re-order					
O <sub>2</sub> /CO High Span, NO <sub>x</sub> Zero	1300	1300	1300			
NO <sub>x</sub> Low Span/CO Low Span	400	320	190			
NO <sub>x</sub> High Span, O <sub>2</sub> /CO Zero	1560	1400	1420			
<b>Stack Sample Line</b>	Please enter readings					
Sample Line Temperature	250	250	250			
Sample NH <sub>3</sub> Temperature	760	760	760			
Sample Line Pressure/Vacuum	6.6	6.5	6.4			
Sample Line Pressure/Vacuum	5.6	5.2	5.7			
Sample Line Pressure/Vacuum	6.6	6.6	6.9			
Sample Line Pressure	6.4	5.5	5.5			
Verify Functionality of Sample Pump A Flow Switch	✓	✓	✓			
Verify Functionality of Sample Pump B Flow Switch	✓	✓	✓			
<b>Visual Checks</b>						
Room Enclosure Temperature	70.0	68.0	68.0			
Moisture Sensor A/Filter	✓	✓	✓			
Moisture Sensor B/Filter	✓	✓	✓			
Operational Status of Sample Pumps (2)	✓	✓	✓			
Operational Status of Condensate Drain Pumps (2)	✓	✓	✓			
Check LED status of Sample Cooler	✓	✓	✓			
NH <sub>3</sub> Scrubber Drain	✓	✓	✓			
<b>Analyzer Sample Flow Meter Readings</b>	Please enter readings					
System Flow	9.7	4.2	4.1			
O <sub>2</sub> Analyzer	1.55	1.5	1.5			
NO <sub>x</sub> Analyzer	1.55	1.55	1.55			
NO <sub>x</sub> By-Pass	1.3	1.3	1.3			
CO Analyzer	1.6	1.55	1.6			
Cal Gas Flow (only during Calibration)	4.4	4.3	4.3			
System Flow	1.45	1.45	1.45			
NO <sub>x</sub> /NH <sub>3</sub> Analyzer	1.4	1.35	1.4			
NO <sub>x</sub> /NH <sub>3</sub> Analyzer By-Pass	5.0	5.0	5.0			
NO <sub>x</sub> Dry Air						
<b>DAHHS Checks</b>						
Check DAHS for normal operation. Is system logging data?	✓	✓	✓			
Check Alarms in DAHS.	✓	✓	✓			
Check chart recorder for normal operation	✓	✓	✓			
Check analyzer calibration drift. Did all calibrations pass?	✓	✓	✓			
Check printer status	✓	✓	✓			
<b>REMARKS:</b>						

Mark as either Acceptable "✓", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_



**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station**  
**Daily Quality Control/Quality Assurance Plan**  
**Checklist for CEMS Shelter Inspection**

Parameters to Check	Tag ID	Limits	Min	Max	Time	Wkd	Thu	Fri	Sat	Sun
Technician's Initial						11/18/19	11/19/19			
Calibration Gas Pressures						11/19/19	11/20/19	11/21/19		
O2/CO High Span, NOX Zero	SV1	>150 psi	1020	180	97.7		76.0			
NOX Low Span/CO Low Span	SV2	>150 psi	1780	1640	1620		1670			
NOX High Span, OZICO Zero	SV3	>150 psi	1400	1330	1300		1330			
Stack Sample Line										
Sample Line Temperature	TC1	250°F	250	350	350		250			
Sample NH3 Temperature	TC2	760°F	760	760	760		760			
Sample Line Pressure/Vacuum	PI-1	6.0 Hg	6.6	6.6	6.1		6.1			
Sample Line Pressure/Vacuum	PI-2	8.0 Hg	5.5	5.1	5.1		5.1			
Sample Line Pressure/Vacuum	PI-4	7.5 Hg	6.5	6.6	6.6		6.6			
Sample Line Pressure	PI-5	8 Psi	6.0	5.9	5.9		5.9			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	✓	✓	✓		✓			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	✓	✓	✓		✓			
Visual Checks										
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	70.0	68.5	68.5		68.5			
Moisture Sensor A/Filter	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	✓	✓	✓		✓			
Moisture Sensor B/Filter	MS-2	Check if ok	✓	✓	✓		✓			
Operational Status of Sample Pumps (2)		Check if ok	✓	✓	✓		✓			
Operational Status of Condensate Drain Pumps (2)		Check if ok	✓	✓	✓		✓			
Check LED status of Sample Cooler		Check if ok	✓	✓	✓		✓			
NH3 Scrubber Drain	HV-4	Drain as needed	✓	✓	✓		✓			
Analyzer Sample Flow Meter Readings										
System Flow	FM-1	3-5 LPM	4.3	4.1	4.1		4.3			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.55	1.55	1.55		1.5			
NOX Analyzer	FM-3	1.2 - 1.7 LPM	1.6	1.55	1.6		1.55			
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.35	1.3	1.3		1.3			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.65	1.6	1.6		1.6			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	4.4	4.4	4.4		4.5			
System Flow	FM-7	3-5 LPM	4.4	4.45	4.45		4.5			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.4	1.4	1.4		1.4			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.4	1.4	1.4		1.4			
NOX Dry Air	FM-10	500-700 CCM	540	580	580		580			
DAHNS Checks										
Check DAHS for normal operation. Is system logging data?			✓	✓	✓		✓			
Check Alarms in DAHS			✓	✓	✓		✓			
Check chart recorder for normal operation			✓	✓	✓		✓			
Check analyzer calibration drift. Did all calibrations pass?			✓	✓	✓		✓			
Check printer status			✓	✓	✓		✓			
REMARKS:										

Mark as either Acceptable "✓", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_

**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station  
Daily Quality Control/Quality Assurance Plan  
Checklist for CEMS Shelter Inspection**

Parameters to Check	Tag ID	Limits	Mon	Tue	Wed	Thu	Fri	Sat	Sun
<p><b>Technician's Initial</b>                      Calibration Gas Pressures                      O2/CO High Spn, NOX Zero                      NOX Low Spn/CO Low Spn                      NOX High Spn, O2/CO Zero                      Stack Sample Line</p>									
<p align="center">Please enter readings for the Maintenance Manager when it is time to re-order</p>									
SV1		>150 psi	54.0	54.0	53.0	51.0	51.0		
SV2		>150 psi	134.0	128.0	128.0	128.0	128.0		
SV3		>150 psi	114.0	109.0	108.0	103.0	103.0		
<p align="center">Please enter readings</p>									
TC1		250°F	75.0	75.0	75.0	75.0	75.0		
TC2		76°F	76.0	76.0	76.0	76.0	76.0		
PI-1		6.0 Hg	6.6	6.7	6.7	6.5	6.5		
PI-2		8.0 Hg	5.7	5.5	5.5	5.7	5.7		
PI-4		7.5 Hg	6.1	6.6	6.6	6.6	6.6		
PI-5		8 PSI	6.1	6.0	6.0	6.1	6.1		
FS-1		5-7 LPM (set point)	✓	✓	✓	✓	✓		
FS-2		5-7 LPM (set point)	✓	✓	✓	✓	✓		
<p><b>Visual Checks</b></p>									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	69.5	69.0	69.5	68.5	68.5		
Moisture Sensor A/Filter	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	✓	✓	✓	✓	✓		
Moisture Sensor B/Filter	MS-2	Operational Status of Sample Pumps (2)	✓	✓	✓	✓	✓		
Operational Status of Condensate Drain Pumps (2)		Operational Status of Condensate Drain Pumps (2)	✓	✓	✓	✓	✓		
Check LED status of Sample Cooler		Check if ok	✓	✓	✓	✓	✓		
NH3 Scrubber Drain	HV-4	Check if ok	✓	✓	✓	✓	✓		
<p><b>Analyzer Sample Flow Meter Readings</b></p>									
System Flow	FM-1	3-5 LPM	4.3	4.3	4.3	4.3	4.3		
O2 Analyzer	FM-2	1.2-1.7 LPM	1.55	1.55	1.55	1.53	1.53		
NOx Analyzer	FM-3	1.2-1.7 LPM	1.6	1.6	1.6	1.6	1.6		
NOX By-Pass	FM-4	1.2-1.7 LPM	1.3	1.3	1.3	1.3	1.3		
CO Analyzer	FM-5	1.2-1.7 LPM	1.55	1.55	1.6	1.55	1.55		
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7							
System Flow	FM-7	3-5 LPM	4.5	4.5	4.4	4.5	4.5		
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.4	1.45	1.45	1.45	1.45		
NOX/NH3 Analyzer By-Pass	FM-9	1.2-1.5 LPM	1.4	1.4	1.4	1.4	1.4		
NOX Dry Air	FM-10	500-700 CCM	58.0	6.0	6.0	6.0	6.0		
<p><b>DAHS Checks</b></p>									
Check DAHS for normal operation. Is system logging data?			✓	✓	✓	✓	✓		
Check Alarms in DAHS.			✓	✓	✓	✓	✓		
Check chart recorder for normal operation			✓	✓	✓	✓	✓		
Check analyzer calibration drift. Did all calibrations pass?			✓	✓	✓	✓	✓		
Check printer status			✓	✓	✓	✓	✓		
<p><b>REMARKS:</b></p>									

Mark as either Acceptable "✓", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_

**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station  
 Daily Quality Control/Quality Assurance Plan  
 Checklist for CEMS Shelter Inspection**

Parameter to Check	Tag ID	Limits	Mon	Tue	Wed	Thu	Fri	Sat	Sun
Dates: 12/19/14 12/19/14 12/19/14 12/19/14 12/19/14 12/19/14 12/19/14 12/19/14 12/19/14 12/19/14									
Technician's Initial									
Calibration Gas Pressures									
O2/CO High Span, NOX Zero	SV1	> 150 psi	500	480	480	470			
NOX Low Span/CO Low Span	SV2	> 150 psi	1250	1200	1210	1180			
NOX High Span, O2/CO Zero	SV3	> 150 psi	1050	1040	1040	970			
Stack Sample Line			Please enter readings						
Sample Line Temperature	TC1	250F	250	250	250	250			
Sample NH3 Temperature -	TC2	760F	760	760	760	760			
Sample Line Pressure/Vacuum	PI-1	60"Hg	6.6	6.4	6.5	6.6			
Sample Line Pressure/Vacuum	PI-2	8.0"Hg	6.6	6.7	6.7	6.6			
Sample Line Pressure/Vacuum	PI-4	7.5"Hg	6.6	6.6	6.6	6.6			
Sample Line Pressure	PI-5	8 Psi	6.1	6.1	6.1	6.1			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	✓	✓	✓	✓			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	✓	✓	✓	✓			
Visual Checks									
Room Enclosure Temperature		72 F (+/-5)F	70.0	67.0	70.0	69.5			
Moisture Sensor A/Filter	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	✓	✓	✓	✓			
Moisture Sensor B/Filter	MS-2	Check if ok	✓	✓	✓	✓			
Operational Status of Sample Pumps (2)		Check if ok	✓	✓	✓	✓			
Operational Status of Condensate Drain Pumps (2)		Check if ok	✓	✓	✓	✓			
Check LED status of Sample Cooler		Check if ok	✓	✓	✓	✓			
NH3 Scrubber Drain	RV-4	Drain as needed	✓	✓	✓	✓			
Analyzer Sample Flow Meter Readings			Please enter readings						
System Flow	FM-1	3-5 LPM	4.3	4.0	4.0	4.2			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.55	1.55	1.55	1.5			
NOx Analyzer	FM-3	1.2 - 1.7 LPM	1.6	1.6	1.6	1.55			
NOx By-Pass	FM-4	1.2 - 1.7 LPM	1.85	1.3	1.3	1.3			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.6	1.85	1.6	1.55			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7							
System Flow	FM-7	3-5 LPM	4.5	4.5	4.5	4.5			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.45	1.45	1.45	1.45			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.4	1.4	1.4	1.4			
NOX Dry Air	FM-10	500-700 CCM	650	650	650	650			
DAHS Checks									
Check DAHS for normal operation. Is system logging data?			✓	✓	✓	✓			
Check Alarms in DAHS.			✓	✓	✓	✓			
Check chart recorder for normal operation			✓	✓	✓	✓			
Check analyzer calibration drnt. Did all calibrations pass?			✓	✓	✓	✓			
Check printer status			✓	✓	✓	✓			
REMARKS:									

Mark as either Acceptable "✓", Corrective Action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_

**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station  
Daily Quality Control/Quality Assurance Plan  
Checklist for CEMS Shelter Inspection**

Parameters to Check	Tag ID	Limits	Mon	Tue	Wed	Thu	Fri	Sat	Sun
<p><b>Technician's Initial</b></p> <p>12/16/19 12/18/19 12/19/19 12/19/19</p>									
<p><b>Calibration Gas Pressures</b></p> <p>O2/CO High Span, NOX Zero 410 7200 1170 1060</p> <p>NOX Low Span/CO Low Span 990 990 990 940</p> <p>NOX High Span, O2/CO Zero</p>									
<p><b>Stack Sample Line</b></p> <p>TC1 250 250 250 250</p> <p>TC2 760 760 760 760</p> <p>PI-1 6.4 6.4 6.4 6.4</p> <p>PI-2 5.7 5.7 5.7 5.7</p> <p>PI-4 6.6 6.6 6.6 6.6</p> <p>PI-5 6.1 6.1 6.1 6.1</p> <p>FS-1 8 Psi</p> <p>FS-2 5-7 LPM (set point)</p>									
<p><b>Visual Checks</b></p> <p>Room Enclosure Temperature 72 F (+/-5) F 67.5 67.5 68.0 68.5</p> <p>Moisture Sensor A/Filter Clean and dry, if filter shows buildup and flow levels are dropping, replace filter ✓</p> <p>Moisture Sensor B/Filter ✓</p> <p>Operational Status of Sample Pumps (2) ✓</p> <p>Operational Status of Condensate Drain Pumps (2) ✓</p> <p>Check LED status of Sample Cooler ✓</p> <p>NH3 Scrubber Drain ✓</p>									
<p><b>Analyzer Sample Flow Meter Readings</b></p> <p>System Flow 4.3 4.3 4.3 4.3</p> <p>Ox Analyzer 1.55 1.55 1.55 1.55</p> <p>NOx Analyzer 1.6 1.6 1.6 1.6</p> <p>NOX By-Pass 1.3 1.3 1.3 1.3</p> <p>CO Analyzer 1.55 1.55 1.55 1.55</p> <p>Cal Gas Flow (only during Calibration) 4.5 4.5 4.5 4.5</p> <p>System Flow 3-5 LPM 3-5 LPM 3-5 LPM 3-5 LPM</p> <p>NOX/NH3 Analyzer 1.45 1.45 1.45 1.45</p> <p>NOX/NH3 Analyzer By-Pass 1.4 1.4 1.4 1.4</p> <p>NOX Dry Air 6.0 6.0 6.0 6.0</p>									
<p><b>DAHIS Checks</b></p> <p>Check DAHS for normal operation. Is system logging data? ✓</p> <p>Check Alarms in DAHS. ✓</p> <p>Check chart recorder for normal operation ✓</p> <p>Check analyzer calibration drift. Did all calibrations pass? ✓</p> <p>Check printer status ✓</p>									
<p><b>REMARKS:</b></p>									

Mark as either Acceptable "✓", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_

**Barre/Center/Grapeland/Miraloma/McGrath Peaker Generating Station**  
**Daily Quality Control/Quality Assurance Plan**  
**Checklist for CEMS Shelter Inspection**

Parameters to Check	Tag ID	Limits	Mon	Tue	Wed	Thu	Fri	Sat	Sun
Dates			12/20/19	12/21/19					
Technician's Initial			SD	SD					
Please enter readings and notify the Maintenance Manager when it is time to re-order									
Calibration Gas Pressures									
O2/CO High Span, NOX Zero	SV1	>150 psi	1440	1440					
NOX Low Span/CO Low Span	SV2	>150 psi	1010	1070					
NOX High Span, O2/CO Zero	SV3	>150 psi	900	910					
Stack Sample Line			Please enter readings						
Sample Line Temperature	TC1	250F	250	250					
Sample NH3 Temperature	TC2	760F	760	760					
Sample Line Pressure/Vacuum	PI-1	6.0 "Hg	6.5	6.5					
Sample Line Pressure/Vacuum	PI-2	8.0 "Hg	5.7	5.7					
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg	6.6	6.6					
Sample Line Pressure	PI-5	8 PSI	6.0	6.1					
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	V	V					
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	V	V					
Visual Checks									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	67.0	68.5					
Moisture Sensor A/Filter	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	V	V					
Moisture Sensor B/Filter	MS-2	Check if ok	V	V					
Operational Status of Sample Pumps (2)		Check if ok	V	V					
Operational Status of Condensate Drain Pumps (2)		Check if ok	V	V					
Check LED status of Sample Cooler		Check if ok	V	V					
NH3 Scrubber Drain	HY-4	Drain as needed	V	V					
Analyze Sample Flow Meter Readings			Please enter readings						
System Flow	FM-1	3-5 LPM	4.3	7.1					
Oz Analyzer	FM-2	1.2 - 1.7 LPM	1.55	1.55					
NOx Analyzer	FM-3	1.2 - 1.7 LPM	1.6	1.6					
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.35	1.3					
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.6	1.6					
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7							
System Flow	FM-7	3-5 LPM	4.5	4.5					
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.45	1.45					
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.4	1.4					
NOX Dry Air	FM-10	500-700 CCM	600	600					
DAHs Checks									
Check DAHS for normal operation. Is system logging data?			V	V					
Check Alarms in DAHS.			V	V					
Check chat recorder for normal operation			V	V					
Check analyzer calibration drift. Did all calibrations pass?			V	V					
Check printer status			V	V					
REMARKS:									

Mark as either Acceptable "V", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_

**Attachment 3**  
**CEMS Calibrations Records**



Daily Stack Calibration Report  
Generated: 2/11/2020

Company: McGrath Generating Station  
Plant: 251 N. Harbor Blvd.  
City/St: Oxnard, CA 93035  
Source: stack

Period Start: 1/1/2019  
Period End: 12/30/2019  
Included Calibrations: Daily (40CFR60)/(40CFR75)

Range of Analyzers

Channel	Target Units	Actual Units	Diff Units	Error %	Units	Part60 Allowable %	Part75 Allowable	WD Error %	Units	Part75 Allowable	Gross MW	Process	On	Off	Expire Date
O2_5	0.00	0.00	0.00	0.00	0.00	25.00 %	0.00	25.00 %	0.00	25.00 %	0.00	0.00	0.00	0.00	2/12/2027
NOXLOW_5	0.00	0.00	0.00	0.00	0.00	10.00 ppm	0.00	10.00 ppm	0.00	10.00 ppm	0.00	0.00	0.00	0.00	2/12/2027
NOXHGH_5	0.00	0.00	0.00	0.00	0.00	200.00 ppm	0.00	200.00 ppm	0.00	200.00 ppm	0.00	0.00	0.00	0.00	2/12/2027
COLOW_5	0.00	0.00	0.00	0.00	0.00	10.00 ppm	0.00	10.00 ppm	0.00	10.00 ppm	0.00	0.00	0.00	0.00	2/12/2027
COHGH_5	0.00	0.00	0.00	0.00	0.00	200.00 ppm	0.00	200.00 ppm	0.00	200.00 ppm	0.00	0.00	0.00	0.00	2/12/2027
NOX_NH3L_5	0.00	0.00	0.00	0.00	0.00	10.00 ppm	0.00	10.00 ppm	0.00	10.00 ppm	0.00	0.00	0.00	0.00	2/12/2027
NOX_NH3H_5	0.00	0.00	0.00	0.00	0.00	200.00 ppm	0.00	200.00 ppm	0.00	200.00 ppm	0.00	0.00	0.00	0.00	2/12/2027

Span of Analyzers

Date	Time	Channel	Type	Target Units	Actual Units	Diff Units	Error %	Units	Part60 Allowable %	Part75 Allowable	WD Error %	Units	Part75 Allowable	Gross MW	Process	On	Off	Expire Date
12/30/2019	15:47	COHGH_5	CO	182.60	183.60	1.00	0.5	40.00	20.0	PASS	0	N/A	N/A	50.4	100.0 %	0.0	0.0 %	8/19/2027
12/30/2019	15:47	COHGH_5	CO	182.60	183.60	1.00	0.5	40.00	20.0	PASS	0	N/A	N/A	50.4	100.0 %	0.0	0.0 %	8/19/2027
12/26/2019	17:16	COHGH_5	CO	182.60	183.40	0.80	0.4	40.00	20.0	PASS	0	N/A	N/A	50.3	100.0 %	0.0	0.0 %	8/19/2027
12/26/2019	17:16	COHGH_5	CO	182.60	183.40	0.80	0.4	40.00	20.0	PASS	0	N/A	N/A	50.3	100.0 %	0.0	0.0 %	8/19/2027
12/18/2019	17:46	COHGH_5	CO	182.60	182.63	0.03	0.0	40.00	20.0	PASS	0	N/A	N/A	50.4	100.0 %	0.0	0.0 %	8/19/2027
12/18/2019	17:46	COHGH_5	CO	182.60	182.63	0.03	0.0	40.00	20.0	PASS	0	N/A	N/A	50.4	100.0 %	0.0	0.0 %	8/19/2027
12/17/2019	17:01	COHGH_5	CO	183.70	183.49	-0.21	-0.1	40.00	20.0	PASS	0	N/A	N/A	0.0	0.0 %	0.0	0.0 %	8/19/2027
12/17/2019	17:01	COHGH_5	CO	183.70	183.49	-0.21	-0.1	40.00	20.0	PASS	0	N/A	N/A	0.0	0.0 %	0.0	0.0 %	8/19/2027
12/11/2019	15:06	COHGH_5	CO	183.70	183.50	-0.20	-0.1	40.00	20.0	PASS	0	N/A	N/A	0.0	0.0 %	0.0	0.0 %	8/19/2027
12/11/2019	15:06	COHGH_5	CO	183.70	183.50	-0.20	-0.1	40.00	20.0	PASS	0	N/A	N/A	0.0	0.0 %	0.0	0.0 %	8/19/2027
12/04/2019	13:40	COHGH_5	CO	183.70	183.58	-0.12	-0.2	40.00	20.0	PASS	0	N/A	N/A	0.0	0.0 %	0.0	0.0 %	8/19/2027
12/04/2019	13:40	COHGH_5	CO	183.70	183.58	-0.12	-0.2	40.00	20.0	PASS	0	N/A	N/A	0.0	0.0 %	0.0	0.0 %	8/19/2027
12/03/2019	08:31	COHGH_5	CO	183.70	184.56	1.25	0.1	40.00	20.0	PASS	0	N/A	N/A	49.8	100.0 %	0.0	0.0 %	8/19/2027
12/03/2019	08:31	COHGH_5	CO	183.70	184.56	1.25	0.1	40.00	20.0	PASS	0	N/A	N/A	49.8	100.0 %	0.0	0.0 %	8/19/2027
11/26/2019	07:01	COHGH_5	CO	183.70	184.30	0.60	0.1	40.00	20.0	PASS	0	N/A	N/A	50.8	100.0 %	0.0	0.0 %	8/19/2027
11/26/2019	07:01	COHGH_5	CO	183.70	184.30	0.60	0.1	40.00	20.0	PASS	0	N/A	N/A	50.8	100.0 %	0.0	0.0 %	8/19/2027
11/24/2019	17:16	COHGH_5	CO	183.70	184.17	0.47	0.2	40.00	20.0	PASS	0	N/A	N/A	49.1	100.0 %	0.0	0.0 %	8/19/2027
11/24/2019	17:16	COHGH_5	CO	183.70	184.17	0.47	0.2	40.00	20.0	PASS	0	N/A	N/A	49.1	100.0 %	0.0	0.0 %	8/19/2027
11/22/2019	14:50	COHGH_5	CO	183.70	184.21	0.51	0.3	40.00	20.0	PASS	0	N/A	N/A	49.3	100.0 %	0.0	0.0 %	8/19/2027
11/22/2019	14:50	COHGH_5	CO	183.70	184.21	0.51	0.3	40.00	20.0	PASS	0	N/A	N/A	49.3	100.0 %	0.0	0.0 %	8/19/2027
11/21/2019	12:44	COHGH_5	CO	183.70	184.44	0.74	0.4	40.00	20.0	PASS	0	N/A	N/A	0.0	0.0 %	0.0	0.0 %	8/19/2027
11/21/2019	12:44	COHGH_5	CO	183.70	184.44	0.74	0.4	40.00	20.0	PASS	0	N/A	N/A	0.0	0.0 %	0.0	0.0 %	8/19/2027
11/18/2019	17:01	COHGH_5	CO	183.70	184.05	0.35	0.2	40.00	20.0	PASS	0	N/A	N/A	48.7	100.0 %	0.0	0.0 %	8/19/2027
11/18/2019	17:01	COHGH_5	CO	183.70	184.05	0.35	0.2	40.00	20.0	PASS	0	N/A	N/A	48.7	100.0 %	0.0	0.0 %	8/19/2027
11/17/2019	17:16	COHGH_5	CO	183.70	184.07	0.37	0.2	40.00	20.0	PASS	0	N/A	N/A	49.3	100.0 %	0.0	0.0 %	8/19/2027
11/17/2019	17:16	COHGH_5	CO	183.70	184.07	0.37	0.2	40.00	20.0	PASS	0	N/A	N/A	49.3	100.0 %	0.0	0.0 %	8/19/2027
11/16/2019	17:16	COHGH_5	CO	183.70	183.94	-0.24	-0.1	40.00	20.0	PASS	0	N/A	N/A	49.0	100.0 %	0.0	0.0 %	8/19/2027
11/16/2019	17:16	COHGH_5	CO	183.70	183.94	-0.24	-0.1	40.00	20.0	PASS	0	N/A	N/A	49.0	100.0 %	0.0	0.0 %	8/19/2027
11/15/2019	17:16	COHGH_5	CO	183.70	183.58	-0.12	-0.1	40.00	20.0	PASS	0	N/A	N/A	49.6	100.0 %	0.0	0.0 %	8/19/2027
11/15/2019	17:16	COHGH_5	CO	183.70	183.58	-0.12	-0.1	40.00	20.0	PASS	0	N/A	N/A	49.6	100.0 %	0.0	0.0 %	8/19/2027
11/14/2019	06:16	COHGH_5	CO	183.70	183.41	-0.29	-0.1	40.00	20.0	PASS	0	N/A	N/A	49.8	100.0 %	0.0	0.0 %	8/19/2027
11/14/2019	06:16	COHGH_5	CO	183.70	183.41	-0.29	-0.1	40.00	20.0	PASS	0	N/A	N/A	49.8	100.0 %	0.0	0.0 %	8/19/2027
11/13/2019	16:16	COHGH_5	CO	183.70	183.35	-0.35	-0.2	40.00	20.0	PASS	0	N/A	N/A	49.4	100.0 %	0.0	0.0 %	8/19/2027
11/13/2019	16:16	COHGH_5	CO	183.70	183.35	-0.35	-0.2	40.00	20.0	PASS	0	N/A	N/A	49.4	100.0 %	0.0	0.0 %	8/19/2027
11/12/2019	17:16	COHGH_5	CO	183.70	183.74	0.04	0.0	40.00	20.0	PASS	0	N/A	N/A	49.6	100.0 %	0.0	0.0 %	8/19/2027
11/12/2019	17:16	COHGH_5	CO	183.70	183.74	0.04	0.0	40.00	20.0	PASS	0	N/A	N/A	49.6	100.0 %	0.0	0.0 %	8/19/2027
11/11/2019	16:16	COHGH_5	CO	183.70	183.62	-0.08	0.0	40.00	20.0	PASS	0	N/A	N/A	49.6	100.0 %	0.0	0.0 %	8/19/2027
11/11/2019	16:16	COHGH_5	CO	183.70	183.62	-0.08	0.0	40.00	20.0	PASS	0	N/A	N/A	49.6	100.0 %	0.0	0.0 %	8/19/2027
11/10/2019	17:46	COHGH_5	CO	183.70	183.62	-0.08	0.0	40.00	20.0	PASS	0	N/A	N/A	49.4	100.0 %	0.0	0.0 %	8/19/2027
11/10/2019	17:46	COHGH_5	CO	183.70	183.62	-0.08	0.0	40.00	20.0	PASS	0	N/A	N/A	49.4	100.0 %	0.0	0.0 %	8/19/2027
11/10/2019	17:46	COHGH_5	CO	183.70	183.74	0.04	0.0	40.00	20.0	PASS	0	N/A	N/A	49.4	100.0 %	0.0	0.0 %	8/19/2027
11/10/2019	17:46	COHGH_5	CO	183.70	183.74	0.04	0.0	40.00	20.0	PASS	0	N/A	N/A	49.4	100.0 %	0.0	0.0 %	8/19/2027

Daily Stack Calibration Report  
Generated: 2/11/2020

Company: McGrath Generating Station  
Plant: 251 N. Harbor Blvd.  
City/St.: Oxnard, CA 93035  
Source: stack

Period Start: 1/1/2019  
Period End: 12/30/2019  
Included Calibrations: Daily (40CFR60)/(40CFR75)

Date	Time	Channel	Type	Target Units	Actual Units	Diff Units	Error	Units	Part60 Allowable	WP Error	Units	Part75 Allowable	Gross M <sup>3</sup> /M <sup>3</sup>	Process On	Bottle ID	Expire Date
10/10/2019	05:16	COHIGH_5	CO	180.40	180.51	0.11	0.06	20.0	PASS	0	N/A	N/A	0.0	0.0	CCI49073	9/17/2026
10/16/2019	05:16	COHIGH_5	CO	180.40	180.51	0.11	0.06	20.0	PASS	0	N/A	N/A	49.3	100.0	CCI49073	9/17/2026
10/19/2019	17:11	COHIGH_5	CO	180.40	180.51	0.11	0.06	20.0	PASS	0	N/A	N/A	0.0	0.0	CCI49073	9/17/2026
10/28/2019	16:01	COHIGH_5	CO	180.40	180.66	0.26	0.14	20.0	PASS	0	N/A	N/A	0.0	0.0	CCI49073	9/17/2026
10/08/2019	16:01	COHIGH_5	CO	180.40	180.66	0.26	0.14	20.0	PASS	0	N/A	N/A	0.0	0.0	CCI49073	9/17/2026
10/07/2019	17:46	COHIGH_5	CO	180.40	180.53	0.13	0.07	20.0	PASS	0	N/A	N/A	0.0	0.0	CCI49073	9/17/2026
10/06/2019	17:16	COHIGH_5	CO	180.40	180.53	0.13	0.07	20.0	PASS	0	N/A	N/A	48.6	100.0	CCI49073	9/17/2026
10/05/2019	17:16	COHIGH_5	CO	180.40	180.53	0.13	0.07	20.0	PASS	0	N/A	N/A	48.6	82.4	CCI49073	9/17/2026
10/02/2019	18:01	COHIGH_5	CO	180.40	179.96	-0.44	-0.24	20.0	PASS	0	N/A	N/A	49.8	100.0	CCI49073	9/17/2026
10/02/2019	18:01	COHIGH_5	CO	180.40	179.96	-0.44	-0.24	20.0	PASS	0	N/A	N/A	0.0	0.0	CCI49073	9/17/2026
10/02/2019	05:24	COHIGH_5	CO	180.40	179.96	-0.44	-0.24	20.0	PASS	0	N/A	N/A	0.0	0.0	CCI49073	9/17/2026
09/21/2019	16:01	COHIGH_5	CO	180.40	181.49	1.09	0.60	20.0	PASS	0	N/A	N/A	0.0	0.0	CCI49073	9/17/2026
09/18/2019	13:58	COHIGH_5	CO	180.40	181.61	1.21	0.66	20.0	PASS	0	N/A	N/A	0.0	0.0	CCI49073	9/17/2026
09/05/2019	14:16	COHIGH_5	CO	180.40	180.57	0.17	0.09	20.0	PASS	0	N/A	N/A	47.9	100.0	CCI49073	9/17/2026
09/04/2019	17:01	COHIGH_5	CO	180.40	181.04	0.64	0.34	20.0	PASS	0	N/A	N/A	48.1	100.0	CCI49073	9/17/2026
09/04/2019	05:26	COHIGH_5	CO	180.40	180.72	0.32	0.17	20.0	PASS	0	N/A	N/A	0.0	0.0	CCI49073	9/17/2026
09/03/2019	16:46	COHIGH_5	CO	180.40	180.72	0.32	0.17	20.0	PASS	0	N/A	N/A	48.0	100.0	CCI49073	9/17/2026
09/02/2019	17:46	COHIGH_5	CO	180.40	182.95	2.55	1.33	20.0	PASS	0	N/A	N/A	48.1	100.0	CCI49073	9/17/2026
09/02/2019	17:46	COHIGH_5	CO	180.40	182.32	1.92	1.04	20.0	PASS	0	N/A	N/A	0.0	0.0	CCI49073	9/17/2026
09/01/2019	18:01	COHIGH_5	CO	180.40	182.71	2.31	1.24	20.0	PASS	0	N/A	N/A	0.0	0.0	CCI49073	9/17/2026
08/30/2019	14:01	COHIGH_5	CO	180.40	182.71	2.31	1.24	20.0	PASS	0	N/A	N/A	48.0	100.0	CCI49073	9/17/2026
08/30/2019	14:01	COHIGH_5	CO	180.40	182.44	2.04	1.10	20.0	PASS	0	N/A	N/A	0.0	0.0	CCI49073	9/17/2026
08/25/2019	00:40	COHIGH_5	CO	180.40	182.32	1.92	1.04	20.0	PASS	0	N/A	N/A	48.4	100.0	CCI49073	9/17/2026
08/24/2019	17:46	COHIGH_5	CO	180.40	182.48	2.08	1.10	20.0	PASS	0	N/A	N/A	48.3	100.0	CCI49073	9/17/2026
08/19/2019	13:46	COHIGH_5	CO	180.40	181.32	0.92	0.48	20.0	PASS	0	N/A	N/A	49.3	76.5	CCI49073	9/17/2026
08/15/2019	13:46	COHIGH_5	CO	180.40	181.68	1.28	0.66	20.0	PASS	0	N/A	N/A	0.0	0.0	CCI49073	9/17/2026
08/14/2019	16:28	COHIGH_5	CO	180.40	181.76	1.36	0.71	20.0	PASS	0	N/A	N/A	48.0	100.0	CCI49073	9/17/2026
08/12/2019	14:01	COHIGH_5	CO	180.40	181.65	1.25	0.64	20.0	PASS	0	N/A	N/A	0.0	0.0	CCI49073	9/17/2026
08/06/2019	09:29	COHIGH_5	CO	180.40	181.13	0.73	0.38	20.0	PASS	0	N/A	N/A	49.0	100.0	CCI49073	9/17/2026
08/05/2019	17:31	COHIGH_5	CO	180.40	184.52	4.12	2.11	20.0	PASS	0	N/A	N/A	0.0	0.0	CCI49073	9/17/2026

Daily Stack Calibration Report  
Generated: 2/11/2020

Company: McGrath Generating Station  
Plant: 251 N. Harbor Blvd.  
City/St: Oxnard, CA 93035  
Source: stack

Period Start: 1/1/2019  
Period End: 12/30/2019  
Included Calibrations: Daily (40CFR60)/(40CFR75)

Date	Time	Channel	Type	Target Units	Actual Units	Diff Units	Error %	Units	Part60 Allowable %	WD Error	Units	Part75 Allowable %	Gross Mw	Process On	Bottle ID	Expire Date
04/14/2019	15:01	COHIGH_5	CO ZERO	183.00	0.17	0.17	0.1	40.00	20.0	PASS	0	N/A	0.0	0.0	SG9159413BAL	7/9/2026
04/14/2019	15:01	COHIGH_5	CO SPAN	183.00	181.89	-1.11	-0.6	40.00	20.0	PASS	0	N/A	49.8	100.0	ALM029052	12/13/2026
04/13/2019	18:16	COHIGH_5	CO ZERO	183.00	0.14	0.14	0.1	40.00	20.0	PASS	0	N/A	0.0	0.0	SG9159413BAL	7/9/2026
04/13/2019	18:16	COHIGH_5	CO SPAN	183.00	181.67	-1.33	-0.7	40.00	20.0	PASS	0	N/A	0.0	0.0	ALM029052	12/13/2026
04/12/2019	05:33	COHIGH_5	CO ZERO	183.00	0.15	0.15	0.1	40.00	20.0	PASS	0	N/A	0.0	0.0	SG9159413BAL	7/9/2026
04/12/2019	05:33	COHIGH_5	CO SPAN	183.00	181.94	-1.05	-0.5	40.00	20.0	PASS	0	N/A	0.0	0.0	ALM029052	12/13/2026
04/11/2019	12:46	COHIGH_5	CO ZERO	183.00	0.13	0.13	0.1	40.00	20.0	PASS	0	N/A	0.0	0.0	SG9159413BAL	7/9/2026
04/11/2019	12:46	COHIGH_5	CO SPAN	183.00	181.93	-1.07	-0.5	40.00	20.0	PASS	0	N/A	0.0	0.0	ALM029052	12/13/2026
04/08/2019	18:46	COHIGH_5	CO ZERO	183.00	0.13	0.13	0.1	40.00	20.0	PASS	0	N/A	0.0	0.0	SG9159413BAL	7/9/2026
04/08/2019	18:46	COHIGH_5	CO SPAN	183.00	181.55	-1.45	-0.7	40.00	20.0	PASS	0	N/A	0.0	0.0	ALM029052	12/13/2026
04/04/2019	09:56	COHIGH_5	CO ZERO	183.00	0.09	0.09	0.0	40.00	20.0	PASS	0	N/A	0.0	0.0	SG9159413BAL	7/9/2026
04/04/2019	09:56	COHIGH_5	CO SPAN	183.00	184.08	1.08	0.5	40.00	20.0	PASS	0	N/A	0.0	0.0	ALM029052	12/13/2026
04/01/2019	18:48	COHIGH_5	CO ZERO	182.50	0.31	0.31	0.2	40.00	20.0	PASS	0	N/A	49.5	100.0	SG9159413BAL	7/9/2026
04/01/2019	18:48	COHIGH_5	CO SPAN	182.50	183.91	1.41	0.7	40.00	20.0	PASS	0	N/A	50.8	100.0	ALM-063377	11/26/2026
03/31/2019	18:01	COHIGH_5	CO ZERO	182.50	0.31	0.31	0.2	40.00	20.0	PASS	0	N/A	0.0	0.0	SG9159413BAL	7/9/2026
03/31/2019	18:01	COHIGH_5	CO SPAN	182.50	183.74	1.24	0.6	40.00	20.0	PASS	0	N/A	0.0	0.0	ALM-063377	11/26/2026
03/27/2019	04:31	COHIGH_5	CO ZERO	182.50	0.17	0.17	0.1	40.00	20.0	PASS	0	N/A	0.0	0.0	SG9159413BAL	7/9/2026
03/27/2019	04:31	COHIGH_5	CO SPAN	182.50	183.22	0.72	0.4	40.00	20.0	PASS	0	N/A	0.0	0.0	ALM-063377	11/26/2026
03/26/2019	12:33	COHIGH_5	CO ZERO	182.50	0.25	0.25	0.1	40.00	20.0	PASS	0	N/A	0.0	0.0	SG9159413BAL	7/9/2026
03/26/2019	12:33	COHIGH_5	CO SPAN	182.50	183.21	0.71	0.4	40.00	20.0	PASS	0	N/A	50.5	100.0	ALM-063377	11/26/2026
03/18/2019	18:46	COHIGH_5	CO ZERO	182.50	0.16	0.16	0.1	40.00	20.0	PASS	0	N/A	49.1	100.0	SG9159413BAL	7/9/2026
03/18/2019	18:46	COHIGH_5	CO SPAN	182.50	182.34	-0.16	-0.1	40.00	20.0	PASS	0	N/A	50.1	100.0	ALM-063377	11/26/2026
03/17/2019	18:01	COHIGH_5	CO ZERO	182.50	0.15	0.15	0.1	40.00	20.0	PASS	0	N/A	0.0	0.0	SG9159413BAL	7/9/2026
03/17/2019	18:01	COHIGH_5	CO SPAN	182.50	182.52	0.02	0.1	40.00	20.0	PASS	0	N/A	0.0	0.0	ALM029052	12/13/2026
03/15/2019	18:16	COHIGH_5	CO ZERO	182.50	0.13	0.13	0.1	40.00	20.0	PASS	0	N/A	0.0	0.0	SG9159413BAL	7/9/2026
03/15/2019	18:16	COHIGH_5	CO SPAN	182.50	182.49	-0.01	0.0	40.00	20.0	PASS	0	N/A	50.7	100.0	ALM-063377	11/26/2026
03/11/2019	04:16	COHIGH_5	CO ZERO	182.50	0.10	0.10	0.1	40.00	20.0	PASS	0	N/A	0.0	0.0	SG9159413BAL	7/9/2026
03/11/2019	04:16	COHIGH_5	CO SPAN	182.50	182.19	-0.31	-0.2	40.00	20.0	PASS	0	N/A	0.0	0.0	ALM-063377	11/26/2026
03/06/2019	14:56	COHIGH_5	CO ZERO	182.50	0.05	0.05	0.0	40.00	20.0	PASS	0	N/A	0.0	0.0	SG9159413BAL	7/9/2026
03/06/2019	14:56	COHIGH_5	CO SPAN	182.50	182.01	-0.49	-0.2	40.00	20.0	PASS	0	N/A	50.5	100.0	ALM-063377	11/26/2026
03/05/2019	07:33	COHIGH_5	CO ZERO	182.50	0.31	0.31	0.2	40.00	20.0	PASS	0	N/A	50.2	100.0	SG9159413BAL	7/9/2026
03/05/2019	07:33	COHIGH_5	CO SPAN	182.50	184.88	2.38	1.2	40.00	20.0	PASS	0	N/A	50.3	100.0	ALM-063377	11/26/2026
03/04/2019	18:01	COHIGH_5	CO ZERO	182.50	0.29	0.29	0.1	40.00	20.0	PASS	0	N/A	50.4	100.0	SG9159413BAL	7/9/2026
03/04/2019	18:01	COHIGH_5	CO SPAN	182.50	184.88	2.38	1.2	40.00	20.0	PASS	0	N/A	50.6	100.0	ALM-063377	11/26/2026
03/02/2019	06:01	COHIGH_5	CO ZERO	182.50	0.31	0.31	0.2	40.00	20.0	PASS	0	N/A	0.0	0.0	SG9159413BAL	7/9/2026
03/02/2019	06:01	COHIGH_5	CO SPAN	182.50	184.49	1.99	1.0	40.00	20.0	PASS	0	N/A	50.9	100.0	ALM-063377	11/26/2026
02/26/2019	23:21	COHIGH_5	CO ZERO	182.50	0.23	0.23	0.1	40.00	20.0	PASS	0	N/A	0.0	0.0	SG9159413BAL	7/9/2026
02/26/2019	23:21	COHIGH_5	CO SPAN	182.50	184.20	1.70	0.9	40.00	20.0	PASS	0	N/A	0.0	0.0	ALM-063377	11/26/2026
02/25/2019	19:46	COHIGH_5	CO ZERO	182.50	0.23	0.23	0.1	40.00	20.0	PASS	0	N/A	50.9	100.0	SG9159413BAL	7/9/2026
02/25/2019	19:46	COHIGH_5	CO SPAN	182.50	184.22	1.72	0.9	40.00	20.0	PASS	0	N/A	50.6	100.0	ALM-063377	11/26/2026
02/19/2019	18:01	COHIGH_5	CO ZERO	182.50	0.15	0.15	0.1	40.00	20.0	PASS	0	N/A	0.0	0.0	SG9159413BAL	7/9/2026
02/19/2019	18:01	COHIGH_5	CO SPAN	182.50	183.32	0.82	0.4	40.00	20.0	PASS	0	N/A	0.0	0.0	ALM029052	12/13/2026
02/15/2019	17:46	COHIGH_5	CO ZERO	182.50	0.16	0.16	0.1	40.00	20.0	PASS	0	N/A	0.0	0.0	SG9159413BAL	7/9/2026
02/15/2019	17:46	COHIGH_5	CO SPAN	182.50	183.49	0.99	0.5	40.00	20.0	PASS	0	N/A	0.0	0.0	ALM-063377	11/26/2026
02/14/2019	13:40	COHIGH_5	CO ZERO	182.50	0.14	0.14	0.1	40.00	20.0	PASS	0	N/A	0.0	0.0	SG9159413BAL	7/9/2026
02/14/2019	13:40	COHIGH_5	CO SPAN	182.50	183.50	1.00	0.5	40.00	20.0	PASS	0	N/A	50.9	100.0	ALM-063377	11/26/2026
02/06/2019	17:16	COHIGH_5	CO ZERO	182.50	0.05	0.05	0.0	40.00	20.0	PASS	0	N/A	0.0	0.0	SG9159413BAL	7/9/2026
02/06/2019	17:16	COHIGH_5	CO SPAN	182.50	182.93	0.43	0.2	40.00	20.0	PASS	0	N/A	0.0	0.0	ALM-063377	11/26/2026
02/06/2019	15:00	COHIGH_5	CO ZERO	182.50	0.05	0.05	0.0	40.00	20.0	PASS	0	N/A	0.0	0.0	SG9159413BAL	7/9/2026
02/06/2019	15:00	COHIGH_5	CO SPAN	182.50	185.84	3.34	1.7	40.00	20.0	PASS	0	N/A	0.0	0.0	ALM-063377	11/26/2026

Daily Stack Calibration Report  
Generated: 2/11/2020

Company: McGrath Generating Station  
Plant: 251 N. Harbor Blvd.  
City/St: Oxnard, CA 93035  
Source: stack

Period Start: 1/1/2019  
Period End: 12/30/2019  
Included Calibrations: Daily (40CFR60)/(40CFR75)

Date	Time	Channel	CO	Type	Target	Actual	Diff	Error	Units	Part60 Allowable	WD	Error	Units	Part75 Allowable	Process	Gross MW	On	Process	Bottle ID	Expire Date
12/03/2019	09:31	COLOW_5	CO	ZERO	0.00	0.16	0.16	1.6	2.00	20.0	PASS	0	N/A	N/A	N/A	49.8	100.0	N/A	5G9167509BAL	2/12/2027
12/03/2019	09:31	COLOW_5	CO	SPAN	9.05	9.31	0.26	2.6	2.00	20.0	PASS	0	N/A	N/A	N/A	50.8	100.0	N/A	CC266925	1/9/2022
11/26/2019	07:01	COLOW_5	CO	SPAN	9.00	9.05	0.05	0.9	2.00	20.0	PASS	0	N/A	N/A	N/A	49.1	100.0	N/A	5G9167509BAL	2/12/2027
11/24/2019	17:16	COLOW_5	CO	ZERO	0.00	0.08	0.08	1.8	2.00	20.0	PASS	0	N/A	N/A	N/A	49.3	100.0	N/A	CC266925	1/9/2022
11/24/2019	17:16	COLOW_5	CO	SPAN	9.05	9.19	0.14	1.4	2.00	20.0	PASS	0	N/A	N/A	N/A	49.3	100.0	N/A	CC266925	1/9/2022
11/22/2019	14:50	COLOW_5	CO	ZERO	0.00	0.07	0.07	0.7	2.00	20.0	PASS	0	N/A	N/A	N/A	0.0	0.0	N/A	5G9167509BAL	2/12/2027
11/22/2019	14:50	COLOW_5	CO	SPAN	9.05	9.20	0.15	1.5	2.00	20.0	PASS	0	N/A	N/A	N/A	48.7	100.0	N/A	CC266925	1/9/2022
11/21/2019	12:44	COLOW_5	CO	ZERO	0.00	0.08	0.08	0.8	2.00	20.0	PASS	0	N/A	N/A	N/A	49.3	100.0	N/A	5G9167509BAL	2/12/2027
11/21/2019	12:44	COLOW_5	CO	SPAN	9.05	9.17	0.12	1.2	2.00	20.0	PASS	0	N/A	N/A	N/A	49.0	100.0	N/A	CC266925	1/9/2022
11/18/2019	17:01	COLOW_5	CO	ZERO	0.00	0.07	0.07	0.7	2.00	20.0	PASS	0	N/A	N/A	N/A	49.6	100.0	N/A	5G9167509BAL	2/12/2027
11/18/2019	17:01	COLOW_5	CO	SPAN	9.05	9.14	0.09	0.9	2.00	20.0	PASS	0	N/A	N/A	N/A	49.6	100.0	N/A	CC266925	1/9/2022
11/17/2019	17:16	COLOW_5	CO	ZERO	0.00	0.03	0.03	0.3	2.00	20.0	PASS	0	N/A	N/A	N/A	49.0	100.0	N/A	5G9167509BAL	2/12/2027
11/17/2019	17:16	COLOW_5	CO	SPAN	9.05	9.14	0.09	0.9	2.00	20.0	PASS	0	N/A	N/A	N/A	49.6	100.0	N/A	CC266925	1/9/2022
11/16/2019	17:16	COLOW_5	CO	ZERO	0.00	0.02	0.02	0.2	2.00	20.0	PASS	0	N/A	N/A	N/A	49.6	100.0	N/A	5G9167509BAL	2/12/2027
11/16/2019	17:16	COLOW_5	CO	SPAN	9.05	9.12	0.07	0.7	2.00	20.0	PASS	0	N/A	N/A	N/A	49.8	100.0	N/A	CC266925	1/9/2022
11/15/2019	17:16	COLOW_5	CO	ZERO	0.00	0.03	0.03	0.3	2.00	20.0	PASS	0	N/A	N/A	N/A	49.8	100.0	N/A	5G9167509BAL	2/12/2027
11/15/2019	17:16	COLOW_5	CO	SPAN	9.05	9.13	0.08	0.8	2.00	20.0	PASS	0	N/A	N/A	N/A	49.8	100.0	N/A	CC266925	1/9/2022
11/14/2019	06:16	COLOW_5	CO	ZERO	0.00	0.02	0.02	0.2	2.00	20.0	PASS	0	N/A	N/A	N/A	49.4	100.0	N/A	5G9167509BAL	2/12/2027
11/14/2019	06:16	COLOW_5	CO	SPAN	8.94	9.01	0.07	0.7	2.00	20.0	PASS	0	N/A	N/A	N/A	49.6	100.0	N/A	CC454217	9/28/2021
11/13/2019	16:18	COLOW_5	CO	ZERO	0.00	0.07	0.07	0.7	2.00	20.0	PASS	0	N/A	N/A	N/A	49.6	100.0	N/A	5G9167509BAL	2/12/2027
11/13/2019	16:18	COLOW_5	CO	SPAN	8.94	9.01	0.07	0.7	2.00	20.0	PASS	0	N/A	N/A	N/A	49.6	100.0	N/A	CC454217	9/28/2021
11/12/2019	17:16	COLOW_5	CO	ZERO	0.00	0.03	0.03	0.3	2.00	20.0	PASS	0	N/A	N/A	N/A	49.6	100.0	N/A	5G9167509BAL	2/12/2027
11/12/2019	17:16	COLOW_5	CO	SPAN	8.94	9.00	0.06	0.6	2.00	20.0	PASS	0	N/A	N/A	N/A	49.6	100.0	N/A	CC454217	9/28/2021
11/11/2019	16:16	COLOW_5	CO	ZERO	0.00	0.00	0.00	0.0	2.00	20.0	PASS	0	N/A	N/A	N/A	49.4	100.0	N/A	5G9167509BAL	2/12/2027
11/11/2019	16:16	COLOW_5	CO	SPAN	8.94	9.00	0.06	0.6	2.00	20.0	PASS	0	N/A	N/A	N/A	49.4	100.0	N/A	CC454217	9/28/2021
11/10/2019	17:46	COLOW_5	CO	ZERO	0.00	0.00	0.00	0.0	2.00	20.0	PASS	0	N/A	N/A	N/A	49.2	100.0	N/A	5G9167509BAL	2/12/2027
11/10/2019	17:46	COLOW_5	CO	SPAN	8.94	9.01	0.07	0.7	2.00	20.0	PASS	0	N/A	N/A	N/A	50.0	100.0	N/A	CC454217	9/28/2021
11/09/2019	17:01	COLOW_5	CO	ZERO	0.00	-0.01	-0.01	-0.1	2.00	20.0	PASS	0	N/A	N/A	N/A	49.8	100.0	N/A	5G9167509BAL	2/12/2027
11/09/2019	17:01	COLOW_5	CO	SPAN	8.94	8.98	0.04	0.4	2.00	20.0	PASS	0	N/A	N/A	N/A	49.8	100.0	N/A	CC454217	9/28/2021
11/08/2019	06:01	COLOW_5	CO	ZERO	0.00	0.00	0.00	0.0	2.00	20.0	PASS	0	N/A	N/A	N/A	49.8	100.0	N/A	5G9167509BAL	2/12/2027
11/08/2019	06:01	COLOW_5	CO	SPAN	8.94	8.96	0.02	0.2	2.00	20.0	PASS	0	N/A	N/A	N/A	49.8	100.0	N/A	CC454217	9/28/2021
11/07/2019	06:16	COLOW_5	CO	ZERO	0.00	-0.02	-0.02	-0.2	2.00	20.0	PASS	0	N/A	N/A	N/A	0.0	0.0	N/A	5G9167509BAL	2/12/2027
11/07/2019	06:16	COLOW_5	CO	SPAN	8.94	8.97	0.03	0.3	2.00	20.0	PASS	0	N/A	N/A	N/A	49.0	100.0	N/A	CC454217	9/28/2021
11/06/2019	13:46	COLOW_5	CO	ZERO	0.00	-0.01	-0.01	-0.1	2.00	20.0	PASS	0	N/A	N/A	N/A	49.0	100.0	N/A	5G9167509BAL	2/12/2027
11/06/2019	13:46	COLOW_5	CO	SPAN	8.94	8.93	0.01	0.1	2.00	20.0	PASS	0	N/A	N/A	N/A	50.1	100.0	N/A	CC454217	9/28/2021
11/06/2019	12:32	COLOW_5	CO	ZERO	0.00	0.14	0.14	1.4	2.00	20.0	PASS	0	N/A	N/A	N/A	50.0	100.0	N/A	5G9167509BAL	2/12/2027
11/06/2019	12:32	COLOW_5	CO	SPAN	8.94	9.18	0.24	2.4	2.00	20.0	PASS	0	N/A	N/A	N/A	49.8	100.0	N/A	CC454217	9/28/2021
11/05/2019	06:43	COLOW_5	CO	ZERO	0.00	0.12	0.12	1.2	2.00	20.0	PASS	0	N/A	N/A	N/A	49.9	100.0	N/A	5G9167509BAL	2/12/2027
11/05/2019	06:43	COLOW_5	CO	SPAN	8.94	9.15	0.21	2.1	2.00	20.0	PASS	0	N/A	N/A	N/A	49.8	100.0	N/A	CC454217	9/28/2021
11/04/2019	06:46	COLOW_5	CO	ZERO	0.00	0.09	0.09	0.9	2.00	20.0	PASS	0	N/A	N/A	N/A	49.9	100.0	N/A	5G9167509BAL	2/12/2027
11/04/2019	06:46	COLOW_5	CO	SPAN	8.94	9.14	0.20	2.0	2.00	20.0	PASS	0	N/A	N/A	N/A	49.8	100.0	N/A	CC454217	9/28/2021
11/03/2019	06:40	COLOW_5	CO	ZERO	0.00	0.11	0.11	1.1	2.00	20.0	PASS	0	N/A	N/A	N/A	49.9	100.0	N/A	5G9167509BAL	2/12/2027
11/03/2019	06:40	COLOW_5	CO	SPAN	8.94	9.11	0.17	1.7	2.00	20.0	PASS	0	N/A	N/A	N/A	49.8	100.0	N/A	CC454217	9/28/2021
11/02/2019	06:46	COLOW_5	CO	ZERO	0.00	0.09	0.09	0.9	2.00	20.0	PASS	0	N/A	N/A	N/A	49.8	100.0	N/A	5G9167509BAL	2/12/2027
11/02/2019	06:46	COLOW_5	CO	SPAN	8.94	9.10	0.16	1.6	2.00	20.0	PASS	0	N/A	N/A	N/A	49.8	100.0	N/A	CC454217	9/28/2021
11/01/2019	05:46	COLOW_5	CO	ZERO	0.00	0.06	0.06	0.6	2.00	20.0	PASS	0	N/A	N/A	N/A	0.0	0.0	N/A	5G9167509BAL	2/12/2027
11/01/2019	05:46	COLOW_5	CO	SPAN	8.94	9.05	0.11	1.1	2.00	20.0	PASS	0	N/A	N/A	N/A	0.0	0.0	N/A	CC454217	9/28/2021
10/31/2019	05:46	COLOW_5	CO	ZERO	0.00	0.02	0.02	0.2	2.00	20.0	PASS	0	N/A	N/A	N/A	0.0	0.0	N/A	5G9167509BAL	2/12/2027
10/31/2019	05:46	COLOW_5	CO	SPAN	8.94	9.05	0.11	1.1	2.00	20.0	PASS	0	N/A	N/A	N/A	0.0	0.0	N/A	CC454217	9/28/2021

Daily Stack Calibration Report

Company: McGrath Generating Station  
Plant: 251 N. Harbor Blvd.  
City/St: Oxnard, CA 93035  
Source: stack

Period Start: 1/1/2019  
Period End: 12/30/2019  
Included Calibrations: Daily (40CFR60)/(40CFR75)

Date	Time	Channel	Type	Target	Actual	Diff	Error %	Units	Fair60 Allowable	WD Error	Units	Part75 Allowable	Gross Mw	Process	On	Bottle ID	Expire Date
09/04/2019	17:01	COLOW_5	CO	0.00	0.05	0.05	0.5	2.00	20.0	PASS	0	N/A	0	N/A	N/A	CC165921	9/17/2026
09/04/2019	08:50	COLOW_5	SPAN	8.97	8.00	-0.97	0.3	2.00	20.0	PASS	0	N/A	0	N/A	N/A	CC328061	9/28/2021
09/04/2019	09:01	COLOW_5	SPAN	8.97	8.02	-0.95	0.2	2.00	20.0	PASS	0	N/A	0.0	0.0	0	CC165921	9/17/2026
09/04/2019	08:50	COLOW_5	SPAN	8.97	8.02	-0.95	0.2	2.00	20.0	PASS	0	N/A	0.0	0.0	0	CC328061	9/28/2021
09/04/2019	08:50	COLOW_5	SPAN	8.97	8.02	-0.95	0.2	2.00	20.0	PASS	0	N/A	48.0	100.0	0	CC165921	9/17/2026
09/03/2019	16:46	COLOW_5	CO	0.00	0.15	0.15	1.5	2.00	20.0	PASS	0	N/A	0	N/A	N/A	CC165921	9/17/2026
09/03/2019	16:46	COLOW_5	SPAN	8.97	9.16	0.19	1.9	2.00	20.0	PASS	0	N/A	0	N/A	N/A	CC165921	9/17/2026
09/03/2019	16:46	COLOW_5	SPAN	8.97	9.16	0.19	1.9	2.00	20.0	PASS	0	N/A	48.1	100.0	0	CC328061	9/28/2021
09/02/2019	17:46	COLOW_5	CO	0.00	0.14	0.14	1.4	2.00	20.0	PASS	0	N/A	0.0	0.0	0	CC165921	9/17/2026
09/02/2019	17:46	COLOW_5	SPAN	8.97	9.14	0.17	1.7	2.00	20.0	PASS	0	N/A	0.0	0.0	0	CC328061	9/28/2021
09/01/2019	18:01	COLOW_5	CO	0.00	0.15	0.15	1.5	2.00	20.0	PASS	0	N/A	0.0	0.0	0	CC165921	9/17/2026
09/01/2019	18:01	COLOW_5	SPAN	8.97	9.15	0.18	1.8	2.00	20.0	PASS	0	N/A	48.0	100.0	0	CC328061	9/28/2021
09/30/2019	14:01	COLOW_5	CO	0.00	0.15	0.15	1.5	2.00	20.0	PASS	0	N/A	0.0	0.0	0	CC165921	9/17/2026
08/30/2019	14:01	COLOW_5	SPAN	8.97	9.13	0.16	1.6	2.00	20.0	PASS	0	N/A	0.0	0.0	0	CC328061	9/28/2021
08/30/2019	14:01	COLOW_5	SPAN	8.97	9.13	0.16	1.6	2.00	20.0	PASS	0	N/A	0.0	0.0	0	CC165921	9/17/2026
08/25/2019	00:40	COLOW_5	CO	0.00	0.10	0.10	1.0	2.00	20.0	PASS	0	N/A	0.0	0.0	0	CC165921	9/17/2026
08/25/2019	00:40	COLOW_5	SPAN	8.97	9.10	0.13	1.3	2.00	20.0	PASS	0	N/A	46.4	100.0	0	CC328061	9/28/2021
08/24/2019	17:46	COLOW_5	CO	0.00	0.12	0.12	1.2	2.00	20.0	PASS	0	N/A	0.0	0.0	0	CC165921	9/17/2026
08/24/2019	17:46	COLOW_5	SPAN	8.97	9.10	0.13	1.3	2.00	20.0	PASS	0	N/A	48.3	100.0	0	CC328061	9/28/2021
08/19/2019	15:46	COLOW_5	CO	0.00	0.09	0.09	0.9	2.00	20.0	PASS	0	N/A	49.3	76.5	0	CC165921	9/17/2026
08/19/2019	15:46	COLOW_5	SPAN	8.97	9.07	0.10	1.0	2.00	20.0	PASS	0	N/A	0.0	0.0	0	CC328061	9/28/2021
08/13/2019	18:17	COLOW_5	CO	0.00	0.06	0.06	0.6	2.00	20.0	PASS	0	N/A	0.0	0.0	0	CC165921	9/17/2026
08/13/2019	18:17	COLOW_5	SPAN	8.97	9.05	0.08	0.8	2.00	20.0	PASS	0	N/A	0.0	0.0	0	CC328061	9/28/2021
08/12/2019	16:28	COLOW_5	CO	0.00	0.06	0.06	0.6	2.00	20.0	PASS	0	N/A	0.0	0.0	0	CC165921	9/17/2026
08/14/2019	16:28	COLOW_5	SPAN	8.97	9.06	0.09	0.9	2.00	20.0	PASS	0	N/A	48.0	100.0	0	CC328061	9/28/2021
08/14/2019	16:28	COLOW_5	SPAN	8.97	9.06	0.09	0.9	2.00	20.0	PASS	0	N/A	0.0	0.0	0	CC165921	9/17/2026
08/12/2019	14:01	COLOW_5	CO	0.00	0.03	0.03	0.3	2.00	20.0	PASS	0	N/A	0.0	0.0	0	CC165921	9/17/2026
08/12/2019	14:01	COLOW_5	SPAN	8.97	9.04	0.07	0.7	2.00	20.0	PASS	0	N/A	0.0	0.0	0	CC328061	9/28/2021
08/08/2019	06:29	COLOW_5	CO	0.00	0.04	0.04	0.4	2.00	20.0	PASS	0	N/A	0.0	0.0	0	CC165921	9/17/2026
08/08/2019	06:29	COLOW_5	SPAN	8.97	8.99	-0.02	0.2	2.00	20.0	PASS	0	N/A	49.0	100.0	0	CC328061	9/28/2021
08/05/2019	17:31	COLOW_5	CO	0.00	0.12	0.12	1.2	2.00	20.0	PASS	0	N/A	0.0	0.0	0	CC165921	9/17/2026
08/05/2019	17:31	COLOW_5	SPAN	8.97	9.04	0.07	0.7	2.00	20.0	PASS	0	N/A	49.3	100.0	0	CC328061	9/28/2021
08/04/2019	18:46	COLOW_5	CO	0.00	0.11	0.11	1.1	2.00	20.0	PASS	0	N/A	0.0	0.0	0	CC165921	9/17/2026
08/04/2019	18:46	COLOW_5	SPAN	8.97	9.06	0.09	0.9	2.00	20.0	PASS	0	N/A	48.6	100.0	0	CC328061	9/28/2021
08/02/2019	13:31	COLOW_5	CO	0.00	0.13	0.13	1.3	2.00	20.0	PASS	0	N/A	0.0	0.0	0	CC165921	9/17/2026
08/02/2019	13:31	COLOW_5	SPAN	8.97	9.02	0.05	0.5	2.00	20.0	PASS	0	N/A	0.0	0.0	0	CC328061	9/28/2021
08/01/2019	12:10	COLOW_5	CO	0.00	0.10	0.10	1.0	2.00	20.0	PASS	0	N/A	0.0	0.0	0	CC165921	9/17/2026
08/01/2019	12:10	COLOW_5	SPAN	8.97	9.01	0.04	0.4	2.00	20.0	PASS	0	N/A	49.6	100.0	0	CC328061	9/28/2021
07/28/2019	18:02	COLOW_5	CO	0.00	0.07	0.07	0.7	2.00	20.0	PASS	0	N/A	0.0	0.0	0	CC165921	9/17/2026
07/28/2019	18:02	COLOW_5	SPAN	8.97	9.01	0.04	0.4	2.00	20.0	PASS	0	N/A	0.0	0.0	0	CC328061	9/28/2021
07/24/2019	07:30	COLOW_5	CO	0.00	0.04	0.04	0.4	2.00	20.0	PASS	0	N/A	0.0	0.0	0	CC165921	9/17/2026
07/24/2019	07:30	COLOW_5	SPAN	8.97	8.99	-0.02	0.2	2.00	20.0	PASS	0	N/A	48.4	100.0	0	CC328061	9/28/2021
07/23/2019	11:01	COLOW_5	CO	0.00	0.39	0.39	3.9	2.00	20.0	PASS	0	N/A	0.0	0.0	0	CC165921	9/17/2026
07/23/2019	11:01	COLOW_5	SPAN	8.97	9.22	0.25	2.5	2.00	20.0	PASS	0	N/A	48.9	5.9	0	CC328061	9/28/2021
07/23/2019	11:01	COLOW_5	SPAN	8.97	9.22	0.25	2.5	2.00	20.0	PASS	0	N/A	0.0	0.0	0	CC165921	9/17/2026
07/22/2019	10:01	COLOW_5	CO	0.00	0.04	0.04	0.4	2.00	20.0	PASS	0	N/A	0.0	0.0	0	CC165921	9/17/2026
07/22/2019	10:01	COLOW_5	SPAN	8.97	9.20	0.23	2.3	2.00	20.0	PASS	0	N/A	49.2	100.0	0	CC328061	9/28/2021
07/19/2019	19:16	COLOW_5	CO	0.00	0.04	0.04	0.4	2.00	20.0	PASS	0	N/A	0.0	0.0	0	CC165921	9/17/2026
07/19/2019	19:16	COLOW_5	SPAN	8.97	9.19	0.22	2.2	2.00	20.0	PASS	0	N/A	48.5	100.0	0	CC328061	9/28/2021
07/16/2019	15:46	COLOW_5	CO	0.00	0.05	0.05	0.5	2.00	20.0	PASS	0	N/A	0.0	0.0	0	CC165921	9/17/2026
07/16/2019	15:46	COLOW_5	SPAN	8.97	9.17	0.20	2.0	2.00	20.0	PASS	0	N/A	49.0	100.0	0	CC328061	9/28/2021
07/08/2019	06:31	COLOW_5	CO	0.00	0.00	0.00	0.0	2.00	20.0	PASS	0	N/A	0.0	0.0	0	CC165921	9/17/2026
07/08/2019	06:31	COLOW_5	SPAN	8.97	9.15	0.18	1.8	2.00	20.0	PASS	0	N/A	48.9	100.0	0	CC328061	9/28/2021
06/29/2019	17:46	COLOW_5	CO	0.00	-0.01	-0.01	-0.1	2.00	20.0	PASS	0	N/A	0.0	0.0	0	CC165921	9/17/2026
06/29/2019	17:46	COLOW_5	SPAN	8.97	9.11	0.14	1.4	2.00	20.0	PASS	0	N/A	0.0	0.0	0	CC328061	9/28/2021

Daily Stack Calibration Report  
Generated: 2/11/2020

Company: McGrath Generating Station  
Plant: 251 N. Harbor Blvd.  
City/St: Oxnard, CA 93035  
Source: stack

Period Start: 1/1/2019  
Period End: 12/30/2019  
Included Calibrations: Daily (40CFR60)/(40CFR75)

Date	Time	Channel	Type	Target Units	Actual Units	Diff Units	Error %	Units	Part60 Allowable %	MP Error	Units	Part75 Allowable	Gross_MF_5	Process On	Bottle ID	Expire Date
03/17/2019	14:01	COLOW_5	CO	0.00	0.08	0.08	0.8	2.00	20.0	0	N/A	N/A	49.1	100.0 %	S69159413BHAL	7/9/2026
03/17/2019	14:01	COLOW_5	CO	0.00	0.08	-0.01	-0.1	2.00	20.0	0	N/A	N/A	50.1	100.0 %	CC280120	4/11/2021
03/16/2019	14:16	COLOW_5	CO	9.09	9.09	0.00	0.0	2.00	20.0	0	N/A	N/A	50.7	100.0 %	S69159413BHAL	7/9/2026
03/16/2019	14:16	COLOW_5	CO	9.09	9.09	0.00	0.0	2.00	20.0	0	N/A	N/A	50.7	100.0 %	CC280120	4/11/2021
03/11/2019	04:16	COLOW_5	CO	9.09	9.08	-0.01	-0.1	2.00	20.0	0	N/A	N/A	0.0	0.0 %	S69159413BHAL	7/9/2026
03/11/2019	04:16	COLOW_5	CO	9.09	9.08	-0.01	-0.1	2.00	20.0	0	N/A	N/A	0.0	0.0 %	CC280120	4/11/2021
03/06/2019	14:56	COLOW_5	CO	9.09	9.04	-0.05	-0.5	2.00	20.0	0	N/A	N/A	50.5	100.0 %	S69159413BHAL	7/9/2026
03/06/2019	14:56	COLOW_5	CO	9.09	9.04	-0.05	-0.5	2.00	20.0	0	N/A	N/A	50.5	100.0 %	CC280120	4/11/2021
03/05/2019	07:33	COLOW_5	CO	9.09	9.28	0.19	1.9	2.00	20.0	0	N/A	N/A	50.2	100.0 %	S69159413BHAL	7/9/2026
03/05/2019	07:33	COLOW_5	CO	9.09	9.28	0.19	1.9	2.00	20.0	0	N/A	N/A	50.2	100.0 %	CC280120	4/11/2021
03/04/2019	14:01	COLOW_5	CO	9.09	9.26	0.17	1.7	2.00	20.0	0	N/A	N/A	50.3	100.0 %	S69159413BHAL	7/9/2026
03/04/2019	14:01	COLOW_5	CO	9.09	9.26	0.17	1.7	2.00	20.0	0	N/A	N/A	50.3	100.0 %	CC280120	4/11/2021
03/02/2019	06:01	COLOW_5	CO	9.09	9.27	0.18	1.8	2.00	20.0	0	N/A	N/A	50.4	100.0 %	S69159413BHAL	7/9/2026
03/02/2019	06:01	COLOW_5	CO	9.09	9.27	0.18	1.8	2.00	20.0	0	N/A	N/A	50.4	100.0 %	CC280120	4/11/2021
02/26/2019	23:21	COLOW_5	CO	9.09	9.21	0.12	1.2	2.00	20.0	0	N/A	N/A	50.6	100.0 %	S69159413BHAL	7/9/2026
02/26/2019	23:21	COLOW_5	CO	9.09	9.21	0.12	1.2	2.00	20.0	0	N/A	N/A	50.6	100.0 %	CC280120	4/11/2021
02/25/2019	14:46	COLOW_5	CO	9.09	9.20	0.11	1.1	2.00	20.0	0	N/A	N/A	50.9	100.0 %	S69159413BHAL	7/9/2026
02/25/2019	14:46	COLOW_5	CO	9.09	9.20	0.11	1.1	2.00	20.0	0	N/A	N/A	50.9	100.0 %	CC280120	4/11/2021
02/19/2019	17:48	COLOW_5	CO	9.09	9.12	0.03	0.3	2.00	20.0	0	N/A	N/A	50.6	100.0 %	S69159413BHAL	7/9/2026
02/19/2019	17:48	COLOW_5	CO	9.09	9.12	0.03	0.3	2.00	20.0	0	N/A	N/A	50.6	100.0 %	CC280120	4/11/2021
02/15/2019	17:48	COLOW_5	CO	9.09	9.16	0.08	0.8	2.00	20.0	0	N/A	N/A	0.0	0.0 %	S69159413BHAL	7/9/2026
02/15/2019	17:48	COLOW_5	CO	9.09	9.16	0.08	0.8	2.00	20.0	0	N/A	N/A	0.0	0.0 %	CC280120	4/11/2021
02/14/2019	13:40	COLOW_5	CO	9.09	9.13	0.04	0.4	2.00	20.0	0	N/A	N/A	50.9	100.0 %	S69159413BHAL	7/9/2026
02/14/2019	13:40	COLOW_5	CO	9.09	9.13	0.04	0.4	2.00	20.0	0	N/A	N/A	50.9	100.0 %	CC280120	4/11/2021
02/06/2019	17:16	COLOW_5	CO	9.09	9.01	-0.08	-0.8	2.00	20.0	0	N/A	N/A	0.0	0.0 %	S69159413BHAL	7/9/2026
02/06/2019	17:16	COLOW_5	CO	9.09	9.01	-0.08	-0.8	2.00	20.0	0	N/A	N/A	0.0	0.0 %	CC280120	4/11/2021
02/06/2019	15:00	COLOW_5	CO	9.09	9.30	0.21	2.1	2.00	20.0	0	N/A	N/A	50.8	100.0 %	S69159413BHAL	7/9/2026
02/06/2019	15:00	COLOW_5	CO	9.09	9.30	0.21	2.1	2.00	20.0	0	N/A	N/A	50.8	100.0 %	CC280120	4/11/2021
02/05/2019	06:46	COLOW_5	CO	9.09	9.30	0.21	2.1	2.00	20.0	0	N/A	N/A	49.9	100.0 %	S69159413BHAL	7/9/2026
02/05/2019	06:46	COLOW_5	CO	9.09	9.30	0.21	2.1	2.00	20.0	0	N/A	N/A	49.9	100.0 %	CC280120	4/11/2021
02/04/2019	17:46	COLOW_5	CO	9.09	9.31	0.22	2.2	2.00	20.0	0	N/A	N/A	50.2	100.0 %	S69159413BHAL	7/9/2026
02/04/2019	17:46	COLOW_5	CO	9.09	9.31	0.22	2.2	2.00	20.0	0	N/A	N/A	50.2	100.0 %	CC280120	4/11/2021
02/04/2019	14:01	COLOW_5	CO	9.09	9.26	0.17	1.7	2.00	20.0	0	N/A	N/A	50.0	100.0 %	S69159413BHAL	7/9/2026
02/04/2019	14:01	COLOW_5	CO	9.09	9.26	0.17	1.7	2.00	20.0	0	N/A	N/A	50.0	100.0 %	CC280120	4/11/2021
02/03/2019	14:01	COLOW_5	CO	9.09	9.26	0.18	1.8	2.00	20.0	0	N/A	N/A	50.3	100.0 %	S69159413BHAL	7/9/2026
02/03/2019	14:01	COLOW_5	CO	9.09	9.26	0.18	1.8	2.00	20.0	0	N/A	N/A	50.3	100.0 %	CC280120	4/11/2021
02/02/2019	21:31	COLOW_5	CO	9.09	9.27	0.18	1.8	2.00	20.0	0	N/A	N/A	50.3	100.0 %	S69159413BHAL	7/9/2026
02/02/2019	21:31	COLOW_5	CO	9.09	9.27	0.18	1.8	2.00	20.0	0	N/A	N/A	50.3	100.0 %	CC280120	4/11/2021
02/01/2019	17:18	COLOW_5	CO	9.09	9.26	0.17	1.7	2.00	20.0	0	N/A	N/A	50.7	100.0 %	S69159413BHAL	7/9/2026
02/01/2019	17:18	COLOW_5	CO	9.09	9.26	0.17	1.7	2.00	20.0	0	N/A	N/A	50.7	100.0 %	CC280120	4/11/2021
01/29/2019	14:31	COLOW_5	CO	9.09	9.25	0.16	1.6	2.00	20.0	0	N/A	N/A	49.9	100.0 %	S69159413BHAL	7/9/2026
01/29/2019	14:31	COLOW_5	CO	9.09	9.25	0.16	1.6	2.00	20.0	0	N/A	N/A	49.9	100.0 %	CC280120	4/11/2021
01/28/2019	07:16	COLOW_5	CO	9.09	9.23	0.12	1.2	2.00	20.0	0	N/A	N/A	50.1	100.0 %	S69159413BHAL	7/9/2026
01/28/2019	07:16	COLOW_5	CO	9.09	9.23	0.12	1.2	2.00	20.0	0	N/A	N/A	50.1	100.0 %	CC280120	4/11/2021
01/26/2019	17:15	COLOW_5	CO	9.09	9.21	0.12	1.2	2.00	20.0	0	N/A	N/A	50.3	100.0 %	S69159413BHAL	7/9/2026
01/26/2019	17:15	COLOW_5	CO	9.09	9.21	0.12	1.2	2.00	20.0	0	N/A	N/A	50.3	100.0 %	CC280120	4/11/2021
01/23/2019	14:01	COLOW_5	CO	9.09	9.21	0.12	1.2	2.00	20.0	0	N/A	N/A	50.5	100.0 %	S69159413BHAL	7/9/2026
01/23/2019	14:01	COLOW_5	CO	9.09	9.21	0.12	1.2	2.00	20.0	0	N/A	N/A	50.5	100.0 %	CC280120	4/11/2021
01/24/2019	14:01	COLOW_5	CO	9.09	9.20	0.11	1.1	2.00	20.0	0	N/A	N/A	50.5	100.0 %	S69159413BHAL	7/9/2026
01/24/2019	14:01	COLOW_5	CO	9.09	9.20	0.11	1.1	2.00	20.0	0	N/A	N/A	50.5	100.0 %	CC280120	4/11/2021
01/23/2019	06:46	COLOW_5	CO	9.09	9.17	0.08	0.8	2.00	20.0	0	N/A	N/A				



Daily Stack Calibration Report  
Generated: 2/11/2020

Period Start: 1/1/2019  
Period End: 12/30/2019  
Included Calibrations: Daily (40CFR60)/(40CFR75)

Company: McGrath Generating Station  
Plant: 251 N. Harbor Blvd.  
City/St: Oxnard, CA 93035  
Source: stack

Date	Time	Channel	Type	Actual Units	Diff Units	Error %	Units	Part60 Allowable	MD Error	Units	Part75 Allowable	Gross MW	Process On	Bottle ID	Expire Date
11/12/2019	17:16	NOX_NHRH_5	NOX	0.11	0.11	0.1	20.00	10.0	PASS	0	N/A	49.6	100.0	SG9167509BAL	8/19/2027
11/12/2019	17:16	NOX_NHRH_5	NOX	179.34	-1.76	-0.9	20.00	10.0	PASS	0	N/A	49.6	100.0	SG9167509BAL	8/19/2027
11/12/2019	16:16	NOX_NHRH_5	NOX	0.00	0.12	0.1	20.00	10.0	PASS	0	N/A	49.6	100.0	SG9167509BAL	8/19/2027
11/12/2019	16:16	NOX_NHRH_5	NOX	181.10	-1.46	-0.7	20.00	10.0	PASS	0	N/A	49.4	100.0	SG9167509BAL	8/19/2027
11/12/2019	17:46	NOX_NHRH_5	NOX	179.44	-1.61	-0.9	20.00	10.0	PASS	0	N/A	49.2	100.0	SG9167509BAL	8/19/2027
11/09/2019	17:01	NOX_NHRH_5	NOX	0.00	0.11	0.1	20.00	10.0	PASS	0	N/A	50.0	100.0	SG9167509BAL	8/19/2027
11/09/2019	17:01	NOX_NHRH_5	NOX	178.99	-2.11	-1.1	20.00	10.0	PASS	0	N/A	50.0	100.0	SG9167509BAL	8/19/2027
11/08/2019	06:01	NOX_NHRH_5	NOX	0.00	0.11	0.1	20.00	10.0	PASS	0	N/A	49.8	100.0	SG9167509BAL	8/19/2027
11/07/2019	06:16	NOX_NHRH_5	NOX	179.68	-1.42	-0.7	20.00	10.0	PASS	0	N/A	0.0	0.0	SG9167509BAL	8/19/2027
11/07/2019	06:16	NOX_NHRH_5	NOX	0.11	0.11	0.1	20.00	10.0	PASS	0	N/A	49.0	100.0	SG9167509BAL	8/19/2027
11/06/2019	13:46	NOX_NHRH_5	NOX	179.53	-1.57	-0.8	20.00	10.0	PASS	0	N/A	50.1	100.0	SG9167509BAL	8/19/2027
11/06/2019	13:46	NOX_NHRH_5	NOX	0.11	0.11	0.1	20.00	10.0	PASS	0	N/A	50.0	100.0	SG9167509BAL	8/19/2027
11/06/2019	12:32	NOX_NHRH_5	NOX	178.96	-2.14	-1.1	20.00	10.0	PASS	0	N/A	49.8	100.0	SG9167509BAL	8/19/2027
11/06/2019	12:32	NOX_NHRH_5	NOX	0.11	0.11	0.1	20.00	10.0	PASS	0	N/A	49.0	100.0	SG9167509BAL	8/19/2027
11/05/2019	06:49	NOX_NHRH_5	NOX	179.09	-2.07	-1.0	20.00	10.0	PASS	0	N/A	49.0	100.0	SG9167509BAL	8/19/2027
11/05/2019	06:49	NOX_NHRH_5	NOX	0.19	0.19	0.1	20.00	10.0	PASS	0	N/A	49.0	100.0	SG9167509BAL	8/19/2027
11/04/2019	06:46	NOX_NHRH_5	NOX	179.19	-1.91	-1.0	20.00	10.0	PASS	0	N/A	49.0	100.0	SG9167509BAL	8/19/2027
11/04/2019	06:46	NOX_NHRH_5	NOX	0.18	0.18	0.1	20.00	10.0	PASS	0	N/A	49.0	100.0	SG9167509BAL	8/19/2027
11/03/2019	06:40	NOX_NHRH_5	NOX	179.00	-2.10	-1.1	20.00	10.0	PASS	0	N/A	49.0	100.0	SG9167509BAL	8/19/2027
11/03/2019	06:40	NOX_NHRH_5	NOX	0.00	0.18	0.1	20.00	10.0	PASS	0	N/A	49.0	100.0	SG9167509BAL	8/19/2027
11/02/2019	06:46	NOX_NHRH_5	NOX	179.16	-1.94	-1.0	20.00	10.0	PASS	0	N/A	49.0	100.0	SG9167509BAL	8/19/2027
11/02/2019	06:46	NOX_NHRH_5	NOX	0.19	0.19	0.1	20.00	10.0	PASS	0	N/A	49.0	100.0	SG9167509BAL	8/19/2027
11/01/2019	05:46	NOX_NHRH_5	NOX	179.87	-1.23	-0.6	20.00	10.0	PASS	0	N/A	49.0	100.0	SG9167509BAL	8/19/2027
11/01/2019	05:46	NOX_NHRH_5	NOX	0.15	0.15	0.1	20.00	10.0	PASS	0	N/A	49.0	100.0	SG9167509BAL	8/19/2027
10/31/2019	05:46	NOX_NHRH_5	NOX	180.24	-0.86	-0.4	20.00	10.0	PASS	0	N/A	49.0	100.0	SG9167509BAL	8/19/2027
10/30/2019	17:01	NOX_NHRH_5	NOX	0.18	0.18	0.1	20.00	10.0	PASS	0	N/A	0.0	0.0	SG9167509BAL	8/19/2027
10/30/2019	17:01	NOX_NHRH_5	NOX	180.51	-0.59	-0.3	20.00	10.0	PASS	0	N/A	0.0	0.0	SG9167509BAL	8/19/2027
10/30/2019	12:48	NOX_NHRH_5	NOX	0.11	0.11	0.1	20.00	10.0	PASS	0	N/A	0.0	0.0	SG9167509BAL	8/19/2027
10/30/2019	12:48	NOX_NHRH_5	NOX	180.52	-0.58	-0.3	20.00	10.0	PASS	0	N/A	0.0	0.0	SG9167509BAL	8/19/2027
10/29/2019	05:46	NOX_NHRH_5	NOX	0.11	0.11	0.1	20.00	10.0	PASS	0	N/A	0.0	0.0	SG9167509BAL	8/19/2027
10/29/2019	05:46	NOX_NHRH_5	NOX	179.10	-2.00	-1.0	20.00	10.0	PASS	0	N/A	0.0	0.0	SG9167509BAL	8/19/2027
10/28/2019	06:01	NOX_NHRH_5	NOX	0.19	0.19	0.1	20.00	10.0	PASS	0	N/A	0.0	0.0	SG9167509BAL	8/19/2027
10/28/2019	06:01	NOX_NHRH_5	NOX	179.63	-1.47	-0.7	20.00	10.0	PASS	0	N/A	0.0	0.0	SG9167509BAL	8/19/2027
10/25/2019	16:46	NOX_NHRH_5	NOX	0.00	0.17	0.1	20.00	10.0	PASS	0	N/A	48.9	100.0	SG9167509BAL	8/19/2027
10/25/2019	16:46	NOX_NHRH_5	NOX	179.41	-1.69	-0.8	20.00	10.0	PASS	0	N/A	49.7	100.0	SG9167509BAL	8/19/2027
10/24/2019	17:01	NOX_NHRH_5	NOX	0.00	0.23	0.1	20.00	10.0	PASS	0	N/A	0.0	0.0	SG9167509BAL	8/19/2027
10/24/2019	17:01	NOX_NHRH_5	NOX	179.22	-1.98	-0.9	20.00	10.0	PASS	0	N/A	0.0	0.0	SG9167509BAL	8/19/2027
10/24/2019	07:05	NOX_NHRH_5	NOX	176.60	-1.31	-0.6	20.00	10.0	PASS	0	N/A	49.5	82.4	SG9167509BAL	8/19/2027
10/24/2019	07:05	NOX_NHRH_5	NOX	0.11	0.11	0.1	20.00	10.0	PASS	0	N/A	47.9	100.0	SG9167509BAL	8/19/2027
10/23/2019	05:16	NOX_NHRH_5	NOX	176.31	-1.29	-0.6	20.00	10.0	PASS	0	N/A	0.0	0.0	SG9167509BAL	8/19/2027
10/23/2019	05:16	NOX_NHRH_5	NOX	0.11	0.11	0.1	20.00	10.0	PASS	0	N/A	0.0	0.0	SG9167509BAL	8/19/2027
10/22/2019	16:46	NOX_NHRH_5	NOX	177.60	-1.17	-0.6	20.00	10.0	PASS	0	N/A	0.0	0.0	SG9167509BAL	8/19/2027
10/22/2019	16:46	NOX_NHRH_5	NOX	0.11	0.11	0.1	20.00	10.0	PASS	0	N/A	0.0	0.0	SG9167509BAL	8/19/2027
10/21/2019	14:46	NOX_NHRH_5	NOX	176.83	-0.77	-0.4	20.00	10.0	PASS	0	N/A	48.8	82.4	SG9167509BAL	8/19/2027
10/21/2019	14:46	NOX_NHRH_5	NOX	0.11	0.11	0.1	20.00	10.0	PASS	0	N/A	0.0	0.0	SG9167509BAL	8/19/2027
10/20/2019	17:16	NOX_NHRH_5	NOX	176.52	-1.08	-0.5	20.00	10.0	PASS	0	N/A	0.0	0.0	SG9167509BAL	8/19/2027
10/20/2019	17:16	NOX_NHRH_5	NOX	0.11	0.11	0.1	20.00	10.0	PASS	0	N/A	0.0	0.0	SG9167509BAL	8/19/2027

Daily Stack Calibration Report

Generated: 2/11/2020

Company: McGrath Generating Station  
Plant: 251 N. Harbor Blvd.  
City/St: Oxnard, CA 93035  
Source: stack

Period Start: 1/1/2019  
Period End: 12/30/2019  
Included Calibrations: Daily (40CFR60)/(40CFR75)

Date	Time	Channel	Type	Target Units	Actual Units	Diff Units	Error %	Units	Part60 Allowable %	MD Error %	Units	Part75 Allowable %	Gross MW	Process On	Bottle ID	Expire Date
08/12/2019	14:01	NOX_NH3H_5	NOX	0.00	0.09	0.09	0.0	20.00	10.0	PASS	0	N/A	48.0	100.0 %	CCI49073	3/11/2026
08/12/2019	14:01	NOX_NH3H_5	NOX	0.00	0.41	0.41	0.0	20.00	10.0	PASS	0	N/A	48.0	100.0 %	CCI49073	3/11/2026
08/08/2019	09:29	NOX_NH3H_5	NOX	0.00	0.09	0.09	0.0	20.00	10.0	PASS	0	N/A	0.0	0.0 %	CCI49073	3/11/2026
08/08/2019	09:29	NOX_NH3H_5	NOX	0.00	0.33	0.33	0.0	20.00	10.0	PASS	0	N/A	0.0	0.0 %	CCI49073	3/11/2026
08/05/2019	17:31	NOX_NH3H_5	NOX	0.00	0.10	0.10	0.0	20.00	10.0	PASS	0	N/A	49.0	100.0 %	CCI49073	3/11/2026
08/05/2019	17:31	NOX_NH3H_5	NOX	0.00	0.01	0.01	0.0	20.00	10.0	PASS	0	N/A	49.0	100.0 %	CCI49073	3/11/2026
08/05/2019	17:31	NOX_NH3H_5	NOX	0.00	0.09	0.09	0.0	20.00	10.0	PASS	0	N/A	49.3	100.0 %	CCI49073	3/11/2026
08/04/2019	16:46	NOX_NH3H_5	NOX	0.00	0.11	0.11	0.0	20.00	10.0	PASS	0	N/A	48.6	100.0 %	CCI49073	3/11/2026
08/04/2019	16:46	NOX_NH3H_5	NOX	0.00	0.11	0.11	0.0	20.00	10.0	PASS	0	N/A	48.6	100.0 %	CCI49073	3/11/2026
08/02/2019	13:31	NOX_NH3H_5	NOX	0.00	0.49	0.49	0.0	20.00	10.0	PASS	0	N/A	0.0	0.0 %	CCI49073	3/11/2026
08/02/2019	13:31	NOX_NH3H_5	NOX	0.00	0.10	0.10	0.0	20.00	10.0	PASS	0	N/A	0.0	0.0 %	CCI49073	3/11/2026
08/01/2019	12:10	NOX_NH3H_5	NOX	0.00	0.39	0.39	0.0	20.00	10.0	PASS	0	N/A	0.0	0.0 %	CCI49073	3/11/2026
08/01/2019	12:10	NOX_NH3H_5	NOX	0.00	0.10	0.10	0.0	20.00	10.0	PASS	0	N/A	49.6	100.0 %	ALM029052	12/13/2026
07/28/2019	16:02	NOX_NH3H_5	NOX	0.00	0.10	0.10	0.0	20.00	10.0	PASS	0	N/A	0.0	0.0 %	CCI49073	3/11/2026
07/28/2019	16:02	NOX_NH3H_5	NOX	0.00	4.43	-4.43	-2.2	20.00	10.0	PASS	0	N/A	0.0	0.0 %	CCI49073	3/11/2026
07/24/2019	07:30	NOX_NH3H_5	NOX	0.00	0.11	0.11	0.0	20.00	10.0	PASS	0	N/A	0.0	0.0 %	CCI49073	3/11/2026
07/24/2019	07:30	NOX_NH3H_5	NOX	0.00	0.27	-0.27	-0.2	20.00	10.0	PASS	0	N/A	48.4	100.0 %	ALM029052	12/13/2026
07/23/2019	11:01	NOX_NH3H_5	NOX	0.00	0.11	0.11	0.0	20.00	10.0	PASS	0	N/A	48.9	5.9 %	CCI49073	3/11/2026
07/23/2019	11:01	NOX_NH3H_5	NOX	0.00	0.02	0.02	0.0	20.00	10.0	PASS	0	N/A	48.9	5.9 %	ALM029052	12/13/2026
07/22/2019	10:01	NOX_NH3H_5	NOX	0.00	0.10	0.10	0.0	20.00	10.0	PASS	0	N/A	49.2	100.0 %	CCI49073	3/11/2026
07/22/2019	10:01	NOX_NH3H_5	NOX	0.00	0.32	0.32	0.0	20.00	10.0	PASS	0	N/A	49.2	100.0 %	ALM029052	12/13/2026
07/19/2019	19:16	NOX_NH3H_5	NOX	0.00	0.11	0.11	0.0	20.00	10.0	PASS	0	N/A	48.5	100.0 %	CCI49073	3/11/2026
07/19/2019	19:16	NOX_NH3H_5	NOX	0.00	0.11	0.11	0.0	20.00	10.0	PASS	0	N/A	48.5	100.0 %	ALM029052	12/13/2026
07/19/2019	13:46	NOX_NH3H_5	NOX	0.00	0.11	0.11	0.0	20.00	10.0	PASS	0	N/A	49.0	100.0 %	CCI49073	3/11/2026
07/19/2019	13:46	NOX_NH3H_5	NOX	0.00	-0.16	-0.16	-0.1	20.00	10.0	PASS	0	N/A	49.0	100.0 %	ALM029052	12/13/2026
07/09/2019	05:31	NOX_NH3H_5	NOX	0.00	0.78	0.78	0.0	20.00	10.0	PASS	0	N/A	48.9	100.0 %	CCI49073	3/11/2026
07/08/2019	06:31	NOX_NH3H_5	NOX	0.00	0.71	0.71	0.0	20.00	10.0	PASS	0	N/A	48.9	100.0 %	ALM029052	12/13/2026
06/29/2019	17:46	NOX_NH3H_5	NOX	0.00	0.11	0.11	0.0	20.00	10.0	PASS	0	N/A	0.0	0.0 %	CCI49073	3/11/2026
06/29/2019	17:46	NOX_NH3H_5	NOX	0.00	0.82	0.82	0.0	20.00	10.0	PASS	0	N/A	0.0	0.0 %	ALM029052	12/13/2026
06/20/2019	10:12	NOX_NH3H_5	NOX	0.00	0.10	0.10	0.0	20.00	10.0	PASS	0	N/A	0.0	0.0 %	CCI49073	3/11/2026
06/20/2019	10:12	NOX_NH3H_5	NOX	0.00	0.97	0.97	0.0	20.00	10.0	PASS	0	N/A	0.0	0.0 %	ALM029052	12/13/2026
06/10/2019	16:31	NOX_NH3H_5	NOX	0.00	0.10	0.10	0.0	20.00	10.0	PASS	0	N/A	48.9	100.0 %	CCI49073	3/11/2026
06/10/2019	16:31	NOX_NH3H_5	NOX	0.00	1.03	1.03	0.0	20.00	10.0	PASS	0	N/A	48.9	100.0 %	ALM029052	12/13/2026
06/04/2019	06:31	NOX_NH3H_5	NOX	0.00	0.10	0.10	0.0	20.00	10.0	PASS	0	N/A	49.4	100.0 %	CCI49073	3/11/2026
06/04/2019	06:31	NOX_NH3H_5	NOX	0.00	1.51	1.51	0.8	20.00	10.0	PASS	0	N/A	49.4	100.0 %	ALM029052	12/13/2026
05/29/2019	07:51	NOX_NH3H_5	NOX	0.00	0.10	0.10	0.0	20.00	10.0	PASS	0	N/A	0.0	0.0 %	CCI49073	3/11/2026
05/29/2019	07:51	NOX_NH3H_5	NOX	0.00	1.07	1.07	0.5	20.00	10.0	PASS	0	N/A	0.0	0.0 %	ALM029052	12/13/2026
05/21/2019	07:10	NOX_NH3H_5	NOX	0.00	0.08	0.08	0.0	20.00	10.0	PASS	0	N/A	0.0	0.0 %	CCI49073	3/11/2026
05/21/2019	07:10	NOX_NH3H_5	NOX	0.00	0.95	0.95	0.5	20.00	10.0	PASS	0	N/A	0.0	0.0 %	ALM029052	12/13/2026
05/20/2019	13:30	NOX_NH3H_5	NOX	0.00	0.08	0.08	0.0	20.00	10.0	PASS	0	N/A	0.0	0.0 %	CCI49073	3/11/2026
05/20/2019	13:30	NOX_NH3H_5	NOX	0.00	1.02	1.02	0.5	20.00	10.0	PASS	0	N/A	0.0	0.0 %	ALM029052	12/13/2026
05/19/2019	14:44	NOX_NH3H_5	NOX	0.00	0.11	0.11	0.0	20.00	10.0	PASS	0	N/A	0.0	0.0 %	CCI49073	3/11/2026
05/19/2019	14:44	NOX_NH3H_5	NOX	0.00	0.36	0.36	0.2	20.00	10.0	PASS	0	N/A	0.0	0.0 %	ALM029052	12/13/2026
05/17/2019	16:15	NOX_NH3H_5	NOX	0.00	0.31	0.31	0.1	20.00	10.0	PASS	0	N/A	0.0	0.0 %	CCI49073	3/11/2026
05/17/2019	16:15	NOX_NH3H_5	NOX	0.00	0.31	0.31	0.1	20.00	10.0	PASS	0	N/A	0.0	0.0 %	ALM029052	12/13/2026
05/06/2019	15:00	NOX_NH3H_5	NOX	0.00	0.11	0.11	0.0	20.00	10.0	PASS	0	N/A	0.0	0.0 %	CCI49073	3/11/2026
05/06/2019	15:00	NOX_NH3H_5	NOX	0.00	-1.24	-1.24	-0.6	20.00	10.0	PASS	0	N/A	49.6	100.0 %	ALM029052	12/13/2026
04/30/2019	18:01	NOX_NH3H_5	NOX	0.00	0.21	0.21	0.1	20.00	10.0	PASS	0	N/A	50.0	100.0 %	SG9159413BAL	7/9/2026
04/30/2019	18:01	NOX_NH3H_5	NOX	0.00	1.68	-1.68	-0.8	20.00	10.0	PASS	0	N/A	50.0	100.0 %	ALM029052	12/13/2026
04/25/2019	18:46	NOX_NH3H_5	NOX	0.00	0.11	0.11	0.0	20.00	10.0	PASS	0	N/A	50.0	100.0 %	SG9159413BAL	7/9/2026
04/25/2019	18:46	NOX_NH3H_5	NOX	0.00	0.11	0.11	0.0	20.00	10.0	PASS	0	N/A	50.0	100.0 %	ALM029052	12/13/2026
04/25/2019	18:46	NOX_NH3H_5	NOX	179.10	177.26	-1.84	-0.9	20.00	10.0	PASS	0	N/A	50.0	100.0 %	SG9159413BAL	7/9/2026



Daily Stack Calibration Report  
Generated: 2/11/2020

Company: McGrath Generating Station  
Plant: 251 N. Harbor Blvd.  
City/St: Oxnard, CA 93035  
Source: stack

Period Start: 1/1/2019  
Period End: 12/30/2019  
Included Calibrations: Daily (40CFR60)/(40CFR75)

Date	Time	Channel	Type	Target Units	Actual Units	Diff Units	Error %	Units	Part60 Allowable %	WD Error %	Units	Part75 Allowable %	Gross MW	Process On	Bottle ID	Expire Date
11/02/2019	05:46	NOK NH3L.5	NOK ZERO	0.00	0.03	0.03	0.1	1.00	10.0	0	N/A	N/A	49.9	100.0 %	CC149073	8/19/2021
11/02/2019	05:46	NOK NH3L.5	NOK ZERO	0.04	0.04	0.00	0.4	1.00	10.0	0	N/A	N/A	49.8	100.0 %	CC149073	8/19/2021
11/01/2019	05:46	NOK NH3L.5	NOK ZERO	0.04	0.04	0.00	0.7	1.00	10.0	0	N/A	N/A	0.0	0.0 %	CC149073	8/19/2021
11/01/2019	05:46	NOK NH3L.5	NOK ZERO	9.11	9.11	0.00	0.3	1.00	10.0	0	N/A	N/A	0.0	0.0 %	CC149073	8/19/2021
10/31/2019	05:46	NOK NH3L.5	NOK ZERO	9.11	9.11	0.00	0.7	1.00	10.0	0	N/A	N/A	0.0	0.0 %	CC149073	8/19/2021
10/30/2019	17:01	NOK NH3L.5	NOK ZERO	9.04	9.11	0.07	0.4	1.00	10.0	0	N/A	N/A	49.0	100.0 %	CC149073	8/19/2021
10/30/2019	17:01	NOK NH3L.5	NOK ZERO	9.04	9.12	0.08	0.8	1.00	10.0	0	N/A	N/A	0.0	0.0 %	CC149073	8/19/2021
10/30/2019	12:48	NOK NH3L.5	NOK ZERO	9.00	9.00	0.00	0.0	1.00	10.0	0	N/A	N/A	0.0	0.0 %	CC149073	8/19/2021
10/30/2019	12:48	NOK NH3L.5	NOK ZERO	9.08	9.08	0.00	0.4	1.00	10.0	0	N/A	N/A	0.0	0.0 %	CC149073	8/19/2021
10/29/2019	05:46	NOK NH3L.5	NOK ZERO	0.00	0.03	0.03	0.3	1.00	10.0	0	N/A	N/A	0.0	0.0 %	CC149073	8/19/2021
10/29/2019	05:46	NOK NH3L.5	NOK ZERO	9.04	9.04	0.00	0.0	1.00	10.0	0	N/A	N/A	0.0	0.0 %	CC149073	8/19/2021
10/28/2019	06:01	NOK NH3L.5	NOK ZERO	9.04	9.04	0.00	0.4	1.00	10.0	0	N/A	N/A	0.0	0.0 %	CC149073	8/19/2021
10/28/2019	06:01	NOK NH3L.5	NOK ZERO	9.04	9.08	0.04	0.4	1.00	10.0	0	N/A	N/A	49.9	100.0 %	CC149073	8/19/2021
10/25/2019	16:46	NOK NH3L.5	NOK ZERO	9.04	9.06	0.02	0.2	1.00	10.0	0	N/A	N/A	49.7	100.0 %	CC149073	8/19/2021
10/24/2019	17:01	NOK NH3L.5	NOK ZERO	9.08	9.05	-0.03	0.6	1.00	10.0	0	N/A	N/A	0.0	0.0 %	CC149073	8/19/2021
10/24/2019	07:05	NOK NH3L.5	NOK ZERO	9.04	9.02	-0.02	0.2	1.00	10.0	0	N/A	N/A	0.0	0.0 %	CC149073	8/19/2021
10/23/2019	05:16	NOK NH3L.5	NOK ZERO	9.00	9.02	0.02	0.2	1.00	10.0	0	N/A	N/A	49.5	100.0 %	CC149073	8/19/2021
10/23/2019	05:16	NOK NH3L.5	NOK ZERO	9.04	9.05	0.01	0.1	1.00	10.0	0	N/A	N/A	47.9	100.0 %	CC149073	8/19/2021
10/22/2019	16:46	NOK NH3L.5	NOK ZERO	9.00	9.03	0.03	0.3	1.00	10.0	0	N/A	N/A	0.0	0.0 %	CC149073	8/19/2021
10/22/2019	16:46	NOK NH3L.5	NOK ZERO	9.04	9.06	0.02	0.2	1.00	10.0	0	N/A	N/A	0.0	0.0 %	CC149073	8/19/2021
10/21/2019	14:46	NOK NH3L.5	NOK ZERO	9.00	9.03	0.03	0.3	1.00	10.0	0	N/A	N/A	48.8	100.0 %	CC149073	8/19/2021
10/20/2019	17:16	NOK NH3L.5	NOK ZERO	9.04	9.08	0.04	0.4	1.00	10.0	0	N/A	N/A	48.8	100.0 %	CC149073	8/19/2021
10/20/2019	17:16	NOK NH3L.5	NOK ZERO	9.00	9.03	0.03	0.3	1.00	10.0	0	N/A	N/A	48.8	100.0 %	CC149073	8/19/2021
10/19/2019	17:01	NOK NH3L.5	NOK ZERO	9.04	9.06	0.02	0.2	1.00	10.0	0	N/A	N/A	50.2	100.0 %	CC149073	8/19/2021
10/19/2019	17:01	NOK NH3L.5	NOK ZERO	9.00	9.03	0.03	0.3	1.00	10.0	0	N/A	N/A	0.0	0.0 %	CC149073	8/19/2021
10/18/2019	05:46	NOK NH3L.5	NOK ZERO	9.04	9.06	0.02	0.2	1.00	10.0	0	N/A	N/A	0.0	0.0 %	CC149073	8/19/2021
10/18/2019	05:46	NOK NH3L.5	NOK ZERO	9.00	9.02	0.02	0.2	1.00	10.0	0	N/A	N/A	0.0	0.0 %	CC149073	8/19/2021
10/17/2019	16:01	NOK NH3L.5	NOK ZERO	9.04	9.05	0.01	0.1	1.00	10.0	0	N/A	N/A	0.0	0.0 %	CC149073	8/19/2021
10/17/2019	16:01	NOK NH3L.5	NOK ZERO	9.04	9.03	-0.01	-0.1	1.00	10.0	0	N/A	N/A	0.0	0.0 %	CC149073	8/19/2021
10/16/2019	05:16	NOK NH3L.5	NOK ZERO	9.00	9.02	0.02	0.2	1.00	10.0	0	N/A	N/A	0.0	0.0 %	CC149073	8/19/2021
10/16/2019	05:16	NOK NH3L.5	NOK ZERO	9.04	9.07	0.03	0.3	1.00	10.0	0	N/A	N/A	49.3	100.0 %	CC149073	8/19/2021
10/15/2019	17:11	NOK NH3L.5	NOK ZERO	9.00	9.06	0.06	0.6	1.00	10.0	0	N/A	N/A	0.0	0.0 %	CC149073	8/19/2021
10/15/2019	17:11	NOK NH3L.5	NOK ZERO	9.04	9.03	-0.01	-0.1	1.00	10.0	0	N/A	N/A	0.0	0.0 %	CC149073	8/19/2021
10/08/2019	18:01	NOK NH3L.5	NOK ZERO	9.04	9.05	0.01	0.1	1.00	10.0	0	N/A	N/A	0.0	0.0 %	CC149073	8/19/2021
10/07/2019	17:46	NOK NH3L.5	NOK ZERO	9.00	9.02	0.02	0.2	1.00	10.0	0	N/A	N/A	0.0	0.0 %	CC149073	8/19/2021
10/06/2019	17:16	NOK NH3L.5	NOK ZERO	9.04	9.05	0.01	0.1	1.00	10.0	0	N/A	N/A	48.6	100.0 %	CC149073	8/19/2021
10/06/2019	17:16	NOK NH3L.5	NOK ZERO	9.00	9.02	0.02	0.2	1.00	10.0	0	N/A	N/A	48.6	100.0 %	CC149073	8/19/2021
10/05/2019	17:16	NOK NH3L.5	NOK ZERO	9.00	9.03	0.03	0.3	1.00	10.0	0	N/A	N/A	48.8	100.0 %	CC149073	8/19/2021
10/05/2019	17:16	NOK NH3L.5	NOK ZERO	9.04	9.08	0.04	0.4	1.00	10.0	0	N/A	N/A	48.8	100.0 %	CC149073	8/19/2021
10/02/2019	18:01	NOK NH3L.5	NOK ZERO	9.00	9.06	0.06	0.6	1.00	10.0	0	N/A	N/A	0.0	0.0 %	CC149073	8/19/2021
10/02/2019	18:01	NOK NH3L.5	NOK ZERO	9.04	9.11	0.07	0.7	1.00	10.0	0	N/A	N/A	0.0	0.0 %	CC149073	8/19/2021
10/02/2019	09:24	NOK NH3L.5	NOK ZERO	9.00	9.00	0.00	0.0	1.00	10.0	0	N/A	N/A	0.0	0.0 %	CC149073	8/19/2021
10/02/2019	09:24	NOK NH3L.5	NOK ZERO	9.04	9.01	-0.03	-0.3	1.00	10.0	0	N/A	N/A	0.0	0.0 %	CC149073	8/19/2021

Daily Stack Calibration Report  
Generated: 2/11/2020

Company: McGrath Generating Station  
Plant: 251 N. Harbor Blvd,  
City/St: Oxnard, CA 93035  
Source: Stack

Period Start: 1/1/2019  
Period End: 12/30/2019  
Included Calibrations: Daily (40CFR60)/(40CFR75)

Date	Time	Channel	Type	Target Units	Actual Units	Diff Units	Error %	Units	Part60 Allowable %	MD Error %	Units	Part75 Allowable	Gross_MW	Process On	Bottle ID	Expire Date
07/16/2019	13:46	NOX_NH3L_5	NOX	0.00	0.01	0.01	0.1	1.00	10.0	0	N/A	N/A	48.5	100.0 %	ALM029052	12/13/2026
07/16/2019	13:46	NOX_NH3L_5	ZERO	9.07	9.10	0.03	0.3	1.00	10.0	0	N/A	N/A	48.5	100.0 %	CC328061	9/28/2021
07/16/2019	13:46	NOX_NH3L_5	NOX	0.00	0.01	0.01	0.1	1.00	10.0	0	N/A	N/A	49.0	100.0 %	ALM029052	12/13/2026
07/16/2019	13:46	NOX_NH3L_5	ZERO	9.07	9.07	0.00	0.0	1.00	10.0	0	N/A	N/A	49.0	100.0 %	CC328061	9/28/2021
06/29/2019	17:46	NOX_NH3L_5	NOX	0.00	0.05	0.05	0.2	1.00	10.0	0	N/A	N/A	48.9	100.0 %	ALM029052	12/13/2026
06/29/2019	17:46	NOX_NH3L_5	ZERO	9.07	9.15	0.08	0.8	1.00	10.0	0	N/A	N/A	48.9	100.0 %	CC328061	9/28/2021
06/20/2019	10:12	NOX_NH3L_5	NOX	0.00	0.01	0.01	0.1	1.00	10.0	0	N/A	N/A	0.0	0.0 %	ALM029052	12/13/2026
06/20/2019	10:12	NOX_NH3L_5	ZERO	9.07	9.17	0.10	1.0	1.00	10.0	0	N/A	N/A	0.0	0.0 %	CC328061	9/28/2021
06/10/2019	15:31	NOX_NH3L_5	NOX	0.00	0.01	0.01	0.1	1.00	10.0	0	N/A	N/A	49.9	100.0 %	ALM029052	12/13/2026
06/10/2019	15:31	NOX_NH3L_5	ZERO	9.07	9.18	0.11	1.1	1.00	10.0	0	N/A	N/A	49.9	100.0 %	CC328061	9/28/2021
06/04/2019	06:31	NOX_NH3L_5	NOX	0.00	0.00	0.00	0.0	1.00	10.0	0	N/A	N/A	49.4	100.0 %	ALM029052	12/13/2026
06/04/2019	06:31	NOX_NH3L_5	ZERO	9.07	9.18	0.11	1.1	1.00	10.0	0	N/A	N/A	49.4	100.0 %	CC328061	9/28/2021
05/29/2019	07:51	NOX_NH3L_5	NOX	0.00	0.00	0.00	0.0	1.00	10.0	0	N/A	N/A	0.0	0.0 %	ALM029052	12/13/2026
05/29/2019	07:51	NOX_NH3L_5	ZERO	9.07	9.14	0.07	0.7	1.00	10.0	0	N/A	N/A	0.0	0.0 %	CC328061	9/28/2021
05/21/2019	07:10	NOX_NH3L_5	NOX	0.00	0.00	0.00	0.0	1.00	10.0	0	N/A	N/A	0.0	0.0 %	ALM029052	12/13/2026
05/21/2019	07:10	NOX_NH3L_5	ZERO	9.07	9.16	0.09	0.9	1.00	10.0	0	N/A	N/A	0.0	0.0 %	CC328061	9/28/2021
05/20/2019	13:30	NOX_NH3L_5	NOX	0.00	0.00	0.00	0.0	1.00	10.0	0	N/A	N/A	0.0	0.0 %	ALM029052	12/13/2026
05/20/2019	13:30	NOX_NH3L_5	ZERO	9.07	9.12	0.05	0.5	1.00	10.0	0	N/A	N/A	0.0	0.0 %	CC328061	9/28/2021
05/19/2019	14:44	NOX_NH3L_5	NOX	0.00	0.00	0.00	0.0	1.00	10.0	0	N/A	N/A	0.0	0.0 %	ALM029052	12/13/2026
05/19/2019	14:44	NOX_NH3L_5	ZERO	9.07	9.09	0.02	0.2	1.00	10.0	0	N/A	N/A	0.0	0.0 %	CC328061	9/28/2021
05/17/2019	15:15	NOX_NH3L_5	NOX	0.00	0.00	0.00	0.0	1.00	10.0	0	N/A	N/A	0.0	0.0 %	ALM029052	12/13/2026
05/17/2019	15:15	NOX_NH3L_5	ZERO	9.07	9.11	0.04	0.4	1.00	10.0	0	N/A	N/A	0.0	0.0 %	CC328061	9/28/2021
05/06/2019	15:00	NOX_NH3L_5	NOX	0.00	0.00	0.00	0.0	1.00	10.0	0	N/A	N/A	0.0	0.0 %	ALM029052	12/13/2026
05/06/2019	15:00	NOX_NH3L_5	ZERO	9.07	9.08	0.01	0.1	1.00	10.0	0	N/A	N/A	0.0	0.0 %	CC328061	9/28/2021
04/30/2019	18:01	NOX_NH3L_5	NOX	0.00	0.06	0.06	0.6	1.00	10.0	0	N/A	N/A	49.6	100.0 %	ALM029052	12/13/2026
04/30/2019	18:01	NOX_NH3L_5	ZERO	9.07	9.17	0.10	1.0	1.00	10.0	0	N/A	N/A	49.6	100.0 %	CC328061	9/28/2021
04/25/2019	18:46	NOX_NH3L_5	NOX	0.00	0.03	0.03	0.3	1.00	10.0	0	N/A	N/A	50.0	100.0 %	ALM029052	12/13/2026
04/25/2019	18:46	NOX_NH3L_5	ZERO	9.07	9.12	0.05	0.5	1.00	10.0	0	N/A	N/A	50.0	100.0 %	CC328061	9/28/2021
04/24/2019	18:01	NOX_NH3L_5	NOX	0.00	0.05	0.05	0.5	1.00	10.0	0	N/A	N/A	50.1	100.0 %	ALM029052	12/13/2026
04/24/2019	18:01	NOX_NH3L_5	ZERO	9.07	9.14	0.07	0.7	1.00	10.0	0	N/A	N/A	50.1	100.0 %	CC328061	9/28/2021
04/22/2019	19:03	NOX_NH3L_5	NOX	0.00	0.05	0.05	0.5	1.00	10.0	0	N/A	N/A	0.0	0.0 %	ALM029052	12/13/2026
04/22/2019	19:03	NOX_NH3L_5	ZERO	9.07	9.08	0.01	0.1	1.00	10.0	0	N/A	N/A	0.0	0.0 %	CC328061	9/28/2021
04/21/2019	19:01	NOX_NH3L_5	NOX	0.00	0.07	0.07	0.7	1.00	10.0	0	N/A	N/A	0.0	0.0 %	ALM029052	12/13/2026
04/21/2019	19:01	NOX_NH3L_5	ZERO	9.07	9.15	0.08	0.8	1.00	10.0	0	N/A	N/A	0.0	0.0 %	CC328061	9/28/2021
04/14/2019	15:01	NOX_NH3L_5	NOX	0.00	0.03	0.03	0.3	1.00	10.0	0	N/A	N/A	0.0	0.0 %	ALM029052	12/13/2026
04/14/2019	15:01	NOX_NH3L_5	ZERO	9.07	9.13	0.06	0.6	1.00	10.0	0	N/A	N/A	0.0	0.0 %	CC328061	9/28/2021
04/13/2019	18:16	NOX_NH3L_5	NOX	0.00	0.04	0.04	0.4	1.00	10.0	0	N/A	N/A	49.8	100.0 %	ALM029052	12/13/2026
04/13/2019	18:16	NOX_NH3L_5	ZERO	9.07	9.15	0.08	0.8	1.00	10.0	0	N/A	N/A	49.8	100.0 %	CC328061	9/28/2021
04/12/2019	05:33	NOX_NH3L_5	NOX	0.00	0.04	0.04	0.4	1.00	10.0	0	N/A	N/A	0.0	0.0 %	ALM029052	12/13/2026
04/12/2019	05:33	NOX_NH3L_5	ZERO	9.07	9.07	0.00	0.0	1.00	10.0	0	N/A	N/A	0.0	0.0 %	CC328061	9/28/2021
04/11/2019	12:46	NOX_NH3L_5	NOX	0.00	0.06	0.06	0.6	1.00	10.0	0	N/A	N/A	0.0	0.0 %	ALM029052	12/13/2026
04/11/2019	12:46	NOX_NH3L_5	ZERO	9.07	9.17	0.10	1.0	1.00	10.0	0	N/A	N/A	0.0	0.0 %	CC328061	9/28/2021
04/09/2019	18:46	NOX_NH3L_5	NOX	0.00	0.07	0.07	0.7	1.00	10.0	0	N/A	N/A	0.0	0.0 %	ALM029052	12/13/2026
04/09/2019	18:46	NOX_NH3L_5	ZERO	9.07	9.19	0.12	1.2	1.00	10.0	0	N/A	N/A	0.0	0.0 %	CC328061	9/28/2021
04/04/2019	09:56	NOX_NH3L_5	NOX	0.00	0.00	0.00	0.0	1.00	10.0	0	N/A	N/A	0.0	0.0 %	ALM029052	12/13/2026
04/04/2019	09:56	NOX_NH3L_5	ZERO	9.07	9.10	0.03	0.3	1.00	10.0	0	N/A	N/A	0.0	0.0 %	CC328061	9/28/2021
04/01/2019	18:48	NOX_NH3L_5	NOX	0.00	0.05	0.05	0.5	1.00	10.0	0	N/A	N/A	0.0	0.0 %	ALM-063377	11/26/2026
04/01/2019	18:48	NOX_NH3L_5	ZERO	8.76	8.96	0.20	2.0	1.00	10.0	0	N/A	N/A	0.0	0.0 %	CC280120	4/11/2021
03/31/2019	18:01	NOX_NH3L_5	NOX	0.00	0.07	0.07	0.7	1.00	10.0	0	N/A	N/A	49.5	100.0 %	ALM-063377	11/26/2026
03/31/2019	18:01	NOX_NH3L_5	ZERO	8.76	9.00	0.24	2.4	1.00	10.0	0	N/A	N/A	49.5	100.0 %	CC280120	4/11/2021

Company: McGrath Generating Station  
Plant: 251 N. Harbor Blvd.  
City/St: Oxnard, CA 93035  
Source: stack

Daily Stack Calibration Report  
Generated: 2/11/2020

Period Start: 1/1/2019  
Period End: 12/30/2019  
Included Calibrations: Daily (40CFR60)/(40CFR75)

Date	Time	Channel	Type	Target	Actual	Diff	Error %	Units	Part60 Allowable	MD Error	Units	Part75 Allowable	Units	Gross MW	Process	On	Bottle ID	Expire Date
01/26/2019	17:15	NOX NH3L	NOX	8.76	8.83	0.07	0.8	1.00	10.0	0	N/A	N/A	N/A	49.9	100.0 %		CC100080	8/21/2026
01/26/2019	17:15	NOX NH3L	NOX	8.76	8.83	0.07	0.8	1.00	10.0	0	N/A	N/A	N/A	49.9	100.0 %		CC100080	8/21/2026
01/25/2019	16:01	NOX NH3L	NOX	8.76	8.86	0.10	1.0	1.00	10.0	0	N/A	N/A	N/A	50.1	100.0 %		CC100080	8/21/2026
01/24/2019	16:01	NOX NH3L	NOX	8.76	8.86	0.10	1.0	1.00	10.0	0	N/A	N/A	N/A	50.2	100.0 %		CC100080	8/21/2026
01/24/2019	16:01	NOX NH3L	NOX	8.76	8.87	0.11	1.1	1.00	10.0	0	N/A	N/A	N/A	50.6	100.0 %		CC100080	8/21/2026
01/23/2019	06:46	NOX NH3L	NOX	8.76	8.90	0.14	1.4	1.00	10.0	0	N/A	N/A	N/A	50.6	100.0 %		CC100080	8/21/2026
01/22/2019	07:13	NOX NH3L	NOX	8.76	8.88	0.12	1.2	1.00	10.0	0	N/A	N/A	N/A	49.8	100.0 %		CC100080	8/21/2026
01/19/2019	17:16	NOX NH3L	NOX	8.76	8.87	0.11	1.1	1.00	10.0	0	N/A	N/A	N/A	51.0	100.0 %		CC100080	8/21/2026
01/18/2019	07:01	NOX NH3L	NOX	8.76	8.90	0.14	1.4	1.00	10.0	0	N/A	N/A	N/A	50.0	100.0 %		CC100080	8/21/2026
01/16/2019	17:48	NOX NH3L	NOX	8.76	8.89	0.13	1.3	1.00	10.0	0	N/A	N/A	N/A	50.8	100.0 %		CC100080	8/21/2026
01/14/2019	11:33	NOX NH3L	NOX	8.76	8.92	0.16	1.6	1.00	10.0	0	N/A	N/A	N/A	50.4	100.0 %		CC100080	8/21/2026
01/13/2019	01:32	NOX NH3L	NOX	8.76	8.92	0.16	1.6	1.00	10.0	0	N/A	N/A	N/A	0.0	0.0 %		CC100080	8/21/2026
01/12/2019	09:42	NOX NH3L	NOX	8.76	8.78	0.02	0.2	1.00	10.0	0	N/A	N/A	N/A	0.0	0.0 %		CC100080	8/21/2026
01/12/2019	07:11	NOX NH3L	NOX	8.76	8.78	0.02	0.2	1.00	10.0	0	N/A	N/A	N/A	0.0	0.0 %		CC100080	8/21/2026
01/09/2019	11:16	NOX NH3L	NOX	8.76	8.79	0.03	0.3	1.00	10.0	0	N/A	N/A	N/A	0.0	0.0 %		CC100080	8/21/2026
12/30/2019	15:47	NOX HIGH	NOX	181.10	181.93	0.83	0.4	20.00	10.0	0	0.1	10.00	5.0	50.4	100.0 %		SG9167509BAL	11/28/2027
12/30/2019	15:47	NOX HIGH	NOX	181.10	181.93	0.83	0.4	20.00	10.0	0	0.1	10.00	5.0	50.4	100.0 %		SG9167509BAL	11/28/2027
12/26/2019	17:16	NOX HIGH	NOX	181.10	181.42	0.32	0.2	20.00	10.0	0	0.0	10.00	5.0	50.3	100.0 %		SG9167509BAL	11/28/2027
12/26/2019	17:16	NOX HIGH	NOX	181.10	181.42	0.32	0.2	20.00	10.0	0	0.0	10.00	5.0	50.3	100.0 %		SG9167509BAL	11/28/2027
12/18/2019	17:46	NOX HIGH	NOX	181.10	181.57	0.47	0.2	20.00	10.0	0	0.3	10.00	5.0	50.4	100.0 %		SG9167509BAL	11/28/2027
12/18/2019	17:46	NOX HIGH	NOX	181.10	181.57	0.47	0.2	20.00	10.0	0	0.3	10.00	5.0	50.4	100.0 %		SG9167509BAL	11/28/2027
12/17/2019	17:01	NOX HIGH	NOX	181.10	182.55	1.45	0.7	20.00	10.0	0	0.7	10.00	5.0	50.4	100.0 %		SG9167509BAL	11/28/2027
12/17/2019	17:01	NOX HIGH	NOX	181.10	182.55	1.45	0.7	20.00	10.0	0	0.7	10.00	5.0	50.4	100.0 %		SG9167509BAL	11/28/2027
12/17/2019	15:06	NOX HIGH	NOX	181.10	181.53	0.43	0.2	20.00	10.0	0	0.2	10.00	5.0	50.4	100.0 %		SG9167509BAL	11/28/2027
12/17/2019	15:06	NOX HIGH	NOX	181.10	181.53	0.43	0.2	20.00	10.0	0	0.2	10.00	5.0	50.4	100.0 %		SG9167509BAL	11/28/2027
12/17/2019	13:40	NOX HIGH	NOX	181.10	180.81	-0.29	-0.1	20.00	10.0	0	-0.2	10.00	5.0	50.4	100.0 %		SG9167509BAL	11/28/2027
12/17/2019	13:40	NOX HIGH	NOX	181.10	180.81	-0.29	-0.1	20.00	10.0	0	-0.2	10.00	5.0	50.4	100.0 %		SG9167509BAL	11/28/2027
12/07/2019	03:50	NOX HIGH	NOX	181.10	181.09	0.00	0.0	20.00	10.0	0	0.0	10.00	5.0	50.8	100.0 %		SG9167509BAL	11/28/2027
12/07/2019	03:50	NOX HIGH	NOX	181.10	181.09	0.00	0.0	20.00	10.0	0	0.0	10.00	5.0	50.8	100.0 %		SG9167509BAL	11/28/2027
12/03/2019	09:31	NOX HIGH	NOX	181.10	180.60	-0.50	-0.3	20.00	10.0	0	-0.3	10.00	5.0	49.1	100.0 %		SG9167509BAL	11/28/2027
12/03/2019	09:31	NOX HIGH	NOX	181.10	180.60	-0.50	-0.3	20.00	10.0	0	-0.3	10.00	5.0	49.1	100.0 %		SG9167509BAL	11/28/2027
11/26/2019	07:01	NOX HIGH	NOX	181.10	180.76	-0.34	-0.2	20.00	10.0	0	-0.2	10.00	5.0	49.3	100.0 %		SG9167509BAL	11/28/2027
11/26/2019	07:01	NOX HIGH	NOX	181.10	180.76	-0.34	-0.2	20.00	10.0	0	-0.2	10.00	5.0	49.3	100.0 %		SG9167509BAL	11/28/2027
11/24/2019	17:16	NOX HIGH	NOX	181.10	180.77	-0.33	-0.2	20.00	10.0	0	-0.2	10.00	5.0	0.0	0.0 %		SG9167509BAL	11/28/2027
11/24/2019	17:16	NOX HIGH	NOX	181.10	180.77	-0.33	-0.2	20.00	10.0	0	-0.2	10.00	5.0	0.0	0.0 %		SG9167509BAL	11/28/2027
11/22/2019	14:50	NOX HIGH	NOX	181.10	180.77	-0.33	-0.2	20.00	10.0	0	-0.2	10.00	5.0	0.0	0.0 %		SG9167509BAL	11/28/2027
11/22/2019	14:50	NOX HIGH	NOX	181.10	180.77	-0.33	-0.2	20.00	10.0	0	-0.2	10.00	5.0	0.0	0.0 %		SG9167509BAL	11/28/2027
11/21/2019	12:44	NOX HIGH	NOX	181.10	181.29	0.19	0.1	20.00	10.0	0	0.1	10.00	5.0	48.7	100.0 %		SG9167509BAL	11/28/2027
11/21/2019	12:44	NOX HIGH	NOX	181.10	181.29	0.19	0.1	20.00	10.0	0	0.1	10.00	5.0	48.7	100.0 %		SG9167509BAL	11/28/2027
11/18/2019	17:01	NOX HIGH	NOX	181.10	180.93	-0.17	-0.1	20.00	10.0	0	-0.1	10.00	5.0	49.3	100.0 %		SG9167509BAL	11/28/2027
11/18/2019	17:01	NOX HIGH	NOX	181.10	180.93	-0.17	-0.1	20.00	10.0	0	-0.1	10.00	5.0	49.3	100.0 %		SG9167509BAL	11/28/2027
11/17/2019	17:16	NOX HIGH	NOX	181.10	181.19	0.09	0.0	20.00	10.0	0	0.0	10.00	5.0	50.4	100.0 %		SG9167509BAL	11/28/2027
11/17/2019	17:16	NOX HIGH	NOX	181.10	181.19	0.09	0.0	20.00	10.0	0	0.0	10.00	5.0	50.4	100.0 %		SG9167509BAL	11/28/2027



Daily Stack Calibration Report  
Generated: 2/11/2020

Plant: McGrath Generating Station  
City/St: Oxnard, CA 93035  
Source: Stack

Period Start: 1/1/2019  
Period End: 12/30/2019  
Included Calibrations: Daily (40CFR60)/(40CFR75)

Date	Time	Channel	Type	Target	Actual	Diff	Error %	Units	Part60 Allowable	MD Error %	Units	Part75 Allowable	Gross MW	Process	Bottle ID	Expire Date
10/23/2019	05:16	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	49.5	82.4 %	CCI49073	3/11/2027
10/23/2019	05:16	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	49.5	82.4 %	CCI49073	3/11/2027
10/22/2019	16:46	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	47.9	100.0 %	CCI49073	3/11/2027
10/22/2019	16:46	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	47.9	100.0 %	CCI49073	3/11/2027
10/21/2019	14:46	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	0.0	0.0 %	CCI49073	3/11/2027
10/21/2019	14:46	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	0.0	0.0 %	CCI49073	3/11/2027
10/20/2019	17:16	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	48.6	82.4 %	CCI49073	3/11/2027
10/20/2019	17:16	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	48.6	82.4 %	CCI49073	3/11/2027
10/19/2019	17:01	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	48.8	100.0 %	CCI49073	3/11/2027
10/19/2019	17:01	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	48.8	100.0 %	CCI49073	3/11/2027
10/18/2019	05:46	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	50.1	100.0 %	CCI49073	3/11/2027
10/18/2019	05:46	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	50.1	100.0 %	CCI49073	3/11/2027
10/17/2019	18:01	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	0.0	0.0 %	CCI49073	3/11/2027
10/17/2019	18:01	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	0.0	0.0 %	CCI49073	3/11/2027
10/16/2019	09:16	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	0.0	0.0 %	CCI49073	3/11/2027
10/16/2019	09:16	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	0.0	0.0 %	CCI49073	3/11/2027
10/15/2019	17:11	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	49.3	100.0 %	CCI49073	3/11/2027
10/15/2019	17:11	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	49.3	100.0 %	CCI49073	3/11/2027
10/15/2019	18:01	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	0.0	0.0 %	CCI49073	3/11/2027
10/15/2019	18:01	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	0.0	0.0 %	CCI49073	3/11/2027
10/08/2019	18:01	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	0.0	0.0 %	CCI49073	3/11/2027
10/08/2019	18:01	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	0.0	0.0 %	CCI49073	3/11/2027
10/07/2019	17:46	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	0.0	0.0 %	CCI49073	3/11/2027
10/07/2019	17:46	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	0.0	0.0 %	CCI49073	3/11/2027
10/06/2019	17:16	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	48.6	100.0 %	CCI49073	3/11/2027
10/06/2019	17:16	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	48.6	100.0 %	CCI49073	3/11/2027
10/05/2019	17:16	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	48.6	82.4 %	CCI49073	3/11/2027
10/05/2019	17:16	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	48.6	82.4 %	CCI49073	3/11/2027
10/02/2019	18:01	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	48.8	100.0 %	CCI49073	3/11/2027
10/02/2019	18:01	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	48.8	100.0 %	CCI49073	3/11/2027
10/02/2019	09:24	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	0.0	0.0 %	CCI49073	3/11/2027
10/02/2019	09:24	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	0.0	0.0 %	CCI49073	3/11/2027
09/21/2019	18:01	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	0.0	0.0 %	CCI49073	3/11/2027
09/21/2019	18:01	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	0.0	0.0 %	CCI49073	3/11/2027
09/18/2019	13:58	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	0.0	0.0 %	CCI49073	3/11/2027
09/18/2019	13:58	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	0.0	0.0 %	CCI49073	3/11/2027
09/05/2019	14:16	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	47.9	100.0 %	CCI49073	3/11/2027
09/05/2019	14:16	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	47.9	100.0 %	CCI49073	3/11/2027
09/05/2019	14:16	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	48.1	100.0 %	CCI49073	3/11/2027
09/05/2019	14:16	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	48.1	100.0 %	CCI49073	3/11/2027
09/04/2019	17:01	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	0.0	0.0 %	CCI49073	3/11/2027
09/04/2019	17:01	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	0.0	0.0 %	CCI49073	3/11/2027
09/04/2019	09:26	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	0.0	0.0 %	CCI49073	3/11/2027
09/04/2019	09:26	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	0.0	0.0 %	CCI49073	3/11/2027
09/03/2019	16:46	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	48.0	100.0 %	CCI49073	3/11/2027
09/03/2019	16:46	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	48.0	100.0 %	CCI49073	3/11/2027
09/02/2019	17:46	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	48.1	100.0 %	CCI49073	3/11/2027
09/02/2019	17:46	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	48.1	100.0 %	CCI49073	3/11/2027
09/01/2019	18:01	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	0.0	0.0 %	CCI49073	3/11/2027
09/01/2019	18:01	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	0.0	0.0 %	CCI49073	3/11/2027
08/30/2019	14:01	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	48.0	100.0 %	CCI49073	3/11/2027
08/30/2019	14:01	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	48.0	100.0 %	CCI49073	3/11/2027
08/25/2019	00:40	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	0.0	0.0 %	CCI49073	3/11/2027
08/25/2019	00:40	NORHIGH_5	NOK	177.60	179.65	2.05	1.1	20.00	10.0	PASS	0	5.0	0.0	0.0 %	CCI49073	3/11/2027

Daily Stack Calibration Report  
Generated: 2/11/2020

Company: McGrath Generating Station  
Plant: 251 N. Harbor Blvd.  
City/St: Oxnard, CA 93035  
Source: stack

Period Start: 1/1/2019  
Period End: 12/30/2019  
Included Calibrations: Daily (40CFR60)/(40CFR75)

Date	Time	Channel	Type	Target Units	Actual Units	Diff Units	Error %	Units	Part60 Allowable	Part75 Allowable	Gross Wf.5 MF	Process On	Bottle ID	Expire Date
05/17/2019	16:15	NOXHIGH5	NOX	177.60	177.90	0.30	0.17	20.00	10.0	PASS	0.0	0.0	ALM029052	12/13/2026
05/17/2019	16:15	NOXHIGH5	NOX	177.60	177.90	0.30	0.17	20.00	10.0	PASS	0.0	0.0	ALM029052	12/13/2026
05/17/2019	16:15	NOXHIGH5	NOX	177.60	177.90	0.30	0.17	20.00	10.0	PASS	0.0	0.0	ALM029052	12/13/2026
05/17/2019	16:15	NOXHIGH5	NOX	177.60	177.90	0.30	0.17	20.00	10.0	PASS	0.0	0.0	ALM029052	12/13/2026
04/30/2019	18:01	NOXHIGH5	NOX	179.10	180.74	1.64	0.9	20.00	10.0	PASS	49.6	100.0	SG9159413BBL	7/9/2026
04/30/2019	18:01	NOXHIGH5	NOX	179.10	180.74	1.64	0.9	20.00	10.0	PASS	49.6	100.0	SG9159413BBL	7/9/2026
04/25/2019	18:46	NOXHIGH5	NOX	179.10	180.85	1.75	0.9	20.00	10.0	PASS	50.0	100.0	ALM029052	12/13/2026
04/25/2019	18:46	NOXHIGH5	NOX	179.10	180.85	1.75	0.9	20.00	10.0	PASS	50.0	100.0	ALM029052	12/13/2026
04/24/2019	18:01	NOXHIGH5	NOX	179.10	180.85	1.75	0.9	20.00	10.0	PASS	50.1	100.0	SG9159413BBL	7/9/2026
04/24/2019	18:01	NOXHIGH5	NOX	179.10	180.85	1.75	0.9	20.00	10.0	PASS	50.1	100.0	SG9159413BBL	7/9/2026
04/22/2019	19:03	NOXHIGH5	NOX	179.10	180.78	1.68	0.9	20.00	10.0	PASS	0.0	0.0	ALM029052	12/13/2026
04/22/2019	19:03	NOXHIGH5	NOX	179.10	180.78	1.68	0.9	20.00	10.0	PASS	0.0	0.0	ALM029052	12/13/2026
04/21/2019	19:01	NOXHIGH5	NOX	179.10	180.52	1.42	0.8	20.00	10.0	PASS	0.0	0.0	ALM029052	12/13/2026
04/21/2019	19:01	NOXHIGH5	NOX	179.10	180.52	1.42	0.8	20.00	10.0	PASS	0.0	0.0	ALM029052	12/13/2026
04/14/2019	19:01	NOXHIGH5	NOX	179.10	180.42	1.32	0.7	20.00	10.0	PASS	0.0	0.0	ALM029052	12/13/2026
04/14/2019	19:01	NOXHIGH5	NOX	179.10	180.42	1.32	0.7	20.00	10.0	PASS	0.0	0.0	ALM029052	12/13/2026
04/13/2019	18:16	NOXHIGH5	NOX	179.10	180.55	1.45	0.8	20.00	10.0	PASS	49.8	100.0	SG9159413BBL	7/9/2026
04/13/2019	18:16	NOXHIGH5	NOX	179.10	180.55	1.45	0.8	20.00	10.0	PASS	49.8	100.0	SG9159413BBL	7/9/2026
04/15/2019	05:33	NOXHIGH5	NOX	179.10	180.25	1.15	0.6	20.00	10.0	PASS	0.0	0.0	ALM029052	12/13/2026
04/15/2019	05:33	NOXHIGH5	NOX	179.10	180.25	1.15	0.6	20.00	10.0	PASS	0.0	0.0	ALM029052	12/13/2026
04/11/2019	12:46	NOXHIGH5	NOX	179.10	180.04	0.94	0.5	20.00	10.0	PASS	0.0	0.0	ALM029052	12/13/2026
04/11/2019	12:46	NOXHIGH5	NOX	179.10	180.04	0.94	0.5	20.00	10.0	PASS	0.0	0.0	ALM029052	12/13/2026
04/08/2019	18:46	NOXHIGH5	NOX	179.10	181.12	2.02	1.1	20.00	10.0	PASS	0.0	0.0	ALM029052	12/13/2026
04/08/2019	18:46	NOXHIGH5	NOX	179.10	181.12	2.02	1.1	20.00	10.0	PASS	0.0	0.0	ALM029052	12/13/2026
04/04/2019	09:56	NOXHIGH5	NOX	179.10	180.59	1.49	0.8	20.00	10.0	PASS	0.0	0.0	ALM029052	12/13/2026
04/04/2019	09:56	NOXHIGH5	NOX	179.10	180.59	1.49	0.8	20.00	10.0	PASS	0.0	0.0	ALM029052	12/13/2026
04/04/2019	09:56	NOXHIGH5	NOX	179.10	180.59	1.49	0.8	20.00	10.0	PASS	0.0	0.0	ALM029052	12/13/2026
04/04/2019	09:56	NOXHIGH5	NOX	179.10	180.59	1.49	0.8	20.00	10.0	PASS	0.0	0.0	ALM029052	12/13/2026
04/01/2019	18:48	NOXHIGH5	NOX	179.10	179.82	0.72	0.4	20.00	10.0	PASS	0.0	0.0	ALM029052	12/13/2026
04/01/2019	18:48	NOXHIGH5	NOX	179.10	179.82	0.72	0.4	20.00	10.0	PASS	0.0	0.0	ALM029052	12/13/2026
03/31/2019	18:01	NOXHIGH5	NOX	179.10	180.01	0.91	0.5	20.00	10.0	PASS	49.5	100.0	SG9159413BBL	7/9/2026
03/31/2019	18:01	NOXHIGH5	NOX	179.10	180.01	0.91	0.5	20.00	10.0	PASS	49.5	100.0	SG9159413BBL	7/9/2026
03/27/2019	04:31	NOXHIGH5	NOX	179.10	179.97	0.87	0.5	20.00	10.0	PASS	50.8	100.0	ALM-063377	11/26/2026
03/27/2019	04:31	NOXHIGH5	NOX	179.10	179.97	0.87	0.5	20.00	10.0	PASS	50.8	100.0	ALM-063377	11/26/2026
03/26/2019	12:33	NOXHIGH5	NOX	179.10	180.02	0.92	0.5	20.00	10.0	PASS	0.0	0.0	ALM-063377	11/26/2026
03/26/2019	12:33	NOXHIGH5	NOX	179.10	180.02	0.92	0.5	20.00	10.0	PASS	0.0	0.0	ALM-063377	11/26/2026
03/18/2019	18:46	NOXHIGH5	NOX	179.10	180.23	1.13	0.6	20.00	10.0	PASS	0.0	0.0	ALM-063377	11/26/2026
03/18/2019	18:46	NOXHIGH5	NOX	179.10	180.23	1.13	0.6	20.00	10.0	PASS	0.0	0.0	ALM-063377	11/26/2026
03/17/2019	18:01	NOXHIGH5	NOX	179.10	180.04	1.20	0.7	20.00	10.0	PASS	0.0	0.0	ALM-063377	11/26/2026
03/17/2019	18:01	NOXHIGH5	NOX	179.10	180.04	1.20	0.7	20.00	10.0	PASS	0.0	0.0	ALM-063377	11/26/2026
03/16/2019	18:16	NOXHIGH5	NOX	179.10	179.65	0.55	0.3	20.00	10.0	PASS	0.0	0.0	ALM-063377	11/26/2026
03/16/2019	18:16	NOXHIGH5	NOX	179.10	179.65	0.55	0.3	20.00	10.0	PASS	0.0	0.0	ALM-063377	11/26/2026
03/11/2019	04:16	NOXHIGH5	NOX	179.10	179.65	0.55	0.3	20.00	10.0	PASS	0.0	0.0	ALM-063377	11/26/2026
03/11/2019	04:16	NOXHIGH5	NOX	179.10	179.65	0.55	0.3	20.00	10.0	PASS	0.0	0.0	ALM-063377	11/26/2026
03/06/2019	14:56	NOXHIGH5	NOX	179.10	180.29	1.19	0.6	20.00	10.0	PASS	0.0	0.0	ALM-063377	11/26/2026
03/06/2019	14:56	NOXHIGH5	NOX	179.10	180.29	1.19	0.6	20.00	10.0	PASS	0.0	0.0	ALM-063377	11/26/2026
03/05/2019	07:33	NOXHIGH5	NOX	179.10	180.17	1.07	0.5	20.00	10.0	PASS	50.5	100.0	SG9159413BBL	7/9/2026
03/05/2019	07:33	NOXHIGH5	NOX	179.10	180.17	1.07	0.5	20.00	10.0	PASS	50.5	100.0	SG9159413BBL	7/9/2026
03/04/2019	18:01	NOXHIGH5	NOX	179.10	180.32	1.22	0.6	20.00	10.0	PASS	50.2	100.0	ALM-063377	11/26/2026
03/04/2019	18:01	NOXHIGH5	NOX	179.10	180.32	1.22	0.6	20.00	10.0	PASS	50.2	100.0	ALM-063377	11/26/2026
03/02/2019	06:01	NOXHIGH5	NOX	179.10	180.00	0.90	0.5	20.00	10.0	PASS	50.3	100.0	ALM-063377	11/26/2026
03/02/2019	06:01	NOXHIGH5	NOX	179.10	180.00	0.90	0.5	20.00	10.0	PASS	50.3	100.0	ALM-063377	11/26/2026

Daily Stack Calibration Report  
Generated: 2/11/2020

Company: McGrath Generating Station  
Plant: 251 N. Harbor Blvd.  
City/St.: Oxnard, CA 93035  
Source: stack

Period Start: 1/1/2019  
Period End: 12/30/2019  
Included Calibrations: Daily (40CFR60)/(40CFR75)

Date	Time	Channel	Type	Target Units	Actual Units	Diff Units	Error 1	Units	Part60 Allowable	MD Error	Units	Part75 Allowable	PASS	Gross MW	Process On	Bottle ID	Expire Date
01/09/2019	11:16	NOXLOW 5	ZERO	173.00	180.70	0.11	0.11	20.00	10.00	0.1	10.00	5.0	PASS	0.0	0.0	CC100080	8/21/2026
01/09/2019	11:17	NOXLOW 5	ZERO	173.00	180.70	1.00	0.5	20.00	10.00	0.5	10.00	5.0	PASS	0.0	0.0	CC37505	8/6/2026
12/30/2019	15:47	NOXLOW 5	SPAN	8.85	8.90	0.05	0.5	1.00	10.00	0.5	10.00	5.0	PASS	0.0	0.0	EB0078249	11/28/2027
12/30/2019	15:47	NOXLOW 5	SPAN	8.85	8.90	0.05	0.5	1.00	10.00	0.5	10.00	5.0	PASS	0.0	0.0	CC266925	11/28/2027
12/26/2019	17:16	NOXLOW 5	ZERO	8.85	8.75	-0.10	-1.0	1.00	10.00	0.0	5.00	5.0	PASS	50.4	100.0	EB0078249	11/28/2027
12/26/2019	17:16	NOXLOW 5	ZERO	8.85	8.75	-0.10	-1.0	1.00	10.00	0.0	5.00	5.0	PASS	50.4	100.0	CC266925	11/28/2027
12/18/2019	17:46	NOXLOW 5	ZERO	8.85	8.76	-0.09	-0.9	1.00	10.00	0.0	5.00	5.0	PASS	50.3	100.0	EB0078249	11/28/2027
12/18/2019	17:46	NOXLOW 5	ZERO	8.85	8.76	-0.09	-0.9	1.00	10.00	0.0	5.00	5.0	PASS	50.3	100.0	CC266925	11/28/2027
12/17/2019	17:01	NOXLOW 5	ZERO	8.85	8.83	0.03	0.3	1.00	10.00	0.0	5.00	5.0	PASS	50.4	100.0	CC197991	8/19/2027
12/17/2019	17:01	NOXLOW 5	ZERO	8.85	8.83	0.03	0.3	1.00	10.00	0.0	5.00	5.0	PASS	50.4	100.0	CC266925	11/28/2027
12/11/2019	15:06	NOXLOW 5	ZERO	8.85	-0.01	-0.01	-0.1	1.00	10.00	0.0	5.00	5.0	PASS	0.0	0.0	CC197991	8/19/2027
12/11/2019	15:06	NOXLOW 5	ZERO	8.85	-0.01	-0.01	-0.1	1.00	10.00	0.0	5.00	5.0	PASS	0.0	0.0	CC266925	11/28/2027
12/04/2019	13:40	NOXLOW 5	ZERO	8.85	8.88	0.03	0.3	1.00	10.00	0.0	5.00	5.0	PASS	0.0	0.0	CC197991	8/19/2027
12/04/2019	13:40	NOXLOW 5	ZERO	8.85	8.88	0.03	0.3	1.00	10.00	0.0	5.00	5.0	PASS	0.0	0.0	CC266925	11/28/2027
12/03/2019	09:31	NOXLOW 5	ZERO	8.85	8.97	0.12	1.2	1.00	10.00	0.0	5.00	5.0	PASS	49.8	100.0	CC197991	8/19/2027
12/03/2019	09:31	NOXLOW 5	ZERO	8.85	8.97	0.12	1.2	1.00	10.00	0.0	5.00	5.0	PASS	49.8	100.0	CC266925	11/28/2027
12/03/2019	09:31	NOXLOW 5	ZERO	8.85	8.86	0.01	0.1	1.00	10.00	0.0	5.00	5.0	PASS	50.8	100.0	CC197991	8/19/2027
12/03/2019	09:31	NOXLOW 5	ZERO	8.85	8.86	0.01	0.1	1.00	10.00	0.0	5.00	5.0	PASS	50.8	100.0	CC266925	11/28/2027
11/26/2019	07:01	NOXLOW 5	ZERO	8.85	8.86	0.01	0.1	1.00	10.00	0.0	5.00	5.0	PASS	49.1	100.0	CC197991	8/19/2027
11/26/2019	07:01	NOXLOW 5	ZERO	8.85	8.86	0.01	0.1	1.00	10.00	0.0	5.00	5.0	PASS	49.1	100.0	CC266925	11/28/2027
11/24/2019	17:16	NOXLOW 5	ZERO	8.85	8.77	-0.08	-0.8	1.00	10.00	0.0	5.00	5.0	PASS	49.4	100.0	CC197991	8/19/2027
11/24/2019	17:16	NOXLOW 5	ZERO	8.85	8.77	-0.08	-0.8	1.00	10.00	0.0	5.00	5.0	PASS	49.4	100.0	CC266925	11/28/2027
11/22/2019	14:50	NOXLOW 5	ZERO	8.85	8.80	-0.05	-0.5	1.00	10.00	0.0	5.00	5.0	PASS	0.0	0.0	CC197991	8/19/2027
11/22/2019	14:50	NOXLOW 5	ZERO	8.85	8.80	-0.05	-0.5	1.00	10.00	0.0	5.00	5.0	PASS	0.0	0.0	CC266925	11/28/2027
11/21/2019	12:44	NOXLOW 5	ZERO	8.85	8.87	0.02	0.2	1.00	10.00	0.0	5.00	5.0	PASS	48.7	100.0	CC197991	8/19/2027
11/21/2019	12:44	NOXLOW 5	ZERO	8.85	8.87	0.02	0.2	1.00	10.00	0.0	5.00	5.0	PASS	48.7	100.0	CC266925	11/28/2027
11/18/2019	17:01	NOXLOW 5	ZERO	8.85	8.67	-0.18	-1.8	1.00	10.00	0.0	5.00	5.0	PASS	49.3	100.0	CC197991	8/19/2027
11/18/2019	17:01	NOXLOW 5	ZERO	8.85	8.67	-0.18	-1.8	1.00	10.00	0.0	5.00	5.0	PASS	49.3	100.0	CC266925	11/28/2027
11/17/2019	17:16	NOXLOW 5	ZERO	8.85	8.72	-0.13	-1.3	1.00	10.00	0.0	5.00	5.0	PASS	49.0	100.0	CC197991	8/19/2027
11/17/2019	17:16	NOXLOW 5	ZERO	8.85	8.72	-0.13	-1.3	1.00	10.00	0.0	5.00	5.0	PASS	49.0	100.0	CC266925	11/28/2027
11/16/2019	17:16	NOXLOW 5	ZERO	8.85	8.76	-0.09	-0.9	1.00	10.00	0.0	5.00	5.0	PASS	49.6	100.0	CC197991	8/19/2027
11/16/2019	17:16	NOXLOW 5	ZERO	8.85	8.76	-0.09	-0.9	1.00	10.00	0.0	5.00	5.0	PASS	49.6	100.0	CC266925	11/28/2027
11/15/2019	17:16	NOXLOW 5	ZERO	8.85	8.76	-0.09	-0.9	1.00	10.00	0.0	5.00	5.0	PASS	49.9	100.0	CC197991	8/19/2027
11/15/2019	17:16	NOXLOW 5	ZERO	8.85	8.76	-0.09	-0.9	1.00	10.00	0.0	5.00	5.0	PASS	49.9	100.0	CC266925	11/28/2027
11/14/2019	06:16	NOXLOW 5	ZERO	9.04	9.10	0.06	0.6	1.00	10.00	0.0	5.00	5.0	PASS	49.4	100.0	CC454217	8/19/2027
11/14/2019	06:16	NOXLOW 5	ZERO	9.04	9.10	0.06	0.6	1.00	10.00	0.0	5.00	5.0	PASS	49.4	100.0	CC454217	8/19/2027
11/13/2019	16:16	NOXLOW 5	ZERO	9.04	9.05	0.01	0.1	1.00	10.00	0.0	5.00	5.0	PASS	49.6	100.0	CC454217	8/19/2027
11/13/2019	16:16	NOXLOW 5	ZERO	9.04	9.05	0.01	0.1	1.00	10.00	0.0	5.00	5.0	PASS	49.6	100.0	CC454217	8/19/2027
11/13/2019	17:46	NOXLOW 5	SPAN	9.04	9.06	0.02	0.2	1.00	10.00	0.0	5.00	5.0	PASS	49.6	100.0	CC197991	8/19/2027
11/13/2019	17:46	NOXLOW 5	SPAN	9.04	9.06	0.02	0.2	1.00	10.00	0.0	5.00	5.0	PASS	49.6	100.0	CC266925	11/28/2027
11/11/2019	16:16	NOXLOW 5	ZERO	9.04	9.00	-0.04	-0.4	1.00	10.00	0.0	5.00	5.0	PASS	49.4	100.0	CC454217	8/19/2027
11/11/2019	16:16	NOXLOW 5	ZERO	9.04	9.00	-0.04	-0.4	1.00	10.00	0.0	5.00	5.0	PASS	49.4	100.0	CC454217	8/19/2027
11/10/2019	17:46	NOXLOW 5	ZERO	9.04	9.03	-0.01	-0.1	1.00	10.00	0.0	5.00	5.0	PASS	49.2	100.0	CC197991	8/19/2027
11/10/2019	17:46	NOXLOW 5	ZERO	9.04	9.03	-0.01	-0.1	1.00	10.00	0.0	5.00	5.0	PASS	49.2	100.0	CC266925	11/28/2027
11/09/2019	17:01	NOXLOW 5	ZERO	9.04	9.01	-0.03	-0.3	1.00	10.00	0.0	5.00	5.0	PASS	50.0	100.0	CC454217	8/19/2027
11/09/2019	17:01	NOXLOW 5	ZERO	9.04	9.01	-0.03	-0.3	1.00	10.00	0.0	5.00	5.0	PASS	50.0	100.0	CC454217	8/19/2027
11/08/2019	06:01	NOXLOW 5	ZERO	9.04	9.09	0.05	0.5	1.00	10.00	0.0	5.00	5.0	PASS	49.8	100.0	CC197991	8/19/2027
11/08/2019	06:01	NOXLOW 5	ZERO	9.04	9.09	0.05	0.5	1.00	10.00	0.0	5.00	5.0	PASS	49.8	100.0	CC197991	8/19/2027
11/07/2019	06:16	NOXLOW 5	ZERO	9.04	9.08	0.04	0.4	1.00	10.00	0.0	5.00	5.0	PASS	0.0	0.0	CC454217	8/19/2027
11/07/2019	06:16	NOXLOW 5	ZERO	9.04	9.08	0.04	0.4	1.00	10.00	0.0	5.00	5.0	PASS	0.0	0.0	CC454217	8/19/2027
11/06/2019	13:46	NOXLOW 5	ZERO	9.04	9.00	-0.04	-0.4	1.00	10.00	0.0	5.00	5.0	PASS	0.0	0.0	CC197991	8/19/2027
11/06/2019	13:46	NOXLOW 5	ZERO	9.04	9.00	-0.04	-0.4	1.00	10.00	0.0	5.00	5.0	PASS	0.0	0.0	CC454217	8/19/2027

Daily Stack Calibration Report  
Generated: 2/11/2020

Company: McGrath Generating Station  
Plant: 251 N. Harbor Blvd.  
City/St: Oxnard, CA 93035  
Source: stack

Period Start: 1/1/2019  
Period End: 12/30/2019  
Included Calibrations: Daily (40CFR60)/(40CFR75)

Date	Time	Channel	Type	Target	Actual	Diff	Error	Units	Part#0 Allowable	MD Error	Units	Part#5 Allowable	Process	Group	MD	On	Bottle ID	Expiry Date
10/06/2019	17:16	NOXL0W_5	NOX	9.00	9.00	0.00	0.00	1.00	10.0	0.0	5.00	5.0	100.0	48.6	100.0	0.0	CC149073	3/11/2021
10/06/2019	17:16	NOXL0W_5	NOX	9.04	8.86	-0.18	-1.8	1.00	10.0	0.0	5.00	5.0	100.0	48.6	100.0	0.0	CC149073	3/11/2021
10/06/2019	17:16	NOXL0W_5	NOX	9.04	8.92	-0.12	-1.2	1.00	10.0	0.0	5.00	5.0	100.0	48.6	100.0	0.0	CC149073	3/11/2021
10/06/2019	17:16	NOXL0W_5	NOX	9.04	9.02	-0.02	-0.2	1.00	10.0	0.0	5.00	5.0	100.0	48.6	100.0	0.0	CC149073	3/11/2021
10/02/2019	18:01	NOXL0W_5	NOX	9.04	9.06	0.02	0.2	1.00	10.0	0.0	5.00	5.0	100.0	48.6	100.0	0.0	CC149073	3/11/2021
10/02/2019	18:01	NOXL0W_5	NOX	9.04	9.01	-0.03	-0.3	1.00	10.0	0.0	5.00	5.0	100.0	48.6	100.0	0.0	CC149073	3/11/2021
10/02/2019	09:24	NOXL0W_5	NOX	9.04	9.09	0.05	0.5	1.00	10.0	0.0	5.00	5.0	100.0	48.6	100.0	0.0	CC149073	3/11/2021
10/02/2019	09:24	NOXL0W_5	NOX	9.04	9.05	0.01	0.1	1.00	10.0	0.0	5.00	5.0	100.0	48.6	100.0	0.0	CC149073	3/11/2021
09/21/2019	18:01	NOXL0W_5	NOX	9.04	8.97	-0.07	-0.7	1.00	10.0	0.0	5.00	5.0	100.0	48.6	100.0	0.0	CC149073	3/11/2021
09/21/2019	18:01	NOXL0W_5	NOX	9.04	8.95	-0.09	-0.9	1.00	10.0	0.0	5.00	5.0	100.0	48.6	100.0	0.0	CC149073	3/11/2021
09/18/2019	13:58	NOXL0W_5	NOX	9.04	9.02	-0.02	-0.2	1.00	10.0	0.0	5.00	5.0	100.0	48.6	100.0	0.0	CC149073	3/11/2021
09/18/2019	13:58	NOXL0W_5	NOX	9.04	9.09	0.05	0.5	1.00	10.0	0.0	5.00	5.0	100.0	48.6	100.0	0.0	CC149073	3/11/2021
09/05/2019	14:16	NOXL0W_5	NOX	9.04	9.03	-0.01	-0.1	1.00	10.0	0.0	5.00	5.0	100.0	48.6	100.0	0.0	CC149073	3/11/2021
09/04/2019	17:01	NOXL0W_5	NOX	9.07	9.03	-0.04	-0.4	1.00	10.0	0.0	5.00	5.0	100.0	48.6	100.0	0.0	CC149073	3/11/2021
09/04/2019	09:26	NOXL0W_5	NOX	9.07	9.21	0.14	1.4	1.00	10.0	0.0	5.00	5.0	100.0	48.6	100.0	0.0	CC149073	3/11/2021
09/04/2019	09:26	NOXL0W_5	NOX	9.07	9.02	-0.05	-0.5	1.00	10.0	0.0	5.00	5.0	100.0	48.6	100.0	0.0	CC149073	3/11/2021
09/03/2019	16:46	NOXL0W_5	NOX	9.07	9.05	-0.02	-0.2	1.00	10.0	0.0	5.00	5.0	100.0	48.6	100.0	0.0	CC149073	3/11/2021
09/03/2019	17:46	NOXL0W_5	NOX	9.07	9.05	-0.02	-0.2	1.00	10.0	0.0	5.00	5.0	100.0	48.6	100.0	0.0	CC149073	3/11/2021
09/02/2019	17:46	NOXL0W_5	NOX	9.07	9.09	0.02	0.2	1.00	10.0	0.0	5.00	5.0	100.0	48.6	100.0	0.0	CC149073	3/11/2021
09/01/2019	18:01	NOXL0W_5	NOX	9.07	9.09	0.02	0.2	1.00	10.0	0.0	5.00	5.0	100.0	48.6	100.0	0.0	CC149073	3/11/2021
08/30/2019	14:01	NOXL0W_5	NOX	9.07	9.13	0.06	0.6	1.00	10.0	0.0	5.00	5.0	100.0	48.6	100.0	0.0	CC149073	3/11/2021
08/30/2019	14:01	NOXL0W_5	NOX	9.07	9.12	0.05	0.5	1.00	10.0	0.0	5.00	5.0	100.0	48.6	100.0	0.0	CC149073	3/11/2021
08/25/2019	06:40	NOXL0W_5	NOX	9.07	9.12	0.05	0.5	1.00	10.0	0.0	5.00	5.0	100.0	48.6	100.0	0.0	CC149073	3/11/2021
08/25/2019	06:40	NOXL0W_5	NOX	9.07	9.14	0.07	0.7	1.00	10.0	0.0	5.00	5.0	100.0	48.6	100.0	0.0	CC149073	3/11/2021
08/24/2019	17:46	NOXL0W_5	NOX	9.07	9.14	0.07	0.7	1.00	10.0	0.0	5.00	5.0	100.0	48.6	100.0	0.0	CC149073	3/11/2021
08/19/2019	15:46	NOXL0W_5	NOX	9.07	9.09	0.02	0.2	1.00	10.0	0.0	5.00	5.0	100.0	48.6	100.0	0.0	CC149073	3/11/2021
08/19/2019	15:46	NOXL0W_5	NOX	9.07	9.09	0.02	0.2	1.00	10.0	0.0	5.00	5.0	100.0	48.6	100.0	0.0	CC149073	3/11/2021
08/15/2019	16:17	NOXL0W_5	NOX	9.07	9.05	-0.02	-0.2	1.00	10.0	0.0	5.00	5.0	100.0	48.6	100.0	0.0	CC149073	3/11/2021
08/14/2019	16:28	NOXL0W_5	NOX	9.07	9.05	-0.02	-0.2	1.00	10.0	0.0	5.00	5.0	100.0	48.6	100.0	0.0	CC149073	3/11/2021
08/14/2019	16:28	NOXL0W_5	NOX	9.07	9.05	-0.02	-0.2	1.00	10.0	0.0	5.00	5.0	100.0	48.6	100.0	0.0	CC149073	3/11/2021
08/12/2019	14:01	NOXL0W_5	NOX	9.07	9.13	0.06	0.6	1.00	10.0	0.0	5.00	5.0	100.0	48.6	100.0	0.0	CC149073	3/11/2021
08/12/2019	14:01	NOXL0W_5	NOX	9.07	9.14	0.07	0.7	1.00	10.0	0.0	5.00	5.0	100.0	48.6	100.0	0.0	CC149073	3/11/2021
08/08/2019	09:25	NOXL0W_5	NOX	9.07	9.20	0.13	1.3	1.00	10.0	0.0	5.00	5.0	100.0	48.6	100.0	0.0	CC149073	3/11/2021
08/08/2019	09:25	NOXL0W_5	NOX	9.07	9.14	0.07	0.7	1.00	10.0	0.0	5.00	5.0	100.0	48.6	100.0	0.0	CC149073	3/11/2021
08/05/2019	17:31	NOXL0W_5	NOX	9.07	9.00	-0.07	-0.7	1.00	10.0	0.0	5.00	5.0	100.0	48.6	100.0	0.0	CC149073	3/11/2021
08/05/2019	17:31	NOXL0W_5	NOX	9.07	9.03	-0.04	-0.4	1.00	10.0	0.0	5.00	5.0	100.0	48.6	100.0	0.0	CC149073	3/11/2021
08/04/2019	18:46	NOXL0W_5	NOX	9.07	9.03	-0.04	-0.4	1.00	10.0	0.0	5.00	5.0	100.0	48.6	100.0	0.0	CC149073	3/11/2021
08/02/2019	13:31	NOXL0W_5	NOX	9.07	9.14	0.07	0.7	1.00	10.0	0.0	5.00	5.0	100.0	48.6	100.0	0.0	CC149073	3/11/2021
08/02/2019	13:31	NOXL0W_5	NOX	9.07	9.14	0.07	0.7	1.00	10.0	0.0	5.00	5.0	100.0	48.6	100.0	0.0	CC149073	3/11/2021
08/01/2019	12:10	NOXL0W_5	NOX	9.07	9.12	0.05	0.5	1.00	10.0	0.0	5.00	5.0	100.0	48.6	100.0	0.0	CC149073	3/11/2021
08/01/2019	12:10	NOXL0W_5	NOX	9.07	9.12	0.05	0.5	1.00	10.0	0.0	5.00	5.0	100.0	48.6	100.0	0.0	CC149073	3/11/2021
07/28/2019	18:02	NOXL0W_5	NOX	9.07	9.04	-0.03	-0.3	1.00	10.0	0.0	5.00	5.0	100.0	48.6	100.0	0.0	CC149073	3/11/2021
07/28/2019	18:02	NOXL0W_5	NOX	9.07	9.04	-0.03	-0.3	1.00	10.0	0.0	5.00	5.0	100.0	48.6	100.0	0.0	CC149073	3/11/2021

Daily Stack Calibration Report  
Generated: 2/11/2020

Period Start: 1/1/2019  
Period End: 12/30/2019  
Included Calibrations: Daily (40CFR60)/(40CFR75)

Company: McGrath Generating Station  
Plant: 251 N. Harbor Blvd.  
City/St: Oxnard, CA 93035  
Source: Stack

Date	Time	Channel	Type	Target	Actual	Diff	Error	Units	Part60 Allowable	MD Error	Units	Part75 Allowable	Gross_MW	Process	On	Bottle ID	Expire Date
04/08/2019	18:46	NOXLOW 5	NOK ZERO	9.07	9.16	0.02	0.2	1.00	10.0	0.0	3.00	5.0	0.0	0.0	0.0	ALM028052	12/13/2026
04/08/2019	18:46	NOXLOW 4	NOK SPAN	9.07	9.16	0.11	0.1	1.00	10.0	0.0	3.00	5.0	0.0	0.0	0.0	CC328061	9/28/2021
04/04/2019	09:56	NOXLOW 5	NOK ZERO	9.07	-0.02	-0.02	-0.2	1.00	10.0	0.0	3.00	5.0	0.0	0.0	0.0	ALM028052	12/13/2026
04/04/2019	09:56	NOXLOW 4	NOK SPAN	9.07	9.10	0.03	0.3	1.00	10.0	0.0	3.00	5.0	0.0	0.0	0.0	CC328061	9/28/2021
04/01/2019	18:48	NOXLOW 5	NOK ZERO	8.76	-0.01	-0.01	-0.1	1.00	10.0	0.0	3.00	5.0	0.0	0.0	0.0	ALM-063377	11/26/2026
04/01/2019	18:48	NOXLOW 4	NOK SPAN	8.76	8.83	0.07	0.7	1.00	10.0	0.0	3.00	5.0	49.5	100.0	0.0	CC380120	4/11/2021
03/31/2019	18:01	NOXLOW 5	NOK ZERO	8.76	0.01	0.01	0.1	1.00	10.0	0.0	3.00	5.0	0.0	0.0	0.0	ALM-063377	11/26/2026
03/31/2019	18:01	NOXLOW 4	NOK SPAN	8.76	8.85	0.09	0.9	1.00	10.0	0.0	3.00	5.0	50.8	100.0	0.0	CC380120	4/11/2021
03/27/2019	04:31	NOXLOW 5	NOK ZERO	8.76	0.02	0.02	0.2	1.00	10.0	0.0	3.00	5.0	0.0	0.0	0.0	ALM-063377	11/26/2026
03/27/2019	04:31	NOXLOW 4	NOK SPAN	8.76	8.91	0.15	1.5	1.00	10.0	0.0	3.00	5.0	0.0	0.0	0.0	CC380120	4/11/2021
03/26/2019	12:33	NOXLOW 5	NOK ZERO	8.76	-0.03	-0.03	-0.3	1.00	10.0	0.0	3.00	5.0	0.0	0.0	0.0	ALM-063377	11/26/2026
03/26/2019	12:33	NOXLOW 4	NOK SPAN	8.76	8.83	0.07	0.7	1.00	10.0	0.0	3.00	5.0	0.0	0.0	0.0	CC380120	4/11/2021
03/25/2019	18:46	NOXLOW 5	NOK ZERO	8.76	-0.01	-0.01	-0.1	1.00	10.0	0.0	3.00	5.0	0.0	0.0	0.0	ALM-063377	11/26/2026
03/25/2019	18:46	NOXLOW 4	NOK SPAN	8.76	8.62	-0.14	-1.4	1.00	10.0	0.0	3.00	5.0	50.5	100.0	0.0	CC380120	4/11/2021
03/18/2019	18:46	NOXLOW 5	NOK ZERO	8.76	-0.01	-0.01	-0.1	1.00	10.0	0.0	3.00	5.0	0.0	0.0	0.0	ALM-063377	11/26/2026
03/18/2019	18:46	NOXLOW 4	NOK SPAN	8.76	8.62	-0.14	-1.4	1.00	10.0	0.0	3.00	5.0	49.1	100.0	0.0	CC380120	4/11/2021
03/17/2019	18:01	NOXLOW 5	NOK ZERO	8.76	-0.01	-0.01	-0.1	1.00	10.0	0.0	3.00	5.0	0.0	0.0	0.0	ALM-063377	11/26/2026
03/17/2019	18:01	NOXLOW 4	NOK SPAN	8.76	8.70	-0.06	-0.6	1.00	10.0	0.0	3.00	5.0	50.1	100.0	0.0	CC380120	4/11/2021
03/16/2019	18:16	NOXLOW 5	NOK ZERO	8.76	0.00	0.00	0.0	1.00	10.0	0.0	3.00	5.0	0.0	0.0	0.0	ALM-063377	11/26/2026
03/16/2019	18:16	NOXLOW 4	NOK SPAN	8.76	8.63	-0.13	-1.3	1.00	10.0	0.0	3.00	5.0	50.7	100.0	0.0	CC380120	4/11/2021
03/11/2019	04:16	NOXLOW 5	NOK ZERO	8.76	0.00	0.00	0.0	1.00	10.0	0.0	3.00	5.0	0.0	0.0	0.0	ALM-063377	11/26/2026
03/11/2019	04:16	NOXLOW 4	NOK SPAN	8.76	8.54	-0.22	-2.2	1.00	10.0	0.0	3.00	5.0	50.5	100.0	0.0	CC380120	4/11/2021
03/06/2019	14:56	NOXLOW 5	NOK ZERO	8.76	-0.01	-0.01	-0.1	1.00	10.0	0.0	3.00	5.0	0.0	0.0	0.0	ALM-063377	11/26/2026
03/06/2019	14:56	NOXLOW 4	NOK SPAN	8.76	8.74	-0.02	-0.2	1.00	10.0	0.0	3.00	5.0	50.5	100.0	0.0	CC380120	4/11/2021
03/05/2019	07:33	NOXLOW 5	NOK ZERO	8.76	-0.02	-0.02	-0.2	1.00	10.0	0.0	3.00	5.0	0.0	0.0	0.0	ALM-063377	11/26/2026
03/05/2019	07:33	NOXLOW 4	NOK SPAN	8.76	8.89	0.13	1.3	1.00	10.0	0.0	3.00	5.0	50.2	100.0	0.0	CC380120	4/11/2021
03/04/2019	18:01	NOXLOW 5	NOK ZERO	8.76	0.00	0.00	0.0	1.00	10.0	0.0	3.00	5.0	0.0	0.0	0.0	ALM-063377	11/26/2026
03/04/2019	18:01	NOXLOW 4	NOK SPAN	8.76	8.81	0.05	0.5	1.00	10.0	0.0	3.00	5.0	50.3	100.0	0.0	CC380120	4/11/2021
03/02/2019	06:01	NOXLOW 5	NOK ZERO	8.76	0.00	0.00	0.0	1.00	10.0	0.0	3.00	5.0	0.0	0.0	0.0	ALM-063377	11/26/2026
03/02/2019	06:01	NOXLOW 4	NOK SPAN	8.76	8.80	0.04	0.4	1.00	10.0	0.0	3.00	5.0	50.3	100.0	0.0	CC380120	4/11/2021
02/26/2019	23:21	NOXLOW 5	NOK ZERO	8.76	-0.01	-0.01	-0.1	1.00	10.0	0.0	3.00	5.0	0.0	0.0	0.0	ALM-063377	11/26/2026
02/26/2019	23:21	NOXLOW 4	NOK SPAN	8.76	8.80	0.04	0.4	1.00	10.0	0.0	3.00	5.0	50.6	100.0	0.0	CC380120	4/11/2021
02/25/2019	18:46	NOXLOW 5	NOK ZERO	8.76	0.01	0.01	0.1	1.00	10.0	0.0	3.00	5.0	0.0	0.0	0.0	ALM-063377	11/26/2026
02/25/2019	18:46	NOXLOW 4	NOK SPAN	8.76	8.78	0.02	0.2	1.00	10.0	0.0	3.00	5.0	50.8	100.0	0.0	CC380120	4/11/2021
02/19/2019	18:01	NOXLOW 5	NOK ZERO	8.76	0.02	0.02	0.2	1.00	10.0	0.0	3.00	5.0	0.0	0.0	0.0	ALM-063377	11/26/2026
02/19/2019	18:01	NOXLOW 4	NOK SPAN	8.76	8.77	0.01	0.1	1.00	10.0	0.0	3.00	5.0	50.6	100.0	0.0	CC380120	4/11/2021
02/15/2019	17:46	NOXLOW 5	NOK ZERO	8.76	0.00	0.00	0.0	1.00	10.0	0.0	3.00	5.0	0.0	0.0	0.0	ALM-063377	11/26/2026
02/15/2019	17:46	NOXLOW 4	NOK SPAN	8.76	8.81	0.05	0.5	1.00	10.0	0.0	3.00	5.0	0.0	0.0	0.0	CC380120	4/11/2021
02/14/2019	13:40	NOXLOW 5	NOK ZERO	8.76	-0.03	-0.03	-0.3	1.00	10.0	0.0	3.00	5.0	0.0	0.0	0.0	ALM-063377	11/26/2026
02/14/2019	13:40	NOXLOW 4	NOK SPAN	8.76	8.73	-0.03	-0.3	1.00	10.0	0.0	3.00	5.0	50.9	100.0	0.0	CC380120	4/11/2021
02/06/2019	17:16	NOXLOW 5	NOK ZERO	8.76	-0.01	-0.01	-0.1	1.00	10.0	0.0	3.00	5.0	0.0	0.0	0.0	ALM-063377	11/26/2026
02/06/2019	17:16	NOXLOW 4	NOK SPAN	8.76	8.84	0.08	0.8	1.00	10.0	0.0	3.00	5.0	0.0	0.0	0.0	CC380120	4/11/2021
02/06/2019	15:00	NOXLOW 5	NOK ZERO	8.76	-0.03	-0.03	-0.3	1.00	10.0	0.0	3.00	5.0	0.0	0.0	0.0	ALM-063377	11/26/2026
02/06/2019	15:00	NOXLOW 4	NOK SPAN	8.76	8.77	0.01	0.1	1.00	10.0	0.0	3.00	5.0	50.8	100.0	0.0	CC100080	8/21/2026
02/05/2019	06:46	NOXLOW 5	NOK ZERO	8.76	0.00	0.00	0.0	1.00	10.0	0.0	3.00	5.0	0.0	0.0	0.0	ALM-063377	11/26/2026
02/05/2019	06:46	NOXLOW 4	NOK SPAN	8.76	8.62	-0.14	-1.4	1.00	10.0	0.0	3.00	5.0	49.9	100.0	0.0	CC100080	8/21/2026
02/04/2019	17:46	NOXLOW 5	NOK ZERO	8.76	-0.01	-0.01	-0.1	1.00	10.0	0.0	3.00	5.0	0.0	0.0	0.0	ALM-063377	11/26/2026
02/04/2019	17:46	NOXLOW 4	NOK SPAN	8.76	8.54	-0.22	-2.2	1.00	10.0	0.0	3.00	5.0	50.2	100.0	0.0	CC100080	8/21/2026
02/03/2019	18:01	NOXLOW 5	NOK ZERO	8.76	-0.01	-0.01	-0.1	1.00	10.0	0.0	3.00	5.0	0.0	0.0	0.0	ALM-063377	11/26/2026
02/03/2019	18:01	NOXLOW 4	NOK SPAN	8.76	8.65	-0.11	-1.1	1.00	10.0	0.0	3.00	5.0	50.2	100.0	0.0	CC380120	4/11/2021

Daily Stack Calibration Report  
Generated: 2/11/2020

Company: McGrath Generating Station  
Plant: 251 N. Harbor Blvd,  
City/St: Oxnard, CA 93035  
Source: stack

Period Start: 1/1/2019  
Period End: 12/30/2019  
Included Calibrations: Daily (40CFR60)/(40CFR75)

Date	Time	Channel	Type	Target Units	Actual Units	Diff Units	Error %	Part60 Allowable Units	MD Error %	Part75 Allowable Units	Process MW	Gross MW	On	Process	Bottle ID	Expire Date
11/22/2019	14:50	02_5	ZERO	0.00	0.11	0.11	N/A	2.00	0	1.00	49.3	100.0	100.0	PASS	SG9167509BAL	2/12/2027
11/22/2019	14:50	02_5	SPAN	22.51	22.32	-0.19	N/A	2.00	0	1.00	49.3	100.0	100.0	PASS	CC197991	8/19/2027
11/22/2019	14:50	02_5	ZERO	0.00	0.12	0.12	N/A	2.00	0	1.00	0.0	0.0	0.0	PASS	SG9167509BAL	2/12/2027
11/22/2019	14:50	02_5	SPAN	22.51	22.19	-0.32	N/A	2.00	0	1.00	0.0	0.0	0.0	PASS	CC197991	8/19/2027
11/22/2019	14:50	02_5	ZERO	0.00	0.12	0.12	N/A	2.00	0	1.00	48.7	100.0	100.0	PASS	SG9167509BAL	2/12/2027
11/22/2019	14:50	02_5	SPAN	22.51	22.11	-0.40	N/A	2.00	0	1.00	48.7	100.0	100.0	PASS	CC197991	8/19/2027
11/17/2019	17:16	02_5	ZERO	0.00	0.11	0.11	N/A	2.00	0	1.00	49.3	100.0	100.0	PASS	SG9167509BAL	2/12/2027
11/17/2019	17:16	02_5	SPAN	22.51	22.20	-0.31	N/A	2.00	0	1.00	49.3	100.0	100.0	PASS	CC197991	8/19/2027
11/16/2019	17:16	02_5	ZERO	0.00	0.11	0.11	N/A	2.00	0	1.00	49.0	100.0	100.0	PASS	SG9167509BAL	2/12/2027
11/16/2019	17:16	02_5	SPAN	22.51	22.21	-0.30	N/A	2.00	0	1.00	49.0	100.0	100.0	PASS	CC197991	8/19/2027
11/15/2019	17:16	02_5	ZERO	0.00	0.11	0.11	N/A	2.00	0	1.00	49.6	100.0	100.0	PASS	SG9167509BAL	2/12/2027
11/15/2019	17:16	02_5	SPAN	22.51	22.25	-0.26	N/A	2.00	0	1.00	49.6	100.0	100.0	PASS	CC197991	8/19/2027
11/14/2019	06:16	02_5	ZERO	0.00	0.11	0.11	N/A	2.00	0	1.00	49.8	100.0	100.0	PASS	SG9167509BAL	2/12/2027
11/14/2019	06:16	02_5	SPAN	22.51	22.31	-0.20	N/A	2.00	0	1.00	49.8	100.0	100.0	PASS	CC197991	8/19/2027
11/13/2019	16:16	02_5	ZERO	0.00	0.11	0.11	N/A	2.00	0	1.00	49.4	100.0	100.0	PASS	SG9167509BAL	2/12/2027
11/13/2019	16:16	02_5	SPAN	22.51	22.24	-0.27	N/A	2.00	0	1.00	49.4	100.0	100.0	PASS	CC197991	8/19/2027
11/12/2019	17:16	02_5	ZERO	0.00	0.11	0.11	N/A	2.00	0	1.00	49.6	100.0	100.0	PASS	SG9167509BAL	2/12/2027
11/12/2019	17:16	02_5	SPAN	22.51	22.25	-0.26	N/A	2.00	0	1.00	49.6	100.0	100.0	PASS	CC197991	8/19/2027
11/11/2019	16:16	02_5	ZERO	0.00	0.11	0.11	N/A	2.00	0	1.00	49.6	100.0	100.0	PASS	SG9167509BAL	2/12/2027
11/11/2019	16:16	02_5	SPAN	22.51	22.24	-0.27	N/A	2.00	0	1.00	49.6	100.0	100.0	PASS	CC197991	8/19/2027
11/10/2019	17:46	02_5	ZERO	0.00	0.10	0.10	N/A	2.00	0	1.00	49.4	100.0	100.0	PASS	SG9167509BAL	2/12/2027
11/10/2019	17:46	02_5	SPAN	22.51	22.19	-0.32	N/A	2.00	0	1.00	49.4	100.0	100.0	PASS	CC197991	8/19/2027
11/09/2019	17:01	02_5	ZERO	0.00	0.10	0.10	N/A	2.00	0	1.00	49.2	100.0	100.0	PASS	SG9167509BAL	2/12/2027
11/09/2019	17:01	02_5	SPAN	22.51	22.00	-0.51	N/A	2.00	0	1.00	49.2	100.0	100.0	PASS	CC197991	8/19/2027
11/08/2019	06:01	02_5	ZERO	0.00	0.10	0.10	N/A	2.00	0	1.00	50.0	100.0	100.0	PASS	SG9167509BAL	2/12/2027
11/08/2019	06:01	02_5	SPAN	22.51	22.10	-0.41	N/A	2.00	0	1.00	50.0	100.0	100.0	PASS	CC197991	8/19/2027
11/07/2019	06:16	02_5	ZERO	0.00	0.10	0.10	N/A	2.00	0	1.00	49.8	100.0	100.0	PASS	SG9167509BAL	2/12/2027
11/07/2019	06:16	02_5	SPAN	22.51	22.27	-0.24	N/A	2.00	0	1.00	49.8	100.0	100.0	PASS	CC197991	8/19/2027
11/06/2019	13:46	02_5	ZERO	0.00	0.10	0.10	N/A	2.00	0	1.00	0.0	0.0	0.0	PASS	SG9167509BAL	2/12/2027
11/06/2019	13:46	02_5	SPAN	22.51	22.18	-0.33	N/A	2.00	0	1.00	0.0	0.0	0.0	PASS	CC197991	8/19/2027
11/06/2019	12:32	02_5	ZERO	0.00	0.10	0.10	N/A	2.00	0	1.00	49.0	100.0	100.0	PASS	SG9167509BAL	2/12/2027
11/06/2019	12:32	02_5	SPAN	22.51	22.18	-0.33	N/A	2.00	0	1.00	49.0	100.0	100.0	PASS	CC197991	8/19/2027
11/05/2019	06:49	02_5	ZERO	0.00	0.10	0.10	N/A	2.00	0	1.00	50.1	100.0	100.0	PASS	SG9167509BAL	2/12/2027
11/05/2019	06:49	02_5	SPAN	22.51	22.21	-0.30	N/A	2.00	0	1.00	50.1	100.0	100.0	PASS	CC197991	8/19/2027
11/04/2019	06:46	02_5	ZERO	0.00	0.10	0.10	N/A	2.00	0	1.00	50.0	100.0	100.0	PASS	SG9167509BAL	2/12/2027
11/04/2019	06:46	02_5	SPAN	22.51	22.18	-0.33	N/A	2.00	0	1.00	50.0	100.0	100.0	PASS	CC197991	8/19/2027
11/03/2019	00:40	02_5	ZERO	0.00	0.10	0.10	N/A	2.00	0	1.00	49.8	100.0	100.0	PASS	SG9167509BAL	2/12/2027
11/03/2019	00:40	02_5	SPAN	22.51	22.19	-0.32	N/A	2.00	0	1.00	49.8	100.0	100.0	PASS	CC197991	8/19/2027
11/02/2019	06:46	02_5	ZERO	0.00	0.10	0.10	N/A	2.00	0	1.00	49.9	100.0	100.0	PASS	SG9167509BAL	2/12/2027
11/02/2019	06:46	02_5	SPAN	22.51	22.25	-0.26	N/A	2.00	0	1.00	49.9	100.0	100.0	PASS	CC197991	8/19/2027
11/01/2019	05:48	02_5	ZERO	0.00	0.10	0.10	N/A	2.00	0	1.00	49.8	100.0	100.0	PASS	SG9167509BAL	2/12/2027
11/01/2019	05:48	02_5	SPAN	22.51	22.21	-0.30	N/A	2.00	0	1.00	49.8	100.0	100.0	PASS	CC197991	8/19/2027
10/31/2019	05:46	02_5	ZERO	0.00	0.10	0.10	N/A	2.00	0	1.00	0.0	0.0	0.0	PASS	SG9167509BAL	2/12/2027
10/31/2019	05:46	02_5	SPAN	22.51	22.34	-0.17	N/A	2.00	0	1.00	0.0	0.0	0.0	PASS	CC197991	8/19/2027
10/30/2019	17:01	02_5	ZERO	0.00	0.10	0.10	N/A	2.00	0	1.00	49.0	100.0	100.0	PASS	SG9167509BAL	2/12/2027
10/30/2019	17:01	02_5	SPAN	22.51	22.33	-0.18	N/A	2.00	0	1.00	49.0	100.0	100.0	PASS	CC197991	8/19/2027
10/30/2019	12:48	02_5	ZERO	0.00	0.10	0.10	N/A	2.00	0	1.00	0.0	0.0	0.0	PASS	SG9167509BAL	2/12/2027
10/30/2019	12:48	02_5	SPAN	22.51	22.32	-0.19	N/A	2.00	0	1.00	0.0	0.0	0.0	PASS	CC197991	8/19/2027
10/29/2019	05:46	02_5	ZERO	0.00	0.10	0.10	N/A	2.00	0	1.00	0.0	0.0	0.0	PASS	SG9167509BAL	2/12/2027
10/29/2019	05:46	02_5	SPAN	22.48	22.11	-0.37	N/A	2.00	0	1.00	0.0	0.0	0.0	PASS	CC149073	3/11/2027



Daily Stack Calibration Report  
Generated: 2/11/2020

Company: McGrath Generating Station  
Plant: 251 N. Harbor Blvd,  
City/St: Oxnard, CA 93035  
Source: stack

Period Start: 1/1/2019  
Period End: 12/30/2019  
Included Calibrations: Daily (40CFR60)/(40CFR75)

Date	Time	Channel	Type	Target Units	Actual Units	Diff Units	Error %	Units	Part60 Allowable	WD Error %	Units	Part75 Allowable	Gross MW	Process On	Botlle ID	Expire Date
09/02/2019	17:46	02_5	ZERO	0.00	0.11	0.11	N/A	2.00	N/A	0	1.00	N/A	48.1	100.0 %	CCI149073	9/17/2026
09/02/2019	17:46	02_5	ZERO	22.48	22.17	-0.31	N/A	2.00	N/A	0	1.00	N/A	0.0	0.0 %	CCI149073	9/17/2026
09/01/2019	18:01	02_5	ZERO	22.48	22.11	-0.37	N/A	2.00	N/A	0	1.00	N/A	0.0	0.0 %	CCI149073	9/17/2026
09/01/2019	18:01	02_5	SPAN	22.48	22.11	-0.37	N/A	2.00	N/A	0	1.00	N/A	0.0	0.0 %	CCI149073	9/17/2026
08/30/2019	14:01	02_5	ZERO	0.00	0.10	0.10	N/A	2.00	N/A	0	1.00	N/A	48.0	100.0 %	CCI149073	9/17/2026
08/30/2019	14:01	02_5	SPAN	22.48	22.18	-0.30	N/A	2.00	N/A	0	1.00	N/A	0.0	0.0 %	CCI149073	9/17/2026
08/25/2019	09:40	02_5	ZERO	0.00	0.10	0.10	N/A	2.00	N/A	0	1.00	N/A	0.0	0.0 %	CCI149073	9/17/2026
08/25/2019	09:40	02_5	SPAN	22.48	22.21	-0.27	N/A	2.00	N/A	0	1.00	N/A	48.4	100.0 %	CCI149073	9/17/2026
08/24/2019	17:46	02_5	ZERO	0.00	0.10	0.10	N/A	2.00	N/A	0	1.00	N/A	48.3	100.0 %	CCI149073	9/17/2026
08/24/2019	17:46	02_5	SPAN	22.48	22.18	-0.30	N/A	2.00	N/A	0	1.00	N/A	0.0	0.0 %	CCI149073	9/17/2026
08/19/2019	15:46	02_5	ZERO	0.00	0.10	0.10	N/A	2.00	N/A	0	1.00	N/A	49.3	76.5 %	CCI149073	9/17/2026
08/19/2019	15:46	02_5	SPAN	22.48	22.18	-0.30	N/A	2.00	N/A	0	1.00	N/A	0.0	0.0 %	CCI149073	9/17/2026
08/15/2019	18:17	02_5	ZERO	0.00	0.10	0.10	N/A	2.00	N/A	0	1.00	N/A	48.0	100.0 %	CCI149073	9/17/2026
08/15/2019	18:17	02_5	SPAN	22.48	22.18	-0.30	N/A	2.00	N/A	0	1.00	N/A	0.0	0.0 %	CCI149073	9/17/2026
08/14/2019	16:28	02_5	ZERO	0.00	0.10	0.10	N/A	2.00	N/A	0	1.00	N/A	48.0	100.0 %	CCI149073	9/17/2026
08/14/2019	16:28	02_5	SPAN	22.48	22.18	-0.30	N/A	2.00	N/A	0	1.00	N/A	0.0	0.0 %	CCI149073	9/17/2026
08/12/2019	14:01	02_5	ZERO	0.00	0.10	0.10	N/A	2.00	N/A	0	1.00	N/A	0.0	0.0 %	CCI149073	9/17/2026
08/12/2019	14:01	02_5	SPAN	22.48	22.20	-0.28	N/A	2.00	N/A	0	1.00	N/A	0.0	0.0 %	CCI149073	9/17/2026
08/08/2019	09:29	02_5	ZERO	0.00	0.10	0.10	N/A	2.00	N/A	0	1.00	N/A	49.0	100.0 %	CCI149073	9/17/2026
08/08/2019	09:29	02_5	SPAN	22.48	22.21	-0.27	N/A	2.00	N/A	0	1.00	N/A	0.0	0.0 %	CCI149073	9/17/2026
08/05/2019	17:31	02_5	ZERO	0.00	0.10	0.10	N/A	2.00	N/A	0	1.00	N/A	48.6	100.0 %	CCI149073	9/17/2026
08/05/2019	17:31	02_5	SPAN	22.48	22.17	-0.31	N/A	2.00	N/A	0	1.00	N/A	0.0	0.0 %	CCI149073	9/17/2026
08/04/2019	18:46	02_5	ZERO	0.00	0.10	0.10	N/A	2.00	N/A	0	1.00	N/A	49.6	100.0 %	CCI149073	9/17/2026
08/04/2019	18:46	02_5	SPAN	22.48	22.20	-0.28	N/A	2.00	N/A	0	1.00	N/A	0.0	0.0 %	CCI149073	9/17/2026
08/02/2019	13:31	02_5	ZERO	0.00	0.10	0.10	N/A	2.00	N/A	0	1.00	N/A	49.0	100.0 %	CCI149073	9/17/2026
08/02/2019	13:31	02_5	SPAN	22.48	22.25	-0.23	N/A	2.00	N/A	0	1.00	N/A	0.0	0.0 %	CCI149073	9/17/2026
08/01/2019	12:10	02_5	ZERO	0.00	0.10	0.10	N/A	2.00	N/A	0	1.00	N/A	48.4	100.0 %	CCI149073	9/17/2026
08/01/2019	12:10	02_5	SPAN	22.38	22.08	-0.30	N/A	2.00	N/A	0	1.00	N/A	0.0	0.0 %	CCI149073	9/17/2026
07/28/2019	18:02	02_5	ZERO	0.00	0.10	0.10	N/A	2.00	N/A	0	1.00	N/A	48.9	5.9 %	CCI149073	9/17/2026
07/28/2019	18:02	02_5	SPAN	22.38	22.13	-0.25	N/A	2.00	N/A	0	1.00	N/A	49.2	100.0 %	CCI149073	9/17/2026
07/24/2019	07:30	02_5	ZERO	0.00	0.10	0.10	N/A	2.00	N/A	0	1.00	N/A	48.5	100.0 %	CCI149073	9/17/2026
07/24/2019	07:30	02_5	SPAN	22.38	22.14	-0.24	N/A	2.00	N/A	0	1.00	N/A	49.0	100.0 %	CCI149073	9/17/2026
07/23/2019	11:01	02_5	ZERO	0.00	0.10	0.10	N/A	2.00	N/A	0	1.00	N/A	48.9	100.0 %	CCI149073	9/17/2026
07/23/2019	11:01	02_5	SPAN	22.38	22.13	-0.25	N/A	2.00	N/A	0	1.00	N/A	0.0	0.0 %	CCI149073	9/17/2026
07/22/2019	10:01	02_5	ZERO	0.00	0.10	0.10	N/A	2.00	N/A	0	1.00	N/A	48.9	100.0 %	CCI149073	9/17/2026
07/22/2019	10:01	02_5	SPAN	22.38	22.07	-0.31	N/A	2.00	N/A	0	1.00	N/A	0.0	0.0 %	CCI149073	9/17/2026
07/19/2019	18:16	02_5	ZERO	0.00	0.10	0.10	N/A	2.00	N/A	0	1.00	N/A	48.9	100.0 %	CCI149073	9/17/2026
07/19/2019	18:16	02_5	SPAN	22.38	22.02	-0.36	N/A	2.00	N/A	0	1.00	N/A	0.0	0.0 %	CCI149073	9/17/2026
07/16/2019	15:46	02_5	ZERO	0.00	0.10	0.10	N/A	2.00	N/A	0	1.00	N/A	48.9	100.0 %	CCI149073	9/17/2026
07/16/2019	15:46	02_5	SPAN	22.38	22.13	-0.25	N/A	2.00	N/A	0	1.00	N/A	0.0	0.0 %	CCI149073	9/17/2026
07/08/2019	06:31	02_5	ZERO	0.00	0.10	0.10	N/A	2.00	N/A	0	1.00	N/A	48.9	100.0 %	CCI149073	9/17/2026
07/08/2019	06:31	02_5	SPAN	22.38	22.13	-0.25	N/A	2.00	N/A	0	1.00	N/A	49.4	100.0 %	CCI149073	9/17/2026
06/29/2019	17:46	02_5	ZERO	0.00	0.10	0.10	N/A	2.00	N/A	0	1.00	N/A	48.9	100.0 %	CCI149073	9/17/2026
06/29/2019	17:46	02_5	SPAN	22.38	22.13	-0.25	N/A	2.00	N/A	0	1.00	N/A	49.4	100.0 %	CCI149073	9/17/2026
06/20/2019	10:12	02_5	ZERO	0.00	0.10	0.10	N/A	2.00	N/A	0	1.00	N/A	48.9	100.0 %	CCI149073	9/17/2026
06/20/2019	10:12	02_5	SPAN	22.38	22.13	-0.25	N/A	2.00	N/A	0	1.00	N/A	49.4	100.0 %	CCI149073	9/17/2026
06/10/2019	19:31	02_5	ZERO	0.00	0.10	0.10	N/A	2.00	N/A	0	1.00	N/A	48.9	100.0 %	CCI149073	9/17/2026
06/10/2019	19:31	02_5	SPAN	22.38	22.10	-0.28	N/A	2.00	N/A	0	1.00	N/A	49.4	100.0 %	CCI149073	9/17/2026
06/04/2019	06:31	02_5	ZERO	0.00	0.10	0.10	N/A	2.00	N/A	0	1.00	N/A	48.9	100.0 %	CCI149073	9/17/2026
06/04/2019	06:31	02_5	SPAN	22.38	22.08	-0.30	N/A	2.00	N/A	0	1.00	N/A	49.4	100.0 %	CCI149073	9/17/2026

Rabcock & Wilcox Power Generation Group NetDARSS

Daily Stack Calibration Report  
Generated: 2/11/2020


Period Start: 1/1/2019  
Period End: 12/30/2019  
Included Calibrations: Daily (40CFR60)/(40CFR75)

Company: McGrath Generating Station  
Plant: 251 N. Harbor Blvd.  
City/ST: Oxnard, CA 93035  
Source: stack

Date	Time	Channel	Type	Target Units	Actual Units	Diff Units	Error %	Units	Part60 Allowable	Part75 Allowable	Gross MW	Process On	Bottle ID	Expire Date
03/06/2019	14:56	02_5	ZERO	0.00	0.15	-0.15	-100.00	2.00	N/A	N/A	0.0	0.0	SG9159413BAL	7/9/2026
03/06/2019	14:56	02_5	SPAN	22.47	22.21	-0.26	-1.16	2.00	N/A	N/A	50.5	100.0	SG9159413BAL	7/9/2026
03/05/2019	07:33	02_5	ZERO	0.00	0.14	-0.14	-100.00	2.00	N/A	N/A	50.5	100.0	SG9159413BAL	7/9/2026
03/05/2019	07:33	02_5	SPAN	22.47	22.25	-0.22	-0.98	2.00	N/A	N/A	50.2	100.0	ALM-063377	7/9/2026
03/04/2019	18:01	02_5	ZERO	0.00	0.13	-0.13	-100.00	2.00	N/A	N/A	50.3	100.0	SG9159413BAL	7/9/2026
03/04/2019	18:01	02_5	SPAN	22.47	22.28	-0.19	-0.84	2.00	N/A	N/A	50.3	100.0	ALM-063377	7/9/2026
03/02/2019	06:01	02_5	ZERO	0.00	0.13	-0.13	-100.00	2.00	N/A	N/A	50.4	100.0	SG9159413BAL	7/9/2026
03/02/2019	06:01	02_5	SPAN	22.47	22.21	-0.26	-1.16	2.00	N/A	N/A	50.4	100.0	ALM-063377	7/9/2026
02/26/2019	23:21	02_5	ZERO	0.00	0.12	-0.12	-100.00	2.00	N/A	N/A	50.6	100.0	SG9159413BAL	7/9/2026
02/26/2019	23:21	02_5	SPAN	22.47	22.28	-0.19	-0.84	2.00	N/A	N/A	50.6	100.0	ALM-063377	7/9/2026
02/25/2019	19:46	02_5	ZERO	0.00	0.12	-0.12	-100.00	2.00	N/A	N/A	50.9	100.0	SG9159413BAL	7/9/2026
02/25/2019	19:46	02_5	SPAN	22.47	22.25	-0.22	-0.98	2.00	N/A	N/A	50.9	100.0	ALM-063377	7/9/2026
02/19/2019	18:01	02_5	ZERO	0.00	0.13	-0.13	-100.00	2.00	N/A	N/A	50.6	100.0	SG9159413BAL	7/9/2026
02/19/2019	18:01	02_5	SPAN	22.47	22.29	-0.18	-0.81	2.00	N/A	N/A	50.6	100.0	ALM-063377	7/9/2026
02/15/2019	17:46	02_5	ZERO	0.00	0.12	-0.12	-100.00	2.00	N/A	N/A	0.0	0.0	SG9159413BAL	7/9/2026
02/15/2019	17:46	02_5	SPAN	22.47	22.26	-0.21	-0.93	2.00	N/A	N/A	0.0	0.0	ALM-063377	7/9/2026
02/14/2019	13:40	02_5	ZERO	0.00	0.13	-0.13	-100.00	2.00	N/A	N/A	50.9	100.0	SG9159413BAL	7/9/2026
02/14/2019	13:40	02_5	SPAN	22.47	22.27	-0.19	-0.84	2.00	N/A	N/A	50.9	100.0	ALM-063377	7/9/2026
02/08/2019	17:18	02_5	ZERO	0.00	0.16	-0.16	-100.00	2.00	N/A	N/A	0.0	0.0	SG9159413BAL	7/9/2026
02/08/2019	17:18	02_5	SPAN	22.47	22.31	-0.16	-0.71	2.00	N/A	N/A	0.0	0.0	ALM-063377	7/9/2026
02/06/2019	15:00	02_5	ZERO	0.00	0.13	-0.13	-100.00	2.00	N/A	N/A	50.8	100.0	SG9159413BAL	7/9/2026
02/06/2019	15:00	02_5	SPAN	22.47	22.32	-0.15	-0.67	2.00	N/A	N/A	50.8	100.0	CC100080	8/21/2026
02/05/2019	06:46	02_5	ZERO	0.00	0.13	-0.13	-100.00	2.00	N/A	N/A	49.9	100.0	SG9159413BAL	7/9/2026
02/05/2019	06:46	02_5	SPAN	22.50	22.20	-0.30	-1.33	2.00	N/A	N/A	49.9	100.0	CC100080	8/21/2026
02/04/2019	17:46	02_5	ZERO	0.00	0.13	-0.13	-100.00	2.00	N/A	N/A	50.2	100.0	SG9159413BAL	7/9/2026
02/04/2019	17:46	02_5	SPAN	22.50	22.13	-0.37	-1.64	2.00	N/A	N/A	50.2	100.0	CC100080	8/21/2026
02/03/2019	18:01	02_5	ZERO	0.00	0.13	-0.13	-100.00	2.00	N/A	N/A	50.0	100.0	SG9159413BAL	7/9/2026
02/03/2019	18:01	02_5	SPAN	22.50	22.18	-0.32	-1.42	2.00	N/A	N/A	50.0	100.0	CC100080	8/21/2026
02/02/2019	21:31	02_5	ZERO	0.00	0.13	-0.13	-100.00	2.00	N/A	N/A	50.3	100.0	SG9159413BAL	7/9/2026
02/02/2019	21:31	02_5	SPAN	22.50	22.14	-0.36	-1.60	2.00	N/A	N/A	50.3	100.0	CC100080	8/21/2026
02/01/2019	17:16	02_5	ZERO	0.00	0.13	-0.13	-100.00	2.00	N/A	N/A	50.3	100.0	SG9159413BAL	7/9/2026
02/01/2019	17:16	02_5	SPAN	22.50	22.24	-0.26	-1.16	2.00	N/A	N/A	50.3	100.0	CC100080	8/21/2026
01/29/2019	19:31	02_5	ZERO	0.00	0.13	-0.13	-100.00	2.00	N/A	N/A	50.7	100.0	SG9159413BAL	7/9/2026
01/29/2019	19:31	02_5	SPAN	22.50	22.17	-0.33	-1.46	2.00	N/A	N/A	50.7	100.0	CC100080	8/21/2026
01/25/2019	07:16	02_5	ZERO	0.00	0.12	-0.12	-100.00	2.00	N/A	N/A	49.9	100.0	SG9159413BAL	7/9/2026
01/25/2019	07:16	02_5	SPAN	22.50	22.45	-0.05	-0.22	2.00	N/A	N/A	49.9	100.0	CC100080	8/21/2026
01/24/2019	07:16	02_5	ZERO	0.00	0.11	-0.11	-100.00	2.00	N/A	N/A	50.1	100.0	SG9159413BAL	7/9/2026
01/24/2019	07:16	02_5	SPAN	22.50	22.36	-0.14	-0.62	2.00	N/A	N/A	50.1	100.0	CC100080	8/21/2026
01/23/2019	17:13	02_5	ZERO	0.00	0.13	-0.13	-100.00	2.00	N/A	N/A	50.3	100.0	SG9159413BAL	7/9/2026
01/23/2019	17:13	02_5	SPAN	22.50	22.33	-0.17	-0.76	2.00	N/A	N/A	50.3	100.0	CC100080	8/21/2026
01/22/2019	06:46	02_5	ZERO	0.00	0.12	-0.12	-100.00	2.00	N/A	N/A	50.5	100.0	SG9159413BAL	7/9/2026
01/22/2019	06:46	02_5	SPAN	22.50	22.36	-0.14	-0.62	2.00	N/A	N/A	50.5	100.0	CC100080	8/21/2026
01/22/2019	07:13	02_5	ZERO	0.00	0.13	-0.13	-100.00	2.00	N/A	N/A	50.6	100.0	SG9159413BAL	7/9/2026
01/22/2019	07:13	02_5	SPAN	22.50	22.47	-0.03	-1.33	2.00	N/A	N/A	50.6	100.0	CC100080	8/21/2026
01/19/2019	17:16	02_5	ZERO	0.00	0.13	-0.13	-100.00	2.00	N/A	N/A	49.8	100.0	SG9159413BAL	7/9/2026
01/19/2019	17:16	02_5	SPAN	22.50	22.38	-0.12	-5.33	2.00	N/A	N/A	49.8	100.0	CC100080	8/21/2026
01/18/2019	07:01	02_5	ZERO	0.00	0.12	-0.12	-100.00	2.00	N/A	N/A	51.0	100.0	SG9159413BAL	7/9/2026
01/18/2019	07:01	02_5	SPAN	22.50	22.43	-0.07	-3.11	2.00	N/A	N/A	51.0	100.0	CC100080	8/21/2026

## **Attachment 4**

# **SCR and CO catalyst and temperature devices calibrations Records**



# Instrumentation Calibration Record McGrath Peaker

Instrument Number | PDIT-402

Instrument Name | Co Catalyst Pres Drop Transmitter W/ Ind (B-255-PDIT-402)

Zero | 0 | Span | 5 | Units | "WG

Alarm 1 Setpoint | | Alarm 2 Setpoint | |

Alarm 1 Inc/Dec | | Alarm 2 Inc/Dec | |

⊙ Span Calibration- Found	0%	<u>0</u>	25	<u>1.25</u>	50%	<u>2.5</u>	75%	<u>3.75</u>	100%	<u>5</u>
		<del>3.9</del> 4.2		8.2		<del>11.34</del> 12.6		16.4		<del>16.5</del> 19.8
⊙ Span Calibration- Left	0%	4.2	25	8.2	50%	12.6	75%	16.4	100%	19.8

⊙ Switch Calibration Setpoint Found | N/A | Setpoint Left | N/A

System | NH3 System

Location | NH3 Service Platform


Technician | Hiu / Hinson | Completion Date | 5-16-2019

Manufacturer | Fluke | Manufacturer | Fluke

Model | 700DP5 | Model | 754

Serial Number | 457734 | Serial Number | 2308008

Calibration Due Date | 4-9-2020 | Calibration Due Date | 3-9-2019



# Instrumentation Calibration Record McGrath Peaker

Instrument Number | TE-403B

Instrument Name | McGrath Scr Catalyst Inlet Temp Element (B-255-TE-403B)

Zero | \_\_\_\_\_ Span | \_\_\_\_\_ Units | \_\_\_\_\_

Alarm 1 Setpoint | \_\_\_\_\_ Alarm 2 Setpoint | \_\_\_\_\_

Alarm 1 Inc/Dec | \_\_\_\_\_ Alarm 2 Inc/Dec | \_\_\_\_\_

	0%	25%	50%	75%	100%
Span Calibration- Found	31.8	301.8	600.1	900.3	1200.7
Span Calibration- Left	31.8	301.8	600.1	900.3	1200.7


Switch Calibration Setpoint Found | \_\_\_\_\_ Setpoint Left | \_\_\_\_\_

System | Emmissions Reduction

Location | SCR Catalyst

Technician | *SCOTT HINSON* Completion Date | *5-15-19*

Manufacturer	<i>Fluke</i>	Manufacturer	<i>Fluke</i>
Model	<i>91025</i>	Model	<i>91441</i>
Serial Number	<i>B28355</i>	Serial Number	<i>B2A126</i>
Calibration Due Date	<i>4-9-2020</i>	Calibration Due Date	<i>4-9-2020</i>



# Instrumentation Calibration Record McGrath Peaker

Instrument Number | TE-404B

Instrument Name | McGrath Scr Catalyst Outlet Temp Element (B-255-TE-404B)

Zero	Span	Units																				
Alarm 1 Setpoint	Alarm 2 Setpoint																					
Alarm 1 Inc/Dec	Alarm 2 Inc/Dec																					
Span Calibration- Found	<table style="width: 100%; text-align: center;"> <tr> <td>0%</td> <td><u>32</u></td> <td>25</td> <td><u>300</u></td> <td>50%</td> <td><u>600</u></td> <td>75%</td> <td><u>900</u></td> <td>100%</td> <td><u>1200</u></td> </tr> <tr> <td></td> <td><u>32.2</u></td> <td></td> <td><u>300.6</u></td> <td></td> <td><u>601.2</u></td> <td></td> <td><u>902.5</u></td> <td></td> <td><u>1200.9</u></td> </tr> </table>	0%	<u>32</u>	25	<u>300</u>	50%	<u>600</u>	75%	<u>900</u>	100%	<u>1200</u>		<u>32.2</u>		<u>300.6</u>		<u>601.2</u>		<u>902.5</u>		<u>1200.9</u>	
0%	<u>32</u>	25	<u>300</u>	50%	<u>600</u>	75%	<u>900</u>	100%	<u>1200</u>													
	<u>32.2</u>		<u>300.6</u>		<u>601.2</u>		<u>902.5</u>		<u>1200.9</u>													
Span Calibration- Left	<table style="width: 100%; text-align: center;"> <tr> <td>0%</td> <td><u>32</u></td> <td>25</td> <td><u>300</u></td> <td>50%</td> <td><u>600</u></td> <td>75%</td> <td><u>900</u></td> <td>100%</td> <td><u>1200</u></td> </tr> <tr> <td></td> <td><u>32.2</u></td> <td></td> <td><u>300.6</u></td> <td></td> <td><u>601.2</u></td> <td></td> <td><u>902.5</u></td> <td></td> <td><u>1200.9</u></td> </tr> </table>	0%	<u>32</u>	25	<u>300</u>	50%	<u>600</u>	75%	<u>900</u>	100%	<u>1200</u>		<u>32.2</u>		<u>300.6</u>		<u>601.2</u>		<u>902.5</u>		<u>1200.9</u>	
0%	<u>32</u>	25	<u>300</u>	50%	<u>600</u>	75%	<u>900</u>	100%	<u>1200</u>													
	<u>32.2</u>		<u>300.6</u>		<u>601.2</u>		<u>902.5</u>		<u>1200.9</u>													
Switch Calibration	Setpoint Found	Setpoint Left																				


System | Emmissions Reduction

Location | SCR Catalyst

Technician | Scott Hinson      Completion Date | 5-15-19

Manufacturer	<u>Fluke</u>	Manufacturer	<u>Fluke</u>
Model	<u>91025</u>	Model	<u>9144</u>
Serial Number	<u>B28355</u>	Serial Number	<u>B2A126</u>
Calibration Due Date	<u>4-9-2020</u>	Calibration Due Date	<u>4-9-2020</u>





# Instrumentation Calibration Record McGrath Peaker

Instrument Number TE-404A

Instrument Name McGrath Scr Catalyst Outlet Temp Element (B-255-TE-404A)


Zero	Span	Units
Alarm 1 Setpoint	Alarm 2 Setpoint	
Alarm 1 Inc/Dec	Alarm 2 Inc/Dec	
Span Calibration- Found	0% <u>32</u> <u>32.2</u>	25% <u>300</u> <u>300.4</u>
	50% <u>600</u> <u>600.3</u>	75% <u>900</u> <u>900.1</u>
	100% <u>1200</u> <u>1200.9</u>	
Span Calibration- Left	0% <u>32.2</u>	25% <u>300.4</u>
	50% <u>600.3</u>	75% <u>900.1</u>
	100% <u>1200.9</u>	
Switch Calibration	Setpoint Found	Setpoint Left

System Emmissions Reduction

Location SCR Catalyst

Technician SCOTT HINSON Completion Date 5-15-19

Manufacturer <u>Fluke</u>	Manufacturer <u>Fluke</u>
Model <u>9102S</u>	Model <u>9144</u>
Serial Number <u>828355</u>	Serial Number <u>B2A126</u>
Calibration Due Date <u>4-9-2020</u>	Calibration Due Date <u>4-9-2020</u>



# Instrumentation Calibration Record McGrath Peaker

Instrument Number | PDIT-403

Instrument Name | SCR Catalyst Pres Drop Transmitter W/ Ind (B-255-PDIT-403)

Zero | 0 | Span | 10 | Units | WG

Alarm 1 Setpoint | | Alarm 2 Setpoint | |

Alarm 1 Inc/Dec | | Alarm 2 Inc/Dec | |

<input checked="" type="radio"/> Span Calibration- Found	0%	25	50%	75%	100%
	4.36	8.2	12.2	16.2	20.5
<input checked="" type="radio"/> Span Calibration- Left	0%	25	50%	75%	100%
	4.36	8.2	12.2	16.2	20.5


Switch Calibration Setpoint Found | N/A | Setpoint Left | N/A

System | NH3 System

Location | NH3 Service Platform

Technician | Hill/Hinson | Completion Date | 5-16-2019

Manufacturer	Fluke	Manufacturer	Fluke
Model	700DP5	Model #	754
Serial Number	457734	Serial Number	2308008
Calibration Due Date	4-9-2020	Calibration Due Date	3-9-2019



# Instrumentation Calibration Record McGrath Peaker

Instrument Number | TE-403D

Instrument Name | McGrath Scr Catalyst Inlet Temp Element (B-255-TE-403D)

Zero | \_\_\_\_\_ Span | \_\_\_\_\_ Units | \_\_\_\_\_

Alarm 1 Setpoint | \_\_\_\_\_ Alarm 2 Setpoint | \_\_\_\_\_

Alarm 1 Inc/Dec | \_\_\_\_\_ Alarm 2 Inc/Dec | \_\_\_\_\_

		32		300		600		900		1200
Span Calibration- Found	0%	32.2	25	300.7	50%	600.8	75%	901.0	100%	1200.7

Span Calibration- Left	0%	32.2	25	300.7	50%	600.8	75%	901.0	100%	1200.7
---------------------------	----	------	----	-------	-----	-------	-----	-------	------	--------


Switch Calibration Setpoint Found | \_\_\_\_\_ Setpoint Left | \_\_\_\_\_

System | Emmissions Reduction

Location | SCR Catalyst

Technician | *Scott Hanson* Completion Date | *5-15-19*

Manufacturer	<i>Fluke</i>	Manufacturer	<i>Fluke</i>
Model	<i>91025</i>	Model	<i>9144</i>
Serial Number	<i>B28355</i>	Serial Number	<i>B2A126</i>
Calibration Due Date	<i>4-9-2020</i>	Calibration Due Date	<i>4-9-2020</i>



# Instrumentation Calibration Record McGrath Peaker

Instrument Number TE-403A

Instrument Name McGrath Scr Catalyst Inlet Temp Element (B-255-TE-403A)


Zero	Span	Units				
Alarm 1 Setpoint	Alarm 2 Setpoint					
Alarm 1 Inc/Dec	Alarm 2 Inc/Dec					
Span Calibration- Found	0% <u>52</u>	25% <u>31.8</u>	50% <u>299.1</u>	75% <u>600.6</u>	100% <u>901.2</u>	1200 <u>1200.4</u>
	0% <u>31.8</u>	25% <u>299.1</u>	50% <u>600.6</u>	75% <u>901.2</u>	100% <u>1200.4</u>	
Switch Calibration	Setpoint Found	Setpoint Left				

System Emmissions Reduction

Location SCR Catalyst

Technician SCOTT Hinson Completion Date 5-15-19

Manufacturer <u>Fluke</u>	Manufacturer <u>Fluke</u>
Model <u>91025</u>	Model <u>9144</u>
Serial Number <u>B28355</u>	Serial Number <u>B2A126</u>
Calibration Due Date <u>4/9/2020</u>	Calibration Due Date <u>4/9/2020</u>



# Instrumentation Calibration Record McGrath Peaker

Instrument Number | TE-403C

Instrument Name | McGrath Scr Catalyst Inlet Temp Element (B-255-TE-403C)

Zero | \_\_\_\_\_ Span | \_\_\_\_\_ Units | \_\_\_\_\_

Alarm 1 Setpoint | \_\_\_\_\_ Alarm 2 Setpoint | \_\_\_\_\_

Alarm 1 Inc/Dec | \_\_\_\_\_ Alarm 2 Inc/Dec | \_\_\_\_\_

	0%	<sup>32</sup>		25	<sup>300</sup>		50%	<sup>600</sup>		75%	<sup>900</sup>		100%	<sup>1200</sup>
Span Calibration- Found		32.2			302.4			600.3			900.9			1200.6

	0%	<sup>32</sup>		25	<sup>300</sup>		50%	<sup>600</sup>		75%	<sup>900</sup>		100%	<sup>1200</sup>
Span Calibration- Left		32.2			302.4			600.3			900.9			1200.6

Switch Calibration Setpoint Found | \_\_\_\_\_ Setpoint Left | \_\_\_\_\_

System | Emmissions Reduction

Location | SCR Catalyst

Technician | *Scott Hinson* Completion Date | *5-15-19*

Manufacturer   <i>Fluke</i>	Manufacturer   <i>Fluke</i>
Model   <i>9102S</i>	Model   <i>9144</i>
Serial Number   <i>B28355</i>	Serial Number   <i>B2A126</i>
Calibration Due Date   <i>4-9-2020</i>	Calibration Due Date   <i>4-9-2020</i>

## **Attachment 5**

### **Fuel and Ammonia flowmeters calibrations records**



# Fuel flowmeter



1963 Essex Court  
 Redlands, CA 92373  
 (909)307-2295 Fax (909)307-2395  
 www.gommci.com

## Certificate of Calibration

Calibration Date:	5/13/2019
Calibration Due Date:	5/13/2020
Customer:	McGrath Peaker, 251 N. Harbor Blvd., Oxnard, CA

Certificate Lot Number:	190513
Technician:	Ricardo Linares
CA Weights & Measures ID:	1918-30904

### Calibrated Instrument Data

Equipment ID:	427111 (Sensor), 427110 (Flow Converter)	Manufacturer:	Yokogawa		
Location:	Unknown-Device shipped to MMCI headquarters for calibration.	Model Number:	DY050S1-NBLBA4-2N/KF1/SCT (Sensor), DYAS1-D2N/KF1/SCT (Flow Converter)		
Calibration Description:	Hydraulic calibration with direct totalizer comparison from flow meter to calibration standard indicated below. Flow meter is a 2" vortex style with remote flow converter.	Serial Number:	S5F505478 620 (Sensor) S5F505492 620 (Flow Converter)		
Notes:	NA	As Found		As Left	
		Adjustment K	1.0000		1.0000
		mA Output 1:	0 to 345 cf/min		0 to 345 cf/min
		K-Factor:	8.833 Pulses/liter		8.833 Pulses/liter

### Calibration Performance

Status:	Found (Hydraulic calibration of flow meter with direct totalizer comparison to MMCI standard)			Units:	US Gallons
				Tolerance:	± 0.80%
Test Rate/min	Sensor Total	Standard	Error Sensor/Standard		Pass/Fail
50	154.00	154.76	-0.49%		Pass
100	307.00	306.38	0.20%		Pass
150	319.00	318.49	0.16%		Pass

Status:	Left (Hydraulic calibration of flow meter with direct totalizer comparison to MMCI standard)			Units:	US Gallons
				Tolerance:	± 0.80%
Test Rate/min	Sensor Total	Standard	Error Sensor/Standard		Pass/Fail

### Calibration Standards

Standard 1:	Gravimetric Prover, MOD: 4X4 HP-5K, SN: 95-5690, Due: 6/6/2019, NIST: 1197132
Standard 2:	

Standard 3:	
Standard 4:	

Technician Signature

This device has been calibrated using standards traceable to the National Institute of Standards & Technology (NIST). This certificate shall not be reproduced in any form, except in full, without the expressed written consent of MMCI. Please refer to MMCI's contact information above regarding any questions associated with this certificate.

# Fuel flow transmitter



1963 Essex Court  
Redlands, CA 92373  
(909)307-2295 Fax (909)307-2395  
www.gommi.com

## Certificate of Calibration

Calibration Date:	5/13/2019
Calibration Due Date:	5/13/2020
Customer:	McGrath Peaker, 251 N. Harbor Blvd., Oxnard, CA

Certificate Lot Number:	190513
Technician:	Ricardo Linares
CA Weights & Measures ID:	1918-30904

### Calibrated Instrument Data

Equipment ID:	427111 (Sensor), 427110 (Flow Converter)	Manufacturer:	Yokogawa		
Location:	Unknown-Device shipped to MMCI headquarters for calibration.	Model Number:	DY050S1-NBLBA4-2N/KF1/SCT (Sensor), DYAS1-D2N/KF1/SCT (Flow Converter)		
Calibration Description:	mA calibration of flow transmitter mA output #1	Serial Number:	S5F505478 620 (Sensor), S5F505492 620 (Flow Converter)		
Notes:	NA	As Found			
		Adjustment K	1.0000	As Left	1.0000
		mA Output 1:	0 to 345 c/min		0 to 345 c/min
		K-Factor:	8.833 Pulses/liter		8.833 Pulses/liter

### Calibration Performance


Status:	Found (mA calibration of flow transmitter mA output with direct comparison to MMCI standard)			Units:	mA
				Tolerance:	± 0.20%
Sensor Simulated mA	Standard Measured	Error Sensor/Standard			Pass/Fail
4.00	3.998	0.05%			Pass
8.00	7.998	0.03%			Pass
12.00	11.998	0.02%			Pass
16.00	15.998	0.01%			Pass
20.00	19.996	0.02%			Pass

Status:	Left (mA calibration of flow transmitter mA output with direct comparison to MMCI standard)			Units:	mA
				Tolerance:	± 0.20%
Sensor Simulated mA	Standard Measured	Error Sensor/Standard			Pass/Fail

### Calibration Standards

Standard 1:	Fluke 744, SN: 8060005, Due: 7/11/2019, NIST: 19-B229L-20-1
Standard 2:	

Standard 3:	
Standard 4:	

Technician Signature 

This device has been calibrated using standards traceable to the National Institute of Standards & Technology (NIST). This certificate shall not be reproduced in any form, except in full, without the expressed written consent of MMCI. Please refer to MMCI's contact information above regarding any questions associated with this certificate.

# Ammonia flow meter



1963 Essex Court  
Redlands, CA 92373  
(909)307-2295 Fax (909)307-2395  
www.gommci.com

## Certificate of Calibration

Calibration Date:	5/13/2019
Calibration Due Date:	5/13/2020
Customer:	McGrath Peaker, 251 N. Harbor Blvd., Oxnard, CA

Certificate Lot Number:	190513
Technician:	Ricardo Linares
CA Weights & Measures ID:	1918-30904

### Calibrated Instrument Data

Equipment ID:	457823	Manufacturer:	Micro Motion		
Location:	Unknown	Model Number:	CMF025M313NQBUEZZZ (Sensor), 1700R11ABUEZZZ (Xmitr)		
Calibration Description:	Hydraulic calibration with direct totalizer comparison from flow meter to calibration standard indicated below. Flow meter is a 0.25" Coriolis with remote transmitter.	Serial Number:	14358175 (Sensor), 3215549 (Xmitr)		
Notes:	NA	As Found			
		Flo Cal Factor:	5.1149	As Left	5.1149
		mA Output 1:	0 to 150 lb/hr		0 to 150 lb/hr
		Pulse Out:	25,000 pulses/lb		25,000 pulses/lb

### Calibration Performance

Status:	Found (Hydraulic calibration of flow meter with direct totalizer comparison to MMCI standard)			Units:	Pounds
				Tolerance:	± 0.50%
Test Rate/Hour	Sensor Total	Standard	Error Sensor/Standard		Pass/Fail
75	6.187	6.185	0.03%		Pass
100	8.355	8.350	0.06%		Pass
150	12.563	12.560	0.02%		Pass

Status:	Left (Hydraulic calibration of flow meter with direct totalizer comparison to MMCI standard)			Units:	Pounds
				Tolerance:	± 0.50%
Test Rate/Hour	Sensor Total	Standard	Error Sensor/Standard		Pass/Fail

### Calibration Standards

Standard 1:	Torrey Scale, Mod: L-EQ 10/20, SN: I16-006363, Due: 6/12/2018, NIST: 2384501
Standard 2:	

Standard 3:	
Standard 4:	

Technician Signature 

This device has been calibrated using standards traceable to the National Institute of Standards & Technology (NIST). This certificate shall not be reproduced in any form, except in full, without the expressed written consent of MMCI. Please refer to MMCI's contact information above regarding any questions associated with this certificate.

# Ammonia transmitter



1963 Essex Court  
 Redlands, CA 92373  
 (909)307-2295 Fax (909)307-2395  
 www.gommci.com

## Certificate of Calibration

Calibration Date:	5/13/2019
Calibration Due Date:	5/13/2020
Customer:	McGrath Peaker, 251 N. Harbor Blvd, Oxnard, CA

Certificate Lot Number:	190513
Technician:	Ricardo Linares
CA Weights & Measures ID:	1918-30904

### Calibrated Instrument Data

Equipment ID:	457823	Manufacturer:	Micro Motion		
Location:	Unknown	Model Number:	CMF025M313NOBUEZZZ (Sensor), 1700R11ABUEZZZ (Xmitr)		
Calibration Description:	Calibration of transmitter mA output	Serial Number:	14358175 (Sensor), 3215549 (Xmitr)		
Notes:	NA		As Found		As Left
		Flo Cal Factor:	5.1149		5.1149
		mA Output 1:	0 to 150 lb/hr		0 to 150 lb/hr
		Pulse Out:	25 000 pulses/lb		25,000 pulses/lb

### Calibration Performance

Status:	Found (mA calibration of flow transmitter mA output with direct comparison to MMCI standard)			Units:	mA
				Tolerance:	± 0.20%
Sensor Simulated mA	Standard Measured	Error Sensor/Standard			Pass/Fail
4.00	3.996	0.10%			Pass
8.00	7.997	0.04%			Pass
12.00	11.997	0.03%			Pass
16.00	15.997	0.02%			Pass
20.00	19.997	0.02%			Pass

Status:	Left (mA calibration of flow transmitter mA output with direct comparison to MMCI standard)			Units:	mA
				Tolerance:	± 0.20%
Sensor Simulated mA	Standard Measured	Error Sensor/Standard			Pass/Fail

### Calibration Standards

Standard 1:	Fuke 744, SN: 8060005, Due: 7/11/2019, NIST: 19-B2Z9L-20-1
Standard 2:	

Standard 3:	
Standard 4:	

Technician Signature 

This device has been calibrated using standards traceable to the National Institute of Standards & Technology (NIST). This certificate shall not be reproduced in any form, except in full, without the expressed written consent of MMCI. Please refer to MMCI's contact information above regarding any questions associated with this certificate.

**Attachment 6**  
**Generator and Engine Specification**



Waukesha VGF Series

A photograph showing a worker in a yellow jacket and white hard hat standing next to a large, complex industrial gas engine. The engine is mounted on a red base and has various pipes and components. The background shows a factory environment with metal structures and a concrete floor.

A New Look At  
Reliable, Compact,  
Low Emission  
Gas Engines.



Whether you're designing an engine package for a new installation or retrofitting an engine room, space is always an issue. Your customers want more power squeezed into smaller spaces. So, how do you reconcile the need for more power and limited space? Simple, size up the Waukesha VGF family of gas engines. This series of compact, fuel efficient, low emission gas engines comes in 6, 8, 12 and 16 cylinder outputs with both

inline and vee configurations to meet almost any installation requirements.


### **Driving Down the Cost of Horsepower.**

This compact engine is purposely designed from the ground up for stationary, spark ignited, gaseous fuel applications. The VGF is not limited to weight-sensitive mobile equipment requirements. Its high weight-to-power ratio provides a solid foundation for years of

consistent and dependable operation. For the size and price of other high speed engines, the VGF provides full power around the clock, with substantially reduced maintenance and operating costs. You get more engine, more reliability, more performance, more uptime, and more value – at less cost.

Because of their size to power ratio and high speed continuous-duty capability, VGF engines are remarkably cost-effective to

# A Family of Compact Engines



their "clean" design requires less piping.

**Strong Resemblance.**

The VGF Series reflects Waukesha's usual robust structural strength, along with sophisticated engineering features. Derived from the design and manufacturing integrity of the classic Waukesha VHP, these engines have inherently long component life. So overhaul intervals will be few and far between. The performance and durability of the VGF Series make this engine

line a design classic in itself.

**Fast and Lean.**

VGF engines lead a clean life, thanks to Waukesha's lean burn technology. Our patented combustion system allows the VGF engine to meet clean air standards throughout the world. (Consult your distributor for site specific requirements.) Both GL (Gas Lean Burn) and GLD (Gas Lean Burn Draw Thru) models are available as standard

engines. They are designed to run efficiently with high or low fuel pressure systems for maximum application flexibility.

The VGF is also available in a rich burn naturally aspirated version (G) for applications where less horsepower is required or a 3-way catalyst is desired.

*The Waukesha VGF Series. Simple to buy.*

*Simple to install. Simple to run. Simple to meet emissions requirements. Simple to*

*maintain. How much simpler can we make*

*your engine choice?*

# to Fit Your Requirements.






# VGF

First of all, we need to drive home a simple point. This is not a warmed over automotive engine designed for occasional rpm spikes. The VGF is industrial strength continuous high rpm horsepower in a range from 160 BHP (120 KWb) to 1065 BHP (800 KWb).

## How this Hard-Working



- The *GL (Lean Burn) fuel system and high turbulence combustion chamber* provide excellent fuel efficiency and optimum combustion stability.
- VGF's *optimum BMEP* results in better service life for key components and long maintenance intervals.

■ *Patented high turbulence combustion chamber* allows ability to burn lean air fuel mixtures with an open combustion chamber. This produces low emissions across engine load and speed range. It also provides lower fuel consumption, which is typically 91%



of life cycle costs.

- *Low fuel pressure GLD model* has draw-thru carburetion capability which increases application potential. It allows operation with



■ *Individual, four valve, water cooled*

*cylinder heads* ensure optimum perfor-


mance and reliability. Cooler

cylinder head operation

results in longer valve

train component life

and lower mainte-



# Engine Works so Well.

nance cost.

■ Waukesha's *multi-fuel capability* means

you have various options for primary fuel

requirements – unlike typical dual fuel systems

where one fuel is used for primary require-

ments and the second fuel as back-up. The

VGF is adaptable to natural gas and propane

as well as digester gas and even landfill gas.

■ *Standard Custom Engine Control*®

(CEC) Ignition Module provides precise

timing and control for reduced emissions

and fuel costs. No wearing parts means

consistent ignition performance and lower

maintenance costs.

■ Because of the *tremendous torque* of VGF


engines, RPMs can be turned down to


reduce fuel consumption and still maintain

constant torque capability.

■ When required by local restrictions,

the VGF can be ordered in a *rich burn draw*






High temperature cooling capability increases heat recovery opportunities, making the VGF a better fit for chiller or cogeneration applications.

Virtually all wearing components of the VGF series are interchangeable across the VGF engine series. This includes major components – pistons, rings, sleeves, conrods, cylinder heads, bearings and valve train parts. So not only do you have proven component reliability, you have lower parts inventory requirement even if you're running different models of the VGF.




A fully counterweighted crankshaft helps prevent engine vibration for a smoother running package. It minimizes main and rod bearing loads and maximizes component life. VGF shafts are T-drilled for continuous lubrication of main bearings, keeping them cooler

# Engine Performance Refle




Emission | Performance vs. % Load

1500 & 1800  
@ 7.8% O<sub>2</sub> Exhaust  
130°F ICW, 185°F JW







and cleaner for longer life.

■ *Flanged connection points* make installation and alignment easy. Compact packaging simplifies set-up and adjustments for reduced costs.

■ *Maintenance is simplified* because the size of the engine and the thoughtful location

of service points and controls places everything conveniently within the technician's reach. The VGF engine series allows *complete in-place maintenance and in-frame overhaul*. All VGFs have camshaft and connrod/crankshaft inspection doors. Vee engines have a base-type oil pan with inspection doors.


All these features point to the fact that

the VGF is intelligently designed and quality built to provide you with a compact, high speed gas engine in the Waukesha tradition of rugged reliability. This is an engine that will work long and hard for you. And it will have overhaul intervals so far apart you'll forget the meaning of downtime.

*When it comes to life cycle numbers, the*


*Waukesha VGF adds up to be the right choice.*

# Waukesha Company Performance.



## Emission | Performance vs. % Load

1500 & 1800  
@ 8.2% O<sub>2</sub> Exhaust (T.A. LUFT)  
130° F ICW, 185° F JW






From design and development to manufacturing to total aftermarket support, the VGF family of engines symbolizes Waukesha's commitment to its customers. We build engines worthy of your installation

and your investment. And we stand behind them with a worldwide distributor network.

**The Best in the Business.**

The VGF line is backed by the best warranty of any industrial engine manufacturer. On

# Why You Should Specify



## VGF PERFORMANCE

Configuration	Engine Model	Intercooler Water Temperature °F (°C)
V16	P48GL/GLD	130° (54°)
V12	L36GL/GLD	130° (54°)
Inline 8	H24GL/GLD	130° (54°)
	H24G	
Inline 6	F18GL/GLD	130° (54°)
	F18G	

## VGF STANDBY RATINGS

Configuration	Engine Model
V16	P48GL/GLD
V12	L36GL/GLD
Inline 8	H24GL/GLD
Inline 6	F18GL/GLD

## VGF STATS

All data are based on standard conditions of

29.54 inches Hg. (100 kPa) barometric pressure,

77°F (25°C) ambient and induction air temperature,

30% relative humidity at 0.3 inches Hg. (1 kPa)

water vapor pressure, 185° F (85° C) engine jacket

water outlet temperature. Rating fuel standard:

Commercial quality dry natural gas.

Configuration	Engine Model	Bore x Stroke in (mm)
V16	P48GL/GLD	5.98 x 6.5 (152 x 165)
V12	L36GL/GLD	5.98 x 6.5 (152 x 165)
Inline 8	H24GL/GLD	5.98 x 6.5 (152 x 165)
	H24G	5.98 x 6.5 (152 x 165)
Inline 6	F18GL/GLD	5.98 x 6.5 (152 x 165)
	F18G	5.98 x 6.5 (152 x 165)



new engines, all parts and labor are covered for one full year. Five years on major forgings and castings. New service parts are warranted for one year along with the labor costs to replace them.

*We built and backed this engine so you can be sure. The Waukesha VGF is the easy choice. The smart choice. The right choice.*

# the Waukesha VGF.


## Continuous Brake Horsepower (kWb) at Indicated RPM

1200 rpm		1500 rpm		1800 rpm	
710	(530)	885	(660)	1065	(800)
530	(400)	665	(500)	800	(600)
355	(265)	445	(330)	530	(400)
215	(160)	265	(200)	320	(240)
265	(200)	330	(250)	400	(300)
160	(120)	200	(150)	240	(180)

## Brake Horsepower (kW/b) at Indicated RPM

1500 rpm (50 Hz)		1800 rpm (60 Hz)	
1025	(765)	1230	(918)
770	(574)	920	(686)
510	(380)	615	(460)
385	(285)	460	(345)

Displacement cu in (liters)	Weight lbs (Kgs)	Height in (mm)	Length in (mm)	Width in (mm)
2924 (48)	14,900 (6,759)	75.5 (1918)	106.5 (2705)	62.0 (1574)
2193 (36)	11,525 (5,228)	75.5 (1918)	88.0 (2235)	62.0 (1574)
1462 (24)	7,200 (3,265)	68.0 (1727)	94.5 (2395)	50.0 (1264)
1462 (24)	7,200 (3,265)	68.0 (1727)	94.5 (2395)	50.0 (1264)
1096 (18)	5,500 (2,495)	68.0 (1727)	80.5 (2043)	50.0 (1264)
1096 (18)	5,500 (2,495)	68.0 (1727)	80.5 (2043)	50.0 (1264)







*University of Illinois  
in Chicago installed an  
L36GL standby set.*



*A landfill at Vlagheide in Schijndel,  
The Netherlands, has five H24GLDs  
efficiently generating electricity from low  
BTU landfill gas.*

**Strong Work Ethic.**

Waukesha has nearly a century of stationary gas engine experience in rugged applications all over the world. Simply put, Waukesha engines are built to work. The VGF

continues that heritage.

The VGF is the perfect blend of compact size, brute strength and the right technology. No wasted weight, space or hardware. The result is an engine of timely design



*Waukesha VGF F18G  
drives 90 kW induction  
generator in parallel with  
utility for Canonsburg,  
Pennsylvania, wastewater  
treatment plant.  
Recovered heat is used to  
maintain temperature in  
digesters.*

*The Proof is in*



*This F18GL engine  
compresses gas for  
Ocelot Energy, Inc.  
in south central  
Alberta, Canada.*



*Elkerliek Hospital in The Netherlands uses a P48GLD  
and an H24GLD for standby power and cogeneration.*




and enduring reliability. It is economical to own and operate. And it lends itself to extraordinary installation versatility.

The VGF is manufactured in the USA at Waukesha Engine Division in

Wisconsin and in Europe at Waukesha Engine Division, Appingedam, The Netherlands.

Nearly one thousand VGF engines have been installed since product introduction in 1987.



A 700 kW VGF P48GL cogen system generates electricity and warehouse heat for this grain drying operation in Dangannon, Ontario.

## the Performance.



CNG Transmission Corp. in Utica, NY, has a VGF H24GL driving a 375 kW generator for standby electrical power at a compressor station.



A VGF H24GL genset rated at 350 kW is used for peak shaving at Lethbridge


Regional Hospital in Alberta, Canada. Exhaust heat is converted to steam via a waste heat boiler.




This greenhouse in Antwerpen,

Holland, obtains

electricity and heat from an F18GLD cogeneration system.



Greensburg Sewer Authority, Greensburg, PA, uses a digester gas powered VGF F18G for aeration in wastewater treatment. Recovered engine heat maintains temperature in digesters.



The Stegeman Meat Factory in Deventer, The Netherlands, has an L36GLD cogen system supplying electricity as well as hot water for absorption cooling.





**Waukesha**

Waukesha Engine

Dresser, Inc.

1000 West St. Paul Avenue

Waukesha, WI 53188-4999

Fax: (262) 549-2795

(262) 547-3311

[waukeshaengine.dresser.com](http://waukeshaengine.dresser.com)

Waukesha Engine

Dresser Industrial Products, b.v.

Farmsumerweg 43, Postbus 330

9900 AH Appingedam, The Netherlands

Fax: (31) 596-628111

(31) 596-652222



101 Industrial Blvd.  
Mansfield, TX 76063-3811  
Phone (817) 840-5544  
Fax (817) 453-0219  
Toll Free 1-800-888-5557

**Equipment Proposed:**

Kohler 625 KW Standby Generator  
Model Number 600RZW  
Engine Waukesha VGF L36GLD Lean-Burn  
Natural Gas Fueled  
Isochronous Governor  
Heavy duty dry type air filters  
Lube oil filters and drain connections to skid  
Unit mounted radiator with shell and fan guard  
24-volt starter and alternator  
Battery with cables and mounting tray  
Battery charger 10 amp with charge rate meter  
Muffler critical type with flex connector  
Engine block heater thermostatically controlled  
Generator: 1800 RPM, PMG type excitation, 60 Hz, 3 phase, 480 volt, .25% constant voltage regulator, Class H insulation, direct flex disc drive, 10 or 12 lead reconnectable  
Decision-Maker 550 Digital Generator Controller  
Detailed Specs Included at end of this document  
All weather outdoor sound attenuated generator enclosure rated 85 dba @ 1 meter with interior lighting  
1000 amp 100% rated main line circuit breaker mounted in connection box with GFI  
Spring isolators  
Dry contacts  
Alternator heater  
Woodward speed controller  
Marathon DVR2000EC voltage regulator  
Natural gas regulator 8" W.C.-2.5psig  
Natural gas solenoid valve

**Project Management Services:**

Start-up, three up to 8-hour days including travel  
Training of owner's personnel at time of start up  
Operation of equipment at Wedlake Manufacturing in Tulsa, OK  
Factory load bank testing  
Submittal drawings:

- Dimensional drawings, Electrical drawings, Product specifications

Production testing  
Technical assistance  
Operation and maintenance manuals for engine, generator and controls  
One (1) year warranty

**Decision-Maker 550 Controller Details**

**Standards:**

- NFPA 99
- NFPA 110, Level 1
- UL-508 (pending)

**Hardware Features**

- Alarm horn
- Battery circuits are fuse protected
- Controller mounts in four orientations locally or remotely up to a distance of 12 m (40 ft. )
- Five LED status indicating lights
- Latch-type emergency stop switch
- Vacuum fluorescent display
- Terminals for remote annunciator
- Three-position (run, off/reset, auto) selector switch

**Shutdown Functions**

Engine functions:

**CLIFFORD POWER SYSTEMS, INC. IS COMMITTED TO BE THE PREFERRED LEADER IN THE POWER GENERATION INDUSTRY. WE WILL FULFILL THIS MISSION BY PROVIDING OUR CUSTOMERS WITH SERVICE ABOVE AND BEYOND THEIR EXPECTATIONS.**



- Air damper fault, if equipped
- High coolant temperature
- High oil temperature
- Low coolant level
- Low oil pressure
- Overcrank
- Overspeed
- General functions:
- Auxiliary—(up to 7 analog inputs each with a high and low programmable shutdown level). NOTE: Non-ECM models have 5 programmable shutdowns)
- Auxiliary—Digital (up to 21 programmable shutdowns)
- ECM communications loss (ECM models only)
- Emergency stop
- Internal fault
- Master switch in off/reset position
- Master switch error
- Master switch open
- NFPA 110 fault

#### Generator functions:

- Alternator protection against overload and short circuits
- Locked rotor (failed to crank)
- Over AC output voltage
- Overfrequency
- Under AC output voltage
- Underfrequency

### Warning Functions

#### Engine functions:

- Coolant temperature signal loss
- High battery voltage
- High coolant temperature
- Low battery voltage
- Low coolant temperature
- Low fuel (level or pressure)\*
- Low oil pressure
- Oil pressure signal loss
- Speed sensor fault
- Starting aid fault
- Weak battery

#### General functions:

- Auxiliary—(up to 7 analog inputs each with a high and low programmable warning level). NOTE: Non-ECM models have 5 programmable warnings)
- Auxiliary—Digital (up to 21 programmable warnings)
- Battery charger fault\*
- Emergency power system (EPS) supplying load
- Engine cooldown delay
- Engine start delay
- Load shed kW overload
- Load shed underfrequency
- Master switch not in auto
- NFPA-110 fault
- System ready

#### Generator functions:

- AC sensing loss
- Generator running
- Ground fault\*
- Overcurrent
- Underfrequency
- Requires optional input sensors.

### User-Defined Common Faults

The user customizes outputs through a menu of shutdowns and warnings.

User defines up to 21 relay driver outputs (RDOs), (relays not included) from the following list of functions:

#### Engine functions:

- Air damper fault, if equipped
- Coolant temperature signal loss
- High battery voltage
- High coolant temperature shutdown
- High coolant temperature warning
- High oil temperature (ECM models only)
- Low battery voltage

**CLIFFORD POWER SYSTEMS, INC. IS COMMITTED TO BE THE PREFERRED LEADER IN THE POWER GENERATION INDUSTRY. WE WILL FULFILL THIS MISSION BY PROVIDING OUR CUSTOMERS WITH SERVICE ABOVE AND BEYOND THEIR EXPECTATIONS.**

PAGE 3 OF 3

- Low coolant level
- Low coolant temperature
- Low fuel (level or pressure)\*
- Low oil pressure shutdown
- Low oil pressure warning
- Oil pressure signal loss
- Overcrank
- Overspeed
- Speed sensor fault
- Starting aid
- System ready
- Weak battery

**General functions:**

- Battery charger fault\*
- ECM communications loss (ECM models only)
- EEPROM write failure
- Emergency stop
- Engine cooldown delay
- Engine start delay
- EPS supplying load
- Internal fault
- Load shed kW overload
- Load shed underfrequency
- Master switch error
- Master switch not in auto
- Master switch to off
- NFPA 110 common alarm fault

**Generator functions:**

- AC sensing loss
- Alternator protection against overload and short circuits
- Generator running
- Ground fault
- Locked rotor (failed to crank)
- Overcurrent
- Overfrequency
- Overvoltage
- Underfrequency
- Undervoltage

\* Requires optional input sensors.

**NFPA-110 Common Alarms**

Additional annunciated alarms including NFPA 110 alarms.

**Engine functions:**

- High battery voltage
- High coolant temperature shutdown
- High coolant temperature warning
- Low battery voltage
- Low coolant temperature warning
- Low fuel (level or pressure)\*
- Low oil pressure shutdown
- Low oil pressure warning
- Overcrank
- Overspeed

**General functions:**

- Battery charger fault\*
- Master switch not in auto
- NFPA 110 common alarm

\*Requires optional input sensors.

**Monitoring**

Standard Equipment and Features

Alarm horn

Indicators:

- Not in auto (yellow)
- Program mode (yellow)
- System ready (green)
- System shutdown (red)
- System warning (yellow)
- Switches and standard features:
- Keypad, 16-button multi-function soft-membrane environmentally sealed
- Lamp test

CLIFFORD POWER SYSTEMS, INC. IS COMMITTED TO BE THE PREFERRED LEADER IN THE POWER GENERATION INDUSTRY. WE WILL FULFILL THIS MISSION BY PROVIDING OUR CUSTOMERS WITH SERVICE ABOVE AND BEYOND THEIR EXPECTATIONS.

- Switch, auto/off-reset/run (engine start)
- Switch, emergency stop (normally closed contacts)
- Vacuum fluorescent display with two lines of 20 characters

### Displays

Some engine displays are dependent upon enhanced electronic engine control availability.

Engine monitoring (metric or English units):

- Ambient temperature (ECM models only)
- Battery voltage
- Coolant—pressure, temperature, and level (ECM models only)
- Engine start countdown
- Fuel—pressure, temperature, fuel rate, amount of fuel used during last run (ECM models only)
- Oil—pressure, temperature, level, and crankcase pressure
- RPM

Generator monitoring:

- Current (L1, L2, L3), \_ 0.25% accuracy
- Frequency, \_ 0.5% accuracy
- Kilowatts, total per phase (L1, L2, L3), \_ 0.5% accuracy
- KVA, total per phase (L1, L2, L3), \_ 0.5% accuracy
- KVAR, total absorbing/generating per phase (L1, L2, L3), \_ 0.5% accuracy
- Percent alternator duty level (actual load kW/standby kW rating)
- Power factor per phase, leading/absorbing
- Voltage (line-to-line, line-to-neutral for all phases), \_ 0.25% accuracy

Operational records:

- Event history (stores up to 100 system events)
- Last start date
- Number of starts
- Number of starts since last maintenance
- Operating days since last maintenance
- Operating mode—standby or prime power
- Run time (total, loaded and unloaded hours, and total kW hours)
- Run time since maintenance (total, loaded, and unloaded hours and total kW hours)
- System shutdowns
- System warnings
- Time, date, and day of week

Time delays:

- Crank cycles for on/pause
- Crank cycles for overcrank shutdown
- Engine cooldown
- Engine start
- Load shed
- Voltage, over- and under-
- Starting aid

System parameters:

- Current, rated
- ECM serial number (ECM models only)
- Engine model number
- Engine serial number
- Frequency
- Generator set model number
- Generator set serial number
- Generator set spec number
- kW Rating
- Phase, single and three
- Unit number
- Voltage
- Voltage configuration, wye or delta

### Inputs

Customer and remote inputs:

- Analog inputs 0-5 VDC (up to 7 user-defined analog inputs with multiple shutdown and warning levels). NOTE: Non-ECM models have 4 programmable shutdowns)
- Digital contact (up to 21 user-defined digital inputs with shutdown or warning levels).
- Ground fault detector\*
- Remote emergency stop
- Remote reset
- Remote 2-wire start

Digital inputs:

- Air damper fault, if equipped
- Battery charger fault\*
- Emergency stop

CLIFFORD POWER SYSTEMS, INC. IS COMMITTED TO BE THE PREFERRED LEADER IN THE POWER GENERATION INDUSTRY. WE WILL FULFILL THIS MISSION BY PROVIDING OUR CUSTOMERS WITH SERVICE ABOVE AND BEYOND THEIR EXPECTATIONS.

PAGE 005A

# KOHLER POWER SYSTEMS

## Model: 600RZW

190-600 V

Gas



### Ratings Range


	Lean-Burn GLD Engine		Rich-Burn GSID Engine	
	60 Hz	50 Hz	60 Hz	50 Hz
<b>Standby: kW</b>	620-625	524-528	600	500-504
<b>kVA</b>	775-781	655-660	750	625-630
<b>Prime: kW</b>	510-600	428-504	510-540	428-456
<b>kVA</b>	638-750	535-630	638-675	535-570

### Generator Set Ratings

Alternator Voltage	Ph	Hz	Lean-Burn GLD Engine			Rich-Burn GSID Engine			
			130°C Rise Standby	105°C Rise Prime	80°C Rise Prime	130°C Rise Standby	105°C Rise Prime	80°C Rise Prime	
			kW/kVA	kW/kVA	kW/kVA	kW/kVA	kW/kVA	kW/kVA	
5M4032	120/208	3	60	620/775	590/738	570/713	600/750	535/669	535/669
	127/220	3	60	620/775	590/738	590/738	600/750	535/669	535/669
	139/240	3	60	625/781	595/744	570/713	600/750	540/675	540/675
	240/416	3	60	620/775	590/738	570/713	600/750	535/669	535/669
	277/480	3	60	625/781	595/744	570/713	600/750	540/675	540/675
	110/190	3	50	524/655	500/625	488/610	500/625	456/570	456/570
	115/200	3	50	524/655	500/625	472/590	500/625	456/570	456/570
	120/208	3	50	524/655	500/625	440/550	500/625	456/570	440/550
	220/380	3	50	524/655	500/625	488/610	500/625	456/570	456/570
	230/400	3	50	524/655	500/625	472/590	500/625	456/570	456/570
240/416	3	50	524/655	500/625	440/550	500/625	456/570	440/550	
5M4034	120/208	3	60	625/781	595/744	590/738	600/750	540/675	540/675
	127/220	3	60	625/781	595/744	595/744	600/750	540/675	540/675
	139/240	3	60	625/781	595/744	585/731	600/750	540/675	540/675
	240/416	3	60	625/781	595/744	590/738	600/750	540/675	540/675
	277/480	3	60	625/781	595/744	585/731	600/750	540/675	540/675
	110/190	3	50	528/660	504/630	500/625	504/630	456/570	456/570
	115/200	3	50	528/660	504/630	472/590	504/630	456/570	456/570
	120/208	3	50	528/660	504/630	428/535	504/630	456/570	428/535
	220/380	3	50	528/660	504/630	500/625	504/630	456/570	456/570
	230/400	3	50	528/660	504/630	422/590	504/630	456/570	456/570
240/416	3	50	528/660	504/630	428/535	504/630	456/570	428/535	
5M4036	120/208	3	60	625/781	595/744	600/750	600/750	540/675	540/675
	127/220	3	60	625/781	595/744	570/713	600/750	540/675	535/669
	139/240	3	60	625/781	595/744	595/744	600/750	540/675	540/675
	220/380	3	60	625/781	595/744	595/744	600/750	540/675	540/675
	240/416	3	60	625/781	595/744	600/750	600/750	540/675	540/675
	277/480	3	60	625/781	595/744	595/744	600/750	540/675	540/675
	110/190	3	50	528/660	504/630	504/630	504/630	456/570	456/570
	115/200	3	50	528/660	504/630	504/630	504/630	456/570	456/570
	120/208	3	50	528/660	504/630	480/600	504/630	456/570	456/570
	220/380	3	50	528/660	504/630	504/630	504/630	456/570	456/570
230/400	3	50	528/660	504/630	504/630	504/630	456/570	456/570	
240/416	3	50	528/660	504/630	480/600	504/630	456/570	456/570	
5M4164	220/380	3	60	625/781	595/744	570/713	600/750	540/675	570/698
5M4166	220/380	3	60	625/781	595/744	595/744	600/750	540/675	540/675
5M4274	347/600	3	60	625/781	595/744	530/683	600/750	535/669	530/663
5M4276	347/600	3	60	625/781	595/744	565/706	600/750	540/675	540/675

### Standard Features

- Kohler Co. provides one-source responsibility for the generating system and accessories.
  - The generator set and its components are prototype-tested, factory-built, and production-tested.
  - The generator set complies with ISO 8528-5, Class G4 requirements for transient performance.\*
  - A one-year limited warranty covers all systems and components. Two-, five-, and ten-year extended warranties are also available.
  - Alternator features:
    - The brushless, rotating-field alternator has broadrange reconnectability.
    - The pilot-excited, permanent-magnet (PM) alternator provides superior short-circuit capability.
  - Other features:
    - The low coolant level shutdown prevents overheating (standard on radiator models only).
    - The generator set is direct-mounted to the skid.
    - An electronic, isochronous governor delivers precise frequency regulation.
    - Electronic engine controls manage the engine.
    - Lean-burn natural gas technology provides maximum power and fuel efficiency.
    - Rich-burn natural gas technology reduces harmful exhaust emissions when used with a catalytic converter.
- \* This generator set does not meet NFPA 110 requirements for the one-step load acceptance and the 10-second start sequence.



**RATINGS:** All three-phase units are rated at 0.8 power factor. Standby Ratings: Standby ratings apply to installations served by a reliable utility source. The standby rating is applicable to varying loads for the duration of a power outage. There is no overload capability for this rating. Ratings are in accordance with ISO-3046/1, BS 5614, AS 2789, and DIN 6271. Prime Power Ratings: Prime power ratings apply to installations where utility power is unavailable or unreliable. At varying load, the number of generator set operating hours is unlimited. Rich Burn: A 10% overload capacity is available for one hour in twelve. Lean Burn: A 5% overload capacity is available for one hour in twelve. Ratings are in accordance with ISO-3046/1, overload power in accordance with ISO-3046/1, BS 5614, AS 2789, and DIN 6271. For limited running time and base load ratings, consult the factory. Obtain this technical information bulletin (TIB-101) on ratings guidelines for the complete ratings definitions. The generator set manufacturer reserves the right to change the design or specifications without notice and without any obligation or liability whatsoever. GENERAL GUIDELINES FOR DERATING: Altitude: Deduct 1% for each 150 m (492 ft.) elevation above 500 m (1640 ft.). Temperature: Deduct 2% for each 10°C (18°F) temperature above 35°C (100°F).

G4-91 (600RZW) 1/05e

## Alternator Specifications

Specifications	Alternator
Type	4-Pole, Rotating-Field
Exciter type	Brushless, Permanent-Magnet, Pilot Exciter
Voltage regulator	Solid State, Volts/Hz
Insulation:	NEMA MG1
Material	Class H, Synthetic, Nonhygroscopic
Temperature rise	130°C, 150°C, Standby
Bearing: quantity, type	1, Sealed
Coupling	Flexible Disc
Amortisseur windings	Full
Rotor balancing	125% (60 Hz), 150% (50 Hz)
Voltage regulation, no-load to full-load (with <0.5% drift due to temp. variation)	3-phase, ±0.25%
Unbalanced load capability	100% of Rated Standby Current
Peak motor starting kVA:	(35% dip for voltages below)
480 V/380 V	5M4032 (10 lead) .... 2200 (60Hz), 1375 (50Hz)
480 V/380 V	5M4034 (10 lead) .... 2600 (60Hz), 1750 (50Hz)
480 V/380 V	5M4036 (10 lead) .... 3150 (60Hz), 2100 (50Hz)
380 V	5M4164 (4 lead) ..... 2250 (60Hz)
380 V	5M4166 (4 lead) ..... 2750 (60Hz)
600 V	5M4274 (4 lead) ..... 1545 (60Hz)
600 V	5M4276 (4 lead) ..... 2800 (60Hz)

- NEMA MG1, IEEE, and ANSI standards compliance for temperature rise and motor starting.
- Sustained short-circuit current of up to 300% of the rated current for up to 10 seconds.
- Sustained short-circuit current enabling downstream circuit breakers to trip without collapsing the alternator field.
- Self-ventilated and dripproof construction.
- Superior voltage waveform from two-thirds pitch windings and skewed stator.
- Digital solid-state, volts-per-hertz voltage regulator with ±0.25% no-load to full-load regulation.
- Brushless alternator with brushless pilot exciter for excellent load response.

## Application Data

### Engine

Engine Specifications	60 Hz	50 Hz
Manufacturer	Waukesha Engine	
Engine model		
Lean-Burn GLD Engine	VGF L36GLD, 4-Cycle	
Rich-Burn GSID Engine	VGF L36GSID, 4-Cycle	
Engine type	Turbocharged, Intercooled	
Cylinder arrangement	12 V	
Displacement, L (cu. in.)	36 (2186)	
Bore and stroke, mm (in.)	152 x 165 (5.99 x 6.5)	
Compression ratio		
Lean-Burn GLD Engine	11:1	
Rich-Burn GSID Engine	8.7:1	
Piston speed, m/min. (ft./min.)	594 (1950)	495 (1625)
Main bearings: quantity, type	7, Half-Shell	
Rated rpm	1800	1500
Max. power at rated rpm, kWm (BHP)		
Lean-Burn GLD Engine	690 (925)	574 (770)
Rich-Burn GSID Engine	656 (880)	548 (735)
Cylinder head material	Cast Iron	
Piston: type, material	Aluminum Alloy	
Crankshaft material	Forged Steel	
Valve material, intake/exhaust:	Hard-Faced Steel	
Governor: type, make/model	Electronic	
Frequency regulation, no-load to full-load	Isochronous	
Frequency regulation, steady state	±0.50%	
Frequency	Field-Convertible	
Air cleaner type, all models	Dry	

### Fuel

Fuel System	60 Hz	50 Hz
Fuel type	Natural Gas	
Fuel supply line inlet, mm (in.)	50.8 (2)	
	ANSI 125 (b, Flange)	
Natural gas fuel supply pressure, measured at the generator set fuel inlet after any fuel system equipment accessories, kPa (oz./in. <sup>2</sup> )	2-34 (4.8-80)	
Particulate filter requirement, mm (in.)	0.005 (0.0002)	

### Exhaust

Exhaust System	60 Hz	50 Hz
Exhaust flow at rated kW, m <sup>3</sup> /min. (cfm)		
Lean-Burn GLD Engine	135 (4765)	108 (3816)
Rich-Burn GSID Engine	106 (3755)	84 (2962)
Exhaust temperature at rated kW, dry exhaust, °C (°F)		
Lean-Burn GLD Engine	450 (843)	427 (800)
Rich-Burn GSID Engine	600 (1114)	579 (1074)
Maximum allowable back pressure, kPa (in. Hg)	3.73 (1.1)	
Engine exhaust outlet size, mm (in.)	See ADV Drawing	

### Engine Electrical

Engine Electrical System	60 Hz	50 Hz
Ignition system	Electronic	
Battery charging, min.	Requires Float/Equalizer Battery Charger, 24 V, 10 A	
Starter motor rated voltage (DC)	24	
Battery, recommended cold cranking amps (CCA):		
Qty., CCA rating	2, 1150	
Battery voltage (DC)	12	

### Lubrication

Lubricating System	60 Hz	50 Hz
Type	Full Pressure	
Oil pan capacity, L (qt.)	—	
Oil pan capacity with filter, L (gal.)	163 (43)	
Oil filter: quantity, type	2, Cartridge	
Oil cooler	Water-Cooled	
Oil requirements:	SAE40 Allowable Sulfated Ash Content by Weight	
	0.5-1.0% (GLD)	
	0.35-0.5% (GSID)	

G4-91 (800R2W) 1/05e



## Application Data

### Cooling

Radiator System	60 Hz	50 Hz
Ambient temperature, °C (°F)	38 (100)	
Engine jacket water capacity, L (gal.)	166 (44)	
Engine auxiliary water capacity, L (gal.)	57 (15)	
Radiator jacket water capacity, including engine, L (gal.)	357 (94)	
Radiator auxiliary water capacity, including engine, L (gal.)	224 (59)	
Minimum engine jacket water flow, Lpm (gpm)		
Lean-Burn GLD Engine	825 (218)	697 (184)
Rich-Burn GSID Engine	997 (263)	841 (222)
Minimum engine auxiliary water flow, Lpm (gpm)	235 (62)	197 (52)
Heat rejected to cooling water at standby rated kW, wet exhaust, kW (Btu/min.)		
Lean-Burn GLD Engine	648 (26920)	401 (22780)
Rich-Burn GSID Engine	574 (32670)	476 (27080)
Heat rejected to auxiliary cooling water at standby rated kW, wet exhaust, kW (Btu/min.)		
Lean-Burn GLD Engine	182 (10370)	128 (7300)
Rich-Burn GSID Engine	131 (7470)	102 (5800)
Water pump type	Centrifugal	
Fan diameter, including blades, mm (in.)	1829 (72)	
Fan, kWm (HP)	31 (42)	19 (25)
Max. restriction of cooling air, intake and discharge side of radiator, kPa (in. H <sub>2</sub> O)	0.125 (0.5)	

### Operation Requirements


Air Requirements	60 Hz	50 Hz
Radiator-cooled cooling air, m <sup>3</sup> /min. (scfm)*	1890 (66700)	1410 (49800)
Combustion air, m <sup>3</sup> /min. (scfm)		
Lean-Burn GLD Engine	52 (1820)	42 (1485)
Rich-Burn GSID Engine	33 (1180)	27 (965)
Heat rejected to ambient air, kW (Btu/min.):		
Lean-Burn GLD Engine	34 (1933)	31 (1783)
Rich-Burn GSID Engine	42 (2383)	39 (2233)
Alternator	42 (2383)	35 (1960)

\* Air density = 1.20 kg/m<sup>3</sup> (0.075 lbm/ft<sup>3</sup>)

Fuel Consumption†	60 Hz	50 Hz
Natural Gas, m <sup>3</sup> /hr. (cfh) at % load	Lean-Burn Standby Rating	
100%	202 (7153)	164 (5794)
75%	159 (5603)	128 (4533)
50%	116 (4054)	93 (3271)
25%	71 (2504)	57 (2010)
Natural Gas, m <sup>3</sup> /hr. (cfh) at % load	Lean-Burn Prime Rating	
100%	194 (6851)	157 (5548)
75%	152 (5377)	123 (4348)
50%	111 (3903)	89 (3148)
25%	69 (2429)	55 (1948)
Natural Gas, m <sup>3</sup> /hr. (cfh) at % load	Rich-Burn Standby Rating	
100%	201 (7105)	165 (5819)
75%	159 (5602)	129 (4568)
50%	116 (4068)	94 (3319)
25%	73 (2594)	59 (2070)
Natural Gas, m <sup>3</sup> /hr. (cfh) at % load	Rich-Burn Prime Rating	
100%	186 (6559)	152 (5364)
75%	147 (5192)	120 (4228)
50%	108 (3825)	88 (3092)
25%	70 (2468)	55 (1956)

† Fuel energy content = 35.38 MJ/m<sup>3</sup> (900 Btu/scft) saturated lower heating value.

### Controller



#### Decision-Maker™ 550 Controller

Audiovisual annunciation.

Programmable microprocessor logic and digital display features.

Alternator safeguard circuit protection.

24-volt engine electrical system capability.

Remote start, remote annunciation, and remote communication options.

Refer to G6-48 for additional controller features and accessories.

KOHLER CO., Kohler, Wisconsin 53044 USA  
 Phone 920-565-3381, Fax 920-458-1648  
 For the nearest sales and service outlet in the  
 US and Canada, phone 1-800-544-2444  
 KohlerPowerSystems.com

Kohler Power Systems  
 Asia Pacific Headquarters  
 7 Jurong Pler Road  
 Singapore 619159  
 Phone (65) 6264-6422, Fax (65) 6264-6455

## Standard Features and Accessories

### Standard Features

- Air Cleaner, Heavy Duty
- Air Cleaner Restriction Indicator
- Alternator Protection
- Oil Drain Extension
- Operation and Installation Literature
- Radiator Duct Flange

### Accessories

- Enclosed Unit
  - Sound Enclosure (with enclosed critical silencer)
  - Weather Enclosure (with enclosed critical silencer)
- Open Unit
  - Exhaust Silencer, Critical, Lean-Burn GLD Engine: 60 Hz kit: PA-354896; 50 Hz kit: PA-354894
  - Exhaust Silencer, Critical, Rich-Burn GSID Engine: Kit: PA-354894
  - Exhaust Silencer, Residential, Kit: PA-354892
  - Flexible Exhaust Connector, Stainless Steel
- Cooling System
  - Block Heater
  - Remote Radiator Cooling
- Fuel System
  - Air/Fuel Ratio Controller
  - Gas Regulator
  - Natural Gas Filter
  - Gas Solenoid Valve
- Electrical System
  - Battery
  - Battery Charger, Equalize/Float Type
  - Battery Heater
  - Battery Rack and Cables
- Engine and Alternator
  - Bus Bar Kits
  - CSA Certification
  - Alternator Strip Heater
  - Line Circuit Breaker (NEMA1 enclosure) *100% noted*
  - Line Circuit Breaker with Shunt Trip (NEMA1 enclosure)
  - Optional Alternators
  - Pre-Lube Pumps
  - Pre-Lube Pumps with Heaters
  - Rated Power Factor Testing
  - Remote Voltage Adjust Control
  - Spring Isolators

### Maintenance and Literature

- General Maintenance Literature Kit
- Maintenance Kit (includes air, oil, and fuel filters)
- Overhaul Literature Kit
- Production Literature Kit

### Controller


- Common Failure Relay Kit
- Communications Products and PC Software
- Customer Connection Kit
- Dry Contact Kit (isolated alarm)
- Remote Annunciator Panel
- Remote Audiovisual Alarm Panel
- Remote Emergency Stop Kit
- Remote Mounting Cable
- Run Relay Kit

### Miscellaneous Accessories

- Woodward Controller*
- Marathon AVR 2000 EC*
- 
- 
- 
- 
- 
- 

### Dimensions and Weights

Overall Size, L x W x H, mm (in.): 4924 x 2416 x 3111  
 (193.8 x 95.1 x 122.5)  
 Weight (radiator model), wet, kg (lb.): 10750 (23700)



NOTE: This drawing is provided for reference only and should not be used for planning installation. Contact your local distributor for more detailed information.

**DISTRIBUTED BY:**

© 2002, 2003, 2004, 2005 by Kohler Co. All rights reserved.

G4-01 (800RZW) 1/05e

**Attachment 7**  
**Blackstart Generator Engine Log**

## Black Start Internal Combustion Engine Monthly Operating Log

Site: McGrathBeach Peaker  
 Facility ID: 7891  
 BHP: 924 HP  
 Device ID:

Model: Waukesha, Model VG36 GL/GLD  
 Fuel Type Natural Gas

Permit Conditions: Operator shall limit the operating time to no more than 200 hours in any one year.

Operator shall install and maintain non-resettable totalizing time meter to indicate elapsed operating time of engine.  
 The engine shall only be operated during utility failure periods (except for maintenance).

Emissions factor 1.25 grms NOx/BHP-hr

Date	Timer Reading (Start)	Timer Reading (End of run)	Total Hours Operated	Reason for Operation	Emergency Operation Hours	Maintenance and Testing Hours	Rolling Hours	Operator Initial
8/30/2019	85.5	86.0	0.5	Test run engine		0.5	86.0	VM
10/10/2019	86.0	87.2	1.2	Test run engine		1.2	87.2	VM
10/14/2019	87.2	87.9	0.7	Blackstart Islanding		0.7	87.9	VM

Total Emergency Use Hours (hours/year)	Total Maintenance and Testing Hours (hours/year)	Total Hours (hours/year)	NOx Emissions (tons)
0.0	2.4	2.4	0.0031

## **Attachment 8**

# **Pressure-vacuum relief valve calibration**



# Basin Valve Company

# Breather Valve Service Report

Customer : Southern California Edison

PO No :

Site : Peaker Generating Stations

Rev : 6

Sales Order : 193912

Date Required : 5/8/2019

Location :

Repair Nameplate Data		By : CB	Original Nameplate Data		By : CB
SAP Number :	Pretest Date : 5/3/2019		Set Pressure : 0	Capacity : 0	
Tag Number : .PSV-200-E	Job Number : D14		Set Vacuum : 3.5 IN WC	Capacity : 156.5	
Manufacturer : Groth	Size : 2		Last Repair Nameplate Data By : CB		
Model No : 1300A-02-355-T0Z	Set Pressure : 0		Set Pressure : 0	Capacity : 0	
Serial No : 121258-10-3	Capacity : 0		Set Vacuum : 3.5	Capacity :	Unique ID : D14
Shop No :	Set Vacuum : 3.5		Repair Company : Basin Valve Company		
Interval : 0	Capacity : 156.5		Last Repair Date : 3/4/2015		
Units :	Press Units : In WC		Field Location : MC GRATH		
Inlet : 2 / 150 / RF	Outlet : / /				

Work Order :	Pre-Test Information		By : HA
Pop PSIG : 0	New Valve :	No Pop : 2	Fouled : Leaked At : 0.5
Cleanliness Condition : Normal condition		Conditions After Dismantling	By : MR
		Mechanical Condition : Slight pitting scratched	

Parts	Pretest Conditions	Work Performed	Note			
Body	Good					
Vacuum Seat	Good	Lapped				
Pressure Seat						
Vacuum Pallet	Good					
Pressure Pallet						
Pressure Pallet Stem						
Pallet Guide	Good					
Diaphragm Pressure						
Diaphragm Vacuum		Replaced				
Backup Disc Pressure						
Backup Disc Vacuum						
Spacer Pressure						
Spacer Vacuum						
Flange	Good		Qty	PO Number	Part Number	Description
Gaskets		Replaced	1			SGK
Loading Weights	Good					
Retaining Plat						
Vacuum Cover	Good					
Pressure Cover	Good					
Spring						
Spare 1						

Special Instructions :

O2 Cleaning Required     Replace Next Shut Down

- Repair as Required
- Final Test Only
- Repair Return to SP
- PreTest Return to SP
- Change Set Pressure
- Replace Soft Goods
- Pull from SP
- Build From Spare Pool / Tag No
- Seals Intact
- Seals Broken
- Seals Missing

Valve Repair Note :

Assembled By : NJ	Mach/Lapp By : NJ	Final Test Information	Cleaned By : DR	Inspected By : CB
Test Specifications :	Test Medium : Air	Test Type : Seat	Code Stamp Applied :	
	Set Pressure : 0	Set Vacuum : 3.5		
Gauges Used :	Primary : WC Stand	Secondary : WC Stand	Hold Time :	
Misc Items :	ID Tag : <input checked="" type="checkbox"/>	Paint : <input checked="" type="checkbox"/>	Seals : <input checked="" type="checkbox"/>	Flange Protector : <input type="checkbox"/>
Final Test By : Noe Jimenez	Sig : _____	Final Test Date : 5/6/2019	Company : Basin Valve Company	
QC Witnessed By : Jorge Martinez	Sig : _____	QC Date : 5/6/2019	Company :	
VR Stamp Number/s : 20	Install Verified By :	Date :		

**Basin Valve Company**  
**Customer : Southern California Edison**

**Safety Valve Pre-Test Graph**


193912

Repair Nameplate Data		By :
Revision : 6	Test Date : 5/4/2019	
Tag Number : PSV-201-B-E	Job Number : D18	
Manufacturer : CROSBY	Orifice : K	
Model No : JLT-JOS-E-15-OR-J	Set Pressure : 50	
Serial No : HS06/55272	Cold Set : 50	
Shop No : 82353544E	Back Press : 0	
Interval : 0	Capacity : 383	
Units : GPM	Temp Corr : 0	
Intet : 3 / 150 / RF	Outlet : 4 / 150 / RF	

Original Nameplate Data			By : JEO
Set Pressure : 50	Cold Set : 50	Back Press :	
Capacity : 383	Units : GPM	Code Stamp : UV	
Last Repair Nameplate Data			By :
Set Pressure : 50	Cold Set : 50	Back Press :	
Capacity : 383	Units : GPM	Unique ID : 188076	
Repair Company : Basin Valve Company			
Last Repair Date : 3/30/2018		VR : <input checked="" type="checkbox"/>	

Repair Note : Set Pressure Definition : First Steady Stream

Pre Test 50.61 PSIG



# Basin Valve Company

# Safety Valve Service Report

Customer : Southern California Edison

PO No :

Site : Peaker Generating Stations

Rev : 6

Sales Order : 193912

Date Required : 5/8/2019

Location :

Repair Nameplate Data		By : JEO
SAP Number :	Pretest Date :	
Tag Number : PSV-201-B-E	Job Number : D18	
Manufacturer : CROSBY	Orifice : K	
Model No : JLT-JOS-E-15-OR-J	Set Press : 50	
Serial No : HS06/55272	Cold Set : 50	
Shop No : 82353544E	Back Press : 0	
Interval : 0	Capacity : 383	
Units : GPM	Temp Corr : 0	
Inlet : 3 / 150 / RF	Outlet : 4 / 150 / RF	

Original Nameplate Data			By : JEO
Set Pressure : 50	Cold Set : 50	Back Press :	
Capacity : 383	% Over Pressure : 10	Units : GPM	
Temp Corr :		Code Stamp : UV	
Model Number : JLT-JOS-E-15-OR-J		Code Case :	
Serial Number : HS06/55272			

Last Repair Nameplate Data			By :
Set Pressure : 50	Cold Set : 50	Back Pressure :	
Capacity : 383	Units : GPM	Unique ID : 188076	
Repair Company : Basin Valve Company			
Last Repair Date : 3/30/2018		VR : <input checked="" type="checkbox"/>	
Field Location :			

Work Order :	Pre-Test Information	By : N/A
Pop PSIG : 50.61	New Valve : <input type="checkbox"/>	No Pop : <input type="checkbox"/>
	Fouled : <input type="checkbox"/>	Leaked At : <input type="checkbox"/>
Probable Cause of Failure : Valve performed properly		

Cleanliness Condition : All Parts Clean	Conditions After Dismantling	By : N/A
	Mechanical Condition : Passed pretest-No internal inspection made	

Parts	Pretest Conditions	Work Performed	Note	Part No
Bonnet Assembly				
Spring				
Upper Spring Washer				
Lower Spring Washer				
Compression Screw				
Compression Jam Nut				
Body				
Inlet Flange				
Outlet flange				
Guide				
Disc				
Disc Holder				
Nozzle				
Spindle				
Overlap Adjustment				
Retaining Ring				
Floating Washer				
Spindle Nut				
Lock Nut				
Cap				
Top lever & Pin				
Lower Lever & Pin				
Upper Adj Ring & Pin				
Lower Adj Ring & Pin				
Bellows				
Gaskets				

Critical Dimensions				Ring Adjustment / Spring Info			
Disc :	Min / Max :	After Repair :	Material Left :	Upper Ring :	As Found :	After Repair :	
Disc Holder :	Min / Max :	After Repair :	Material Left :	Lower Ring :	As Found :	After Repair :	
Guide :	Min / Max :	After Repair :	Material Left :	Compression Screw :	As Found :	After Repair :	
Nozzle :	Min / Max :	4.654	After Repair :	Spindle / Stem :	As Found :	After Repair :	
Special Instructions :				Spring Number : X36139		Spring Range : 39-50	

Back Pressure Tested at PSIG   O2 Cleaning Required  Repair as Required  Replace Soft Goods

Seat Leakage Tested at  % of Set Pressure  Final Test Only  Pull from SP

Replace Next Shut Down  Repair Return to SP  Build From SP / Tag No

Valve Repair Note :  PreTest Return to SP  Change Set Pressure  Seals Intact  Seals Broken  Seals Missing

Add Face Seal Conn  Cap / Lever  Open  Packed  Screwed

Assembled By : N/A Mach/Lapp By : N/A Final Test Information Cleaned By : N/A Inspected By : N/A

Test Specifications :	Test Medium : Liquid	Test Type : Seat	Set Pressure Definition : First Steady Stream	Code Stamp Applied : None
Set Pressure : 50	Average Test : 50.61	Test 1 : 50.61	Test 2 : 50.61	Test 3 : 50.61
Gauges Used :	Primary : CPU	Secondary : D-2	Hold Time :	
Misc Items :	ID Tag : <input checked="" type="checkbox"/>	Paint :	Seals : <input checked="" type="checkbox"/>	Flange Protector : <input checked="" type="checkbox"/>
Final Test By : Erick Delgadillo	Sig : _____	Final Test Date : 5/4/2019	Company : Basin Valve Company	
QC Witnessed By : Jorge Martinez	Sig : _____	QC Date : 5/4/2019	Company :	
VR Stamp Number/s : 20	Install Verified By :	Date :		

**Attachment 9**  
**Coating and Solvent usage log**

**COATING, ADHESIVE, and SOLVENT USAGE CHART**

COMPANY NAME: So Cal Edison McGrath Peaker  
 ADDRESS: 251 N Harbor Blvd Oxnard CA 93035  
 TELEPHONE NUMBER: (805)673-7228  
 PERIOD: FROM January THROUGH December  
 Maintain daily logs and submit copies monthly to C.J. Akunyili (chijoke.akunyili@scce.com). Call 909-478-1771 for assistance.

PERMIT NUMBER: 7891  
 PREPARED BY (Print Name): Chijoke Akunyili  
 SIGNATURE: Environmental Science Advisor  
 TITLE:

16 Fluid Oz = 1 Pint 4 Quarts = 1 Gallon 1b = 454  
 2 Pints = 1 Quart 1 Gallon = 3.785 Liters 1 Kilogram =

DATE	NAME, NUMBER, COLOR	COATING CATEGORY	MANUFACTURER	SIZE	QUANTITY USED	ROG CONTENT (lb/ROG)	ROG (lb)
<b>COATINGS</b>							
6/3/2019	Ametek AK-2 High Solid Epoxy	Industrial Maintenance/Rust Preventive Coating	PPG	GAL	0.25	0.7	0.175
6/5/2019	Tri-Polar 6060 Light Gray ALKYD	Metal Parts and Product	PPG	GAL	1	2.7	2.7
6/7/2019	K&L KOLOR-SIL ENAMEL SKY GRAY/KL16792/05	Metal Parts and Product	PPG	GAL	1	2.7	2.7
6/7/2019	K&L KOLOR-SIL ENAMEL SKY GRAY/KL16792/05	Metal Parts and Product	PPG	GAL	1	2.7	2.7
7/8/2019	Carbomastic 15, two components (A+B)	Industrial Maintenance/Rust Preventive Coating	Carboline	GAL	1	0.734	0.734
7/9/2019	Carbomastic 15, two components (A+B)	Industrial Maintenance/Rust Preventive Coating	Carboline	GAL	1	0.734	0.734
7/10/2019	Carbomastic 15, two components (A+B)	Industrial Maintenance/Rust Preventive Coating	Carboline	GAL	2	0.734	1.468
7/11/2019	Carbomastic 15, two components (A+B)	Industrial Maintenance/Rust Preventive Coating	Carboline	GAL	2	0.734	1.468
7/15/2019	Carbomastic 15, two components (A+B)	Industrial Maintenance/Rust Preventive Coating	Carboline	GAL	2	0.734	1.468
7/16/2019	Carbomastic 15, two components (A+B)	Industrial Maintenance/Rust Preventive Coating	Carboline	GAL	1	0.734	0.734
7/17/2019	Carbomastic 15, two components (A+B)	Industrial Maintenance/Rust Preventive Coating	Carboline	GAL	0.5	0.734	0.367
7/17/2019	Carbothane 134, two components (A+B)	Industrial Maintenance/Rust Preventive Coating	Carboline	GAL	0.5	1.565	0.7825
7/18/2019	Carbomastic 15, two components (A+B)	Industrial Maintenance/Rust Preventive Coating	Carboline	GAL	1	0.734	0.734
7/19/2019	Carbomastic 15, Aluminum (A+B)	Industrial Maintenance/Rust Preventive Coating	Carboline	GAL	1	0.734	0.734
7/22/2019	Carbomastic 15, Aluminum (A+B)	Industrial Maintenance/Rust Preventive Coating	Carboline	GAL	1	0.734	0.734
7/23/2019	Carbomastic 15, two components (A+B)	Industrial Maintenance/Rust Preventive Coating	Carboline	GAL	1	0.734	0.734

Note: Rule 74.12 Surface Coating of Metal Parts, and Usage is less than 200 lbs/month threshold.



7/24/2019	Carbomastic 15, two components (A+B)	Industrial Maintenance/Rust Preventive Coating	Carboline	GAL	1	0.734	0.734	0.734
7/25/2019	Carbomastic 15, two components (A+B)	Industrial Maintenance/Rust Preventive Coating	Carboline	GAL	1	0.734	0.734	0.734
7/25/2019	Carboline 134, two components (A+B)	Industrial Maintenance/Rust Preventive Coating	Carboline	GAL	1	1.565	1.565	1.565
7/29/2019	Carbocrylic 3359 (grey)	Industrial Maintenance/Rust Preventive Coating	Carboline	GAL	5	1.8	1.8	9
7/30/2019	Carbocrylic 3359 (grey)	Industrial Maintenance/Rust Preventive Coating	Carboline	GAL	5	1.8	1.8	9
7/30/2019	Carboline 134, two components (A+B)	Industrial Maintenance/Rust Preventive Coating	Carboline	GAL	0.5	1.565	1.565	0.7825
7/31/2019	Carbomastic 15, two components (A+B)	Industrial Maintenance/Rust Preventive Coating	Carboline	GAL	0.5	0.734	0.734	0.367
7/31/2019	Carbomastic 15, two components (A+B)	Industrial Maintenance/Rust Preventive Coating	Carboline	GAL	0.5	0.734	0.734	0.367
8/1/2019	Carbomastic 15, two components (A+B)	Industrial Maintenance/Rust Preventive Coating	Carboline	GAL	0.5	0.734	0.734	0.367
8/1/2019	Carbocrylic 3359 (grey)	Industrial Maintenance/Rust Preventive Coating	Carboline	GAL	10	1.8	1.8	18
8/5/2019	Carbomastic 15, two components (A+B)	Industrial Maintenance/Rust Preventive Coating	Carboline	GAL	0.5	0.734	0.734	0.367
8/6/2019	Carbocrylic 3359 (grey)	Industrial Maintenance/Rust Preventive Coating	Carboline	GAL	5	1.8	1.8	9
8/6/2019	Carboline 134, two components (A+B)	Industrial Maintenance/Rust Preventive Coating	Carboline	GAL	2.5	1.565	1.565	3.9125
8/7/2019	Carbomastic 15, two components (A+B)	Industrial Maintenance/Rust Preventive Coating	Carboline	GAL	0.5	0.734	0.734	0.367
8/8/2019	Carbocrylic 3359 (grey)	Industrial Maintenance/Rust Preventive Coating	Carboline	GAL	20	1.8	1.8	36
8/12/2019	Carbocrylic 3359 (grey)	Industrial Maintenance/Rust Preventive Coating	Carboline	GAL	15	1.8	1.8	27
8/13/2019	Carbomastic 15, two components (A+B)	Industrial Maintenance/Rust Preventive Coating	Carboline	GAL	0.5	0.734	0.734	0.367
<b>SOLVENT</b>								
01/01-12/31	Jet Engine Cleaner	Jet Engine Cleaner	Zok International	GAL	55	0.08	0.08	4.4
01/01-12/31	Simple Green Cleaner	Multipurpose surface cleaning	Zok International	GAL	3	0.042	0.042	0.126
06/03-06/07	Acetone	Thinning and Cleaning of coating application equipment	Ecolink, Inc.	32 oz	3	0.21	0.21	0.157248
01/01-12/31	S-34 NG Cleaner Nuclear Grade		Ecolink, Inc.	32 oz	3	0.21	0.21	0.157248
<b>AEROSOL SPRAY</b>								
01/01-12/31	CO Contact Cleaner Aerosol		CRC Industries	14 oz	5	7.49	7.49	4.08954
01/01-12/31	WD-40 Aerosol		WD-40 Company	14 oz	4	1.7	1.7	0.74256
01/01-12/31	Cold Galvanized Corrosion Inhibitor		LPS	14 oz	1	3.07	3.07	0.335244
01/01-12/31	D-Solvents, Graphite Dry Lubricant		LPS	14 oz	1	3.07	3.07	0.335244
01/01-12/31	Cold Galvanized Corrosion Inhibitor		LPS	14 oz	1	3.07	3.07	0.335244
01/01-12/31	3M Multipurpose Adhesive		3M	16 oz	1	3.07	3.07	0.363136
<b>Total VOC Emissions (pounds)</b>								<b>147.900718</b>

---

**Attachment 10**  
**2019 Opacity Survey**



**TEST REPORT FOR  
2019 PERMIT TO OPERATE COMPLIANCE TEST  
AT SOUTHERN CALIFORNIA EDISON'S  
MCGRATH PEAKER FACILITY**

Prepared For:

**Southern California Edison**  
251 N. Harbor Blvd.  
Oxnard, California

For Submittal To:

**Ventura County Air Pollution Control District**  
669 County Square Drive  
Ventura, California 93003

Prepared By:

**Montrose Air Quality Services, LLC**  
1631 E. St. Andrew Pl.  
Santa Ana, California 92705  
(714) 282-8240

Ali Aleshaiker

Test Date: **July 8, 2019**  
Production Date: **August 8, 2019**  
Report Number: **W002AS-580464-RT-93**



**CONFIDENTIALITY STATEMENT**

***Except as otherwise required by law or regulation, this information contained in this communication is intended exclusively for the individual or entity to which it is addressed. This communication may contain information that is proprietary, privileged or confidential or otherwise legally exempt from disclosure. If you are not the named addressee, you are not authorized to read, print, retain, copy, or disseminate this message or any part of it.***

**REVIEW AND CERTIFICATION**

All work, calculations, and other activities and tasks performed and presented in this document were carried out by me or under my direction and supervision. I hereby certify that, to the best of my knowledge, Montrose operated in conformance with the requirements of the Montrose Quality Management System and ASTM D7036-04 during this test project.

Signature: Ali Aleshaiker Date: 8/8/2019

Name: Ali Aleshaiker Title: Client Project Manager

I have reviewed, technically and editorially, details, calculations, results, conclusions, and other appropriate written materials contained herein. I hereby certify that, to the best of my knowledge, the presented material is authentic, accurate, and conforms to the requirements of the Montrose Quality Management System and ASTM D7036-04.

Signature: Matt McCune Date: 8/8/2019

Name: Matt McCune Title: Regional Vice President

**TABLE OF CONTENTS**

<u>SECTION</u>	<u>PAGE</u>
1.0 INTRODUCTION AND SUMMARY .....	6
2.0 UNIT AND CEMS DESCRIPTION .....	7
2.1 UNIT DESCRIPTION .....	7
2.2 TEST CONDITIONS .....	9
2.3 SAMPLE LOCATION .....	9
3.0 TEST DESCRIPTION .....	10
3.1 NO <sub>x</sub> , O <sub>2</sub> , AND CO BY CONTINUOUS ANALYZERS .....	11
3.2 AMMONIA BY BAAQMD METHOD ST-1B .....	11
3.3 REACTIVE ORGANIC COMPOUNDS (ROC'S) BY MODIFIED EPA METHOD 18 .....	11
3.4 STACK GAS VOLUMETRIC FLOW RATE .....	11
3.5 FUEL ANALYSIS .....	11
3.6 VISUAL EMISSIONS .....	11
4.0 TEST RESULTS AND OVERVIEW .....	13
4.1 TEST RESULTS .....	13
4.2 TEST OVERVIEW .....	15
APPENDIX A TEST DATA .....	16
A.1 NO <sub>x</sub> AND CO DATA .....	17
A.2 AMMONIA DATA .....	52
A.3 ROC DATA .....	58
A.4 FUEL ANALYSIS DATA .....	63
A.5 VISUAL EMISSIONS DATA .....	68
A.6 QUALITY ASSURANCE DATA .....	70
APPENDIX B UNIT OPERATIONS DATA .....	86
APPENDIX C GENERAL EMISSIONS CALCULATIONS .....	93
APPENDIX D QUALITY ASSURANCE .....	97
D.1 QUALITY ASSURANCE PROGRAM .....	98
D.2 CARB AND STAC CERTIFICATIONS .....	104
D.3 INDIVIDUAL QI CERTIFICATES .....	108
APPENDIX E APPLICABLE PERMIT SECTIONS .....	116



**TABLE OF CONTENTS (CONTINUED)**

<b><u>SECTION</u></b>	<b><u>PAGE</u></b>
<b>LIST OF TABLES</b>	
TABLE 1-1 PERMIT TO OPERATE COMPLIANCE TEST RESULTS SUMMARY .....	6
TABLE 2-1 SAMPLE POINT LOCATIONS .....	9
TABLE 3-1 EMISSION LIMITS .....	10
TABLE 3-2 COMPLIANCE TEST MATRIX .....	10
TABLE 4-1 PERMIT TO OPERATE COMPLIANCE TEST RESULTS .....	14
TABLE 4-2 PERMIT TO OPERATE COMPLIANCE TEST RESULTS .....	15
<b>LIST OF FIGURES</b>	
FIGURE 2-1 SCE PEAKER PHOTOGRAPH (EXAMPLE) .....	8

### 3.6 VISUAL EMISSIONS

Ali Aleshaiker of MAQS, a CARB certified visible emission evaluator (most recent re-certification performed 1/25/19), conducted the annual Rule 50 Opacity survey of the station's Gas Turbine LM6000 exhaust using EPA Method 9. During each observation, three 6-minute visual opacity measurements were obtained. The results show that no emissions were visible from the source at the time of the observations. The raw data sheets are provided in Appendix A.5.

According to the facility representative the 924 Waukesha VGF L36GLD Black Start Generator IC Engine was out of service and could not be operated for visible emissions evaluation.



**Appendix A.5**  
**Visual Emissions Data**


Facility Name: SLE McGoath  
 Street Address: 251 North Harbor Blvd.  
 City: Dana Point State: CA Zip: 93035  
 Phone: NA

Process Equipment: Turbine Operating Mode: Online  
 Control Equipment: CO Catalyst Operating Mode: Online

Describe Emission Point:  
Stack Exit  
 Ht. Above Ground Level: ~100' Ht. Rel. to Observer: ~100'  
 Dist. from Observer: ~300' Dir. from Observer: NW

Describe Emissions  
 Start: None End: None  
 Emission Color: Start: NA End: NA  
 Water Plume Present? None  
 Point in the Plume at which Opacity was Determined:  
Stack Exit

Describe Plume Background:  
Sky  
 Background Color: Start: White End: White  
 Sky Conditions: Start: Cloudy End: Cloudy  
 Wind Speed: Start: LSMPH End: LSMPH  
 Wind Direction: Start: E End: E  
 Ambient Temperature: Start: 69°F End: 69°F



Minute	Seconds			
	0	15	30	45
1	0	0	0	0
2	0	0	0	0
3	0	0	0	0
4	0	0	0	0
5	0	0	0	0
6	0	0	0	0
7	-	-	-	-
8	0	0	0	0
9	0	0	0	0
10	0	0	0	0
11	0	0	0	0
12	0	0	0	0
13	0	0	0	0
14	-	-	-	-
15	0	0	0	0
16	0	0	0	0
17	0	0	0	0
18	0	0	0	0
19	0	0	0	0
20	0	0	0	0
21				
22				
23				
24				
25				
26				
27				
28				
29				
30				
31				
32				
33				
34				
35				
36				
37				
38				
39				
40				

Observers Name: Ali Alshaker  
 Observers Signature: [Signature] Date: 7/8/19  
 Company Name: Montrose Air Quality Services  
 Certified By: [Signature] Date: 1/25/19  
 Cal. Air Resources Board