VENTURA COUNTY
2021 FEB 11 PM 1: 59
A.P.C.D.

# 2020 Reporting Year

# **Annual Title V Compliance Certification**

For

The Procter & Gamble Paper Products Company Oxnard, CA Facility

VCAPCD Permit No. 00015

Contact:

# 3

Cindy Stines Site Environmental Leader 805-485-8871 x2408 Stines.cg@pg.com



# ANNUAL COMPLIANCE CERTIFICATION SIGNATURE COVER FORM

A copy of each Annual Compliance Certification shall be submitted to EPA, Region 9, at the following address:

Mr. Gerardo Rios, Chief Permits Office (AIR-3) Office of Air Division EPA Region 9 75 Hawthorne Street San Francisco, CA 94105

#### Confidentiality

All information in a Part 70 permit compliance certification is public information. The Part 70 permit is also public information.

#### **Certification by Responsible Official**

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in this compliance certification are true, accurate, and complete.

Signature and Title of Responsible Official:  Title: Alant Manager	Date: 2/10/2021

Time Period Covered by Compliance Certification

01/01/20 (MM/DD/YY) to 12/31/20 (MM/DD/YY)



# RESPONSIBLE OFFICIAL'S CERTIFICATION FORM

Ventura County APCD Rule 33.9 requires that "any document, including reports, schedule of compliance progress reports and compliance certifications, required by a Part 70 permit shall be certified by a responsible official." Therefore, this form shall be signed by the company's Responsible Official and submitted with all such reports, including, but not limited to semi-annual reports, deviation and emergency reports and any periodic reports required by a Part 70 permit. However, when submitting your Annual Compliance Certifications, please use the form titled Annual Compliance Certification Signature Cover Form.

Semi-annual reports, deviations and emergency reports and any periodic reports required by your Part 70 permit should be submitted to:

Ed Swede
Air Quality Engineer
Ventura County Air Pollution Control District
669 County Square Drive
Ventura, CA 93003

### **Certification by Responsible Official**

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in this document is true, accurate, and complete.

Title: Plant Manager
----------------------

T.O.C Permit Revisions Table Permit Summary and Statement of Basis

This section contains a descriptive summary and statement of basis.

Compliance Certification is not applicable to this summary information

Permitted Equipment and Applicable Requirements Table

This is a summary of requirements.

Specific and enforceable permit terms and conditions are found in other sections of the permit.

Compliance Certification is not applicable to this summary information.

Permitted Throughput and Consumption Limit Table



A. Attachment # or Permit Condition #:	D. Frequency of monitoring:
Section 3 – Permitted Throughput Limits Table 3 (00015-411,431,441)	Monthly
Bestier & Fermities Fill ough part annual Fill of Court o	,
B. Description: Stationary Combustion Engines	E. Source test reference method
	N/A
List of Throughput Permit Limits for Emissions Units	.,
ll ll	
C. Method of monitoring:	F. Currently in Compliance?
12 month rolling totals, based on monthly data for regualted emissions inlcuding	YES
ROC's are tracked on a monthly basis.	
	C. Compliance Shakusa
	G. Compliance Status:
	CONTINUOUS
	H. *Excursions, Exceedence, or other non-
	compliance:
	NO
	NO



A And I will be a to Conditation H	D. Fragueray of
A. Attachment # or Permit Condition #:	D. Frequency of
	monitoring:
	Monthly
B. Description: Stationary Combustion Engines	E. Source test reference method N/A
Condition 1 - Emergency or Maintenance Engine Operation <50 hrs/calendar yr	
Condition 2- Emergency Engines equipped with operating, non resettable, elapsed hour meters.	
Condition 3 - Records for each emergency engine should include: Engine manufacturer, model number, operator identification number and location.	
Condition $4$ - Report annual hours of maintenance operation to the District annually by Feb $15$ .	
C. Method of monitoring:	F. Currently in Compliance?
Condition 1 – Fire/Emergency and Maintenance hr run times tracked in monthly log	YES
Condition 2 – All engines are equipped with a non-resettable hour meter	G. Compliance Status: CONTINUOUS
Condition 3 & 4 - Emergency Diesel Engine Annual Report forms are submitted to the District	Commods
	H. *Excursions, Exceedence, or other non-compliance: NO

Permitted Emissions Table

This is a summary of requirements.

Specific and enforceable permit terms and conditions are found in other sections of the permit.

Compliance Certification is not applicable to this summary information.

Exempt Equipment List (Insignificant Activities Table)

This is a summary of insignificant activities listed in the permit for informational purposes. Compliance Certification is not applicable to this section.

Specific Applicable Requirements (Attachments)



Terrou covered by compliance certification. Familiarly 2, 2020	
A. Attachment # or Permit Condition #:	D. Frequency of
Section 6 - 74.15 N.1	monitoring: Biennial
B. Description: Boilers, Heater Treaters, Steam Generators, and Process Heaters	E. Source test reference method:
Condition 1 – Emissions: NOx < 40 ppmvd, CO < 400 ppmvd	Source Test Summary Form 1 of 4
Condition 2 – Source Tested every 24 months using ARB Method 100	ARB Method 100:
Condition 3.a-b - Alternate Fuel Use limitations	со
Condition 4 – Startup emissions exemption	Stack Gas O2
Condition 5 – Recordkeeping: Alternate Fuels, Biennial Source test report	
Condition 6 – Flue Gas Recirculation requirements per Section 7	
C. Method of monitoring:	F. Currently in
Condition 1 & 2 -3/3/2020 Source Test demonstrated compliance	Compliance? YES
Condition 3 – Only Natural Gas was used for the 2020 calendar year.	G. Compliance Status:
Condition 4 – Instructional Condition; Certification not applicable.	Continuous
Condition 5 – No alternate fuel utilized. Source Test report furnished to District on time.	H. *Excursions,
Condition 6 – Compliance with applicable Section 7 flue gas recirculation requirements.	Exceedence, or other non-compliance: No



#### ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

A. Attachment # or Permit Condition #:  Section 6 – Attachment 74.19N1-(6/14/11)	D. Frequency of monitoring:  Monthly
	E. Source test reference method: N/A
Condition 1 – Chemical Approval Process verifies only <225 g/l ROC content inks are allowed on-site.  Condition 2 & 3 – Facility does not use Fountain Solution in Graphic Arts operations; only Solvent free, water based cleaning solution is used.  Condition 4 & 5 – Per written procedures, facility utilizes solvent-free cleaning solutions (water).  Condition 6 – Visual observation of ROC containing materials in closed containers while in storage.  Condition 7 – Facility resources are trained to dispose of waste per CA Title 22, and Federal	F. Currently in Compliance? YES G. Compliance Status: Continuous H. *Excursions, Exceedence, or other non-compliance: NO



Period Covered by Comphanice Certification. January 1, 2020 - Decei	
A. Attachment # or Permit Condition #:	D. Frequency of monitoring:
Section 6 – Attachment 74.34N2 (12/13/2016)	Monthly
B. Description: NOx Reductions from Miscellaneous Sources	E. Source test reference method: N/A
Condition 1- Perform combustion system maintenance in accordance with manufacturer's	
written instructions/specifications or according to good engineering practices focused on reliability and emission controls.	
Condition 2 - Document maintenance activities in a site specific combustion and emission controls sytems maintenance plan. The plan must be kept onsite and available to the APCD	
upon request.	
Condition 2 - Maintain records of combustion system maintenance and make available to APCD upon request	
	F. Currently in
C. Method of monitoring:	Compliance?
Condition 1 $\&$ 2 - Combustion system maintenance was performed for all applicable units in accordance with a site written plan and is available upon request.	YES
Condition 3 - Maintenance records including manufacturer's inspection reports for 2020 are on file and available upon request.	G. Compliance Status: CONTINUOUS
	H. *Excursions,
	Exceedence, or other
	non-compliance:
	NO
	=



A. Attachment # or Permit Condition #: Section 6 – Attachment 103N5 (02/09/99)	D. Frequency of monitoring:  Monthly
B. Description: Boiler Capacity Factor  Condition 1 – Operate at less than 30% Capacity Factor (CF) for CEMs exemption  Condition 2 – Install CEMs upon request of District  Condition 3 –Maintain monthly fuel consumption records and submit annual capacity factor calculation to demonstrate unit maintains < 30% CF each year.	E. Source test reference method N/A
C. Method of monitoring:  Condition 1 – Operate at less than 30% Capacity Factor for CEMs exemption  Condition 2 – Install CEMs upon request of District  Condition 3 – Monthly fuel records and annual capacity factor calculation are documented	F. Currently in Compliance? YES G. Compliance Status: CONTINUOUS
	H. *Excursions, Exceedence, or other non-compliance: NO



A. Attachment # or Permit Condition #:	D. Frequency of
Section 6 – Attachment STRMLN15LM6000-NOx-rev291	monitoring: Monthly
B. Description: LM6000 Gas Turbine Based Cogeneration Unit  Condition 1, 2, 4, & 6 - NOx < 2.5 ppmvd avg. @ 15% O2 over 3 hr. period, Annual Source Test, and CEMs, ROC < 2.0 ppmvd @ 15% O2 average over 3 consecutive hrs. Operate Oxidation Catalyst & test annually, Outlet Ammonia < 20 ppmvd verified annually via source test, PM < 3.08 lbs/MMscf & source test using ARB Method 5 upon District request  Condition 3: Emissions Exemption: 12 hr cold startup, 3 hr normal-startup, 2 hr unplanned load changes, and 1 hr shutdown  Condition 5.a-f - Source Test Annually at normal operating load. Test Notification and protocol submitted 15 days in advance with report submitted within 45 days of test to include permit specified parameters  Condition 7.a-l & 8.a-c - Operate and maintain CEMs & record permit specified data, CEMs calibration and maintenance per 40 CFR, part 51, Appendix P, Sections 3.0 through 3.9.5  Condition 9 - Written Notification of monitored emission standards violations within 96 hours  Condition 10.a-d & 11 - Permanent CEMs records, to include permit specified data, Upon request submit CEMs data to District  Condition 12 & 13 - CEMs data reduced per 40 CFR, part 51, appendix P, paragraphs 5.0 – 5.3.3.  Records maintained per permit conditions  Condition 14.a-b - Turbine Operating hours report & annual source test report	E. Source test reference method Source Test Summary Form 2 of 4  EPA Method 20 -NOx ARB Method 100 -CO, O2 EPA Method 18 -ROC ASTM Method D 3588-91 - Fuel HV BAAQMD Method ST-1B-NH3
C. Method of monitoring:  Condition 1, 2, 4, 5, & 6 – Annual source test conducted on March 4, 2020.  C6ondition 2, 7, 10, 11, 13 – Recordkeeping.  Condition 3 – Exemptions applied as required throughout the calendar year.  Condition 5 – Utilize certified Source Test vendors, use specified test methods, and submit documentation per deadline requirements.  Condition 8 - Maintenance via operators with assistance from CEM manufacturer.  Condition 9 – Operational procedures ensure compliance with 96 hour reporting requirement.  Condition 12 – Data Acquisition System data reduction and recordkeeping per specification.  Condition 14 – Turbine report submitted semi-annually, source test submitted annually.	F. Currently in Compliance? YES G. Compliance Status: INTERMENTENT H. *Excursions, Exceedence, or other non-compliance: NO



A. Attachment # or Permit Condition #: Section 6 – Attachment STRMLN15LM2500-NOx,CO-rev 391	D. Frequency of monitoring:  Monthly
B. Description: GE LM-2500 Gas Turbine Based Cogeneration Unit NOx and CO Applicable Requirements  Condition 1 – 3 Hour NOx average < 24 ppmvd @ 15% O2 while burning Natural Gas  Condition 2 – Emissions Exemption: 1 hr for startup & shutdown  Condition 3 – Source Test Annually at normal operating load. Test Notification and protocol submitted 15 days in advance with report submitted within 45 days after test to include permit specified parameters.  Condition 4 – Operate and maintain CEMs & record permit specified data.  Condition 5 – CEMs calibration and maintenance per 40 CFR, part 51, Appendix P, Sections 3.0 through 3.9.5.  Condition 6 – Written Notification of emissions violations within 96 hours.  Condition 7 – Permanent CEMs records, to include permit specified data.  Condition 8 – Upon request submit CEMs data to District.  Condition 9 – CEMs data reduced per 40 CFR, part 51, appendix P, paragraphs 5.0 – 5.3.3.  Condition 10 – Records maintained per permit conditions.  Condition 11 – Turbine Operating hours report & annual source test report.	E. Source test reference method See Source Test Summary Form 3 of 4  EPA Method 20 -NOx ARB Method 100 -CO, O2 ASTM Method D 3588-91 - Fuel HV
C. Method of monitoring:  Condition 1, 3 – Annual source test conducted on May 19, 2020 6Condition 1, 2, 4, 7, 8, 9, 10 – Recordkeeping  Condition 5 – Maintenance via operators with assistance from CEMs manufacturer  Condition 6 – Operational procedures ensure compliance with 96 hour reporting requirement  Condition 11 – Turbine report submitted semi-annually, source test submitted annually	F. Currently in Compliance? YES G. Compliance Status: INTERMENTENT H. *Excursions, Exceedence, or other non-compliance: NO



A. Attachment # or Permit Condition #: Section 6 – Attachment STRMLN15-SOx-rev 441	D. Frequency of monitoring:  Monthly
B. Description: LM6000 and LM2500 Gas Turbine Based Cogeneration Units SOx Applicable Requirements - Streamlined	E. Source test reference method N/A
Condition 1 – Gaseous Fuel < 50 grains sulfur per 100 Cu Ft. of fuel	
Condition 2 – If use PUC fuels used Rule 64 compliance is assumed	
Condition 3 – All emissions must be < 300 ppm SO2 at discharge	
Condition 4 – Upon Request source test for SO2 at discharge points	
C. Method of monitoring:	F. Currently in Compliance?
Condition 1-3 - Both the LM6000 and LM2500 exclusively use PUC-quality natural gas.	YES
Condition 4 – Source Test upon request	G. Compliance Status: CONTINUOUS
	H. *Excursions, Exceedence, or other non-compliance:



A. Attachment # or Permit Condition #: Section 6 – Attachment NESHAP KK	D. Frequency of monitoring:  Monthly
B. Description: 40 CFR Part 63 Subpart KK Applicable Requirements	E. Source test reference method
Condition 1 – Use < 10 Ton per 12 month rolling period of each HAP	.,,,,
Condition 2 – Use < 25 tons total per 12 month rolling period for all HAPs	
Condition 3 – HAP exclusion for various activities	
Condition 4 – Considered Area Source if it complies with HAP limitations	
Condition 5 – Maintain monthly records and calculations of HAP materials and their HAP fractions	
Condition 6 – Provided 40 CFR 63.9(b) Notification	
C. Method of monitoring:	F. Currently in
Conditions 1 – 6: In 2020, site maintained non-major HAP status by emitting less than 10 TPY of any one HAP and less than 25 TPY of all HAPs. HAP emission and mass fraction monthly records are maintained as required by permit condition.	Compliance? YES
monthly records are maintained as required by permit condition.	G. Compliance Status: CONTINUOUS
	H. *Excursions, Exceedence, or other non-compliance: NO



A. Attachment # or Permit Condition #:	D. Frequency of
Section 6 – Attachment ATCM Engine N1	monitoring:
-	Monthly
3. Description: ATCM for Stationary Compression Ignition Engines	E. Source test reference
	method
	N/A
Condition 1.a-e: Use specified approved fuels	
Condition 2: Monthly log of engine hours of operation	
Conditions 3.a-e: Maintain fuel purchase records	
C. Method of monitoring:	F. Currently in
Condition 1.a-e: Facility uses only specified approved fuels.	Compliance?
Condition 1.a-e. Facility uses only specified approved rueis.	YES
Condition 2: Facility maintains monthly log of engine hours of operation.	
,	G. Compliance Status:
Conditions 3.a-e: Facility maintains fuel purchase records.	CONTINUOUS
	H. *Excursions,
	Exceedence, or other
	non-compliance:
	NO
	1



A. Attachment # or Permit Condition #:	D. Frequency of
Section 6 - Attachment 40CFR63 ZZZZN3	monitoring:
ection 6 - Attachment 40Cr No3 2222N3	_
	Monthly
3. Description: 40 CFR Part 63 Subpart ZZZZ Applicable Requirements	E. Source test reference
	method
Condition 1: Meet work practice standards including annual oil and filter changes, air cleaner inspections and	N/A
pelt/hose inspections. Report any delays due to emergency use to APCD.	
<u>Condition 2</u> : Operate and maintain IC engines according to manufacturer's emission related instructions or per	
ite plan to maintain and operate equipment consistent with good air pollution control practices.	
Condition 3: RICE must be equipped with non-resettable hour meter.	
Condition 4: Minimize idle time during startup and minimize startup time to safe engine loading time, not to	
exceed 30 minutes.	
Condition 5: Limit non-emergency use of engines to no more than 100 hours per calendar year for	
maintenance and readiness testing and other allowed uses. Within this 100 hour allowance, limit hours for	
non-emergency non-maintenance/readiness testing (uses outlined in 63.6640 (f) ) to no more than 50 hours	
per calendar year.	
Condition 6: Maintain records of maintenance conducted on stationary emergency RICE and record hours of	
operation for emergency use and non-emergency uses to demonstrate compliance with Condition 5.	
Condition 7 & 8: Non applicable condition - the site does not operate RICE for emergency demand response.	
Condition 9: Annually certify that all engines operate in compliance with 40 CFR Part 63 Subpart ZZZZ.	
C. Method of monitoring:  Condition 1: Maintain records to demonstrate that annual oil and filter changes, air cleaner inspections and	F. Currently in
annual belt/hose inspections are completed. Report any delays due to emergency use to APCD.	Compliance?
Condition 2: Operate and maintain IC engines according to site plans for maintenance and operation	YES
consistent with good air pollution control practices.	G. Compliance Status:
Condition 3: RICE are currently equipped with non-resettable hour meters.	CONTINUOUS
Condition 4: Minimize idle time during startup and minimize startup time to safe engine loading time, not to	
exceed 30 minutes	
Condition 5: Compliance with hour limitations is demonstrated by records of hours of operation for	H. *Excursions,
emergency, non-emergency and non-emergency/non- maintenance or readiness testing use.  Condition 6: Maintain records of maintenance conducted on stationary emergency RICE and record hours of	Exceedence, or other
operation for emergency use and non-emergency uses to demonstrate compliance with Condition 5.	
Conditions 7 & 8: Non-applicable condition - the site does not operate RICE for emergency demand response.	non-compliance:
Condition 9: Annual Subpart ZZZZ compliance certification is satisfied by the ACC	NO

Permit Specific Conditions (Attachments)



#### ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

. Attachment # or Permit Condition #:	D. Frequency of
ection 7 – Attachment PO00015PC1-rev411, 431, 441	monitoring: Monthly
. Description: Throughput & Consumption Limits and Solvent Records	E. Source test
	reference method
ondition 1 – Maintain Monthly throughput (emissions) records as detailed in Section No. 3 "Permitted Throughput nd Consumption Limit Table.	N/A
ondition 2 – Maintain a list of all exempt solvents used, a reference to the specific permit exemption status and neir ROC content and pounds used per rolling 12 month period.	
ondition 3 - Permission to operate a rental boiler that is < 100 MMBTU/hr as an alternative to operating the 100 MMBTU/hr B-301 Boiler for up to 12 months. While in use, PO00015PC2 shall apply and PO00015PC4 shall not pply. The temporary boiler shall be equipped with Low NOx burners to meet the PO00015PC2 emissions mitations for the B-301 Boiler and the permittee shall maintain documentation that the temporary boiler meets the required emission limitations and records of usage of the temporary rental boiler.	
. Method of monitoring:	F. Currently in
ondition 1 – Monthly records of emissions specified in Table 3 throughput column are recorded.	Compliance? YES
	G. Compliance Statu
ondition 3 - Rental boiler was not used during this reporting period.	
	H. *Excursions, Exceedance, or othe non-compliance: NO



# ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification. January 1, 2020 - December 31, 2020	
A. Attachment # or Permit Condition #:  Section 7 – Attachment PO00015PC2-rev 411, 431, 441	D. Frequency of monitoring:  Monthly
B. Description: Combustion Emissions Units- LM6000, LM2500, B&W Steam Boiler, 1X Hot Air, 1X Yankee Furnace, 2X Furnaces  Condition 1 – Specifies monitoring requirements and calculations to demonstrate compliance with TPY emissions limits for Combustion Unit group identified in this condition.  Condition 2 – Restricts fuel used in specified combustion units to Natural Gas (NG)  Condition 3 – Maintain records: 12 mo. Rolling average fuel usage and emissions based on Emission Factors and CEM units specified in this condition and condition 1 above.  Condition 4 - The Table 4 CO hourly lb./hour for the LM2500 shall be demonstrated by the annual source test requirement in STRMLIN15LM2500-NOx, CO.  Condition 5 - The Table 4 CO hourly lb./hour for the LM600 shall be demonstrated by the annual source test requirement in STRMLIN15LM6000-NOx.  Condition 6 - Permission to operate a rental boiler that is < 100 MMBTU/hr as an alternative to operating the 100 MMBTU/hr B-301 Boiler for up to 12 months. While in use, PO00015PC2 shall apply and PO00015PC4 shall not apply. The temporary boiler shall be equipped with Low NOx burners to meet the PO00015PC2 emissions limitations for the B-301 Boiler and shall maintain documentation that the temporary boiler meets the B-301 emission limitations and records of usage of the temporary rental boiler.	E. Source test reference method N/A
C. Method of monitoring:  Condition 1 – Monthly monitoring of emissions records to ensure compliance with combustion emission limits.  Condition 2 – Facility exclusively utilized PUC Natural Gas to fire all permitted combustion units at facility.  Condition 3 - CEMS data from the turbines is used to maintain 12 month rolling averages for NOx, CO, and NH3. All other 12 month rolling averages are maintained by Emission Factors and fuel use.  Condition 4 & 5 - Source Test records demonstrating the Table 4 limits for each turbine was performed and submitted per the STRMLN Requirements for each turbine.  Condition 6 - Alternative Operating Scenario was not utilized in RY2020	F. Currently in Compliance? YES G. Compliance Statu CONTINUOUS  H. *Excursions, Exceedance, or othe non-compliance: NO
Condition 6 - Alternative Operating Scenario was not utilized in K12020	



#### ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

A. Attachment # or Permit Condition #:	D. Frequency of monitoring: Condtion 2 - Semi Annual
Section 7 – Attachment PO00015PC3-rev351	Condition 3 - Permit Term Condition 4 - Bi Annual
B. Description: 2X Papermachine Hot Air Furnace and "Yankee" Hood Furnace Requirements	E. Source test
Condition 1 –Emission limitations: NOx < 0.08 lb./MMBTU, CO < 0.045 lb./MMBTU	reference method:  ARB Method 100:
Condition 2 –Fuel and air settings locked in position as specified in permit. Settings recorded every 6 months	NOx CO
Condition 3 – Source test the Pre Dryer Hot Air Furnance and Yankee Hot Air Furnace once every 24 months un ARB Method 100 for NOx, CO and O2. Notification & Test Protocol to District 15 days in advance. Report with after test. before March 28, 2020 using ARB Method 100 for NOx, CO and O2. Notification & Test Protocol to District 15 days in advance. Report within 45 after test.	in 45   See Source Test Form
C. Method of monitoring:	F. Currently in Compliance?
Condition 1 - Both Furnaces demonstrated compliance to the NOx and CO limits per their last Source Test 5/26/20	YES*
Condition 2 – Fuel Linkage settings for the Yankee and Hot Air Furnaces were monitored in January and July to meet requirement	G. Compliance Status: INTERMITTENT**
Condition 3 - Condition requirements were met as demonstrated in the most recently submitted Source Test Report.	H. *Excursions, exceedances, or other non-compliance:
	Possible exception to continious compliance***



#### ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

A. Attachment # or Permit Condition #:	D. Frequency of
Section 7 – Attachment PO00015PC4 –rev 411, 431, 441	monitoring: Monthly
B. Description: Flue Gas Recirculation (FGR) Requirements for Babcock & Wilcox Steam Boiler	E. Source test reference method N/A
Condition 1.a-b – FGR system settings locked (physically pinned) in place per permit specifications. Parameters to be monitored, measured, and recorded on monthly basis.	
C. Mathad of manitoning.	F. Currently in
C. Method of monitoring: Parameters to be monitored, measured, and recorded on monthly basis.	Compliance?
	G. Compliance Status CONTINUOUS
	H. *Excursions, Exceedance, or other non-compliance: NO



#### ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

A. Attachment # or Permit Condition #: Section 7 – Attachment PO00015PC5-rev 441	D. Frequency of monitoring:  Monthly
B. Description: Particulate Matter Emission Requirements 1X Paper Machine, 2X Paper Machine, Wet Lapper and Converting Line Rooms  Condition 1: Emission Limitations: 1X PM < 6.75 lbs/hr., 2X PM < 3.99 lbs/hr., Wet Lapper < 0.10  Condition 2: To demonstrate compliance with emission limitations, daily average of hourly readings of scrubber pressure drop and liquor flow rate for 1X, 2X and wet lapper scrubbers shall be recorded and maintained no less than the values specified in this condition.  Condition 3.a-e: Daily Record not required for less than full day operation. Excursions to be corrected expeditiously, meters and gauges maintained per facility plan, and made available upon request. Excursions require summary of corrective actions. Semi annual report of Excursions.  Condition 4.a-b: PM emissions must meet limitations specified in Rules 52 and 53 (table limits in each rule)  Condition 5: Compliance with Rule 52 & 53 achieved with compliance with Condition 1 and 2  Condition 6: Converting room emissions shall be re-circulated back into room	E. Source test reference method N/A
permit and will document and submit corrective action in the Semi Annual Report as required by the permit.  Condition 6 – Converting Room emissions are circulated back into room via equipment listed in the Section 5 Insignificant Activities List.	F. Currently in Compliance? YES G. Compliance Stat CONTINUOUS  H. *Excursions, Exceedance, or oth non-compliance: NO



Period Covered by Compliance Certification: January 1, 2020 - December 31, 20	20
A. Attachment # or Permit Condition #: Section 7 – Attachment PO00015PC6-rev351	D. Frequency of monitoring:  Monthly
B. Description: ROC Emission Requirements Manufacturing Chemicals for Ink and Additive Applications  Condition 1 – ROC Emission limit for manufacturing chemicals used in inks and additives for producing, converting, and packaging toilet tissue and paper towels shall not exceed 60 tons per year in any 12 month period.  Condition 2 – Maintain monthly records of ROC emissions from manufacturing chemicals used in inks and additives for producing, converting and packaging toilet tissue and paper towels and demonstrate compliance based on 12-month rolling average emissions.	E. Source test reference method N/A
C. Method of monitoring:  Condition 1 – Facility ROC emissions rates are recorded and tracked to ensure 12 month rolling totals maintained below 60 TPY  Condition 2 – Maintain monthly usage data for ROC containing manufacturing chemicals	F. Currently in Compliance? YES  G. Compliance Stat
\$	H. *Excursions, Exceedance, or oth non-compliance: NO



Period Covered by Compliance Certification: January 1, 2020 - December 31, 2020	
A. Attachment # or Permit Condition #: Section 7 — Attachment PO00015PC7-rev391	D. Frequency of monitoring:  Monthly
B. Description: Federal PSD Permit Requirements- Cogeneration Turbine (LM-6000), Cogeneration Turbine (LM-2500),Babcock & Wilcox Steam Boiler, 1X Paper Machine Hot Air Furnace, and 1X Papermachine "Yankee" Hood Furnace	E. Source test reference method N/A
Condition 1 – If request increase in permitted NOx emissions for specified combustion sources above 250 TPY, submit PSD application for LM6000 turbine	
C. Method of monitoring:	F. Currently in
Condition $1-1$ If request increase in NOx emissions in excess of 250 TPY, will submit PSD application for LM6000 turbine.	Compliance? YES
	G. Compliance Statu CONTINUOUS
	H. *Excursions, Exceedance, or othe non-compliance: NO



#### ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

A. Attachment # or Permit Condition #:  Section 7 – Attachment PO00015PC8	D. Frequency of monitoring: Monthly
B. Description: ERC Certificate No. 1166  Condition 1 – All motor vehicle parking and traffic on paved roads or paved parking lots, except for emergencies, construction, maintenance and agricultural use.	E. Source test reference method N/A
C. Method of monitoring:  Condition 1 – Access to unpaved areas is restricted except for non routine access during emergencies or for maintenance and construction activities. Signs indicating prohibition for parking, and travel over unpaved areas are posted throughout site. Parking and traffic expectations communicated to facility and enforced by facility personnel	F. Currently in Compliance? YES
personner	G. Compliance Status: CONTINUOUS
	H. *Excursions, Exceedance, or other non-compliance: NO

General Applicable Requirements (Attachments)



Period Covered by Compliance Certification: January 1, 2020 - December 31, 2020	
A. Attachment # or Permit Condition #:  Section 8 – Attachment Rule 50 (8/20/2020)	D. Frequency of monitoring:  Monthly
B. Description: Opacity	E. Source test
Condition 1 – Do not discharge into the atmosphere any air contaminants for > 3 minutes in one hour which are as dark or darker than No. 1 on the Ringleman Chart or equal to or greater than 20% Opacity	reference method: N/A
Condition 2 – Periodic "Quarterly" Surveillance and record of visible emissions other than uncombined water	
Condition 3 – Annual compliance certification, including site survey	
Condition 4 – Per District Request, Opacity is determined by a person certified in reading smoke using EPA Method 9 or a certified and calibrated monitoring system	
	:4
C. Method of monitoring:	F. Currently in
Condition 1 & 2 – No visible emissions were observed in 2020	Compliance? YES
Condition 3 - Quarterly Opacity Survey completed on 2/21/20, 3/19/20, 5/26/20, 8/20/20	G. Compliance Status:
Condition 4 - Per District request, a certified, calibrated monitoring system or a person certified in EPA Method 9 will determine Opacity	CONTINUOUS
	H. *Excursions, Exceedence, or other non-compliance: NO



Period Covered by Compliance Certification: January 1, 2020 - December 31, 20	20
A. Attachment # or Permit Condition #: Section 8 – Attachment 54.B.1 (01/14/14)	D. Frequency of monitoring:  Monthly
B. Description: Sulfur Compounds – Sulfur Emissions from Combustion Operations at Point of Discharge  Condition 1 – Point of Discharge SO2 concentrations < 300 ppmvd (corrected to 3% oxygen for boilers and 15% oxygen for turbines), from combustion operations specified.  Condition 2 – Comply with fuel Sulfur content limits per Rule 64. No monitoring required.  Condition 3 – Upon District Request determine point of Discharge concentrations of SO2	E. Source test reference method: N/A
C. Method of monitoring:  Condition 1 — Compliance with permit condition Attachment P00015PC2. Only PUC-quality natural gas and CARB approved diesel used on site in 2020  Conditions 2 — Fuel Oil Sulfur Content provided by supplier at each delivery. Gaseous sulfur content meeting PUC Quality requirements. Data furnished to district upon request.  Condition 3 — Furnish District with data upon request.	F. Currently in Compliance? YES G. Compliance Status: CONTINUOUS  H. *Excursions, Exceedence, or oth non-compliance: NO



Period Covered by Compliance Certification: January 1, 2020 - December 31, 20	20
A. Attachment # or Permit Condition #: Section 8 - Attachment 54.B.2 (01/14/14)	D. Frequency of monitoring: Monthly
Condition 1 – Property Line SO2 concentrations: 1 hr. < 0.25 ppmvd, 24 hr. < 0.04 ppmvd  Condition 2 - Property line 1 hour sulfur dioxide limit of 0.075 ppm  Condition 3 – Provide fuel or exhaust analysis along with modeling data or other demonstration to District upon request  Condition 4a-c – Upon District Request determine ground level concentrations of SO2	E. Source test reference method: N/A
Condition 1 - Compliance with permit condition Attachment P00015PC2. Only PUC-quality natural gas, and CARB approved diesel used on site in 2020  Conditions 2 – If the District requires ambient air monitoring, test methods specified will be employed.  Conditions 3 - Fuel Analysis provided by suppliers at request of facility. Exhaust analysis based on emissions factors ncorporated into facility AB2588 Health Risk Assessment.  Condition 4– Furnish District with data upon request.	F. Currently in Compliance? YES G. Compliance Status: CONTINUOUS  H. *Excursions, Exceedence, or oth non-compliance: NO



Period Covered by Compliance Certification: January 1, 2020 - December 31, 2020		
A. Attachment # or Permit Condition #:  Section 8 – Attachment 55 (06/10/08)	D. Frequency of monitoring:  Monthly	
B. Description: Fugitive Dust  Condition 1 – Do not cause or allow fugitive dust such that is visible past the property line.  Condition 2 – Do not cause of allow fugitive dust to cause 20% opacity as measured by EPA Method 9 using Rule 55 modifications.  Condition 3 – Do not allow "track-out" to extend ≥25ft unless control measures are utilized  Condition 4 - Remove all "track-out" at the conclusion of each workday or evening shift  Condition 5 - Comply with specific activity requirements for earth moving, bulk material handling, and truck hauling activities  Condition 6- Comply with specific record keeping requirements for each type of activity  Condition 7 - Annually certify that all applicable source of dust are in compliance or certify that there are no operations, disturbed surface areas, or man made conditions that are subject to Rule 55.	E. Source test reference method: N/A	
C. Method of monitoring:  Condition 1-2— Routine activities do not result in fugitive dust causing visible emissions beyond specified boundaries. Outdoor projects are controlled and monitored such that Conditions 1-2 are met.  Condition 3 — Site property is such that the possibility of track out is minimized. For projects where the possibility of track out exists — vehicles are inspected and managed to prevent track out.  Condition 4 — When applicable, Track Out is removed at the conclusion of each workday or shift.  Condition 5 — Site utilizes procedures and methods for prevent fugitive dust.  Condition 6 — When required, records are kept.  Condition 7 — Ongoing assessment of site activity to ensure Rule 55 compliance.	F. Currently in Compliance? YES G. Compliance Status: CONTINUOUS H. *Excursions, Exceedence, or other non-compliance: NO	



Period Covered by Compliance Certification: January 1, 2020 - December 31, 20	20
A. Attachment # or Permit Condition #: Section 8 – Attachment 57.1 (01/11/05)	D. Frequency of monitoring:  Monthly
B. Description: Particulate Matter Emissions from Fuel Burning Equipment	E. Source test reference method;
Condition 1 – PM shall not exceed 0.12 lbs/Mmbtu  Condition 2 – Compliance demonstration required upon district request  Condition 3 – Periodic monitoring not required. Certify compliance by referring to District Rule 57.B analysis dated 12/3/97	IN/A
Condition 1 – Satisfy Conditions 2 & 3 of this attachment.  Condition 2 – Monitoring is not required based on district analysis (Per comments in permit, Table 1.C.3, Condition 57.1)  Condition 3 – Periodic monitoring is not required. Compliance certified via District analysis of Rule 57.B, dated	F. Currently in Compliance? YES G. Compliance Status: CONTINUOUS
12/3/97.	H. *Excursions, Exceedence, or oth non-compliance: NO



A. Attachment # or Permit Condition #:	D. Frequency of
Section 8 – Attachment 64.B.1 (04/13/99)	monitoring:  Monthly
B. Description: Sulfur Content of Fuels – Gaseous Fuel Requirements	E. Source test reference method:
Condition 1 – Gaseous Fuel sulfur compounds < 788 ppmvd	N/A
Condition 2 – Periodic Monitoring not required if using PUC Natural Gas	
Condition 3 – Analyze fuel if using non-PUC quality fuel	
Condition 4a-b — Monitoring required if landfill or oilfield gaseous fuel is used	
	2
ar and the state of the state o	
. Method of monitoring:	F. Currently in
Conditions 1-4: Maintain records showing that only PUC Quality natural gas is used, therefore no other monitoring s required. Facility does not use landfill or oilfield gaseous fuel.	Compliance? YES
	G. Compliance Status: CONTINUOUS
	H. *Excursions, Exceedence, or oth non-compliance:
	NO



Period Covered by Compliance Certification: January 1, 2020 - December 31, 2020	
A. Attachment # or Permit Condition #:	D. Frequency of monitoring:
Section 8 – Attachment 64.B.2 (04/13/99)	Monthly
B. Description: Sulfur Content of Fuels – Liquid Fuel Requirements	E. Source test reference method:
Condition 1 – No liquid Fuel usage with sulfur content > 0.5% by weight	
Condition 2 – If only use ARB quality liquid fuel compliance is assured without monitoring	
Condition 3 – Requirements for use of non ARB liquid fuels	
	-
C. Method of monitoring:	F. Currently in
Conditions $1 \& 2 - Maintain$ records of exclusive use of ARB compliant liquid fuel used on site in 2019 – No other monitoring is required.	Compliance? YES
Condition 3 — Monitor per permit requirements if use non-ARB quality liquid fuel	G. Compliance Status: CONTINUOUS
	H. *Excursions, Exceedence, or other non-compliance: NO



#### Period Covered by Compliance Certification: January 1, 2020 - December 31, 2020 A. Attachment # or Permit Condition #: D. Frequency of monitoring: Section 8 – Attachment 74.6 (03/15/19) Monthly E. Source test B. Description: Surface Cleaning and Degreasing reference method: N/A Condition 1.a-c: Limitations on use of solvents in surface cleaning. Solvents used for equipment cleanup and other cleanup of uncured coatings, adhesives, inks or resings and used for cleaning of electronic components shall not exceed < 900 g/l ROC & < 33 mmHg partial pressure. Cleaning solvents used for other purposes shall not exceed 25 g/I as applied. Condition 2.a-d: If use solvents > 25 g/l ROC are used, one of the specified cleaning methods must be employed. Specified methods include wipe cleaning; non-atomized solvent flow, dip, or flush with solvent collection and solvent capacity of less than 1 liter (unless cleaning equipment stated in conditions 8-10 are used), or solvent application from hand held spray or squirt bottle with a cpacity of less than one liter; or use of enclosed gun washer. Condition 3: No liquid cleaning solvent leaks from equipment or containers. Condition 4: No solvents shall be solicited, supplied, sold, or used that would violate Rule 74.6. Condition 5: Use less than one gallon of halogenated solvents per week for cold cleaning. If use maintain records. Condition 6: Solvent stored in non-absorbent containers and closed except for filling or emptying. Condition 7: Dispose of solvents and solvent residues as specified in California Hazardous Waste Code. Condition 8.a-f: Cold Cleaning equipment requirements, except for remote reservoir cold cleaners. Condition 9.a-e: Remote Reservoir cold cleaner equipment requirements. Condition 10.a-g: Cold Cleaner operating requirements. Condition 11.a-h: Rule 74.6 exemptions Condition 12.a-o: Condition 1 exemptions Condition 13: Condition 1 and 2 exemptions Condition 14.a-d: Solvent Material recordkeeping requirements. Upon district request, make information available to district personnel Condition 15: Maintain records and perform routine surveillance of solvent cleaning activities F. Currently in C. Method of monitoring: Compliance? Conditions 1–4, 6-7: Compliance for permit conditions pertaining to solvent storage and handling is satisfied via YES personnel training and observation. Chemical Approval System ensures conformity with solvent ROC content limits. G. Compliance Condition 5: Facility does not use halogenated cold cleaner solvents Status: **CONTINUOUS** Conditions 8-10: Cold cleaners are exempt per section 5 of Site Title V permit. H. \*Excursions, Condition 11: Exempted Solvents including Cold Cleaner Solvent is maintained on Surface Cleaning and Degreasing Exceedence, or other List non-compliance: NO Condition 14: Recordkeeping per permit requirements. Condition 15: Visual surveillance performed routinely. Site uses chemical approval process to confirm that only ROC content acceptable solvents are purchased and used on site.



Period Covered by Compliance Certification: January 1, 2020 - December 31, 2020	
A. Attachment # or Permit Condition #: Section 8 – Attachment 74.11.1 (9/11/12)	D. Frequency of monitoring:  Monthly
	Monthly
B. Description: Large Water Heaters and Small Boilers  Condition 1.a-b: Requirements for new small boilers and heaters (75-400 MBTU/hr) installed after January 1, 2013	E. Source test reference method: N/A
but before January 1, 2014	
Condition 2.a-b: New units installed after January 1, 2014 which are >/= 75 MBTU/hr and = 400 MBTU/hr must meet specified NOx limits and be certified in accordance with Rule 74.11.1.C.</td <td></td>	
Condition 3 a-b: New units installed after January 1, 2013 $>$ /= 400 MBTU/hr and $<$ 1,000 MBTU/hr must meet specified NOx limits and be certified in accordance with Rule 74.11.1.C.	
Condition 4 – Maintain a list-of manufacturer, brand name, model #, heat input rating, and installation date for each applicable unit. Submit upon request.	
Condition 5 - Certify annually and include a formal survey identifying each unit and documentation of certification status.	
C. Method of monitoring:	F. Currently in
Conditions 1-5: Facility does not presently utilize Heaters or Boilers that are rated at 75 – 1,000 MBTU/hr., thus facility is not subject to equipment certification, recordkeeping, and annual survey requirements	Compliance? YES
	G. Compliance
	Status: CONTINUOUS
	H. *Excursions,
	Exceedence, or other
	non-compliance:



Period Covered by Compliance Certification: January 1, 2020 - December 31, 2020	
A. Attachment # or Permit Condition #: Section 8 – Attachment 74.22	D. Frequency of monitoring:  Monthly
B. Description: Natural Gas-Fired Fan-Type Central Furnaces	E. Source test reference method:
Condition 1.a-b: New fan type central furnaces require NOx < 40ng per Joule Output	N/A
Condition 2: Maintain list of fan types with permit specified data	
Condition 3: Annual survey of fan furnaces	
C. Method of monitoring: Conditions 1–3: Facility has not installed nor does the site currently operate any natural gas-fired, fan-type central	F. Currently in Compliance?
urnaces on-site. Thus, the rule is not applicable at the facility.	G. Compliance Status: CONTINUOUS
	H. *Excursions, Exceedence, or oth non-compliance: <b>NO</b>

## Permit Section: 9-11

General Requirements for Short-Term Activities (Attachments)

**General Permit Conditions** 

Miscellaneous Federal Program Conditions



A. Attachment # or Permit Condition #:	D. Frequency of
Section 9 — Attachment 74.1 (12-07-2017)	monitoring: Monthly
B. Description: Abrasive Blasting	E. Source test reference method:
Condition 1.a-c: Abrasive Blasting shall be conducted indoors, using specified methods	N/A
Condition 2.a-d: For Outdoor blasting use steel or iron shot/grit or utilize specified alternate methods	
Condition 3 – Adhere to Rule 74.1.B.2 requirements for pavement marking	
Condition 4 – Stucco and concrete blasting per Rule 74.1.B.3	
Condition 5 — Use California approved and labeled materials for abrasive blasting	
Condition 6 - Comply with visible emissions standard per rule 74.1.C.2	
Condition 7 - Monitor abrasive blast operations to ensure compliance with Rule 74.1, maintain records to satisfy the information requirements in conditions 7a-e, maintain records on site, and submit to the District upon request	
C. Method of monitoring:  Condition 1.a-c: Abrasive Blasting shall be conducted indoors, using specified methods	F. Currently in Compliance?
Condition 2.a-d: Approved abrasive blasting material was used for outdoor blasting.	G. Compliance Statu
Condition 3 – Adhere to Rule 74.1.B.2 requirements for pavement marking	CONTINUOUS
Condition 4 – No stucco or concrete blasting occurred in 2019	H. *Excursions,
Condition 5 – Use California approved and labeled materials for abrasive blasting	Exceedence, or other non-compliance:
Condition 6 – Comply with visible emissions standard per rule 74.1.C.2	NO
Condition 7.a-e: Monitoring records are maintained for each short term abrasive blast operation, when applicable	



Period Covered by Compliance Certification: January 1, 2020 - December 31, 2020	
A. Attachment # or Permit Condition #: Section 9 – Attachment 74.2	D. Frequency of monitoring: Monthly
B. Description: Architectural Coatings  Condition 1.a-c: VOC Coating content limits, less water and exempt OC's, Flat <100 g/l; Nonflat <150 g/l; Nonflat High Gloss <250 g/l  Condition 2 — Specialty coatings shall conform with Rule 74.2 Table of Standards. Industrial Maintenance <250 g/l less water & exempt OC's  Condition 3 — Architectural coatings and cleaning materials to remain closed except when in use.  Condition 4 — Adhere to Rule 74.2.B.1 thinning requirements  Condition 5 — Conduct periodic facility inspections and an annual compliance certification of architectural coating operations to ensure compliance with Rule 74.2  Condition 6 — VOC content and other properties measured per procedures in Rule 74.2.G	E. Source test reference method N/A
Condition 1, 2 – All paints used at facility are reviewed for compliance prior to approval for use.  Condition 3 – Closure requirements are documented / training provided to all site personnel and contractors.  Condition 4 – The facility prohibit the thinning of paints and coatings if thinning can cause the paint or coating to exceed it's specified limit.  Condition 5 – Visual observations occur routinely. VOC data maintained for each coating via vendor supplied SDS.  Data will be furnished to District upon request.  Condition 6 – Architectural coating properties determined using vendor supplied data.	F. Currently in Compliance? YES G. Compliance Status CONTINUOUS  H. *Excursions, Exceedence, or other non-compliance: NO



Period Covered by Compliance Certification. January 1, 2020 - December 31, 2020	
A. Attachment # or Permit Condition #:	D. Frequency of monitoring:
Section 9 – Attachment 74.28	Monthly
B. Description: Asphalt Roofing Operations	E. Source test reference method
Condition $1-$ Kettles shall operate with lids. Lid will not be opened unless temperature is < $150$ oF	N/A
Condition 2 – Max Temperatures: Asphalt < 500oF, Coal tar pitch < 400oF	
Condition 3 – Lid to remained closed, and receiving containers to be covered	
Condition 4 – Kettle vents to remain closed at all times	
Condition 5 – Facility will verify Rule 74.28 requirements met during projects	
C. Method of monitoring:	F. Currently in
Conditions 1-5: Internal administrative procedures. Permits and conditions were met in Rule 74.28 during 2020 roofing restoration.	Compliance? YES
	G. Compliance Status CONTINUOUS
	H. *Excursions,
	Exceedence, or other non-compliance:
	NO
	2



A. Attachment # or Permit Condition #:	D. Frequency of
Section 9 - Attachment 40 CFR 61.M	monitoring: Monthly
B. Description: National Emissions Standards for Asbestos	E. Source test reference method N/A
Condition 1 – Comply with 40 CFR part 61, Subpart M	IN/A
Condition 2 – Adhere to 40 CFR part 61.145 requirements for Demolition and Renovation.	
C. Method of monitoring:	F. Currently in Compliance?
Condition 1 – Site Asbestos abatement program managed consistent with 40 CFR Part 61, Subpart M. State certified contractors are utilized for ACM demolition and renovation. Adherence with 40 CFR Part 61.145 is	YES
mandatory for job approval.	G. Compliance Status: CONTINUOUS
Condition 2 – ACM demolition and renovation are observed by site resources to ensure compliance with 40 CFR	
Part 61.145. Activities involving ACM recorded are filed with Site Environmental Leader. Notification is provided to District prior to ACM renovation or demolition for activities requiring notification.	
No applicable activities occurred during 2020	H. *Excursions, Exceedence, or other non-compliance:
	NO
a a	



A. Attachment # or Permit Condition #:	D. Frequency of monitoring:
Section 10 — District General Part 70 Permit Conditions	Monthly
B. Description: District General Part 70 Permit Conditions	E. Source test reference method N/A
Condition 1 – Comply with all federally enforceable conditions, and all applicable requirements specified in the	
Condition 2 – Comply with new applicable requirements that become effective during the permit terms in a timely manner	
Condition 3 – Promptly report deviations within 4 hours of detection	
Condition 4 – The need to halt / reduce activity is not a defense against enforcement action  Condition 5 – Retain all required records, monitoring data and support information for at least 5 years  Condition 6 – Provide requested information to District in a timely manner	
Condition 7.a-d: Facilitate permit specified District inspection rights  Condition 8 – Permit may be modified, revoked, reopened, reissued or terminated for cause	
Condition 9.a-d: Permit will be reopened per permit specified reasons Condition 10 – All fees shall be paid on timely basis	
Condition 11 – Permit does not convey property rights	
Condition 12 – One invalid term / condition does not invalidate the entire permit Condition 13 – Renewal application must be submitted between 6 to 18 months prior to expiration	
Condition 14 – Part 70 requires all applications, reports or other data that must be submitted per the Title V permit to be certified by the responsible official.	
Condition 15 – Annual Part 70 Compliance Certification	
C. Method of monitoring:	F. Currently in
Condition 1, All deviations from Title V requirements are reported as required.	Compliance? YES
Condition 2, 4, 7-9, 11-12: Not applicable - Instructional conditions.	G. Compliance Status:
Condition 3 – Internal administrative procedures.	intermittent
Condition 5 – Electronic databases and hard copy archives used for 5 year data retention.	H. *Excursions,
Condition 6 – Reports submitted to district	Exceedence, or other non-compliance:
Condition 10 – Internal Administrative procedures. Records of payments exist.	NO
Condition 12, 15, Internal Administrative presedures	



A. Attachment # or Permit Condition #: Section 10 – Shield -40CFR 72-78 rev 391	D. Frequency of monitoring: Monthly
B. Description: Permit Shield – Acid Rain Program Reference Information Only	E. Source test reference method N/A
C. Method of monitoring: Not Applicable - Reference Information only	F. Currently in Compliance? YES G. Compliance Status: CONTINUOUS
	H. *Excursions, Exceedence, or other non-compliance: <b>NO</b>
A. Attachment # or Permit Condition #: Section 10 – Shield 60KKKK	D. Frequency of monitoring: Monthly
B. Description: Permit Shield – Standards of Performance for Stationary Combustion Turbines  Reference Information Only	E. Source test reference method N/A
C. Method of monitoring: Not Applicable - Reference Information only	F. Currently in Compliance? YES G. Compliance Status: CONTINUOUS
	H. *Excursions, Exceedence, or other non-compliance:
A. Attachment # or Permit Condition #: Section 10 – Shield 63YYYY	D. Frequency of monitoring: Monthly
B. Description: Permit Shield – NESHAP For Stationary Combustion Turbines Reference Information Only	E. Source test reference method N/A
C. Method of monitoring: Not Applicable - Reference Information only	F. Currently in Compliance? YES G. Compliance Status: CONTINUOUS
	H. *Excursions, Exceedence, or other non-compliance:



#### ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: January 1, 2020 - December 31,	2020
A. Attachment # or Permit Condition #:	D. Frequency of
Section 10 – Shield 60 IIII	monitoring: Monthly
B. Description: Permit Shield – Stationary Compression Ignition Internal Combustion Engines	E. Source test reference
Reference Information Only	method
	N/A
C. Method of monitoring:	F. Currently in
Not Applicable - Reference Information only	Compliance? YES
	G. Compliance Status:
	H. *Excursions,
	Exceedence, or other
	non-compliance: NO
A. Attachment # or Permit Condition #:	D. Frequency of
Section 10 – Shield 60Dc	monitoring: Monthly
B. Description: Permit Shield – 40 CFR Part 60, Subpart Dc, "Standards of Performance for Small Industrial - Commercial -	E. Source test reference
Reference Information Only	method
national and the day	N/A
C. Method of monitoring:	F. Currently in
Not Applicable - Reference Information only	Compliance? YES
	G. Compliance Status:
	CONTINUOUS
	H. *Excursions,
	Exceedence, or other
	non-compliance: NO
A. Attachment # or Permit Condition #:	D. Frequency of
Section 10 – Shield 63DDDDD	monitoring: Monthly
B. Description: Permit Shield – NESHAP For Industrial, Commercial, and Institutional Boilers and Process Heaters	E. Source test reference
Reference Information Only	method
	N/A
C. Method of monitoring:	F. Currently in
Not Applicable - Reference Information only	Compliance? YES
Not Applicable - Reference information only	G. Compliance Status:
	CONTINUOUS
'	H. *Excursions,
	Exceedence, or other
	non-compliance: NO
A. Attachment # or Permit Condition #:	D. Frequency of
Section 10 – Shield 63JJJJJJ	monitoring: Monthly
B. Description: Permit Shield – NESHAP For Industrial, Commercial, and Insititutional Boiler Area Sources	E. Source test reference
	method
Reference Information Only	N/A
C. Method of monitoring:	F. Currently in
C. Method of monitoring:	F. Currently in Compliance? <b>YES</b>
	Compliance? <b>YES</b> G. Compliance Status:
C. Method of monitoring:	Compliance? YES  G. Compliance Status: CONTINUOUS
C. Method of monitoring:	Compliance? YES  G. Compliance Status: CONTINUOUS  H. *Excursions,
C. Method of monitoring:	Compliance? YES  G. Compliance Status: CONTINUOUS



Period Covered by Compliance Certification: January 1, 2020 - December 31, 2020	
D. Frequency of monitoring: Monthly	
E. Source test reference	
method N/A	
F. Currently in Compliance? YES	
G. Compliance Status:	



#### ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

District		
Period Covered by Compliance Certification: January 1, 2020 - December 31, 2020		
A. Attachment # or Permit Condition #:	D. Frequency of monitoring:  Monthly	
Section 11 — Attachment 40 CFR Part 68		
B. Description: Accidental Release Prevention and Risk Management Plans  Condition 1 – Should facility become subject to 40 CFR Part 68, then must submit Risk Management Plan and provide annual certification	E. Source test reference method N/A	
C. Method of monitoring:	F. Currently in Compliance? YES	
Condition 1— Threshold Quantity calculations used to determine applicability of 40 CFR Part 68, in addition to administrative storage quantity restrictions.		
	G. Compliance Status: CONTINUOUS	
	H. *Excursions, Exceedence, or other non-compliance:	



A. Attachment # or Permit Condition #:  Section 11 – Attachment 40 CFR Part 82 (04/10/15)	D. Frequency of monitoring:  Monthly
B. Description: Protection of Stratospheric Ozone  Condition 1 – Subject to 40 CFR part 82, Subpart B if perform service on motor (fleet) vehicles	E. Source test reference method N/A
C. Method of monitoring:  Condition 1— Facility does not maintain or otherwise service fleet vehicles at facility. Not subject to requirements	F. Currently in Compliance?
specified in permit condition.	G. Compliance Status: CONTINUOUS
Condition 2 – Internal administrative procedures to implement and manage applicable 40 CFR Part 82, Subpart F requirements.	H. *Excursions, Exceedence, or other non-compliance:

## **Deviations**



## ANNUAL COMPLIANCE CERTIFICATION SIGNATURE COVER FORM

A copy of each Annual Compliance Certification shall be submitted to EPA, Region 9, at the following address:

Mr. Gerardo Rios, Chief Permits Office (AIR-3) Office of Air Division EPA Region 9 75 Hawthorne Street San Francisco, CA 94105

#### Confidentiality

All information in a Part 70 permit compliance certification is public information. The Part 70 permit is also public information.

#### **Certification by Responsible Official**

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in this compliance certification are true, accurate, and complete.

Signature and Title of Responsible Official:  Title: Plant Manager	Date: 2/10/2021

Time Period Covered by Compliance Certification

01/01/20 (MM/DD/YY) to 12/31/20 (MM/DD/YY)



## RESPONSIBLE OFFICIAL'S CERTIFICATION FORM

Ventura County APCD Rule 33.9 requires that "any document, including reports, schedule of compliance progress reports and compliance certifications, required by a Part 70 permit shall be certified by a responsible official." Therefore, this form shall be signed by the company's Responsible Official and submitted with all such reports, including, but not limited to semi-annual reports, deviation and emergency reports and any periodic reports required by a Part 70 permit. However, when submitting your Annual Compliance Certifications, please use the form titled Annual Compliance Certification Signature Cover Form.

Semi-annual reports, deviations and emergency reports and any periodic reports required by your Part 70 permit should be submitted to:

Ed Swede
Air Quality Engineer
Ventura County Air Pollution Control District
669 County Square Drive
Ventura, CA 93003

#### **Certification by Responsible Official**

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in this document is true, accurate, and complete.

Signature and Title of Responsible Official:  Signature:  Title:  Alangee  Title:	Date: 2/10/202/



February 10, 2021

Mr. Keith Macias AQS, Inspector Ventura County APCD 669 County Square Drive Ventura, California 93003

Subject: RY2020 Annual Title V Compliance Certification and Semi-Annual Deviation Report

Mr. Macias:

Enclosed is The Procter & Gamble Paper Products Company's Oxnard facility, Part 70 Permit No. 00015 Compliance Certification for the January 1, 2020 through December 31, 2020 reporting period. This submission also constitutes the Semi-Annual Deviation Report for the time period July 1, 2020 – Dec 31, 2020.

I can be reached at 805-485-8871, X 2408 or stines.cg@pg.com should you have any questions about our facilities certification.

Respectfully,

Mrs. Cindy Stines

Site Environmental Systems Leader

Cc:

Mr. Marvelle Berry, Plant Manager; P&G Mr. Sokny Field, HS&E Leader; P&G Ms. Chris Cote, AQS; VCAPCD



#### **DEVIATION SUMMARY FORM**

Period Covered by Compliance Certification: <u>01/01/2020 to 12/31/2020</u>

A. Attachment # or Permit Condition #:	B. Equipment description:	C. Deviation Period:	
Rule 32 Excess Emissions Report	B301 Source Test Failure	Dates: 3/2/20	
		When Discovered:	
	· · · · · · · · · · · · · · · · · · ·	Date: 3/2/20	
D. Parameters monitored:	E. Limit:	F. Actual:	
B301 CO Emissions Source Test Failure	400 ppm	>400	
G. Probable Cause of Deviation	H. Corrective actions taken:		
On March 3rd 2020, the boiler repair service determined that the O-rings on the Master Controller were defective	On March 3 <sup>rd</sup> 2020, the boiler repair service determined that the O- rings on the Master Controller were defective. They were removed and replaced with new O-rings. The unit was restarted for the purpose of demonstrating the repair was complete. Upon demonstration that the repair was complete, P&G resources, Horizon Air Measurement Services Inc, and VCAPCD representative Ed Swede performed and observed a new source test. The results of the source test performed on March 3 <sup>rd</sup> 2020, demonstrate compliance with Rule 74.15.B1 as required in Condition 1 of attachment 74.15N1 in P&G's Title V permit.		

A. Attachment # or Permit Condition #:	B. Equipment description:	C. Deviation Period:
Attachment 74.15N1	2X Paper Machine	Date 01/01/2020 - 06/30/2020
Condition 2		When Discovered:
Rule 74.15.B.1		Date: 5/20/20
D. Parameters monitored:	E. Limit:	F. Actual:
Oxygen%	Biannual Source Test Date	5/26/20
NOx MMBtu limit 0.08		•
CO MMBtu limit is 0.0386		



#### **DEVIATION SUMMARY FORM**

Period Covered by Compliance Certification: 01/01/2020 to 12/31/2020

#### G. Probable Cause of Deviation

P&G was unable to complete the emissions testing program on the 2X Paper Machine due to operational limitations with the Hot Air Furnace Burner.

#### H. Corrective actions taken:

On Wednesday May 20, 2020, P&G was unable to complete the emissions testing program on the 2X Paper Machine due to operational limitations with the Hot Air Furnace Burner. The emissions test program was originally delayed due to complications that occurred as a result of the damage and repairs resulting from fire on 03/30/2020. The operational limitations experienced during testing prevented P&G from achieving normal operations. Before the Hot Air Furnace Burner was shut down due to operational issues that prevented normal operations to be achieved, P&G observed elevated CO concentrations on the Hot Air Furnace Burner. The Hot Air Furnace Burner was shut down on Wednesday May 20. 2020 and remained nonoperational until the commencement of the burner inspection, tuning, and testing activities on Tuesday May 26, 2020. Emissions testing was completed on the 2X Paper Machine on May 26, 2020 by Horizon Air Measurement Services, Inc. The emissions test program demonstrated that the 2X paper machine is in compliance with the permitted NOX and CO emissions limits contained in the facility's Title V Operation Permit (TVOP). While the delay in completing the test report and did not cause a deviation from any TVOP conditions, P&G is conservatively including the original non-completion of the test program on May 20, 2020 on this deviation report to be consistent with previous communications with the Ventura County Air Pollution Control District (VCAPCD).

## **Source Tests**



## ANNUAL COMPLIANCE CERTIFICATION SIGNATURE COVER FORM

A copy of each Annual Compliance Certification shall be submitted to EPA, Region 9, at the following address:

Mr. Gerardo Rios, Chief Permits Office (AIR-3) Office of Air Division EPA Region 9 75 Hawthorne Street San Francisco, CA 94105

#### Confidentiality

All information in a Part 70 permit compliance certification is public information. The Part 70 permit is also public information.

#### **Certification by Responsible Official**

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in this compliance certification are true, accurate, and complete.

Signature and Title of Responsible Official:  Title: Plant Manager	Date: 2/10/2021
--	-----------------

Time Period Covered by Compliance Certification

01/01/20 (MM/DD/YY) to 12/31/20 (MM/DD/YY)



## RESPONSIBLE OFFICIAL'S CERTIFICATION FORM

Ventura County APCD Rule 33.9 requires that "any document, including reports, schedule of compliance progress reports and compliance certifications, required by a Part 70 permit shall be certified by a responsible official." Therefore, this form shall be signed by the company's Responsible Official and submitted with all such reports, including, but not limited to semi-annual reports, deviation and emergency reports and any periodic reports required by a Part 70 permit. However, when submitting your Annual Compliance Certifications, please use the form titled Annual Compliance Certification Signature Cover Form.

Semi-annual reports, deviations and emergency reports and any periodic reports required by your Part 70 permit should be submitted to:

Ed Swede
Air Quality Engineer
Ventura County Air Pollution Control District
669 County Square Drive
Ventura, CA 93003

#### **Certification by Responsible Official**

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in this document is true, accurate, and complete.

Signature:
------------



## ANNUAL COMPLIANCE CERTIFICATION SOURCE TEST SUMMARY FORM

A. Emission Unit Description:			B. Pollutant
B-301 Boiler			NOx
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test:	F. Test Date
23.50 ppm @3% O2	40 ppm @ 3% O2	P27-076-FR B301	3/2/2020
A. Emission Unit Description:			B. Pollutant
B-301 Boiler			со
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test:	F. Test Date
793.00 ppm @ 3% O2	400 ppm @ 3% O2	P27-076-FR B301	3/2/2020
A. Emission Unit Description:			B. Pollutant
B-301 Boiler			NOx
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test:	F. Test Date
28.80 ppm @3% O2	40 ppm @ 3% O2	P27-076-FR B301	3/3/2020
A. Emission Unit Description:			B. Pollutant
B-301 Boiler			со
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test:	F. Test Date
201.00 ppm @ 3% O2	400 ppm @ 3% O2	P27-076-FR B301	3/3/2020



## ANNUAL COMPLIANCE CERTIFICATION SOURCE TEST SUMMARY FORM

A. Emission Unit Description:			B. Pollutant
LM2500 Turbine			NOx
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test:	F. Test Date
19.40 ppm @ 15% O2	24 ppm @ 15% O2	P27-077-FR COMP-C1	5/19/2020
A. Emission Unit Description:			B. Pollutant
LM2500Turbine			со
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test:	F. Test Date
33.30 lb/hour	180.13 lb/hour	P27-077-FR COMP-C1	5/19/2020
	•		
A. Emission Unit Description:			B. Pollutant
LM2500 Turbine			O2
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test:	F. Test Date
14.30 %	N/A	P27-077-FR COMP-C1	5/19/2020
A. Emission Unit Description:			B. Pollutant
LM2500 Turbine			Heat Rate
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test:	F. Test Date
243.00 MMbtu/hour	N/A	P27-077-FR COMP-C1	5/19/2020



A. Emission Unit Description:

## ANNUAL COMPLIANCE CERTIFICATION SOURCE TEST SUMMARY FORM

B. Pollutant

LM2500 Turbine			NOx
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test:	F. Test Date
19.40 ppm @ 15% O2	24 ppm @ 15% O2	P27-077-FR COMP-C1	5/19/2020
A. Emission Unit Description:			B. Pollutant
LM2500Turbine			со
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test:	F. Test Date
33.30 lb/hour	180.13 lb/hour	P27-077-FR COMP-C1	5/19/2020
A. Emission Unit Description:			B. Pollutant
LM2500 Turbine			02
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test:	F. Test Date
14.30 %	N/A	P27-077-FR COMP-C1	5/19/2020
A. Emission Unit Description:			B. Pollutant
LM2500 Turbine			Heat Rate
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test:	F. Test Date
243.00 MMbtu/hour	N/A	P27-077-FR COMP-C1	5/19/2020



## ANNUAL COMPLIANCE CERTIFICATION SOURCE TEST SUMMARY FORM

A. Emission Unit Description:			B. Pollutant
LM6000 Turbine			NOx
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test:	F. Test Date
2.25 ppm @ 15% O2	2.5 ppm @ 15% O2	P27-077-FR-COMP	3/4/2020
A. Emission Unit Description:			B. Pollutant
LM6000 Turbine			со
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test:	F. Test Date
3.74 lb/hour	10.20 lb/hour	P27-077-FR-COMP	3/4/2020
			B. Pollutant
A. Emission Unit Description:			B. Pollutant
LM6000 Turbine			02
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test:	F. Test Date
17.48 %	N/A	P27-077-FR-COMP	3/4/2020
A. Emission Unit Description:			B. Pollutant
LM6000 Turbine			Heat Rate
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test:	F. Test Date
443.00 MMbtu/hour	N/A	P27-077-FR-COMP	3/4/2020
A. Emission Unit Description:			B. Pollutant
LM6000 Turbine			NH3
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test:	F. Test Date
1.01 ppm @ 15% O2	20 ppm @ 15% O2	P27-077-FR-COMP	3/4/2020
A. Emission Unit Description:			B. Pollutant
LM6000 Turbine			ROC
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test:	F. Test Date
<0.39 ppm @ 3% O2	2.0 ppm @ 3% O2	P27-077-FR-COMP	3/4/2020



## ANNUAL COMPLIANCE CERTIFICATION SOURCE TEST SUMMARY FORM

A. Emission Unit Description:			B. Pollutant
2X Predryer (70 Mmbtu/ho			
Yankee Hot Air Furnace (40			
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test:	F. Test Date
0.0705 lb/Mmbtu	0.080 lb/Mmbtu	P27-076-FR2X	5/26/2020
A. Emission Unit Description:			B. Pollutant
2X Predryer (70 Mmbtu/ho	со		
Yankee Hot Air Furnace (40			
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test:	F. Test Date
0.0386 lb/Mmbtu	0.045 lb/Mmbtu	P27-076-FR2X	5/26/2020
A. Emission Unit Description:			B. Pollutant
2X Predryer (70 Mmbtu/ho			
Yankee Hot Air Furnace (40	02		
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test:	F. Test Date
19.71 %	N/A	P27-076-FR2X	5/26/2020

## Additional Documents in Support of Part 70 Compliance Certification for RY2020



## RESPONSIBLE OFFICIAL'S CERTIFICATION FORM

Ventura County APCD Rule 33.9 requires that "any document, including reports, schedule of compliance progress reports and compliance certifications, required by a Part 70 permit shall be certified by a responsible official." Therefore, this form shall be signed by the company's Responsible Official and submitted with all such reports, including, but not limited to semi-annual reports, deviation and emergency reports and any periodic reports required by a Part 70 permit. However, when submitting your Annual Compliance Certifications, please use the form titled Annual Compliance Certification Signature Cover Form.

Semi-annual reports, deviations and emergency reports and any periodic reports required by your Part 70 permit should be submitted to:

Ed Swede
Air Quality Engineer
Ventura County Air Pollution Control District
669 County Square Drive
Ventura, CA 93003

#### **Certification by Responsible Official**

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in this document is true, accurate, and complete.

Signature and Title of Responsible Official:  Signature:  Title:   Alant Manager	Date: 2/10/202/
--	-----------------



February 10, 2021

Keith Macias AQS, Inspector Ventura County APCD 669 County Square Drive Ventura, California 93003

Subject: Additional Documents in Support of Part 70 Compliance Certification for Report Year 2020

#### Mr. Macias:

Enclosed are additional documents in support of The Procter & Gamble Paper Products Company's Oxnard facility, Part 70 Permit No. 00015 Compliance Certification for the January 1, 2020 through December 31, 2020 reporting period. If you have any questions concerning these documents or would like supplemental information not included with this submission, please contact me at your earliest convenience.

I can be reached at 805-485-8871, X 2408 or stines.cg@pg.com should you have any questions about this certification.

Respectfully,

Cindy Stines

Site Environmental Systems Leader

Cc:

Mr. Marvelle Berry, Plant Manager; P&G Mr. Sokny Field, HS&E Leader; P&G Ms. Chris Cote, AQS; VCAPCD



February 10, 2021

Michelle Wood AQS, Inspector Ventura County APCD 669 County Square Drive Ventura, California 93003

Subject: Additional Documents in Support of Part 70 Compliance Certification for Report Year 2020

Mrs. Wood:

Enclosed are additional documents in support of The Procter & Gamble Paper Products Company's Oxnard facility, Part 70 Permit No. 00015 Compliance Certification for the January 1, 2020 through December 31, 2020 reporting period. If you have any questions concerning these documents or would like supplemental information not included with this submission, please contact me at your earliest convenience.

I can be reached at 805-485-8871, X2408 or stines.cg@pg.com should you have any questions about this certification.

Respectfully,

Cindy Stines

Site Environmental Leader

Cc:

Mr. Marvelle Berry, Plant Manager; P&G Mr. Sokny Field, HS&E Leader; P&G Ms. Chris Cote, AQS; VCAPCD

# Semi-Annual Report Permit to Operate No. 0015 Actual Annual Operating Hours for LM2500 and LM6000 Turbines

Report Period 1/1/2020 - 12/31/2020

## P&G

The P&G Paper Products Co. 800 North Rice Avenue Oxnard, CA 93030 (805) 485-8871 www.pg.com

February 10, 2021

Ed Swede AQS Inspector Ventura County APCD 669 County Square Drive Ventura, California 93003

Subject: Semi Annual Report - Permit to Operate No. 0015
Actual Annual Operating Hours for LM2500 and LM6000 Turbines
Report Period: 01/01/20–12/31/20

Mr. Swede:

This report satisfies our streamlined Semi-Annual reporting requirement for our LM6000 turbine per Attachment STRMLN15LM6000-NOx-rev291, Condition 14.a-b, and for our LM2500 turbine per Attachment STRMLN15LM2500-NOx, CO-rev351, Condition 11.a-b. This report covers actual annual operating hours for both turbines and summarizes the results from the most recent respective annual source test.

Source test results for each turbine were within the prescribed compliance limits for all tested emissions.

Additionally, per Section 10, District General Part 70 Permit Conditions, Condition 5, a Responsible Official Certification is attached to these reports.

If you have any questions, please contact me, at (805) 485-8871 x 2408 or stines.cg@pg.com

Respectfully,

Cindy Stines

cc: Mr. Marvelle Berry, P&G, Oxnard Plant Manager Mrs. Sokny Field, P&G, HSE Leader

Mr. Eric Jenkins - P&G, SEL



# RESPONSIBLE OFFICIAL'S CERTIFICATION FORM

Ventura County APCD Rule 33.9 requires that "any document, including reports, schedule of compliance progress reports and compliance certifications, required by a Part 70 permit shall be certified by a responsible official." Therefore, this form shall be signed by the company's Responsible Official and submitted with all such reports, including, but not limited to semi-annual reports, deviation and emergency reports and any periodic reports required by a Part 70 permit. However, when submitting your Annual Compliance Certifications, please use the form titled Annual Compliance Certification Signature Cover Form.

Semi-annual reports, deviations and emergency reports and any periodic reports required by your Part 70 permit should be submitted to:

Ed Swede
Air Quality Engineer
Ventura County Air Pollution Control District
669 County Square Drive
Ventura, CA 93003

#### Certification by Responsible Official

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in this document is true, accurate, and complete.

Signature and Title of Responsible Official:  Signature:  Title:     Plant Manager	Date: 2 /10/2021
--	------------------

#### REPORT #1 – LM-2500

#### Operating Hours and Source Test Results

# SUMMARY REPORT ANNUAL OPERATING HOURS AND SOURCE TEST RESULTS

Reporting Period Dates: From 01/01/20 through 12/31/20

Company: The Procter & Gamble Paper Products Company

Address:800 North Rice Avenue, Oxnard, CA 93030

Certification or Audit: May 19, 2020 (Annual Source Test)
Process Unit Description: LM-2500 Gas Turbine (Cogen I)

**Total Source Operating** 

Time in Reporting Period: 4227.6

#### SOURCE TEST SUMMARY

Pollutant	Measured Emissions	Permit Limit
Oxides of Nitrogen, ppmvd @15% O <sub>2</sub>	19.4	24
Carbon Monoxide, lb/hr	33.3	180.13

#### REPORT #2 - LM-6000

#### Operating Hours and Source Test Results

# SUMMARY REPORT ANNUAL OPERATING HOURS AND SOURCE TEST RESULTS

Reporting Period Dates: From 01/01/20 through 12/31/20

Company: The Procter & Gamble Paper Products Company

Address:800 North Rice Avenue, Oxnard, CA 93030

Certification or Audit: March 4, 2020 (Annual Source Test)

Process Unit Description: LM-6000 Gas Turbine (Cogen II)

**Total Source Operating** 

Time in Reporting Period: 4057.68

#### SOURCE TEST SUMMARY

Pollutant	Measured Emissions	Permit Limit
Oxides of Nitrogen, ppmvd @15% O <sub>2</sub>	2,25	2.5
Carbon Monoxide, lb/hr (expressed as CH4)	3.74	10.2
Reactive Organic Compounds, ppmvd @15%	< 0.39	2.0
Ammonia, ppmvd @ 15% O <sub>2</sub>	1.01	20



# RESPONSIBLE OFFICIAL'S CERTIFICATION FORM

Ventura County APCD Rule 33.9 requires that "any document, including reports, schedule of compliance progress reports and compliance certifications, required by a Part 70 permit shall be certified by a responsible official." Therefore, this form shall be signed by the company's Responsible Official and submitted with all such reports, including, but not limited to semi-annual reports, deviation and emergency reports and any periodic reports required by a Part 70 permit. However, when submitting your Annual Compliance Certifications, please use the form titled Annual Compliance Certification Signature Cover Form.

Semi-annual reports, deviations and emergency reports and any periodic reports required by your Part 70 permit should be submitted to:

Ed Swede
Air Quality Engineer
Ventura County Air Pollution Control District
669 County Square Drive
Ventura, CA 93003

#### **Certification by Responsible Official**

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in this document is true, accurate, and complete.

Signature and Title of Responsible Official:  Signature:  Title: Plant Manager	Date: 2/10/2021
--	-----------------

Semi-Annual Scrubber Report Permit to Operate No. 0015 Excursion Report for 1X, and 2X Paper Machine Dry End Scrubbers

Report Period 7/1/2020 - 12/31/2020



February 10, 2021

Mr. Ed Swede AQS, Inspector Ventura County APCD 669 County Square Drive Ventura, California 93003

Subject: Semi Annual Report - Permit to Operate No. 0015

Excursion Report for 1X, and 2X Paper Machine Dry End Scrubbers

Report Period: 7/1/20 – 12/31/20

Mr. Swede,

Pursuant to Section 7, Attachment PO00015PC5, Condition 3.e this report satisfies our semi-annual reporting requirement to report excursions for our 1X and 2X Dry End scrubbers.

Additionally, per Section 10, District General Part 70 Permit Conditions, Condition 5, a Responsible Official Certification is attached to these reports.

I can be reached at 805-485-8871 X 2408 or stines.cg@pg.com should you have any questions about this certification.

Respectfully

Cindy Stines

Site Environmental System Leader

Cc:

Mr. Marvelle Berry, Plant Manager; P&G Mr. Sokny Field, HS&E Leader; P&G

Ms. Chris Cote, AQS; VCAPCD



# RESPONSIBLE OFFICIAL'S CERTIFICATION FORM

Ventura County APCD Rule 33.9 requires that "any document, including reports, schedule of compliance progress reports and compliance certifications, required by a Part 70 permit shall be certified by a responsible official." Therefore, this form shall be signed by the company's Responsible Official and submitted with all such reports, including, but not limited to semi-annual reports, deviation and emergency reports and any periodic reports required by a Part 70 permit. However, when submitting your Annual Compliance Certifications, please use the form titled Annual Compliance Certification Signature Cover Form.

Semi-annual reports, deviations and emergency reports and any periodic reports required by your Part 70 permit should be submitted to:

Ed Swede
Air Quality Engineer
Ventura County Air Pollution Control District
669 County Square Drive
Ventura, CA 93003

#### Certification by Responsible Official

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in this document is true, accurate, and complete.

Signature and Title of Responsible Official:  Signature:  Title:  And Mangger	Date: 2/10/2021
---	-----------------

Part 70 - Semi Annual Scrubber Excursion Report

Facility:

The Procter & Gamble Paper Products Company - Oxnard, CA

Permit No.:

00015

Report Period:

July 1, 2020 – December 31, 2020

Subject Units:

2 Dry End Scrubbers: 1X Paper Machine and 2X Paper Machine

Total Number of Excursions:	0
Total Duration of Excursions:	0 hours

#### Excursion Details -

Date	Duration	Cause	Corrective Action
None			

The report above satisfies requirements identified in our facility Part 70 Permit, Attachment PO00015PC5, Condition 3.e.

### EMERGENCY DIESEL ENGINE 2020 ANNUAL REPORT FORM

Reporting Period: January 1 through December 31, 2020

Due Date: See Notice to Supply Information (NTSI) Issued During Inspection

Your APCD Permit to Operate requires your facility to submit reports of the annual hours of operation and/or maintenance and testing, and emergency use for each diesel emergency engine. If the annual operating hours, excluding emergency operation, exceed the specified annual permit limit, please include an explanation. Please Note: California Health and Safety Code 42304 requires the holder of an APCD Permit to Operate to furnish the information requested by the APCD within a reasonable time or the APCD may suspend the Permit to Operate.

PERMIT NUMBER: 00015					
Facility Name:	Procter & Gamble Paper Products Contact:			Cindy Stines	
Facility Address:	800 North Rice Avenue		Title:	Environmental Systems Leader	
Facility City:	Oxnard		Phone:	805-484-8871 X 2408	
	ENGINE	DETAILS	 }		
Engine Description	Engine BHp Rating: 210 BHp Engine Description (Manufacturer, Model, Serial Number, etc.):				
Clarke Detroit D Serial No. PE60 fire suppression	Diesel Allison, Inc. Diesel-Fir 168T157094, ID: Warehouse I.	ed Emerge Pump #2,	ency Engine PG-2, (PG	e, Model JU6HUF50, -5) used for	
RI	EPORTING REQUIREMENT	S FOR CA	LENDAR	YEAR 2020	
	Date of Reading			Meter Reading	
First of 2020:	1/2/2020	F	irst of 2020:	414	
End of 2020:	1/2/2021	E	nd of 2020:	437.7	
	Total annual hours for:	Maintenance	e & Testing:	23.7	
	F	lours of Eme	rgency use:	0	
	Total Hours of operation: 23.7				
Has the engine listed above exceeded the permit limit for maintenance and testing? NO If yes, please explain here or attach additional pages:					
Signature of pers	on supplying the information: "I	certify that ti	he above info	ormation is correct."	
Signature: Date: 2/10/21			1/21		
Print Name: Ma	rvelle Berry	Titl	le: Plant M	lanager	
Phone #: 805-48	35-8871	Em	nail: Berry.n	n@pg.com	
SEND REPORT TO: Inspector Name:  Ventura County Air Pollution Control District 669 County Square Drive, Second Floor Ventura, CA 93003 or FAX: 805/645-1444  For questions contact: Eric Wetherbee at (805) 645-1496, or erlc@vcapcd.org  Entered in Engine Database			rbee at (805) 645-1496, or rlc@vcapcd.org		

## EMERGENCY DIESEL ENGINE 2020 ANNUAL REPORT FORM

Reporting Period: January 1 through December 31, 2020

Due Date: See Notice to Supply Information (NTSI) Issued During Inspection

Your APCD Permit to Operate requires your facility to submit reports of the annual hours of operation and/or maintenance and testing, and emergency use for each diesel emergency engine. If the annual operating hours, excluding emergency operation, exceed the specified annual permit limit, please include an explanation. Please Note: California Health and Safety Code 42304 requires the holder of an APCD Permit to Operate to furnish the information requested by the APCD within a reasonable time or the APCD may suspend the Permit to Operate.

PERMIT NUMBER: 00015				
Facility Name:	Procter & Gamble Paper Products Contact:			Cindy Stines
Facility Address:	800 North Rice Avenue		Title:	Environmental Systems Leader
Facility City:	Oxnard		Phone:	805-484-8871 X 2408
	ENGINI	E DETAILS	3	
Engine BHp Rating: 420 BHp Engine Description (Manufacturer, Model, Serial Number, etc.): Caterpillar Diesel-Fired Emergency Standby Engine, Model 3406, Serial No. 6TB10913, ID: Utility Yard Pump PG-3), used for fire suppression.				
R	EPORTING REQUIREMENT	TS FOR CA	ALENDAR	YEAR 2020
	Date of Reading			Meter Reading
First of 2020:	1/2/2020	F	irst of 2020	815.5
End of 2020;	1/2/2021	E	End of 2020:	835.1
	Total annual hours for:	Maintenanc	e & Testing:	20
	Hours of Emergency use: 0.3			
Total Hours of operation: 19.7				19.7
Has the engine listed above exceeded the permit limit for maintenance and testing? NO If yes, please explain here or attach additional pages:				
Signature of pers	on supplying the information: "	I certify that t	he above info	ormation is correct."
Signature: Date: 2/10/21			10/21	
Print Name: Marvelle Berry Title: Plant			le: Plant N	lanager
Phone #: 805-48	85-8871	En	nail: Berry.r	m@pg.com
SEND REPORT TO: Inspector Name:  Ventura County Air Pollution Control District 669 County Square Drive, Second Floor Ventura, CA 93003 or FAX: 805/645-1444				ontact: rbee at (805) 645-1496, or orlc@vcapcd.org red in Engine Database

#### **EMERGENCY DIESEL ENGINE** 2020 ANNUAL REPORT FORM

Reporting Period: January 1 through December 31, 2020

Due Date: See Notice to Supply Information (NTSI) Issued During Inspection

Your APCD Permit to Operate requires your facility to submit reports of the annual hours of operation and/or maintenance and testing, and emergency use for each diesel emergency engine. If the annual operating hours, excluding emergency operation, exceed the specified annual permit limit, please include an explanation. Please Note: California Health and Safety Code 42304 requires the holder of an APCD Permit to Operate to furnish the information requested by the APCD within a reasonable time or the APCD may suspend the Permit to Operate.

	dopona tilo i omitto opolitico				
PERMIT NUMBER: 00015					
Facility Name:	Procter & Gamble Paper Products Contact:			Cindy Stines	
Facility Address:	800 North Rice Avenue		Title:	Environmental Systems Leader	
Facility City:	Oxnard		Phone:	805-484-8871 X 2408	
	ENGINE	DETAILS	<b>)</b>		
Engine Description	Engine BHp Rating: 210 BHp Engine Description (Manufacturer, Model, Serial Number, etc.):				
Clarke Detroit D Serial No. PE60 fire suppression	Diesel Allison, Inc.  Diesel-Fir 168T185639, ID: Warehouse 1.	ed Emerge Pump #1,	ency Engine (PG-4), us	e, Model JU6HUF50, ed for	
RI	EPORTING REQUIREMENT	S FOR CA	LENDAR	YEAR 2020	
	Date of Reading			Meter Reading	
First of 2020:	1/2/2020	F	irst of 2020:	411.6	
End of 2020:	1/2/2021	E	nd of 2020:	436.3	
	Total annual hours for: Maintenance & Testing: 24.7				
	Hours of Emergency use: 0				
	Total Hours of operation: 24.7				
Has the engine listed above exceeded the permit limit for maintenance and testing? NO If yes, please explain here or attach additional pages:					
Signature of pers	on supplying the information: "/	certify that ti	ne above info	ormation is correct."	
Signature: \( \int \lambda \la			10/20		
Print Name: Ma	rvelle Berry	Titl	e: Plant M	lanager	
Phone #: 805-48	35-8871	Em	nail: Berry.n	n@pg.com	
SEND REPORT TO: Inspector Name: Ventura County Air Pollution Control District 669 County Square Drive, Second Floor Ventura, CA 93003 or FAX: 805/645-1444  For questions contact: Eric Wetherbee at (805) 645-1496, or eric@vcapcd.org Lentered in Engine Database			rbee at (805) 645-1496, or <u>ric@vcapcd.org</u>		

## EMERGENCY DIESEL ENGINE 2020 ANNUAL REPORT FORM

Reporting Period: January 1 through December 31, 2020

Due Date: See Notice to Supply Information (NTSI) Issued During Inspection

Your APCD Permit to Operate requires your facility to submit reports of the annual hours of operation and/or maintenance and testing, and emergency use for each diesel emergency engine. If the annual operating hours, excluding emergency operation, exceed the specified annual permit limit, please include an explanation. <u>Please Note:</u> California Health and Safety Code 42304 requires the holder of an APCD Permit to Operate to furnish the information requested by the APCD within a reasonable time or the APCD may suspend the Permit to Operate.

PERMIT NUME	PERMIT NUMBER: 00015				
Facility Name:	Procter & Gamble Paper Products Contact:			Cindy Stines	
Facility Address:	800 North Rice Avenue		Title:	Environmental Systems Leader	
Facility City:	Oxnard		Phone:	805-484-8871 X 2408	
	ENGINE	DETAILS			
Engine BHp Rating Engine Description	g: 210 BHp n (Manufacturer, Model, Serial Nur	mber, etc.):			
Clarke Detroit D Serial No. PE60 fire suppression	Diesel Allison, Inc. Diesel-Fir 168T157094, ID: Warehouse 1.	ed Emerge Pump #2,	ency Engino PG-2, (PG	e, Model JU6HUF50, i-5) used for	
R	EPORTING REQUIREMENT	S FOR CA	LENDAR	YEAR 2020	
	Date of Reading			Meter Reading	
First of 2020:	1/2/2020	F	irst of 2020:	414	
End of 2020:	1/2/2021	Ε	ind of 2020:	437.7	
Total annual hours for: Maintenance & Testing:				23.7	
	ŀ	lours of Eme	rgency use:	0	
Total Hours of operation: 23.7			23.7		
Has the engine listed above exceeded the permit limit for maintenance and testing? NO If yes, please explain here or attach additional pages:					
Signature of pers	on supplying the information: "	certify that th	he above info	ormation is correct."	
Signature: Date:			te: $2/$	10/21	
Print Name: Marvelle Berry			Title: Plant Manager		
Phone #: 805-48	35-8871	Em	nail: Berry.r	n@pg.com	
SEND REPORT TO: Inspector Name: Ventura County Air Pollution Control District 669 County Square Drive, Second Floor Ventura, CA 93003 or FAX: 805/645-1444			<u>_</u>	ontact: rbee at (805) 645-1496, or ric@vcapcd.org red in Engine Database	

	ž.				Opacity Annual Form	al Survey
				WCAPCE Part 70 Parmit	Procter & Gamble Oxr Attachment 50 Compliance Do	
			Condusted F		Actachment 30 Compliance Of	Time. 13:10 0 0
			Conducted C	on Date 8/20/20 V ZRIC Jan Pris		Signature Excit Call
			CONDUCTES D	LICIE WILL IDS	V sible Emissions Certification	
	sion Points				Mark Bassat Cartification	#
awing - PC	3-3419820				Most Recent Certificatio Dat	
	1			·	T	
						Visible Emissions other than Uncombined Water
Stack	Stack Hight (ft)	Stack D/a (sq ft)	Emissions Unit	Emission Description	Stack Position	N - if there are no visible emissions for 2 3minutes Y- if there are visible emissions > 20% or No 1 Ringelmann for 2 3minutes
S-1	62	2 10	Washer Wet Lapper	PM	When Fan motor on	N
5-2	8.4	12.67	Cogen 2/LM6000 Turbine	Thermal Output with NOx, CO, SOx_PM_ ROC_NH3	Damper closed when 2X is running	7
5-3	27	4 40	B-301 Steam Boiler	Thermal Output with NOx, CO, SOx PM, ROC	FGR closed during SU (1hr) only - 100% Exhaust - otherwise partial exhaust	7
Stack 5-4	is not a phys	ical stack b	out represents the totals stack	is from 1X process stacks 4A-4E		
1,0110,011			I	Thermal Output with NOx, CO, SOx, PM,		
S-4A	56	4 72	1X PreDryer	ROC HAF +Burners OR Cogen + Burners	Open when 1x running	N
S 4B		*2	Furnace Cooling	Hot Air Release from shell cooling	fipen	7
5-40			ens.	Thermal Output, NOx, CO, SOx FM, BOC	Normally Closed	N
5-40	90	9.63	Cogen 1/LM2500 Turbine	Therma Output, NOx, CO, SOx, PM, ROC	Demper closed when 1X running	N
5.4E			W/WL Broke Pulper vent	PM	Open vent	И
5.5			1X Scrubber	PM	When Fan motor on	N
5-6	· *	160	2X Scrubber	PM	When Fan motor on	N
Stack S-7	is not physic	al stack but	represents the totals stacks	from 2X NOTE - PreDryer Exhaust is the em	ission from the YHAF (after d	rying)
			2X PreDryer Exhaust (YHAF Stack)	Thermal Output with NOx, CO, SOx, PM, ROC, NH3  LM6000 + MAF +PD	Normally Open	
S-7A	7.5	12.22	Exhaust Objection			N
S-78		7.0	Exhaust Divertion (PDF Stack)	Thermal Output with NOx, CO, SOx, PM, ROC, NH3	Normally Closed	N
\$-7C		7.57	2X Vacuum Stack		Open Vent	N.
5-70		(24)	2X Wet End (Former)	PM	Open Vent	N
5-7E	•		2X Broke Pulper Vent	PM	Open Vent	2
2			Fire Pump #2	CARB Fuel Combustion	Openvent	.2
3			Fire Pump #3	CARB Fuel Combustion	Openvent	N
4			Fire Pump #4	CARB Fuel Combustion	Open vent	2
5			Fire Pump #5	CARB Fuel Combustion	Open vent	N
	J.			· · · · · · · · · · · · · · · · · · ·		Will Calm Close Ste.

#### Permit Emission Points Drawing - PG-3419820

	Stack Hight	Stack Dia				
	(ft)	(sq ft)	I	Emission Description		
Stack	1		Emissions Unit		Stack Position	Calculation
5-1	52	2 10	Waiher Wet Lapper	PM	When Fan motor on	Permit · Fixed Operating Parameters
				Thermal Output with NOx CO 50x, PM	Damper closed when 2X is	
2.2	24	12.67	Coden 2/LM6000 Turbing	ROC, NH3	funning	CEMS
	-			T. 10 - 1 - 1 10 - 60 to 114	FGR closed during SU (1hr)	
	1		I	Thermal Output with NOx, CO SOx, PM	only - 10 1% Exhaust -	
5.3	27	4.46	5-301 Steam Soiler	ROC	otherwise partial exhaust	Permit - Emission Factor for 8-301
tack 5-4	is not a ohy	sical stack h	ut represents the totals stack	s from 18 process stacks 4A-4E		
254.544.	1		I	There ar Output with NOx CO SOx PM,		
	1 8		l .	ROC		CEMS
	F 0			HAF +Burners	Open when 1X running	
5 44	56	4.72	1X PreDryer	OR Cogen + Burners		Parmit Emission Factors for HAF, Burners, and C150x PM, ROC
5-49			Furnace Cooling	Hot Air Release from shell cooling	Open	Inclusive of C1 Emissions
5 45			HRB	Therma Output NOx CO, SOx, PM, ROC	Normally Closed	Inclusive of C1 Emissions
- 33						CEMS for NOx CO
				Therma Output, NOs, CO, SOx, PM, ROC	Damper closed when IX	
\$-4D	50	963	Cagen 1/LM2500 Turbine	THE THE BUTPER, NOV. CO. 30X 7 MI NOC	running	Permit Emission factors SOx, PM, ROC
5 4E	30		W/W: Broke Fulper vent	PM	Open vent	Calculation included in Turbine and Furnace emission factors for PN
3 46			AAVAY BLOKE Laibet Asur	PW	OBERVENI	Calculation included in Foliatile and Farrace evil short according to
	1		*** ** * * * * * * * * * * * * * * * *	DM.	MIL F	Permit - Fixed Operating Parameters
5-5			1X Scrubber	PM	When Fan motor on	Permit - Fixed Operating Parameters
5-6	-		2X Scrubber	PM	When Fan motor on	Permit - rixed Operating Parameters
-						
lack S-7	is not physic	al stack but	represents the totals stacks	from 2X NOTE - PreDryer Exhaust is the em	ission from the THAF latter o	ryingi
				Thermal Output with NOx, CO 50x, PM		
			2X PreOryer Exhault	ROC, NH3	Normally Open	
			2X PreOryer Exhau (t (YHAF Stack)		Normally Open	
5-7A	74	12.22	(YHAF Stack)	FW6000 + HAF +bD	Normally Open	(PD + HAF) X Emission Factor + Cozen 2 Emissions
	74	12-22	(YHAF Stack)	EM6000 + HAF +PD Thermal Dutput with NOx CO SO = PM		Y 72 -
S 7B	74	12.22	(YHAF Stack)  Exhaust Divertion (PDF Stack)	EM6000 + MAF -PD The mail Cutput with NO 4 CO SO 4 PM ROC, NH3	Normally Closed	Inclusive of 2X emissions
5 7B 5-7C	74		(YMAF Stack)  Exhaust Divertion (PDF Stack)  ZX Vacuum Stack	EM6000 - HAF -PD  The ordal Output with NO & CO SO E PM ROC, NH3 PM	Normally Closed Open Vent	Inclusive of 2X emissions Calculation included in Turbine and Furnace emission factors for PA
S 7B S-7C S-7D		_ 2	(YMAF Stack)  Exhaust Divertion (PDF Stack)  ZX Vacuum Statk  ZX Wet End (Former)	EM6000 + HAF +PD  Theorial Dutout with NOx CO SO EPM ROC, NH3 PM PM	Normally Closed Open Vent Open Vent	Inclusive of 2X emissions Calculation included in Turbine and Furnace emission factors for PA Calculation included in Turbine and Furnace emission factors for PA
5 7B S-7C		- 12 14	(YMAF Stack)  Exhaust Divertion (PDF Stack)  ZX Vacuum Stack	EM6000 - HAF -PD  The ordal Output with NO & CO SO E PM ROC, NH3 PM	Normally Closed Open Vent	Inclusive of 2X emissions Calculation included in Turbine and Furnace emission factors for PA
S 7B S-7C S-7D		- 13 - 14 - 12	(YMAF Stack)  Exhaust Divertion (PDF Stack)  ZX Vacuum Statk  ZX Wet End (Former)	EM6000 + HAF +PD  Theorial Dutout with NOx CO SO EPM ROC, NH3 PM PM	Normally Closed Open Vent Open Vent	Inclusive of 2X emissions Calculation included in Turbine and Furnace emission factors for PA Calculation included in Turbine and Furnace emission factors for PA
5 7B 5-7C 5-7D		- 13 - 14 - 12	(YMAF Stack)  Exhaust Divertion (PDF Stack)  ZX Vacuum Statk  ZX Wet End (Former)	EM6000 + HAF +PD  Theorial Dutout with NOx CO SO EPM ROC, NH3 PM PM	Normally Closed Open Vent Open Vent	Inclusive of 2X emissions Calculation included in Turbine and Furnace emission factors for PA Calculation included in Turbine and Furnace emission factors for PA
5 7B 5-7C 5-7D 5-7E		- 13 - 14 - 12	(YMAF Stack)  Exhaust Divertion (PDF Stack)  ZX Vacuum Statk  ZX Wet End (Former)	EM6000 + HAF +PD  Theorial Dutout with NOx CO SO EPM ROC, NH3 PM PM	Normally Closed Open Vent Open Vent	Inclusive of 2X emissions Calculation included in Turbine and Furnace emission factors for PA Calculation included in Turbine and Furnace emission factors for PA
S 78 S-7C S-7D S-7E		- 13 - 14 - 12	(YMAF Stack)  Exhaust Divertion (PDF Stack)  ZX Vacuum Statk  ZX Wet End (Former)	EM6000 + HAF +PD  Theorial Dutout with NOx CO SO EPM ROC, NH3 PM PM	Normally Closed Open Vent Open Vent	Inclusive of 2X emissions Calculation included in Turbine and Furnace emission factors for PA Calculation included in Turbine and Furnace emission factors for PA
S 7B S-7C S-7D S-7E		- 13 - 14 - 12	[YMAF Stack]  Exhaust Divertion (PDF Stack)  2X Vacuum Stack  2X Vet End (Former)  2X Broke Pulper Vent  Fire Pump #2	EM6000 + HAF -PD  The intal Dutout with NOx CO SOx PM ROC, NH3 PM PM PM PM PM	Normally Closed Open Vent Open Vent Open Vent	Inclusive of 2X emissions Calculation included in Turbine and Furnace emission factors for PA Calculation included in Turbine and Furnace emission factors for PA Calculation included in Turbine and Furnace emission factors for PA
S 7B S-7C S-7D S-7E		- 13 - 14 - 12	(YMAF Stack)  Exhaust Divertion (PDF Stack)  2X Vacuum Stack  2X Wet End (Former)  2X Broke Pulper Vent  Fire Pump #2  Fire Pump #3	EM6000 - HAF - PD  The intal Cutput with NOx CO SOx PM ROC, NH3 PM PM PM PM CARB Fuel Combustion CARB Fuel Combustion	Normally Closed Open Vent Open Vent Open Vent Open Vent	Inclusive of 2X emissions  Calculation included in Turbine and Furnace emission factors for PA  Calculation included in Turbine and Furnace emission factors for PA  Calculation included in Turbine and Furnace emission factors for PA  Report allocated fuel usage
S 78 S-7C S-7D S-7E		- 13 - 14 - 12	(YMAF Stack)  Exhaust Divertion (PDF Stack)  2X Vacuum Stack  2X Wet End (Former)  2X Broke Pulper Vent  Fire Pump #2  Fire Pump #3  Fire Pump #4	EM6000 - HAF - PD  The intel Cutout with NO & CO SO E PM ROC, NH3 PM PM PM PM CARB Fuel Combustion CARB Fuel Combustion CARB Fuel Combustion	Normally Closed Open Vent	Inclusive of 2X emissions Calculation included in Turbine and Furnace emission factors for PAV Calculation included in Turbine and Furnace emission factors for PAV Calculation included in Turbine and Furnace emission factors for PAV Report allocated fuel usage Report allocated fuel usage Report allocated fuel usage
S 7B S-7C S-7D S-7E		- 13 - 14 - 12	(YMAF Stack)  Exhaust Divertion (PDF Stack)  2X Vacuum Stack  2X Wet End (Former)  2X Broke Pulper Vent  Fire Pump #2  Fire Pump #3	EM6000 - HAF - PD  The intal Cutput with NOx CO SOx PM ROC, NH3 PM PM PM PM CARB Fuel Combustion CARB Fuel Combustion	Normally Closed Open Vent Open Vent Open Vent Open Vent Open vent Open vent	Inclusive of 2X emissions  Calculation included in Turbine and Furnace emission factors for PA  Calculation included in Turbine and Furnace emission factors for PA  Calculation included in Turbine and Furnace emission factors for PA  Report allocated fuel usage  Report a located fuel usage
5 7B 5-7C 5-7D 5-7E		- 13 - 14 - 12	(YMAF Stack)  Exhaust Divertion (PDF Stack)  2X Vacuum Stack  2X Wet End (Former)  2X Broke Pulper Vent  Fire Pump #2  Fire Pump #3  Fire Pump #4	EM6000 - HAF - PD  The intel Cutout with NO & CO SO E PM ROC, NH3 PM PM PM PM CARB Fuel Combustion CARB Fuel Combustion CARB Fuel Combustion	Normally Closed Open Vent	Inclusive of 2X emissions Calculation included in Turbine and Furnace emission factors for PAV Calculation included in Turbine and Furnace emission factors for PAV Calculation included in Turbine and Furnace emission factors for PAV Report allocated fuel usage Report allocated fuel usage Report allocated fuel usage
S 78 S-7C S-7D S-7E	ps.	- 13 - 14 - 12	(YMAF Stack)  Exhaust Divertion (PDF Stack)  2X Vacuum Stack  2X Wet End (Former)  2X Broke Pulper Vent  Fire Pump #2  Fire Pump #3  Fire Pump #4	EM6000 - HAF - PD  The intel Cutout with NO & CO SO E PM ROC, NH3 PM PM PM PM CARB Fuel Combustion CARB Fuel Combustion CARB Fuel Combustion	Normally Closed Open Vent	Inclusive of 2X emissions Calculation included in Turbine and Furnace emission factors for PAV Calculation included in Turbine and Furnace emission factors for PAV Calculation included in Turbine and Furnace emission factors for PAV Report allocated fuel usage Report allocated fuel usage Report allocated fuel usage
S 78 S-7C S-7D S-7E	ps.	- 13 - 14 - 12	(YMAF Stack)  Exhaust Divertion (PDF Stack)  2X Vacuum Stack  2X Wet End (Former)  2X Broke Pulper Vent  Fire Pump #2  Fire Pump #3  Fire Pump #4  Fire Pump #5	EM6000 - HAF - PD  The intel Cutout with NO & CO SO E PM ROC, NH3 PM PM PM PM CARB Fuel Combustion CARB Fuel Combustion CARB Fuel Combustion	Normally Closed Open Vent	Inclusive of 2X emissions Calculation included in Turbine and Furnace emission factors for PA Calculation included in Turbine and Furnace emission factors for PA Calculation included in Turbine and Furnace emission factors for PA Report allocated fuel usage
5 78 5-7C 5-7D 5-7E	ps.	- 13 - 14 - 12	[YMAF Stack]  Exhaust Divertion (PDF Stack)  2X Vacuum Stack  2X Wet End (Former)  2X Broke Pulper Vent  Fire Pump #2  Fire Pump #3  Fire Pump #4  Fire Pump #5	EM6000 - HAF - PD  The intel Cutout with NO & CO SO E PM ROC, NH3 PM PM PM PM CARB Fuel Combustion CARB Fuel Combustion CARB Fuel Combustion	Normally Closed Open Vent	Inclusive of 2X emissions Calculation included in Turbine and Furnace emission factors for PA Calculation included in Turbine and Furnace emission factors for PA Calculation included in Turbine and Furnace emission factors for PA Calculation included in Turbine and Furnace emission factors for PA Report allocated fuel usage
5 78 5-7C 5-7D 5-7E	ps.	- 13 - 14 - 12	[YHAF Stack]  Exhaust Divertion (PDF Stack)  2X Vacuum Stack  2X Wet End (Fermer)  2X Broke Pulper Vent  Fire Pump #2  Fire Pump #3  Fire Pump #4  Fire Pump #5  Parts Cleaner - Pmking  Parts Cleaner - Cytg	EM6000 - HAF - PD  The intel Cutout with NO & CO SO E PM ROC, NH3 PM PM PM PM CARB Fuel Combustion CARB Fuel Combustion CARB Fuel Combustion	Normally Closed Open Vent	Inclusive of 2X emissions  Calculation included in Turbine and Furnace emission factors for PA  Calculation included in Turbine and Furnace emission factors for PA  Calculation included in Turbine and Furnace emission factors for PA  Report allocated fuel usage  Insignificant Activity  Insignificant Activity
5 78 5-7C 5-7D 5-7E	ps.	- 13 - 14 - 12	(YMAF Stack)  Exhaust Divertion (PDF Stack)  2X Vacuum Stack  2X Wei End (Former)  2X Broke Pulper Vent  Fire Pump #2  Fire Pump #3  Fire Pump #4  Fire Pump #5  Parts Cleaner - Pmiking  Parts Cleaner - Cvtg  Parts Cleaner - Truck Shop	EM6000 - HAF - PD  The intel Cutout with NO & CO SO E PM ROC, NH3 PM PM PM PM CARB Fuel Combustion CARB Fuel Combustion CARB Fuel Combustion	Normally Closed Open Vent	Inclusive of 2X emissions  Calculation included in Turbine and Furnace emission factors for PAV  Calculation included in Turbine and Furnace emission factors for PAV  Calculation included in Turbine and Furnace emission factors for PAV  Report allocated fuel usage  Insignificant Activity  Insignificant Activity  Insignificant Activity
5 7B 5-7C 5-7D	ps.	- 13 - 14 - 12	[YHAF Stack]  Exhaust Divertion (PDF Stack)  2X Vacuum Stack  2X Wet End (Fermer)  2X Broke Pulper Vent  Fire Pump #2  Fire Pump #3  Fire Pump #4  Fire Pump #5  Parts Cleaner - Pmking  Parts Cleaner - Cytg	EM6000 - HAF - PD  The intel Cutout with NO & CO SO E PM ROC, NH3 PM PM PM PM CARB Fuel Combustion CARB Fuel Combustion CARB Fuel Combustion	Normally Closed Open Vent	Inclusive of 2X emissions  Calculation included in Turbine and Furnace emission factors for PA  Calculation included in Turbine and Furnace emission factors for PA  Calculation included in Turbine and Furnace emission factors for PA  Report allocated fuel usage  Insignificant Activity  Insignificant Activity

# PO00015, Attachment 103N; Capacity Factor: Babcock & Wilcox Boiler

	B301	
Fuel		de
Usage	(MINISCF)	
Jan-20	8.15	
Feb-20	11.17	
Mar-20	11.98	
Apr-20	4.60	
May-20	7.38	
Jun-20	4.61	
Jul-20	3.51	
Aug-20	1.40	
Sep-20	4.21	
Oct-20	2.13	
Nov-20	2.77	Maxim
Dec-20	3.90	
12 Month Total	65.81	

# Annual Heat Input (AHI):

Higher Heating Value 1,050 BTU/scf

1,050 MMBTU/MMSCF

Fuel Used in 12 Months (MIMscf) \* Higher Heating Value (MMBTU/MMscf) AHI

65.81 \* 1050 T 69,101 MMSTU Ц 1

# Maximum Potential Heat Input (MPHI)

100 MMBTU/hr :Rated Firing Capacity (RFC)

ity Factor Ratio of Annual Actual Heat Imput

Capacity Factor (CF)

to Maximum Potential Heat Input

num Potential Operating Hours

8,784 hrs (MPOH): MPHI = RFC - MPOH

MPHI = 878,400 MMBTU

:of MPHI (Maximum Allowable) 30% 263,520 MIMBTU Maximum Allowable Rolling 12 month Fuel Usage 250.97 MIMSCF

CF = AHI / MPHI

CF = 0.07867 Ratio

%GF 7.9% (%CF)

PO00015, Attachment 103N; Capacity Factor: Babcock & Wilcox Boiler

Fuel         :High           Usage         (MMSCF)           Jan-20         8.15           Feb-20         11.17	:Higher Heating Value 1,050 BTU/scf		
~		U/scf	
	1,050 MI	1,050 MMBTU/MMSCF	
HIM!			
	AHI = Fuel Used in	12 Months (MMscf) *	Fuel Used in 12 Months (MMscf) * Higher Heating Value (MMBTU/MMscf)
Mar-20 11.98			
Apr-20 4.60	AH! = 65.81 • 1050		
May-20 7.38			
Jun-20 4.61	AHI = 69,101 MI	MMBTU	
Jul-20 3.51			
Aug-20 1.40 M	Maximum Potential Heat Input (MPHI)	: (MPHI)	Capacity Factor (CF)
Sep-20 4.21			
2.13	Rated Firing Capacity (RFC)	100 MMBTU/hr	ity Factor Rabo of Annual actual Heat Input
Nov-20 2.77 Maximum	Maximum Potential Operating Hours		to Maximum Potential Beat wout
Dec-20 3:90	(MPOH):	8,784 hrs	
12 Month Total 65.81			
	MPHI = RF	MPHI = RFC = MPOH	CF = AHI / MPHI
	MPHI= 87	MPHI = 878,400 MMBTU	CF = 0.07867 Ratio
IMPMI to:	of MPHI (Maximum Allowable) 30% 263,520 MMBTU	53,520 MMBTU	% CF = 7.9% (%CF)

#### PO00015PC1.1 RY 2020 Monthly Throughput

	PMKG	CVTG	Total Facility		C	ombustic	n Emissi	ons	
Month	ROC	ROC	ROC	ROC	NOx	PM	SOx	CO	NH3
	(tons)	(tons)	(tons)	(tons)	(tons)	(tons)	(tons)	(tons)	(tons)
Jan-20	2.20	0.33	3.75	1.22	9.07	1.51	0.15	11.94	0.32
Feb-20	2.22	0.46	3.69	1.01	9.33	1.26	0.13	14.02	0.31
Mar-20	2.28	0.39	3.59	0.92	9.65	1.15	0.12	10.97	0.31
Арг-20	2.22	0.52	3.81	1.07	7.93	1.33	0.14	9.66	0.31
May-20	2.15	0.38	3.53	1.00	8.50	1.24	0.12	9.96	0.38
Jun-20	2.18	0.56	3.92	1.18	8.78	1.47	0.14	13.02	0.38
Jul-20	2.20	0.45	3.89	1.23	10.27	1.54	0.15	11.03	0.35
Aug-20	2.34	0.23	3.82	1.25	9.03	1.54	0.15	9.96	0.29
Sep-20	2.29	0.34	3.80	1.18	8.67	1.45	0.14	9.36	0.28
Oct-20	2.14	0.34	3.71	1.22	8.97	1.51	0.14	11.98	0.39
Nov-20	2.17	0.23	3.55	1.15	8.47	1.44	0.13	12.02	0.60
Dec-20	2.37	0.23	3.82	1.22	9.08	1.53	0.14	18.28	0.50
				Current Actu	ual in Tons ver	sus Permit	Limit		
12 Mo Tons	26.77	4.46	44.88	13.65	107.75	16.96	1.66	142.18	4.43
				ROC	NOx	PM	SOx	со	NH3
			Permit Limits ->	16.82	132.88	68.3	2.03	284.93	54.19



201.00 ppm @ 3% O2

#### **ANNUAL COMPLIANCE CERTIFICATION SOURCE TEST SUMMARY FORM**

Period Covered by Compliance Certification: January 1, 2020- December 31, 2020

A. Emission Unit Description:			B. Pollutant
B-301 Boiler			NOx
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test:	F. Test Date
23.50 ppm @3% O2	40 ppm @ 3% O2	P27-076-FR B301	3/2/2020
A. Emission Unit Description:			B. Pollutant
B-301 Boiler			со
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test:	F. Test Date
793.00 ppm @ 3% O2	400 ppm @ 3% O2	P27-076-FR B301	3/2/2020
A. Emission Unit Description:			B. Pollutant
B-301 Boiler			NOx
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test:	F. Test Date
28.80 ppm @3% O2	40 ppm @ 3% O2	P27-076-FR B301	3/3/2020
A. Emission Unit Description:			B. Pollutant
B-301 Boiler			со
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test:	F. Test Date
201.00 ppm @ 3% O2	400 ppm @ 3% O2	P27-076-FR B301	3/3/2020



# ANNUAL COMPLIANCE CERTIFICATION SOURCE TEST SUMMARY FORM

Period Covered by Compliance Certification: January 1, 2020- December 31, 2020

A. Emission Unit Description:			B. Pollutant
LM6000 Turbine			NOx
Livioud Turbine			
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test:	F. Test Date
2.25 ppm @ 15% O2	2.5 ppm @ 15% O2	P27-077-FR-COMP	3/4/2020
			D. Dellistent
A. Emission Unit Description:			B. Pollutant
LM6000 Turbine			со
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test:	F. Test Date
3:74 lb/hour	10.20 lb/hour	P27-077-FR-COMP	3/4/2020
			I= = #
A. Emission Unit Description:			B. Pollutant
LM6000 Turbine			O2
Elvidodd Farbine			
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test:	F. Test Date
17.48 %	N/A	P27-077-FR-COMP	3/4/2020
			T "
A. Emission Unit Description:			B. Pollutant
LM6000 Turbine		T	Heat Rate
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test:	F. Test Date
443.00 MMbtu/hour	N/A	P27-077-FR-COMP	3/4/2020
A. Emission Unit Description:			B. Pollutant
LM6000 Turbine			NH3
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test:	F. Test Date
1.01 ppm @ 15% O2	20 ppm @ 15% O2	P27-077-FR-COMP	3/4/2020
1.01 ppin @ 13% 02	20 ppin @ 13/0 02	12/0//11/00//	9,0,000
A. Emission Unit Description:			B. Pollutant
LM6000 Turbine			ROC
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test:	F. Test Date
<0.39 ppm @ 3% O2	2.0 ppm @ 3% O2	P27-077-FR-COMP	3/4/2020



243.00 MMbtu/hour

# ANNUAL COMPLIANCE CERTIFICATION SOURCE TEST SUMMARY FORM

P27-077-FR COMP-C1

5/19/2020

Period Covered by Compliance Certification: January 1, 2020- December 31, 2020

A. Emission Unit Description:			B. Pollutant
LM2500 Turbine			NOx
15	D. Limited Envisoien Bates	Charifia Course Tost:	F. Test Date
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test:	SHELL HAVE BUILDING THE LOCATION
19.40 ppm @ 15% O2	24 ppm @ 15% O2	P27-077-FR COMP-C1	5/19/2020
A. Emission Unit Description:			B. Pollutant
A Top part			
LM2500Turbine			со
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test:	F. Test Date
microscopic Train (Train Control Contr	_		
33.30 lb/hour	180.13 lb/hour	P27-077-FR COMP-C1	5/19/2020
33.30 lb/hour	180.13 lb/hour	P27-077-FR COMP-C1	5/19/2020
	180.13 lb/hour	P27-077-FR COMP-C1	5/19/2020 B. Pollutant
A. Emission Unit Description:	180.13 lb/hour	P27-077-FR COMP-C1	
	180.13 lb/hour	P27-077-FR COMP-C1	
A. Emission Unit Description:  LM2500 Turbine			B. Pollutant  O2
A. Emission Unit Description:  LM2500 Turbine  C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test:	B. Pollutant  O2  F. Test Date
A. Emission Unit Description:  LM2500 Turbine			B. Pollutant  O2
A. Emission Unit Description:  LM2500 Turbine  C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test:	B. Pollutant  O2  F. Test Date
A. Emission Unit Description:  LM2500 Turbine  C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test:	B. Pollutant  O2  F. Test Date
A. Emission Unit Description:  LM2500 Turbine  C. Measured Emission Rate:  14.30 %	D. Limited Emission Rate:	E. Specific Source Test:	B. Pollutant  O2  F. Test Date  5/19/2020
A. Emission Unit Description:  LM2500 Turbine  C. Measured Emission Rate:  14.30 %  A. Emission Unit Description:	D. Limited Emission Rate:	E. Specific Source Test:	B. Pollutant  O2  F. Test Date  5/19/2020  B. Pollutant

N/A



# ANNUAL COMPLIANCE CERTIFICATION SOURCE TEST SUMMARY FORM

Period Covered by Compliance Certification: January 1, 2020- December 31, 2020

A. Emission Unit Description:	B. Pollutant				
2X Predryer (70 Mmbtu/ho					
Yankee Hot Air Furnace (40					
C. Measured Emission Rate:	F. Test Date				
0.0705 lb/Mmbtu	0.0705 lb/Mmbtu 0.080 lb/Mmbtu P27-076-FR2X				
A. Emission Unit Description:			B. Pollutant		
2X Predryer (70 Mmbtu/ho	our) and		со		
Yankee Hot Air Furnace (40	Mmbtu/hour)		CO		
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test:	F. Test Date		
0.0386 lb/Mmbtu	0.045 lb/Mmbtu	P27-076-FR2X	5/26/2020		
A. Emission Unit Description:			B. Pollutant		
2X Predryer (70 Mmbtu/ho	03				
Yankee Hot Air Furnace (40	) Mmbtu/hour)		O2		
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test:	F. Test Date		
19.71 %	N/A	P27-076-FR2X	5/26/2020		