

FIELD DATA & STRIP CHARTS

EMISSIONS TEST - SCAQMD Method 100.1

Date: 10/22/20

Job #: 220-113
Client #: 23022

**** Test Information ****

Client: New Indy
County: Ventura
Site(s): Oxnard, CA
Unit(s): Nebraska Boiler

**** Personnel ****

AIRx: KK/WH
Client: RL
APCD: -

| | | | | | | |
|-------------|---------|-----------|-----------|----------|----------|---------|
| Run Length: | 21 | Inlet () | Outlet(X) | Fuel () | HC's() | |
| No. Points: | Single | S.T.(X) | E.I.() | Data() | H2S () | NH3 () |
| | Time | Baro. | Temp. | | Weather. | |
| Arrive: | 6:30 AM | 29.94 | 62 | | Clear | |
| Depart: | 3:30 PM | 29.96 | 67 | | Clear | |

**** Instrument Information ****

| | | | |
|-------------|------|-------|---------------|
| Instrument | "On" | Unit# | Make/Model |
| Outlet NOx: | 1 | 3 | API 200EH |
| O2: | 1 | 12 | Servomex 1400 |

Recorders: Soltec 6 pin 10 cm/hr

**** Calibration Information ****

| | | | | | | |
|------|-------|------|------|-------|-----------|----------|
| | Units | Zero | Span | Range | Gas Cyl.# | Gas Flow |
| NOx: | ppmv | 0.0 | 20.2 | 50 | CC724456 | 1.0 |
| NOx: | ppmv | 0.0 | 40.0 | 50 | DT0028766 | 1.0 |
| NO2: | ppmv | 0.0 | 19.0 | 50 | CC3240 | 1.0 |
| O2: | % | 0.0 | 3.98 | 10 | CC60235 | 0.6 |
| O2: | % | 0.0 | 8.05 | 10 | CC160530 | 0.6 |

**** Recorder Information ****

| | | | | |
|-------------|------|--------|----------|-------|
| | | Chanl. | Pen Type | Color |
| Outlet NOx: | ppmv | 1 | Cont. | Black |
| O2: | % | 2 | Cont. | Green |

| | | | |
|-----------|------------|------------|-----------------|
| CLIENT: | New-Indy | JOB# | 220-113 |
| PLANT: | Oxnard, CA | RUN# | RATA 1 |
| DATE: | 10/22/2020 | UNIT ID: | Nebraska Boiler |
| ENGINEER: | KK/WH | RUN START: | 7:55 AM |

| NOx, ppm | O2, % | NOx, ppm @ 3% O2 | TIME |
|--------------|-------------|------------------|-----------------|
| 25.26 | 4.51 | 27.59 | 7:55 |
| 25.41 | 4.61 | 27.92 | 7:56 |
| 25.51 | 4.54 | 27.91 | 7:57 |
| 25.24 | 4.64 | 27.79 | 7:58 |
| 25.21 | 4.47 | 27.47 | 7:59 |
| 25.00 | 4.48 | 27.25 | 8:00 |
| 25.09 | 4.62 | 27.59 | 8:01 |
| 24.87 | 4.33 | 26.87 | 8:02 |
| 24.88 | 4.54 | 27.22 | 8:03 |
| 25.13 | 4.66 | 27.70 | 8:04 |
| 24.97 | 4.39 | 27.07 | 8:05 |
| 24.92 | 4.25 | 26.79 | 8:06 |
| 25.27 | 4.48 | 27.55 | 8:07 |
| 25.22 | 4.37 | 27.31 | 8:08 |
| 25.11 | 4.30 | 27.08 | 8:09 |
| 25.25 | 4.28 | 27.19 | 8:10 |
| 25.29 | 4.51 | 27.62 | 8:11 |
| 25.04 | 4.70 | 27.67 | 8:12 |
| 25.03 | 4.50 | 27.32 | 8:13 |
| 25.28 | 4.49 | 27.58 | 8:14 |
| 25.06 | 4.48 | 27.32 | 8:15 |
| 24.97 | 4.87 | 27.88 | 8:16 |
| 25.14 | 4.50 | 27.44 | Averages |

| | | | |
|-----------|------------|------------|-----------------|
| CLIENT: | New Indy | JOB# | 220-113 |
| PLANT: | Oxnard, CA | RUN# | RATA 2 |
| DATE: | 10/22/2020 | UNIT ID: | Nebraska Boiler |
| ENGINEER: | KK/WH | RUN START: | 8:17 AM |

| NOx, ppm | O2, % | NOx, ppm @ 3% O2 | TIME |
|--------------|-------------|------------------|-----------------|
| 24.70 | 4.35 | 26.71 | 8:17 |
| 24.73 | 4.49 | 26.98 | 8:18 |
| 24.74 | 4.83 | 27.56 | 8:19 |
| 24.58 | 4.46 | 26.76 | 8:20 |
| 24.41 | 4.45 | 26.56 | 8:21 |
| 24.55 | 4.42 | 26.67 | 8:22 |
| 24.57 | 4.44 | 26.72 | 8:23 |
| 24.54 | 4.43 | 26.67 | 8:24 |
| 24.44 | 4.89 | 27.33 | 8:25 |
| 24.22 | 4.67 | 26.71 | 8:26 |
| 24.34 | 4.36 | 26.34 | 8:27 |
| 24.56 | 4.73 | 27.19 | 8:28 |
| 24.49 | 4.34 | 26.47 | 8:29 |
| 24.47 | 4.33 | 26.43 | 8:30 |
| 24.68 | 4.44 | 26.84 | 8:31 |
| 24.53 | 4.68 | 27.07 | 8:32 |
| 24.42 | 4.25 | 26.25 | 8:33 |
| 24.48 | 4.34 | 26.46 | 8:34 |
| 24.64 | 4.77 | 27.34 | 8:35 |
| 24.47 | 4.32 | 26.42 | 8:36 |
| 24.54 | 4.42 | 26.65 | 8:37 |
| 24.52 | 4.66 | 27.03 | 8:38 |
| 24.53 | 4.50 | 26.78 | Averages |

| | | | |
|-----------|------------|------------|-----------------|
| CLIENT: | New-Indy | JOB# | 220-113 |
| PLANT: | Oxnard, CA | RUN# | RATA 3 |
| DATE: | 10/22/2020 | UNIT ID: | Nebraska Boiler |
| ENGINEER: | KK/WH | RUN START: | 8:38 AM |

| NOx, ppm | O2, % | NOx, ppm @ 3% O2 | Time |
|--------------|-------------|------------------|-----------------|
| 24.52 | 4.66 | 27.03 | 8:38 |
| 24.39 | 4.25 | 26.22 | 8:39 |
| 24.57 | 4.43 | 26.70 | 8:40 |
| 24.70 | 4.77 | 27.41 | 8:41 |
| 24.51 | 4.07 | 26.07 | 8:42 |
| 24.52 | 4.67 | 27.04 | 8:43 |
| 24.42 | 4.54 | 26.72 | 8:44 |
| 24.21 | 4.22 | 25.98 | 8:45 |
| 24.45 | 4.21 | 26.22 | 8:46 |
| 24.65 | 4.72 | 27.27 | 8:47 |
| 24.50 | 4.50 | 26.74 | 8:48 |
| 24.38 | 4.46 | 26.55 | 8:49 |
| 24.67 | 4.34 | 26.67 | 8:50 |
| 24.66 | 4.74 | 27.32 | 8:51 |
| 24.29 | 4.26 | 26.13 | 8:52 |
| 24.29 | 4.31 | 26.21 | 8:53 |
| 24.43 | 4.74 | 27.06 | 8:54 |
| 24.24 | 4.39 | 26.28 | 8:55 |
| 24.11 | 4.37 | 26.11 | 8:56 |
| 24.48 | 4.54 | 26.78 | 8:57 |
| 24.47 | 4.69 | 27.02 | 8:58 |
| 24.16 | 4.38 | 26.18 | 8:59 |
| 24.44 | 4.47 | 26.62 | Averages |

| | | | |
|-----------|------------|------------|-----------------|
| CLIENT: | New Indy | JOB# | 220-113 |
| PLANT: | Oxnard, CA | RUN# | RATA 4 |
| DATE: | 10/22/2020 | UNIT ID: | Nebraska Boiler |
| ENGINEER: | KK/WH | RUN START: | 9:15 AM |

| NOx, ppm | O2, % | NOx, ppm @ 3% O2 | TIME |
|--------------|-------------|------------------|-----------------|
| 24.28 | 4.21 | 26.04 | 9:15 |
| 24.39 | 4.54 | 26.69 | 9:16 |
| 24.30 | 4.51 | 26.54 | 9:17 |
| 24.21 | 4.36 | 26.20 | 9:18 |
| 24.41 | 4.48 | 26.61 | 9:19 |
| 24.42 | 4.55 | 26.74 | 9:20 |
| 24.30 | 4.33 | 26.25 | 9:21 |
| 24.52 | 4.48 | 26.73 | 9:22 |
| 24.53 | 4.65 | 27.02 | 9:23 |
| 24.39 | 4.08 | 25.96 | 9:24 |
| 24.44 | 4.61 | 26.86 | 9:25 |
| 24.30 | 4.51 | 26.54 | 9:26 |
| 24.19 | 4.08 | 25.74 | 9:27 |
| 24.42 | 4.97 | 27.44 | 9:28 |
| 24.54 | 4.49 | 26.77 | 9:29 |
| 24.53 | 4.35 | 26.53 | 9:30 |
| 24.90 | 4.28 | 26.82 | 9:31 |
| 25.22 | 4.22 | 27.06 | 9:32 |
| 25.22 | 5.16 | 28.68 | 9:33 |
| 24.75 | 4.71 | 27.36 | 9:34 |
| 24.48 | 4.27 | 26.35 | 9:35 |
| 24.92 | 4.47 | 27.15 | 9:36 |
| 24.53 | 4.47 | 26.73 | Averages |

| | | | |
|-----------|------------|------------|-----------------|
| CLIENT: | New Indy | JOB# | 220-113 |
| PLANT: | Oxnard, CA | RUN# | RATA 5 |
| DATE: | 10/22/2020 | UNIT ID: | Nebraska Boiler |
| ENGINEER: | KK/WH | RUN START: | 9:37 AM |

| NOx, ppm | O2, % | NOx, ppm @ 3% O2 | TIME |
|--------------|-------------|------------------|-----------------|
| 25.07 | 4.92 | 28.08 | 9:37 |
| 25.02 | 4.24 | 26.88 | 9:38 |
| 25.09 | 4.48 | 27.35 | 9:39 |
| 25.12 | 4.86 | 28.03 | 9:40 |
| 24.92 | 4.18 | 26.68 | 9:41 |
| 25.02 | 4.55 | 27.39 | 9:42 |
| 25.04 | 4.84 | 27.91 | 9:43 |
| 24.83 | 4.18 | 26.58 | 9:44 |
| 24.83 | 4.78 | 27.57 | 9:45 |
| 24.79 | 4.81 | 27.58 | 9:46 |
| 24.58 | 4.24 | 26.41 | 9:47 |
| 24.77 | 4.53 | 27.09 | 9:48 |
| 24.87 | 5.00 | 28.00 | 9:49 |
| 24.75 | 4.39 | 26.83 | 9:50 |
| 24.88 | 4.17 | 26.62 | 9:51 |
| 25.33 | 4.65 | 27.90 | 9:52 |
| 25.42 | 4.06 | 27.02 | 9:53 |
| 25.55 | 3.88 | 26.87 | 9:54 |
| 25.85 | 4.40 | 28.04 | 9:55 |
| 25.71 | 4.79 | 28.57 | 9:56 |
| 25.32 | 4.40 | 27.47 | 9:57 |
| 25.19 | 4.56 | 27.59 | 9:58 |
| 25.09 | 4.50 | 27.39 | Averages |

| | | | |
|-----------|------------|------------|-----------------|
| CLIENT: | New Indy | JOB# | 220-113 |
| PLANT: | Oxnard, CA | RUN# | RATA 6 |
| DATE: | 10/22/2020 | UNIT ID: | Nebraska Boiler |
| ENGINEER: | KK/WH | RUN START: | 9:59 AM |

| NOx, ppm | O2, % | NOx, ppm @ 3% O2 | TIME |
|--------------|-------------|------------------|-----------------|
| 25.21 | 5.05 | 28.47 | 9:59 |
| 25.01 | 4.29 | 26.95 | 10:00 |
| 25.01 | 4.64 | 27.53 | 10:01 |
| 24.96 | 4.75 | 27.66 | 10:02 |
| 24.90 | 3.98 | 26.34 | 10:03 |
| 25.21 | 4.43 | 27.40 | 10:04 |
| 25.19 | 4.51 | 27.51 | 10:05 |
| 24.90 | 4.07 | 26.48 | 10:06 |
| 24.97 | 4.62 | 27.45 | 10:07 |
| 24.96 | 4.69 | 27.56 | 10:08 |
| 24.66 | 4.07 | 26.23 | 10:09 |
| 24.71 | 4.41 | 26.82 | 10:10 |
| 24.81 | 4.86 | 27.69 | 10:11 |
| 24.61 | 4.37 | 26.65 | 10:12 |
| 24.60 | 4.12 | 26.24 | 10:13 |
| 24.77 | 4.82 | 27.57 | 10:14 |
| 24.55 | 4.70 | 27.13 | 10:15 |
| 24.25 | 4.33 | 26.20 | 10:16 |
| 24.33 | 4.35 | 26.31 | 10:17 |
| 24.43 | 4.60 | 26.83 | 10:18 |
| 24.34 | 4.81 | 27.08 | 10:19 |
| 24.44 | 4.15 | 26.12 | 10:20 |
| 24.76 | 4.48 | 27.01 | Averages |

| | | | |
|-----------|------------|------------|-----------------|
| CLIENT: | New-Indy | JOB# | 220-113 |
| PLANT: | Oxnard, CA | RUN# | RATA 7 |
| DATE: | 10/22/2020 | UNIT ID: | Nebraska Boiler |
| ENGINEER: | KK/WH | RUN START: | 10:35 AM |

| NOx, ppm | O2, % | NOx, ppm @ 3% O2 | TIME |
|--------------|-------------|------------------|-----------------|
| 24.49 | 4.16 | 26.19 | 10:35 |
| 24.63 | 4.81 | 27.40 | 10:36 |
| 25.44 | 4.67 | 28.06 | 10:37 |
| 25.90 | 4.14 | 27.66 | 10:38 |
| 26.18 | 4.80 | 29.11 | 10:39 |
| 26.21 | 4.53 | 28.66 | 10:40 |
| 26.19 | 4.11 | 27.92 | 10:41 |
| 26.32 | 4.89 | 29.43 | 10:42 |
| 26.09 | 4.77 | 28.95 | 10:43 |
| 25.88 | 4.37 | 28.02 | 10:44 |
| 26.22 | 4.40 | 28.44 | 10:45 |
| 26.25 | 5.18 | 29.89 | 10:46 |
| 25.98 | 4.48 | 28.32 | 10:47 |
| 25.93 | 4.44 | 28.20 | 10:48 |
| 26.23 | 4.79 | 29.14 | 10:49 |
| 26.06 | 4.76 | 28.90 | 10:50 |
| 25.85 | 4.10 | 27.54 | 10:51 |
| 26.09 | 4.47 | 28.42 | 10:52 |
| 26.13 | 4.81 | 29.07 | 10:53 |
| 25.96 | 4.43 | 28.21 | 10:54 |
| 25.82 | 4.44 | 28.08 | 10:55 |
| 25.92 | 4.45 | 28.20 | 10:56 |
| 25.90 | 4.55 | 28.36 | Averages |

| | | | |
|-----------|------------|------------|-----------------|
| CLIENT: | New-Indy | JOB# | 220-113 |
| PLANT: | Oxnard, CA | RUN# | RATA 8 |
| DATE: | 10/22/2020 | UNIT ID: | Nebraska Boiler |
| ENGINEER: | KK/WH | RUN START: | 10:57 AM |

| NOx, ppm | O2, % | NOx, ppm @ 3% O2 | TIME |
|--------------|-------------|------------------|-----------------|
| 25.91 | 4.45 | 28.19 | 10:57 |
| 25.99 | 4.68 | 28.68 | 10:58 |
| 25.84 | 4.72 | 28.59 | 10:59 |
| 25.87 | 4.27 | 27.85 | 11:00 |
| 26.08 | 4.72 | 28.85 | 11:01 |
| 26.13 | 4.71 | 28.89 | 11:02 |
| 25.98 | 4.17 | 27.80 | 11:03 |
| 26.09 | 4.71 | 28.85 | 11:04 |
| 25.95 | 4.70 | 28.67 | 11:05 |
| 25.73 | 4.07 | 27.37 | 11:06 |
| 25.98 | 4.29 | 28.00 | 11:07 |
| 26.08 | 4.70 | 28.82 | 11:08 |
| 25.83 | 4.63 | 28.42 | 11:09 |
| 25.67 | 4.44 | 27.92 | 11:10 |
| 25.70 | 4.11 | 27.40 | 11:11 |
| 25.89 | 4.42 | 28.12 | 11:12 |
| 26.00 | 4.69 | 28.71 | 11:13 |
| 25.97 | 4.63 | 28.57 | 11:14 |
| 25.88 | 4.42 | 28.11 | 11:15 |
| 25.81 | 4.30 | 27.83 | 11:16 |
| 25.77 | 4.29 | 27.77 | 11:17 |
| 25.88 | 4.43 | 28.13 | 11:18 |
| 25.91 | 4.48 | 28.25 | Averages |

| | | | |
|-----------|------------|------------|-----------------|
| CLIENT: | New Indy | JOB# | 220-113 |
| PLANT: | Oxnard, CA | RUN# | RATA 9 |
| DATE: | 10/22/2020 | UNIT ID: | Nebraska Boiler |
| ENGINEER: | KK/WH | RUN START: | 11:19 AM |

| NOx, ppm | O2, % | NOx, ppm @ 3% O2 | TIME |
|--------------|-------------|------------------|-----------------|
| 25.81 | 4.85 | 28.78 | 11:19 |
| 25.53 | 4.28 | 27.50 | 11:20 |
| 25.59 | 4.21 | 27.45 | 11:21 |
| 25.80 | 4.81 | 28.70 | 11:23 |
| 25.64 | 4.43 | 27.87 | 11:24 |
| 25.59 | 4.18 | 27.40 | 11:25 |
| 25.89 | 4.22 | 27.78 | 11:26 |
| 25.98 | 4.85 | 28.97 | 11:27 |
| 25.56 | 4.69 | 28.22 | 11:28 |
| 25.35 | 4.25 | 27.25 | 11:29 |
| 25.63 | 4.74 | 28.39 | 11:30 |
| 25.61 | 4.77 | 28.42 | 11:31 |
| 25.57 | 4.47 | 27.86 | 11:32 |
| 25.62 | 4.48 | 27.93 | 11:33 |
| 25.50 | 4.74 | 28.25 | 11:34 |
| 25.31 | 4.84 | 28.21 | 11:35 |
| 25.28 | 4.30 | 27.26 | 11:36 |
| 25.45 | 4.30 | 27.44 | 11:37 |
| 25.55 | 4.88 | 28.55 | 11:38 |
| 25.45 | 4.50 | 27.78 | 11:39 |
| 25.32 | 4.13 | 27.03 | 11:40 |
| 25.51 | 4.11 | 27.20 | 11:41 |
| 25.57 | 4.50 | 27.92 | Averages |

Down 57 sec
 Down 58 sec
 Down 56 sec
 Down 46 sec
 Down 45 sec

Up 83 sec
 Up 60 sec
 Up 59 sec
 Up 48 sec
 Up 46 sec
 Up 47 sec

Response times

8.02 N/A
 8.03 N/A
 8.05 N/A
 8.06 N/A
 8.07 N/A
 8.08 N/A
 8.09 N/A
 8.10 N/A
 8.11 N/A
 8.12 N/A
 8.13 N/A
 8.14 N/A
 8.15 N/A
 8.16 N/A
 8.17 N/A
 8.18 N/A
 8.19 N/A
 8.20 N/A
 8.21 N/A
 8.22 N/A
 8.23 N/A
 8.24 N/A
 8.25 N/A
 8.26 N/A
 8.27 N/A
 8.28 N/A
 8.29 N/A
 8.30 N/A
 8.31 N/A
 8.32 N/A
 8.33 N/A
 8.34 N/A
 8.35 N/A
 8.36 N/A
 8.37 N/A
 8.38 N/A
 8.39 N/A
 8.40 N/A
 8.41 N/A
 8.42 N/A
 8.43 N/A
 8.44 N/A
 8.45 N/A
 8.46 N/A
 8.47 N/A
 8.48 N/A
 8.49 N/A
 8.50 N/A
 8.51 N/A
 8.52 N/A
 8.53 N/A
 8.54 N/A
 8.55 N/A
 8.56 N/A
 8.57 N/A
 8.58 N/A
 8.59 N/A
 8.60 N/A
 8.61 N/A
 8.62 N/A
 8.63 N/A
 8.64 N/A
 8.65 N/A
 8.66 N/A
 8.67 N/A
 8.68 N/A
 8.69 N/A
 8.70 N/A
 8.71 N/A
 8.72 N/A
 8.73 N/A
 8.74 N/A
 8.75 N/A
 8.76 N/A
 8.77 N/A
 8.78 N/A
 8.79 N/A
 8.80 N/A
 8.81 N/A
 8.82 N/A
 8.83 N/A
 8.84 N/A
 8.85 N/A
 8.86 N/A
 8.87 N/A
 8.88 N/A
 8.89 N/A
 8.90 N/A
 8.91 N/A
 8.92 N/A
 8.93 N/A
 8.94 N/A
 8.95 N/A
 8.96 N/A
 8.97 N/A
 8.98 N/A
 8.99 N/A
 9.00 N/A

Initial Bias Cal

NO₂ → NO conversion


5.05
 5.06
 5.07
 5.08
 5.09
 5.10
 5.11
 5.12
 5.13
 5.14
 5.15
 5.16
 5.17
 5.18
 5.19
 5.20
 5.21
 5.22
 5.23
 5.24
 5.25
 5.26
 5.27
 5.28
 5.29
 5.30
 5.31
 5.32
 5.33
 5.34
 5.35
 5.36
 5.37
 5.38
 5.39
 5.40
 5.41
 5.42
 5.43
 5.44
 5.45
 5.46
 5.47
 5.48
 5.49
 5.50
 5.51
 5.52
 5.53
 5.54
 5.55
 5.56
 5.57
 5.58
 5.59
 5.60
 5.61
 5.62
 5.63
 5.64
 5.65
 5.66
 5.67
 5.68
 5.69
 5.70
 5.71
 5.72
 5.73
 5.74
 5.75
 5.76
 5.77
 5.78
 5.79
 5.80
 5.81
 5.82
 5.83
 5.84
 5.85
 5.86
 5.87
 5.88
 5.89
 5.90
 5.91
 5.92
 5.93
 5.94
 5.95
 5.96
 5.97
 5.98
 5.99
 6.00
 6.01
 6.02
 6.03
 6.04
 6.05
 6.06
 6.07
 6.08
 6.09
 6.10
 6.11
 6.12
 6.13
 6.14
 6.15
 6.16
 6.17
 6.18
 6.19
 6.20
 6.21
 6.22
 6.23
 6.24
 6.25
 6.26
 6.27
 6.28
 6.29
 6.30
 6.31
 6.32
 6.33
 6.34
 6.35
 6.36
 6.37
 6.38
 6.39
 6.40
 6.41
 6.42
 6.43
 6.44
 6.45
 6.46
 6.47
 6.48
 6.49
 6.50
 6.51
 6.52
 6.53
 6.54
 6.55
 6.56
 6.57
 6.58
 6.59
 6.60
 6.61
 6.62
 6.63
 6.64
 6.65
 6.66
 6.67
 6.68
 6.69
 6.70
 6.71
 6.72
 6.73
 6.74
 6.75
 6.76
 6.77
 6.78
 6.79
 6.80
 6.81
 6.82
 6.83
 6.84
 6.85
 6.86
 6.87
 6.88
 6.89
 6.90
 6.91
 6.92
 6.93
 6.94
 6.95
 6.96
 6.97
 6.98
 6.99
 7.00
 7.01
 7.02
 7.03
 7.04
 7.05
 7.06
 7.07
 7.08
 7.09
 7.10
 7.11
 7.12
 7.13
 7.14
 7.15
 7.16
 7.17
 7.18
 7.19
 7.20
 7.21
 7.22
 7.23
 7.24
 7.25
 7.26
 7.27
 7.28
 7.29
 7.30
 7.31
 7.32
 7.33
 7.34
 7.35
 7.36
 7.37
 7.38
 7.39
 7.40
 7.41
 7.42
 7.43
 7.44
 7.45
 7.46
 7.47
 7.48
 7.49
 7.50
 7.51
 7.52
 7.53
 7.54
 7.55
 7.56
 7.57
 7.58
 7.59
 7.60
 7.61
 7.62
 7.63
 7.64
 7.65
 7.66
 7.67
 7.68
 7.69
 7.70
 7.71
 7.72
 7.73
 7.74
 7.75
 7.76
 7.77
 7.78
 7.79
 7.80
 7.81
 7.82
 7.83
 7.84
 7.85
 7.86
 7.87
 7.88
 7.89
 7.90
 7.91
 7.92
 7.93
 7.94
 7.95
 7.96
 7.97
 7.98
 7.99
 8.00
 8.01
 8.02
 8.03
 8.04
 8.05
 8.06
 8.07
 8.08
 8.09
 8.10
 8.11
 8.12
 8.13
 8.14
 8.15
 8.16
 8.17
 8.18
 8.19
 8.20
 8.21
 8.22
 8.23
 8.24
 8.25
 8.26
 8.27
 8.28
 8.29
 8.30
 8.31
 8.32
 8.33
 8.34
 8.35
 8.36
 8.37
 8.38
 8.39
 8.40
 8.41
 8.42
 8.43
 8.44
 8.45
 8.46
 8.47
 8.48
 8.49
 8.50
 8.51
 8.52
 8.53
 8.54
 8.55
 8.56
 8.57
 8.58
 8.59
 8.60
 8.61
 8.62
 8.63
 8.64
 8.65
 8.66
 8.67
 8.68
 8.69
 8.70
 8.71
 8.72
 8.73
 8.74
 8.75
 8.76
 8.77
 8.78
 8.79
 8.80
 8.81
 8.82
 8.83
 8.84
 8.85
 8.86
 8.87
 8.88
 8.89
 8.90
 8.91
 8.92
 8.93
 8.94
 8.95
 8.96
 8.97
 8.98
 8.99
 9.00
 9.01
 9.02
 9.03
 9.04
 9.05
 9.06
 9.07
 9.08
 9.09
 9.10
 9.11
 9.12
 9.13
 9.14
 9.15
 9.16
 9.17
 9.18
 9.19
 9.20
 9.21
 9.22
 9.23
 9.24
 9.25
 9.26
 9.27
 9.28
 9.29
 9.30
 9.31
 9.32
 9.33
 9.34
 9.35
 9.36
 9.37
 9.38
 9.39
 9.40
 9.41
 9.42
 9.43
 9.44
 9.45
 9.46
 9.47
 9.48
 9.49
 9.50
 9.51
 9.52
 9.53
 9.54
 9.55
 9.56
 9.57
 9.58
 9.59
 9.60
 9.61
 9.62
 9.63
 9.64
 9.65
 9.66
 9.67
 9.68
 9.69
 9.70
 9.71
 9.72
 9.73
 9.74
 9.75
 9.76
 9.77
 9.78
 9.79
 9.80
 9.81
 9.82
 9.83
 9.84
 9.85
 9.86
 9.87
 9.88
 9.89
 9.90
 9.91
 9.92
 9.93
 9.94
 9.95
 9.96
 9.97
 9.98
 9.99
 10.00

Initial Internal Linearity Cal

New Inv
 10.22.20


2018
Mar 20
Port Bias Cal

200



START 2-2-13 4:56

Post
Net of 15 Cell
20.2
3.94




START AT 9:19 65-2486

101
02

200

Post Sues and
2080

zero



START Run 7-8-9
188 25.89
SE: 01
10:35

New-Indy Oxnard, LLC
 Nebraska Boiler CEMS RATA TEST - November 22, 2020

10/22/2020 7:55 10/22/2020 8:17 1 m

Katya

| NOx, ppm (3% O2) | | Raw NOx, ppm | | O2 (%) | | Gas Flow (SCFH) | |
|---------------------------------------|--------------|-----------------------------------|--------------|-----------------------------|-------------|--------------------------------|---------------|
| 931A1391_CNOX | | 931A1391.AT | | 931A1392.AT | | 931F1374B.ft | |
| 22-Oct-20 07:55:00 | 30.70 | 22-Oct-20 07:55:00 | 27.74 | 22-Oct-20 07:55:00 | 4.73 | 22-Oct-20 07:55:00 | 76,986 |
| 22-Oct-20 07:56:00 | 31.35 | 22-Oct-20 07:56:00 | 28.45 | 22-Oct-20 07:56:00 | 4.66 | 22-Oct-20 07:56:00 | 75,144 |
| 22-Oct-20 07:57:00 | 31.78 | 22-Oct-20 07:57:00 | 27.98 | 22-Oct-20 07:57:00 | 5.14 | 22-Oct-20 07:57:00 | 73,297 |
| 22-Oct-20 07:58:00 | 31.14 | 22-Oct-20 07:58:00 | 28.12 | 22-Oct-20 07:58:00 | 4.73 | 22-Oct-20 07:58:00 | 77,398 |
| 22-Oct-20 07:59:00 | 31.20 | 22-Oct-20 07:59:00 | 28.45 | 22-Oct-20 07:59:00 | 4.65 | 22-Oct-20 07:59:00 | 75,282 |
| 22-Oct-20 08:00:00 | 31.02 | 22-Oct-20 08:00:00 | 27.38 | 22-Oct-20 08:00:00 | 5.10 | 22-Oct-20 08:00:00 | 73,422 |
| 22-Oct-20 08:01:00 | 31.35 | 22-Oct-20 08:01:00 | 28.15 | 22-Oct-20 08:01:00 | 4.82 | 22-Oct-20 08:01:00 | 76,848 |
| 22-Oct-20 08:02:00 | 31.32 | 22-Oct-20 08:02:00 | 28.54 | 22-Oct-20 08:02:00 | 4.59 | 22-Oct-20 08:02:00 | 76,823 |
| 22-Oct-20 08:03:00 | 31.52 | 22-Oct-20 08:03:00 | 27.98 | 22-Oct-20 08:03:00 | 5.01 | 22-Oct-20 08:03:00 | 74,436 |
| 22-Oct-20 08:04:00 | 31.39 | 22-Oct-20 08:04:00 | 28.22 | 22-Oct-20 08:04:00 | 4.80 | 22-Oct-20 08:04:00 | 76,347 |
| 22-Oct-20 08:05:00 | 31.45 | 22-Oct-20 08:05:00 | 28.39 | 22-Oct-20 08:05:00 | 4.74 | 22-Oct-20 08:05:00 | 76,412 |
| 22-Oct-20 08:06:00 | 30.64 | 22-Oct-20 08:06:00 | 27.86 | 22-Oct-20 08:06:00 | 4.74 | 22-Oct-20 08:06:00 | 76,426 |
| 22-Oct-20 08:07:00 | 31.43 | 22-Oct-20 08:07:00 | 28.20 | 22-Oct-20 08:07:00 | 4.84 | 22-Oct-20 08:07:00 | 73,747 |
| 22-Oct-20 08:08:00 | 31.26 | 22-Oct-20 08:08:00 | 27.71 | 22-Oct-20 08:08:00 | 5.03 | 22-Oct-20 08:08:00 | 75,408 |
| 22-Oct-20 08:09:00 | 30.94 | 22-Oct-20 08:09:00 | 28.03 | 22-Oct-20 08:09:00 | 4.68 | 22-Oct-20 08:09:00 | 76,648 |
| 22-Oct-20 08:10:00 | 31.45 | 22-Oct-20 08:10:00 | 28.50 | 22-Oct-20 08:10:00 | 4.68 | 22-Oct-20 08:10:00 | 76,530 |
| 22-Oct-20 08:11:00 | 31.65 | 22-Oct-20 08:11:00 | 28.22 | 22-Oct-20 08:11:00 | 4.94 | 22-Oct-20 08:11:00 | 72,891 |
| 22-Oct-20 08:12:00 | 31.32 | 22-Oct-20 08:12:00 | 27.43 | 22-Oct-20 08:12:00 | 5.22 | 22-Oct-20 08:12:00 | 73,471 |
| 22-Oct-20 08:13:00 | 31.17 | 22-Oct-20 08:13:00 | 28.11 | 22-Oct-20 08:13:00 | 4.76 | 22-Oct-20 08:13:00 | 76,889 |
| 22-Oct-20 08:14:00 | 31.64 | 22-Oct-20 08:14:00 | 28.18 | 22-Oct-20 08:14:00 | 4.95 | 22-Oct-20 08:14:00 | 72,682 |
| 22-Oct-20 08:15:00 | 31.83 | 22-Oct-20 08:15:00 | 27.94 | 22-Oct-20 08:15:00 | 5.19 | 22-Oct-20 08:15:00 | 73,606 |
| 22-Oct-20 08:16:00 | 31.27 | 22-Oct-20 08:16:00 | 27.94 | 22-Oct-20 08:16:00 | 4.94 | 22-Oct-20 08:16:00 | 74,814 |
| Average Stack NOx, ppm (3% O2) | 31.31 | Average Stack Raw NOx, ppm | 28.06 | Average Stack O2 (%) | 4.86 | Average Gas Flow (SCFH) | 75,250 |

New-Indy Oxnard, LLC
 Nebraska Boiler CEMS RATA TEST - November 22, 2020

10/22/2020 8:17 10/22/2020 8:39 1 m

Rata 2

| NOx, ppm (3% O2) | | Raw NOx, ppm | | O2 (%) | | Gas Flow (SCFH) | |
|---------------------------------------|--------------|-----------------------------------|--------------|-----------------------------|-------------|--------------------------------|---------------|
| 931AI391_CNOX | | 931AI381.AT | | 931AI392.AT | | 931FI374B.ft | |
| 22-Oct-20 08:17:00 | 31.51 | 22-Oct-20 08:17:00 | 28.15 | 22-Oct-20 08:17:00 | 4.91 | 22-Oct-20 08:17:00 | 74,879 |
| 22-Oct-20 08:18:00 | 31.58 | 22-Oct-20 08:18:00 | 28.33 | 22-Oct-20 08:18:00 | 4.84 | 22-Oct-20 08:18:00 | 74,841 |
| 22-Oct-20 08:19:00 | 31.13 | 22-Oct-20 08:19:00 | 27.81 | 22-Oct-20 08:19:00 | 4.91 | 22-Oct-20 08:19:00 | 74,889 |
| 22-Oct-20 08:20:00 | 31.53 | 22-Oct-20 08:20:00 | 28.21 | 22-Oct-20 08:20:00 | 4.88 | 22-Oct-20 08:20:00 | 73,752 |
| 22-Oct-20 08:21:00 | 31.93 | 22-Oct-20 08:21:00 | 27.91 | 22-Oct-20 08:21:00 | 5.25 | 22-Oct-20 08:21:00 | 71,951 |
| 22-Oct-20 08:22:00 | 31.22 | 22-Oct-20 08:22:00 | 28.03 | 22-Oct-20 08:22:00 | 4.82 | 22-Oct-20 08:22:00 | 75,453 |
| 22-Oct-20 08:23:00 | 31.49 | 22-Oct-20 08:23:00 | 28.35 | 22-Oct-20 08:23:00 | 4.78 | 22-Oct-20 08:23:00 | 73,719 |
| 22-Oct-20 08:24:00 | 31.49 | 22-Oct-20 08:24:00 | 27.68 | 22-Oct-20 08:24:00 | 5.16 | 22-Oct-20 08:24:00 | 73,268 |
| 22-Oct-20 08:25:00 | 30.95 | 22-Oct-20 08:25:00 | 27.99 | 22-Oct-20 08:25:00 | 4.71 | 22-Oct-20 08:25:00 | 76,002 |
| 22-Oct-20 08:26:00 | 31.36 | 22-Oct-20 08:26:00 | 28.40 | 22-Oct-20 08:26:00 | 4.69 | 22-Oct-20 08:26:00 | 75,978 |
| 22-Oct-20 08:27:00 | 31.35 | 22-Oct-20 08:27:00 | 28.10 | 22-Oct-20 08:27:00 | 4.85 | 22-Oct-20 08:27:00 | 72,854 |
| 22-Oct-20 08:28:00 | 31.16 | 22-Oct-20 08:28:00 | 27.47 | 22-Oct-20 08:28:00 | 5.12 | 22-Oct-20 08:28:00 | 73,992 |
| 22-Oct-20 08:29:00 | 30.91 | 22-Oct-20 08:29:00 | 28.06 | 22-Oct-20 08:29:00 | 4.65 | 22-Oct-20 08:29:00 | 76,249 |
| 22-Oct-20 08:30:00 | 31.14 | 22-Oct-20 08:30:00 | 28.06 | 22-Oct-20 08:30:00 | 4.78 | 22-Oct-20 08:30:00 | 73,306 |
| 22-Oct-20 08:31:00 | 31.72 | 22-Oct-20 08:31:00 | 27.91 | 22-Oct-20 08:31:00 | 5.20 | 22-Oct-20 08:31:00 | 72,606 |
| 22-Oct-20 08:32:00 | 30.91 | 22-Oct-20 08:32:00 | 28.01 | 22-Oct-20 08:32:00 | 4.68 | 22-Oct-20 08:32:00 | 76,631 |
| 22-Oct-20 08:33:00 | 31.09 | 22-Oct-20 08:33:00 | 27.94 | 22-Oct-20 08:33:00 | 4.81 | 22-Oct-20 08:33:00 | 72,704 |
| 22-Oct-20 08:34:00 | 31.19 | 22-Oct-20 08:34:00 | 27.52 | 22-Oct-20 08:34:00 | 5.10 | 22-Oct-20 08:34:00 | 73,577 |
| 22-Oct-20 08:35:00 | 31.08 | 22-Oct-20 08:35:00 | 28.12 | 22-Oct-20 08:35:00 | 4.71 | 22-Oct-20 08:35:00 | 76,515 |
| 22-Oct-20 08:36:00 | 31.34 | 22-Oct-20 08:36:00 | 28.16 | 22-Oct-20 08:36:00 | 4.82 | 22-Oct-20 08:36:00 | 72,892 |
| 22-Oct-20 08:37:00 | 31.68 | 22-Oct-20 08:37:00 | 27.74 | 22-Oct-20 08:37:00 | 5.19 | 22-Oct-20 08:37:00 | 72,481 |
| 22-Oct-20 08:38:00 | 30.82 | 22-Oct-20 08:38:00 | 27.86 | 22-Oct-20 08:38:00 | 4.72 | 22-Oct-20 08:38:00 | 76,153 |
| Average Stack NOx, ppm (3% O2) | 31.30 | Average Stack Raw NOx, ppm | 27.99 | Average Stack O2 (%) | 4.89 | Average Gas Flow (SCFH) | 74,304 |

New-Indy Oxnard, LLC
 Nebraska Boiler CEMS RATA TEST - November 22, 2020

10/22/2020 9:39

10/22/2020 9:01 1 m

Rata 3

| NOx, ppm (3% O2) | | Raw NOx, ppm | | O2 (%) | | Gas Flow (SCFH) | |
|---------------------------------------|--------------|-----------------------------------|--------------|-----------------------------|-------------|--------------------------------|---------------|
| 931AI391_CNOX | | 931AI391.AT | | 931AI392.AT | | 931FI374B.R | |
| 22-Oct-20 08:39:00 | 31.21 | 22-Oct-20 08:39:00 | 27.84 | 22-Oct-20 08:39:00 | 4.93 | 22-Oct-20 08:39:00 | 71,957 |
| 22-Oct-20 08:40:00 | 30.88 | 22-Oct-20 08:40:00 | 27.39 | 22-Oct-20 08:40:00 | 5.01 | 22-Oct-20 08:40:00 | 73,901 |
| 22-Oct-20 08:41:00 | 30.67 | 22-Oct-20 08:41:00 | 27.52 | 22-Oct-20 08:41:00 | 4.83 | 22-Oct-20 08:41:00 | 76,200 |
| 22-Oct-20 08:42:00 | 31.50 | 22-Oct-20 08:42:00 | 28.57 | 22-Oct-20 08:42:00 | 4.67 | 22-Oct-20 08:42:00 | 75,139 |
| 22-Oct-20 08:43:00 | 31.60 | 22-Oct-20 08:43:00 | 27.93 | 22-Oct-20 08:43:00 | 5.08 | 22-Oct-20 08:43:00 | 72,002 |
| 22-Oct-20 08:44:00 | 31.41 | 22-Oct-20 08:44:00 | 27.74 | 22-Oct-20 08:44:00 | 5.09 | 22-Oct-20 08:44:00 | 73,861 |
| 22-Oct-20 08:45:00 | 31.07 | 22-Oct-20 08:45:00 | 28.06 | 22-Oct-20 08:45:00 | 4.73 | 22-Oct-20 08:45:00 | 76,946 |
| 22-Oct-20 08:46:00 | 31.15 | 22-Oct-20 08:46:00 | 28.26 | 22-Oct-20 08:46:00 | 4.66 | 22-Oct-20 08:46:00 | 74,001 |
| 22-Oct-20 08:47:00 | 31.99 | 22-Oct-20 08:47:00 | 27.91 | 22-Oct-20 08:47:00 | 5.28 | 22-Oct-20 08:47:00 | 72,254 |
| 22-Oct-20 08:48:00 | 31.04 | 22-Oct-20 08:48:00 | 27.88 | 22-Oct-20 08:48:00 | 4.86 | 22-Oct-20 08:48:00 | 75,541 |
| 22-Oct-20 08:49:00 | 30.68 | 22-Oct-20 08:49:00 | 27.97 | 22-Oct-20 08:49:00 | 4.81 | 22-Oct-20 08:49:00 | 74,787 |
| 22-Oct-20 08:50:00 | 31.17 | 22-Oct-20 08:50:00 | 27.56 | 22-Oct-20 08:50:00 | 5.08 | 22-Oct-20 08:50:00 | 72,038 |
| 22-Oct-20 08:51:00 | 30.83 | 22-Oct-20 08:51:00 | 27.50 | 22-Oct-20 08:51:00 | 4.94 | 22-Oct-20 08:51:00 | 74,278 |
| 22-Oct-20 08:52:00 | 31.14 | 22-Oct-20 08:52:00 | 28.21 | 22-Oct-20 08:52:00 | 4.68 | 22-Oct-20 08:52:00 | 76,606 |
| 22-Oct-20 08:53:00 | 31.26 | 22-Oct-20 08:53:00 | 28.05 | 22-Oct-20 08:53:00 | 4.81 | 22-Oct-20 08:53:00 | 72,852 |
| 22-Oct-20 08:54:00 | 31.45 | 22-Oct-20 08:54:00 | 27.78 | 22-Oct-20 08:54:00 | 5.09 | 22-Oct-20 08:54:00 | 71,842 |
| 22-Oct-20 08:55:00 | 31.00 | 22-Oct-20 08:55:00 | 27.53 | 22-Oct-20 08:55:00 | 5.01 | 22-Oct-20 08:55:00 | 73,818 |
| 22-Oct-20 08:56:00 | 30.89 | 22-Oct-20 08:56:00 | 28.11 | 22-Oct-20 08:56:00 | 4.62 | 22-Oct-20 08:56:00 | 76,564 |
| 22-Oct-20 08:57:00 | 31.24 | 22-Oct-20 08:57:00 | 27.89 | 22-Oct-20 08:57:00 | 4.92 | 22-Oct-20 08:57:00 | 72,341 |
| 22-Oct-20 08:58:00 | 30.50 | 22-Oct-20 08:58:00 | 27.16 | 22-Oct-20 08:58:00 | 4.96 | 22-Oct-20 08:58:00 | 75,102 |
| 22-Oct-20 08:59:00 | 31.23 | 22-Oct-20 08:59:00 | 28.37 | 22-Oct-20 08:59:00 | 4.64 | 22-Oct-20 08:59:00 | 76,927 |
| 22-Oct-20 09:00:00 | 31.51 | 22-Oct-20 09:00:00 | 28.63 | 22-Oct-20 09:00:00 | 4.64 | 22-Oct-20 09:00:00 | 76,969 |
| Average Stack NOx, ppm (3% O2) | 31.16 | Average Stack Raw NOx, ppm | 27.90 | Average Stack O2 (%) | 4.87 | Average Gas Flow (SCFH) | 74,360 |

New-Indy Oxnard, LLC
 Nebraska Boiler CEMS RATA TEST - November 22, 2020

10/22/2020 9:18

10/22/2020 9:37

1 m

Rata 4

| NOx, ppm (3% O2) | | Raw NOx, ppm | | O2 (%) | | Gas Flow (SCFH) | |
|---------------------------------------|--------------|-----------------------------------|--------------|-----------------------------|-------------|--------------------------------|---------------|
| 931AI391_CN0X | | 931AI391.AY | | 931AI392.AY | | 931FI374B.R | |
| 22-Oct-20 09:15:00 | 30.43 | 22-Oct-20 09:15:00 | 27.89 | 22-Oct-20 09:15:00 | 4.49 | 22-Oct-20 09:15:00 | 75,454 |
| 22-Oct-20 09:16:00 | 30.94 | 22-Oct-20 09:16:00 | 27.50 | 22-Oct-20 09:16:00 | 4.99 | 22-Oct-20 09:16:00 | 72,222 |
| 22-Oct-20 09:17:00 | 30.61 | 22-Oct-20 09:17:00 | 27.28 | 22-Oct-20 09:17:00 | 4.94 | 22-Oct-20 09:17:00 | 75,513 |
| 22-Oct-20 09:18:00 | 30.95 | 22-Oct-20 09:18:00 | 28.29 | 22-Oct-20 09:18:00 | 4.54 | 22-Oct-20 09:18:00 | 76,541 |
| 22-Oct-20 09:19:00 | 31.46 | 22-Oct-20 09:19:00 | 27.86 | 22-Oct-20 09:19:00 | 5.05 | 22-Oct-20 09:19:00 | 71,364 |
| 22-Oct-20 09:20:00 | 30.66 | 22-Oct-20 09:20:00 | 27.29 | 22-Oct-20 09:20:00 | 4.97 | 22-Oct-20 09:20:00 | 74,975 |
| 22-Oct-20 09:21:00 | 30.74 | 22-Oct-20 09:21:00 | 27.95 | 22-Oct-20 09:21:00 | 4.62 | 22-Oct-20 09:21:00 | 75,189 |
| 22-Oct-20 09:22:00 | 30.94 | 22-Oct-20 09:22:00 | 27.32 | 22-Oct-20 09:22:00 | 5.10 | 22-Oct-20 09:22:00 | 71,781 |
| 22-Oct-20 09:23:00 | 30.61 | 22-Oct-20 09:23:00 | 27.25 | 22-Oct-20 09:23:00 | 4.96 | 22-Oct-20 09:23:00 | 75,915 |
| 22-Oct-20 09:24:00 | 31.28 | 22-Oct-20 09:24:00 | 28.20 | 22-Oct-20 09:24:00 | 4.77 | 22-Oct-20 09:24:00 | 73,909 |
| 22-Oct-20 09:25:00 | 31.07 | 22-Oct-20 09:25:00 | 27.17 | 22-Oct-20 09:25:00 | 5.24 | 22-Oct-20 09:25:00 | 71,896 |
| 22-Oct-20 09:26:00 | 30.61 | 22-Oct-20 09:26:00 | 27.52 | 22-Oct-20 09:26:00 | 4.81 | 22-Oct-20 09:26:00 | 75,792 |
| 22-Oct-20 09:27:00 | 30.56 | 22-Oct-20 09:27:00 | 27.78 | 22-Oct-20 09:27:00 | 4.63 | 22-Oct-20 09:27:00 | 76,657 |
| 22-Oct-20 09:28:00 | 30.38 | 22-Oct-20 09:28:00 | 27.90 | 22-Oct-20 09:28:00 | 4.46 | 22-Oct-20 09:28:00 | 81,475 |
| 22-Oct-20 09:29:00 | 30.77 | 22-Oct-20 09:29:00 | 28.00 | 22-Oct-20 09:29:00 | 4.57 | 22-Oct-20 09:29:00 | 75,213 |
| 22-Oct-20 09:30:00 | 30.70 | 22-Oct-20 09:30:00 | 26.68 | 22-Oct-20 09:30:00 | 5.35 | 22-Oct-20 09:30:00 | 71,165 |
| 22-Oct-20 09:31:00 | 30.77 | 22-Oct-20 09:31:00 | 27.34 | 22-Oct-20 09:31:00 | 4.97 | 22-Oct-20 09:31:00 | 75,404 |
| 22-Oct-20 09:32:00 | 30.91 | 22-Oct-20 09:32:00 | 28.09 | 22-Oct-20 09:32:00 | 4.63 | 22-Oct-20 09:32:00 | 76,962 |
| 22-Oct-20 09:33:00 | 32.13 | 22-Oct-20 09:33:00 | 28.70 | 22-Oct-20 09:33:00 | 4.92 | 22-Oct-20 09:33:00 | 73,269 |
| 22-Oct-20 09:34:00 | 30.99 | 22-Oct-20 09:34:00 | 27.21 | 22-Oct-20 09:34:00 | 5.18 | 22-Oct-20 09:34:00 | 73,971 |
| 22-Oct-20 09:35:00 | 30.81 | 22-Oct-20 09:35:00 | 27.91 | 22-Oct-20 09:35:00 | 4.69 | 22-Oct-20 09:35:00 | 76,657 |
| 22-Oct-20 09:36:00 | 31.33 | 22-Oct-20 09:36:00 | 28.08 | 22-Oct-20 09:36:00 | 4.86 | 22-Oct-20 09:36:00 | 73,084 |
| Average Stack NOx, ppm (3% O2) | 30.89 | Average Stack Raw NOx, ppm | 27.69 | Average Stack O2 (%) | 4.85 | Average Gas Flow (SCFH) | 74,746 |

New-Indy Oxnard, LLC
 Nebraska Boiler CEMS RATA TEST - November 22, 2020

10/22/2020 9:37

10/22/2020 9:59 1 m

Ratus

| NOx, ppm (3% O2) | | Raw NOx, ppm | | O2 (%) | | Gas Flow (SCFH) | |
|---------------------------------------|--------------|-----------------------------------|--------------|-----------------------------|-------------|--------------------------------|---------------|
| 931AI391_CNOX | | 931AI391.AT | | 931AI392.AT | | 931FI374B.ft | |
| 22-Oct-20 09:37:00 | 31.09 | 22-Oct-20 09:37:00 | 27.40 | 22-Oct-20 09:37:00 | 5.13 | 22-Oct-20 09:37:00 | 74,379 |
| 22-Oct-20 09:38:00 | 30.45 | 22-Oct-20 09:38:00 | 27.65 | 22-Oct-20 09:38:00 | 4.64 | 22-Oct-20 09:38:00 | 76,551 |
| 22-Oct-20 09:39:00 | 30.69 | 22-Oct-20 09:39:00 | 27.39 | 22-Oct-20 09:39:00 | 4.93 | 22-Oct-20 09:39:00 | 72,851 |
| 22-Oct-20 09:40:00 | 30.66 | 22-Oct-20 09:40:00 | 26.95 | 22-Oct-20 09:40:00 | 5.16 | 22-Oct-20 09:40:00 | 74,537 |
| 22-Oct-20 09:41:00 | 30.41 | 22-Oct-20 09:41:00 | 27.65 | 22-Oct-20 09:41:00 | 4.63 | 22-Oct-20 09:41:00 | 76,073 |
| 22-Oct-20 09:42:00 | 31.05 | 22-Oct-20 09:42:00 | 27.55 | 22-Oct-20 09:42:00 | 5.01 | 22-Oct-20 09:42:00 | 72,108 |
| 22-Oct-20 09:43:00 | 30.95 | 22-Oct-20 09:43:00 | 27.32 | 22-Oct-20 09:43:00 | 5.10 | 22-Oct-20 09:43:00 | 74,188 |
| 22-Oct-20 09:44:00 | 30.28 | 22-Oct-20 09:44:00 | 27.39 | 22-Oct-20 09:44:00 | 4.70 | 22-Oct-20 09:44:00 | 78,834 |
| 22-Oct-20 09:45:00 | 30.82 | 22-Oct-20 09:45:00 | 27.64 | 22-Oct-20 09:45:00 | 4.85 | 22-Oct-20 09:45:00 | 73,172 |
| 22-Oct-20 09:46:00 | 31.06 | 22-Oct-20 09:46:00 | 27.08 | 22-Oct-20 09:46:00 | 5.29 | 22-Oct-20 09:46:00 | 72,343 |
| 22-Oct-20 09:47:00 | 30.10 | 22-Oct-20 09:47:00 | 27.09 | 22-Oct-20 09:47:00 | 4.86 | 22-Oct-20 09:47:00 | 76,135 |
| 22-Oct-20 09:48:00 | 30.47 | 22-Oct-20 09:48:00 | 27.75 | 22-Oct-20 09:48:00 | 4.60 | 22-Oct-20 09:48:00 | 75,698 |
| 22-Oct-20 09:49:00 | 30.35 | 22-Oct-20 09:49:00 | 27.03 | 22-Oct-20 09:49:00 | 4.96 | 22-Oct-20 09:49:00 | 74,167 |
| 22-Oct-20 09:50:00 | 30.21 | 22-Oct-20 09:50:00 | 27.60 | 22-Oct-20 09:50:00 | 4.55 | 22-Oct-20 09:50:00 | 78,060 |
| 22-Oct-20 09:51:00 | 30.62 | 22-Oct-20 09:51:00 | 28.19 | 22-Oct-20 09:51:00 | 4.42 | 22-Oct-20 09:51:00 | 79,171 |
| 22-Oct-20 09:52:00 | 30.73 | 22-Oct-20 09:52:00 | 27.86 | 22-Oct-20 09:52:00 | 4.67 | 22-Oct-20 09:52:00 | 74,936 |
| 22-Oct-20 09:53:00 | 30.95 | 22-Oct-20 09:53:00 | 27.13 | 22-Oct-20 09:53:00 | 5.21 | 22-Oct-20 09:53:00 | 74,718 |
| 22-Oct-20 09:54:00 | 30.47 | 22-Oct-20 09:54:00 | 27.45 | 22-Oct-20 09:54:00 | 4.78 | 22-Oct-20 09:54:00 | 75,905 |
| 22-Oct-20 09:55:00 | 30.49 | 22-Oct-20 09:55:00 | 27.39 | 22-Oct-20 09:55:00 | 4.79 | 22-Oct-20 09:55:00 | 74,167 |
| 22-Oct-20 09:56:00 | 31.04 | 22-Oct-20 09:56:00 | 27.05 | 22-Oct-20 09:56:00 | 5.30 | 22-Oct-20 09:56:00 | 71,952 |
| 22-Oct-20 09:57:00 | 30.67 | 22-Oct-20 09:57:00 | 27.45 | 22-Oct-20 09:57:00 | 4.88 | 22-Oct-20 09:57:00 | 76,308 |
| 22-Oct-20 09:58:00 | 29.56 | 22-Oct-20 09:58:00 | 26.67 | 22-Oct-20 09:58:00 | 4.75 | 22-Oct-20 09:58:00 | 75,337 |
| Average Stack NOx, ppm (3% O2) | 30.60 | Average Stack Raw NOx, ppm | 27.39 | Average Stack O2 (%) | 4.87 | Average Gas Flow (SCFH) | 74,981 |

New-Indy Oxnard, LLC
 Nebraska Boiler CEMS RATA TEST - November 22, 2020

10/22/2020 9:59 10/22/2020 10:21 1 m

Rata 6

| NOx, ppm (3% O2) | | Raw NOx, ppm | | O2 (%) | | Gas Flow (SCFH) | |
|---------------------------------------|--------------|-----------------------------------|--------------|-----------------------------|-------------|--------------------------------|---------------|
| 931AI391_CNOX | | 931AI391_AT | | 931AI392AT | | 931FI374B.R | |
| 22-Oct-20 09:59:00 | 30.75 | 22-Oct-20 09:59:00 | 26.93 | 22-Oct-20 09:59:00 | 5.22 | 22-Oct-20 09:59:00 | 73,330 |
| 22-Oct-20 10:00:00 | 30.00 | 22-Oct-20 10:00:00 | 27.42 | 22-Oct-20 10:00:00 | 4.54 | 22-Oct-20 10:00:00 | 76,736 |
| 22-Oct-20 10:01:00 | 30.46 | 22-Oct-20 10:01:00 | 27.70 | 22-Oct-20 10:01:00 | 4.62 | 22-Oct-20 10:01:00 | 73,893 |
| 22-Oct-20 10:02:00 | 30.07 | 22-Oct-20 10:02:00 | 26.83 | 22-Oct-20 10:02:00 | 4.93 | 22-Oct-20 10:02:00 | 74,470 |
| 22-Oct-20 10:03:00 | 29.63 | 22-Oct-20 10:03:00 | 27.15 | 22-Oct-20 10:03:00 | 4.50 | 22-Oct-20 10:03:00 | 76,771 |
| 22-Oct-20 10:04:00 | 30.55 | 22-Oct-20 10:04:00 | 27.60 | 22-Oct-20 10:04:00 | 4.73 | 22-Oct-20 10:04:00 | 73,399 |
| 22-Oct-20 10:05:00 | 30.43 | 22-Oct-20 10:05:00 | 26.96 | 22-Oct-20 10:05:00 | 5.04 | 22-Oct-20 10:05:00 | 73,503 |
| 22-Oct-20 10:06:00 | 30.46 | 22-Oct-20 10:06:00 | 27.78 | 22-Oct-20 10:06:00 | 4.57 | 22-Oct-20 10:06:00 | 76,989 |
| 22-Oct-20 10:07:00 | 30.45 | 22-Oct-20 10:07:00 | 27.81 | 22-Oct-20 10:07:00 | 4.55 | 22-Oct-20 10:07:00 | 74,541 |
| 22-Oct-20 10:08:00 | 30.40 | 22-Oct-20 10:08:00 | 26.89 | 22-Oct-20 10:08:00 | 5.03 | 22-Oct-20 10:08:00 | 72,236 |
| 22-Oct-20 10:09:00 | 29.96 | 22-Oct-20 10:09:00 | 26.74 | 22-Oct-20 10:09:00 | 4.92 | 22-Oct-20 10:09:00 | 75,666 |
| 22-Oct-20 10:10:00 | 30.26 | 22-Oct-20 10:10:00 | 27.73 | 22-Oct-20 10:10:00 | 4.50 | 22-Oct-20 10:10:00 | 76,873 |
| 22-Oct-20 10:11:00 | 30.60 | 22-Oct-20 10:11:00 | 27.33 | 22-Oct-20 10:11:00 | 4.91 | 22-Oct-20 10:11:00 | 72,608 |
| 22-Oct-20 10:12:00 | 30.24 | 22-Oct-20 10:12:00 | 26.71 | 22-Oct-20 10:12:00 | 5.09 | 22-Oct-20 10:12:00 | 73,423 |
| 22-Oct-20 10:13:00 | 29.76 | 22-Oct-20 10:13:00 | 26.93 | 22-Oct-20 10:13:00 | 4.73 | 22-Oct-20 10:13:00 | 75,519 |
| 22-Oct-20 10:14:00 | 29.72 | 22-Oct-20 10:14:00 | 26.91 | 22-Oct-20 10:14:00 | 4.69 | 22-Oct-20 10:14:00 | 75,565 |
| 22-Oct-20 10:15:00 | 30.63 | 22-Oct-20 10:15:00 | 27.57 | 22-Oct-20 10:15:00 | 4.79 | 22-Oct-20 10:15:00 | 74,258 |
| 22-Oct-20 10:16:00 | 30.78 | 22-Oct-20 10:16:00 | 27.04 | 22-Oct-20 10:16:00 | 5.17 | 22-Oct-20 10:16:00 | 72,722 |
| 22-Oct-20 10:17:00 | 30.08 | 22-Oct-20 10:17:00 | 27.27 | 22-Oct-20 10:17:00 | 4.67 | 22-Oct-20 10:17:00 | 76,666 |
| 22-Oct-20 10:18:00 | 29.82 | 22-Oct-20 10:18:00 | 27.22 | 22-Oct-20 10:18:00 | 4.66 | 22-Oct-20 10:18:00 | 76,083 |
| 22-Oct-20 10:19:00 | 30.45 | 22-Oct-20 10:19:00 | 27.12 | 22-Oct-20 10:19:00 | 4.95 | 22-Oct-20 10:19:00 | 72,480 |
| 22-Oct-20 10:20:00 | 29.82 | 22-Oct-20 10:20:00 | 26.81 | 22-Oct-20 10:20:00 | 4.80 | 22-Oct-20 10:20:00 | 76,150 |
| Average Stack NOx, ppm (3% O2) | 30.24 | Average Stack Raw NOx, ppm | 27.20 | Average Stack O2 (%) | 4.80 | Average Gas Flow (SCFH) | 74,717 |

New-Indy Oxnard, LLC
 Nebraska Boiler CEMS RATA TEST - November 22, 2020

10/22/2020 10:35

10/22/2020 10:57 1 m

Kater

| NOx, ppm (3% O2) | | Raw NOx, ppm | | O2 (%) | | Gas Flow (SCFH) | |
|---------------------------------------|--------------|-----------------------------------|--------------|-----------------------------|-------------|--------------------------------|---------------|
| 931AI391_CNOX | | 931AI391.AT | | 931AI392.AT | | 931FI374B.R | |
| 22-Oct-20 10:35:00 | 30.84 | 22-Oct-20 10:35:00 | 27.17 | 22-Oct-20 10:35:00 | 5.12 | 22-Oct-20 10:35:00 | 72,070 |
| 22-Oct-20 10:36:00 | 30.01 | 22-Oct-20 10:36:00 | 26.95 | 22-Oct-20 10:36:00 | 4.82 | 22-Oct-20 10:36:00 | 76,456 |
| 22-Oct-20 10:37:00 | 30.51 | 22-Oct-20 10:37:00 | 27.75 | 22-Oct-20 10:37:00 | 4.62 | 22-Oct-20 10:37:00 | 75,237 |
| 22-Oct-20 10:38:00 | 30.61 | 22-Oct-20 10:38:00 | 26.80 | 22-Oct-20 10:38:00 | 5.22 | 22-Oct-20 10:38:00 | 70,998 |
| 22-Oct-20 10:39:00 | 30.39 | 22-Oct-20 10:39:00 | 26.95 | 22-Oct-20 10:39:00 | 5.03 | 22-Oct-20 10:39:00 | 73,547 |
| 22-Oct-20 10:40:00 | 29.77 | 22-Oct-20 10:40:00 | 26.85 | 22-Oct-20 10:40:00 | 4.76 | 22-Oct-20 10:40:00 | 76,045 |
| 22-Oct-20 10:41:00 | 29.95 | 22-Oct-20 10:41:00 | 26.91 | 22-Oct-20 10:41:00 | 4.82 | 22-Oct-20 10:41:00 | 71,147 |
| 22-Oct-20 10:42:00 | 30.54 | 22-Oct-20 10:42:00 | 26.62 | 22-Oct-20 10:42:00 | 5.30 | 22-Oct-20 10:42:00 | 71,960 |
| 22-Oct-20 10:43:00 | 29.98 | 22-Oct-20 10:43:00 | 26.90 | 22-Oct-20 10:43:00 | 4.84 | 22-Oct-20 10:43:00 | 73,709 |
| 22-Oct-20 10:44:00 | 29.59 | 22-Oct-20 10:44:00 | 26.56 | 22-Oct-20 10:44:00 | 4.83 | 22-Oct-20 10:44:00 | 73,519 |
| 22-Oct-20 10:45:00 | 30.39 | 22-Oct-20 10:45:00 | 26.80 | 22-Oct-20 10:45:00 | 5.12 | 22-Oct-20 10:45:00 | 70,523 |
| 22-Oct-20 10:46:00 | 30.20 | 22-Oct-20 10:46:00 | 26.76 | 22-Oct-20 10:46:00 | 5.04 | 22-Oct-20 10:46:00 | 73,549 |
| 22-Oct-20 10:47:00 | 30.19 | 22-Oct-20 10:47:00 | 27.45 | 22-Oct-20 10:47:00 | 4.62 | 22-Oct-20 10:47:00 | 76,405 |
| 22-Oct-20 10:48:00 | 30.01 | 22-Oct-20 10:48:00 | 26.79 | 22-Oct-20 10:48:00 | 4.92 | 22-Oct-20 10:48:00 | 70,961 |
| 22-Oct-20 10:49:00 | 29.94 | 22-Oct-20 10:49:00 | 26.39 | 22-Oct-20 10:49:00 | 5.11 | 22-Oct-20 10:49:00 | 72,903 |
| 22-Oct-20 10:50:00 | 29.47 | 22-Oct-20 10:50:00 | 26.50 | 22-Oct-20 10:50:00 | 4.80 | 22-Oct-20 10:50:00 | 73,379 |
| 22-Oct-20 10:51:00 | 30.05 | 22-Oct-20 10:51:00 | 27.00 | 22-Oct-20 10:51:00 | 4.82 | 22-Oct-20 10:51:00 | 73,421 |
| 22-Oct-20 10:52:00 | 30.22 | 22-Oct-20 10:52:00 | 27.16 | 22-Oct-20 10:52:00 | 4.81 | 22-Oct-20 10:52:00 | 73,474 |
| 22-Oct-20 10:53:00 | 29.82 | 22-Oct-20 10:53:00 | 26.79 | 22-Oct-20 10:53:00 | 4.82 | 22-Oct-20 10:53:00 | 73,461 |
| 22-Oct-20 10:54:00 | 30.39 | 22-Oct-20 10:54:00 | 27.12 | 22-Oct-20 10:54:00 | 4.93 | 22-Oct-20 10:54:00 | 71,091 |
| 22-Oct-20 10:55:00 | 29.55 | 22-Oct-20 10:55:00 | 26.24 | 22-Oct-20 10:55:00 | 5.00 | 22-Oct-20 10:55:00 | 73,327 |
| 22-Oct-20 10:56:00 | 28.88 | 22-Oct-20 10:56:00 | 27.06 | 22-Oct-20 10:56:00 | 4.68 | 22-Oct-20 10:56:00 | 74,239 |
| Average Stack NOx, ppm (3% O2) | 30.10 | Average Stack Raw NOx, ppm | 26.89 | Average Stack O2 (%) | 4.91 | Average Gas Flow (SCFH) | 73,246 |

New-Indy Oxnard, LLC
 Nebraska Boiler CEMS RATA TEST - November 22, 2020

10/22/2020 10:57 10/22/2020 11:10 1 m

Ruler 8

| NOx, ppm (3% O2) | | Raw NOx, ppm | | O2 (%) | | Gas Flow (SCFH) | |
|---------------------------------------|--------------|-----------------------------------|--------------|-----------------------------|-------------|--------------------------------|---------------|
| 931AI391_CNOX | | 931AI391.AT | | 931AI392.AT | | 931FJ374B.ft | |
| 22-Oct-20 10:57:00 | 29.88 | 22-Oct-20 10:57:00 | 26.62 | 22-Oct-20 10:57:00 | 4.96 | 22-Oct-20 10:57:00 | 70,945 |
| 22-Oct-20 10:58:00 | 29.83 | 22-Oct-20 10:58:00 | 26.48 | 22-Oct-20 10:58:00 | 5.01 | 22-Oct-20 10:58:00 | 72,731 |
| 22-Oct-20 10:59:00 | 29.96 | 22-Oct-20 10:59:00 | 27.23 | 22-Oct-20 10:59:00 | 4.63 | 22-Oct-20 10:59:00 | 74,778 |
| 22-Oct-20 11:00:00 | 29.94 | 22-Oct-20 11:00:00 | 26.70 | 22-Oct-20 11:00:00 | 4.94 | 22-Oct-20 11:00:00 | 70,905 |
| 22-Oct-20 11:01:00 | 30.16 | 22-Oct-20 11:01:00 | 26.78 | 22-Oct-20 11:01:00 | 5.00 | 22-Oct-20 11:01:00 | 72,583 |
| 22-Oct-20 11:02:00 | 29.38 | 22-Oct-20 11:02:00 | 26.78 | 22-Oct-20 11:02:00 | 4.59 | 22-Oct-20 11:02:00 | 75,972 |
| 22-Oct-20 11:03:00 | 29.67 | 22-Oct-20 11:03:00 | 26.93 | 22-Oct-20 11:03:00 | 4.65 | 22-Oct-20 11:03:00 | 72,648 |
| 22-Oct-20 11:04:00 | 29.78 | 22-Oct-20 11:04:00 | 26.60 | 22-Oct-20 11:04:00 | 4.98 | 22-Oct-20 11:04:00 | 71,628 |
| 22-Oct-20 11:05:00 | 30.10 | 22-Oct-20 11:05:00 | 26.79 | 22-Oct-20 11:05:00 | 4.97 | 22-Oct-20 11:05:00 | 72,220 |
| 22-Oct-20 11:06:00 | 29.17 | 22-Oct-20 11:06:00 | 26.21 | 22-Oct-20 11:06:00 | 4.82 | 22-Oct-20 11:06:00 | 72,993 |
| 22-Oct-20 11:07:00 | 29.02 | 22-Oct-20 11:07:00 | 26.39 | 22-Oct-20 11:07:00 | 4.61 | 22-Oct-20 11:07:00 | 75,410 |
| 22-Oct-20 11:08:00 | 29.82 | 22-Oct-20 11:08:00 | 27.00 | 22-Oct-20 11:08:00 | 4.69 | 22-Oct-20 11:08:00 | 72,097 |
| 22-Oct-20 11:09:00 | 29.90 | 22-Oct-20 11:09:00 | 26.61 | 22-Oct-20 11:09:00 | 4.97 | 22-Oct-20 11:09:00 | 71,378 |
| 22-Oct-20 11:10:00 | 29.52 | 22-Oct-20 11:10:00 | 26.33 | 22-Oct-20 11:10:00 | 4.93 | 22-Oct-20 11:10:00 | 71,445 |
| 22-Oct-20 11:11:00 | 29.51 | 22-Oct-20 11:11:00 | 26.50 | 22-Oct-20 11:11:00 | 4.83 | 22-Oct-20 11:11:00 | 73,061 |
| 22-Oct-20 11:12:00 | 29.52 | 22-Oct-20 11:12:00 | 26.66 | 22-Oct-20 11:12:00 | 4.74 | 22-Oct-20 11:12:00 | 73,694 |
| 22-Oct-20 11:13:00 | 29.58 | 22-Oct-20 11:13:00 | 26.73 | 22-Oct-20 11:13:00 | 4.72 | 22-Oct-20 11:13:00 | 73,754 |
| 22-Oct-20 11:14:00 | 29.63 | 22-Oct-20 11:14:00 | 26.80 | 22-Oct-20 11:14:00 | 4.71 | 22-Oct-20 11:14:00 | 72,390 |
| 22-Oct-20 11:15:00 | 29.84 | 22-Oct-20 11:15:00 | 26.29 | 22-Oct-20 11:15:00 | 5.13 | 22-Oct-20 11:15:00 | 70,842 |
| 22-Oct-20 11:16:00 | 29.38 | 22-Oct-20 11:16:00 | 26.50 | 22-Oct-20 11:16:00 | 4.76 | 22-Oct-20 11:16:00 | 73,847 |
| 22-Oct-20 11:17:00 | 29.70 | 22-Oct-20 11:17:00 | 26.97 | 22-Oct-20 11:17:00 | 4.65 | 22-Oct-20 11:17:00 | 73,791 |
| 22-Oct-20 11:18:00 | 29.32 | 22-Oct-20 11:18:00 | 26.59 | 22-Oct-20 11:18:00 | 4.66 | 22-Oct-20 11:18:00 | 73,156 |
| Average Stack NOx, ppm (3% O2) | 29.66 | Average Stack Raw NOx, ppm | 26.66 | Average Stack O2 (%) | 4.82 | Average Gas Flow (SCFH) | 72,829 |

New-Indy Oxnard, LLC
 Nebraska Boiler CEMS RATA TEST - November 22, 2020

10/22/2020 11:19 10/22/2020 11:41 1 m

Rata 9

| NOx, ppm (3% O2) | | Raw NOx, ppm | | O2 (%) | | Gas Flow (SCFH) | |
|---------------------------------------|--------------|-----------------------------------|--------------|-----------------------------|-------------|--------------------------------|---------------|
| 931AI391_CNOX | | 931AI391.AT | | 931AI392.AT | | 931FI374B.ft | |
| 22-Oct-20 11:19:00 | 29.60 | 22-Oct-20 11:19:00 | 26.39 | 22-Oct-20 11:19:00 | 4.94 | 22-Oct-20 11:19:00 | 72,871 |
| 22-Oct-20 11:20:00 | 29.49 | 22-Oct-20 11:20:00 | 26.84 | 22-Oct-20 11:20:00 | 4.61 | 22-Oct-20 11:20:00 | 74,039 |
| 22-Oct-20 11:21:00 | 29.66 | 22-Oct-20 11:21:00 | 27.00 | 22-Oct-20 11:21:00 | 4.60 | 22-Oct-20 11:21:00 | 73,756 |
| 22-Oct-20 11:22:00 | 30.20 | 22-Oct-20 11:22:00 | 26.85 | 22-Oct-20 11:22:00 | 4.98 | 22-Oct-20 11:22:00 | 70,269 |
| 22-Oct-20 11:23:00 | 29.88 | 22-Oct-20 11:23:00 | 26.28 | 22-Oct-20 11:23:00 | 5.16 | 22-Oct-20 11:23:00 | 71,492 |
| 22-Oct-20 11:24:00 | 29.61 | 22-Oct-20 11:24:00 | 26.59 | 22-Oct-20 11:24:00 | 4.82 | 22-Oct-20 11:24:00 | 73,618 |
| 22-Oct-20 11:25:00 | 29.66 | 22-Oct-20 11:25:00 | 26.51 | 22-Oct-20 11:25:00 | 4.90 | 22-Oct-20 11:25:00 | 70,661 |
| 22-Oct-20 11:26:00 | 30.19 | 22-Oct-20 11:26:00 | 26.56 | 22-Oct-20 11:26:00 | 5.16 | 22-Oct-20 11:26:00 | 70,590 |
| 22-Oct-20 11:27:00 | 30.21 | 22-Oct-20 11:27:00 | 26.98 | 22-Oct-20 11:27:00 | 4.91 | 22-Oct-20 11:27:00 | 71,696 |
| 22-Oct-20 11:28:00 | 29.43 | 22-Oct-20 11:28:00 | 26.33 | 22-Oct-20 11:28:00 | 4.88 | 22-Oct-20 11:28:00 | 71,655 |
| 22-Oct-20 11:29:00 | 29.48 | 22-Oct-20 11:29:00 | 26.39 | 22-Oct-20 11:29:00 | 4.88 | 22-Oct-20 11:29:00 | 70,288 |
| 22-Oct-20 11:30:00 | 30.00 | 22-Oct-20 11:30:00 | 26.26 | 22-Oct-20 11:30:00 | 5.23 | 22-Oct-20 11:30:00 | 69,630 |
| 22-Oct-20 11:31:00 | 29.52 | 22-Oct-20 11:31:00 | 26.47 | 22-Oct-20 11:31:00 | 4.85 | 22-Oct-20 11:31:00 | 71,913 |
| 22-Oct-20 11:32:00 | 29.31 | 22-Oct-20 11:32:00 | 26.62 | 22-Oct-20 11:32:00 | 4.65 | 22-Oct-20 11:32:00 | 72,072 |
| 22-Oct-20 11:33:00 | 29.97 | 22-Oct-20 11:33:00 | 26.57 | 22-Oct-20 11:33:00 | 5.02 | 22-Oct-20 11:33:00 | 69,046 |
| 22-Oct-20 11:34:00 | 29.61 | 22-Oct-20 11:34:00 | 26.27 | 22-Oct-20 11:34:00 | 5.02 | 22-Oct-20 11:34:00 | 70,728 |
| 22-Oct-20 11:35:00 | 29.21 | 22-Oct-20 11:35:00 | 26.39 | 22-Oct-20 11:35:00 | 4.73 | 22-Oct-20 11:35:00 | 72,413 |
| 22-Oct-20 11:36:00 | 29.21 | 22-Oct-20 11:36:00 | 26.52 | 22-Oct-20 11:36:00 | 4.64 | 22-Oct-20 11:36:00 | 72,433 |
| 22-Oct-20 11:37:00 | 29.11 | 22-Oct-20 11:37:00 | 26.42 | 22-Oct-20 11:37:00 | 4.62 | 22-Oct-20 11:37:00 | 71,320 |
| 22-Oct-20 11:38:00 | 29.61 | 22-Oct-20 11:38:00 | 26.27 | 22-Oct-20 11:38:00 | 5.01 | 22-Oct-20 11:38:00 | 70,340 |
| 22-Oct-20 11:39:00 | 28.97 | 22-Oct-20 11:39:00 | 26.08 | 22-Oct-20 11:39:00 | 4.78 | 22-Oct-20 11:39:00 | 72,495 |
| 22-Oct-20 11:40:00 | 28.77 | 22-Oct-20 11:40:00 | 26.32 | 22-Oct-20 11:40:00 | 4.53 | 22-Oct-20 11:40:00 | 72,327 |
| Average Stack NOx, ppm (3% O2) | 29.58 | Average Stack Raw NOx, ppm | 26.50 | Average Stack O2 (%) | 4.86 | Average Gas Flow (SCFH) | 71,621 |


BOILER DATA SHEET

Client: New Indy
 Site: OXNARD
 Unit: Nabraska Boiler

Date: 10.22.20
 Client #: 23002
 Lab #: 220-113

Make: Nabraska
 S/N: 2D-1983
 Model: N8E9551
 BTU/hr Rating: 108 MMBTU/hr
 Fuel Type: NG
 FGR Equipped: YES

Stack Diameter: 44"
 "A" Distance: 7' (1.9 DD)
 "B" Distance: 15.5' (4.23 DD)
 Port Size: 2.5"
 M or F: Female
 Offset: 3 inch



Boiler Load: Run 1: Normal Run 2: Normal Run 3: Normal % of Rating
 FGR Setting: Run 1: 40.2 Run 2: 40.0 Run 3: 40.1
 Fuel: 70.7 % / 71.4 % / 71.4 %

Notes: _____

**EPA METHOD 20 MEASUREMENT
SYSTEM PERFORMANCE TIME**

RESPONSE TIME

DATE OF TEST: 10.22.20

PROBE LOCATION: STACK

ANALYZER TYPE & MODEL #

NOx: API 200EH

CO: -

O2: SERVOMEX 1400

Span Gas Concentration/Analyzer Full Scale Setting:

NOx; Gas, ppmv: 40.0

Full Scale setting, ppmv 50

CO; Gas, ppmv: -

Full Scale setting, ppmv -

O2; Gas, %: 8.05

Full Scale setting, % 25

UPSCALE TIME - Analyzer + Sampling System:

| Trial # | Nox | CO | O2 |
|------------------|-----------|----------|-------------------|
| 1 | <u>59</u> | <u>-</u> | <u>47</u> seconds |
| 2 | <u>60</u> | <u>-</u> | <u>46</u> seconds |
| 3 | <u>58</u> | <u>-</u> | <u>48</u> seconds |
| Average Response | <u>59</u> | <u>-</u> | <u>47</u> seconds |

DOWNSCALE - Analyzer + Sampling System:

| Trial # | Nox | CO | O2 |
|------------------|-----------|----------|-------------------|
| 1 | <u>56</u> | <u>-</u> | <u>45</u> seconds |
| 2 | <u>58</u> | <u>-</u> | <u>46</u> seconds |
| 3 | <u>57</u> | <u>-</u> | <u>46</u> seconds |
| Average Response | <u>57</u> | <u>-</u> | <u>46</u> seconds |

Slower
Average

60

-

48 seconds

| |
|--------------------------------------|
| DESCRIPTION OF METHOD(S) USED |
|--------------------------------------|

EPA Method 7 - Nitrogen Oxides (NOx)

Method 7: NOx from stationary sources

Applicability: Applicable range: $2 \text{ mg/m}^3 < [\text{NOx}]_{\text{as NO}_2} < 400 \text{ mg/m}^3$ (m^3 at dry standard conditions)

Principle: A grab sample is collected in a evacuated flask containing a dilute sulfuric acid-hydrogen peroxide absorbing solution, and the NOx (except NO) are measured colorimetrically using phenoldisulfonic acid.

Method 7A: NOx from stationary sources

Applicability: Applicable range: $125 \text{ mg/m}^3 (65 \text{ ppm}) < [\text{NOx}]_{\text{as NO}_2} < 1250 \text{ mg/m}^3 (655 \text{ ppm})$

Principle: A grab sample is collected in a evacuated flask containing a dilute sulfuric acid-hydrogen peroxide absorbing solution, and the NOx (except NO) are oxidized to nitrates and measured by ion chromatography.

Method 7B: NOx from nitric acid plants

Applicability: Applicable range: $57 \text{ mg/m}^3 (30 \text{ ppm}) < [\text{NOx}]_{\text{as NO}_2} < 1550 \text{ mg/m}^3 (786 \text{ ppm})$

Principle: A grab sample is collected in a evacuated flask containing a dilute sulfuric acid-hydrogen peroxide absorbing solution, and the NOx (except NO) are measured by ultraviolet absorption.

Method 7C and 7D: NOx from fossil fuel fired generators, electric utility plants or nitric acid plants

Applicability: Applicable range: $13 \text{ mg/m}^3 (7 \text{ ppm}) < [\text{NOx}]_{\text{as NO}_2} < 1782 \text{ mg/m}^3 (932 \text{ ppm})$

Principle: A grab sample is collected from the stack in alkaline-potassium permanganate solution. $\text{NOx} = \text{NO} + \text{NO}_2$

7C: NOx are oxidized to NO_2 and NO_3 . Cadmium is used to reduce NO_3 to NO_2 , which is analyzed colorimetrically.

7D: NOx are oxidized to NO_3 and analyzed by ion chromatography.

Method 7E: NOx from stationary source - Using Instrumental Analyzer

Analytical range: Determined by instrumental design. A portion of it is selected by choosing the span of the monitoring system. The span shall be selected such that the pollutant gas concentration equivalent to the emission standard is not less than 30% of the span. If at any time during the test, the pollutant concentration exceeds the span, the test is invalid.

Sensitivity: The Minimum Detection Limit (MDL) depends on the analytical range, the span, and the signal-to-noise ratio of the measurement system. The MDL should be less than 2% of the span.

Principle: A gas sample is continuously extracted from a stack and conveyed to a *chemiluminescent* analyzer for determination of NOx concentration.

Measurement system: Sample interface, Gas analyzer, Data recorder.

NO₂ to NO converter: Not necessary if the NO₂ portion of the exhaust gas is less than 5% of the total NOx concentration.

NOx analyzer: Based on the chemiluminescent reaction of NO and ozone to form NO₂ in an excited state. Light emission is monitored through an optical filter by a high sensitivity photomultiplier tube, the output of which is electrically processed so it is linearly proportional to the NO concentration.

NOx calibration gases (NO in N₂): Three calibration gases shall be used. Ambient air may be used for the zero gas.

CARB Method 100

Generalized Procedures For Continuous Gaseous Emission Stack Sampling

Principle: A sample of an exhaust gas stream is continuously extracted, conditioned, and analyzed by instruments to determine average emission concentrations. By combining this information with stack gas flowrate and moisture, mass emission rates can be determined.

Applicability: Determination of emissions of oxides of nitrogen, carbon monoxide, carbon dioxide, sulfur dioxide, total hydrocarbons, and oxygen from stationary sources flowing gas streams in ducts, stacks, and flues. This method is an alternative to EPA reference methods 3A, 6C, 7E, 10, and 25A and B.

Range: The range is selected so that the sample gas concentration for each run is between 10 and 95% of the range for each pollutant of interest.

Measurement system: Sample interface, Gas analyzer, Data acquisition

Probe Nozzle: Quartz, borosilicate, stainless steel, porcelain or aluminum oxide

Probe: Shall have an inside diameter of 6 mm or larger and shall be of one of the materials mentioned above

Sample line: Teflon or other material that does not alter the sample gas

Sample conditioner: capable of reducing sample gas temperature to 60°F or 20°F lower than ambient temp.

Probe filter: internal or external, to prevent accumulation of particulate in the measurement system

Probe Calibration System: allows calibration of the instruments by introducing calibration gases

Sample System Heaters: if needed, to prevent condensation of water or hydrocarbons

Gas analyzers: shall be housed in a temperature-controlled, vibration-free environment:

- CO & CO₂: Nondispersive infrared analyzer
- O₂ : Paramagnetic or electrochemical (fuel cell) analyzer
- Total HC : Flame ionization detector (FID) or nondispersive infrared analyzer (NDIR)
- NO_x : Chemiluminescent analyzer, minimum of 90% efficiency for NO₂ conversion
- SO₂ : Infrared or ultraviolet absorption or fluorescence analyzer

Data recorder: Provides a permanent record of gas analyzer data. Consist of a strip chart recorder and an electronic data logger capable of integration at ten second interval. Resolution or readability should be 0.5% of range.

Range: Upper limit of the gas concentration measurement range displayed on the data recorder

Calibration gas (CalGas): A gas of known concentration in an inert diluent gas

- High-Range: 80 to 100% of the range
- Mid-Range: 40 to 60% of the range
- Zero gas: impurity concentration < 0.25% of the range → Nitrogen

Analyzer calibration error: The difference between the known concentration of the CalGas and the gas concentration exhibited by the gas analyzer when the CalGas is introduced directly to the analyzer.

Performance Spec: less than 2% of the range for the zero, mid-range, and high-range CalGas.

Sampling system BIAS: The difference between the gas concentrations exhibited by the measurement system when CalGas is introduced at the sampling probe tip filter and when the same CalGas is introduced directly to the analyzer.

Performance Spec: less than 5% of the range for the zero, mid-range, and high-range CalGas.

Zero Drift: The difference in the measurement system responses at a zero concentration level during the initial calibration, and final calibration check after a test.

No adjustment to the measurement system is allowed at that point.

Performance Spec: less than 3% of the range over the period of each run.

Calibration Drift (or Span Drift): The difference in the measurement system responses at a mid-range

~~concentration level during the initial calibration, and final calibration check after a test.~~

No adjustment to the measurement system is allowed at that point.

Performance Spec: less than 3% of the range over the period of each run.

Response time: the time required for the system to display 95% of a step change in gas concentration on the data recorder.

Interference response: The output response of the measurement system to a component in the sample gas, other than the gas component being measured.

Performance Spec: less than 5% of the range.

Measurement System Performance Test Procedures:

- **Cleaning/Assembly of sample train:** Flush probe, lines and sample conditioner with Deionized Water, then acetone. Dry with filtered dry air. Assemble as shown in accompanying figure.
- **Pretest Leak Check:** Leak check the vacuum side of the assembly at the maximum pump vacuum.
- **Calibrate analyzers and data recorders:** Allow analyzers to warm up. Adjust system components to achieve manufacturer's recommended sampling rates. Introduce CalGases directly to the instruments and make all necessary adjustments to calibrate the analyzer and data recorder.
- **Analyzer calibration error check:** at the beginning of test run
 1. Introduce zero, mid-range, high range CalGas
 2. Make no adjustments to the system except those necessary to achieve the correct flow rate.
 3. If invalid calibration is exhibited (> 2% of the range), take corrective action and repeat check.
- **Sampling system BIAS check:** Mandatory
 1. Backflush gas through the probe as necessary to prevent particulate buildup
 2. Introduce zero, and either mid-range or high-range (whichever is closest to effluent concentration)
 3. Make no adjustments to the system except those necessary to achieve the correct flow rate.
 4. If invalid calibration is exhibited (> 5% of the range), take corrective action and repeat check.
 5. If adjustment to the analyzer is required, first repeat the analyzer calibration error check, then repeat the sampling system BIAS check.
- **Stratification check:** Select traverse points according to ARB Methods 1 and 2. Multipoint gas sampling (traversing) must be performed unless data is available to demonstrate the mean pollutant concentration is *less than 10% different* from any single point.

Sample Collection:

1. Insert probe in stack
2. If traversing required, leave probe at each position for at least the system response time + 1 minute.
3. Three sample runs is recommended. See District Rules and permit conditions for special requirements.
4. When test duration exceeds one hour, conduct system BIAS checks every 2 hours. Adjust settings as necessary, mark strip charts and record changes in log books.
5. Strip chart must include the following information: pollutant, source, range, calibration cylinder ID number, chart speeds, date, time, operator.
6. **At end of run, perform sampling system BIAS Check.** Make no adjustments except to flow rates.

INSTRUMENT INFORMATION


Method 100 – Sample Train Assembly

Probe:

1. AIRx Testing Services, Inc. uses a stainless steel sampling probe.
2. The probe is connected to the sample conditioner using a heated (if necessary) Teflon sampling line.

Sample Conditioner (Condenser System):

1. The sample conditioner consists of a moisture knock-out bottle immersed in an ice bath.
2. All parts of the conditioner exposed to the sample are either glass, stainless steel, or Teflon.
3. The sample conditioner is setup so that the sample gas is not bubbled through the condensate.
4. A temperature gauge is used to determine the temperature of the condenser outlet.



Manifold Panel & Strip Chart Recorder:

1. The sample gas exiting the condenser is transported to the instrument manifold panel.
2. The sample manifold directs the sample gas through to the various analyzers.
3. All components of the system that contact the sample are either stainless steel, Teflon, or glass.
4. The data is continuously recorded on a Soltec 10" strip chart recorder with a 1% resolution.

Calibration System:

1. The system is composed of the Analyzer Calibration and the System BIAS Check.
2. Certified Calibration gases are supplied to the analyzers for calibration purposes.
3. The selection of zero or span calibration gases or sample gas is accomplished by operation of selector knobs located on the main flow control panel.

Nitrogen Oxides: – Chemiluminescent Analyzer: Based on the chemiluminescent reaction of NO and ozone to form NO₂ in an excited state. Light emission is monitored through an optical filter by a high sensitivity photomultiplier tube, the output of which is electronically processed so it is linearly proportional to the NO concentration. The output is in units of ppmv.

Carbon Monoxide – Non-Dispersive Infrared (NDIR) Analyzer: Radiation from an infrared source is passed through a narrow band-pass filter and a multiple optical pass sample cell where absorption by the sample gas occurs. The infrared radiation exits the sample cell and falls on a solid state infrared detector. The output is in units of ppmv.

Oxygen – Electrochemical Analyzer: Oxygen in the flue gas sample diffuses through a Teflon membrane and is reduced on the surface of the cathode. A corresponding oxidation occurs at the anode and an electric current proportional to the concentration of oxygen is produced. The output is in units of percent O₂ by volume.

Carbon Dioxide – Non Dispersive Infrared (NDIR) Analyzer: The instrument measures the differential in infrared energy absorbed from energy beams passed through a reference cell (containing a gas selected to have minimal absorption of infrared energy in the wavelength absorbed by CO₂) and a sample cell through which the sample gas flows continuously. The output is in units of percent CO₂ by volume.

SOURCE EMISSION INSTRUMENTATION LIST

OXYGEN

| | |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <p>Unit No. - 5: Manufacturer: California Analytical Instruments Model No.: 110P Serial No.: T02034 Method: Paramagnetic Range (%) 0-5, 10, 25</p> | <p>Unit No. - 13: Manufacturer: Servomex Model No.: 1400 Serial No.: X1420/B707 Method: Paramagnetic Range (%) 0-25</p> |
| <p>Unit No. - 7: Manufacturer: Teledyne Model No.: 320-AX Serial No.: 108742 Method: Electrochemical Range (%) 0-5, 10, 25</p> | |
| <p>Unit No. - 9: Manufacturer: Servomex Model No.: 1400 Serial No.: 01420/B701/730 Method: Paramagnetic Range (%) 0-25, 100</p> | |
| <p>Unit No. - 10: Manufacturer: Servomex Model No.: 1400 Serial No.: 01420/B308 Method: Paramagnetic Range (%) 0-25</p> | |
| <p>Unit No. - 11: Manufacturer: Teledyne Model No.: 320-A Serial No.: 111211 Method: Electrochemical Range (%) 0-5, 10, 25</p> | |
| <p>Unit No. - 12: Manufacturer: Servomex Model No.: 1400 Serial No.: 01420/B7103 Method: Paramagnetic Range (%) 0-25, 100</p> | |



SOURCE EMISSION INSTRUMENTATION LIST

OXIDES OF NITROGEN

| | |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <p>Unit No. - 1: Manufacturer: API Model No.: 200 EH Serial No.: 233 Method: Chemiluminescence Range (ppmv) 0-5000</p> | <p>Unit No. - 6: Manufacturer: API Model No.: 200 A Serial No.: 1013 Method: Chemiluminescence Range (ppmv) 0-50</p> |
| <p>Unit No. - 2: Manufacturer: API Model No.: 200 EH Serial No.: 234 Method: Chemiluminescence Range (ppmv) 0-5000</p> | <p>Unit No. - 7: Manufacturer: Thermo Environmental (TECO) Model No.: 10AR Serial No.: 25559-221 Method: Chemiluminescence Range (ppmv) 0-2.5, 10, 25, 100, 250, 1000, 2500, 10000</p> |
| <p>Unit No. - 3: Manufacturer: API Model No.: 200 EH Serial No.: 109 Method: Chemiluminescence Range (ppmv) 0-5000</p> | <p>Unit No. - 8: Manufacturer: Thermo Environmental (TECO) Model No.: 10AR Serial No.: 38586-258 Method: Chemiluminescence Range (ppmv) 0-2.5, 10, 25, 100, 250, 1000, 2500, 10000</p> |
| <p>Unit No. - 4: Manufacturer: API Model No.: 200 EH Serial No.: 442 Method: Chemiluminescence Range (ppmv) 0-5000</p> | |
| <p>Unit No. - 5: Manufacturer: API Model No.: 200 EH Serial No.: 441 Method: Chemiluminescence Range (ppmv) 0-5000</p> | |



QUALITY ASSURANCE



Praxair
 5700 South Alameda Street
 Los Angeles, CA 90058
 Tel: (323) 585-2154 Fax: (714) 542-6689
 PGVPID: F22017

DocNumber: 000105588

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information:

PRAXAIR PKG OXNARD CA HPS
 455 E WOOLEY RD
 OXNARD CA 93030

Praxair Order Number: 70207599
 Customer P. O. Number:
 Customer Reference Number:

Fill Date: 2/27/2017
 Pair Number: NI CD803E-AS
 Lot Number: 109705811
 Cylinder Style & Outlet: AS CGA 580
 Cylinder Pressure & Volume: 2000 psig 140 cu. ft.

Certified Concentration:

| | | |
|------------------|----------------|-------------------------|
| Expiration Date: | 3/8/2025 | NIST Traceable |
| Cylinder Number: | CC60235 | Analytical Uncertainty: |
| 7.98 % | CARBON DIOXIDE | ± 0.4 % |
| 3.98 % | OXYGEN | ± 0.4 % |
| Balance | NITROGEN | |

Certification Information: Certification Date: 3/8/2017 Term: 96 Months Expiration Date: 3/8/2025
 This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1. Do Not Use this Standard if Pressure is less than 100 PSIG.

CO2 responses have been corrected for Oxygen IR Broadening effect. O2 responses have been corrected for CO2 interference.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: CARBON DIOXIDE

Requested Concentration: 8 %
 Certified Concentration: 7.98 %
 Instrument Used: Horiba VIA-510 S/N 574763031
 Analytical Method: NDIR
 Last Multipoint Calibration: 2/13/2017

| | | | |
|----------------------|------|------------------|----------|
| First Analysis Data: | | Date: | 3/8/2017 |
| Z: | 0 | R: | 6.98 |
| C: | 7.97 | Conc: | 7.985 |
| R: | 6.98 | Z: | 0 |
| C: | 7.97 | Conc: | 7.985 |
| Z: | 0 | C: | 7.97 |
| R: | 7 | Conc: | 7.985 |
| UOM: | % | Mean Test Assay: | 7.985 % |

Reference Standard Type: GMIS
 Ref. Std. Cylinder #: DT0008914
 Ref. Std. Conc: 7.00 %
 Ref. Std. Traceable to SRM #: 1674b
 SRM Sample #: 7-H-07
 SRM Cylinder #: FF10631

| | | | |
|-----------------------|---|------------------|-----|
| Second Analysis Data: | | Date: | |
| Z: | 0 | R: | 0 |
| C: | 0 | Conc: | 0 |
| R: | 0 | Z: | 0 |
| C: | 0 | Conc: | 0 |
| Z: | 0 | R: | 0 |
| C: | 0 | Conc: | 0 |
| UOM: | % | Mean Test Assay: | 0 % |

2. Component: OXYGEN

Requested Concentration: 4 %
 Certified Concentration: 3.98 %
 Instrument Used: OXYMAT SE
 Analytical Method: PARAMAGNETIC
 Last Multipoint Calibration: 3/3/2017

| | | | |
|----------------------|------|------------------|----------|
| First Analysis Data: | | Date: | 3/8/2017 |
| Z: | 0 | R: | 5.01 |
| C: | 3.97 | Conc: | 3.975 |
| R: | 5 | Z: | 0 |
| C: | 3.97 | Conc: | 3.975 |
| Z: | 0 | C: | 3.97 |
| R: | 5 | Conc: | 3.975 |
| UOM: | % | Mean Test Assay: | 3.975 % |

Reference Standard Type: GMIS
 Ref. Std. Cylinder #: CC244935
 Ref. Std. Conc: 5.01 %
 Ref. Std. Traceable to SRM #: 2658a
 SRM Sample #: 72-D-28
 SRM Cylinder #: CAL016862

| | | | |
|-----------------------|---|------------------|-----|
| Second Analysis Data: | | Date: | |
| Z: | 0 | R: | 0 |
| C: | 0 | Conc: | 0 |
| R: | 0 | Z: | 0 |
| C: | 0 | Conc: | 0 |
| Z: | 0 | R: | 0 |
| C: | 0 | Conc: | 0 |
| UOM: | % | Mean Test Assay: | 0 % |

Analyzed by:

Ying Yu

Ying Yu

Certified by:

Nassim Haddad

Information contained herein has been prepared at your request by qualified experts within Praxair Distribution, Inc. While we believe that the information is accurate within the limits of the analytical methods employed and is complete to the extent of the specific analyses performed, we make no warranty or representation as to the suitability of the use of the information for any purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall the liability of Praxair Distribution, Inc., arising out of the use of the information contained herein exceed the fee established for providing such information.



AIR LIQUIDE

Air Liquide America
Specialty Gases LLC



Intertek

RATA CLASS

Guaranteed +/- 1% Accuracy

8832 DICE ROAD, SANTA FE SPRINGS, CA 90670-2516

Phone: 800-323-2212

Fax: 562-464-5262

CERTIFICATE OF ACCURACY: EPA Protocol Gas

Assay Laboratory - PGVP Vendor ID: A52013

Document #: 51261428-004
P.O. No.: AIRX

Customer:

AIR LIQUIDE AMERICA SPECIALTY GASES LLC
8832 DICE ROAD
SANTA FE SPRINGS, CA 90670-2516

ALHC-HCF-FRESNO-MEDGAS (LOC 24337)
3703 BAGLEY AVENUE
TRANSFER ACCOUNT
FRESNO CA 93725
US.

ANALYTICAL INFORMATION Gas Type : CO2,O2,BALN

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; Procedure G-1.

EPA/600/R-12/531; May 2012. Do not use this standard if pressure is less than 100 psig.

Cylinder Number: CC160530 Certification Date: 02Jul2013 Exp. Date: 03Jul2021
Cylinder Pressure: 2000 PSIG Batch No: SBO0073261

| COMPONENT | CERTIFIED CONCENTRATION (Moles) | | ACCURACY ABSOLUTE / RELATIVE | | | |
|----------------|---------------------------------|---|------------------------------|---|---|------|
| CARBON DIOXIDE | 20.1 | % | .13 | % | / | .6 % |
| OXYGEN | 8.05 | % | .06 | % | / | .7 % |
| NITROGEN | BALANCE | | | | | |

TRACEABILITY

REFERENCE STANDARD

| COMPONENT | CONCENTRATION | UNCERTAINTY | CYLINDER | TYPE/SRM SAMPLE | EXP. DATE |
|----------------|---------------|-------------|----------|-----------------|-----------|
| CARBON DIOXIDE | 17.87 % | 0.110 % | K026459 | NTRM 1800/ | 01Mar2016 |
| OXYGEN | 10.03 % | 0.070 % | K027603 | NTRM 2658/ | 01Feb2016 |

ANALYTICAL METHOD

1st Analysis: 02Jul2013

| COMPONENT | INSTRUMENT | ANALYTICAL PRINCIPLE | CALIBRATED | CONCENTRATION |
|----------------|------------------------------|----------------------|------------|---------------|
| CARBON DIOXIDE | GC-TCD/HP 5890 H/3 140A38374 | GC | 20Jun2013 | 20.11 % |
| OXYGEN | GC-TCD/HP 5890 H/3 140A38374 | GC | 22Jun2013 | 8.051 % |

APPROVED BY:

DC
DC



CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information

PRAXAIR PKG OXNARD CA HPS
 455 E WOOLEY RD
 OXNARD CA 93030

Certificate Issuance Date: 06/27/2019

Praxair Order Number: 70998288
 Part Number: NI NO20ME-AS
 Customer PO Number: 78981976

Fill Date: 06/07/2019

Lot Number: 70086915805
 Cylinder Style & Outlet: AS CGA 560
 Cylinder Pressure and Volume: 2000 psig 140 ltr

Certified Concentration

| | | |
|------------------|--------------|----------------------|
| Expiration Date: | 06/27/2022 | NIST Traceable |
| Cylinder Number: | CC724456 | Expanded Uncertainty |
| 20.1 ppm | Nitric oxide | ± 0.5 % |
| Balance | Nitrogen | |

ProSpec EZ Cert



For Reference Only: NOx 20.2 ppm

Certification Information: Certification Date: 06/27/2019 Term: 36 Months Expiration Date: 06/27/2022

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1.
 Do Not Use this Standard if Pressure is less than 100 PSIG.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: Nitric oxide
 Requested Concentration: 20 ppm
 Certified Concentration: 20.1 ppm
 Instrument Used: Thermo Electron 42i-LS S/N 1030645077
 Analytical Method: Chemiluminescence
 Last Multipoint Calibration: 06/10/2019

Reference Standard: Type / Cylinder #: GMS / CC2819
 Concentration / Uncertainty: 19.90 ppm ±0.504%
 Expiration Date: 03/28/2022
 Traceable to: SRM # / Sample # / Cylinder #: APEX1161149 / NA / APEX1161149
 SRM Concentration / Uncertainty: 20.03 ppm / ±0.10 ppm
 SRM Expiration Date: 01/27/2020

| First Analysis Data: | | | | Date |
|----------------------|---------------------------|----------|------------|------------|
| Z: 0 | R: 19.9 | C: 20 | Conc: 20 | 06/20/2019 |
| R: 19.88 | Z: 0 | C: 20.1 | Conc: 20.1 | |
| Z: 0 | C: 20.1 | R: 19.91 | Conc: 20.1 | |
| UOM: ppm | Mean Test Assay: 20.1 ppm | | | |

| Second Analysis Data: | | | | Date |
|-----------------------|---------------------------|----------|------------|------------|
| Z: 0 | R: 19.9 | C: 20.1 | Conc: 20.1 | 06/27/2019 |
| R: 19.89 | Z: 0 | C: 20.2 | Conc: 20.2 | |
| Z: 0 | C: 20.1 | R: 19.89 | Conc: 20.1 | |
| UOM: ppm | Mean Test Assay: 20.1 ppm | | | |

Analyzed By

Henry Koung

Certified By

Lucanna Flores



Customer & Order Information:

PRAXAIR PKG OXNARD CA HPS
 455 E WOOLEY RD,
 OXNARD, CA 93030-7224
 Praxair Order Number: 71378203
 Customer PO Number: 79369772

Certificate Issuance Date: 7/10/2020
 Certification Date: 7/10/2020
 Lot Number: 70086018201
 Part Number: NI NX20MP-AS
 DocNumber: 232651
 Expiration Date: 7/10/2021

CERTIFICATE OF ANALYSIS
Primary Standard

| Component | Requested Concentration (Molar) | Certified Concentration (Molar) | Analytical Reference | Analytical Uncertainty |
|---------------------------|---------------------------------|---------------------------------|----------------------|------------------------|
| Nitrogen dioxide (as NOx) | 20 ppm | 19.01 ppm | 1 | ± 1% |
| Nitrogen | Balance | Balance | | |

Cylinder Style: AS
 Cylinder Pressure @ 70 F: 2000 psig
 Cylinder Volume: 142 ft³
 Valve Outlet Connection: CGA 660
 Cylinder Number(s): CC3240

Fill Date: 6/30/2020
 Analysis Date: 7/10/2020

Filling Method: Gravimetric

Comments: This mixture contains 2% Oxygen.

Analyst: Leeanna Flores

Approved Signer: Henry Koung

Key to Analytical Techniques:

| Reference | Analytical Instrument - Analytical Principle |
|-----------|----------------------------------------------|
| 1 | MKS MG2031 - FTIR |

The gas calibration cylinder standard prepared by Praxair Distribution, Inc. is considered a certified standard. It is prepared by gravimetric, volumetric, or partial pressure techniques. The calibration standard provided is certified against Praxair Distribution, Inc. Reference Materials which are traceable to the International System of Units (SI) through either weights traceable to the National Institute of Standards and Technology (NIST) or Measurement Canada, or through NIST Standard Reference Materials or equivalent where available.

Note: All expressions for concentration (e.g., % or ppm) are for gas phase, by volume (e.g., ppmv) unless otherwise noted. Analytical uncertainty is expressed as a Relative % unless otherwise noted.

IMPORTANT

The information contained herein has been prepared at your request by personnel within Praxair Distribution, Inc. While we believe the information is accurate within the limits of the analytical methods employed and is complete to the extent of the specific analyses performed, we make no warranty or representation as to the suitability of the use of the information for any particular purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall liability of Praxair Distribution, Inc. arising out of the use of the information contained herein exceed the fee established for providing such information.

DocNumber: 224275



Praxair Distribution, Inc.
5700 S. Alameda Street
Los Angeles CA 90058
Tel: 323-586-2154
Fax: 714-542-6689
PGVP ID: F22018

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information

PRAXAIR PKG OXNARD CA 3HS
455 E WOOLEY RD
OXNARD CA 93030

Certificate Modification Date: 09/18/2018

Praxair Order Number: 70717073

Part Number: NI NO40ME-AS

Fill Date: 09/05/2018

Lot Number: 70086824802

Cylinder Style & Outlet: AS

CGA 650

Cylinder Pressure and Volume: 2000 psig 140 ft³

Certified Concentration

| | | |
|------------------|--------------|----------------------|
| Expiration Date: | 09/18/2021 | NIST Traceable |
| Cylinder Number: | DT0028765 | Expanded Uncertainty |
| 39.9 ppm | Nitric oxide | ± 0.8 % |
| Balance | Nitrogen | |

ProSpec EZ Cert



For Reference Only: NOx 40.0 ppm

Certification Information: Certification Date: 09/18/2018 Term: 36 Months Expiration Date: 09/18/2021

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1.
Do Not Use this Standard if Pressure is less than 100 PSIG.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: Nitric oxide
Requested Concentration: 40 ppm
Certified Concentration: 39.9 ppm
Instrument Used: Thermo Electron 42i-LS S/N 1030645077
Analytical Method: Chemiluminescence
Last Multiport Calibration: 09/10/2018

Reference Standard: Type / Cylinder #: GMIS / CC505947
Concentration / Uncertainty: 49.44 ppm ±0.714%
Expiration Date: 08/09/2021
Traceable to: SRM # / Sample # / Cylinder #: 1683b / 45-V-37 / CAL017858
SRM Concentration / Uncertainty: 48.79 / ±0.34 ppm
SRM Expiration Date: 03/25/2019

| First Analysis Data: | | | | Date |
|----------------------|------|------|-------|---------------------------|
| Z: | R: | C: | Conc: | 09/11/2018 |
| 0 | 49.4 | 30.8 | 30.8 | |
| R: | Z: | C: | Conc: | |
| 49.4 | 0 | 39.9 | 39.9 | |
| Z: | C: | R: | Conc: | |
| 0 | 39.9 | 49.4 | 39.9 | |
| UOM: ppm | | | | Mean Test Assay: 39.9 ppm |

| Second Analysis Data: | | | | Date |
|-----------------------|------|------|-------|---------------------------|
| Z: | R: | C: | Conc: | 09/18/2018 |
| 0 | 49.4 | 35.7 | 35.7 | |
| R: | Z: | C: | Conc: | |
| 49.4 | 0 | 39.9 | 39.9 | |
| Z: | C: | R: | Conc: | |
| 0 | 39.9 | 49.4 | 39.9 | |
| UOM: ppm | | | | Mean Test Assay: 39.9 ppm |

Analyzed By

Henry Koung

Certified By

Amala Beal

Work Order Details

202367: BS-PM, 1Y, INSPECT ADMIN OFFICE COMPUTER ROOM GENERATOR

CHECK PDRAIN PLUG COULD NOT REMOVE IT

This is an official APCD requirement effective 2014. Maintenance delays shall be reported to APCD Compliance Division.

Required annual maintenance includes:

- Change Oil
- Change Oil Filter
- Change Spark Plugs
- Hose & Belt inspection/replacement as needed

PARTS

OIL MOTOR, CASTROL HYSTER P/N - 995 C5W30 -- VENDER #28333296 - Johnson Lift Hyster

OIL FILTER, HYSTER P/N - HYS BWB243 -- VENDER #28333296 - Johnson Lift Hyster

SPARK PLUG WIRES HYSTER P/N - 995 35-4134 - VENDER #28333296 - Johnson Lift Hyster

SPARK PLUG, HYSTER P/N - 995 764 - VENDER #28333296 - Johnson Lift Hyster

VALVE, PCV HYSTER P/N - HYS 3133057 - VENDER #28333296 - Johnson Lift Hyster

DC24MF GP24 Maeine Battery 750

Asset: 6810

Generator, Main Office Computer Room

Location: 3146

Generator, Main Office Computer Room

CI:

Equipment #: 111-9013

Functional Location: 8149-09-01-030-140-080

MCC Location:

| | | | | | |
|-----------------------|----------|-----------------------|---------------|------------------------|----------|
| Sched Start: | 11/23/20 | Site: | OXNARD | Job Plan: | JP2036 |
| Sched Finish: | | Priority: | 3 | Supervisor: | |
| Target Start: | 11/23/20 | Work Type: | PM | Lead: | EMENDOZA |
| Target Finish: | | Status: | COMP | Vendor: | |
| Actual Start: | 11/24/20 | Parent: | | Person Group: | 213 |
| Actual Finish: | 11/24/20 | Failure Class: | | Service: | |
| Report Date: | 6/4/20 | Problem Code: | | Service Group: | |
| Reported By: | MAXADMIN | GL Account: | 393900.453120 | Classification: | |
| On Behalf Of: | | | | | |

NEW INDY

CONTAINERBOARD

January 4, 2021

County of Ventura
Air Pollution Control District
669 County Square Drive, 2nd Floor
Ventura, CA 93003

Attention: Mr. Ed Swede

Subject: 2020 Annual Report for Emergency Generator


Dear Mr. Swede:

In compliance with Rule 74.9(F)(2) reporting requirement, New-Indy Oxnard mill is submitting the following information for the stationary internal combustion engine(s) rated at >50 HP maintained at the facility:

| Unit | 2020 Hours of Operation | 2020 Maintenance Hours |
|------------------------------------------------------|----------------------------|---------------------------|
| Admin Emergency Generator WINCO PSS35000 88 HP | 3 | 28 |

If you have any questions, please do not hesitate to contact me at (805) 271-7284.

Sincerely,


Robyn Lebrilla
Environmental Engineer

NEW INDY OXNARD, LLC

5936 PERKINS ROAD • OXNARD, CALIFORNIA 93033 • WWW.NEWINDYCONTAINERBOARD.COM
PHONE (805) 986-3881 • FAX (805) 488-5186



Ventura County
Air Pollution
Control District

RESPONSIBLE OFFICIAL'S CERTIFICATION FORM


Ventura County APCD Rule 33.9 requires that "any document, including reports, schedule of compliance progress reports and compliance certifications, required by a Part 70 permit shall be certified by a responsible official." Therefore, this form shall be signed by the company's Responsible Official and submitted with all such reports, including, but not limited to semi-annual reports, deviation and emergency reports and any periodic reports required by a Part 70 permit. However, when submitting your Annual Compliance Certifications, please use the form titled Annual Compliance Certification Signature Cover Form.

Semi-annual reports, deviations and emergency reports and any periodic reports required by your Part 70 permit should be submitted to:


Air Quality Engineer
Ventura County Air Pollution Control District
669 County Square Drive
Ventura, CA 93003


Certification by Responsible Official


I certify that, based on information and belief formed after reasonable inquiry, the statements and information in this document is true, accurate, and complete.

| | |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------|
| <p>Signature and Title of Responsible Official:</p> <p>Signature: <u></u></p> <p>Title: <u>Mill Manager</u></p> | <p>Date: <u>01/07/2021</u></p> |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------|

Stack Opacity Observation Protocol

| | |
|--------------------------------------------------------|-----------------------------------------------------------------------------------|
| Object: | Cogen Stack |
| Date of Observation: | 06/30/20 |
| Time of Observation: | 9:00 AM |
| Fuel burned: | Natural Gas |
| Name of the observing person: | Zhen Han |
| Signature |  |
| Was Visible Emission Other Than Steam Present ? | no |
| | |
| Object: | Nebraska Boiler |
| Date of Observation: | n/a |
| Time of Observation: | n/a |
| Fuel burned: | n/a |
| Name of the observing person: | n/a |
| Signature | n/a |
| Was Visible Emission Other Than Steam Present ? | n/a |

| | |
|--------------------------------------------------------|-------------------------------------------------------------------------------------|
| Object: | Paper Forming/Paper Drying |
| Date of Observation: | 06/30/20 |
| Time of Observation: | 9:00 AM |
| Fuel burned: | N/A |
| Name of the observing person: | Zhen Han |
| Signature |  |
| Was Visible Emission Other Than Steam Present ? | no |

| | |
|--------------------------------------------------------|-------------------------------------------------------------------------------------|
| Object: | Maxon Burner |
| Date of Observation: | 06/30/20 |
| Time of Observation: | 9:00 AM |
| Fuel burned: | Natural Gas |
| Name of the observing person: | Zhen Han |
| Signature |  |
| Was Visible Emission Other Than Steam Present ? | no |

Stack Opacity Observation Protocol


| | |
|--------------------------------------------------------|-----------------------------------------------------------------------------------|
| Object: | Cogen Stack |
| Date of Observation: | 09/30/20 |
| Time of Observation: | 3:12 PM |
| Fuel burned: | Natural Gas |
| Name of the observing person: | Zhen Han |
| Signature |  |
| Was Visible Emission Other Than Steam Present ? | no |

| | |
|--------------------------------------------------------|-----------------|
| Object: | Nebraska Boiler |
| Date of Observation: | n/a |
| Time of Observation: | n/a |
| Fuel burned: | n/a |
| Name of the observing person: | n/a |
| Signature | n/a |
| Was Visible Emission Other Than Steam Present ? | n/a |


| | |
|--------------------------------------------------------|-------------------------------------------------------------------------------------|
| Object: | Paper Forming/Paper Drying |
| Date of Observation: | 09/30/20 |
| Time of Observation: | 3:12 PM |
| Fuel burned: | N/A |
| Name of the observing person: | Zhen Han |
| Signature |  |
| Was Visible Emission Other Than Steam Present ? | no |

| | |
|--------------------------------------------------------|-------------------------------------------------------------------------------------|
| Object: | Maxon Burner |
| Date of Observation: | 09/30/20 |
| Time of Observation: | 3:12 PM |
| Fuel burned: | Natural Gas |
| Name of the observing person: | Zhen Han |
| Signature |  |
| Was Visible Emission Other Than Steam Present ? | no |

Stack Opacity Observation Protocol


| | |
|--------------------------------------------------------|-----------------------------------------------------------------------------------|
| Object: | Cogen Stack |
| Date of Observation: | 12/23/20 |
| Time of Observation: | 9:00 AM |
| Fuel burned: | Natural Gas |
| Name of the observing person: | Zhen Han |
| Signature |  |
| Was Visible Emission Other Than Steam Present ? | no |


| | |
|--------------------------------------------------------|------------------------|
| Object: | Nebraska Boiler |
| Date of Observation: | n/a |
| Time of Observation: | n/a |
| Fuel burned: | n/a |
| Name of the observing person: | n/a |
| Signature | n/a |
| Was Visible Emission Other Than Steam Present ? | n/a |


| | |
|--------------------------------------------------------|-------------------------------------------------------------------------------------|
| Object: | Paper Forming/Paper Drying |
| Date of Observation: | 12/23/20 |
| Time of Observation: | 9:00 AM |
| Fuel burned: | N/A |
| Name of the observing person: | Zhen Han |
| Signature |  |
| Was Visible Emission Other Than Steam Present ? | no |

| | |
|--------------------------------------------------------|-------------------------------------------------------------------------------------|
| Object: | Maxon Burner |
| Date of Observation: | 12/23/20 |
| Time of Observation: | 9:00 AM |
| Fuel burned: | Natural Gas |
| Name of the observing person: | Zhen Han |
| Signature |  |
| Was Visible Emission Other Than Steam Present ? | no |

Stack Opacity Observation Protocol

| | |
|--------------------------------------------------------|-----------------------------------------------------------------------------------|
| Object: | Cogen Stack |
| Date of Observation: | 03/11/21 |
| Time of Observation: | 11:30 AM |
| Fuel burned: | Natural Gas |
| Name of the observing person: | Zhen Han |
| Signature |  |
| Was Visible Emission Other Than Steam Present ? | no |
| | |
| Object: | Nebraska Boiler |
| Date of Observation: | n/a |
| Time of Observation: | n/a |
| Fuel burned: | n/a |
| Name of the observing person: | n/a |
| Signature | n/a |
| Was Visible Emission Other Than Steam Present ? | n/a |

| | |
|--------------------------------------------------------|-------------------------------------------------------------------------------------|
| Object: | Paper Forming/Paper Drying |
| Date of Observation: | 03/11/21 |
| Time of Observation: | 11:30 AM |
| Fuel burned: | N/A |
| Name of the observing person: | Zhen Han |
| Signature |  |
| Was Visible Emission Other Than Steam Present ? | no |

| | |
|--------------------------------------------------------|-------------------------------------------------------------------------------------|
| Object: | Maxon Burner |
| Date of Observation: | 03/11/21 |
| Time of Observation: | 11:30 AM |
| Fuel burned: | Natural Gas |
| Name of the observing person: | Zhen Han |
| Signature |  |
| Was Visible Emission Other Than Steam Present ? | no |

**VENTURA COUNTY
AIR POLLUTION CONTROL DISTRICT**
Memorandum

TO: Karl Krause
FROM: Terri Thomas
SUBJECT: Rule 54.B.2 Compliance

DATE: May 23, 1996

Per your request, I ran some screening level dispersion modeling tests to determine equipment parameters that would comply with Rule 54.B.2. Rule 54.B.2 limits ground level property line SO₂ concentrations to 0.25 ppm_v for 1 hour and 0.04 ppm_v for 24 hours.

I assume that the most common SO₂ emission source is diesel combustion in IC engines. Therefore, that was the focus of my analysis.

To determine appropriate stack parameters, I reviewed 4 source test reports for diesel ICEs prepared for AB 2588. For screening purposes, the most conservative value was chosen from the test data for each stack parameter. The following summarizes stack data from these reports:

| Parameter | # tests reporting parameter value | range of values | screening value |
|-------------------|-----------------------------------|---------------------|-------------------------|
| Stack velocity | 3 | 1,812-11,343 ft/min | 1,812 ft/min 9.2 m/s |
| Stack diameter | 3 | 2-6 inches | 2 inches 0.05 meters |
| Stack temperature | 4 | 192-785°F | 192°F 362 K |
| Stack height | 0 | NA | 2 meters |

SO₂ emissions were based on 300 ppm_v in the stack, which is the limit in Rule 54.B.1.a. This limit cannot be exceeded if the diesel fuel meets the 0.5% sulfur limit in Rule 64.B.2.

Other assumptions used in modeling were that the stack was vertical and has no raincap, and the property line was at least 100 meters from the stack.

Using the parameters and assumptions listed above, screening modeling showed that the limits in Rule 54.B.2 would not be exceeded.

Use of the minimum stack diameter, and thus, the minimum flow rate and emission rate is not the most conservative case. In order to determine the maximum emission rate that could be shown to meet the Rule under the conditions described above, modeling was performed by increasing the emissions and flow rate (to maintain the 300 ppm_v SO₂ stack concentration), but increasing the stack diameter to maintain the minimum velocity. Modeling results are summarized below.

| Emission rate (g/s) | Emission rate (lb/hr) and (lb/day) | 1 hour max concentration (ppm _v) (limit=0.25) | 24 hour max concentration (ppm _v) (limit=0.04) |
|---------------------|------------------------------------|-----------------------------------------------------------|------------------------------------------------------------|
| 0.0145 | 0.12 2.76 | 0.04 | 0.01 |
| 0.029 | 0.23 5.52 | 0.06 | 0.03 |
| 0.058 | 0.46 11.04 | 0.11 | 0.04 |
| 0.116 | 0.92 22.08 | 0.17 | 0.07 |
| 0.232 | 1.84 44.15 | 0.23 | 0.05 |

From the above, if SO₂ emissions do not exceed 1.84 lb/hr, the 1-hour limit of Rule 54.B.2 will be met. This is equivalent to burning 26 gallons of diesel at 0.5% sulfur per hour.

If SO₂ emissions do not exceed 11.04 lb/day, the 24-hour limit of Rule 54.B.2 will be met. This is equivalent to burning 155 gallons of diesel at 0.5% sulfur per day.

If the sulfur content of the fuel is lower than 0.5%, the allowable amount of fuel would, of course, be greater.

Let me know if the above information meets your needs. If so, another scenario that is probably common is a nonvertical stack (or stack with raincap). I can develop similar information for this case if you want.



Ventura County
Air Pollution
Control District

669 County Square Dr
Ventura California 93003

tel 805/645-1400
fax 805/645-1444
www.vcapcd.org

Dr. Laki Tisopoulos, P.E.
Air Pollution Control Officer

Permit to Operate 07141 - R07

Page 1 of 6

Valid: 10/01/2020 to 09/30/2021

THIS PERMIT HAS BEEN ISSUED TO THE FOLLOWING:

COMPANY NAME AND ADDRESS:

C.D. Lyon Construction Inc.
PO BOX 1456
VENTURA, CA 93002-1456

FACILITY NAME AND ADDRESS:

C.D. Lyon Construction Inc.
Portable Equipment Various Locations
Ventura County, CA

EQUIPMENT DESCRIPTION:

Permission is hereby granted to operate the equipment listed at the end of this permit in Table A.

1. THIS PERMIT HAS BEEN ISSUED SUBJECT TO THE FOLLOWING PERMITTED EMISSIONS (PURSUANT TO RULE 29.B):

| Permitted Emission | Tons/Year | Pounds/Hour |
|--------------------|-----------|-------------|
| Reactive Organics | 2.15 | 2.07 |
| Particulate Matter | 5.62 | 39.00 |

Note: Because of rounding, values in these tables shown as 0.00 are less than 0.005, but greater than zero.

THIS PERMIT HAS BEEN ISSUED SUBJECT TO THE FOLLOWING CONDITIONS:

2. Annual abrasive usage shall not exceed 144 tons while operating in Ventura County.

In order to comply with this condition, permittee shall maintain daily records and monthly reports of abrasive usage. Monthly usage shall be totaled and the monthly totals summed for the previous twelve (12) months. Material usage totals for any of these twelve (12) month periods in excess of the above limits shall be considered a violation of this condition. Prior to exceeding the above limit, permittee shall submit an application to modify this condition.

3. Annual usage shall not exceed 648 Gal/Yr of coatings with Maximum 3.51 Lbs/Gal ROC, as applied and 288 Gal/Yr of coatings application equipment cleanup material with Maximum 7.09 Lbs/Gal ROC, as applied, while operating in Ventura County.

In order to comply with this condition, permittee shall maintain daily records and monthly reports of coatings, surface preparation materials, and coatings application equipment cleanup materials.

Final Issue Date: 08/27/2020

Permit to Operate 07141 - R07

Page 2 of 6

Monthly usage shall be totaled and the monthly totals summed for the previous twelve months. Material usage totals for any of these twelve (12) month periods in excess of the above limit shall be considered a violation of this condition. Prior to exceeding the above limit, permittee shall submit an application to modify this condition.

4. Pursuant to APCD Rule 74.6.B.1, the permittee shall not use any material with an ROC content in excess of 25 grams per liter of material for substrate surface preparation.
5. This permit authorizes abrasive blasting and/or painting of stationary structures and their appurtenances at their permanent sites only.
6. All coating operations shall comply with APCD Rule 74.2, "Architectural Coatings". The reactive organic compound content of flat coatings shall not exceed 50 grams per liter, computed on a minus water, minus exempt solvent basis as applied. The reactive organic compound content of nonflat coatings used shall not exceed 100 grams per liter, computed on a minus water, minus exempt solvent basis as applied. The reactive organic compound content of the industrial maintenance coatings used shall not exceed 250 grams per liter, computed on a minus water, minus exempt solvent basis as applied. Other coatings used shall meet their specific limit in the Rule 74.2 Table of Standards. Thinning of the coatings shall not cause the coatings to exceed their applicable standard.
7. All ROC containing materials, used or unused, including but not limited to surface coatings, surface preparation materials and cleanup materials shall be stored in closed containers. This condition is applied as Best Available Control Technology (BACT).
8. All abrasive blasting activities shall be conducted in conformance with all applicable provisions of Title 17, California Administrative Code, Subchapter 6 (Abrasive Blasting) and APCD Rule 74.1 (Abrasive Blasting). This includes, but is not limited to, the following permit conditions.
9. Pursuant to Rule 74.1.B.1.a, all abrasive blasting operations shall be conducted within a permanent building except when steel or iron grit/shot is used exclusively, or when the item to be blasted exceeds eight feet in any dimension, or when the surface being blasted is situated at its permanent location or no further away from its permanent location than is necessary to allow the surface to be blasted.
10. Pursuant to APCD Rule 74.1.B.1.c, when the item to be blasted exceeds eight feet in any dimension, or when the surface to be blasted is situated at its permanent location or no further away from its permanent location than is necessary to allow the surface to be blasted, the abrasive blasting operation shall be conducted using wet abrasive blasting, hydroblasting, vacuum blasting or dry blasting with certified abrasives.
11. The discharge into the atmosphere from abrasive blasting operations conducted outside a permanent building shall not be as dark or darker in shade than No. 2 on the Ringlemann Chart or of such opacity as to obscure an observer's view to a degree equal to or greater than does smoke described as Ringlemann No. 2. (Note: Ringlemann No. 2 is equivalent to 40% opacity), as required by APCD Rule 74.1.C.1.a.

Final Issue Date: 08/27/2020

Permit to Operate 07141 - R07

Page 3 of 6

12. The discharge into the atmosphere from abrasive blasting operations conducted within a permanent building shall not be as dark or darker in shade than No. 1 on the Ringlemann Chart or of such opacity as to obscure an observer's view to a degree equal to or greater than does smoke described as Ringlemann No. 1. (Note: Ringlemann No. 1 is equivalent to 20% opacity), as required by APCD Rule 74.1.C.1.b.
13. The permittee shall employ reasonable methods to insure that discharge from the abrasive blasting and/or surface coating work area does not cause a nuisance, pursuant to California Health & Safety Code Section 41700 and APCD Rule 51 (Nuisance). Such methods may include, but are not limited to, use of shrouding and covering of objects adjacent to the blasting and/or surface coating activity.
14. Pursuant to APCD Rule 74.1.B.4, only abrasives certified in accordance with Section 92350 of the California Code of Regulations shall be used for permissible outdoor blasting. Packages or containers for certified abrasives shall be legibly and permanently labeled with each of the following:
 - a) The manufacturer's name or identification trade name;
 - b) The grade, weight proportion of components in abrasive blends, brand name of the abrasive, or brand names and grades of components of abrasive blends; and
 - c) The statement "ARB certified for permissible dry outdoor blasting."
15. The District shall be notified at least 48 hours prior to conducting abrasive blasting and/or surface coating operations by leaving a message on the District 24-hour message recorder at (805)654-2797 or by faxing a notification to (805)645-1444.

The notification shall include the following information:

 - a) Identification of operator and the Permit to Operate number (No. 7141).
 - b) The location (street address and city) and a description of the abrasive blasting and/or surface coating activity.
 - c) The expected starting date and duration of the abrasive blasting and/or surface coating activity.
16. The permittee shall record and maintain the following information on each abrasive blasting operation performed in Ventura County. The records shall be compiled into a monthly report. These records shall be maintained for the previous two years and shall be made available to APCD personnel upon request:
 - a) The location and a description of the abrasive blasting activities.
 - b) The starting and ending dates.
 - c) The total hours of actual abrasive blasting activity and the amount of abrasives used.
17. The permittee shall record and maintain the following information on each surface coating operation performed in Ventura County. The records shall be compiled into a monthly report. These records

Permit to Operate 07141 - R07

Page 4 of 6

shall be maintained for the previous two years and shall be made available to APCD personnel upon request:

- a) The location and a description of the surface coating activities.
- b) The starting and ending dates.
- c) On a daily or per site basis, record usage as follows: the brand name and product or number for each coating, solvent and thinner used; the mix ratio of the components used; the quantity of each material used; the ROC content of the coatings, as applied, computed on a minus water, minus exempt solvent basis; the coating category (e.g., coating, solvent, thinner, etc.); and the method of application.
- d) On a daily or per site basis, record usage of spray equipment cleanup solvent used, which includes the following: brand and product name or number of each solvent; the quantity of each solvent used; the ROC content; and the method of application.

If purchase records are used to determine the amount of solvents used, then records and manifest of the amounts of solvents disposed of or sent to a recycler must also be maintained.

18. Portable abrasive blasting and surface coating equipment may be used anywhere in Ventura County.
19. Wipe cleaning operations shall comply with all applicable provisions of APCD Rule 74.6, "Surface Cleaning and Degreasing", including, but not limited to, the following material requirements:

Any materials used for cleanup, including cleanup of application equipment, shall have an ROC composite partial pressure no greater than 33 mm Hg at 20 degrees Celsius and shall have an ROC content no greater than 900 grams per liter of material (Rule 74.6.B.1).

Cleanup is defined as the removal of uncured coating, adhesive or ink from any surface, including coating application equipment, oversprayed surface, and hands. Application equipment includes but is not limited to, spray guns, rollers, and brushes.

This condition does not apply to cleaning activities using Clean Air Solvent, or a solvent with an ROC-content no more than 25 grams per liter as applied (Rule 74.6.E.1.a).

20. Wipe cleaning operations shall comply with all applicable provisions of APCD Rule 74.6, "Surface Cleaning and Degreasing". Accordingly, no person shall perform solvent cleaning unless one of the following cleaning devices or methods is used (Rule 74.6.B.2):
- a) Wipe cleaning where solvent is dispensed to wipe cleaning materials from containers that are kept closed to prevent evaporation, except while dispensing solvent or replenishing the solvent supply;
 - b) Application of solvent from a hand-held spray bottle, squirt bottle or other closed container with a capacity of one liter or less;
 - c) Non-atomized solvent flow, dip or flush method where pooling is prevented or drained, and all solvent runoff is collected in a manner that enables solvent recovery or disposal. The collection

Permit to Operate 07141 - R07

Page 5 of 6

system shall be kept closed to prevent evaporation except while collecting solvent runoff or emptying the collection system.

If the cleaning method has a solvent capacity more than one gallon, a cold cleaner or remote reservoir cold cleaner meeting the equipment and operation requirements of Rule 74.6 Sections C and D shall be used.

- d) A properly used enclosed gun washer or low emission spray gun cleaner.

No person shall allow liquid cleaning solvent to leak from any equipment or container (Rule 74.6.B.3).

21. All ROC-containing solvents shall be stored in non-absorbent, non-leaking containers which shall be kept closed at all times except when filling or emptying (Rule 74.6.B.4.a).

Waste solvent and waste solvent residues shall be disposed of in a manner conforming with Division 20, Chapter 6.5 of the California Health and Safety Code (Rule 74.6.B.4.b).

22. Permittee shall maintain a current material list for at least two (2) years from the date of each record showing each ROC containing material used in solvent cleaning activities. All such records shall be made available to APCD personnel upon request (Rule 74.6.F). The records shall summarize the following information:

- a) Solvent name and manufacturer's description.
- b) All intended uses of the solvent at the facility, classified as follows:
 - 1) Cleanup, including application equipment cleaning, or
 - 2) Cleaning of electronic components, electrical apparatus components, medical devices, or aerospace components, or
 - 3) Solvent used pursuant to an exemption in Section E of Rule 74.6.C. (specify exemption claimed)
- c) The ROC content in units of grams of ROC per liter of material (and ROC composite partial pressure in units of mm Hg @ 20C, if applicable) of the solvent.
- d) The mix ratio, if the solvent is a mix of materials blended by the operator.

Within 30 days after receipt of this permit, the permittee may petition the Hearing Board to review any new or modified condition (Rule 22). This permit, or a copy, shall be posted reasonably close to the subject equipment and shall be accessible to inspection personnel (Rule 19). This permit is not transferrable from one location to another unless the equipment is specifically listed as being portable (Rule 20).

Final Issue Date: 08/27/2020

Permit to Operate 07141 - R07

Page 6 of 6

The granting of this Permit to Operate shall not be construed as an endorsement by the District and shall not guarantee compliance with the rules of the District. This Permit to Operate shall not be construed to allow any emission unit to operate in violation of any state or federal emission standard or any rule of the District.

This permit cannot be considered as permission to violate existing laws, ordinances, regulations or statutes of other government agencies.



Ali Ghasemi, Manager
Engineering Division

For:

Dr. Laki Tisopulos
Air Pollution Control Officer

Attachments:

- Table A - Permit Equipment List(s)
- Q:\PRISM\PRISMFileRoom\PermitFiles\07141\Engineering\Permits\Renewal 07141 R07 - Final Permit - 8-27-2020.docx

Final Issue Date: 08/27/2020

Equipment List for Permit to Operate 07141 - R07

Page 1 of 1

PERMIT EQUIPMENT LIST - TABLE A

Renewal 07141 R07 / FID: 07141 C.D. Lyon Construction Inc. / SSID: 07141

A PERMITTED EQUIPMENT

- 1 Abrasive Blasting Operation**
- 2 Architectural Surface Coating Operation**

Final Issue Date: 08/27/2020

**VENTURA COUNTY
AIR POLLUTION CONTROL DISTRICT**
Memorandum

TO: Interested Parties DATE: December 3, 1997

FROM: John Harader

SUBJECT: Rule 57.B / AP-42 Emission Factor Comparison

Section B of District Rule 57, "Combustion Contaminants - Specific", limits the combustion contaminant emission concentration from any fuel burning equipment. Combustion contaminants are defined in District Rule 2 as particulate matter discharged into the atmosphere from the burning of any kind of material containing carbon in a free or combined state. The emission concentration limit is 0.1 grain per cubic foot of gas calculated to 12 percent of carbon dioxide at standard conditions (0.1 gr/scf @ 12% CO₂). This limit can be converted to a lb/MMBTU emission factor by the following equation from 40 CFR Part 60, Appendix A, Method 19:

$$E = C F_c (100/\%CO_2)(lb/7000gr)$$

E = lb/MMBTU emission factor
 C = Pollutant concentration (lb/DSCF)
 F_c = CO₂ F-factor
 = 1430 dscf CO₂/MMBTU for liquid fuels
 = 1040 dscf CO₂/MMBTU for natural gas

The pollutant concentration, C, and the %CO₂ values can be wet or dry as long as they are consistent. The %CO₂ of 12 may be used in the equation if the pollutant concentration has been corrected to 12% CO₂:

$$C_{@12\%CO_2} = C(12/\%CO_2)$$

The Rule 57.B emission limit is a limit at 12% CO₂; therefore the emission rate equation can be written:

$$E = (0.1 \text{ gr/scf}) F_c (100/12)(lb/7000gr)$$

For Natural Gas: E = 0.12 lb PM/MMBTU
 For Liquid Fuels: E = 0.17 lb PM/MMBTU

Based on EPA AP-42 emission factors and source test data, all natural gas fired or fuel oil fired boilers, process heaters, and turbines; and natural gas fired or diesel fired engines

operate below this emission factor or emission limit. The particulate matter emission factors for these units are:

| | | |
|--------------------------|---------------------------------------|--------------------|
| Natural Gas Fired Units | Rule 57.B Factor = 0.12 lb PM / MMBTU | |
| Boiler > 100 MMBTU/Hr | 3 lb/mmcf | 0.00286 lb / MMBTU |
| Boiler 10 - 100 MMBTU/Hr | 13.7 lb/mmcf | 0.0131 lb / MMBTU |
| Boiler < 10 MMBTU/Hr | 12 lb/mmcf | 0.0114 lb / MMBTU |
| Turbine | | 0.0419 lb / MMBTU |
| Lean Burn Engine | | 0.046 lb / MMBTU |
| Rich Burn Engine | | 0.0007 lb / MMBTU |

| | | |
|--------------------------------|---------------------------------------|------------------|
| Fuel Oil or Diesel Fired Units | Rule 57.B Factor = 0.17 lb PM / MMBTU | |
| Fuel Oil Fired Boiler | 2 lb / Mgal | 0.014 lb / MMBTU |
| Fuel Oil Fired Turbine | | 0.061 lb / MMBTU |
| Diesel Engine > 600 HP | | 0.062 lb / MMBTU |

Compliance with the emission limit for diesel engines < 600 HP has been shown through the conducting of a source test on an engine within Ventura County. This source test was conducted for the purpose of generating an emission factor to be used for Air Toxic "Hot Spots" emission estimations. The measured particulate concentration for this engine was 0.1 gr/dscf at 12 percent CO₂. The engine source test was a Cummins NTA engine rated at 335 horsepower at 2100 rpm. The source test was conducted July 29, 1992.

m:\title\rule57.Bcomp

New-Indy Oxnard, LLC
Attachment to 8.i.Rule 74.11.1.1 - Title V Annual Certification

Date: 2/26/21
 Conducted by: Zhen Han

Formal survey identifying each natural gas-fired water heater, boiler, steam generator and process heater with heat input capacity between 75,000 and 1,000,000 btu/hr.

| | North Property Space Heaters | North Property Water Heater | Admin Water Heater | Maintenance Lunch Room Water Heater |
|-----------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------|----------------------------------------------------|-------------------------------------------------|----------------------------------------------------|
| Manufacturer | Modine Manufacturing Company | Bradford White Corporation | Rinnai Corporation | Bradford White Corporation |
| Brand name | Modine | Eco-Defender | Rinnai | Eco-Defender |
| Model number | PD 300AE0130 | URG250T6N | RL94e (REU-VC2837WD-US) | URG250T6N |
| Heat input rating | 300,000 BTU/hr | 40,000 BTU/hr | 199,000 BTU/hr | 40,000 BTU/hr |
| Installation date | | Nov-15 | Jun-17 | Oct-20 |
| Certification status under VCAPCD Rule 74.11.1C or SCAQMD Rule 1146.2 | None | Complies with jurisdictions having 10ng/J NOx Regs | Complies with SCAQMD Rule 1146.2 (<14 ng NOx/J) | Complies with jurisdictions having 10ng/J NOx Regs |
| Number of units | 4 | 1 | 1 | 1 |
| Comment | Rule 74.11.1C covers NG-fired water heaters, small boilers, steam generator or process heaters - NOT space heaters | Exempt - less than 75000 BTU/hr | | Exempt - less than 75000 BTU/hr |

NOTES:

- * 2 steam cleaners - propane fired
- * Sump pumps & welders - portable, not natural gas-fired

