

**COMPLIANCE CERTIFICATION
JANUARY 1, 2020 – DECEMBER 31, 2020**

**TITLE V
FEDERAL OPERATING PERMIT
PART 70 PERMIT NO. 01006**

**NAVAL BASE VENTURA COUNTY
PORT HUENEME**



For submittal to:

Ventura County Air Pollution Control District
669 County Square Drive
Ventura, CA 93003

EPA Region IX
75 Hawthorne St.
San Francisco, CA 94105

RECEIVED
VENTURA COUNTY

2021 MAR -4 PM 3:48

A.P.C.D.



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION SIGNATURE COVER FORM

A copy of each Annual Compliance Certification shall be submitted to EPA, Region 9, at the following address:


Mr. Gerardo Rios, Chief
Permits Office (AIR-3)
Office of Air Division
EPA Region 9
75 Hawthorne Street
San Francisco, CA 94105

Confidentiality

All information in a Part 70 permit compliance certification is public information. The Part 70 permit is also public information.

Certification by Responsible Official

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in this compliance certification are true, accurate, and complete.

Signature and Title of Responsible Official:  Title: Jeffrey E. Chism, Captain, U.S. Navy Commanding Officer, Naval Base Ventura County	Date: 2/26/2021
---	------------------------

Time Period Covered by Compliance Certification 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)


**COMPLIANCE CERTIFICATION
JANUARY 1, 2020 - DECEMBER 31, 2020**

**TITLE V FEDERAL OPERATING PERMIT
PART 70 PERMIT NO. 01006**

**NAVAL BASE VENTURA COUNTY
PORT HUENEME**



1	SPECIFIC APPLICABLE REQUIREMENTS	
2	PERMIT SPECIFIC CONDITIONS	
3	GENERAL APPLICABLE REQUIREMENTS	
4	SHORT-TERM ACTIVITIES	
5	GENERAL PERMIT CONDITIONS	
6	MISCELLANEOUS FEDERAL PROGRAM CONDITIONS	
7	APPENDIX – A SUPPORTING DOCUMENTATION FOR USE OF COMPLIANT FUEL	
8	APPENDIX – B BOILER TUNE-UP/SCREENING SUMMARY FORMS	
9	APPENDIX– C FORMAL SURVEYS/ENGINES HOURS OF OPERATION RECORDS	
10	APPENDIX – D RICE NESHAP MAINTENANCE RECORDS	
11	APPENDIX– E GAS STATION VERIFICATION TESTING RESULTS	
12	APPENDIX– F ANNUAL THROUGHPUT/CONSUMPTION REPORT	




ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 70N3-01006- GOV-491, Condition No. <u>1</u></p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: General requirements of Rule 70, including requirements for pressure/vacuum relief valves at vent pipes, requirements for bulk transfers, and good operating practices as applicable to the Gasoline Dispensing Facility (GDF) at Building 5307</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: The tank suffered structural damage and has been out of service since 4, January 2016.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 70N3-01006- GOV-491, Condition No. <u>2</u></p>	<p>D. Frequency of monitoring: Daily inspection of Phase I spill containment devices and annual inspection for the rest of requirements</p>
<p>B. Description: Phase I vapor recovery requirements as applicable to the GDF at Building 5307</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: The tank suffered structural damage and has been out of service since 4, January 2016.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 70N3-01006- GOV-491, Condition Nos. 3.1 through 3.7</p>	<p>D. Frequency of monitoring: Monthly for appropriate hose drape and good working order, and annually for the rest of the requirements</p>
<p>B. Description: Phase II vapor recovery requirements (Conditions 3.1 through 3.7) as applicable to the GDF at Building 5307</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: The tank suffered structural damage and has been out of service since 4, January 2016.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 70N3-01006- GOV-491, Condition Nos. 3.8 through 3.10</p>	<p>D. Frequency of monitoring:</p> <p style="text-align: center;">Periodic</p>
<p>B. Description:</p> <p>Phase II vapor recovery requirements (Conditions 3.8 through 3.10) specific to the GDF at Building 5307</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p style="text-align: center;">N/A</p>
<p>C. Method of monitoring:</p> <p>The tank suffered structural damage and has been out of service since 4, January 2016.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p style="text-align: center;">*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 70N3-01006- GOV-491, Condition 3.11</p>	<p>D. Frequency of monitoring:</p> <p style="text-align: center;">Daily</p>
<p>B. Description:</p> <p>Requirement to perform daily inspection of hanging hardware at Building 5307 GDF</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p style="text-align: center;">N/A</p>
<p>C. Method of monitoring:</p> <p>The tank suffered structural damage and has been out of service since 4, January 2016.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p style="text-align: center;">*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 70N3-01006- GOV-491, Condition No. 4</p>	<p>D. Frequency of monitoring:</p> <p style="text-align: center;">Periodic</p>
<p>B. Description:</p> <p>Requirement that Phase II vapor recovery system at the Building 5307 GDF be maintained and operated with none of the defects listed in California Code of Regulations Section 94006, Subchapter 8, Chapter 1, Part III, of Title 17, adopted 11/12/02 (Rule 70E.2) (4.1), and that defective equipment be tagged "Out of Order" (4.2)</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p style="text-align: center;">N/A</p>
<p>C. Method of monitoring:</p> <p>The tank suffered structural damage and has been out of service since 4, January 2016.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p style="text-align: center;">*If yes, attach Deviation Summary Form</p>



ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 70N3-01006- GOV-491, Condition No. 5</p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Requirement that proper signs be posted at Building 5307 GDF as listed in Conditions 5.1 through 5.5</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: The tank suffered structural damage and has been out of service since 4, January 2016.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 70N3-01006- GOV-491, Condition No. 6</p>	<p>D. Frequency of monitoring: Annual</p>
<p>B. Description: Requirement to annually perform a static pressure performance test (TP-201.3b) and a dynamic Pressure Performance (TP-201.4) at the Building 5307 GDF</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: The tank suffered structural damage and has been out of service since 4, January 2016.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 70N3-01006- GOV-491, Condition No. 7.1</p>	<p>D. Frequency of monitoring: periodic</p>
<p>B. Description: Requirement for the Building 5307 GDF to keep records of tests performed on the vapor recovery systems</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: The tank suffered structural damage and has been out of service since 4, January 2016.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 70N3-01006- GOV-491, Condition No. 7.2</p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Requirement for the GDF at Building 5307 to keep records of all maintenance performed on the vapor recovery systems.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: The tank suffered structural damage and has been out of service since 4, January 2016.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 70N3-01006- GOV-491, Condition Nos. 7.3</p>	<p>D. Frequency of monitoring: Daily</p>
<p>B. Description: Requirement for the GDF at Building 5307 to keep records of daily hanging hardware inspections on phase II vapor recovery systems</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: The tank suffered structural damage and has been out of service since 4, January 2016.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 70N3-01006- GOV-491, Condition No. 8</p>	<p>D. Frequency of monitoring: As Needed</p>
<p>B. Description: Requirement to submit an application prior to any major modification to the GDF at Building 5307 (8.1) and to pass all required vapor recovery tests within 45 days of modification (8.2)</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: No major modification occurred at Building 5307 GDF during this reporting period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 70N3-01006-E85-491, Condition No. 1</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description:</p> <p>General requirements of Rule 70, including requirements for pressure/vacuum relief valves at vent pipes, requirements for bulk transfers, and good operating practices as applicable to the E-85 fueling facility at Building 5307</p>	<p>Periodic</p>
<p>C. Method of monitoring:</p> <p>All vent pipes are equipped with the appropriate pressure/vacuum relief valve. Proper operation of valves is verified annually at the time of the static pressure performance tests (1.1). All bulk transfers utilized a properly operating California Air Resources Board (CARB)-certified vapor recovery system (1.2). Good operating practices are ensured by periodic monitoring by the Naval Base Ventura County (NBVC) field operations team (1.3).</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 70N3-01006-E85-491, Condition No. 2.1</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description:</p> <p>Phase I vapor recovery requirement for a permanently installed submerged fill pipe which extends to within six inches of the tank bottom as applicable to the E-85 fueling facility at Building 5307</p>	<p>Annual</p>
<p>C. Method of monitoring:</p> <p>Presence of submerged fill in the form of a bottom-fed tank inlet is verified at the time of annual inspection and testing.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 70N3-01006-E85-491, Condition Nos. 2.2 through 2.5</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description:</p> <p>Phase I vapor recovery requirements as applicable to the E-85 fueling facility at Building 5307</p>	<p>Periodic</p>
<p>C. Method of monitoring:</p> <p>An uncertified Phase I vapor recovery system has been installed on E-85 fueling facility under CARB Research and Development (R&D) Authorization. The R&D authorization expires on November 1, 2021. E-85 fueling facility will use a CARB certified Phase I vapor recovery system when such a system is certified by CARB.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>



ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 70N3-01006-E85-491, Condition No. 2.6</p>	<p>D. Frequency of monitoring: Daily</p>
<p>B. Description: Requirement that standing E-85 fuel in Phase I spill containment device is prohibited at E-85 fueling facility at Building 5307</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: A daily inspection of E-85 fueling facility ensures that Phase I spill containment device is clean and free of E-85 fuel.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 70N3-01006-E85-491, Condition No. 3</p>	<p>D. Frequency of monitoring: As Needed</p>
<p>B. Description: The requirement for a Phase II vapor recovery system does not apply to the E-85 fueling facility (3.1) because at least 95 percent of motor vehicles fueled there are equipped with Onboard Vehicle Vapor Recovery (ORVR) (3.2)</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: The E-85 fueling facility at NBVC Port Hueneme Building 5307 is not equipped with a Phase II vapor recovery system (3.1). All E-85 motor vehicles fueled at the facility are equipped with ORVR as mandated by the United States Environmental Protection Agency for passenger cars manufactured after 2000 and light trucks manufactured after 2006 (3.2).</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 70N3-01006-E85-491, Condition No. 4</p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Requirement that proper signs be posted at Building 5307 E-85 fueling facility as listed in Conditions 4.1 through 4.5</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Periodic checks for proper signage are conducted by the NBVC Air Quality Program. Proper signage is also verified at the time of the annual compliance inspection.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 70N3-01006-E85-491, Condition No. 6.1</p>	<p>D. Frequency of monitoring: Annual</p>
<p>B. Description: Requirement for E-85 fueling facility at Building 5307 to keep records of vehicle make, model year, identification number, license plate number, and a statement that an ORVR system is in place and functional for each vehicle fueled from the E-85 fuel tank</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: All E-85 motor vehicles fueled at the facility are equipped with ORVR as mandated by the United States Environmental Protection Agency for passenger cars manufactured after 2000 and light trucks manufactured after 2006.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 70N3-01006-E85-491, Condition Nos. 6.2 and 6.3</p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Requirement for the E-85 fueling facility at Building 5307 to keep records of all tests and maintenance performed on the vapor recovery systems</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Records of all tests and maintenance of the vapor recovery system at the Building 5307 E-85 fueling facility are maintained by the Environmental Division Air Quality Program (EDAQP). Records contain the required elements and are reviewed periodically by the EDAQP staff. Appendix E includes the test results performed during this compliance certification period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 70N3-01006-E85-491, Condition No. 7</p>	<p>D. Frequency of monitoring: As Needed</p>
<p>B. Description: Requirement to submit an application prior to any major modification to the E-85 fueling facility at Building 5307 (7.1) and to pass all required vapor recovery tests within 45 days of modification (7.2)</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: No major modification occurred at Building 5307 E-85 fueling facility during this reporting period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 70-01006-Exchange-491,501, Condition No. 1</p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: General requirements of Rule 70 and California Air Resources Board (CARB) Executive Order VR-202, including requirements for pressure/vacuum relief valves at vent pipes, requirements for bulk transfers, and good operating practices as applicable to Navy Exchange Gasoline Dispensing Facility (GDF).</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: All vent pipes are equipped with the appropriate pressure/vacuum relief valve (1.1), all bulk transfers utilized a properly operating CARB-certified vapor recovery system (1.2), and good operating practices are ensured by periodic monitoring by the Naval Base Ventura County (NBVC) field operations team (1.3).</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 70-01006-Exchange-491,501, Condition No.2</p>	<p>D. Frequency of monitoring: Daily inspection of Phase I spill containment devices and vapor recovery equipment, and annual inspection for requirements 2.1, 2.2, and 2.4.</p>
<p>B. Description: Phase I vapor recovery requirements as applicable to the Navy Exchange GDF</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Presence and length of submerged fill pipes (2.1) are verified at the time of annual inspection and testing. The Navy Exchange GDF employs a permanently installed, CARB Certified, Phase I EVR (2.2) equipped with CARB certified poppetted drybreaks (2.4) as required. Lack of leaks (2.3) is ensured during annual static pressure performance tests. A daily inspection of Phase I spill containment devices ensures that the containment devices are clean and free of gasoline (2.5).</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 70-01006-Exchange-491,501, Condition No. 3</p>	<p>D. Frequency of monitoring: Daily inspection of hanging hardware and annual inspection for the rest of the requirements</p>
<p>B. Description: Phase II vapor recovery requirements as applicable to the Navy Exchange GDF</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Presence of CARB-certified Phase II system was verified at the time of installation (3.1). "Good working order" and the absence of leaks (3.3) are verified by the annual pressure performance tests. All vapor and liquid lines are gravity drained to the USTs as required (3.4). The presence of clearly marked components (3.2), UL listed riser hoses (3.5); insertion interlocks (3.6); coaxial vapor recovery hoses (3.7); and clean air separator (3.9) are verified at the time of the annual inspections. Vapor to Liquid Volume Ratio Test was performed and passed on 11/19/20 (3.8). Hanging hardware on Phase II EVR system is inspected daily by Navy Exchange personnel (3.10).</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>




ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 70-01006-Exchange-491,501, Condition No. 4</p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Requirement that Phase II vapor recovery systems at the Navy Exchange GDF be operated with none of the defects listed in the California Code of Regulations Section 94006, Subchapter 8, Chapter 1, Part III, of Title 17 (4.1) and that defective equipment be tagged "out of order" and not operated per Condition 4.2.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Proper ongoing maintenance of the Navy Exchange GDF is ensured by the GDF manager. Periodic checks for proper GDF maintenance are conducted by the Environmental Division Air Quality Program (EDAQP) staff. Proper maintenance is also verified at the time of the annual compliance inspection. None of the defects listed in California Code of Regulations Section 94006, Subchapter 8, Chapter 1, Part III, of Title 17 were found to exist at the Navy Exchange GDF during inspections (4.1). Any defective equipment found during daily maintenance inspections carried out by the GDF staff is tagged "out of order" and not operated until repaired as required (4.2).</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 70-01006-Exchange-491,501, Condition No. 5</p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Requirement that proper signs be posted at the Navy Exchange GDF as listed in Conditions 5.1 through 5.5</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Periodic checks for proper signage are conducted by the EDAQP. Proper signage is also verified at the time of the annual compliance inspection.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 70-01006-Exchange-491,501, Condition Nos. 6.1 through 6.6</p>	<p>D. Frequency of monitoring: Annual</p>
<p>B. Description: Requirement to perform a Static Pressure Performance Test (TP-201.3), Determination of Static Pressure Performance of the Healy Clean Air Separator Test (Exhibit 4), Vapor to Liquid Volume Ratio for Healy including Veeder-Root ISD Test (Exhibit 5), ISD Operability Test Procedure (Exhibit 9), and Dynamic Back Pressure Test (TP-201.4) annually at the Navy Exchange GDF</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: The most recent tests at the Navy Exchange GDF were performed and passed on 11/19/2020. The District was notified and test results submitted per rule requirements. Appendix E includes the results of the gas station testing during this compliance certification period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 70-01006-Exchange-491,501, Condition No. 6.7</p>	<p>D. Frequency of monitoring: Every three years</p>
<p>B. Description: Requirement to perform the following tests once every three years: Determination of 2 Inch WC Static Pressure Performance of Vapor Recovery Systems of Dispensing Facilities (TP-201.3), Static Torque of Rotatable Phase I Adaptors (TP-201.1B), Leak Rate of Drop Tube/Drain Valve Assembly (TP-201.1C), and Leak Rate and Cracking Pressure of Pressure/Vacuum Vent Valves (TP-201.1E)</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: The most recent tests at the Navy Exchange GDF were performed and passed on 11/19/2020. The District was notified and test results submitted per rule requirements.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 70-01006-Exchange-491,501, Condition No. 7.1</p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Requirement for the Navy Exchange GDF to keep records of tests performed on the vapor recovery systems</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Records of tests of the vapor recovery systems at the Navy Exchange GDF are maintained by the EDAQP. Appendix E includes the results of the gas station testing during this compliance certification period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 70-01006-Exchange-491,501, Condition No. 7.2</p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Requirement for the Navy Exchange GDF to keep records of all maintenance performed on the vapor recovery systems</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Records of all maintenance of the vapor recovery system at the Navy Exchange GDF are maintained by the station manager. Records contain the required elements and are reviewed periodically by the EDAQP staff.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 70-01006-Exchange-491,501, Condition No. 7.3</p>	<p>D. Frequency of monitoring:</p> <p>Daily</p>
<p>B. Description:</p> <p>Requirement for the Navy Exchange GDF to keep records of daily hanging hardware inspections</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p>N/A</p>
<p>C. Method of monitoring:</p> <p>Records of all daily hanging hardware inspections are kept at the Navy Exchange GDF and reviewed routinely by EDAQP staff.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 70-01006-Exchange-491,501, Condition No. 8</p>	<p>D. Frequency of monitoring:</p> <p>As Needed</p>
<p>B. Description:</p> <p>Requirement to submit an application prior to any major modification to the Navy Exchange GDF (8.1) and to pass all required vapor recovery tests within 45 days of modification (8.2)</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p>N/A</p>
<p>C. Method of monitoring:</p> <p>No major modification was performed at the Navy Exchange GDF during this compliance certification period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>




ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 74.6 (2017), Condition No. 1</p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Surface Cleaning and Degreasing -- Solvent ROC and/or Vapor Pressure</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Compliance with ROC and vapor pressure limits is ensured by the fact that all solvents must be approved by Environmental Division Air Quality Program (EDAQP) staff before they can be issued and used by any Naval Base Ventura County (NBVC) entity or tenant organization aboard NBVC.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>Y</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 74.6 (2017), Condition Nos. 2 through 7</p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Conditions relating to solvent handling procedures</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Compliance with Conditions 2 through 7 of Attachment 74.6 is verified by means of routine surveillance of solvent activities that are carried out by EDAQP staff.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 74.6 (2017), Condition No. 8</p>	<p>D. Frequency of monitoring: Routine</p>
<p>B. Description: Equipment and work practice requirements applicable to all cold cleaners (except remote reservoir type) -- Measurement of freeboard height, verification of initial boiling point, ROC content, and ROC composite partial pressure</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Routine inspection of solvent activities that are carried out by EDAQP staff confirmed that no non-remote reservoir cold cleaners exist.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>




ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 74.6 (2017), Condition No. 9</p>	<p>D. Frequency of monitoring:</p> <p>Routine</p>
<p>B. Description:</p> <p>Equipment and work practice standards as applicable to remote reservoir cold cleaners -- Measurement of freeboard height, verification of initial boiling point, ROC content, and ROC composite partial pressure</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p>N/A</p>
<p>C. Method of monitoring:</p> <p>It has been determined that all remote reservoir cold cleaners have either been removed from service or replaced with units that use either aqueous cleaning solutions or non-ROC solvents.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 74.6 (2017), Condition No. 10</p>	<p>D. Frequency of monitoring:</p> <p>Periodic</p>
<p>B. Description:</p> <p>Conditions related to cold cleaning operation</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p>N/A</p>
<p>C. Method of monitoring:</p> <p>Compliance with Condition 10 of Attachment 74.6 is verified by means of routine surveillance carried out by EDAQP staff.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 74.6 (2017), Condition Nos. 14 and 16</p>	<p>D. Frequency of monitoring:</p> <p>Periodic</p>
<p>B. Description:</p> <p>Recordkeeping requirements associated with surface cleaning and degreasing and routine surveillance to comply with Rule 74.6</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p>N/A</p>
<p>C. Method of monitoring:</p> <p>Compliance with the requirement to maintain a current material list showing the name, ROC and vapor pressure, and intended uses of each solvent material is accomplished by means of a database that records each issuance of a solvent material at NBVC Port Hueneme. For each issuance of material, this database documents a reference to the applicable Safety Data Sheet. The database also documents the recipient of the material, its intended uses. In addition, EDAQP staff performs routine inspection of the applicable solvent cleaning activities to ensure compliance with Rule 74.6.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>



ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 74.6.1 (2019), Condition No. 1</p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Requirement that the batch loaded vapor degreaser be equipped with specific mechanical and administrative controls designed to limit emissions.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: The batch loaded vapor degreaser is equipped with a primary condenser and circumferential trough (a), a water separator (c), a snug fitting cover (d), a high vapor cutoff thermostat (e), a pump spray control switch (f), and a condenser water flow switch (g). The freeboard ratio is 1.25 (b), a General Operation Guideline is posted on the machine (h). Periodic inspection of the vapor degreaser confirms that the degreaser is in compliance with the Condition 1 requirement.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>
<p>A. Attachment # or Permit Condition #: Attachment 74.6.1 (2019), Condition Nos. 2 Through 15</p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Conditions for operating the batch loaded vapor degreaser</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: The General Operation Guidelines for the vapor degreaser includes instructions which follow the requirements of Conditions 2 through 15 of Attachment 74.6.1. These requirements are also verified by means of routine surveillance of solvent activities that are carried out by EDAQP personnel.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>
<p>A. Attachment # or Permit Condition #: Attachment 74.6.1 (2019), Condition No. 16</p>	<p>D. Frequency of monitoring: Routine</p>
<p>B. Description Recordkeeping requirement conditions</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: The volume of solvent is recorded each time solvent is added to or removed from the degreaser. These records are reported to the EDAQP on a monthly basis.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 74.9N7, Condition No. 1</p>	<p>D. Frequency of monitoring:</p> <p>Monthly</p>
<p>B. Description:</p> <p>Requirement that emergency standby stationary internal combustion engines shall be operated only during an emergency, or for maintenance operation not to exceed 50 hours per year</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>Base-wide Instructions prohibit the use of emergency generators for "non-emergency" purposes. An investigation into the hours of operation of all emergency standby stationary internal combustion engines greater than 50 BHP is performed monthly. Logs maintained at each engine are reviewed regularly. Hour meter readings are recorded before and after each maintenance operation, typically 0.25 hours, once per month. Any additional operation events are readily apparent upon review of the logs. All such events are further investigated to verify that they were the result of an emergency. In addition, EDAQP is notified by Public Works of all planned maintenance of the power distribution system and construction of power distribution system prior to the maintenance.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: 74.9N7, Condition No. 2</p>	<p>D. Frequency of monitoring:</p> <p>Monthly</p>
<p>B. Description:</p> <p>Requirement that each emergency standby engine shall be equipped with an operating, non-resettable, elapsed-time hour meter</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>All emergency engines are equipped with the required hour meters.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 74.9N7, Condition Nos. 3 and 4</p>	<p>D. Frequency of monitoring:</p> <p>Annually</p>
<p>B. Description:</p> <p>Requirement that engine operating hours for maintenance be reported annually. The report must also include engine manufacturer, engine model number, operator identification number, and location. In addition, the specified report must accompany the Annual Compliance Certification</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>Engine operating hours for maintenance is reported to the District annually. A formatted report detailing annual maintenance operating hours for each engine has been included in Appendix-C of this Compliance Certification as required.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment ATCM Engine N2, Condition Nos. 1 and 3c</p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Non-federally enforceable requirement to use only California Air Resources Board (CARB) diesel fuel in emergency standby stationary CI engines(1) and provide documentation supporting such use(3c)</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: All diesel fuel combusted in stationary emergency standby engines at Naval Base Ventura County (NBVC) during the compliance period was supplied by the NBVC Supply Department, Fuel Branch. All diesel fuel received by the Supply Department, Fuel Branch, is CARB certified. Data demonstrating the use of CARB-Certified fuel is provided in Appendix A.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment ATCM Engine N2, Conditions No. 2, 3a, and 3b</p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Non-federally enforceable requirement that as of January 1, 2006, annual hours of operation for maintenance and testing of the emergency engine(s) not to exceed 20 hours per year. Also, requirement to equip engine(s) with a non-resettable hour meter and maintain a log that differentiates operation during maintenance and testing from emergency use. In addition, the operational hours of each engine shall be summarized by use (emergency or maintenance/testing) on a monthly basis and compiled into a 12-month rolling-sum report</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: All stationary emergency standby engines at NBVC are equipped with non-resettable hour meters. Hours of maintenance and emergency use are recorded for each engine on a monthly basis and summarized into 12-month rolling-sum reports as required.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>




ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment ATCM Engine N4, Condition Nos. 1 and 4c</p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Non-federally enforceable requirement to use only California Air Resources Board (CARB) diesel fuel in emergency standby stationary compression ignition engines(1) and provide documentation supporting such use(4c)</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: All diesel fuel combusted in stationary emergency standby engines at Naval Base Ventura County (NBVC) during the compliance period was supplied by the NBVC Supply Department, Fuel Branch. All diesel fuel received by the Supply Department, Fuel Branch, is CARB certified. Data demonstrating the use of CARB-Certified fuel is provided in Appendix A.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment ATCM Engine N4, Condition Nos. 2 and 4(a&b)</p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Non-federally enforceable requirement to equip emergency standby stationary compression ignition engines with hour meters and limit the number of hours these engines are operated for maintenance and testing to no more than 50 hours during any 12- month period. In addition, the operational hours of each engine shall be summarized by use (emergency or maintenance/testing) on a monthly basis and compiled into a 12-month rolling-sum report</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: All stationary emergency standby engines at NBVC are equipped with non-resettable hour meters. Hours of maintenance and emergency use are recorded for each engine on a monthly basis and summarized into 12-month rolling-sum reports as required.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment ATCM Engine N4, Condition No. 3</p>	<p>D. Frequency of monitoring: Ensured at ATC application submittal</p>
<p>B. Description: Non-federally enforceable requirement that all "in-use" emergency standby stationary compression ignition engines subject to this rule to be EPA/CARB certified to meet the particulate matter standard of 0.15 grams/BHP-hr</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: All "in-use" emergency standby stationary compression ignition engines subject to this rule are CARB certified as required. Certification documents are available upon request.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment ATCM Engine N5, Condition Nos. 1 and 4c</p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Non-federally enforceable requirement to use only California Air Resources Board (CARB) diesel fuel in emergency standby stationary CI engines installed after January 1, 2005 (1) and provide documentation supporting such use(4)</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: All diesel fuel combusted in stationary emergency standby engines at Naval Base Ventura County (NBVC) during the compliance period was supplied by the NBVC Supply Department, Fuel Branch. All diesel fuel received by the Supply Department, Fuel Branch, is CARB certified. Data demonstrating the use of CARB-Certified fuel is provided in Appendix A.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment ATCM Engine N5, Condition No. 2</p>	<p>D. Frequency of monitoring: Monthly</p>
<p>B. Description: Non-federally enforceable requirement that all emergency standby stationary CI engines installed after January 1, 2005 be EPA/CARB certified to meet the particulate matter emission standard of 0.15 grams/BHP-hr</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: All stationary emergency standby engines installed after January 1, 2005 at NBVC are CARB certified as required. Certification documents are available upon request.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment ATCM Engine N5, Conditions No. 3, 4.a, and 4.b</p>	<p>D. Frequency of monitoring: Ensured at ATC application submittal</p>
<p>B. Description: Non-federally enforceable requirement to equip emergency standby stationary CI engines installed after January 1, 2005 with hour meters and limit the number of hours these engines are operated for maintenance and testing to no more than 50 hours during any 12-month period. In addition, the operational hours of each engine shall be summarized by use (emergency or maintenance/testing) on a monthly basis and compiled into a 12-month rolling-sum report. Also, when not being operated for maintenance or testing, the emergency engine(s) are used only for "emergency use".</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: All stationary emergency standby engines installed after January 1, 2005 at NBVC are equipped with non-resettable hour meters. Hours of maintenance and emergency use are recorded for each engine on a monthly basis and summarized into 12-month rolling-sum reports as required.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment ATCM Portable Engine Condition No. <u>1</u></p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Non-federally enforceable requirement to use only California Air Resources Board (CARB) diesel fuel in portable diesel engines</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: All diesel fuel combusted in portable diesel engines at Naval Base Ventura County (NBVC) during the compliance period was supplied by the NBVC Supply Department, Fuel Branch. All diesel fuel received by the Supply Department, Fuel Branch, is CARB certified. Data demonstrating the use of CARB-Certified fuel is provided in Appendix A.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment ATCM Portable Engine Condition No. <u>2</u></p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Non-federally enforceable requirement that all portable diesel-fueled engines permitted prior to January 1, 2010 be certified to meet federal or California standard for newly manufactured engines</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: All portable diesel-fueled engines permitted prior to January 1, 2010 at NBVC meet federal or California standard for newly manufactured engines. All Tier zero portable diesel-fueled engines owned by NBVC were removed from service before January 1, 2010.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment ATCM Portable Engine Condition No. <u>3</u></p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Non-federally enforceable requirement that all portable diesel-fueled engines permitted on or after January 1, 2010 be certified to the most stringent standards contained in the federal or California emission standards for nonroad engines</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: All portable diesel-fueled engines permitted on or after January 1, 2010 at NBVC are certified to the most stringent standards contained in the federal or California emission standards for nonroad engines.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment ATCM Portable Engine Condition No. <u>4</u></p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Non-federally enforceable requirement that the weighted average particulate matter emission rate for the fleet of portable diesel engines shall not exceed the standards specified at Section 93116.3(c), Title 17, California Code of Regulations</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Naval Base Ventura County is unable to meet the fleet average of 0.10 g/bhp-hr beginning 1/1/2020 and has elected the Phase Out Option beginning 1/1/2022. Two Tier 2 portable generators will be phased out prior to 1/1/2022 in order to meet the Portable ATCM requirement.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment CARB Truck & Bus, Condition No. 1</p>	<p>D. Frequency of monitoring:</p> <p>Periodic</p>
<p>B. Description:</p> <p>Non-federally enforceable requirement that all sweeper vehicle auxiliary engines be operated with the applicable requirements of CARB Regulation to reduce emissions from in-use heavy-duty diesel-fueled vehicles</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>All portable diesel sweeper engines operate at NBVC are in compliance with the applicable requirements of CARB "Regulation to Reduce Emission of Diesel Particulate Matter, NOx, and Other Pollutants from In-Use Heavy-Duty Diesel-Fueled Vehicles". All two-engine sweepers at NBVC are operated in compliance with the Regulation and planned to be phased out in accordance with Section (f)(1).</p>	<p>I. Currently in Compliance? (Y or N): <u>Y</u></p> <p>J. Compliance Status? (C or I): <u>C</u></p> <p>K. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment CARB Truck & Bus, Condition No.2</p>	<p>D. Frequency of monitoring:</p> <p>Periodic</p>
<p>B. Description:</p> <p>The permittee shall maintain a status record of each sweeper vehicle's compliance requirements and compliance status with the Regulation to Reduce Emissions of Diesel Particulate Matter, Oxides of Nitrogen and Other Criteria Pollutants, from In-Use and Heavy-Duty Diesel-Fueled Vehicles, specifically the requirements for sweeper vehicle auxiliary engines located in Section (n).</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>Records of all sweepers are included in an inventory of NBVC's Truck & Bus Fleet. The inventory that includes sweepers is kept on file and updated periodically. The inventory includes compliance requirements and replacement schedules, as per the Regulation, including Section (n).</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 74.12N1</p>	<p>D. Frequency of monitoring: Monthly</p>
<p>B. Description: ROC limits for coatings, application method requirements, solvents and vapor pressure limits for solvents, and recordkeeping requirements associated with the coating of metal parts and products</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: All coating and solvent materials must be approved by Environmental Division Air Quality Program (EDAQP) before they can be procured. A description of the item coated is made for the purpose of determining whether Rule 74.12 or another rule applies. A current material list showing the name and manufacturer of the components is accomplished by means of a database that records each issuance of a coating and solvent. In addition, volume of all coatings applied to any metal substrate, manufacturer, ROC Content, mix ratio, and type of coatings are recorded by each coating operation on a daily basis. These records are submitted to the EDAQP on a monthly basis. Volume of all coatings are compiled and reported against permit limits as total coatings applied. Only solvents with ROC contents of 25 grams per liter and less are used for substrate surface cleaning and cleanup. Routine inspection of the coating activities is made to ensure compliance with all standards.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

A. Attachment # or Permit Condition #: Attachment 74.15N1	D. Frequency of monitoring:
B. Description: Emissions not to exceed 40 ppmvd NOx and 400 ppmvd CO, as demonstrated by biennial source test report. Routine surveillance is also required	Biennial
C. Method of monitoring: Wharfs 3 and Wharf 4 boilers have been out of service during the compliance certification period.	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable CARB Method 100 F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 74.15.1N1</p>	<p>D. Frequency of monitoring: Screening annually, source test every 48 months</p>
<p>B. Description: Emissions not to exceed 30 ppmvd NOx and 400 ppmvd CO, as demonstrated by quadrennial source test analysis. Also, requirement to conduct annual screening analysis when source test is not performed.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable CARB Method 100</p>
<p>C. Method of monitoring: The 1.825 MMBTU/hr Laars boiler, located at Building 2, was scheduled to be source tested in June 2019 but was not due to mechanical issues. The boiler has not run since June 2019. A follow-up source test date has been scheduled for February 2021.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 74.15.1N2</p>	<p>D. Frequency of monitoring:</p> <p>Annual</p>
<p>B. Description:</p> <p>Requirement to perform tune-ups, install totalizing fuel meter, and keep records. Submit tune-up reports to District every 12 months</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p>N/A</p>
<p>C. Method of monitoring:</p> <p>The 2.1 MMBTU/hr Hurst Boiler is used for training purposes only and is fired on fuel oil and natural gas. It is equipped with fuel meters for both fuels. Reading from both meters are taken on a monthly basis and compiled into a 12-month rolling sum report. No tune-up report for 2020 per conditional agreement with VCAPCD. Tune-up due March 2021.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>




Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 74.15.1N5</p>	<p>D. Frequency of monitoring: Screening annually, source test every 48 months,</p>
<p>B. Description: Emissions not to exceed 20 ppmvd NOx and 400 ppmvd CO, as demonstrated by quadrennial source test analysis. Also, requirement to conduct annual screening analysis when source test is not performed.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable CARB Method 100</p>
<p>C. Method of monitoring: Two 1.44 MMBTU/hr Lochinvar boilers located at Building 1479 were last source tested on 6/18/2019. The test reported NOx, CO, and Stack Gas Oxygen values in accordance with California Air Resources Board Method 100. The emission screening was conducted on both boilers on 3/25/20. Boilers source test and emission screening results are presented in Appendix B.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 74.18N1</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description:</p> <p>ROC limits for coatings and solvents, work practice and application method requirements and vapor pressure limits for solvents, and recordkeeping requirements associated with the coating of motor vehicles and mobile equipment</p>	<p>Periodic</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p>N/A</p>
<p>C. Method of monitoring:</p> <p>All coating and solvent materials must be approved by Environmental Division Air Quality Program (EDAQP) before they can be procured. A current material list showing the name and manufacturer of the components issued to any operation abroad Naval Base Ventura County accomplished by means of a database that records each issuance of a coating and solvent material. For each issuance of material, this database contains a reference to the applicable SDS sheet. In addition, daily usage records of the type, manufacturer, ROC content, mix ratio, and volume of coatings are submitted to the EDAQP on a monthly basis. ROC contents of 25 grams per liter and less are used for substrate surface cleaning and cleanup. Routine inspection of coating operations is performed to ensure compliance with all standards.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>




Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 74.24N1</p>	<p>D. Frequency of monitoring:- Periodic</p>
<p>B. Description: ROC limits for coatings and solvents, vapor pressure limits for solvents, work practice standards, and recordkeeping requirements associated with marine coating operations</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: All coating and solvent materials must be approved by Environmental Division Air Quality Program before they can be procured. A current material list showing the name and manufacturer of the components issued to any operation aboard Naval Base Ventura County accomplished by means of a database that records each issuance of a coating and solvent material. For each issuance of material, this database contains a reference to the applicable SDS sheet. In addition, daily usage records of the type, manufacturer, ROC content, mix ratio, and volume of coatings are submitted to the EDAQP on a monthly basis. Volume of all coatings are recorded, compiled, and reported against permit limits as total coatings applied. ROC contents of 25 grams per liter and less are used for substrate surface cleaning and cleanup. Routine inspection of coating activities is performed to ensure compliance with all requirements.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>




Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 74.29N2</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Rule 74.29, Soil decontamination operations and recordkeeping procedures</p>	<p>N/A</p>
<p>C. Method of monitoring: The vapor extraction system at the "Navy Exchange Gas Station" (formerly VCAPCD Permit #00902) did not extract vapors from the subsurface at any time during this compliance certification period. The system has been dormant and inactive during this certification period.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>	



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 74.30N1</p>	<p>D. Frequency of monitoring:</p> <p>Periodic</p>
<p>B. Description:</p> <p>ROC limits for coatings and solvents and vapor pressure limits for solvents, work practice standards, and recordkeeping requirements associated with wood products coating operations</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p>N/A</p>
<p>C. Method of monitoring:</p> <p>All coating and solvent materials must be approved by Environmental Division Air Quality Program before they can be procured. Volume of all coatings are recorded, compiled, and reported against permit limits as total coatings applied. Routine inspection of the coating operations ensures that they are in compliance with all requirements</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>



ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

A. Attachment # or Permit Condition #: Attachment NESHAP II	D. Frequency of monitoring: As Needed
B. Description: Requirement to keep records to demonstrate the stationary source is not a major source of HAPs	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring: Hazardous Air Pollutant (HAP) emission calculations were performed to demonstrate that NBVC Port Hueneme site is not a major source of HAPs. No changes occurred during 2020 that would have influenced Naval Base Ventura County (NBVC)'s HAP status. Documentation of the original HAP calculations is maintained by the NBVC Air Program and is available upon request.	F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form




ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 40CFR63ZZZN3, Condition No. 1</p>	<p>D. Frequency of monitoring:</p> <p>Air cleaner inspection: every 1000 hours of operation or annually, whichever comes first</p> <p>Oil and filter change: every 500 hours of operation or annually, whichever comes first</p> <p>Hoses and belts inspection: every 500 hours of operation or annually, whichever comes first</p>
<p>B. Description:</p> <p>National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (RICE)- Requirements to change filter and oil , and inspect air cleaner, hoses, and belts</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>Naval Base Ventura County has a maintenance plan to ensure compliance with the maintenance requirements of Attachment 40CFR63ZZZN3</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 40CFR63ZZZN3, Condition No. 2</p>	<p>D. Frequency of monitoring:</p> <p>Routine</p>
<p>B. Description:</p> <p>Requirement that all existing emergency diesel stationary RICE are operated and maintained according to the manufacture's emission-related written instructions or NVBC plan in a manner to minimize emissions</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>All existing emergency diesel stationary RICE were operated and maintained according to the manufacturer's instructions and RICE NESHAP maintenance requirements during the compliance certification period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 40CFR63ZZZN3, Condition No. 3</p>	<p>D. Frequency of monitoring:</p> <p>Monthly</p>
<p>B. Description:</p> <p>Requirement that existing emergency diesel stationary RICE are equipped with a non-resettable hour meter</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>All existing emergency diesel stationary RICE are equipped with a non-resettable hour meter.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>



ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 40CFR63ZZZN3, Condition No. 4</p>	<p>D. Frequency of monitoring:</p> <p>Routine</p>
<p>B. Description:</p> <p>Requirement that permittee minimize the engine's time spent at idle during startup, not to exceed 30 minutes</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p>N/A</p>
<p>C. Method of monitoring:</p> <p>To conserve resources and reduce emissions, NBVC limits the idling of stationary engines to the period of time required to bring the subject engines to a mechanically optimal operating temperature. In no case do these periods of optimization exceed 30 minutes.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 40CFR63ZZZN3, Condition No. 5(b)</p>	<p>D. Frequency of monitoring:</p> <p>N/A</p>
<p>B. Description:</p> <p>Requirement that existing emergency diesel stationary RICE operations are limited to 100 hours per calendar year for maintenance and testing, emergency demand response, frequency deviation situations, and up to 50 hours per year for non-emergency situations.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p>N/A</p>
<p>C. Method of monitoring:</p> <p>Federally enforceable Rule 74.9 limits the maintenance hours of operation to 50 hours per calendar year for the emergency standby stationary internal combustion engines rated at 50 or more break-horsepower operated at NBVC. In addition, Airborne Toxic Control Measure (ATCM) for stationary compression ignition engines limits the maintenance hours of operation to 20 hours per calendar year for engines installed prior to January 1, 2005 and 50 hours per calendar year for engines installed after January 1, 2005.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 40CFR63ZZZN3, Condition No. 5(c)</p>	<p>D. Frequency of monitoring:</p> <p>N/A</p>
<p>B. Description:</p> <p>Operation of the existing emergency diesel stationary RICE for Peak shaving or non-emergency demand response program</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p>N/A</p>
<p>C. Method of monitoring:</p> <p>None of the existing emergency stationary RICE located at NBVC was operated for peak shaving or non-emergency demand response during the compliance certification period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 40CFR63ZZZN3, Condition No. 6</p>	<p>D. Frequency of monitoring: Monthly</p>
<p>B. Description: Recordkeeping requirements</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Naval Base Ventura County has developed a maintenance plan to ensure compliance with the maintenance requirements of 40 CFR Part 63, Subpart ZZZZ. The records of maintenance are retained by the Environmental Division Air Quality Program (EDAQP). All stationary emergency RICE at NBVC are equipped with non-resettable hour meters. Hours of maintenance and emergency use are recorded for each engine on a monthly basis by the EDAQP.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 40CFR63ZZZN3, Condition No. 9</p>	<p>D. Frequency of monitoring: N/A</p>
<p>B. Description: Requirement that on an annual basis, the permittee certify that all engines at the stationary source are operating in compliance with 40 CFR Part 63, Subpart ZZZZ, NESHAP for RICE</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: All engines at NBVC were operated in compliance with 40 CFR Part 63, Subpart ZZZZ, NESHAP for RICE during the compliance certification period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 40CFR60IIIN1, Condition No. 1</p>	<p>D. Frequency of monitoring:</p> <p>Per Event</p>
<p>B. Description:</p> <p>Requirement that stationary compression ignition engines which are 2007 model or later, are used for emergency purposes, and have an engine displacement of less than 10 liters per cylinder comply with the certification emission standards for new nonroad compression ignition engines for the same model year and maximum engine power found in 40 CFR 89.112 and 40 CFR 89.113.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>Environmental Division Air Quality Program staff review and verify the California Air Resources Board (CARB) and Environmental Protection Agency emission certification for the new stationary compression ignition internal combustion engine prior to purchasing and installing the engine. In addition, VCAPCD Rule 26.2 has required Best Available Control Technology (BACT) for all new emissions units. Therefore, all new emergency diesel engines installed and permitted in Ventura County after 2007 are in compliance with this requirement because the BACT requirements are at least as stringent as the engine standards of 40 CFR 89.112 and 40 CFR 89.113.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 40CFR60IIIN1, Condition No. 2</p>	<p>D. Frequency of monitoring:</p> <p>Periodic</p>
<p>B. Description:</p> <p>Requirement to use CARB diesel fuel in stationary compression ignition emergency engines</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>All diesel fuel combusted in stationary emergency engines at Naval Base Ventura County (NBVC) during the compliance period was supplied by the NBVC Supply Department, Fuel Branch. All diesel fuel received by the Supply Department, Fuel Branch, is CARB certified. Data demonstrating the use of CARB-certified fuel is provided in Appendix A.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment PO01006PC1-671, Condition No. 1</p>	<p>D. Frequency of monitoring:</p> <p>Monthly</p>
<p>B. Description:</p> <p>Requirement to keep monthly records of throughput/usage for all operations listed in Table 3 of Permit 01006. On an ongoing basis, monthly usage for each operation is to be summed for the previous 12 months, and the totals reported.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>All applicable data are gathered each month and entered into a database. For each throughput/usage limit, data are compiled to determine the throughput/usage for each month. Monthly data are then summed for each period of 12 consecutive months. These 12-month rolling sums are reported.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO01006PC1-671, Condition No. 2</p>	<p>D. Frequency of monitoring:</p> <p>Monthly</p>
<p>B. Description:</p> <p>For solvent cleaning activities, requirement to keep monthly records of solvents purchased, recycled, or disposed</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>Records of solvents purchased are extracted from a database called Enterprise Resources Planning (ERP), which keeps a record each time a hazardous material is issued to the end user. Some data as to solvents disposed is gathered from a database called Hazardous Waste Declaration System (HWDS). There are not always records of solvents disposed, and in such cases, the solvents are conservatively assumed to have evaporated, and are reported as such.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO01006PC1-671, Condition No. 3</p>	<p>D. Frequency of monitoring:</p> <p>Annual</p>
<p>B. Description:</p> <p>Requirement that all State-registered portable equipment comply with State registration requirements, and that a copy of State registration be available</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>Tactical support equipment are registered with the California Air Resources Board's Portable Equipment Registration Program (PERP). PERP requirements for tactical support equipment are minimal--requiring only a description of each type of equipment and the number of units attached to the facility. Documentation of equipment registration is maintained in the Air Quality Program Office. Prior to the annual PERP renewal date, a survey is conducted of all tactical support equipment located at the facility.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>



ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment PO01006PC2-rev761, Condition No. 1</p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Requirement that the sulfur content of distillate fuel burned in portable internal combustion engines shall not exceed 0.05% by weight</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: All diesel fuel burned in portable internal combustion engines is supplied by the Naval Base Ventura County (NBVC) Supply Department, Fuel Branch. All diesel fuel received by the Supply Department, Fuel Branch, is California Air Resources Board (CARB) certified. Data demonstrating the use of CARB-certified fuel are provided in Appendix A. Data indicating the use of CARB-certified fuel is maintained at the facility and provided with this annual compliance certification in Appendix A.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO01006PC2-rev761, Condition No. 2, as applicable to individual engines with limits expressed in hours per year</p>	<p>D. Frequency of monitoring: Monthly</p>
<p>B. Description: Requirement that affected engines be equipped with hour meter, and their hours of operation be recorded monthly and compiled so as to demonstrate compliance with the usage limits of Table 3</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Each engine with an applicable limit is equipped with a properly installed and maintained hour meter. Hour meters of each engine are read on a monthly basis or more often to ensure compliance with the rolling-12-month limits. The data are compiled monthly and compared to the applicable limits.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO01006PC2-rev761, Condition No. 2, as applicable to engines that are part of an engine group where the limit is expressed in BHP-hrs/year</p>	<p>D. Frequency of monitoring: Monthly</p>
<p>B. Description: Requirement that engine usage be properly recorded and compiled so as to demonstrate compliance with the usage limits of Table 3</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Each engine is equipped with a properly installed and maintained hour meter. Hour meters of each engine are read monthly. Monthly hours of operation are determined and multiplied by the BHP rating of each engine to determine BHP-hours for that engine for that month. Values for all engines in a group are summed to determine total BHP-hours for that month. Each month, total monthly BHP-hrs are summed for the previous 12 months and compared to the applicable BHP-hr/year limit.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>




ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment PO01006PC2-rev761, Condition No. 3</p>	<p>D. Frequency of monitoring: Per Operation</p>
<p>B. Description: Non-federally enforceable requirement that the five portable John Deere engines (4- 165 BHP units and 1- 315 BHP unit) provide power to a) individual buildings housing critical infrastructure during grid maintenance and electrical repair operations, b) provide power during emergency use, and C) maintenance and testing use of the combined five engines shall not exceed the 95,750 BHP-hr per year limit.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Each engine is equipped with a non-resettable hour meter. A log of engine operation which includes usage record and describes the purpose of each engine use is maintained by Environmental Division Air Quality Program office.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO01006PC2-rev761, Condition No. 4</p>	<p>D. Frequency of monitoring: Per Operation</p>
<p>B. Description: Non-Federally enforceable requirement to notify Ventura County Air Pollution Control (VCAPCD) of long term operations requiring the use of portable engines</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: During this compliance certification period, no portable engines were used at any single location where operations lasted for more than 30 days. Therefore, no notification on this subject was made to VCAPCD.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO01006PC2-rev761, Condition No. 5</p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Prohibition against using a portable engine to perform a permanent function</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Portable engines at NBVC are used by the Public Works Department. Due to the inherent nature of their work, engines are constantly moved from one location to another within the site to perform work.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

A. Attachment # or Permit Condition #: Attachment PO01006PC2-rev761, Condition No. 6	D. Frequency of monitoring: Periodic
B. Description: NOx emission requirements for sweeper engines, as per Rule 26	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring: All sweeper vehicle portable diesel engines have NOx emission certification documents.	F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment PO01006PC4- rev671, Condition No. 1</p>	<p>D. Frequency of monitoring:</p> <p>N/A</p>
<p>B. Description:</p> <p>Requirement that the gasoline loading rack at Building 5307 be equipped with a California Air Resources Board (CARB)-certified vapor recovery system</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p>N/A</p>
<p>C. Method of monitoring:</p> <p>Naval Base Ventura County has a letter from CARB dated November 21, 2003, stating that the 20,000-gallon Bryant Fuel Systems bulk plant system installed at Port Hueneme will meet the 95% vapor recovery efficiency requirement as required for site-specific certification.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO01006PC4- rev671, Condition No. 1</p>	<p>D. Frequency of monitoring:</p> <p>Monthly</p>
<p>B. Description:</p> <p>Requirement that no more than 100,000 gallons of gasoline per year are transferred from the loading rack to delivery vessels, and that no more than 100,000 gallons of gasoline per year are subsequently delivered to non-motor vehicle equipment. Monthly recordkeeping to demonstrate compliance is also required</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p>N/A</p>
<p>C. Method of monitoring:</p> <p>Fuel transfers are recorded in a database at the point at which they are transferred from the delivery vessel to the end user (dispensed into equipment that is not a motor vehicle). Data from this database is compiled into monthly reports. Fuel transfers from the loading rack to the delivery vessel are assumed equal fuel deliveries. Since the gasoline tank has been out of service since 4 January 2016, no gasoline has been transferred from the loading rack after 4 January 2016.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>



ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment PO01006PC5-671, Condition No. 1</p>	<p>D. Frequency of monitoring: Annually</p>
<p>B. Description: Federally enforceable requirement that five boilers (one at Wharf 3, one at Wharf 4, one at Building 2, and two at Building 1479) and one burner at Building 1100 be fired only on PUC regulated natural gas</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Compliance is demonstrated by the fact that the only fuel supply to these boilers is by the natural gas utility distribution system, which is PUC-regulated. Boilers at Wharves 3 and 4 were out of service during the compliance certification period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO01006PC5-671, Condition No. 2</p>	<p>D. Frequency of monitoring: Monthly</p>
<p>B. Description: Requirement that natural gas usage for each boiler shall not exceed the limits listed in Section No. 3, "Permitted Throughput and Consumption Limit Table"</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Boiler gas meter readings are taken each month. These readings are compiled into reports that express gas usage on a monthly basis and usage over the preceding 12 months. Reports were generated for each of the twelve month periods that ended during the compliance certification period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO01006PC5-671, Condition No. 3, as applicable to distillate oil consumption in the Hurst Boiler at Building 1419</p>	<p>D. Frequency of monitoring: Monthly</p>
<p>B. Description: Requirement that the total distillate oil consumption in the Hurst Boiler shall not exceed 1,000 gallons per year. Associated recordkeeping to ensure compliance is also required</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: The 2.1 MMBTU Hurst boiler at Building 1419 is fitted with two totalizing fuel meters--one on the fuel delivery line, and one on the return line. Consumption is determined by subtracting the fuel returned from the fuel delivered.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment PO01006PC5-671, Condition No. 3, as applicable to natural gas consumption in the Hurst Boiler at Building 1419</p>	<p>D. Frequency of monitoring: Monthly</p>
<p>B. Description: Requirement that the total natural gas consumption in the Hurst Boiler shall not exceed 0.1 MMCF per year. Associated recordkeeping to ensure compliance is also required</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Natural gas consumption in the 2.1 MMBTU Hurst Boiler at Building 1419 was determined by a totalizing fuel meter.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO01006PC5-671, Condition No. 3, as applicable to the Global boilers</p>	<p>D. Frequency of monitoring: Monthly</p>
<p>B. Description: Requirement that the annual hours of operation for the two Global aircraft de-icer process heaters does not exceed 200 hours. Associated recordkeeping to ensure compliance is also required</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: The two Global aircraft de-icers are equipped with dedicated totalizing hour meters and the hour meter readings are taken each month.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO01006PC5-671, Condition No. 4</p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Requirement that the sulfur content of distillate fuel burned in the Hurst and Global boilers shall not exceed 0.05% by weight.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Compliance with this requirement is demonstrated by the fact that all diesel fuel burned in boilers is supplied by the Naval Base Ventura County Supply Department, Fuel Branch, and that all diesel fuel received by the Supply Department, Fuel Branch is California Air Resources Board certified. Please see Appendix A for documentation.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment PO01006PC5-671, Condition No. 5</p>	<p>D. Frequency of monitoring: Biennial</p>
<p>B. Description: BACT condition for the two 8.4 MMBTU/hr Superior boilers at Wharf #3 and Wharf #4 that limits NOx emissions to 12 ppmvd at 3% oxygen, averaged over 16 consecutive minutes. Source testing requirement is also specified at a minimum of every 24 months</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable CARB Method 100 and EPA Method 19</p>
<p>C. Method of monitoring: Both Boilers were out of service during the compliance certification period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO01006PC5-671, Condition No. 6</p>	<p>D. Frequency of monitoring: Monthly</p>
<p>B. Description: Requirement to install dedicated totalizing natural gas fuel meters on the two 8.4 MMBTU/hr Superior boilers at Wharf 3 and Wharf 4</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Dedicated totalizing fuel meters were installed on Wharves 3 and 4 boilers. Both Boilers were out of service during the compliance certification period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO01006PC5-671, Condition No. 7</p>	<p>D. Frequency of monitoring: Monthly</p>
<p>B. Description: Requirement that the two 4.8 MMBTU/hr Global aircraft de-icers be equipped with dedicated hour meters</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Compliance with this requirement is demonstrated by the fact that the two Global aircraft de-icers are equipped with dedicated totalizing hour meters.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment PO01006PC5-671, Condition No. 8</p>	<p>D. Frequency of monitoring:</p> <p>Periodic</p>
<p>B. Description:</p> <p>Requirement that the two 4.8 MMBTU/hr Global aircraft de-icers are to be used only for aircraft deicing training purposes only</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>Compliance with this requirement is ensured by the fact that the de-icer vehicles in which the boilers are permanently mounted are not readily suitable for any purpose other than aircraft de-icing. Routine inspections ensure that the units are not altered. Since there is never any ice in Port Hueneme to remove, or any aircraft to de-ice, it is logical that the boilers are only used for training purposes.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO01006PC5-671, Condition No. 9</p>	<p>D. Frequency of monitoring:</p> <p>Monthly</p>
<p>B. Description:</p> <p>Requirement that the Hurst boiler located in building 1419 be used for training purposes only</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>Compliance with this requirement is demonstrated by the fact that the boiler is plumbed in such a manner that any steam or hot water produced by it cannot serve any useful purpose. Logically, it can only be used for training purposes.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO01006PC5-671, Condition No. 10</p>	<p>D. Frequency of monitoring:</p> <p>Periodic</p>
<p>B. Description:</p> <p>BACT requirement that the Hurst boiler located in building 1419 operates in compliance with APCD Rule 74.16.1 and Rule 74.16.1.B.2</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>Though the annual heat input of the 2.1 MMBTU/hr Hurst boiler is less than 300 MMBTU, it is operated per the requirements of Rule 74.16.1.B.2 for boilers with an annual heat input greater than 300 MMBTU (and less than 1,800 MMBTU).</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment PO01006PC5-671, Condition No. 11</p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Requirement that the NCEL Burner shall be used for testing purposes only</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: The NCEL burner is designed to produce a very high speed flame to simulate a jet engine exhaust. It is impractical to use this burner for any purpose other than for testing. Routine inspections ensure that the burner is used for testing only.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment PO01006PC6-741, Conditions No. 1 and 2</p>	<p>D. Frequency of monitoring:</p> <p>Daily during operations and monthly for recordkeeping purposes</p>
<p>B. Description:</p> <p>Federally enforceable requirement that the ROC and throughput of coatings and solvents used at NBVC Port Hueneme do not exceed the limits listed in Table 3 of Title V Permit #01006.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>Compliance with this requirement is demonstrated by means of daily logs (compiled on a monthly basis) that record the ROC and volume of coating applied and a description of the item coated. To ensure compliance with the ROC requirement, the Environmental Division Air Quality Program (EDAQP) screens the coatings and solvents prior to purchase and use in coating operations. In addition, routine inspections of paint cabinets are performed to ensure compliance with ROC content requirements. Monthly usage is summed each month and for the previous 12 months to demonstrate compliance. No coatings were applied by the Port Services Department during the compliance certification period other than architectural coatings for routine maintenance purposes.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>
<p>A. Attachment # or Permit Condition #: Attachment PO01006PC6-741, Condition No. 3</p>	<p>D. Frequency of monitoring:</p> <p>As Needed</p>
<p>B. Description:</p> <p>ROC content limit of 2.8 lbs/gallon for coating of marine vessels by Naval Surface Warfare Center (NSWC). Associated recordkeeping is also required</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>All coating and solvent materials must be approved by EDAQP before they can be procured. Approval of any coating with ROC content in excess of 2.8 lbs/gallon is not granted. Routine inspection of coating activities is performed to ensure compliance with all requirements including maintaining records of coatings and ROC content.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>
<p>A. Attachment # or Permit Condition #: Attachment PO01006PC6-741, Condition No. 4</p>	<p>D. Frequency of monitoring:</p> <p>Periodic</p>
<p>B. Description:</p> <p>Requirement that only inorganic solvents are used in surface preparation or cleanup of application equipment associated with the coating of marine vessels at Naval Surface Warfare Center (NSWC) buildings.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>All materials must be approved by EDAQP before they can be procured. Compliance is also ensured by periodic inspection of the paint storage lockers by Air Quality Program personnel.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment PO01006PC6-741, Condition No. 5</p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Non-Federally enforceable requirement for paint spray booths and painting rooms to be fitted with overspray filters, and that the filters be replaced before the spray booth manometer reaches 0.5 inches of water column.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Each spray booth is equipped with overspray filters and a manometer. Compliance is ensured by periodic monitoring and inspection of coating operations in spray booths and paint rooms performed by EDAQP staff.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO01006PC6-741, Condition No. 6</p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Non-Federally enforceable prohibiting the use of coatings containing lead or hexavalent chromium.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Compliance with this requirement is demonstrated by the fact that all coatings must be approved by the EDAQP prior to their purchase or use in coating operations. No coatings containing lead or hexavalent chromium are approved for use.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment PO01006PC7-rev721, Conditions No. <u>1</u></p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Limit of one ton per year of abrasives for use in unconfined abrasive blasting operations</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Projects that involve unconfined blasting are required to go through the Public Works Project Review Board. Such projects are reviewed by Environmental Division Air Quality Program (EDAQP) staff, who require that the quantity of the abrasive blasting materials used is reported to the EDAQP.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO01006PC7-rev721, Conditions No. <u>2</u></p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Limit of seven tons per year of abrasives for combined use in four abrasive blast cabinets</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Monthly abrasive usage records for the four abrasive blast cabinets are submitted to the EDAQP and compiled into rolling 12 month throughput reports.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO01006PC7-rev721, Conditions No. <u>3</u></p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Requirement that unconfined abrasive blasting operations comply with Rule 74.1</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Projects that involve unconfined blasting are required to go through the Public Works Project Review Board. Such projects are reviewed by EDAQP staff, which in turn requires that all contractors comply with Rule 74.1.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment PO01006PC7-rev721, Condition No. 4(a)</p>	<p>D. Frequency of monitoring: Annual</p>
<p>B. Description: Opacity survey from confined abrasive blasting operations at Buildings 813 and 1497</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: The Building 1497 blast booth was out of service during the compliance certification period. Opacity survey was performed on the blast cabinets located inside Buildings 813 and 1497 on 12/10/2020. No opacity was noted.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO01006PC7-rev721, Condition No. 4(b)</p>	<p>D. Frequency of monitoring: Annual</p>
<p>B. Description: Requirement to control PM emissions from dust collectors, a floor reclaim system, bucket elevator, and media cleaning unit associated with the Building 1497 blast booths. This includes maintenance of the dust collector system and inspection and/or replacement of each filter cartridge on an annual basis.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: The Building 1497 blast booth was out of service during the compliance certification period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO01006PC7-rev721, Condition No. 4(d)</p>	<p>D. Frequency of monitoring: Routine</p>
<p>B. Description: Requirement to follow dust handling and filters inspection protocols and to operate the Clemco abrasive blast cabinet at Building 813 pursuant to manufacturer's specifications.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: The three Clemco abrasive blast cabinets dust collectors and their pulse jet cleaning systems were operated pursuant to manufacturer's specifications. All filters were inspected 12/10/2020. A record of filter inspection is maintained at the facility.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment PO01006PC7-rev721, Condition No. 4(e)</p>	<p>D. Frequency of monitoring: Routine</p>
<p>B. Description: Requirement to use manufacturer's approved blast media in the Building 813 and Building 1497 blast cabinets</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Routine surveillance of the blast cabinets at Buildings 813 and 1497 confirms that only blast media that is approved by the manufacturer was used during the compliance certification period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO01006PC7-rev721, Condition No. 5</p>	<p>D. Frequency of monitoring: Monthly for abrasive usage and annually for opacity and filter inspection</p>
<p>B. Description: Requirement to keep a record of the annual survey and inspection of duct collector filters, and monthly and twelve month rolling sum of abrasive blast media used in Building 813 and 1497 blast cabinets</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Records of the annual inspection of duct collector filters, and monthly and twelve month rolling sums of abrasive blast media used in Building 813 and 1497 blast cabinets are maintained by EDAQP.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>




Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

A. Attachment # or Permit Condition #: Attachment PO1006PC8	D. Frequency of monitoring:
B. Description: Conditions associated with alternative operating scenarios	N/A
	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring: No surge condition or national security emergency was declared at any time during this compliance certification period.	F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form



ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment PO01006PC9-rev491</p>	<p>D. Frequency of monitoring:</p> <p>Monthly</p>
<p>B. Description:</p> <p>Requirement that any equipment designated as "Out of Service" in Tables 2, 3, and 4 of this permit is shut down and not operated.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>All the equipment designated as "Out of Service" in Tables 2, 3, and 4 of this permit were shut down and did not operate during the compliance period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO01006PC9-rev641, Condition 2</p>	<p>D. Frequency of monitoring:</p> <p>As Needed</p>
<p>B. Description:</p> <p>Requirement that before operating any equipment designated as "Out of Service", a Modification to Part 70 Permit application be submitted.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>A Modification to Part 70 Permit application is submitted before operating any equipment designated as "Out of Service".</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Rule 50-- Opacity,</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Prohibition of visible emissions, requirement for routine surveillance and a formal opacity survey</p>	<p>Annual</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Surveillance of all equipment is conducted on a routine basis as required. A formal survey of all emission units at the facility was completed in July, August, and December 2020. An untrained observer noted no visible emissions during the survey. Appendix C contains a copy of the formal survey results.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

A. Attachment # or Permit Condition #: Attachment 54.B.1	D. Frequency of monitoring:
B. Description: Sulfur emissions at point of discharge	N/A
	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring: Compliance with Attachment 54.B.1 is demonstrated by compliance with Rule 64 as noted in the Applicability section of Attachment 54.B.1.	F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 54.B.2</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Ground or sea level sulfur emissions at or beyond the stationary source property line</p>	<p>N/A</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Compliance with Attachment 54.B.2 is demonstrated by screening level dispersion modeling tests referenced in the Ventura County Air Pollution Control District (VCAPCD) Memorandum dated May 23, 1996, authored by Terri Thomas of the VCAPCD.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 55</p>	<p>D. Frequency of monitoring: Routine</p>
<p>B. Description: Applicable requirements for activities capable of generating fugitive dust</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: The Public Works Project Review Board requires that contractors who perform construction activities at Naval Base Ventura County and are capable of generating fugitive dust to comply with the Ventura County Air Pollution Control District Rule 55 conditions.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 55.1</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description:</p> <p>Applicable requirements for paved and unpaved road activities</p>	<p>Routine</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>The Public Works Project Review Board requires that contractors who perform road construction activities at Naval Base Ventura County to comply with the Ventura County Air Pollution Control District Rule 55.1 conditions.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

A. Attachment # or Permit Condition #: Attachment 57.1	D. Frequency of monitoring:
B. Description: Limit on emissions of particulate matter to 0.12 pounds per MMBTU of fuel input	N/A
	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring: According to an analysis of the facility by Ventura County Air Pollution Control District using Rule 57.B dated December 3, 1997 periodic monitoring is not necessary to demonstrate compliance with Rule 57.1 Compliance with other conditions of this permit is sufficient to ensure compliance with Rule 57.1.	F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Rule 64</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Sulfur Content of Fuels</p>	<p>Periodic</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Compliance with Rule 64.B.1 is demonstrated by the fact that P.U.C. regulated natural gas is the only gaseous fuel combusted at this facility. Compliance with Rule 64.B.2 is demonstrated by the fact that the diesel fuel and reformulated gasoline combusted at this facility are California Air Resources Board certified. All of these fuels comply with the 0.5% sulfur content limits of Rule 64. Supporting document for purchase of CARB certified diesel is included in Appendix 7. All of the fuels complied with the 0.5% sulfur content limits of Rule 64 during the compliance period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 74.6 (2003), Condition No. 1</p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Surface Cleaning and Degreasing -- Solvent ROC and/or Vapor Pressure</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Compliance with ROC and vapor pressure limits is ensured by the fact that all solvents must be approved by Environmental Division Air Quality Program (EDAQP) staff before they can be issued and used by any Naval Base Ventura County (NBVC) entity or tenant organization aboard NBVC.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 74.6 (2003), Condition Nos. 2 through 7</p>	<p>D. Frequency of monitoring: Periodic</p>
<p>B. Description: Conditions relating to solvent handling procedures</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Compliance with Conditions 2 through 7 of Attachment 74.6 is verified by means of routine surveillance of solvent activities that are carried out by EDAQP staff during routine visits to subject facilities.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 74.6 (2003), Condition No. 8</p>	<p>D. Frequency of monitoring: Routine</p>
<p>B. Description: Equipment and work practice requirements applicable to all cold cleaners (except remote reservoir type) -- Measurement of freeboard height, verification of initial boiling point, ROC content, and ROC composite partial pressure.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Routine inspection of solvent activities that are carried out by EDAQP staff confirmed that no non-remote reservoir cold cleaners exist.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 74.6 (2003), Condition No. 9</p>	<p>D. Frequency of monitoring:</p> <p>Routine</p>
<p>B. Description:</p> <p>Equipment and work practice standards as applicable to remote reservoir cold cleaners -- Measurement of freeboard height, verification of initial boiling point, ROC content, and ROC composite partial pressure</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>Ongoing investigation has determined that all remote reservoir cold cleaners have either been removed from service or replaced with units that use either aqueous cleaning solutions or non-ROC solvents.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 74.6 (2003), Condition No. 10</p>	<p>D. Frequency of monitoring:</p> <p>Periodic</p>
<p>B. Description:</p> <p>Conditions related to cold cleaning operation</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>Compliance with Condition 10 of Attachment 74.6 is verified by means of routine surveillance carried out by EDAQP staff during routine visits to subject facilities.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 74.6 (2003), Condition Nos. 14 and 16</p>	<p>D. Frequency of monitoring:</p> <p>Periodic</p>
<p>B. Description:</p> <p>Recordkeeping requirements associated with surface cleaning and degreasing and routine surveillance to comply with Rule 74.6</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>Compliance with the requirement to maintain a current material list showing the name, ROC and vapor pressure, and intended uses of each solvent material is accomplished by means of a database that records each issuance of a solvent material to any operation aboard NBVC. For each issuance of material, this database contains a reference to the applicable SDS sheet. The database also contains references to the recipient of the material, and ultimately to the screening sheet, which is the document that approved the material, and describes all intended uses. In addition, EDAQP staff performs routine inspection of the applicable solvent cleaning activities to ensure compliance with Rule 74.6.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 74.11</p>	<p>D. Frequency of monitoring: Upon Installation</p>
<p>B. Description: Natural gas-fired water heaters rated at less than 75,000 BTU/hr installed after July 1, 2010</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Through the Public Works Project Review Board, installers of natural gas-fired water heaters are required to comply with conditions of Ventura County Air Pollution Control District Rule 74.11. In addition, a Standard Operating Procedure (SOP) was developed and implemented by the Environmental Division Air Quality Program (EDAQP). The SOP requires the installers of water heaters to obtain a copy of the certification document from the seller or manufacturer and submit it to the EDAQP for review and approval prior to purchase. Appendix C includes the result of a limited survey of natural gas-fired water heaters rated at less than 75,000 BTU/hr installed during this compliance certification period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 74.11.1</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description:</p> <p>Natural gas-fired large water heaters and small boilers, steam generators and process heaters with a rated heat input capacity greater than 75,000 BTU/hr and less than or equal to 1,000,000 BTU/hr</p>	<p>Routine</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>Through the Public Works Project Review Board, installers of natural gas-fired large water heaters, small boilers, steam generators, and process heaters are required to comply with conditions of Ventura County Air Pollution Control District Rule 74.11.1. In addition a Standard Operating Procedure (SOP) was developed and implemented by the Environmental Division Air Quality Program (EDAQP) which requires the purchasers or installers of such devices to obtain certification documents from the seller or manufacturer and submit them to the EDAQP for review and approval. Appendix C includes the result of a limited survey of natural gas-fired water heaters rated at greater than 75,000 BTU/hr and less than or equal to 1,000,000 BTU/hr installed during this compliance certification period.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 74.22</p>	<p>D. Frequency of monitoring:</p> <p>Routine</p>
<p>B. Description:</p> <p>Natural Gas-Fired Fan-Type Central Furnaces</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p>N/A</p>
<p>C. Method of monitoring:</p> <p>Through the Public Works Project Review Board, installers of natural gas-fired fan-type central furnaces are required to comply with conditions of Ventura County Air Pollution Control District Rule 74.22. In addition, a Standard Operating Procedure (SOP) was developed and implemented by the Environmental Division Air Quality Program (EDAQP) which requires the purchasers or installers of natural gas-fired fan-type furnaces to obtain certification documents from the seller or manufacturer and submit it to the EDAQP for review and approval.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>



ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 74.1, Condition No. 1</p>	<p>D. Frequency of monitoring:</p> <p>Routine</p>
<p>B. Description:</p> <p>Requirement that abrasive blasting of moveable items take place within a permanent building</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>As a Navy policy, all abrasive blasting of moveable items must take place within an abrasive blast room or an abrasive blast cabinet equipped with a dust control device. Routine surveillance of abrasive blasting operations is conducted to verify compliance.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 74.1, Condition No. 2</p>	<p>D. Frequency of monitoring:</p> <p>Per Operation</p>
<p>B. Description:</p> <p>Requirement that permissible outdoor blasting take place using approved methods</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>All projects that involve permissible outdoor blasting are required to go through the Public Works Project Review Board. Such projects are reviewed by a member of the Environmental Division Air Quality Program (EDAQP) to ensure compliance with Rule 74.1.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 74.1, Condition Nos. 3 and 4</p>	<p>D. Frequency of monitoring:</p> <p>Per Operation</p>
<p>B. Description:</p> <p>Requirements for the blasting of pavement and stucco</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring:</p> <p>All projects that involve blasting of pavement and stucco are required to go through the Public Works Project Review Board. All such projects reviewed by a member of EDAQP to ensure compliance with Rule 74.1.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 74.1, Condition No. 7</p>	<p>D. Frequency of monitoring: Per Operation</p>
<p>B. Description: Requirement to monitor each abrasive blasting operation and keep records associated with permissible outdoor blasting</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: EDAQP requires all contractors to follow Rule 74.1 when conducting outdoor abrasive blasting operations. Contractors are required to submit the records specified in Condition 7 of Attachment 74.1 to the Environmental Division.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 74.2, Condition Nos. 1 and 2</p>	<p>D. Frequency of monitoring: Per Operation</p>
<p>B. Description: VOC content limits for flat, nonflat, nonflat-high gloss, specialty, and industrial maintenance architectural coatings</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: The Naval Base Ventura County (NBVC) Public Works Project Review Board requires contractors who perform architectural coating operations at NBVC to comply with the VOC limits of Ventura County Air Pollution Control District (VCAPCD) Rule 74.2.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 74.2, Condition No. 3</p>	<p>D. Frequency of monitoring: Routine</p>
<p>B. Description: Requirement that all the architectural coating are applied directly from the containers, and any VOC-containing materials used for thinning and cleanup be stored in closed containers when not in use.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: The NBVC Public Works Project Review Board requires contractors to comply with conditions of VCAPCD Rule 74.2. In addition, hazardous material storage areas and coating operations are routinely inspected by the Environmental Division Air Quality Program (EDAQP).</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 74.2, Condition No. 4</p>	<p>D. Frequency of monitoring: Per Operation</p>
<p>B. Description: Requirement to comply with the architectural coating VOC limits specified in Rule 74.2.B.1</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: The Public Works Project Review Board requires contractors who perform architectural coating operations at NBVC to comply with the VOC limits of VAPCD Rule 74.2.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

A. Attachment # or Permit Condition #: Attachment 74.2, Condition No. 5	D. Frequency of monitoring: Per Operation
B. Description: Requirement to monitor each architectural coating operation, specify VOC compliant architectural coatings, and to maintain VOC records for the coatings used.	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring: The Public Works Project Review Board requires contractors who perform architectural coating operations at NBVC to comply with the VOC limits of VCAPCD Rule 74.2. The VOC records of architectural coatings are kept by EDAQP.	F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

A. Attachment # or Permit Condition #: Attachment 74.4	D. Frequency of monitoring: Per Operation
B. Description: Short-term cutback asphalt activities	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring: No cutback asphalt activities took place during the compliance certification period.	F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 74.27</p>	<p>D. Frequency of monitoring: Per Operation</p>
<p>B. Description: Short-term gasoline and ROC liquid storage tank degassing operations</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Through the Public Works Project Review Board, the Environmental Division Air Quality Program (EDAQP) staff is notified of any planned large projects that may involve emissions of air contaminants. The EDAQP staff reviews the applicability of air regulations to the project and inspects the activities, as needed.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: Attachment 74.28</p>	<p>D. Frequency of monitoring: Per Operation</p>
<p>B. Description: Short-term asphalt roofing operations</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Through the Public Works Project Review Board, Environmental Division Air Quality Program (EDAQP) staff is notified of any planned large projects that may involve emissions of air contaminants. The EDAQP staff reviews the applicability of air regulations to the project and inspects the activities, as needed.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

A. Attachment # or Permit Condition #: Attachment 74.29	D. Frequency of monitoring:
B. Description: Short-term soil decontamination operations	Per Operation
C. Method of monitoring: No short-term soil decontamination activities occurred at the Naval Base Ventura County Port Hueneme site during this compliance certification period.	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: 40CFR61.M</p>	<p>D. Frequency of monitoring:</p> <p>Periodic</p>
<p>B. Description:</p> <p>Short-term asbestos demolition or renovation activities - requirements for inspection, notification, removal, and disposal procedures</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p>N/A</p>
<p>C. Method of monitoring:</p> <p>All short-term demolition and renovation activities undertaken at Naval Base Ventura County (NBVC) are performed by contractors. The Public Works Department at NBVC requires contractors to meet all inspection, notification, removal, and disposal requirements of Attachment 40CFR61.M as a condition of contract. In addition, the NBVC Asbestos Program Manager routinely monitors asbestos abatement contractor activity, and ensures that all requirements for inspection, notification, removal, and disposal are met as required.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: General Part 70 Permit</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: General Title V Requirements</p>	<p>Periodic</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Naval Base Ventura County Environmental Division personnel have conducted regular inspections of permitted sources, retained records as required, and reviewed records for compliance.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

A. Attachment # or Permit Condition #: General Permit to Operate	D. Frequency of monitoring:
B. Description: General Permit to Operate conditions	Periodic
	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring: Routine inspections by Environmental Division Air Quality Program staff ensure that permits are posted and other general permits to operate conditions are complied with.	F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: 40CFRPart 68</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Accidental Release Prevention and Risk Management Plans</p>	<p>N/A</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: No substances regulated by the California Accidental Release Prevention (ARP) Program or the federal Risk Management Plan (RMP) were contained in a process in a quantity that exceeded the respective threshold for California ARP Program or federal RMP.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>



Ventura County
Air Pollution
Control District

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: 40CFR82</p>	<p>D. Frequency of monitoring:</p> <p>Periodic</p>
<p>B. Description:</p> <p>Protection of stratospheric ozone.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p>N/A</p>
<p>C. Method of monitoring:</p> <p>Naval Base Ventura County (NBVC) Port Hueneme has an established Ozone Depleting Substances (ODS) management policy and maintains records of all ODS procured, utilized and recovered from units subject to the record keeping requirements of 40 CFR Part 82, Subpart F. NBVC also verifies all technician certifications, utilizes compliant ODS recovery equipment, follows safe disposal protocols for ODS, adheres to all ODS evacuation requirements, and follows leak detection and management protocols outlined in 40 CFR Part 82.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

Appendix A

NBVC Port Hueneme Supporting Documentation for Use of Compliant Fuel

SEE REVERSE SIDE FOR EMERGENCY RESPONSIBILITY INFORMATION
 In Case of Product Emergency, Spill, Leak, Fire, Explosion, or Accident
 Reference CHEMTREC 24-HOUR TOLL FREE NUMBER 1-800-424-2443

UN1202, GAS OIL, COMBUSTIBLE LIQUID, III
 CAL ULS S R6-20 B0-5 DF2

UN1202, GAS OIL, COMBUSTIBLE LIQUID, III
 CAL ULS S R6-20 B0-5 DF2

00430188 0-1001651-100001-010001-1001654-

Product Description	Gross Qty.	Net Qty.
TOTAL GALLONS 7813		
UN1202, GAS OIL, COMBUSTIBLE LIQUID, III NON-BULK PACKAGES ARE NOT REGULATED BY US DOT		7813 GALLONS
CAL ULS S R6-20 B0-5 DF2	7813	7791

GROSS LOADED AT 66.00 DEGREES F, NET COMPUTED AT 60 DEGREES F, 36.77 API GRAVITY
 CALIFORNIA DIESEL FUEL. MAXIMUM 15 PPM SULFUR. 15 PPM SULFUR (MAXIMUM) UNDEYED 42D ULTRA-LOW SULFUR DIESEL FUEL IS FOR USE
 IN ALL DIESEL VEHICLES AND DIESEL ENGINES. DIESEL FUEL DELIVERED DOES NOT CONTAIN VISIBLE EVIDENCE OF DYE. DIESEL FUEL MAY
 CONTAIN UP TO 5% BIODIESEL. DIESEL FUEL DELIVERED NOT INTENDED FOR MARINE USE. THIS VOLUME OF NEAT OR BLENDED RENEWABLE
 DIESEL IS DESIGNATED AND INTENDED FOR USE AS TRANSPORTATION FUEL, HEATING OIL OR JET FUEL IN THE 48 U.S. CONTIGUOUS STATES
 AND HAWAII. ANY PERSON EXPORTING THIS FUEL IS SUBJECT TO THE REQUIREMENTS OF 40 CFR 80.1430. THIS DIESEL FUEL CONTAINS
 6-20% RENEWABLE (BIOMASS-BASED) DIESEL. NO RIN IS ASSIGNED TO THIS RENEWABLE FUEL.

*Straight Bill of Lading - Short Form - Original - Not Negotiable - Carrier Must Submit Original Bill of Lading with Freight Bill. (*Applies only when designated as "Bill of Lading" above).
 Carrier Received, subject to the classifications and tariffs in effect on the date of the issue of this Bill of Lading, and all conditions herein contained, including conditions on back hereof
 This is to certify that the above-named materials are properly classified, described, packaged, marked and labeled, and are in proper condition for transportation according to the
 applicable regulations of the Department of Transportation. Consignor: CHEVRON PRODUCTS COMPANY
 Carrier has loaded and accepted the above-named materials and certifies the cargo tank is a proper container for the transportation of this commodity under applicable Department of Transportation regulations.
 (Signature of Carrier) 686 TRANSPORT Delivered By: (Full Signature) Jose Godinez
 Received By: (Signature) _____ Date: 02-06-20

TERMINAL COPY

SEE REVERSE SIDE FOR EMERGENCY RESPONSE INFORMATION
In Case of Product Emergency, Spill, Leak, Fire, Exposure or Accident:

Refer to CHEMTREC Journal CON222336

7 24 2020
10 11 2020
10 11 2020
10 11 2020

10 11 2020
10 11 2020
10 11 2020

10 11 2020

1043198 0-1011284-00,009-021200-1001694-

Product Description	Gross Qty.	Net Qty.
---------------------	------------	----------

TOTAL GALLONS 6011

NO OF CARRY TANKS: 1

UNLEADED, GAS OIL, COMBUSTIBLE LIQUID, IIP NON-BULK PACKAGES ARE NOT REGULATED BY US DOT	6011	5982
--	------	------

CAL ULS S 16-20 80-8 DF2
GROSS LOADED AT 70.05 DEGREES F, NET COMPUTED AT 60 DEGREES F, 36.57 API GRAVITY
CALIFORNIA DIESEL FUEL. MAXIMUM 15 PPM SULFUR. 15 PPM SULFUR (MAXIMUM) UNDYED #2D ULTRA-LOW SULFUR DIESEL FUEL IS FOR USE IN ALL DIESEL VEHICLES AND DIESEL ENGINES. DIESEL FUEL DELIVERED DOES NOT CONTAIN VISIBLE EVIDENCE OF DYE. DIESEL FUEL MAY CONTAIN UP TO 5% BIODIESEL. DIESEL FUEL DELIVERED NOT INTENDED FOR MARINE USE. THIS VOLUME OF NEAT OR BLENDED RENEWABLE DIESEL IS DESIGNATED AND INTENDED FOR USE AS TRANSPORTATION FUEL, HEATING OIL OR JET FUEL IN THE 48 U.S. CONTIGUOUS STATES AND HAWAII. ANY PERSON EXPORTING THIS FUEL IS SUBJECT TO THE REQUIREMENTS OF 40 CFR 80.1430. THIS DIESEL FUEL CONTAINS 6-20% RENEWABLE (BIOMASS-BASED) DIESEL. NO RIN IS ASSIGNED TO THIS RENEWABLE FUEL.

*Straight Bill of Lading - Short Form - Original - Not Negotiable - Carrier Must Submit Original Bill of Lading with Freight Bill ("Applies only when designated as "Bill of Lading" above).

Carrier Received, subject to the classifications and tariffs in effect on the date of the issue of this Bill of Lading, and all conditions herein contained, including conditions on back hereof. This is to certify that the above-named materials are properly classified, described, packaged, marked and labeled, and are in proper condition for transportation according to the applicable regulations of the Department of Transportation. Consignor: CHEVRON PRODUCTS COMPANY

Carrier has loaded and accepted the above-named materials and certifies the cargo tank is a proper container for the transportation of this commodity under applicable Department of Transportation regulations.

(Signature of Carrier) GLG TRANSPORT Delivered By: (Full Signature) Jose Godines

Received By: (Signature) _____

Date: 10-26-2020

TERMINAL COPY

Fuel facts-1029(4-15)



CAUTION: SEE REVERSE SIDE FOR HAZARD WARNINGS

BILLING ADDRESS:
Falcon Fuels Contract
7300 Alondra Blvd Suite 204
PO Box 347
Paramount, CA 90723

SHIPPING ADDRESS:
Falcon Fuels Contract
7300 Alondra Blvd Suite 204
PO Box 347
Paramount, CA 90723

Table with columns: DATE DELIVERED, TIME IN, TIME OUT, Trailer License Plate, PRODUCT DESCRIPTION, ADD*, TEMP, GRAV, GROSS GAL, NET GAL. Includes data for 09/10/20, 04:41, 05:07, CA 4SP6824, CARB DIESEL FOR USE IN THE LA BASIN, 83.3, 38.9, 7.705, 7.619.

DOT HAZARDOUS MATERIAL DESCRIPTION: na 1993 DIESEL FUEL, 3, PG III. 7.705 Gross

2 Cargo Tanks PO #:

MESSAGES: Petro-Diamond Incorporated EPA registration # 4088. ChemTel Contract # MIS0004859

Gasoline and diesel fuel meet all CARB & EPA requirements

Emergency contact: 1-800-255-3924. Carrier certifies that the cargo tank supplied for this shipment is a proper container... David Josue Villeda (DRIVER NAME) and signature (DRIVER SIGNATURE)

THIS DOCUMENT IS THE PROPERTY OF THE UNITED STATES GOVERNMENT AND IS LOANED TO YOU BY THE UNITED STATES GOVERNMENT. IT IS TO BE REPRODUCED AND TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT PERMISSION IN WRITING FROM THE UNITED STATES GOVERNMENT. THIS DOCUMENT IS NOT TO BE DISTRIBUTED OUTSIDE YOUR AGENCY OR ORGANIZATION.

THESE TERMS AND CONDITIONS APPLY TO ALL TRANSPORTATION SERVICES PROVIDED BY THE UNITED STATES GOVERNMENT. THE UNITED STATES GOVERNMENT SHALL NOT BE LIABLE FOR ANY LOSS OF OR DAMAGE TO PROPERTY OR FOR ANY INJURY TO PERSONS OR PROPERTY, INCLUDING CONSEQUENTIAL DAMAGES, ARISING OUT OF OR FROM THE USE OF ANY SERVICE PROVIDED BY THE UNITED STATES GOVERNMENT, WHETHER SUCH LOSS, DAMAGE, INJURY, OR PROPERTY IS CAUSED IN WHOLE OR IN PART BY THE NEGLIGENCE OF THE UNITED STATES GOVERNMENT OR BY THE NEGLIGENCE OF ANY OTHER PARTY.

THE UNITED STATES GOVERNMENT SHALL NOT BE LIABLE FOR ANY LOSS OF OR DAMAGE TO PROPERTY OR FOR ANY INJURY TO PERSONS OR PROPERTY, INCLUDING CONSEQUENTIAL DAMAGES, ARISING OUT OF OR FROM THE USE OF ANY SERVICE PROVIDED BY THE UNITED STATES GOVERNMENT, WHETHER SUCH LOSS, DAMAGE, INJURY, OR PROPERTY IS CAUSED IN WHOLE OR IN PART BY THE NEGLIGENCE OF THE UNITED STATES GOVERNMENT OR BY THE NEGLIGENCE OF ANY OTHER PARTY.

THE UNITED STATES GOVERNMENT SHALL NOT BE LIABLE FOR ANY LOSS OF OR DAMAGE TO PROPERTY OR FOR ANY INJURY TO PERSONS OR PROPERTY, INCLUDING CONSEQUENTIAL DAMAGES, ARISING OUT OF OR FROM THE USE OF ANY SERVICE PROVIDED BY THE UNITED STATES GOVERNMENT, WHETHER SUCH LOSS, DAMAGE, INJURY, OR PROPERTY IS CAUSED IN WHOLE OR IN PART BY THE NEGLIGENCE OF THE UNITED STATES GOVERNMENT OR BY THE NEGLIGENCE OF ANY OTHER PARTY.

THE UNITED STATES GOVERNMENT SHALL NOT BE LIABLE FOR ANY LOSS OF OR DAMAGE TO PROPERTY OR FOR ANY INJURY TO PERSONS OR PROPERTY, INCLUDING CONSEQUENTIAL DAMAGES, ARISING OUT OF OR FROM THE USE OF ANY SERVICE PROVIDED BY THE UNITED STATES GOVERNMENT, WHETHER SUCH LOSS, DAMAGE, INJURY, OR PROPERTY IS CAUSED IN WHOLE OR IN PART BY THE NEGLIGENCE OF THE UNITED STATES GOVERNMENT OR BY THE NEGLIGENCE OF ANY OTHER PARTY.

THIS PRODUCT CONTAINS 0.01% OF SULFUR BY WEIGHT AS DETERMINED BY THE TESTS. SULFUR CONTENTS DO NOT EXCEED 0.01% BY WEIGHT AS DETERMINED BY THE TESTS.

BOL NUMBER	IN DATE	OUT DATE	PO NUMBER
6085670901	12/17/2020 04:25	12/17/2020 04:53	

SHIPPER	SHIP TO	BILL TO
0901 Alt Air Paramount, LLC 3835 Somerset Blvd Paramount, CA 90723	10050001A Falcon Fuels, Inc 7300 Alondra Blvd, Suite 204 Paramount, CA 90723	1005A Falcon Fuels, Inc 7300 Alondra Blvd, Suite 204 Paramount, CA 90723

CARRIER	TRUCK	TRUCK LICENSE
277 - Alliance Petroleum Transport Inc	00007	9D64916

DRIVER	TRAILER	TRAILER LICENSE
277004 - Jose Mejia	00071	4AS1154

COMMENTS

CODE	PRODUCT DESCRIPTION	TEMP	GRAVITY	GROSS GAL	NET GAL	NET BBLs
	UN 1202, Diesel Fuel, 3 PG III T&T ERG 123 A1977 RD95 W/ UP TO 4.99% BIO DIESEL	66.0	49.5	7614	7587	130.64

PRODUCT FOR USE IN LA BASIN
CALIFORNIA DIESEL FUEL, MAXIMUM 15PPM SULFUR DIESEL FUEL #1
PRODUCT MEETS ALL D975 AND CARB DIESEL SPECIFICATIONS

SCALE WEIGHT INFORMATION GROSS: 77060 TARE: 27540 NET: 49520

Carrier's receipt of the commodities under this Bill of Lading shall signify acceptance of each of the provisions contained in the Refinery Access Agreement as executed by an authorized employee or owner of Carrier.

Hazardous Hazard Offered	Loaded By	Driver Receiving	Received at Destination by

Shipper's Name **ALT AIR FUELS** Agent **ALT AIR FUELS**

FOR CHEMICAL EMERGENCY - Spill, Leak, Fire, Exposure or Accident **CALL CHEMTREC - DAY OR NIGHT - 800-424-9300**

Appendix B

NBVC Port Hueneme Tune up/Emission Screening Summary Forms

Naval Base Ventura County Boiler Emission Screening Report					
Boiler					
Location: Port Hueneme		Bldg: 1479-1		Permit: 1006	
Make: Lochinvar		Model: CFN1442PM		Rating: 1.44 MMBTU/Hr	
Analyzer					
Make: Testo		Model: 330-1LX		Cal. Date: 8/19/2019	
Screening					
Date: 3/25/2020		Time: 0945		Weather: Sunny	
Raw data			@ 3% O2		Notes: PASS
O2 %	CO ppm	Nox ppm	CO ppm	Nox ppm	
10	64	4	105	7	
	Limit		400	20	



Naval Base Ventura County Boiler Emission Screening Report				
Boiler				
Location: Port Hueneme		Bldg: 1479-2		Permit: 1006
Make: Lochinvar		Model: CFN1442PM		Rating: 1.44 MMBTU/Hr
Analyzer				
Make: Testo		Model: 330-1LX		Cal. Date: 8/19/2019
Screening				
Date: 3/25/2020		Time: 0932		Weather: Sunny
Raw data			@ 3% O2	
O2 %	CO ppm	Nox ppm	CO ppm	Nox ppm
9.5	32	9	50	14
Limit			400	20
Notes: PASS				



Appendix C

NBVC Port Hueneme Formal Surveys & Engines Hours of Operations

**NBVC Port Hueneme
Stationary Standby Engines
Emergency and Maintenance 12-Month
Rolling Sum Hours of Operation**

**NBVC Port Hueneume Stationary Standby Engines
2020 Emergency Hours of Operation 12-Month Rolling Sum Report**

Permit Description	Model #	Serial #	BLDG	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
285 BHP Cummins	6CTAA8.3-G3	46350107	1000	20.3	20.3	20.3	20.3	20.3	20.3	2.0	0.0	0.0	0.0	0.0	0.0
324 BHP Cummins	QSB7-G5-NR3	73759244	1402	4.0	4.0	2.5	1.0	1.0	1.0	1.0	1.0	1.0	0.0	0.0	0.0
464 BHP Cummins	QSL/QSL9-G7 NTR3	1190634556	1412	0.0	0.0	10.9	10.9	10.9	10.9	26.9	26.9	26.9	29.9	29.9	29.9
90 BHP Cummins	4BT3.9-G4	4626695	1440	26.8	27.0	27.0	27.0	27.0	27.0	26.4	26.4	26.4	26.4	26.4	14.9
145 BHP Cummins	QSB5-G3 NR3	73391959	1443	26.0	26.0	26.0	26.0	26.0	26.0	26.6	26.6	26.6	28.4	28.4	17.3
63 BHP Perkins	LD70295	U733229B	1512B	11.8	12.6	12.9	13.5	13.5	13.5	13.5	13.5	13.5	15.2	15.2	3.4
161 BHP Perkins	C4.4	E5G00789	1524	25.6	25.6	25.6	25.6	25.6	25.6	24.9	24.9	24.9	24.9	24.9	15.0
585 BHP Detroit	6V92TA	WA504448	1526	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1490 BHP Cummins	QST30-G5	37235098	2	26.0	26.0	26.0	26.0	26.0	26.0	27.0	27.0	27.0	29.0	29.0	18.0
252 BHP Cummins	6CTAA8.3-G2	46261737	22	26.4	26.4	26.4	26.4	26.4	26.4	26.9	26.9	26.9	28.8	28.8	17.4
56 BHP Cummins	B3.3-G1	6800962	372	26.1	26.1	26.1	26.1	26.1	26.1	26.7	26.7	26.7	28.4	28.4	17.2
435 BHP Cummins	NT855G6	30346676	382	26.2	26.2	26.2	26.2	26.2	26.2	11.2	53.1	53.1	53.1	53.1	41.9
585 BHP Detroit	6V92TA	80637405	437	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
755 BHP Cummins	QSX15-G9	79914017	5035	15.5	15.5	15.5	15.5	13.4	13.4	0.0	0.0	0.0	0.2	0.2	0.2
90 BHP Cummins	4BT3.9-G4	42266702	810	26.5	26.5	26.5	26.5	26.5	26.5	26.9	26.9	26.9	30.1	30.1	18.8
170 BHP Cummins	6BTA5.9-G4	46555763	225	26.3	26.3	26.3	26.3	26.3	26.3	26.6	26.8	26.8	28.7	28.7	17.4
545 BHP Caterpillar	3412-D1	389S5953	527	26.2	26.2	26.2	26.2	26.2	26.2	26.9	26.9	26.9	26.9	34.2	23.0
173 BHP Cummins	QSB5-G13	B200737795	1387	0.0	0.0	0.0	0.0	0.0	0.0	14.6	14.6	14.6	14.6	14.6	14.6
985 BHP Detroit	R 1238A36 2000 G44	5352006058	1388	0.0	0.0	0.0	0.0	3.1	3.1	3.1	3.1	3.1	6.6	6.6	6.6
599 BHP Caterpillar	3406	1LS01484	1388	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
217 BHP Caterpillar	C-6.6	E6M01866	1300	26.4	26.4	26.4	26.4	26.4	26.4	27.1	27.1	27.1	28.9	28.9	17.4

**NBVC Port Hueneme Stationary Standby Engines
2020 Maintenance Hours of Operation 12-Month Rolling Sum Report**

Permit Description	Model #	Serial #	BLDG	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
285 BHP Cummins	6CTAA8.3-G3	46350107	1000	1.9	1.8	1.6	1.6	1.6	1.3	0.9	0.0	0.0	0.0	0.0	0.0
324 BHP Cummins	QSB7-G5-NR3	73759244	1402	1.5	1.3	1.1	0.9	0.9	1.1	1.1	3.2	3.1	3.1	2.9	2.9
464 BHP Cummins	QSL/QSL9-G7 NTR3	1190634556	1412	0.0	0.0	0.0	0.0	0.0	3.8	5.1	5.5	6.8	7.8	8.8	9.7
90 BHP Cummins	4BT3.9-G4	4626695	1440	4.6	4.3	4.3	3.9	3.6	3.6	3.2	2.4	1.8	1.6	1.7	1.5
145 BHP Cummins	QSB5-G3 NR3	73391959	1443	2.3	2.3	2.1	2.1	1.9	1.9	1.3	0.6	0.4	0.4	0.4	0.2
63 BHP Perkins	LD70295	U733229B	1512B	5.9	5.4	4.9	4.5	3.8	3.5	7.0	7.0	6.2	5.9	6.0	6.5
161 BHP Perkins	C4.4	E5G00789	1524	3.0	3.0	3.0	3.0	3.0	3.0	2.4	2.2	1.0	1.0	1.0	1.0
585 BHP Detroit	6V92TA	WA504448	1526	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1490 BHP Cummins	QST30-G5	37235098	2	3.0	3.0	3.0	3.0	3.0	2.0	1.0	1.0	1.0	1.0	0.0	2.0
252 BHP Cummins	6CTAA8.3-G2	46261737	22	2.7	2.5	2.7	2.7	2.5	2.3	1.9	1.2	1.0	1.0	0.8	0.8
56 BHP Cummins	B3.3-G1	6800962	372	3.2	3.2	3.4	3.4	3.4	3.4	2.8	2.1	2.1	1.8	1.8	1.6
435 BHP Cummins	NT855G6	30346676	382	2.5	2.3	2.5	2.3	2.1	2.1	1.9	1.3	1.0	1.0	0.8	0.8
585 BHP Detroit	6V92TA	80637405	437	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
755 BHP Cummins	QSX15-G9	79914017	5035	3.7	3.2	3.2	2.8	2.6	2.6	2.2	1.4	1.2	4.5	7.8	7.8
90 BHP Cummins	4BT3.9-G4	42266702	810	2.4	2.4	2.4	2.2	2.4	2.4	2.0	1.4	1.2	1.2	1.0	1.0
170 BHP Cummins	6BTA5.9-G4	46555763	225	2.9	2.9	2.7	2.5	2.3	2.3	2.0	1.1	0.9	0.9	0.9	0.9
545 BHP Caterpillar	3412-D1	389S5953	527	4.3	4.3	4.5	4.5	4.3	4.3	1.0	1.2	1.0	1.3	1.3	1.3
173 BHP Cummins	QSB5-G13	B200737795	1387	0.0	0.0	0.0	0.0	2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.4
985 BHP Detroit	R 1238A36 2000 G44	5352006058	1388	7.2	7.2	7.4	7.4	0.9	0.8	0.8	0.6	0.4	0.4	0.2	0.2
599 BHP Caterpillar	3406	1LS01484	1388	9.0	9.0	9.0	9.0	6.0	5.0	6.0	6.0	5.0	8.0	9.0	9.0
217 BHP Caterpillar	C-6.6	E6M01866	1300	1.5	1.5	1.8	2.0	2.2	2.2	1.8	1.1	1.1	1.1	1.4	1.4

**NBVC Port Hueneme
Stationary Standby Engines
Annual Report Form**

**EMERGENCY DIESEL ENGINE ANNUAL REPORT FORM
 REPORTING PERIOD: JANUARY 1 TO DECEMBER 31, 2020
 PERMIT NO: 01006 - NAVAL BASE VENTURA COUNTY**

Engine BHP/Make	Engine Model Number	Engine Serial Number	Location	Hour Meter Reading on 1/1/2020	Hour Meter Reading on 1/4/2021	Total M&T Hours in 2020	Total Emergency Hours in 2020	Total Hours in 2020
285 BHP Cummins	6CTAA8.3-G3	46350107	1000	259.5	259.5	0.0	0.0	0.0
324 BHP Cummins	QSB7-G5-NR3	73759244	1402	44.8	47.7	2.9	0.0	2.9
464 BHP Cummins	QSL/QSL9-G7 NTR3	1190634556	1412	0.0	39.6	9.7	29.9	39.6
90 BHP Cummins	4BT3.9-G4	4626695	1440	379.8	396.2	1.5	14.9	16.4
145 BHP Cummins	QSB5-G3 NR3	73391959	1443	199.0	216.5	0.2	17.3	17.5
63 BHP Perkins	LD70295	U733229B	1512B	302.5	312.4	6.5	3.4	9.9
161 BHP Perkins	C4.4	E5G00789	1524	34.4	50.4	1.0	15.0	16.0
585 BHP Detroit	6V92TA	WA504448	1526	227.2	227.2	0.0	0.0	0.0
1490 BHP Cummins	QST30-G5	37235098	2	339.0	359.0	2.0	18.0	20.0
252 BHP Cummins	6CTAA8.3-G2	46261737	22	328.6	346.8	0.8	17.4	18.2
56 BHP Cummins	B3.3-G1	6800962	372	318.5	337.3	1.6	17.2	18.8
435 BHP Cummins	NT855G6	30346676	382	164.9	207.6	0.8	41.9	42.7
585 BHP Detroit	6V92TA	80637405	437	324.9	324.9	0.0	0.0	0.0
755 BHP Cummins	QSX15-G9	79914017	5035	229.6	237.6	7.8	0.2	8.0
90 BHP Cummins	4BT3.9-G4	42266702	810	388.9	408.7	1.0	18.8	19.8
170 BHP Cummins	6BTA5.9-G4	46555763	225	231.5	249.8	0.9	17.4	18.3
545 BHP Caterpillar	3412-D1	389S5953	527	214.2	238.5	1.3	23.0	24.3
173 BHP Cummins	QSB5-G13	B20073795	1387	0.0	17.0	2.4	14.6	17.0
985 BHP Detroit	R 1238A36 2000 G44	5352006058	1388	106.8	113.6	0.2	6.6	6.8
599 BHP Caterpillar	3406	1LS01484	1388	290.0	299.0	9.0	0.0	9.0
217 BHP Caterpillar	C-6.6	E6M01866	1300	176.0	194.8	1.4	17.4	18.8

**NBVC Port Hueneme
Portable Engines Operation**

**NBVC Port Hueneme
Opacity Survey**

2020 NBVC Port Hueneme Opacity Survey Result

Equipment Category	Description of Equipment in Permit Table (abbreviated)	Date of Equipment Inspection	Opacity Noted (Y/N)	Operating During Inspection (Y/N)	Comments
Boiler	8.4 MMBTU Superior, Wharf 3	N/A	N/A	N/A	Out of Service during the Compliance period
Boiler	8.4 MMBTU Superior, Wharf 4	N/A	N/A	N/A	Out of Service during the Compliance period
Boiler	2.1 MMBTU Hurst, Building 1419	8/3/2020	N	N	
Boiler	1.825 MMBTU Raypack, Building 2	8/3/2020	N	N	
Boiler	4.8 MMBTU GL--1800 Aircraft Deicer Boiler, Building 1420	8/3/2020	N	N	
Boiler	4.8 MMBTU GL--1800 Aircraft Deicer Boiler, Building 1420	8/3/2020	N	N	
Boiler	1.6 M NCEL burner, Building-1100	8/3/2020	N	N	
Boiler	1.44 MMBTU Lochinvar, Building 1479	8/3/2020	N	N	
Boiler	1.44 MMBTU Lochinvar, Building 1479	8/3/2020	N	Y	
Crane	173 BHP Daimler/Chrysler	8/3/2020	N	N	
Sweeper	80 BHP Perkins	N/A	N/A	N/A	Out of Service during the Compliance period
Sweeper	80.5 BHP Mitsubishi Heavy Industries	N/A	N/A	N/A	Removed from service
Sweeper	69.7 BHP Yanmar Sweeper Aux	8/3/2020	N	N	
Portable Generator	165 BHP John Deere Diesel Generator, 51-26066	7/12/2020	N	N	PM behind Building 60
Portable Generator	165 BHP John Deere Diesel Generator, 51-26067	7/12/2020	N	N	PM behind Building 60
Portable Generator	165 BHP John Deere Diesel Generator, 51-26068	7/12/2020	N	Y	In use at Building PM 354

2020 NBVC Port Hueneme Opacity Survey Result

Equipment Category	Description of Equipment in Permit Table (abbreviated)	Date of Equipment Inspection	Opacity Noted (Y/N)	Operating During Inspection (Y/N)	Comments
Portable Generator	165 BHP John Deere Diesel Generator, 51-26069	7/12/2020	N	N	PM behind Building 60
Portable Generator	315 BHP John Deere Diesel Generator, 51-28008	7/12/2020	N	Y	In use at Building PM 21
Wood Chipper	70.9 BHP Yanmar Diesel Engine	N/A	N/A	N/A	Did not operate during the compliance period
Spray Booth	DeVilbiss Model 20389, Dry, Building 815	N/A	N/A	N/A	Did not operate during the compliance period
Spray Booth	Spray King Model 300-FAF, Dry, Building 1193	N/A	N/A	N/A	Out of Service during the Compliance period
Spray Booth	Spray King Model 300-FAF, Dry, Building 1193	N/A	N/A	N/A	Out of Service during the Compliance period
Spray Booth	Spray King Model 300-FAF, Dry, Building 1193	N/A	N/A	N/A	Out of Service during the Compliance period
Spray Booth	Spray King Model 300-FAF, Dry, Building 1193	N/A	N/A	N/A	Out of Service during the Compliance period
Spray Booth	Large paint room with filters, 28x19x84, Building 1497	12/10/2020	N	N	
Spray Booth	Small paint room with filters, 28x19x64, Building 1497	12/10/2020	N	N	
Abrasive Blasting	Pauli & Griffin cabinet, Building 325	12/10/2020	N	N	
Abrasive Blasting	Small paint room converte, Building 1497	N/A	N/A	N/A	Out of Service during the compliance period
Abrasive Blasting	Large blast room, Building 1497	N/A	N/A	N/A	Out of Service during the compliance period
Abrasive Blasting	Clemco blast cabinet, Building 1497	12/10/2020	N	N	
Abrasive Blasting	Clemco blast cabinet, Building 813	12/10/2020	N	N	
Abrasive Blasting	Clemco blast cabinet, Building 813	12/10/2020	N	N	

2020 NBVC Port Hueneme Opacity Survey Result

Equipment Category	Description of Equipment in Permit Table (abbreviated)	Date of Equipment Inspection	Opacity Noted (Y/N)	Operating During Inspection (Y/N)	Comments
Abrasive Blasting	Clemco blast cabinet, Building 813	12/10/2020	N	N	
Emerg. Stationary Engine	285 BHP Cummins diesel generator, Building 1000	12/2/2020	N	N	
Emerg. Stationary Engine	324 BHP Cummins diesel generator, Building 1402	12/2/2020	N	N	
Emerg. Stationary Engine	464 BHP Cummins diesel generator, Building 1412	12/2/2020	N	N	
Emerg. Stationary Engine	90 BHP Cummins diesel generator, Building 1440	12/15/2020	N	N	
Emerg. Stationary Engine	145 BHP Cummins diesel generator, Building 1443	12/2/2020	N	N	
Emerg. Stationary Engine	63 BHP Perkins diesel generator, Building 1512-B	12/2/2020	N	N	
Emerg. Stationary Engine	161 BHP Caterpillar diesel generator, Building 1524	12/2/2020	N	N	
Emerg. Stationary Engine	585 BHP Detroit diesel generator, Building 1526	12/4/2020	N	N	
Emerg. Stationary Engine	1490 BHP cummins diesel generator, Building 2	12/2/2020	N	N	
Emerg. Stationary Engine	252 BHP Cummins diesel generator, Building 22	12/15/2020	N	N	
Emerg. Stationary Engine	56 BHP Cummins diesel generator, Building 372	12/2/2020	N	N	
Emerg. Stationary Engine	435 BHP Cummins diesel generator, Building 382	12/4/2020	N	N	
Emerg. Stationary Engine	585 BHP Detroit diesel generator, Building 437	12/4/2020	N	N	
Emerg. Stationary Engine	755 BHP Cummins diesel generator, Building 5035	12/15/2020	N	N	
Emerg. Stationary Engine	90 BHP Cummins diesel generator, Building 810	12/2/2020	N	N	
Emerg. Stationary Engine	170 BHP Cummins diesel generator, Building 225	12/2/2020	N	N	

2020 NBVC Port Hueneme Opacity Survey Result

Equipment Category	Description of Equipment in Permit Table (abbreviated)	Date of Equipment Inspection	Opacity Noted (Y/N)	Operating During Inspection (Y/N)	Comments
Emerg. Stationary Engine	545 BHP Caterpillar diesel generator, Building 527	12/2/2020	N	N	
Emerg. Stationary Engine	173 BHP Cummins diesel generator, Building 1387	12/15/2020	N	N	
Emerg. Stationary Engine	985 BHP Detroit diesel generator, Building 1388	12/2/2020	N	N	
Emerg. Stationary Engine	599 BHP Caterpillar diesel generator, Building 1388	12/2/2020	N	N	
Emerg. Stationary Engine	217 BHP Caterpillar diesel generator, Building 1300	12/2/2020	N	N	

**NBVC Port Hueneme
Rules 74.11 and 74.11.1 Small Boilers and
Water Heaters Survey**

2020 NBVC Port Hueneme Rules 74.11 and 74.11.1 Survey Result

Location	Building Number	Heat Input (BTU/HR)	Make	Model	Serial Number	Year Installed	In Compliance with the Rule 74.11 and 74.11.1?
PH	1388	990,000	RayPak	H8-992C	2003504147	2020	Yes
PH	1388	990,000	RayPak	H8-992C	2003504148	2020	Yes
PH	1389	990,000	RayPak	H8-992C	2003504058	2020	Yes
PH	444	624,000	RayPak	H7-0650B	1909470027	2020	Yes
PH	447	300,000	RayPak	H7-0300B	1910471843	2020	Yes
PH	452	500,000	RayPak	H7-0500B	1910469207	2020	Yes

Appendix D

NBVC Port Hueneme RICE NESHAP Maintenance Records

NAVFAC PORT HUENEME RICE NESHAP MAINTENANCE RECORD

Bldg	Device	Engine Oil Analysis		Engine and Filter Oil Change		Air Cleaner Inspection		Hoses and Belts Inspection	
		Date of Engine Oil Sample Collection	Hour Meter Reading at Time of Engine Oil Sample Collection	Date of Engine Oil and Oil Filter Change	Hour Meter Reading at Time of Engine Oil and Oil Filter Change	Date of Inspection	Hour Meter Reading at Time of Inspection	Date of Inspection	Hour Meter Reading at Time of Inspection
2	1490 BHP Cummins		Post 2006 Construction, Maintenance not Required						
22	252 BHP Cummins	N/A	N/A	12/16/2020	346.8	11/3/2020	346.8	11/3/2020	346.8
225	170 BHP Cummins	N/A	N/A	12/16/2020	249.8	11/10/2020	249.6	11/10/2020	249.6
372	56 BHP Cummins	N/A	N/A	12/20/2020	337.3	11/4/2020	337.3	11/4/2020	337.3
382	435 BHP Cummins	N/A	N/A	12/16/2020	207.6	10/27/2020	207.6	10/27/2020	207.6
430	42 BHP Generac	N/A	N/A	11/4/2020	99600.1	8/27/2020	99600.1	8/27/2020	99600.1
437	585 BHP Detroit	N/A	N/A	NON OP	NON OP	3/22/2020	324.9	3/22/2020	324.9
527	545 BHP Caterpillar	N/A	N/A	12/16/2020	238.5	11/2/2020	231	11/2/2020	231
810	90 BHP Cummins	N/A	N/A	12/16/2020	408.7	8/27/2020	405.5	8/27/2020	405.5
1000	285 BHP Cummins	N/A	N/A	11/9/2020	258.8	11/2/2020	258.6	11/2/2020	258.6
1300	217 BHP Caterpillar		Post 2006 Construction, Maintenance not Required						
1388-1	599 BHP Caterpillar	N/A	N/A	12/12/2020	299	12/12/2020	299	12/12/2020	299
1388-2	985 BHP Detroit		Post 2006 Construction, Maintenance not Required						
1402	324 BHP Cummins		Post 2006 Construction, Maintenance not Required						
1440	90 BHP Cummins	N/A	N/A	11/3/2020	395.9	11/4/2020	396.1	11/4/2020	396.1
1443	145 BHP Cummins- NEW		Post 2006 Construction, Maintenance not Required						
1524	161 BHP Perkins		Post 2006 Construction, Maintenance not Required						
1526	585 BHP Detroit	N/A	N/A	NON OP	NON OP	8/18/2020	227.2	8/18/2020	227.2
5035	755 BHP Cummins		Post 2006 Construction, Maintenance not Required						

Appendix E

NBVC Port Hueneme Gas Station Dispensing Facilities Verification Testing Results

**NBVC Port Hueneme
E85 Dispensing Facility
Verification Testing Results**



2 Inch Pressure Decay TP201.3

Ref. No.: _____
 AQMD Id: _____
 Site Name: NBVC Port Hueneme
 Address: 1000 23rd Ave.
Port Hueneme CA 93041
 Phone: (805) 645-1400

Testing Company

Name: Western Pump, Inc.
 Address: 3235 F Street
San Diego CA 92102
 Phone: (619) 239-9988

Phase I System? Dual point AST
 Phase II System? Balance

Tanks Manifolder? No
 Vapor Pot Present? No

Total # of Nozzles 1
 Products per Nozzle 1

Total # of Tanks 1

Tank Information	<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>All</u>
1. Product Grade	E-85				
2. Actual Tank Capacity, gallons	10247				10247
3. Gasoline Volume, gallons	3409				3409
4. Ullage, (V) gallons (line #2 minus line#3)	6838				6838
Test Information	<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>5</u>
5. Start time	9:15				
6. Initial Test Pressure, inches H ₂ O	2.00				
7. Pressure after 1 minute, inches H ₂ O	2.15				
8. Pressure after 2 minutes, inches H ₂ O	2.26				
9. Pressure after 3 minutes, inches H ₂ O	2.32				
10. Pressure after 4 minutes, inches H ₂ O	2.36				
11. Pressure after 5 minutes, inches H ₂ O	2.42				
12. Allowable Final Pressure	1.94				
13. Pass / Fail (Enter "GF" for Gross failure)	Pass				

2020-10-08
09:00
Digital
2020-07-22
0.00"WC
2
2.246
4.492
0.00"WC
2.09 V/C
Coupler

Requested Test Date.
 Requested Test Time.
 What type of pressure device used?
 Calibration date for pressure device (90 days).
 Enter initial tank ullage pressure (Vent if over 0.5 in. w.c., then start the 30 min no dispensing period)
 Enter flowmeter rate, F(Must be 1 to 5 CFM).
 Calculate ullage fill time, t₂. t₂= $\frac{V}{[1522]F}$
 Calculate gross failure time (Twice t₂).
 Enter ending value of drift test (Must be 0.01 in. w.c. or less).
 Record Vapor Coupler Integrity Test Assembly pressure after 1 minute and location.
 Nitrogen introduction point. Phase I vapor coupler or Phase II vapor riser?

Tester: Raul Gonzalez

Tester Id: 175860

Signature:

Test Date: 2020-10-08



Leak Rate and Cracking Pressure of P/V Vent Valves

Ref. No.: _____
 AQMD Id: _____
 Site Name: NBVC Port Hueneme
 Address: 1000 23rd Ave.
Port Hueneme CA 93041
 Phone: (805) 645-1400

Testing Company

Name: Western Pump, Inc.
 Address: 3235 F Street
San Diego CA 92102
 Phone: (619) 239-9988

P/V Valve Manufacturer:	Husky	Model Number:	5885	Pass/Fail:	Pass
Manufacturer Specified Positive Leak Rate (CFH):	0.05	Manufacturer Specified Negative Leak Rate (CFH):		0.21	
Measured Positive Leak Rate(CFH)	0.03	Measured Negative Leak Rate (CFH)		0.04	
Positive Cracking Pressure (in. H2O)	3.40	Negative Cracking Pressure (in. H2O)		-8.35	

P/V Valve Manufacturer:		Model Number:		Pass/Fail:	
Manufacturer Specified Positive Leak Rate (CFH):		Manufacturer Specified Negative Leak Rate (CFH):			
Measured Positive Leak Rate(CFH)		Measured Negative Leak Rate (CFH)			
Positive Cracking Pressure (in. H2O)		Negative Cracking Pressure (in. H2O)			

P/V Valve Manufacturer:		Model Number:		Pass/Fail:	
Manufacturer Specified Positive Leak Rate (CFH):		Manufacturer Specified Negative Leak Rate (CFH):			
Measured Positive Leak Rate(CFH)		Measured Negative Leak Rate (CFH)			
Positive Cracking Pressure (in. H2O)		Negative Cracking Pressure (in. H2O)			

P/V Valve Manufacturer:		Model Number:		Pass/Fail:	
Manufacturer Specified Positive Leak Rate (CFH):		Manufacturer Specified Negative Leak Rate (CFH):			
Measured Positive Leak Rate(CFH)		Measured Negative Leak Rate (CFH)			
Positive Cracking Pressure (in. H2O)		Negative Cracking Pressure (in. H2O)			

P/V Valve Manufacturer:		Model Number:		Pass/Fail:	
Manufacturer Specified Positive Leak Rate (CFH):		Manufacturer Specified Negative Leak Rate (CFH):			
Measured Positive Leak Rate(CFH)		Measured Negative Leak Rate (CFH)			
Positive Cracking Pressure (in. H2O)		Negative Cracking Pressure (in. H2O)			

P/V Valve Manufacturer:		Model Number:		Pass/Fail:	
Manufacturer Specified Positive Leak Rate (CFH):		Manufacturer Specified Negative Leak Rate (CFH):			
Measured Positive Leak Rate(CFH)		Measured Negative Leak Rate (CFH)			
Positive Cracking Pressure (in. H2O)		Negative Cracking Pressure (in. H2O)			

Tester: Raul Gonzalez
 Signature: _____

Tester Id: 175860
 Test Date: 2020-10-08

VEEDER-RO

T 4:E-85

VOLUME = 3409 GALS

1
G
ER

ALARM TEST		MODE
	BACKUP	FUNCTION
PRINT	CHANGE	STEP
PAPER FEED	ENTER	TANK

OZ. 1	ABC 2	DEF 3
GHI 4	JKL 5	MNO 6
PRS 7	TUV 8	WXY 9
← +/-	0 -□	→ •



ORDER-ROOM

Ullage

= 6838 GALS

	MODE
BACKUP	FUNC-TION
CHANGE	STEP
ENTER	TANK

QZ. 1	ABC 2	DEF 3
GHI 4	JKL 5	MNO 6
PRS 7	TUV 8	WXY 9
← +/-	0 -□	→ .

**NBVC Port Hueneme
Navy Exchange Gasoline Dispensing Facility
Verification Testing Results**

SUMMARY OF SOURCE TEST DATA

SOURCE INFORMATION		FACILITY PARAMETERS		
GDF Name and Address <u>Navy Exchange</u> <u>Bldg 797</u> <u>Port Hueneme Ca 93041</u>	GDF Representative and Title GDF Phone No. <u>NA</u>	PHASE II SYSTEM TYPE (Check One)		
Permit Conditions	Source: GDF Vapor Recovery System GDF # _____ A/C # _____	Balance Hirt Red Jacket Hasstech Healy X Other	Manifolder? Yes	
Operating Parameters				
Number of Nozzels Served by Tank #1	<u>12</u>	Number of Nozzels Served by Tank #3	<u>12</u>	
Number of Nozzels Served by Tank #2	<u>NA</u>	Number of Nozzels Served by Tank #4	<u>NA</u>	
Applicable Regulations:		VN Recommended		
Source Test Results and Comments				
Tank #	<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>
1. Product Grade	<u>87 T1</u>	<u>NA</u>	<u>91</u>	<u>NA</u>
2. Actual Tank Capacity, gallons	<u>20,078</u>	<u> </u>	<u>20,078</u>	<u> </u>
3. Gasoline Volume	<u>11,243</u>	<u> </u>	<u>13232</u>	<u> </u>
4. Ullage, gallons (#2,#3)	<u>8835</u>	<u> </u>	<u>6846</u>	<u> </u>
5. Initial Pressure, inches H2O	<u>2.00</u>	<u> </u>	<u>NA</u>	<u> </u>
6. Pressure After 1 Minute, inches H2O	<u>2.00</u>	<u> </u>	<u> </u>	<u> </u>
7. Pressure After 2 Minute, inches H2O	<u>2.00</u>	<u> </u>	<u> </u>	<u> </u>
8. Pressure After 3 Minute, inches H2O	<u>2.00</u>	<u> </u>	<u> </u>	<u> </u>
9. Pressure After 4 Minute, inches H2O	<u>2.00</u>	<u> </u>	<u> </u>	<u> </u>
10. Final Pressure After 5 Minute, inches H2O	<u>2.00</u>	<u> </u>	<u> </u>	<u> </u>
11. Allowable Final Pressure	<u>1.93</u>	<u> </u>	<u> </u>	<u> </u>
Test Conducted by: Pramdeep Chase	Test Company: PSR ENVIRONMENTAL	Date of Test: 11/19/2020		

Form 1

Static Torque of Rotatable Phase I Adaptors

Test Company: PSR Environmental	Conducted By: Pramdeep Chase
Test Date: 11/19/2020	Facility Name: Navy NEX
Facility Address: Building 797	City: Port Hueneme, CA

Measurement Units: (circle one): Pound-inches pound-feet

Vapor Adaptor 1	Vapor Adaptor 2	Vapor Adaptor 3	Vapor Adaptor 4
Brand: OPW	Brand: OPW	Brand: NA	Brand: NA
Model: 61 VSA	Model: 61 VSA	Model:	Model:
Grade: 87	Grade: 87	Grade:	Grade:
Torque 1: 55	Torque 1: 45	Torque 1:	Torque 1:
Torque 2: 55	Torque 2: 45	Torque 2:	Torque 2:
Torque 3: 55	Torque 3: 55	Torque 3:	Torque 3:
Average: 55	Average: 48.3333333	Average:	Average:
360 Rotation: Yes	360 Rotation: Yes	360 Rotation:	360 Rotation:

Product Adaptor 1	Product Adaptor 1	Product Adaptor 1	Product Adaptor 1
Brand: OPW	Brand: OPW	Brand: NA	Brand: NA
Model: 61 SALP	Model: 61 SALP	Model:	Model:
Grade: 91	Grade: 91	Grade:	Grade:
Torque 1: 45	Torque 1: 45	Torque 1:	Torque 1:
Torque 2: 45	Torque 2: 45	Torque 2:	Torque 2:
Torque 3: 45	Torque 3: 45	Torque 3:	Torque 3:
Average: 45	Average: 45	Average:	Average:
360 Rotation: Yes	360 Rotation: Yes	360 Rotation:	360 Rotation:

Comments: _____

TP-201.1D Form1

Drop Tube Overfill Prevention Device and Spill Container Drain Valve Test Procedure

Facility: Navy NEX	Test Personnel: Pramdeep Chase	Test Date: 11/19/2020
Address: Building 797	Test Company: PSR ENVIRONMENTAL	
City: Port Hueneme, Ca	State, Zip Code Oxnard, CA 93036	
Overfill Prevention Make & Model: OPW	Spill Container Make & Model: OPW	
Date of Last Flow Meter Calibration: 7/14/2020	Date of Last Pressure Gauge Calibration: 7/1/2020	

Test Results

Device Type & Product Grade	Time to Pressurize (SEC)	30-Second Flow Rate (CFH)	30-Second Pressure (in. H2O)	Corrected Flow Rate For Overfill Device Only (See Section 9.2)
87 Drain	10.1	0.00	2.00	NA
91 Drain	9.5	0.01	2.00	0.00
87 Drop Tube	149.7	0.00	2.00	0.00
91 Drop Tube	139	0.00	2.00	0.01

<i>Comments:</i>

Form1

Pressure/Vacuum (P/V) Vent Valve Data Sheet

Facility Name: Navy Nex	Test Date: 11/19/2020
Address: Building 797	Test Company: PSR Environmental
City: Port Hueneme, Ca	Tester Name: Pramdeep Chase

P/V Valve Manufacturer: OPW		Model Number: 723V		Pass
Manufacturers Specified Positive Leak Rate (CFH):	0.05	Manufacturers Specified Negative Leak Rate (CFH):		-0.21
Measured Positive Leak Rate (CFH):	0.00	Measured Negative Leak Rate (CFH):		-0.01
Positive Cracking Pressure (in H2O):	3.42	Negative Cracking Pressure (in H2O):		-7.6

P/V Valve Manufacturer: NA		Model Number:		Pass	Fail
Manufacturers Specified Positive Leak Rate (CFH):		Manufacturers Specified Negative Leak Rate (CFH):			
Measured Positive Leak Rate (CFH):		Measured Negative Leak Rate (CFH):			
Positive Cracking Pressure (in H2O):		Negative Cracking Pressure (in H2O):			

P/V Valve Manufacturer:		Model Number:		Pass	Fail
Manufacturers Specified Positive Leak Rate (CFH):		Manufacturers Specified Negative Leak Rate (CFH):			
Measured Positive Leak Rate (CFH):		Measured Negative Leak Rate (CFH):			
Positive Cracking Pressure (in H2O):		Negative Cracking Pressure (in H2O):			

P/V Valve Manufacturer:		Model Number:		Pass	Fail
Manufacturers Specified Positive Leak Rate (CFH):		Manufacturers Specified Negative Leak Rate (CFH):			
Measured Positive Leak Rate (CFH):		Measured Negative Leak Rate (CFH):			
Positive Cracking Pressure (in H2O):		Negative Cracking Pressure (in H2O):			

VR-201-J and VR-202-J - Weekly, Quarterly, & Annual Inspection and Testing Checklist

TESTING COMPANY

Site Name: Navy Exchange
 Address: Bldg 797
Port Hueneme Ca 93041
 Phone: NA

Name: PSR Environmental
 Address: 364 Vanderbilt Ave
Oxnard ,Ca
 Phone: (805) 403-3930

HEALY DISPENSER VAPOR PIPING VACUUM TEST							
	1/2	3/4	5/6	7/8	9/10	11/12	
Healy VP1000 unit serial number	01908	00307	08122	08834	01068	00242	
Side "A" authorized only, lo vac on?	YES	YES	YES	YES	YES	YES	
Side "A" on, Side "B" auth, hi vac on?	YES	YES	YES	YES	YES	YES	
Side "B" authorized only, lo vac on?	YES	YES	YES	YES	YES	YES	
Side "B" on, Side "A" auth, hi vac on?	YES	YES	YES	YES	YES	YES	
Initial Test Vacuum, inches H ₂ O	78.00	80.00	80.00	76.00	78.00	80.00	
Vacuum after 1 minute, inches H ₂ O	78.00	80.00	80.00	76.00	78.00	80.00	
Allowable Final Vacuum (-4.00)	74.00	76.00	76.00	72.00	74.00	74.00	
Side "A" dispensing vacuum	76.00	78.00	76.00	74.00	78.00	80.00	
Side "B" dispensing vacuum	76.00	78.00	76.00	74.00	78.00	80.00	
Pass / Fail	PASS	PASS	PASS	PASS	PASS	PASS	

HEALY DISPENSER VAPOR PIPING PRESSURE TEST							
	1/2	3/4	5/6	7/8	9/10	11/12	
Dispenser	1/2	3/4	5/6	7/8	9/10	11/12	
Initial Test Pressure, inches H ₂ O	80.00	80.00	80.00	80.00	80.00	80.00	
Pressure after 1 minute, inches H ₂ O	80.00	80.00	80.00	80.00	80.00	80.00	
Allowable Final Pressure	76.00	76.00	76.00	78.00	78.00	78.00	
Pass / Fail	PASS	PASS	PASS	PASS	PASS	PASS	

Manometer What type of pressure device used?


10/28/2020 Calibration date for pressure device (90 days).

Yes All ball valves locked in their "Normal operation" positions when testing complete.

Yes "Site Shutdown Test" passed? (Fueling disabled when power is removed from the Veeder-Root TLS).

Tester: Pramdeep Chase

Test Date: 11/19/2020

Signature: 

Site:**Testing Company**

Site Name: Navy Exchange
 Address: Bldg 797
Port Hueneme Ca 93041
 Phone: NA

Name: PSR Environmental
 Address: 364 Vanderbilt Ave
Oxnard ,Ca
 Phone: (805) 403-3930

Allowable A/L: 0.95-1.15
 CARB EO: VR-202

Test Unit Serial Number: 0418269
 Test Unit Calibration Date: 10/28/2020

Meter Leak Tests: Pre-Test Leak Check (Pass/Fail): Pass
 (For TriTester only) Post-Test Leak Check (Pass/Fail): Pass

*Note: Bulb must not inflate in
less than 30 seconds.*

Dispenser Number	Product Grade	Nozzle Model #	V/L	GPM	PASS /FAIL	Comments
1	87	900	0.99	8.24	Pass	
1	89	900	0.97	8.37	Pass	
1	91	900	0.96	8.24	Pass	
2	87	900	1.05	8.33	Pass	
2	89	900	1.03	8.52	Pass	
2	91	900	1.04	8.41	Pass	
3	87	900	1.02	8.43	Pass	
3	89	900	0.98	8.62	Pass	
3	91	900	0.97	8.52	Pass	
4	87	900	1.03	8.15	Pass	
4	89	900	0.97	8.52	Pass	
4	91	900	1.00	8.06	Pass	
5	87	900	1.11	8.52	Pass	
5	89	900	1.09	8.37	Pass	
5	91	900	1.09	8.33	Pass	
6	87	900	1.11	8.52	Pass	
6	89	900	1.05	8.72	Pass	
6	91	900	1.01	8.43	Pass	
7	87	900	0.95	8.43	Pass	
7	89	900	0.95	8.62	Pass	
7	91	900	0.96	8.82	Pass	
8	87	900	1.05	7.89	Pass	
8	89	900	1.04	7.50	Pass	
8	91	900	1.03	7.58	Pass	
9	87	900	1.08	8.24	Pass	
9	89	900	1.06	7.88	Pass	
9	91	900	1.05	8.15	Pass	
10	87	900	1.03	7.35	Pass	
10	89	900	1.00	7.35	Pass	
10	91	900	1.00	7.43	Pass	

Tester: Pramdeep Chase

Test Date: 11/19/2020

TESTING COMPANY:

Site Name: Navy Exchange
Address: Bldg 797
Port Hueneme Ca 93041
Phone: NA

Name: PSR Environmental
Address: 364 Vanderbilt Ave
Oxnard ,Ca
Phone: (805) 403-3930

Figure 3
Data Form for Determination of Satic Pressure Performance
of the Healy Clean Air Seperator

Date and Time of Last Fuel Drop to GDF: 11-18-20 / 11:32 AM
Date of Last Calibration for Pressure Measurment Device: 10/28/2020

VACUUM TEST (Section 7.1 through 7.2.7)	
Vacuum at start of test, inches water column (7.2.3)	NA
Vacuum at one minute, inches water column	NA
Vacuum at two minutes, inches water column	NA
Vacuum at three minutes, inches water column	NA
Vacuum at four minutes, inches water column	NA
Final vacuum at five minutes, inches water column	NA
System was NOT under vacuum	
Allowable minimum vacuum, inches water column (from table1):	NA

POSTIVE PRESSURE TEST (Section 7.3 through 7.3.9)	
Pressure at start of test, inches water column (7.3.8)	2.00
Pressure at one minute, inches water column	2.03
Pressure at two minutes, inches water column	2.05
Pressure at three minutes, inches water column	2.05
Pressure at four minutes, inches water column	2.06
Final Pressure at five minutes, inches water column	2.06
Allowable final Pressure, inches water column (7.3.9):	1.77

Tester: Pramdeep Chase

Test Date: 11/19/2020

Site:

TESTING COMPANY:

Site Name: Navy Exchange
Address: Bldg 797
Port Hueneme Ca 93041
Phone: NA

Name: PSR Environmental
Address: 364 Vanderbilt Ave
Oxnard, Ca
Phone: (805) 430-3930

EXHIBIT 8

ITEMS TO CONSIDER IN CONDUCTING TP-201.3

The instructions below are required when conducting TP-201.3 for this system. The tester shall document that each step was followed as indicated below and shall include this page of the Exhibit with the submission of TP-201.3 test results. Note that districts may require use of an alternate form to meet these requirements, provided the alternate form includes the same minimum parameters.

- 1 Prior to conducting TP-201.3, all four ball valves on the Healy Clean Air Separator (CAS) shall be closed, as shown in Figure 1, to isolate it from the UST system to permit the pressurization of the UST system.
- 2 Conducting TP-201.3 with any dispenser piping test valve in the closed position is not permitted. Any dispenser with a dispenser piping test valve in the closed position while conducting TP-201.3 will bias the test towards compliance.
- 3 After conducting TP-201.3, the four ball valves on the Healy Clean Air Separator (CAS) shall be locked in their normal operating positions as shown in Figure 2B-5 of Exhibit 2.

Required Steps	Verification
1.All four CAS ball valves closed befor conducting TP-201.3	Yes
2. All dispenser piping test valves open before conducting TP-201.3	Yes
3. All four CAS ball valves in normal operating positions after concucting TP-201.3	Yes

Tester: Pramdeep Chase

Test Date: 11/19/2020

Data Form for Vapor Pressure Sensor Ambient Reference Test

DATE OF TEST: 11/19/2020

SERVICE COMPANY NAME:	PSR Environmental	SERVICE COMPANY'S TELEPHONE	805 403-3930
SERVICE TECHNICIAN:	n/a	VST or VEEDER-ROOT TECH CERTIFICATION #:	B38354
	Pramdeep Chase	ICC or District Training Certification (as applicable)	8191293-VT
STATION NAME:	Navy Exchange	DISTRICT PERMIT #:	NA
STATION ADDRESS:	Bldg 797	CITY, STATE, ZIP:	Port Hueneme Ca 93041

PRESSURE SENSOR LOCATION:	<u>FP: 1/2</u>	PRESSURE SENSOR SERIAL NUMBER:	<u>6922</u>
----------------------------------	----------------	---------------------------------------	-------------

STEP 8.3	DIGITAL MANOMETER VALUE <u>2.02</u> inches WC
STEP 8.3	TLS 350 SENSOR VALUE <u>1.947</u> inches WC (OBTAIN VALUE USING TLS CONSOLE KEYPAD SEQUENCE SHOWN IN FIG. 8-4, Vapor Pressure)
STEP 8.4	TLS 350 Sensor Value within ± 0.2 inches WC of Digital Manometer Value? Yes <u>XX</u> No _____ REQUIREMENTS OF EXHIBIT 2.
STEP 8.5	MODE KEY PRESSED TO EXIT PMC DIAGNOSITC MENU? <u>Yes</u>

Data Form for Vapor Pressure Sensor Ambient Reference Test

DATE OF TEST: 11/19/2020

SERVICE COMPANY NAME: PSR Environmental		SERVICE COMPANY'S TELEPHONE: 805-403-3930	
SERVICE TECHNICIAN:	n/a	VST or VEEDER-ROOT TECH CERTIFICATION #: B38354	
	Pramdeep Chase	ICC or District Training Certification (as applicable) 8191293-VT	
STATION NAME: Navy Exchange		DISTRICT PERMIT #: NA	
STATION ADDRESS: Bldg 797		CITY, STATE, ZIP: Port Hueneme Ca 93041	

STEP 9.1	Pressure Sensor Location:	FP: 1/2	PRESSURE SENSOR SERIAL NUMBER:	6922
----------	---------------------------	---------	--------------------------------	------

STEP 9.2	REFERENCE PORT CAP REMOVED? <u>Yes</u>
	VALVE SET TO AMBIENT REFERENCE PORT (PER FIG. 8-3)? <u>Yes</u>
STEP 9.3	NON-CALIBRATED SENSOR VALUE <u>-0.041</u> INCHES OF WATER COLUMN (OBTAIN VALUE USING TLS CONSOLE KEYPAD SEQUENCE SHOWN IN FIG. 8-4. Vapor pressure)
STEP 9.4	PRESSURE BETWEEN +0.20 & -0.20 (Y/N)? <u>Yes</u> IF NO: THE PRESSURE SENSOR IS OT IN COMPLIANCE WITH THE PRESSURE SENSOR REQUIREMENTS OF EXHIBIT 2.
STEP 9.5	REFERENCE PORT CAP REPLACED? <u>Yes</u>
	VALVE SET TO NORMAL VALVE POSITION (PER FIG 8-3?) <u>Yes</u>
STEP 6.	MODE KEY PRESSED TO EXIT CALIBRATE SMART SENSOR MENU? <u>Yes</u>

Veeder-Root In-Station Diagnostics (ISD)
Vapor Flow Meter Operability Test Procedure

DATE OF TEST: 11/19/2020

SERVICE COMPANY NAME: PSR Environmental		SERVICE COMPANY'S TELEPHONE: (805) 403 - 3930			
SERVICE TECHNICIAN:	n/a	VEEDER-ROOT TECH CERTIFICATION #: (as applicable)		B38354	
	Pramdeep Chase	ICC or DISTRICT TRAINING CERTIFICATION: (as applicable) 8191293-VT			
STATION NAME: Navy Exchange		DISTRICT PERMIT #:		NA	
STATION ADDRESS: Bldg 797		CITY, STATE, ZIP CODE: Port Hueneme Ca 93041			
STEP 2.	VAPOR FLOW METER SERIAL NUMBER	38388		62128	
	DISPENSER FUELING POINT NUMBERS	FP #	1	FP #	3
STEP 3.	LOW GRADE FUEL HOSE V/L RESULT #1 (ONE FP ONLY)	0.99		1.02	
STEP 4.	ISD A/L VALUE #1 CORRESPONDING TO RESULT IN STEP 3	0.95		1.00	
STEP 5.	STEP 4. VALUE MINUS STEP 3. VALUE	DIFF.	-0.04	DIFF.	-0.02
	PASS IF DIFFERENCE IS WITHIN +/- 0.15, LARGER DIFFERENCE, THEN CONTINUE TO STEP 6 (CIRCLE ONE)	PASS	CONTINUE TO STEP 6	PASS	CONTINUE TO STEP 6
STEP 6.	LOW GRADE FUEL HOSE V/L RESULT #2	NA		NA	
	LOW GRADE FUEL HOSE V/L RESULT #3	NA		NA	
	AVERAGE OF 3 V/L RESULTS	AVG.	NA	AVG.	NA
STEP 7.	ISD A/L VALUE #2	NA		NA	
	ISD A/L VALUE #3	NA		NA	
	AVERAGE OF 3 A/L VALUES	AVG.	NA	AVG.	NA
STEP 8.	STEP 7. AVG MINUS STEP 6. AVG	DIFF.	NA	DIFF.	NA
	PASS IF DIFFERENCE IS WITHIN +/- 0.15, IF LARGER DIFFERENCE, THEN CONTINUE TO STEP 9	NA	CONTINUE TO STEP 6	NA	CONTINUE TO STEP 6
STEP 9	IF CONTINUE, REPEAT AT STEP 3. FOR 2ND FP USING 2ND FP COLUMN, ABOVE,				

STATION NAME: Navy Exchange		DISTRICT PERMIT #: NA			
STATION ADDRESS: Bldg 797		CITY: Port Hueneme Ca		STATE, ZIP: 93041	
STEP 2.	VAPOR FLOW METER SERIAL NUMBER	40635		77168	
	DISPENSER FUELING POINT NUMBERS	FP #	5	FP #	7
STEP 3.	LOW GRADE FUEL HOSE V/L RESULT #1 (ONE FP ONLY)	1.11		0.95	
STEP 4.	ISD A/L VALUE #1 CORRESPONDING TO RESULT IN STEP 3	1.05		1.02	
STEP 5.	STEP 4. VALUE MINUS STEP 3. VALUE	DIFF.	-0.06	DIFF.	0.07
	PASS IF DIFFERENCE IS WITHIN +/- 0.15, LARGER DIFFERENCE, THEN CONTINUE TO STEP 6 (CIRCLE ONE)	PASS	CONTINUE TO STEP 6	PASS	CONTINUE TO STEP 6
STEP 6.	LOW GRADE FUEL HOSE V/L RESULT #2	NA		NA	
	LOW GRADE FUEL HOSE V/L RESULT #3	NA		NA	
	AVERAGE OF 3 V/L RESULTS	AVG.	NA	AVG.	NA
STEP 7.	ISD A/L VALUE #2	NA		NA	
	ISD A/L VALUE #3	NA		NA	
	AVERAGE OF 3 A/L VALUES	AVG.	NA	AVG.	NA
STEP 8.	STEP 7. AVG MINUS STEP 6. AVG	DIFF.	NA	DIFF.	NA
	PASS IF DIFFERENCE IS WITHIN +/- 0.15, IF LARGER DIFFERENCE, THEN CONTINUE TO STEP 9	NA	CONTINUE TO STEP 6	NA	CONTINUE TO STEP 6
STEP 9	IF CONTINUE, REPEAT AT STEP 3. FOR 2ND FP USING 2ND FP COLUMN, ABOVE,				

Veeder-Root In-Station Diagnostics (ISD)
Vapor Flow Meter Operability Test Procedure

DATE OF TEST: 11/19/2020

SERVICE COMPANY NAME: PSR Environmental		SERVICE COMPANY'S TELEPHONE: (805) 403 - 3930	
SERVICE TECHNICIAN:	n/a	VEEDER-ROOT TECH CERTIFICATION #: (as applicable) B38354	
	Pramdeep Chase	ICC or DISTRICT TRAINING CERTIFICATION: (as applicable) 8191293-VT	
STATION NAME: Navy Exchange		DISTRICT PERMIT #:	NA
STATION ADDRESS: Bldg 797		CITY, STATE, ZIP CODE: Port Hueneme Ca 93041	
STEP 2.	VAPOR FLOW METER SERIAL NUMBER	65343	72474
	DISPENSER FUELING POINT NUMBERS	FP # 9	FP # 11
STEP 3.	LOW GRADE FUEL HOSE V/L RESULT #1 (ONE FP ONLY)	1.08	0.99
STEP 4.	ISD A/L VALUE #1 CORRESPONDING TO RESULT IN STEP 3	1.12	1.05
STEP 5.	STEP 4. VALUE MINUS STEP 3. VALUE	DIFF. 0.04	DIFF. 0.06
	PASS IF DIFFERENCE IS WITHIN +/- 0.15, LARGER DIFFERENCE, THEN CONTINUE TO STEP 6 (CIRCLE ONE)	PASS CONTINUE TO STEP 6	PASS CONTINUE TO STEP 6
STEP 6.	LOW GRADE FUEL HOSE V/L RESULT #2	NA	NA
	LOW GRADE FUEL HOSE V/L RESULT #3	NA	NA
	AVERAGE OF 3 V/L RESULTS	AVG. NA	AVG. NA
STEP 7.	ISD A/L VALUE #2	NA	NA
	ISD A/L VALUE #3	NA	NA
	AVERAGE OF 3 A/L VALUES	AVG. NA	AVG. NA
STEP 8.	STEP 7. AVG MINUS STEP 6. AVG	DIFF. NA	DIFF. NA
	PASS IF DIFFERENCE IS WITHIN +/- 0.15, IF LARGER DIFFERENCE, THEN CONTINUE TO STEP 9	NA CONTINUE TO STEP 6	NA CONTINUE TO STEP 6
STEP 9	IF CONTINUE, REPEAT AT STEP 3. FOR 2ND FP USING 2ND FP COLUMN, ABOVE,		

STATION NAME:		Navy Exchange		DISTRICT PERMIT #:		NA	
STATION ADDRESS:		Bldg 797		CITY:		STATE, ZIP: Port Hueneme Ca 93041	
STEP 2.	VAPOR FLOW METER SERIAL NUMBER	NA		NA			
	DISPENSER FUELING POINT NUMBERS	FP #	NA	NA	7		
STEP 3.	LOW GRADE FUEL HOSE V/L RESULT #1 (ONE FP ONLY)	NA		NA			
STEP 4.	ISD A/L VALUE #1 CORRESPONDING TO RESULT IN STEP 3	NA		NA			
STEP 5.	STEP 4. VALUE MINUS STEP 3. VALUE	DIFF.	#VALUE!	DIFF.	#VALUE!		
	PASS IF DIFFERENCE IS WITHIN +/- 0.15, LARGER DIFFERENCE, THEN CONTINUE TO STEP 6 (CIRCLE ONE)	PASS	CONTINUE TO STEP 6	PASS	CONTINUE TO STEP 6		
STEP 6.	LOW GRADE FUEL HOSE V/L RESULT #2	NA		NA			
	LOW GRADE FUEL HOSE V/L RESULT #3	NA		NA			
	AVERAGE OF 3 V/L RESULTS	AVG.	NA	AVG.	NA		
STEP 7.	ISD A/L VALUE #2	NA		NA			
	ISD A/L VALUE #3	NA		NA			
	AVERAGE OF 3 A/L VALUES	AVG.	NA	AVG.	NA		
STEP 8.	STEP 7. AVG MINUS STEP 6. AVG	DIFF.	NA	DIFF.	NA		
	PASS IF DIFFERENCE IS WITHIN +/- 0.15, IF LARGER DIFFERENCE, THEN CONTINUE TO STEP 9	NA	CONTINUE TO STEP 6	NA	CONTINUE TO STEP 6		
STEP 9	IF CONTINUE, REPEAT AT STEP 3. FOR 2ND FP USING 2ND FP COLUMN, ABOVE,						

