



February 9, 2021

Mr. Keith Macias  
Manager, Compliance Division  
Ventura County Air Quality Management District  
669 County Square Drive  
Ventura, CA 93003.

**Subject: Submission of Part 70 Permit Annual Compliance Certification  
McGrath Peaker Generating Station, Permit No. 07891**

Dear Mr. Macias,


Southern California Edison Company (SCE) is submitting the Part 70 Permit Annual Compliance Certification for McGrath Peaker Generating Station, Permit #07891, for the period between January 1, 2020 and December 31, 2020.

During the subject period, McGrath experienced permit deviations for exceedances of the Reactive Organic Compound (ROC) emission limit during source testing of the gas turbine on June 23, 2020 and July 9, 2020. As you are aware, this incident has already been discussed at length with the District. A Notice of Violation (NOV# 24316) was issued to the facility on July 9, 2020 for these exceedances. After further investigation the cause of the ROC exceedances was found to be contaminated sampling equipment (Tedlar bags) from the source test vendor, and the facility passed a subsequent re-test on July 20, 2020 using stainless steel canisters in lieu of Tedlar bags. Upon receiving the source test reports and letter of explanation from SCE detailing the cause of the exceedances, the District elected to take no further action. A Deviation Summary Form for this incident is included with this report.

Also, please find enclosed the Annual Compliance Certification Signature Cover Form, Permit Attachment Forms, Source Test Summary Forms, and supporting documents.

If you have any questions regarding these reports, please contact Chijioke (CJ) Akunyili at (909) 809-4368.

Sincerely,

DocuSigned by:  
  
8CDDDB8E198D4CA...

Dan Golden  
Principal Manager  
Generation, Western Operations

Enclosures

cc: Mr. Gerardo Rios, Chief  
Permits office (AIR-3)  
Office of Air Division  
USEPA Region 9  
75 Hawthorne Street  
San Francisco, CA 94105

	Ventura County Air Pollution Control District	<b>ANNUAL COMPLIANCE CERTIFICATION SIGNATURE COVER FORM</b>
---	---	---

A copy of each Annual Compliance Certification shall be submitted to EPA, Region 9, at the following address:


Mr. Gerardo Rios, Chief  
Permits Office (AIR-3)  
Office of Air Division  
EPA Region 9  
75 Hawthorne Street  
San Francisco, CA 94105

**Confidentiality**

All information in a Part 70 permit compliance certification is public information. The Part 70 permit is also public information.

**Certification by Responsible Official**

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in this compliance certification are true, accurate, and complete.

Signature and Title of Responsible Official:	 8CDD88E198D4CA...	Date:
Title:	Principal Manager, Generation	2/11/2021

Time Period Covered by Compliance Certification
01/ 01/20 (MM/DD/YY) to 12/31/20 (MM/DD/YY)



Ventura County  
Air Pollution  
Control District

# ANNUAL COMPLIANCE CERTIFICATION

## SOURCE TEST SUMMARY FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

A. Emission Unit Description: <b>GE LM-6000 PC SPRINT Gas Turbine</b>			B. Pollutant: <b>NOx</b>
C. Measured Emission Rate: 2.28 ppm @15% O2 3.82 lbs/hr	D. Limited Emission Rate: 2.5 ppm @ 15%O2 50 lbs/hr	E. Specific Source Test or Monitoring Record Citation: 07891-T1-161, Condition 1a	F. Test Date: 6/23/20

A. Emission Unit Description: <b>GE LM-6000 PC SPRINT Gas Turbine</b>			B. Pollutant: <b>ROC</b>
C. Measured Emission Rate: 2.17 ppm @15% O2 1.26 lbs/hr	D. Limited Emission Rate: 2.0 ppm @ 15%O2 1.38 lbs/hr	E. Specific Source Test or Monitoring Record Citation: 07891-T1-161, Condition 1b	F. Test Date: 6/23/20

A. Emission Unit Description: <b>GE LM-6000 PC SPRINT Gas Turbine</b>			B. Pollutant: <b>CO</b>
C. Measured Emission Rate: 4.15 ppm @15% O2 4.23 lbs/hr	D. Limited Emission Rate: 6.0 ppm @ 15%O2 15.80 lbs/hr	E. Specific Source Test or Monitoring Record Citation: 07891-T1-161, Condition 1c	F. Test Date: 6/23/20

A. Emission Unit Description: <b>GE LM-6000 PC SPRINT Gas Turbine</b>			B. Pollutant: <b>NH3</b>
C. Measured Emission Rate: 2.76 ppm @15% O2 1.71 lbs/hr	D. Limited Emission Rate: 5.0 ppm @ 15%O2 3.44 lbs/hr	E. Specific Source Test or Monitoring Record Citation: 07891-T1-161, Condition 1d	F. Test Date: 6/23/20

A. Emission Unit Description:			B. Pollutant:
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test or Monitoring Record Citation:	F. Test Date:



Ventura County  
Air Pollution  
Control District

## ANNUAL COMPLIANCE CERTIFICATION

### SOURCE TEST SUMMARY FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

A. Emission Unit Description: <b>GE LM-6000 PC SPRINT Gas Turbine</b>			B. Pollutant: <b>NOx</b>
C. Measured Emission Rate: 2.03 ppm @15% O2 3.37 lbs/hr	D. Limited Emission Rate: 2.5 ppm @ 15%O2 50 lbs/hr	E. Specific Source Test or Monitoring Record Citation: 07891-T1-161, Condition 1a	F. Test Date: 7/9/20

A. Emission Unit Description: <b>GE LM-6000 PC SPRINT Gas Turbine</b>			B. Pollutant: <b>ROC</b>
C. Measured Emission Rate: 11.90 ppm @15% O2 6.89 lbs/hr	D. Limited Emission Rate: 2.0 ppm @ 15%O2 1.38 lbs/hr	E. Specific Source Test or Monitoring Record Citation: 07891-T1-161, Condition 1b	F. Test Date: 7/9/20

A. Emission Unit Description: <b>GE LM-6000 PC SPRINT Gas Turbine</b>			B. Pollutant: <b>CO</b>
C. Measured Emission Rate: 3.12 ppm @15% O2 3.16 lbs/hr	D. Limited Emission Rate: 6.0 ppm @ 15%O2 15.80 lbs/hr	E. Specific Source Test or Monitoring Record Citation: 07891-T1-161, Condition 1c	F. Test Date: 7/9/20

A. Emission Unit Description: <b>GE LM-6000 PC SPRINT Gas Turbine</b>			B. Pollutant: <b>NH3</b>
C. Measured Emission Rate: 3.14 ppm @15% O2 1.93 lbs/hr	D. Limited Emission Rate: 5.0 ppm @ 15%O2 3.44 lbs/hr	E. Specific Source Test or Monitoring Record Citation: 07891-T1-161, Condition 1d	F. Test Date: 7/9/20

A. Emission Unit Description:			B. Pollutant:
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test or Monitoring Record Citation:	F. Test Date:



Ventura County  
Air Pollution  
Control District

# ANNUAL COMPLIANCE CERTIFICATION

## SOURCE TEST SUMMARY FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

A. Emission Unit Description: <b>GE LM-6000 PC SPRINT Gas Turbine</b>			B. Pollutant: <b>NOx</b>
C. Measured Emission Rate: 2.03 ppm @15% O2 3.35 lbs/hr	D. Limited Emission Rate: 2.5 ppm @ 15%O2 50 lbs/hr	E. Specific Source Test or Monitoring Record Citation: 07891-T1-161, Condition 1a	F. Test Date: 7/20/20

A. Emission Unit Description: <b>GE LM-6000 PC SPRINT Gas Turbine</b>			B. Pollutant: <b>ROC</b>
C. Measured Emission Rate: <0.38 ppm @15% O2 <0.22 lbs/hr	D. Limited Emission Rate: 2.0 ppm @ 15%O2 1.38 lbs/hr	E. Specific Source Test or Monitoring Record Citation: 07891-T1-161, Condition 1b	F. Test Date: 7/20/20

A. Emission Unit Description: <b>GE LM-6000 PC SPRINT Gas Turbine</b>			B. Pollutant: <b>CO</b>
C. Measured Emission Rate: 3.43 ppm @15% O2 3.46 lbs/hr	D. Limited Emission Rate: 6.0 ppm @ 15%O2 15.80 lbs/hr	E. Specific Source Test or Monitoring Record Citation: 07891-T1-161, Condition 1c	F. Test Date: 7/20/20

A. Emission Unit Description: <b>GE LM-6000 PC SPRINT Gas Turbine</b>			B. Pollutant: <b>NH3</b>
C. Measured Emission Rate: 3.01 ppm @15% O2 1.84 lbs/hr	D. Limited Emission Rate: 5.0 ppm @ 15%O2 3.44 lbs/hr	E. Specific Source Test or Monitoring Record Citation: 07891-T1-161, Condition 1d	F. Test Date: 7/20/20

A. Emission Unit Description:			B. Pollutant:
C. Measured Emission Rate:	D. Limited Emission Rate:	E. Specific Source Test or Monitoring Record Citation:	F. Test Date:



## ANNUAL COMPLIANCE CERTIFICATION DEVIATION SUMMARY FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<b>A. Attachment # or Permit Condition #:</b> <b>7891-T1-161</b> <b>Condition 1B</b>	<b>B. Equipment description:</b> <b>GE LM-6000 PC SPRINT Gas Turbine</b>	<b>C. Deviation Period: Date &amp; Time</b> Begin: <u>6/23/20, 11:14 AM</u>  End: <u>7/20/20, 5:30 PM</u> When Discovered: Date & Time <u>7/7/20 9:36 AM</u>
<b>D. Parameters monitored:</b> Reactive Organic Compounds (ROC)	<b>E. Limit:</b> <b>2.0 ppmvd @ 15%O2</b>	<b>F. Actual:</b> 2.17 ppmvd @ 15%O2 on 6/23, 11.90 ppmvd @ 15%O2 on 7/9
<b>G. Probable Cause of Deviation:</b> <b>The failed ROC source tests on 6/23 and 7/9 were due to contaminated sampling equipment (Tedlar bags).</b>		<b>H. Corrective actions taken:</b> SCE worked with the source test vendor and VCAPCD to investigate the cause of the high ROC readings and re-tested the unit multiple times. Ambient air sampling eventually confirmed Tedlar bag contamination as the cause. Unit successfully passed a re-test on 7/20 using stainless steel canisters in lieu of Tedlar bags.

<b>A. Attachment # or Permit Condition #:</b>	<b>B. Equipment description:</b>	<b>C. Deviation Period: Date &amp; Time</b> Begin: _____  End: _____ When Discovered: Date & Time _____
<b>D. Parameters monitored:</b>	<b>E. Limit:</b>	<b>F. Actual:</b>
<b>G. Probable Cause of Deviation:</b>		<b>H. Corrective actions taken:</b>

<b>A. Attachment # or Permit Condition #:</b>	<b>B. Equipment description:</b>	<b>C. Deviation Period: Date &amp; Time</b> Begin: _____  End: _____ When Discovered: Date & Time _____
<b>D. Parameters monitored:</b>	<b>E. Limit:</b>	<b>F. Actual:</b>
<b>G. Probable Cause of Deviation:</b>		<b>H. Corrective actions taken:</b>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: <b>7891-T1-161 Conditions # 1-5</b></p>	<p>D. Frequency of monitoring: <b>Annual Source Test and Continuous Emissions Monitoring</b></p>
<p>B. Description: Gas Turbine Emissions Limits: - NOx emissions shall not exceed 2.5 ppmvd @ 15% O2 - NOx emissions shall not exceed 25 ppm @ 15% O2 (4-hr rolling avg) - ROC emissions shall not exceed 2.0 ppmvd @ 15% O2 - CO emissions shall not exceed 6.0 ppmvd @ 15% O2 - NH3 emissions shall not exceed 5.0 ppmvd @ 15% O2</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable <b>Source Test Summary Form attached.</b></p>
<p>C. Method of monitoring: <b>Continuous Emissions Monitoring. Source testing performed on 6/23/20, 7/9/20, and 7/20/20.</b></p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>I</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>Y</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: <b>7891-T1-161 Conditions # 6-12</b></p>	<p>D. Frequency of monitoring: <b>Continuous monitoring</b></p>
<p>B. Description: Continuous Emissions Monitor - Permittee shall: -Install, Operate, Maintain, and Calibrate CEMS pursuant to Rule 74.23; Rule 103, NSPS KKKK and 40 CFR 75. -Promptly report emission violations as indicated by the CEMS -Maintain permanent CEMS records. -Maintain records of all maintenance activities</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable <b>N/A</b></p>
<p>C. Method of monitoring: Attachment #1: CEMS emissions and natural gas usage records. Attachment #2: CEMS maintenance record. Attachment #3: CEMS calibrations record. Attachment #4: SCR and CO catalyst temperature and pressure devices calibrations records. Attachment #5: Fuel and Ammonia flow-meters calibrations records.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: <b>7891-T1-161 Conditions # 13,14</b></p>	<p>D. Frequency of monitoring: <b>Continuous monitoring</b></p>
<p>B. Description: Permittee shall submit operating records pursuant to Rule 74.23.E of: -Actual fuel consumption or operating hour records for the past 12 months; -Annual source test and control system operating parameters Permittee shall submit excess emissions and monitoring report every 6 months pursuant to 40 CFR 60, Subpart KKKK, including 4-hour rolling NOx average</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable Source Test Summary Form attached</p>
<p>C. Method of monitoring: An in-line fuel flow meter is used to monitor actual fuel consumption. Attachment #1 is rolling twelve months total gas consumption. Compliance source tests were performed on 6/23/20, 7/9/20, and 7/20/20. Test reports have been submitted to the District. Excess emissions and monitoring systems reports have been submitted to the District</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: <b>7891-T2 Conditions # 1-2</b></p>	<p>D. Frequency of monitoring:</p> <p style="text-align: center;">N/A</p>
<p>B. Description:</p> <p><b>40 CFR 60 KKKK: SO2 emissions shall not exceed 0.9 lbs/MW-hr or total sulfur in fuel shall not exceed 0.06 lbs/MMBTU heat input</b></p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p style="text-align: center;">N/A</p>
<p>C. Method of monitoring:</p> <p><b>Only PUC quality gas supplied by Southern California Gas Co. is combusted in the turbine, therefore the facility is in compliance with Rule 64 and 40 CFR 60 Subpart KKKK pursuant to 7891-T2 condition #2.</b></p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p><small>*If yes, attach Deviation Summary Form</small></p>

<p>A. Attachment # or Permit Condition #: <b>7891-T2 Conditions # 3,4</b></p>	<p>D. Frequency of monitoring:</p> <p>None for PUC quality gas</p>
<p>B. Description:</p> <p><b>Pursuant to Rule 54.B.1, no person shall discharge sulfur compounds calculated as SO2 in excess of (a) 300 ppmv at point of discharge; (b) 0.25 ppmv, 1-hr average and/or 0.04 ppmv, 24-hr average at ground or sea level.</b></p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p style="text-align: center;">N/A</p>
<p>C. Method of monitoring:</p> <p><b>Combustion of PUC quality natural gas ensures compliance with this requirement. No additional monitoring was required pursuant to 07891-T2 condition #3. No source testing pursuant to condition #4 is required.</b></p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p><small>*If yes, attach Deviation Summary Form</small></p>

<p>A. Attachment # or Permit Condition #: <b>07891-Engine-161 Condition #1</b></p>	<p>D. Frequency of monitoring:</p> <p style="text-align: center;"><b>Continuous</b></p>
<p>B. Description:</p> <p><b>The permitted emissions for the 924 BHP Waukesha engine are based on a NOx emission level of 1.25 grams/BHP-hr. Permittee shall maintain manufacturer's emission documentation that the engine meets this emission level.</b></p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p style="text-align: center;">N/A</p>
<p>C. Method of monitoring:</p> <p><b>Attachment #6 is the generator and engine specification. Emissions Performance vs load curve on page 7 of the attachment shows the engine complies with NOx emissions level of 1.25 grams/BHP-hr.</b></p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p><small>*If yes, attach Deviation Summary Form</small></p>





## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: 07891-Engine-161 Conditions 2 &amp; 7</p> <p>B. Description: -Engine shall be used only when electrical power fails, except for testing and maintenance; -Engine recordkeeping requirement</p>	<p>D. Frequency of monitoring: <b>Monthly</b></p> <p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable <b>N/A</b></p>
<p>C. Method of monitoring: Attachment #7, engine operating log is used to document all engine operations including emergency use hours and testing/maintenance use hours. The log shows the engine in question operated 1.8 hours in 2020.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: 07891-Engine-161 Conditions # 3, 4, 5, 6 &amp; 7</p> <p>B. Description: -Engine shall not operate more than 200 hrs/yr; -Engine shall be equipped with a non-resettable time meter; -Annual compliance certification shall include engine mfr., model number, operator ID and location. -Total engine hours shall be reported annually.</p>	<p>D. Frequency of monitoring: <b>Monthly</b></p> <p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable <b>N/A</b></p>
<p>C. Method of monitoring: Engine operating log is used to document all engine operations including emergency use hours and testing/maintenance use hours. (Attachment #7, engine operating log indicates manufacturer, model number, operator ID and location of use). The engine operated 1.8 hours in 2020.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: PO07891PC-111 Condition 1</p> <p>B. Description: Annual natural gas limit for turbine operation shall not exceed 1,667 MMSCF/yr.</p>	<p>D. Frequency of monitoring: <b>Continuous monitoring</b></p> <p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable <b>N/A</b></p>
<p>C. Method of monitoring: An in-line fuel flow meter calibrated annually is used to monitor natural gas combusted in the turbine. Attachment #1 shows the rolling 12-month natural gas consumption for turbine operation and it indicated only 215.58 mmscf of natural gas was combusted in the gas turbine in 2020.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: <b>PO07891PC1-111 Condition 2</b></p> <p>B. Description: Turbine annual NOx emissions shall not exceed 4.81 tons/yr. Facility annual NOx emissions shall not exceed 4.99 tons/yr.  A rolling 12-month record shall be maintained.</p> <p>C. Method of monitoring: Continuous Emissions Monitoring, Attachment #1 contains the rolling 12-month NOx emissions for 2020, which indicates 1.16 tons of NOx were emitted from the gas turbine. Attachment 7 indicates 0.0023 tons of NOx was emitted from the black-start generator engine.</p>	<p>D. Frequency of monitoring: <b>Continuous Monitoring</b></p> <p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable <b>N/A</b></p> <p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>
---	---

<p>A. Attachment # or Permit Condition #: <b>PO07891PC1-111 Condition 3</b></p> <p>B. Description: The 924 BHP Waukesha natural gas engine shall not be used for more than 200 hours per year.</p> <p>C. Method of monitoring: A totalizing hour meter documents engine operated hours. All engine operation is documented in an operation log. Attachment #7, engine operating log showed the engine operated 1.8 hours in 2020.</p>	<p>D. Frequency of monitoring: <b>Monthly</b></p> <p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable <b>N/A</b></p> <p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>
---	---

<p>A. Attachment # or Permit Condition #: <b>PO07891PC1-111 Condition 4</b></p> <p>B. Description: The LM-6000 SPRINT gas turbine and the 924 BHP Waukesha engine shall be fired on PUC regulated natural gas.</p> <p>C. Method of monitoring: Southern California Gas Company supplies only PUC quality natural gas to McGrath Generating Station.</p>	<p>D. Frequency of monitoring: <b>N/A</b></p> <p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable <b>N/A</b></p> <p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>
---	---



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: PO07891PC1-111 Condition 5</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: The 10,500 gallon ammonia storage tank shall be equipped with a pressure vacuum relief valve set at 50 psig and shall be vented to the vessel from which it is being filled during all filling operations.</p>	<p>N/A</p>
<p>C. Method of monitoring: -Visual observation during filling to verify the tank is vented to the filling vessel. -Attachment #8 is the pressure vacuum relief valve calibration sheet.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p>N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: PO07891-111 Condition 6</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Exempted solvents, coatings, adhesives, and lubricants.</p>	<p>N/A</p>
<p>C. Method of monitoring: A list of all solvents and coatings used at the facility is maintained. Attachment #9 is the coating and solvent usage record for 2020.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p>N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: VCAPCD Rule 50</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Rule 50 - Opacity: No visible emissions for a period or periods greater than 3 minutes in any one hour which are as dark or darker in shade as No. 1 on the Ringelmann Chart, or equivalent to 20% opacity or greater.</p>	<p>Routine surveillance, annual certification</p>
<p>C. Method of monitoring: Annual certification indicating emissions units at the facility comply with applicable sections of Rule 50. Attachment #10 is a copy of the 2020 opacity survey for the gas turbine and Black-start Generator performed on 6/23/20.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p>EPA Method 9</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: <b>VCAPCD Rules 54.B.1 &amp; 54.B.2</b></p>	<p>D. Frequency of monitoring: <b>Upon request</b></p>
<p>B. Description: -Stationary IC engine &amp; gas turbine operators shall not discharge sulfur compounds in excess of 300 ppm by vol (SO<sub>2</sub>) at 15% O<sub>2</sub>. -Sulfur concentration at ground level or at any point at or beyond property line shall not exceed 0.25 ppmv 1-hr average or 0.04 ppmv 24-hr average.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable  EPA Method 6, 6A, 6C, 8, 15, 16A, 16B, or SCAQMD method 307-91</p>
<p>C. Method of monitoring: -Only PUC quality gas is combusted at the facility in compliance with Rule 64 and by extension Rule 54.B.1; -Sulfur concentration at point of discharge and ground level concentration of SO<sub>2</sub> shall be monitored upon District's request.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> <small>*If yes, attach Deviation Summary Form</small></p>

<p>A. Attachment # or Permit Condition #: <b>VCAPCD Rule 55 - Fugitive Dust</b></p>	<p>D. Frequency of monitoring: <b>Routine Surveillance</b></p>
<p>B. Description: Fugitive dust emissions resulting from any operation, disturbed surface area or man made conditions shall not be visible beyond the midpoint of an adjacent street. Opacity shall be less than 20 percent and track out shall be less than 25 feet.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable  <b>N/A</b></p>
<p>C. Method of monitoring: On site operations monitoring: All applicable sources of dust at the facility are operating in compliance with Rule 55. Facility imported 24,650 cu.ft of gravel in 2020 for landscaping purposes.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> <small>*If yes, attach Deviation Summary Form</small></p>

<p>A. Attachment # or Permit Condition #: <b>VCAPCD Rule 57.1</b></p>	<p>D. Frequency of monitoring: <b>Upon request</b></p>
<p>B. Description: Particulate Matter emission from fuel burning equipment shall not exceed 0.12 lbs. per million BTU.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable  <b>CARB Method 5</b></p>
<p>C. Method of monitoring: -Per District Analysis dated Dec. 3rd, 1997, Gas Turbine emission factors was determined to be 0.0419 lb./MMBTU, less than 0.12 lbs./MMBTU limit specified in Rule 57.1 -PM source test will be conducted upon request by the District.</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u> G. Compliance Status? (C or I): <u>C</u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> <small>*If yes, attach Deviation Summary Form</small></p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: <b>VCAPCD Rule 64.B.1</b></p>	<p>D. Frequency of monitoring:</p> <p style="font-size: 1.2em;"><b>None for PUC quality gas</b></p>
<p>B. Description:</p> <p><b>Sulfur content of fuels: No person shall burn gaseous fuel containing sulfur compounds in excess of 50 grains per 100 cubic feet of fuel (788 ppmv).</b></p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p style="font-size: 1.2em;"><b>N/A</b></p>
<p>C. Method of monitoring:</p> <p><b>Southern California Gas Company supplies only PUC quality natural gas to McGrath Peaker. No additional monitoring required.</b></p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p><small>*If yes, attach Deviation Summary Form</small></p>

<p>A. Attachment # or Permit Condition #: <b>VCAPCD Rule 74.6</b></p>	<p>D. Frequency of monitoring:</p> <p style="font-size: 1.2em;"><b>N/A</b></p>
<p>B. Description:</p> <p><b>Surface Cleaning and Degreasing: S-34 NG Cleaner VOC 0.21 lb/gal was used at the facility. Quantity of non-refillable aerosol solvent used at the facility is less than 160 oz per day.</b></p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p style="font-size: 1.2em;"><b>N/A</b></p>
<p>C. Method of monitoring:</p> <p><b>An annual log is used to document surface cleaning and degreasing activities. Attachment 9 is the coating, solvent, adhesive, and aerosol usage log.</b></p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p><small>*If yes, attach Deviation Summary Form</small></p>

<p>A. Attachment # or Permit Condition #: <b>VCAPCD Rule 74.11.1</b></p>	<p>D. Frequency of monitoring:</p> <p style="font-size: 1.2em;"><b>N/A</b></p>
<p>B. Description:</p> <p><b>Large Water Heaters and Small Boilers: comply with NOx emission limits for subject equipment. Maintain list of equipment.</b></p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p style="font-size: 1.2em;"><b>N/A</b></p>
<p>C. Method of monitoring:</p> <p><b>There are no large water heaters or small boilers installed at the facility</b></p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p><small>*If yes, attach Deviation Summary Form</small></p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: <b>VCAPCD Rule 74.22</b></p>	<p>D. Frequency of monitoring:</p> <p style="font-size: 1.2em; text-align: center;">N/A</p>
<p>B. Description: <b>Natural Gas Fired Fan-Type Central Furnaces: comply with NOx emission limits for subject equipment. Maintain list of equipment.</b></p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p style="font-size: 1.2em; text-align: center;">N/A</p>
<p>C. Method of monitoring: <b>There are no natural gas fired fan-type central furnaces installed at the facility.</b></p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p><small>*If yes, attach Deviation Summary Form</small></p>

<p>A. Attachment # or Permit Condition #: <b>VCAPCD Rule 74.1</b></p>	<p>D. Frequency of monitoring:</p> <p style="font-size: 1.2em; text-align: center;">N/A</p>
<p>B. Description: <b>Abrasive Blasting: Comply with visible emissions standards and methods for abrasive blasting operations. Maintain records.</b></p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p style="font-size: 1.2em; text-align: center;">N/A</p>
<p>C. Method of monitoring: <b>No abrasive blasting operation was performed at McGrath Peaker in 2020.</b></p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p><small>*If yes, attach Deviation Summary Form</small></p>

<p>A. Attachment # or Permit Condition #: <b>VCAPCD Rule 74.2</b></p>	<p>D. Frequency of monitoring:</p> <p style="font-size: 1.2em; text-align: center;">N/A</p>
<p>B. Description: <b>Architectural Coatings: Comply with VOC content limits and maintain records for architectural coating use.</b></p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p style="font-size: 1.2em; text-align: center;">N/A</p>
<p>C. Method of monitoring: <b>Architectural coating operation was not performed at McGrath Peaker in 2020.</b></p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p><small>*If yes, attach Deviation Summary Form</small></p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01 / 01 / 20 (MM/DD/YY) to 12 / 31 / 20 (MM/DD/YY)

<p>A. Attachment # or Permit Condition #: <b>VCAPCD Rule 74.4.D</b></p>	<p>D. Frequency of monitoring: <b>N/A</b></p>
<p>B. Description: <b>Cutback Asphalt: Comply with organic compound limit (0.5%) for road oils applied for street paving or maintenance.</b></p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable <b>N/A</b></p>
<p>C. Method of monitoring: <b>Cut back asphalt activities were not performed at the facility in 2020.</b></p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: <b>40 CFR Part 61, Subpart M</b></p>	<p>D. Frequency of monitoring: <b>N/A</b></p>
<p>B. Description: <b>National Emission Standards for Asbestos: Comply with applicable requirements for demolition/renovation activities.</b></p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable <b>N/A</b></p>
<p>C. Method of monitoring: <b>Asbestos demolition/renovation activities were not performed at the facility in 2020.</b></p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #:</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description:</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p>
<p>C. Method of monitoring:</p>	<p>F. Currently in Compliance? (Y or N): _____</p> <p>G. Compliance Status? (C or I): _____</p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): _____ *If yes, attach Deviation Summary Form</p>

## **Attachment 1 – Emissions and Natural Gas Fuel Record**



Monthly Emissions - Averages & Totals Report  
 Southern California Edison - McGrath Beach Substation  
 251 N. Harbor Blvd., Oxnard, Ca 93035  
 Report Period 1/1/2020 00:00 to 12/31/2020 23:59  
 Generated: 2/7/2021

Source: Simple Cycle Combustion Turbine  
 CEMS ID NO.:

Monthly Summary - worksheet 1

MM/YYYY	Process On Mo-To-Date (Hours/mo)	NOx Mo-To-Date (lbs/mo)	CO Mo-To-Date (lbs/mo)	EM10 Mo-To-Date (lbs/mo)	ROC Mo-To-Date (lbs/mo)	SOX Mo-To-Date (lbs/mo)	Gas Flow Mo-To-Date (MMcft/mo)	Gross MW Mo-To-Date (MW/Hrs/mo)
Jan 2020	0.00	0.00	0.00	0	0	0	0.000	0.0
Feb 2020	32.77	130.88	180.28	153	39	9	14.501	1585.5
Mar 2020	54.43	236.23	289.42	243	62	14	22.997	2485.0
Apr 2020	40.58	175.16	208.75	182	46	10	17.203	1863.7
May 2020	96.08	382.00	501.24	449	115	26	42.547	4578.2
Jun 2020	74.92	395.46	366.74	340	87	19	32.172	3428.4
Jul 2020	37.08	167.49	147.42	172	44	10	16.332	1754.8
Aug 2020	65.73	289.59	267.16	302	77	17	28.614	3073.6
Sep 2020	47.88	233.18	228.27	215	55	12	20.353	2186.2
Oct 2020	31.43	171.93	155.49	137	35	8	12.960	1388.9
Nov 2020	13.17	82.73	67.78	58	15	3	5.528	590.4
Dec 2020	5.93	50.25	35.20	25	6	1	2.374	252.2
<b>Total Values</b>	<b>500.00 Hrs</b>	<b>2314.90 lbs</b> 1.16 Tons	<b>2447.75 lbs</b> 1.22 Tons	<b>2276.00 lbs</b> 1.14 Tons	<b>581.00 lbs</b> 0.29 Tons	<b>129.00 lbs</b> 0.06 Tons	<b>215.58 MMcft</b>	<b>23186.90 MW</b>

Monthly Emissions - Averages & Totals Report  
 Southern California Edison - McGrath Beach Substation  
 251 N. Harbor Blvd., Oxnard, Ca 93035  
 Report Period 1/1/2020 00:00 to 12/31/2020 23:59  
 Generated: 2/7/2021

Source: Simple Cycle Combustion Turbine  
 CEMS ID No.:

Monthly Summary - worksheet 2

MM/YYYY	NOx 12Mo Total (lbs/12mo)	CO 12Mo Total (lbs/12mo)	PM10 12Mo Total (lbs/12mo)	ROC 12Mo Total (lbs/12mo)	SOx 12Mo Total (lbs/12mo)	Gas Flow 12Mo Total (MMcft/12mo)
Jan 2020	1905	2036	1933	494	110	183.015
Feb 2020	1834	2034	1910	488	109	180.869
Mar 2020	1850	2113	1946	498	111	184.324
Apr 2020	1867	2201	2008	513	114	190.127
May 2020	2238	2694	2452	627	139	232.233
Jun 2020	2579	3008	2728	698	155	258.354
Jul 2020	2551	2929	2673	683	152	253.112
Aug 2020	2644	2986	2759	705	157	261.283
Sep 2020	2800	3129	2887	738	164	273.395
Oct 2020	2710	2979	2752	704	156	260.563
Nov 2020	2335	2487	2312	591	131	218.940
Dec 2020	2326	2461	2277	582	129	215.580
<b>Final Values</b>	<b>2326 L</b>	<b>2461 L</b>	<b>2277 L</b>	<b>582 L</b>	<b>129 L</b>	<b>215.580 L</b>

## **Attachment 2 – CEMS Maintenance Record**

McGraw Hill  
Quality Assurance Checks  
Monthly Preventive Maintenance

MONTHLY QAOCS INSPECTIONS

Parameters to Check	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC
Date	1/28/2020	2/27/2020	3/25/2020	4/16/2020	5/27/2020	6/24/2020	7/22/2020	8/27/2020	9/23/2020	10/27/2020	11/19/2020	12/9/2020
Technician's Initial:	JW	JW	JW	JW	JW	JW	JW	JW	JW	JW	JW	JW
Unit ID Number	6	5	5	5	5	5	5	5	5	5	5	5
Sample System Checks	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
Check NOx analyzer desiccant media. Replace as necessary	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
Check filter on either H/AC system. Clean or replace as needed	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
Plan for the upcoming linearity/CGA. Check gas bottles pressures <math>-500\text{ psig}</math>. Also check expiration dates. Order new gas bottles as needed keeping in mind the lead time may be several weeks.	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
Check incoming instrument air filter	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
NOx Analyzer												
Motherboard - Voltages - Check status and ensure normal operation	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
Interface - Voltages - Check status and ensure normal operation	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
PMT Voltages	-876.4	-876.4	-876.4	-876.4	-876.4	-876.4	-876.4	-876.4	-876.4	-876.4	-876.4	-876.4
IO Board - Voltages - Check status and ensure normal operation	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
Temperatures:												
Internal	38.4	38.7	38.1	35.1	35.0	38.7	35.7	36.4	38.6	35.8	38.1	38.8
Chamber	50.3	50.2	50.2	50.3	50.1	50.3	50.2	50.3	50.0	50.3	50.3	49.9
COiler	-2.7	-2.8	-2.7	-2.8	-2.8	-2.8	-2.7	-2.8	-3.0	-2.9	-2.7	-2.9
NOx Converter	622.4	620.8	622.7	620.3	621.1	627.1	621.4	622.4	625.6	620.1	620.3	620.8
Other:												
Chamber Pressure	152.9	152.3	152.8	150.8	151.1	185.8	184.8	183.3	184.8	184.5	185.1	185.4
Operator Flow	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK
Alarms Detected	NONE	NONE	NONE	NONE	NONE	NONE	NONE	NONE	NONE	NONE	NONE	NONE
CO Analyzer												
Motherboard - Voltages - Check status and ensure normal operation	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
Interface - Voltages - Check status and ensure normal operation	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
Bias Supply Voltages	-110.8	-110.8	-110.7	-110.7	-110.7	-110.8	-110.8	-110.8	-110.8	-110.8	-110.8	-110.8
IO Board - Voltages - Check status and ensure normal operation	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
Temperatures:												
Internal	32.8	34.2	33.5	33.3	33.1	34.4	33.0	33.5	33.3	33.3	34.0	33.8
Chamber	47.9	48.2	47.7	48.5	48.3	48.2	48.0	47.9	48.4	48.1	48.1	48.0
Other:												
Analyzer Pressure	750.8	747.9	751.2	746.7	747.0	745.5	746.1	742.9	747.9	748.1	752.1	750.8
Sample Flow Rate	0.960	0.972	0.973	0.987	0.983	0.984	0.979	0.974	0.975	0.977	0.986	0.971
Sample Ratio	1.1735500	1.1731200	1.1728500	1.1727400	1.1725200	1.1721600	1.1718300	1.1720000	1.1723500	1.1721300	1.1725500	1.1728100
AGC Intensity	198941	198452	198950	198628	198870	198827	198574	198608	198347	198730	198807	198668
Motor Speed	100	100	100	100	100	100	100	100	100	100	100	100
Alarms Detected	NONE	NONE	NONE	NONE	NONE	NONE	NONE	NONE	NONE	NONE	NONE	NONE
NOxNH3 Analyzer												
Motherboard - Voltages - Check status and ensure normal operation	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
Interface Board - Voltages - Check status and ensure normal operation	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
PMT Voltage	-801.3	-801.3	-800.9	-801.3	-800.9	-801.3	-801.3	-801.3	-800.9	-801.3	-801.3	-801.3
IO Board - Voltages - Check status and ensure normal operation	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
Temperatures:												
Internal	33.1	34.7	34.2	34.0	33.8	34.4	33.7	34.2	33.8	34.5	34.9	34.8
Chamber	50.1	49.8	50.0	49.8	49.9	49.9	49.9	50.1	50.4	49.8	50.0	49.8
COiler	-2.7	-3.1	-3.0	-2.8	-3.1	-3.0	-2.8	-3.0	-3.0	-2.8	-3.0	-3.0
NOx Converter	625.6	623.7	624.8	624.8	621.9	623.5	621.4	621.8	622.7	623.9	624.8	628.8
Other:												
Chamber Pressure	170.3	170.0	170.8	180.1	180.1	184.8	184.4	183.5	184.1	188.8	188.2	188.8
Operator Flow	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK
Alarms Detected	NONE	NONE	NONE	NONE	NONE	NONE	NONE	NONE	NONE	NONE	NONE	NONE

REMARKS:

Mark as either Acceptable "Y", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEWS shelter log book.

Reviewed By: \_\_\_\_\_

Date: \_\_\_\_\_

**McGrath Peaker Generating Station  
Quality Assurance Checks  
Quarterly Preventive Maintenance**

QUARTERLY QA/QC INSPECTIONS				
	First Quarter	Second Quarter	Third Quarter	Fourth Quarter
Date	3/25/2020	6/24/2020	9/24/2020	12/29/2020
Technician's Initial:	JW	JW	JW	JW
<b>SAMPLE SYSTEMS CHECK:</b>				
Inspect sample gas pressure. If sample gas pressure shows a decline, perform one or more of the following:	Y	Y	Y	Y
Perform probe maintenance	Y	Y	Y	Y
Relace filter element and clean the filter chamber	N	N	N	N
Verify if probe box heater is operating	Y	Y	Y	Y
If flow is low check sample pump	N	N	N	N
Perform CEMS sample system leak check	N	N	N	N
Perform general housekeeping duties. Dust/clean all equipment surfaces.	Y	Y	Y	Y
<b>Analyzer Checks</b>				
<b>All Analyzers:</b>				
Visually check for obvious defects such as loose connectors, loose fittings, cracked or clogged tefton lines, and excessive dust or dirt accumulation. Dirt accumulation can cause overheating or component failure and may provide conducting path for electricity	Y	Y	Y	Y
Clean inside of each instrument by vacuuming	Y	Y	Y	Y
Clean all analyzer cooling fans	Y	Y	Y	Y
Caution: Observe all safety warning from manufacturers manual	Y	Y	Y	Y

REMARKS:

Mark as either Acceptable "Y", Corrective action Required "X", or Actual Readings, where required

Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By: \_\_\_\_\_

Date: \_\_\_\_\_

**McGrath Peaker Generating Station  
Quality Assurance Checks  
Annual Preventive Maintenance**

**ANNUAL QA/QC INSPECTIONS**

Date:	6/2/2020
Technician's Initial:	JW

Parameters to Check	Values/Status
<b>TECO MODEL 4211-LS NOx</b>	
Clean the lens in the reaction chamber s needed	Not Needed
Perform a NOx converter check. Replace the converter as necessary	N/A
Inspect and Clean cooler fins on PMT cooler	Checked
Check sample pump A - Replace diaphragm and disk as needed	Replaced
Check sample pump B - Replace diaphragm and disk as needed	N/A
Replace capillaries and O-rings	Inspected
<b>SERVOMEX MODEL 1440D O2 Analyzer</b>	
Check filter element at Flow Control Device. replace as needed	Replaced
Check for leaks	Checked
<b>TECO MODEL 481 CO Analyzer</b>	
Replace IR Source (as needed)	Replaced
Clean correlation wheel, optics, and measuring cell, as necessary	Cleaned
Check for leaks around fittings	Checked
Check pump diaphragm and replace as necessary	Replaced
Replace capillary	Inspected
Clean fan filter	Cleaned
<b>Sample System Checks</b>	
Check sample pump A tubing - Replace diaphragm and disk as needed	Replaced
Check sample pump B tubing - Replace diaphragm and disk as needed	Replaced
Perform probe maintenance, inspect filter and O-rings and replace as necessary	Replaced
Adjust 4-20 mA outputs (analog) to match LED display for all analyzers	Verified
Replace ammonia scrubber media	Replaced
Replace peristaltic pump diaphragm	Replaced
Replace dry air dessicant	Replaced

**REMARKS:**

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Mark as either Acceptable "Y", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By: \_\_\_\_\_

Date: \_\_\_\_\_

## McGrath Peaker Generating Station Quality Assurance Checks Daily Preventive Maintenance

Parameters to Check	Tag ID	Limits	Mon	Tue	Wed	Thu	Fri	Sat	Sun
Dates									
Technician's Initial						1/2/2020			
Please enter readings and notify the Maintenance Manager when it is time to re-order.									
Calibration Gas Pressures						JW			
O2/CO High Span, NOX Zero	SV1	>150 psi				1290			
NOX Low Span/CO Low Span	SV2	>150 psi				1020			
NOX High Span, O2/CO Zero	SV3	>150 psi				910			
Please enter readings.									
Stack Sample Line									
Sample Line Temperature	TC1	250°F				250			
Sample NH3 Temperature -	TC2	760°F				790			
Sample Line Pressure/Vacuum	PI-1	6.0 "Hg				6.5			
Sample Line Pressure/Vacuum	PI-2	8.0 "Hg				5.7			
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg				6.6			
Sample Line Pressure	PI-5	8 psi				6.0			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)				Y			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)				Y			
Visual Checks									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F				67.0			
Moisture Sensor A/Filler	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter				Y			
Moisture Sensor B/Filler	MS-2	Check "Y" if ok, "X" if not				Y			
Operational Status of Sample Pumps (2)		Check "Y" if ok, "X" if not				Y			
Operational Status of Condensate Drain Pumps (2)		Check "Y" if ok, "X" if not				Y			
Check LED status of Sample Cooler		Check "Y" if ok, "X" if not				Y			
NH3 Scrubber Drain	HV-4	Drain as needed				Y			
Please enter readings.									
Analyzer Sample Flow Meter Readings									
System Flow	FM-1	3-5 LPM				4.3			
O2 Analyzer	FM-2	1.2 - 1.7 LPM				1.55			
NOX Analyzer	FM-3	1.2 - 1.7 LPM				1.6			
NOX By-Pass	FM-4	1.2 - 1.7 LPM				1.35			
CO Analyzer	FM-5	1.2 - 1.7 LPM				1.55			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7				N/A			
System Flow	FM-7	3-5 LPM				4.5			
NOX/NH3 Analyzer	FM-8	1.5 LPM				1.45			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM				1.4			
NOX Div Air	FM-10	500-700 CCM				600			
DAHs Checks									
Check DAHS for normal operation. Is system logging data?		Check "Y" if ok, "X" if not				Y			
Check Alarms in DAHS.						Y			
Check chart recorder for normal operation						Y			
Check printer status						Y			
Check analyzer calibration drift. Did all calibrations pass?		Check "Y" if ok, "X" if not				Y			
Is yellow "WARNING" status indicating?		Check "Y" if ok, "X" if not				Y			
Make drift adjustments and perform full hands-off calibration									
REMARKS:									

Mark as either Acceptable "Y", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shaker log book.

Reviewed By Supervisor: \_\_\_\_\_

Date: \_\_\_\_\_

# McGrath Peaker Generating Station Quality Assurance Checks Daily Preventive Maintenance

Parameters to Check		Tag ID	Limits	Mon 4/6/20 JW	Tue 4/7/20 JW	Wed 4/8/20 JW	Thu 4/9/20 JW	Fri	Sat	Sun
<b>Technician's Initial</b>										
<b>Calibration Gas Pressures</b>										
O2/CO High Span, NOX Zero	SV1	>150 psi	1220	1200	1140	1090				
NOX Low Span/CO Low Span	SV2	>150 psi	960	950	890	870				
NOX High Span, O2/CO Zero	SV3	>150 psi	910	900	880	860				
<b>Stack Sample Line</b>										
Sample Line Temperature	TC1	250°F	250	250	250	250				
Sample NH3 Temperature -	TC2	760°F	760	760	780	780				
Sample Line Pressure/Vacuum	PI-1	6.0 "Hg	6.4	6.4	6.4	6.5				
Sample Line Pressure/Vacuum	PI-2	8.0 "Hg	5.8	5.7	5.7	5.6				
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg	6.6	6.6	6.6	6.5				
Sample Line Pressure	PI-5	8 psi	6.2	6.1	6.0	6.0				
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	Y	Y	Y	Y				
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	Y	Y	Y	Y				
<b>Visual Checks</b>										
Room Enclosure Temperature		Check HVAC controls	72 F (+/-5) F	70.0	67.5	67.0	67.0			
Moisture Sensor A/Filler		MS-1	Clean and dry, if filler shows buildup and flow levels are dropping, replace filter	Y	Y	Y	Y			
Moisture Sensor B/Filler		MS-2		Y	Y	Y	Y			
Operational Status of Sample Pumps (2)			Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Operational Status of Condensate Drain Pumps (2)			Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check LED status of Sample Cooler			Check "Y" if ok, "X" if not	Y	Y	Y	Y			
NH3 Scrubber Drain		HV-4	Drain as needed	Y	Y	Y	Y			
<b>Analyzer Sample Flow Meter Readings</b>										
System Flow		FM-1	3-5 LPM	4.3	4.3	4.3	7.3			
O2 Analyzer		FM-2	1.2 - 1.7 LPM	1.55	1.55	1.55	1.55			
NOX Analyzer		FM-3	1.2 - 1.7 LPM	1.6	1.6	1.6	1.6			
NOX By-Pass		FM-4	1.2 - 1.7 LPM	1.35	1.3	1.3	1.3			
CO Analyzer		FM-5	1.2 - 1.7 LPM	1.7	1.65	1.7	1.7			
Cal Gas Flow (only during Calibration)		FM-6	> than FM-1 & FM-7	N/A						
System Flow		FM-7	3-5 LPM	4.5	4.5	4.5	4.5			
NOX/NH3 Analyzer		FM-8	1.5 LPM	1.45	1.45	1.45	1.45			
NOX/NH3 Analyzer By-Pass		FM-9	1.2 - 1.5 LPM	1.4	1.4	1.4	1.4			
NOX Dry Air		FM-10	500 - 700 CCM	590	590	590	590			
<b>DAHS Checks</b>										
Check DAHS for normal operation, Is system logging data?			Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check Alarms In DAHS			Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check chart recorder for normal operation			Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check printer status			Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check analyzer calibration drift, Did all calibrations pass?			Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Is yellow "WARNING" status indicating?			Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Make drift adjustments and perform full hands-off calibration										
<b>REMARKS:</b>										

Mark as either Acceptable "Y", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_

Date: \_\_\_\_\_



# McGrath Peaker Generating Station

## Quality Assurance Checks

### Daily Preventive Maintenance

Parameters to Check	Tag ID	Limits	Mon	Tue	Wed	Thu	Fri	Sat	Sun
Technician's Initial			1/13/20	1/14/20	1/15/20	1/16/20			
Calibration Gas Pressures			JW	JW	JW	JW			
O2/CO High Span, NOX Zero	SV1	>150 psi	1000	990	930	900			
NOX Low Span/CO Low Span	SV2	>150 psi	870	870	870	820			
NOX High Span, O2/CO Zero	SV3	>150 psi	880	880	830	800			
Stack Sample Line									
Sample Line Temperature	TC1	250°F	250	250	250	250			
Sample NH3 Temperature -	TC2	760°F	760	760	760	760			
Sample Line Pressure/Vacuum	PI-1	6.0 "Hg	6.4	6.4	6.6	6.5			
Sample Line Pressure/Vacuum	PI-2	8.0 "Hg	5.7	5.7	5.6	5.6			
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg	6.6	6.6	6.6	6.5			
Sample Line Pressure	PI-5	8 Psi	6.1	6.1	6.1	6.1			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	Y	Y	Y	Y			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	Y	Y	Y	Y			
Visual Checks									
Room Enclosure Temperature		Check HVAC controls	68.5	67.5	69.5	69.0			
Moisture Sensor A/Filler	MS-1	Clean and dry, if filler shows buildup and flow levels are dropping, replace filler	Y	Y	Y	Y			
Moisture Sensor B/Filler	MS-2	Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Operational Status of Condensate Drain Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check LED status of Sample Cooler		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
NH3 Scrubber Drain	HV-4	Drain as needed	Y	Y	Y	Y			
Analyzer Sample Flow Meter Readings									
System Flow	FM-1	3-5 LPM	4.3	4.3	4.3	4.2			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.55	1.55	1.55	1.55			
NOX Analyzer	FM-3	1.2 - 1.7 LPM	1.6	1.6	1.6	1.6			
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.35	1.35	1.3	1.35			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.6	1.7	1.65	1.55			
Cell Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	N/A	N/A	N/A	N/A			
System Flow	FM-7	3-5 LPM	4.5	4.5	4.5	4.5			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.45	1.45	1.45	1.45			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.4	1.4	1.4	1.4			
NOX Dry Air	FM-10	500- 700 CCM	590	580	580	580			
DAHs Checks									
Check DAHS for normal operation. Is system logging data?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check Alarms in DAHS.			Y	Y	Y	Y			
Check chart recorder for normal operation			Y	Y	Y	Y			
Check printer status			Y	Y	Y	Y			
Check analyzer calibration drift. Did all calibrations pass?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Is yellow "WARNING" status indicating?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Make drift adjustments and perform full hands-off calibration						Y			
REMARKS:									

Mark as either Acceptable "Y", Corrective action Required "X" or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator Immediately. Corrective Action performed shall be logged in the CEMS shaker log book.

Reviewed By Supervisor: \_\_\_\_\_

Date: \_\_\_\_\_

# McGrath Peaker Generating Station

## Quality Assurance Checks

### Daily Preventive Maintenance

Parameters to Check	Tag ID	Limits	Mon	Tue	Wed	Thu	Fri	Sat	Sun
<b>Dates</b>									
Technician's Initial				1/21/20	1/22/20	1/23/20			
<b>Calibration Gas Pressures</b>									
O2/CO High Span, NOX Zero	SV1	>150 psi		790	770	770			
NOX Low Span/CO Low Span	SV2	>150 psi		770	770	800			
NOX High Span, O2/CO Zero	SV3	>150 psi		790	790	790			
<b>Stack Sample Line</b>									
Sample Line Temperature	TC1	250°F		250	250	250			
Sample NH3 Temperature -	TC2	780°F		780	780	780			
Sample Line Pressure/Vacuum	P1-1	6.0 "Hg		6.4	6.3	6.4			
Sample Line Pressure/Vacuum	P1-2	8.0 "Hg		5.8	5.8	5.7			
Sample Line Pressure/Vacuum	P1-4	7.5 "Hg		6.5	6.5	6.6			
Sample Line Pressure	P1-5	8 Psi		6.1	6.1	6.0			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)		Y	Y	Y			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)		Y	Y	Y			
<b>Visual Checks</b>									
Room Enclosure Temperature		Check HVAC controls		68.0	67.0	67.5			
Moisture Sensor A/Filler	MS-1	Clean and dry. If filter shows buildup and flow levels are dropping, replace filter.		Y	Y	Y			
Moisture Sensor B/Filler	MS-2			Y	Y	Y			
Operational Status of Sample Pumps (2)		Check "Y" if ok, "X" if not		Y	Y	Y			
Operational Status of Condensate Drain Pumps (2)		Check "Y" if ok, "X" if not		Y	Y	Y			
Check LED status of Sample Cooler		Check "Y" if ok, "X" if not		Y	Y	Y			
NH3 Scrubber Drain	HV-4	Drain as needed		Y	Y	Y			
<b>Analyzer Sample Flow Meter Readings</b>									
System Flow	FM-1	3-5 LPM		4.3	4.3	4.3			
O2 Analyzer	FM-2	1.2 - 1.7 LPM		1.55	1.55	1.55			
NOX Analyzer	FM-3	1.2 - 1.7 LPM		1.6	1.6	1.6			
NOX By-Pass	FM-4	1.2 - 1.7 LPM		1.35	1.35	1.35			
CO Analyzer	FM-5	1.2 - 1.7 LPM		1.7	1.65	1.7			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7							
System Flow	FM-7	3-5 LPM		4.5	4.5	4.5			
NOX/NH3 Analyzer	FM-8	1.5 LPM		1.45	1.45	1.45			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM		1.4	1.4	1.4			
NOX Dry Air	FM-10	500-700 CCM		580	580	580			
<b>DAHS Checks</b>									
Check DAHS for normal operation. Is system logging data?		Check "Y" if ok, "X" if not		Y	Y	Y			
Check Alarms in DAHS.				Y	Y	Y			
Check chart recorder for normal operation				Y	Y	Y			
Check printer status				Y	Y	Y			
Check analyzer calibration drift. Did all calibrations pass?		Check "Y" if ok, "X" if not		Y	Y	Y			
Is yellow "WARNING" status indicating?		Check "Y" if ok, "X" if not		Y	Y	Y			
Make drift adjustments and perform full hands-off calibration				Y		Y			
<b>REMARKS:</b>									
Please enter readings									

Mark as either Acceptable "Y", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator Immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_

Date: \_\_\_\_\_

## McGrath Peaker Generating Station Quality Assurance Checks Daily Preventive Maintenance

Parameters to Check	Tag ID	Limits	Mon 1/27/20 JW	Tue 1/28/20 JW	Wed 1/29/20 JW	Thu 1/30/20 JW	Fri	Sat	Sun
<b>Technician's Initial</b>									
<b>Calibration Gas Pressures</b>									
O2/CO High Span, NOX Zero	SV1	>150 psi	700	690	620	630			
NOX Low Span/CO Low Span	SV2	>150 psi	790	760	720	700			
NOX High Span, O2/CO Zero	SV3	>150 psi	790	790	730	740			
<b>Stack Sample Line</b>									
Sample Line Temperature	TC1	250°F	250	250	250	250			
Sample NH3 Temperature -	TC2	760°F	760	780	780	780			
Sample Line Pressure/Vacuum	PI-1	6.0 "Hg	6.4	6.4	6.8	6.4			
Sample Line Pressure/Vacuum	PI-2	8.0 "Hg	5.8	5.7	5.7	5.8			
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg	6.6	6.6	6.5	6.6			
Sample Line Pressure	PI-5	8 Psi	6.1	6.1	6.0	6.1			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	Y	Y	Y	Y			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	Y	Y	Y	Y			
<b>Visual Checks</b>									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	67.5	69.0	69.0	69.0			
Moisture Sensor A/Filler	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter.	Y	Y	Y	Y			
Moisture Sensor B/Filler	MS-2		Y	Y	Y	Y			
Operational Status of Sample Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Operational Status of Condensate Drain Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check LED status of Sample Cooler		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
NH3 Scrubber Drain	HV-4	Drain as needed	Y	Y	Y	Y			
<b>Analyzer Sample Flow Meter Readings</b>									
System Flow	FM-1	3-5 LPM	4.3	4.3	4.3	4.3			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.65	1.55	1.55	1.55			
NOX Analyzer	FM-3	1.2 - 1.7 LPM	1.7	1.6	1.6	1.6			
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.35	1.35	1.35	1.35			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.65	1.7	1.7	1.65			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	N/A	N/A	N/A	N/A			
System Flow	FM-7	3-5 LPM	4.5	4.5	4.5	4.5			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.45	1.45	1.45	1.45			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.4	1.4	1.4	1.4			
NOX Dry Air	FM-10	500-700 CCM	650	650	680	660			
<b>DAHHS Checks</b>									
Check DAHS for normal operation, is system logging data?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check Alarms in DAHS.			Y	Y	Y	Y			
Check chart recorder for normal operation			Y	Y	Y	Y			
Check printer status			Y	Y	Y	Y			
Check analyzer calibration drift, Did all calibrations pass?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Is yellow "WARNING" status indicating?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Make drift adjustments and perform full hands-off calibration									
<b>REMARKS:</b>									

Mark as either Acceptable "Y", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEWS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_

Date: \_\_\_\_\_

## McGrath Peaker Generating Station Quality Assurance Checks Daily Preventive Maintenance

Parameters to Check	Tag ID	Limits	Mon 2/3/20 JW	Tue	Wed 2/6/20 JW	Thu 2/6/20 JW	Fri	Sat	Sun
<b>Dates</b>									
Technician's Initial									
<b>Calibration Gas Pressures</b>									
O2/CO High Span, NOX Zero	SV1	>150 psi	590		570	520			
NOX Low Span/CO Low Span	SV2	>150 psi	720		720	700			
NOX High Span, O2/CO Zero	SV3	>150 psi	710		750	690			
<b>Stack Sample Line</b>									
Sample Line Temperature	TC1	250°F	250		250	250			
Sample NH3 Temperature -	TC2	780°F	780		780	780			
Sample Line Pressure/Vacuum	PI-1	6.0 "Hg	6.5		6.5	6.3			
Sample Line Pressure/Vacuum	PI-2	8.0 "Hg	5.7		5.8	5.8			
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg	6.5		5.8	5.6			
Sample Line Pressure	PI-5	8 Psi	6.0		6.1	6.1			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	Y		Y	Y			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	Y		Y	Y			
<b>Visual Checks</b>									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	66.5		69.5	67.0			
Moisture Sensor A/Filler	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	Y		Y	Y			
Moisture Sensor B/Filler	MS-2		Y		Y	Y			
Operational Status of Sample Pumps (2)		Check "Y" if ok, "X" if not	Y		Y	Y			
Operational Status of Condensate Drain Pumps (2)		Check "Y" if ok, "X" if not	Y		Y	Y			
Check LED status of Sample Cooler		Check "Y" if ok, "X" if not	Y		Y	Y			
NH3 Scrubber Drain	HV-4	Drain as needed	Y		Y	Y			
<b>Analyzer Sample Flow Meter Readings</b>									
System Flow	FM-1	3-5 LPM	4.1		4.3	4.1			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.55		1.55	1.55			
NOX Analyzer	FM-3	1.2 - 1.7 LPM	1.6		1.6	1.6			
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.35		1.35	1.3			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.6		1.65	1.65			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	N/A		N/A	N/A			
System Flow	FM-7	3-5 LPM	4.5		4.5	4.5			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.45		1.45	1.45			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.4		1.4	1.4			
NOX Dry Air	FM-10	500-700 CCM	660		660	660			
<b>DAHS Checks</b>									
Check DAHS for normal operation. Is system logging data?		Check "Y" if ok, "X" if not	Y		Y	Y			
Check Alarms in DAHS.			Y		Y	Y			
Check chart recorder for normal operation			Y		Y	Y			
Check printer status			Y		Y	Y			
Check analyzer calibration drift. Did all calibrations pass?		Check "Y" if ok, "X" if not	Y		Y	Y			
Is yellow "WARNING" status indicating?		Check "Y" if ok, "X" if not	Y		Y	Y			
Make drift adjustments and perform full hands-off calibration									
<b>REMARKS:</b>									
Please enter readings									

Mark as either Acceptable "Y", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_

Date: \_\_\_\_\_

## McGrath Peaker Generating Station Quality Assurance Checks Daily Preventive Maintenance

Parameters to Check	Tag ID	Limits	Mon	Tue	Wed	Thu	Fri	Sat	Sun
<b>Dates</b>									
Technician's Initial			2/10/20			2/13/20			
			JW			JW			
<b>Calibration Gas Pressures</b>									
O2/CO High Span, NOX Zero	SV1	>150 psi	490			480			
NOX Low Span/CO Low Span	SV2	>150 psi	650			680			
NOX High Span, O2/CO Zero	SV3	>150 psi	690			670			
<b>Stack Sample Line</b>									
Sample Line Temperature	TC1	250°F	250			250			
Sample NH3 Temperature -	TC2	760°F	760			760			
Sample Line Pressure/Vacuum	PI-1	6.0 "Hg	6.5			6.4			
Sample Line Pressure/Vacuum	PI-2	8.0 "Hg	5.6			5.7			
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg	5.7			6.6			
Sample Line Pressure	PI-5	8 Psi	6.0			6.0			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	Y			Y			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	Y			Y			
<b>Visual Checks</b>									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	69.0			68.0			
Moisture Sensor A/Filler	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	Y			Y			
Moisture Sensor B/Filler	MS-2		Y			Y			
Operational Status of Sample Pumps (2)		Check "Y" if ok, "X" if not	Y			Y			
Operational Status of Condensate Drain Pumps (2)		Check "Y" if ok, "X" if not	Y			Y			
Check LED status of Sample Cooler		Check "Y" if ok, "X" if not	Y			Y			
NH3 Scrubber Drain	HV-4	Drain as needed	Y			Y			
<b>Analyzer Sample Flow Meter Readings</b>									
System Flow	FM-1	3-5 LPM	4.3			4.1			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.55			1.55			
NOX Analyzer	FM-3	1.2 - 1.7 LPM	1.6			1.6			
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.35			1.35			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.6			1.85			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	N/A			N/A			
System Flow	FM-7	3-5 LPM	4.5			4.5			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.45			1.45			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.4			1.4			
NOX Dry Air	FM-10	500- 700 CCM	660			610			
<b>DAHs Checks</b>									
Check DAHS for normal operation, is system logging data?		Check "Y" if ok, "X" if not	Y			Y			
Check Alarms in DAHS.			Y			Y			
Check chart recorder for normal operation			Y			Y			
Check printer status			Y			Y			
Check analyzer calibration drift, Did all calibrations pass?		Check "Y" if ok, "X" if not	Y			Y			
Is Yellow "WARNING" status indicating?		Check "Y" if ok, "X" if not	Y			Y			
Make drift adjustments and perform full hands-off calibration									
<b>REMARKS:</b>									
Please enter readings									

Mark as either Acceptable "Y", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shalter log book.

Reviewed By Supervisor: \_\_\_\_\_

Date: \_\_\_\_\_

## McGrath Peaker Generating Station Quality Assurance Checks Daily Preventive Maintenance

Parameters to Check	Tag ID	Limits	Mon	Tue	Wed	Thu	Fri	Sat	Sun
<b>Dates</b>									
Technician's Initial				2/18/20 JW	2/19/20 JW	2/20/20 JW			
<b>Calibration Gas Pressures</b>									
O2/CO High Span, NOX Zero	SV1	>150 psi		370	350	2100			
NOX Low Span/CO Low Span	SV2	>150 psi		600	600	620			
NOX High Span, O2/CO Zero	SV3	>150 psi		630	630	600			
<b>Stack Sample Line</b>									
Sample Line Temperature	TC1	250°F		250	250	250			
Sample NH3 Temperature -	TC2	760°F		760	760	760			
Sample Line Pressure/Vacuum	PI-1	6.0 "Hg		6.4	6.4	6.4			
Sample Line Pressure/Vacuum	PI-2	8.0 "Hg		5.7	5.8	5.7			
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg		6.5	6.6	6.6			
Sample Line Pressure	PI-5	8 Psi		6.0	6.0	6.0			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)		Y	Y	Y			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)		Y	Y	Y			
<b>Visual Checks</b>									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F		68.5	67.0	67.5			
Moisture Sensor A/Filler	MS-1	Clean and dry, if filler shows buildup and flow levels are dropping, replace filter		Y	Y	Y			
Moisture Sensor B/Filler	MS-2			Y	Y	Y			
Operational Status of Sample Pumps (2)		Check "Y" if ok, "X" if not		Y	Y	Y			
Operational Status of Condensate Drain Pumps (2)		Check "Y" if ok, "X" if not		Y	Y	Y			
Check LED status of Sample Cooler		Check "Y" if ok, "X" if not		Y	Y	Y			
NH3 Scrubber Drain	HV-4	Drain as needed		Y	Y	Y			
<b>Analyzer Sample Flow Meter Readings</b>									
System Flow	FM-1	3-5 LPM		4.3	4.3	4.3			
O2 Analyzer	FM-2	1.2 - 1.7 LPM		1.55	1.55	1.55			
NOX Analyzer	FM-3	1.2 - 1.7 LPM		1.6	1.6	1.6			
NOX By-Pass	FM-4	1.2 - 1.7 LPM		1.35	1.35	1.35			
CO Analyzer	FM-5	1.2 - 1.7 LPM		1.6	1.6	1.65			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7		N/A	N/A	N/A			
System Flow	FM-7	3-5 LPM		4.5	4.5	4.5			
NOX/NH3 Analyzer	FM-8	1.5 LPM		1.45	1.45	1.45			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM		1.4	1.4	1.4			
NOX Dry Air	FM-10	500- 700 CCM		600	600	600			
<b>DAHS Checks</b>									
Check DAHS for normal operation. Is system logging data?		Check "Y" if ok, "X" if not		Y	Y	Y			
Check Alarms in DAHS.				Y	Y	Y			
Check chart recorder for normal operation				Y	Y	Y			
Check printer status				Y	Y	Y			
Check analyzer calibration drift. Did all calibrations pass?		Check "Y" if ok, "X" if not		Y	Y	Y			
Is yellow "WARNING" status indicating?		Check "Y" if ok, "X" if not		Y	Y	Y			
Make drift adjustments and perform full hands-off calibration				Y	Y	Y			
<b>REMARKS:</b>									

Mark as either Acceptable "Y", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_



# McGrath Peaker Generating Station

## Quality Assurance Checks

### Daily Preventive Maintenance

Parameters to Check	Tag ID	Limits	Mon	Tue	Wed	Thu	Fri	Sat	Sun
<b>Technician's Initial</b>									
<b>Calibration Gas Pressures</b>									
O2/CO High Span, NOX Zero	SV1	>150 psi	1670	1770	1780	1600			
NOX Low Span/CO Low Span	SV2	>150 psi	580	590	590	480			
NOX High Span, O2/CO Zero	SV3	<150 psi	570	590	550	510			
<b>Stack Sample Line</b>									
Sample Line Temperature	TC1	250°F	250	250	250	250			
Sample NH3 Temperature -	TC2	760°F	760	760	760	760			
Sample Line Pressure/Vacuum	PI-1	6.0 "Hg	6.4	6.1	6.1	6.4			
Sample Line Pressure/Vacuum	PI-2	8.0 "Hg	5.8	5.8	5.9	5.8			
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg	6.6	6.5	6.5	6.5			
Sample Line Pressure	PI-5	8 Psi	6.1	6.2	6.2	6.1			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	Y	Y	Y	Y			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	Y	Y	Y	Y			
<b>Visual Checks</b>									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	67.5	69.0	68.0	70.0			
Moisture Sensor A/Filter	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	Y	Y	Y	Y			
Moisture Sensor B/Filter	MS-2		Y	Y	Y	Y			
Operational Status of Sample Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Operational Status of Condensate Drain Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check LED status of Sample Cooler		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
NH3 Scrubber Drain	HV-4	Drain as needed	Y	Y	Y	Y			
<b>Analyzer Sample Flow Meter Readings</b>									
System Flow	FM-1	3-5 LPM	4.3	4.3	4.3	4.3			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.55	1.55	1.55	1.55			
NOX Analyzer	FM-3	1.2 - 1.7 LPM	1.6	1.6	1.6	1.6			
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.35	1.35	1.35	1.3			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.65	1.65	1.65	1.65			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	N/A	N/A	N/A	N/A			
System Flow	FM-7	3-5 LPM	4.5	4.5	4.5	4.5			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.45	1.45	1.45	1.45			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.4	1.4	1.4	1.4			
NOX Dry Air	FM-10	500-700 CCM	590	590	590	590			
<b>DAHS Checks</b>									
Check DAHS for normal operation, is system logging data?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check Alarms in DAHS.			Y	Y	Y	Y			
Check chart recorder for normal operation			Y	Y	Y	Y			
Check printer status			Y	Y	Y	Y			
Check analyzer calibration drift, Did all calibrations pass?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Is yellow "WARNING" status indicating?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Make drift adjustments and perform full hands-off calibration									
<b>REMARKS:</b>									

Mark as either Acceptable "Y", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEWS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_

Date: \_\_\_\_\_

# McGrath Peaker Generating Station

## Quality Assurance Checks

### Daily Preventive Maintenance

Parameters to Check	Tag ID	Limits	Mon 3/2/20	Tue 3/3/20	Wed 3/4/20	Thu 3/5/20	Fri	Sat	Sun
<b>Dates</b>									
Technician's Initial			JW	JW	JW	JW			
<b>Calibration Gas Pressures</b>									
O2/CO High Span, NOX Zero	SV1	>150 psi	1540	1510	1500	1460			
NOX Low Span/CO Low Span	SV2	>150 psi	430	350	320	1760			
NOX High Span, O2/CO Zero	SV3	>150 psi	430	400	380	2000			
<b>Stack Sample Line</b>									
Sample Line Temperature	TC1	250°F	250	250	250	250			
Sample NH3 Temperature -	TC2	760°F	760	760	760	760			
Sample Line Pressure/Vacuum	PI-1	6.0 "Hg	6.5	6.5	6.4	6.2			
Sample Line Pressure/Vacuum	PI-2	8.0 "Hg	5.8	5.8	5.8	5.9			
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg	6.5	6.5	6.5	6.5			
Sample Line Pressure	PI-5	8 Psi	6.0	6.0	6.0	6.1			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	Y	Y	Y	Y			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	Y	Y	Y	Y			
<b>Visual Checks</b>									
Room Enclosure Temperature	Check HV/AC controls	72 F (+/-5) F	67.5	68.5	69.5	67.5			
Moisture Sensor A/Filler	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	Y	Y	Y	Y			
Moisture Sensor B/Filler	MS-2	Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Operational Status of Condensate Drain Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Operational Status of Condensate Drain Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check LED status of Sample Cooler		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
NH3 Scrubber Drain	HV-4	Drain as needed	Y	Y	Y	Y			
Please enter readings									
<b>Analyzer Sample Flow Meter Readings</b>									
System Flow	FM-1	3-5 LPM	4.3	4.3	4.3	4.3			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.55	1.55	1.55	1.55			
NOX Analyzer	FM-3	1.2 - 1.7 LPM	1.6	1.6	1.6	1.6			
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.35	1.3	1.35	1.35			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.6	1.6	1.6	1.7			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	N/A	N/A	N/A	N/A			
System Flow	FM-7	3-5 LPM	4.5	4.5	4.5	4.5			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.45	1.45	1.45	1.45			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.4	1.4	1.4	1.4			
NOX Dry Air	FM-10	500- 700 CCM	590	580	590	580			
<b>DAHS Checks</b>									
Check DAHS for normal operation, is system logging data?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check Alarms in DAHS		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check chart recorder for normal operation		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check printer status		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check analyzer calibration drift, Did all calibrations pass?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Is yellow "WARNING" status indicating?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Make drift adjustments and perform full hands-off calibration									
<b>REMARKS:</b>									

Mark as either Acceptable "Y", Corrective action Required "X" or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shifter log book.

Reviewed By Supervisor: \_\_\_\_\_

Date: \_\_\_\_\_



# McGrath Peaker Generating Station

## Quality Assurance Checks

### Daily Preventive Maintenance

Parameters to Check		Tag ID	Limits	Mon	Tue	Wed	Thu	Fri	Sat	Sun
Technician's Initial				3/9/20	3/10/20	3/11/20	3/12/20			
Calibration Gas Pressures				JW	JW	JW	JW			
O2/CO High Span, NOX Zero		SV1	>150 psi	1320	1360	1300	1300			
NOX Low Span/CO Low Span		SV2	>150 psi	1580	1580	1550	1530			
NOX High Span, O2/CO Zero		SV3	>150 psi	1850	1930	1860	1830			
Stack Sample Line										
Sample Line Temperature		TC1	250°F	250	250	250	250			
Sample NH3 Temperature -		TC2	760°F	760	760	760	760			
Sample Line Pressure/Vacuum		PI-1	6.0 "Hg	6.9	6.5	7.4	6.6			
Sample Line Pressure/Vacuum		PI-2	8.0 "Hg	5.5	5.7	5.2	5.7			
Sample Line Pressure/Vacuum		PI-4	7.5 "Hg	6.6	6.6	6.8	6.6			
Sample Line Pressure		PI-5	8 Psi	5.9	6.0	5.9	6.0			
Verify Functionality of Sample Pump A Flow Switch		FS-1	5-7 LPM (set point)	Y	Y	Y	Y			
Verify Functionality of Sample Pump B Flow Switch		FS-2	5-7 LPM (set point)	Y	Y	Y	Y			
Visual Checks										
Room Enclosure Temperature		Check HVAC controls	72 F (+/-5) F	69.5	69.5	69.5	68.5			
Moisture Sensor A/Filler		MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	Y	Y	Y	Y			
Moisture Sensor B/Filler		MS-2		Y	Y	Y	Y			
Operational Status of Sample Pumps (2)			Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Operational Status of Condensate Drain Pumps (2)			Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check LED status of Sample Cooler			Check "Y" if ok, "X" if not	Y	Y	Y	Y			
NH3 Scrubber Drain		HV-4	Drain as needed	Y	Y	Y	Y			
Analyzer Sample Flow Meter Readings										
System Flow		FM-1	3.5 LPM	4.3	4.3	4.1	4.3			
O2 Analyzer		FM-2	1.2 - 1.7 LPM	1.55	1.55	1.5	1.55			
NOX Analyzer		FM-3	1.2 - 1.7 LPM	1.6	1.6	1.55	1.6			
NOX By-Pass		FM-4	1.2 - 1.7 LPM	1.35	1.35	1.3	1.35			
CO Analyzer		FM-5	1.2 - 1.7 LPM	1.6	1.65	1.55	1.65			
Cell Gas Flow (only during Calibration)		FM-6	> than FM-1 & FM-7	N/A	N/A	N/A	N/A			
System Flow		FM-7	3.5 LPM	4.5	4.5	4.2	4.5			
NOX/NH3 Analyzer		FM-8	1.5 LPM	1.45	1.45	1.45	1.45			
NOX/NH3 Analyzer By-Pass		FM-9	1.2 - 1.5 LPM	1.4	1.4	1.4	1.4			
NOX Dry Air		FM-10	500-700 CCM	580	590	590	590			
DAHs Checks										
Check DAHS for normal operation, is system logging data?			Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check Alarms in DAHS				Y	Y	Y	Y			
Check chart recorder for normal operation				Y	Y	Y	Y			
Check printer status				Y	Y	Y	Y			
Check analyzer calibration drift, Did all calibrations pass?			Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Is yellow "WARNING" status indicating?			Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Make drift adjustments and perform full hands-off calibration										
REMARKS:										

Mark as either Acceptable "Y" Corrective action Required "X" or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_

Date: \_\_\_\_\_

# McGrath Peaker Generating Station

## Quality Assurance Checks

### Daily Preventive Maintenance

Parameters to Check	Tag ID	Limits	Mon	Tue	Wed	Thu	Fri	Sat	Sun
<b>Technician's Initial</b>									
3/8/20 JW									
<b>Calibration Gas Pressurs</b>									
O2/CO High Span, NOX Zero	SV1	>150 psi	1320	1360	1300	1300			
NOX Low Span/CO Low Span	SV2	>150 psi	1580	1580	1550	1530			
NOX High Span O2/CO Zero	SV3	>150 psi	1850	1930	1860	1830			
<b>Stack Sample Line</b>									
Sample Line Temperature	TC1	250°F	250	250	250	250			
Sample NH3 Temperature -	TC2	760°F	760	760	760	760			
Sample Line Pressure/Vacuum	PI-1	6.0 "Hg	6.9	6.5	7.4	6.6			
Sample Line Pressure/Vacuum	PI-2	8.0 "Hg	5.5	5.7	5.2	5.7			
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg	6.6	6.6	6.8	6.8			
Sample Line Pressure	PI-5	8 Psi	5.9	6.0	5.9	6.0			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	Y	Y	Y	Y			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	Y	Y	Y	Y			
<b>Visual Checks</b>									
Room Enclosure Temperature	Check HVAC controls 72 F (+/-5) F		69.5	69.5	69.5	68.5			
Moisture Sensor A/Filler	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	Y	Y	Y	Y			
Moisture Sensor B/Filler	MS-2	Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Operational Status of Sample Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Operational Status of Condensate Drain Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check LED status of Sample Cooler		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
NH3 Scrubber Drain	HV-4	Drain as needed	Y	Y	Y	Y			
<b>Analyzer Sample Flow Meter Readings</b>									
System Flow	FM-1	3-5 LPM	4.3	4.3	4.1	4.3			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.55	1.55	1.5	1.55			
NOX Analyzer	FM-3	1.2 - 1.7 LPM	1.6	1.6	1.55	1.6			
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.35	1.35	1.3	1.35			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.6	1.65	1.55	1.65			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	N/A	N/A	N/A	N/A			
System Flow	FM-7	3-5 LPM	4.5	4.5	4.2	4.5			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.45	1.45	1.45	1.45			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.4	1.4	1.4	1.4			
NOX Dry Air	FM-10	500- 700 CCM	580	580	580	580			
<b>DAHS Checks</b>									
Check DAHS for normal operation, is system logging data?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check Alarms in DAHS.			Y	Y	Y	Y			
Check chart recorder for normal operation			Y	Y	Y	Y			
Check printer status			Y	Y	Y	Y			
Check analyzer calibration drift, Did all calibrations pass?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Is yellow "WARNING" status indicating?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Make drift adjustments and perform full hands-off calibration									
<b>REMARKS:</b>									

Mark as either Acceptable "Y", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_

Date: \_\_\_\_\_

## McGrath Peaker Generating Station Quality Assurance Checks Daily Preventive Maintenance

Parameters to Check	Tag ID	Limits	Mon 3/16/20	Tue 3/17/20	Wed 3/18/20	Thu 3/19/20	Fri	Sat	Sun
Technician's Initial									
Calibration Gas Pressures									
O2/CO High Span, NOX Zero	SV1	>150 psi	1240	1280	1300	1270			
NOX Low Span/CO Low Span	SV2	>150 psi	1470	1470	1490	1410			
NOX High Span, O2/CO Zero	SV3	>150 psi	1760	1780	1810	1790			
Stack Sample Line									
Sample Line Temperature	TC1	250°F	250	250	250	250			
Sample NH3 Temperature -	TC2	760°F	760	760	760	760			
Sample Line Pressure/Vacuum	PI-1	6.0 "Hg	6.6	6.5	6.7	6.5			
Sample Line Pressure/Vacuum	PI-2	8.0 "Hg	5.7	5.8	5.6	5.8			
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg	6.6	6.6	6.6	6.6			
Sample Line Pressure	PI-5	8 Psi	6.0	6.0	5.9	6.0			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	Y	Y	Y	Y			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	Y	Y	Y	Y			
Visual Checks									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	68.5	68.0	69.5	68.0			
Moisture Sensor A/Filter	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	Y	Y	Y	Y			
Moisture Sensor B/Filter	MS-2	Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Operational Status of Condensate Drain Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check LED status of Sample Cooler		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
NH3 Scrubber Drain	HV-4	Drain as needed	Y	Y	Y	Y			
Analyzer Sample Flow Meter Readings									
System Flow	FM-1	3-5 LPM	4.3	4.3	4.3	4.3			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.55	1.55	1.55	1.55			
NOX Analyzer	FM-3	1.2 - 1.7 LPM	1.6	1.6	1.6	1.6			
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.35	1.35	1.35	1.35			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.6	1.7	1.65	1.7			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	N/A	N/A	N/A	N/A			
System Flow	FM-7	3-5 LPM	4.5	4.5	4.5	4.5			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.45	1.45	1.45	1.45			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.4	1.4	1.4	1.4			
NOX Dry Air	FM-10	500-700 CCM	580	580	570	560			
DAHIS Checks									
Check DAHIS for normal operation, is system logging data?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check Alarms in DAHIS.			Y	Y	Y	Y			
Check chart recorder for normal operation			Y	Y	Y	Y			
Check printer status			Y	Y	Y	Y			
Check analyzer calibration drift, Did all calibrations pass?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Is yellow "WARNING" status indicating?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Make drift adjustments and perform full hands-off calibration									
REMARKS:									

Mark as either Acceptable "Y", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_

# McGrath Peaker Generating Station

## Quality Assurance Checks

### Daily Preventive Maintenance

Parameters to Check	Tag ID	Limits	Mon 3/23/20	Tue 3/24/20	Wed 3/25/20	Thu 3/26/20	Fri	Sat	Sun
Technician's Initial									
Calibration Gas Pressures									
O2/CO High Span, NOX Zero	SV1	>150 psi	1230	1210	1190	1180			
NOX Low Span/CO Low Span	SV2	>150 psi	1410	1380	1340	1280			
NOX High Span, O2/CO Zero	SV3	>150 psi	1770	1740	1700	1670			
Stack Sample Line									
Sample Line Temperature	TC1	250°F	250	250	250	250			
Sample NH3 Temperature -	TC2	760°F	760	760	760	760			
Sample Line Pressure/Vacuum	PI-1	6.0"Hg	6.4	6.5	6.5	6.5			
Sample Line Pressure/Vacuum	PI-2	8.0"Hg	5.8	5.8	5.8	5.8			
Sample Line Pressure/Vacuum	PI-4	7.5"Hg	6.6	6.6	6.5	6.6			
Sample Line Pressure	PI-5	8 Psi	6.1	6.1	6.1	6.0			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	Y	Y	Y	Y			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	Y	Y	Y	Y			
Visual Checks									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	68.5	67.5	69.5	69.0			
Moisture Sensor A/Filler	MS-1	Clean and dry, if filler shows buildup and flow levels are dropping, replace filler	Y	Y	Y	Y			
Moisture Sensor B/Filler	MS-2	Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Operational Status of Sample Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Operational Status of Condensate Drain Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check LED status of Sample Cooler		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
NH3 Scrubber Drain	HV-4	Drain as needed	Y	Y	Y	Y			
Analyzer Sample Flow Meter Readings									
System Flow	FM-1	3-5 LPM	4.3	4.3	4.1	4.3			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.55	1.55	1.55	1.55			
NOX Analyzer	FM-3	1.2 - 1.7 LPM	1.6	1.6	1.6	1.6			
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.35	1.35	1.35	1.3			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.7	1.7	1.65	1.6			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	N/A	N/A	N/A	N/A			
System Flow	FM-7	3-5 LPM	4.5	4.5	4.5	4.5			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.45	1.45	1.45	1.45			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.4	1.4	1.4	1.4			
NOX Dry Air	FM-10	500-700 CCM	650	650	650	660			
DAHS Checks									
Check DAHS for normal operation, is system logging data?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check Alarms in DAHS.		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check chart recorder for normal operation		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check printer status		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check analyzer calibration drift, Did all calibrations pass?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Is yellow "WARNING" status indicating?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Make drift adjustments and perform full hands-off calibration									
REMARKS:									

Mark as either Acceptable "Y", Corrective action Required "X", or Actual Readings, where required

Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shifter log book.

Reviewed By Supervisor: \_\_\_\_\_

Date: \_\_\_\_\_

Revised 11/17

# McGrath Peaker Generating Station

## Quality Assurance Checks

### Daily Preventive Maintenance

Parameters to Check	Tag ID	Limits	Mon 3/30/20 JW	Tue 3/31/20 JW	Wed 4/1/20 JW	Thu 4/2/20 JW	Fri	Sat	Sun
<b>Technician's Initial</b>									
<b>Calibration Gas Pressures</b>									
O2/CO High Span, NOX Zero	SV1	>150 psi	1170	1110	1090	1050			
NOX Low Span/CO Low Span	SV2	>150 psi	1280	1220	1200	1150			
NOX High Span, O2/CO Zero	SV3	>150 psi	1670	1620	1600	1560			
<b>Stack Sample Line</b>									
Sample Line Temperature	TC1	250°F	250	250	260	250			
Sample NH3 Temperature -	TC2	780°F	780	780	760	760			
Sample Line Pressure/Vacuum	PI-1	6.0 "Hg	6.3	6.4	6.5	6.6			
Sample Line Pressure/Vacuum	PI-2	8.0 "Hg	5.5	5.8	5.7	5.7			
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg	6.6	6.6	6.5	6.6			
Sample Line Pressure	PI-5	8 Psi	6.1	6.0	6.0	6.0			
Sample Line Pressure	FS-1	5-7 LPM (set point)	Y	Y	Y	Y			
Verify Functionality of Sample Pump A Flow Switch	FS-2	5-7 LPM (set point)	Y	Y	Y	Y			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	Y	Y	Y	Y			
<b>Visual Checks</b>									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	68.5	67.5	68.5	69.5			
Moisture Sensor A/Filler	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	Y	Y	Y	Y			
Moisture Sensor B/Filler	MS-2	Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Operational Status of Sample Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Operational Status of Condensate Drain Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check LED status of Sample Cooler		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
NH3 Scrubber Drain	HV-4	Drain as needed	Y	Y	Y	Y			
Please enter readings									
<b>Analyzer Sample Flow Meter Readings</b>									
System Flow	FM-1	3-5 LPM	4.0	4.3	4.3	4.3			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.55	1.55	1.55	1.55			
NOX Analyzer	FM-3	1.2 - 1.7 LPM	1.6	1.6	1.6	1.6			
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.35	1.35	1.3	1.35			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.6	1.65	1.7	1.7			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	N/A	N/A	N/A	N/A			
System Flow	FM-7	3-5 LPM	4.5	4.5	4.5	4.5			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.45	1.45	1.45	1.45			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.4	1.4	1.4	1.4			
NOX Dry Air	FM-10	500-700 CCM	660	660	660	660			
<b>DAHS Checks</b>									
Check DAHS for normal operation, Is system logging data?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check Alarms in DAHS.			Y	Y	Y	Y			
Check chart recorder for normal operation			Y	Y	Y	Y			
Check printer status			Y	Y	Y	Y			
Check analyzer calibration drift, Did all calibrations pass?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Is yellow "WARNING" status indicating?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Make drift adjustments and perform full hands-off calibration									
<b>REMARKS:</b>									

Mark as either 'Acceptable' "Y", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shaker log book.

Reviewed By Supervisor: \_\_\_\_\_

Date: \_\_\_\_\_

Revised 11/17

## McGrath Peaker Generating Station Quality Assurance Checks Daily Preventive Maintenance

Parameters to Check	Tag ID	Limits	Mon 4/6/20 JW	Tue 4/7/20 JW	Wed 4/8/20 JW	Thu 4/9/20 JW	Fri	Sat	Sun
<b>Dates</b>									
Technician's Initial									
<b>Calibration Gas Pressures</b>									
O2/CO High Span, NOX Zero	SV1	>150 psi	970	920	910	860			
NOX Low Span/CO Low Span	SV2	>150 psi	1060	940	910	870			
NOX High Span, O2/CO Zero	SV3	>150 psi	1430	1410	1400	1370			
<b>Stack Sample Line</b>									
Sample Line Temperature	TC-1	250°F	250	250	250	250			
Sample NH3 Temperature -	TC2	760°F	760	760	760	760			
Sample Line Pressure/Vacuum	PI-1	6.0 "Hg	6.6	6.4	6.5	6.5			
Sample Line Pressure/Vacuum	PI-2	8.0 "Hg	5.7	5.8	5.7	5.7			
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg	6.6	6.6	6.5	6.5			
Sample Line Pressure	PI-5	8 Psi	6.0	6.1	6.0	6.0			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	Y	Y	Y	Y			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	Y	Y	Y	Y			
<b>Visual Checks</b>									
Room Enclosure Temperature	Check HVAC controls		72 F (+/-5) F	69.5	69.0	69.5	68.0		
Moisture Sensor A/Filler	MS-1	Clean and dry, if filler shows buildup and flow levels are dropping, replace filter	Y	Y	Y	Y			
Moisture Sensor B/Filler	MS-2		Y	Y	Y	Y			
Operational Status of Sample Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Operational Status of Condensate Drain Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check LED status of Sample Cooler		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
NH3 Scrubber Drain	HV-4	Drain as needed	Y	Y	Y	Y			
<b>Analyzer Sample Flow Meter Readings</b>									
System Flow	FM-1	3-5 LPM	4.3	4.3	4.1	4.3			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.5	1.5	1.5	1.5			
NOX Analyzer	FM-3	1.2 - 1.7 LPM	1.6	1.6	1.6	1.6			
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.35	1.35	1.3	1.35			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.65	1.7	1.7	1.7			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	N/A	N/A	N/A	N/A			
System Flow	FM-7	3-5 LPM	4.5	4.5	4.5	4.5			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.45	1.45	1.45	1.45			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.4	1.4	1.4	1.4			
NOX Dry Air	FM-10	500- 700 CCM	600	600	600	600			
<b>DAHS Checks</b>									
Check DAHS for normal operation. Is system logging data?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check Alarms in DAHS.			Y	Y	Y	Y			
Check chart recorder for normal operation			Y	Y	Y	Y			
Check printer status			Y	Y	Y	Y			
Check analyzer calibration drift. Did all calibrations pass?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Is yellow "WARNING" status indicating?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Make drift adjustments and perform full hands-off calibration									
<b>REMARKS:</b>									

Mark as either Acceptable "Y", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEWS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_

Date: \_\_\_\_\_



## McGrath Peaker Generating Station Quality Assurance Checks Daily Preventive Maintenance

Parameters to Check	Tag ID	Limits	Mon	Tue	Wed	Thu	Fri	Sat	Sun
			4/13/20 JW	4/14/20 JW	4/15/20 JW	4/16/20 JW			
<b>Technician's Initial</b>									
<b>Calibration Gas Pressures</b>									
O2/CO High Span, NOX Zero	SV1	>150 psi	870	870	880	880			
NOX Low Span/CO Low Span	SV2	>150 psi	850	860	900	890			
NOX High Span, O2/CO Zero	SV3	>150 psi	1360	1360	1360	1370			
<b>Stack Sample Line</b>									
Sample Line Temperature	TC1	250°F	250	250	250	250			
Sample NH3 Temperature	TC2	760°F	780	760	760	760			
Sample Line Pressure/Vacuum	PI-1	6.0 "Hg	6.6	6.5	6.6	6.5			
Sample Line Pressure/Vacuum	PI-2	6.0 "Hg	5.8	5.8	5.7	5.7			
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg	6.5	6.6	6.5	6.6			
Sample Line Pressure	PI-5	8 Psi	6.0	6.1	6.0	6.0			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	Y	Y	Y	Y			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	Y	Y	Y	Y			
<b>Visual Checks</b>									
Room Enclose Temperature	Check HVAC controls	72 F (+/-5) F	69.5	69.5	69.0	70.0			
Moisture Sensor A/Filler	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	Y	Y	Y	Y			
Moisture Sensor B/Filler	MS-2	Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Operational Status of Condensate Drain Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check LED status of Sample Cooler		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
NH3 Scrubber Drain	HV-4	Drain as needed	Y	Y	Y	Y			
<b>Analyzer Sample Flow Meter Readings</b>									
System Flow	FM-1	3-5 LPM	4.1	4.1	4.3	4.3			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.55	1.5	1.55	1.55			
NOX Analyzer	FM-3	1.2 - 1.7 LPM	1.6	1.6	1.6	1.6			
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.3	1.3	1.35	1.35			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.65	1.65	1.6	1.6			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	N/A	N/A	N/A	N/A			
System Flow	FM-7	3-5 LPM	4.5	4.5	4.5	4.5			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.45	1.45	1.45	1.45			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.4	1.4	1.4	1.4			
NOX Dry Air	FM-10	500-700 CCM	590	590	590	590			
<b>DAHS Checks</b>									
Check DAHS for normal operation, is system logging data?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check Alarms in DAHS			Y	Y	Y	Y			
Check chart recorder for normal operation			Y	Y	Y	Y			
Check printer status			Y	Y	Y	Y			
Check analyzer calibration drift, Did all calibrations pass?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Is yellow "WARNING" status indicating?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Make drift adjustments and perform full hands-off calibration									
<b>REMARKS:</b>									

Mark as either Acceptable "Y", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator Immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_

Date: \_\_\_\_\_

# McGrath Peaker Generating Station

## Quality Assurance Checks

### Daily Preventive Maintenance

Parameters to Check	Tag ID	Limits	Mon	Tue	Wed	Thu	Fri	Sat	Sun
<b>Technician's Initial</b>									
<b>Dates</b>									
Calibration Gas Pressures			4/20/20	4/21/20	4/22/20	4/23/20			
O2/CO High Span, NOX Zero	SV1	>150 psi	820	800	790	780			
NOX Low Span/CO Low Span	SV2	>150 psi	800	790	760	770			
NOX High Span, O2/CO Zero	SV3	>150 psi	1320	1260	1210	1210			
<b>Stack Sample Line</b>									
Sample Line Temperature	TC-1	250°F	250	250	250	250			
Sample NH3 Temperature -	TC2	760°F	760	760	760	760			
Sample Line Pressure/Vacuum	P1-1	6.0 "Hg	6.5	6.5	6.6	6.6			
Sample Line Pressure/Vacuum	P1-2	8.0 "Hg	5.8	5.8	5.8	5.8			
Sample Line Pressure/Vacuum	P1-4	7.5 "Hg	6.6	6.5	6.5	6.6			
Sample Line Pressure	P1-5	8 Psi	6.0	6.0	6.0	6.0			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	Y	Y	Y	Y			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	Y	Y	Y	Y			
<b>Visual Checks</b>									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	67.5	68.5	69.0	69.0			
Moisture Sensor A/Filler	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	Y	Y	Y	Y			
Moisture Sensor B/Filler	MS-2	Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Operational Status of Sample Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Operational Status of Condensate Drain Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check LED status of Sample Cooler		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
NH3 Scrubber Drain	HV-4	Drain as needed	Y	Y	Y	Y			
<b>Analyzer Sample Flow Meter Readings</b>									
System Flow	FM-1	3-5 LPM	4.3	4.3	4.3	4.1			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.55	1.6	1.55	1.6			
NOX Analyzer	FM-3	1.2 - 1.7 LPM	1.8	1.6	1.6	1.6			
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.35	1.35	1.35	1.35			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.65	1.65	1.7	1.65			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	N/A	N/A	N/A	N/A			
System Flow	FM-7	3-5 LPM	4.5	4.5	4.5	4.5			
NOX/NH3 Analyzer	FM-8	1.3 LPM	1.45	1.45	1.45	1.45			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.4	1.4	1.4	1.4			
NOX Dry Air	FM-10	500- 700 CCM	580	580	660	650			
<b>DAHS Checks</b>									
Check DAHS for normal operation, is system logging data?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check Alarms in DAHS.			Y	Y	Y	Y			
Check chart recorder for normal operation			Y	Y	Y	Y			
Check printer status			Y	Y	Y	Y			
Check analyzer calibration drift. Did all calibrations pass?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Is yellow "WARNING" status indicating?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Make drift adjustments and perform full hands-off calibration									
<b>REMARKS:</b>									

Mark as either Acceptable "Y", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator Immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_

Date: \_\_\_\_\_



## McGrath Peaker Generating Station Quality Assurance Checks Daily Preventive Maintenance

Parameters to Check	Tag ID	Limits	Mon	Tue	Wed	Thu	Fri	Sat	Sun
<b>Technician's Initial</b>									
<b>Calibration Gas Pressures</b>									
O2/CO High Span, NOX Zero	SV1	>150 psi	720	700	680	680			
NOX Low Span/CO Low Span	SV2	>150 psi	680	680	640	680			
NOX High Span, O2/CO Zero	SV3	>150 psi	1140	1140	1120	1110			
<b>Stack Sample Line</b>									
<b>Sample Line Temperature</b>									
Sample NH3 Temperature -	TC1	250°F	250	250	250	250			
Sample Line Pressure/Vacuum	TC2	760°F	760	760	760	760			
Sample Line Pressure/Vacuum	PI-1	6.0 "Hg	6.5	6.6	6.4	6.5			
Sample Line Pressure/Vacuum	PI-2	8.0 "Hg	5.7	5.7	5.7	5.7			
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg	6.8	6.8	6.5	6.5			
Sample Line Pressure	PI-5	8 Psi	6.0	6.0	6.0	6.0			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	Y	Y	Y	Y			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	Y	Y	Y	Y			
<b>Visual Checks</b>									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	68.0	69.5	68.0	67.5			
Moisture Sensor A/Filler	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	Y	Y	Y	Y			
Moisture Sensor B/Filler	MS-2	Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Operational Status of Sample Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Operational Status of Condensate Drain Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check LED status of Sample Cooler		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
NH3 Scrubber Drain	HV-4	Drain as needed	Y	Y	Y	Y			
<b>Analyzer Sample Flow Meter Readings</b>									
Please enter readings:									
System Flow	FM-1	3-5 LPM	4.1	4.3	4.3	4.3			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.55	1.55	1.55	1.55			
NOX Analyzer	FM-3	1.2 - 1.7 LPM	1.6	1.6	1.6	1.6			
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.35	1.35	1.35	1.35			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.65	1.65	1.65	1.65			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	N/A	N/A	N/A	N/A			
System Flow	FM-7	3-5 LPM	4.5	4.5	4.5	4.5			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.45	1.45	1.45	1.45			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.4	1.4	1.4	1.4			
NOX Dry Air	FM-10	500- 700 CCM	650	650	650	650			
<b>DAHS Checks</b>									
Check DAHS for normal operation. Is system logging data?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check Alarms in DAHS.		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check chart recorder for normal operation		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check printer status		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check analyzer calibration drift. Did all calibrations pass?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Is yellow "WARNING" status indicating?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Make drift adjustments and perform full hands-off calibration									
<b>REMARKS:</b>									

Mark as either Acceptable "Y", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shaker log book.

Reviewed By Supervisor: \_\_\_\_\_

Date: \_\_\_\_\_

## McGrath Peaker Generating Station Quality Assurance Checks Daily Preventive Maintenance

Parameters to Check	Tag ID	Limits	Mon 5/4/20 JW	Tue 5/5/20 JW	Wed 5/6/20 JW	Thu 5/7/20 JW	Fri	Sat	Sun
<b>Technician's Initial</b>									
<b>Calibration Gas Pressures</b>									
O2/CO High Span, NOX Zero	SV1	>150 psi	650	620	650	620			
NOX Low Span/CO Low Span	SV2	>150 psi	620	580	760	560			
NOX High Span, O2/CO Zero	SV3	>150 psi	1110	1080	1050	1140			
<b>Stack Sample Line</b>									
Sample Line Temperature	TC1	250°F	250	250	250	250			
Sample NH3 Temperature -	TC2	760°F	760	760	760	760			
Sample Line Pressure/Vacuum	PI-1	6.0 "Hg	6.6	6.8	6.4	6.6			
Sample Line Pressure/Vacuum	PI-2	8.0 "Hg	5.7	5.6	5.7	5.7			
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg	6.5	6.5	6.5	6.6			
Sample Line Pressure	PI-5	8 Psi	6.0	5.9	6.0	6.0			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	Y	Y	Y	Y			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	Y	Y	Y	Y			
<b>Visual Checks</b>									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	69.0	70.0	68.5	67.5			
Moisture Sensor A/Filler	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	Y	Y	Y	Y			
Moisture Sensor B/Filler	MS-2		Y	Y	Y	Y			
Operational Status of Sample Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Operational Status of Condensate Drain Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check LED status of Sample Cooler		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
NH3 Scrubber Drain	HV-4	Drain as needed	Y	Y	Y	Y			
<b>Analyzer Sample Flow Meter Readings</b>									
System Flow	FM-1	3-5 LPM	4.3	4.1	4.3	4.3			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.55	1.55	1.55	1.55			
NOx Analyzer	FM-3	1.2 - 1.7 LPM	1.6	1.6	1.6	1.6			
NOx By-Pass	FM-4	1.2 - 1.7 LPM	1.35	1.35	1.35	1.35			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.65	1.65	1.65	1.6			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	N/A	N/A	N/A	N/A			
System Flow	FM-7	3-5 LPM	4.5	4.5	4.5	4.5			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.45	1.45	1.45	1.45			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.4	1.4	1.4	1.4			
NOX Dry Air	FM-10	500- 700 CCM	650	650	650	650			
<b>DAHS Checks</b>									
Check DAHS for normal operation. Is system logging data?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check Alarms in DAHS.			Y	Y	Y	Y			
Check chart recorder for normal operation			Y	Y	Y	Y			
Check printer status			Y	Y	Y	Y			
Check analyzer calibration drift. Did all calibrations pass?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Is yellow "WARNING" status indicating?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Make drift adjustments and perform full hands-off calibration									
<b>REMARKS:</b>									

Mark as either Acceptable "Y", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_

Date: \_\_\_\_\_

## McGrath Peaker Generating Station Quality Assurance Checks Daily Preventive Maintenance

Parameters to Check	Tag ID	Limite	Mon 5/11/20 JW	Tue 5/12/20 JW	Wed 5/13/20 JW	Thu 5/14/20 JW	Fri	Sat	Sun
<b>Dates</b>									
Technician's Initial									
<b>Calibration Gas Pressures</b>									
O2/CO High Span, NOX Zero	SV1	>150 psi	570	520	520	540			
NOX Low Span/CO Low Span	SV2	>150 psi	470	460	430	460			
NOX High Span, O2/CO Zero	SV3	>150 psi	990	960	940	950			
<b>Stack Sample Line</b>									
Sample Line Temperature	TC1	250°F	250	250	250	250			
Sample NH3 Temperature -	TC2	760°F	760	760	760	760			
Sample Line Pressure/Vacuum	PI-1	6.0 "Hg	6.5	6.5	6.5	6.5			
Sample Line Pressure/Vacuum	PI-2	8.0 "Hg	5.7	5.8	5.7	5.7			
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg	6.6	6.5	6.5	6.5			
Sample Line Pressure	PI-5	8 Psi	6.0	6.0	6.0	6.0			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	Y	Y	Y	Y			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	Y	Y	Y	Y			
<b>Visual Checks</b>									
Room Enclose Temperature	Check HVAC controls	72 F (+/-5) F	70.0	69.5	68.0	70.0			
Moisture Sensor A/Filler	MS-1	Clean and dry, if filler shows buildup and flow levels are dropping, replace filler.	Y	Y	Y	Y			
Moisture Sensor B/Filler	MS-2		Y	Y	Y	Y			
Operational Status of Sample Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Operational Status of Condensate Drain Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check LED status of Sample Cooler		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
NH3 Scrubber Drain	HV-4	Drain as needed	Y	Y	Y	Y			
<b>Analyzer Sample Flow Meter Readings</b>									
System Flow	FM-1	3-5 LPM	4.3	4.3	4.3	4.3			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.55	1.55	1.55	1.55			
NOx Analyzer	FM-3	1.2 - 1.7 LPM	1.6	1.6	1.6	1.6			
NOx By-Pass	FM-4	1.2 - 1.7 LPM	1.35	1.35	1.35	1.35			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.6	1.65	1.6	1.7			
Cell Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	N/A	N/A	N/A	N/A			
System Flow	FM-7	3-5 LPM	4.5	4.5	4.5	4.5			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.45	1.45	1.45	1.45			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.4	1.4	1.4	1.4			
NOX Dry Air	FM-10	500- 700 CCM	600	600	590	590			
<b>DAHS Checks</b>									
Check DAHS for normal operation, is system logging data?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check Alarms in DAHS.			Y	Y	Y	Y			
Check chart recorder for normal operation			Y	Y	Y	Y			
Check printer status			Y	Y	Y	Y			
Check analyzer calibration drift, Did all calibrations pass?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Is yellow "WARNING" status indicating?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Make drift adjustments and perform full hands-off calibration									
<b>REMARKS:</b>									

Mark as either Acceptable "Y", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shalter log book.

Reviewed By Supervisor: \_\_\_\_\_

Date: \_\_\_\_\_

## McGrath Peaker Generating Station Quality Assurance Checks Daily Preventive Maintenance

Parameters to Check	Tag ID	Limits	Mon	Tue	Wed	Thu	Fri	Sat	Sun
<b>Dates</b>									
Technician's Initial				5/26/20	5/27/20	5/28/20			
				JW	JW	JW			
<b>Calibration Gas Pressures</b>									
O2/CO High Span, NOX Zero	SV1	>150 psi		1980	1890	1890			
NOX Low Span/CO Low Span	SV2	>150 psi		1700	1640	1620			
NOX High Span, O2/CO Zero	SV3	>150 psi		890	830	820			
<b>Stack Sample Line</b>									
<b>Sample Line Temperature</b>									
Sample NH3 Temperature -	TC1	250°F		250	250	250			
Sample Line Pressure/Vacuum	TC2	760°F		760	760	760			
Sample Line Pressure/Vacuum	PI-1	6.0 "Hg		6.3	6.4	6.5			
Sample Line Pressure/Vacuum	PI-2	8.0 "Hg		5.7	5.8	5.7			
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg		6.5	6.6	6.5			
Sample Line Pressure	PI-5	8 Psi		6.0	6.1	6.0			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)		Y	Y	Y			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)		Y	Y	Y			
<b>Visual Checks</b>									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F		68.0	68.5	69.0			
Moisture Sensor A/Filler	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter		Y	Y	Y			
Moisture Sensor B/Filler	MS-2			Y	Y	Y			
Operational Status of Sample Pumps (2)		Check "Y" if ok, "X" if not		Y	Y	Y			
Operational Status of Condensate Drain Pumps (2)		Check "Y" if ok, "X" if not		Y	Y	Y			
Check LED status of Sample Cooler		Check "Y" if ok, "X" if not		Y	Y	Y			
NH3 Scrubber Drain	HV-4	Drain as needed		Y	Y	Y			
<b>Analyzer Sample Flow Meter Readings</b>									
Please enter readings									
System Flow	FM-1	3-5 LPM		4.3	4.1	4.3			
O2 Analyzer	FM-2	1.2 - 1.7 LPM		1.55	1.55	1.55			
NOX Analyzer	FM-3	1.2 - 1.7 LPM		1.6	1.6	1.6			
NOX By-Pass	FM-4	1.2 - 1.7 LPM		1.4	1.4	1.4			
CO Analyzer	FM-5	1.2 - 1.7 LPM		1.7	1.7	1.65			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7		N/A	N/A	N/A			
System Flow	FM-7	3-5 LPM		4.5	4.5	4.5			
NOX/NH3 Analyzer	FM-8	1.5 LPM		1.45	1.45	1.45			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM		1.4	1.4	1.4			
NOX Dry Air	FM-10	500- 700 CCM		590	580	550			
<b>DAHS Checks</b>									
Check DAHS for normal operation. Is system logging data?		Check "Y" if ok, "X" if not		Y	Y	Y			
Check Alarms in DAHS.				Y	Y	Y			
Check chart recorder for normal operation				Y	Y	Y			
Check printer status				Y	Y	Y			
Check analyzer calibration drift. Did all calibrations pass?		Check "Y" if ok, "X" if not		Y	Y	Y			
Is yellow "WARNING" status indicating?		Check "Y" if ok, "X" if not		Y	Y	Y			
Make drift adjustments and perform full hands-off calibration									
<b>REMARKS:</b>									

Mark as either Acceptable "Y", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_

## McGrath Peaker Generating Station Quality Assurance Checks Daily Preventive Maintenance

Parameters to Check	Tag ID	Limits	Mon	Tue	Wed	Thu	Fri	Sat	Sun
<b>Dates</b>									
Technician's Initial							5/29/20		
<b>Calibration Gas Pressures</b>									
O2/CO High Span, NOX Zero	SV1	>150 psi					1750		
NOX Low Span/CO Low Span	SV2	>150 psi					1400		
NOX High Span, O2/CO Zero	SV3	>150 psi					510		
<b>Stack Sample Line</b>									
<b>Sample Line Temperature</b>									
Sample NH3 Temperature -	TC1	250°F					250		
Sample Line Pressure/Vacuum	TC2	760°F					760		
Sample Line Pressure/Vacuum	PI-1	6.0 "Hg					6.2		
Sample Line Pressure/Vacuum	PI-2	8.0 "Hg					5.1		
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg					6.5		
Sample Line Pressure	PI-5	8 Psi					5.8		
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)					Y		
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)					Y		
<b>Visual Checks</b>									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F					68.0		
Moisture Sensor A/Filler	MS-1	Clean and dry, if filler shows buildup and flow levels are dropping, replace filler					Y		
Moisture Sensor B/Filler	MS-2	Check "Y" if ok, "X" if not					Y		
Operational Status of Sample Pumps (2)		Check "Y" if ok, "X" if not					Y		
Operational Status of Condensate Drain Pumps (2)		Check "Y" if ok, "X" if not					Y		
Check LED status of Sample Cooler		Check "Y" if ok, "X" if not					Y		
NH3 Scrubber Drain	HV-4	Drain as needed					Y		
<b>Analyzer Sample Flow Meter Readings</b>									
Please enter readings									
System Flow	FM-1	3-5 LPM					4.2		
O2 Analyzer	FM-2	1.2 - 1.7 LPM					1.5		
NOX Analyzer	FM-3	1.2 - 1.7 LPM					1.6		
NOX By-Pass	FM-4	1.2 - 1.7 LPM					1.2		
CO Analyzer	FM-5	1.2 - 1.7 LPM					1.6		
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7					N/A		
System Flow	FM-7	3-5 LPM					4.2		
NOX/NH3 Analyzer	FM-8	1.5 LPM					1.45		
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM					1.35		
NOX Dry Air	FM-10	500- 700 CCM					650		
<b>DAHS Checks</b>									
Check DAHS for normal operation. Is system logging data?		Check "Y" if ok, "X" if not					Y		
Check Alarms in DAHS.							Y		
Check chart recorder for normal operation							Y		
Check printer status							Y		
Check analyzer calibration drift. Did all calibrations pass?		Check "Y" if ok, "X" if not					Y		
Is yellow "WARNING" status indicating?		Check "Y" if ok, "X" if not					Y		
Make drift adjustments and perform full hands-off calibration							Y		
<b>REMARKS:</b>									

Mark as either Acceptable "Y", Corrective action Required "X" or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_

Date: \_\_\_\_\_

## McGrath Peaker Generating Station Quality Assurance Checks Daily Preventive Maintenance

Parameters to Check	Tag ID	Limits	Mon	Tue	Wed	Thu	Fri	Sat	Sun
<b>Dates</b>									
Technician's Initial			6/8/20	6/9/20	6/10/20	6/11/20			
<b>Calibration Gas Pressures</b>									
O2/CO High Span, NOX Zero	SV1	>150 psi	1630	1610	1590	1550			
NOX Low Span/CO Low Span	SV2	>150 psi	1330	1310	1300	1280			
NOX High Span, O2/CO Zero	SV3	>150 psi	370	310	290	270			
<b>Stack Sample Line</b>									
<b>Sample Line Temperature</b>									
Sample NH3 Temperature -	TC1	250°F	250	250	250	250			
Sample Line Pressure/Vacuum	TC2	760°F	760	760	760	760			
Sample Line Pressure/Vacuum	PI-1	6.0 "Hg	6.3	6.1	6.1	6.2			
Sample Line Pressure/Vacuum	PI-2	8.0 "Hg	5.2	5.4	5.4	5.3			
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg	6.5	6.5	6.5	6.5			
Sample Line Pressure	PI-5	8 Psi	5.7	5.8	5.8	5.8			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	Y	Y	Y	Y			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	Y	Y	Y	Y			
<b>Visual Checks</b>									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	69.5	70.0	67.5	70.0			
Moisture Sensor A/Filler	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	Y	Y	Y	Y			
Moisture Sensor B/Filler	MS-2		Y	Y	Y	Y			
Operational Status of Sample Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Operational Status of Condensate Drain Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check LED Status of Sample Cooler		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
NH3 Scrubber Drain	HV-4	Drain as needed	Y	Y	Y	Y			
<b>Analyzer Sample Flow Meter Readings</b>									
Please enter readings:									
System Flow	FM-1	3-5 LPM	4.3	4.3	4.3	4.1			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.55	1.55	1.55	1.55			
NOX Analyzer	FM-3	1.2 - 1.7 LPM	1.6	1.6	1.6	1.6			
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.2	1.2	1.2	1.2			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.5	1.55	1.55	1.55			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	N/A	N/A	N/A	N/A			
System Flow	FM-7	3-5 LPM	4.3	4.3	4.3	4.3			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.45	1.45	1.45	1.45			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.35	1.35	1.35	1.35			
NOX Dry Air	FM-10	500- 700 CCM	600	600	590	590			
<b>DAHS Checks</b>									
Check DAHS for normal operation, is system logging data?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check Alarms in DAHS.			Y	Y	Y	Y			
Check chart recorder for normal operation			Y	Y	Y	Y			
Check printer status			Y	Y	Y	Y			
Check analyzer calibration drift, Did all calibrations pass?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Is yellow "WARNING" status indicating?		Check "Y" if ok, "X" if not	Y						
Make drift adjustments and perform full hands-off calibration									
<b>REMARKS:</b>									

Mark as either Acceptable "Y", Corrective action Required "X" or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_

Date: \_\_\_\_\_

## McGrath Peaker Generating Station Quality Assurance Checks Daily Preventive Maintenance

Parameters to Check	Tag ID	Limits	Mon 6/15/20 JW	Tue 6/16/20 JW	Wed 6/17/20 JW	Thu 6/18/20 JW	Fri	Sat	Sun
<b>Technician's Initial</b>									
<b>Calibration Gas Pressures</b>									
O2/CO High Span, NOX Zero	SV1	>150 psi	1500	1470	1390	1320			
NOX Low Span/CO Low Span	SV2	>150 psi	1100	1100	1010	970			
NOX High Span, O2/CO Zero	SV3	>150 psi	2050	2020	1940	1890			
<b>Stack Sample Line</b>									
<b>Sample Line Temperature</b>									
Sample NH3 Temperature -	TC1	250°F	250	250	250	250			
Sample Line Pressure/Vacuum	TC2	760°F	760	760	760	760			
Sample Line Pressure/Vacuum	PI-1	6.0 "Hg	6.1	6.8	6.1	6.1			
Sample Line Pressure/Vacuum	PI-2	8.0 "Hg	5.2	4.7	5.1	5.2			
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg	6.5	6.5	6.5	6.5			
Sample Line Pressure	PI-5	8 Psi	5.8	5.7	5.8	5.7			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	Y	Y	Y	Y			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	Y	Y	Y	Y			
<b>Visual Checks</b>									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	67.5	68.0	68.0	67.5			
Moisture Sensor A/Filler	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	Y	Y	Y	Y			
Moisture Sensor B/Filler	MS-2	Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Operational Status of Sample Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Operational Status of Condensate Drain Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check LED Status of Sample Cooler		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
NH3 Scrubber Drain	HV-4	Drain as needed	Y	Y	Y	Y			
<b>Analyzer Sample Flow Meter Readings</b>									
Please enter readings									
System Flow	FM-1	3-5 LPM	4.2	4.0	4.1	4.1			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.55	1.45	1.55	1.55			
NOX Analyzer	FM-3	1.2 - 1.7 LPM	1.6	1.55	1.6	1.6			
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.2	1.1	1.2	1.2			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.5	1.55	1.6	1.6			
Cell Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	N/A	N/A	N/A	N/A			
System Flow	FM-7	3-5 LPM	4.2	4.2	4.2	4.3			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.4	1.4	1.4	1.4			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.35	1.35	1.35	1.35			
NOX Dry Air	FM-10	500- 700 CCM	590	590	590	590			
<b>DAHS Checks</b>									
Check DAHS for normal operation, Is system logging data?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check Alarms in DAHS.		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check chart recorder for normal operation		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check printer status		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check analyzer calibration drift, Did all calibrations pass?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Is yellow "WARNING" status indicating?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Make drift adjustments and perform full hands-off calibration									
<b>REMARKS:</b>									

Mark as either Acceptable "Y", Corrective action Required "X" or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS staker log book.

Reviewed By Supervisor: \_\_\_\_\_

Date: \_\_\_\_\_



## McGrath Peaker Generating Station Quality Assurance Checks Daily Preventive Maintenance

Parameters to Check	Tag ID	Limits	Mon 5/18/20 JW	Tue 5/19/20 JW	Wed 5/20/20 JW	Thu 5/21/20 JW	Fri	Sat	Sun
<b>Calibration Gas Pressures</b>									
O2/CO High Span, NOX Zero	SV1	>150 psi	420	400	400	410			
NOX Low Span/CO Low Span	SV2	>150 psi	310	300	290	300			
NOX High Span, O2/CO Zero	SV3	>150 psi	830	810	810	810			
<b>Stack Sample Line</b>									
Sample Line Temperature	TC1	250°F	250	250	250	250			
Sample NH3 Temperature -	TC2	760°F	760	760	760	760			
Sample Line Pressure/Vacuum	PI-1	6.0 "Hg	6.6	6.4	6.5	6.5			
Sample Line Pressure/Vacuum	PI-2	8.0 "Hg	5.7	5.8	5.8	5.7			
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg	6.8	6.5	6.5	6.5			
Sample Line Pressure	PI-5	8 Psi	6.0	6.0	6.1	6.0			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	Y	Y	Y	Y			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	Y	Y	Y	Y			
<b>Visual Checks</b>									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	68.5	68.0	69.0	69.5			
Moisture Sensor A/Filler	MS-1	Clean and dry, if filler shows buildup and flow levels are dropping, replace filler	Y	Y	Y	Y			
Moisture Sensor B/Filler	MS-2		Y	Y	Y	Y			
Operational Status of Sample Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Operational Status of Condensate Drain Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check LED status of Sample Cooler		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
NH3 Scrubber Drain	HV-4	Drain as needed	Y	Y	Y	Y			
<b>Analyzer Sample Flow Meter Readings</b>									
System Flow	FM-1	3-5 LPM	4.3	4.3	4.3	4.3			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.55	1.55	1.55	1.55			
NOX Analyzer	FM-3	1.2 - 1.7 LPM	1.6	1.6	1.6	1.6			
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.45	1.4	1.4	1.4			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.65	1.65	1.65	1.65			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	N/A	N/A	N/A	N/A			
System Flow	FM-7	3-5 LPM	4.5	4.5	4.5	4.5			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.45	1.45	1.45	1.45			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.4	1.4	1.4	1.4			
NOX Dry Air	FM-10	500- 700 CCM	590	590	590	590			
<b>DAHS Checks</b>									
Check DAHS for normal operation. Is system logging data?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check Alarms In DAHS.			Y	Y	Y	Y			
Check chart recorder for normal operation			Y	Y	Y	Y			
Check printer status			Y	Y	Y	Y			
Check analyzer calibration drift. Did all calibrations pass?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Is yellow "WARNING" status indicating?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Make drift adjustments and perform full hands-off calibration									
<b>REMARKS:</b>									

Mark as either Acceptable "Y", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_



## McGrath Peaker Generating Station Quality Assurance Checks Daily Preventive Maintenance

Parameters to Check	Tag ID	Limits	Mon 6/22/20 JW	Tue 6/23/20 JW	Wed 6/24/20 JW	Thu	Fri	Sat	Sun
<b>Calibration Gas Pressures</b>									
O2/CO High Span, NOX Zero	SV1	>150 psi	1210	1160	1120				
NOX Low Span/CO Low Span	SV2	>150 psi	820	700	690				
NOX High Span, O2/CO Zero	SV3	>150 psi	1730	1700	1670				
<b>Stack Sample Line</b>									
Sample Line Temperature	TC1	250°F	250	250	250				
Sample NH3 Temperature -	TC2	760°F	760	760	760				
Sample Line Pressure/Vacuum	PI-1	6.0 "Hg	6.3	6.9	6.3				
Sample Line Pressure/Vacuum	PI-2	8.0 "Hg	5.2	4.6	5.1				
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg	6.5	6.8	6.5				
Sample Line Pressure	PI-5	8 Psi	5.7	5.7	5.7				
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	Y	Y	Y				
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	Y	Y	Y				
<b>Visual Checks</b>									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	68.5	69.0	68.5				
Moisture Sensor A/Filler	MS-1	Clean and dry, if filler shows buildup and flow levels are dropping, replace filter.	Y	Y	Y				
Moisture Sensor B/Filler	MS-2		Y	Y	Y				
Operational Status of Sample Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y				
Operational Status of Condensate Drain Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y				
Check LED status of Sample Cooler		Check "Y" if ok, "X" if not	Y	Y	Y				
NH3 Scrubber Drain	HV-4	Drain as needed	Y	Y	Y				
<b>Analyzer Sample Flow Meter Readings</b>									
System Flow	FM-1	3-5 LPM	4.3	4.0	4.1				
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.55	1.45	1.55				
NOX Analyzer	FM-3	1.2 - 1.7 LPM	1.6	1.55	1.6				
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.1	1.1	1.2				
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.55	1.55	1.5				
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	N/A	N/A	N/A				
System Flow	FM-7	3-5 LPM	4.2	4.2	4.3				
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.4	1.4	1.45				
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.35	1.35	1.35				
NOX Dry Air	FM-10	500- 700 CCM	640	640	640				
<b>DAHS Checks</b>									
Check DAHS for normal operation. Is system logging data?		Check "Y" if ok, "X" if not	Y	Y	Y				
Check Alarms in DAHS.			Y	Y	Y				
Check chart recorder for normal operation			Y	Y	Y				
Check printer status			Y	Y	Y				
Check analyzer calibration drift. Did all calibrations pass?		Check "Y" if ok, "X" if not	Y	Y	Y				
Is yellow "WARNING" status indicating?		Check "Y" if ok, "X" if not	Y	Y	Y				
Make drift adjustments and perform full hands-off calibration									
<b>REMARKS:</b>									

Mark as either Acceptable "Y", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_

Date: \_\_\_\_\_

## McGrath Peaker Generating Station Quality Assurance Checks Daily Preventive Maintenance

Parameters to Check	Tag ID	Limits	Mon 6/29/20 JW	Tue 6/30/20 JW	Wed 7/1/20 JW	Thu	Fri	Sat	Sun
<b>Technician's Initial</b>									
<b>Calibration Gas Pressures</b>									
O2/CO High Span, NOX Zero	SV1	>150 psi	1100	1100	1110				
NOX Low Span/CO Low Span	SV2	>150 psi	640	640	630				
NOX High Span, O2/CO Zero	SV3	>150 psi	1660	1640	1630				
<b>Stack Sample Line</b>									
<b>Sample Line Temperature</b>									
Sample NH3 Temperature -	TC1	250°F	250	250	250				
Sample Line Pressure/Vacuum	TC2	760°F	760	760	760				
Sample Line Pressure/Vacuum	PI-1	6.0 "Hg	6.4	6.5	6.4				
Sample Line Pressure/Vacuum	PI-2	8.0 "Hg	5.2	5.2	5.1				
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg	6.5	6.5	6.5				
Sample Line Pressure	PI-5	8 Psi	5.6	5.7	5.9				
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	Y	Y	Y				
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	Y	Y	Y				
<b>Visual Checks</b>									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	69.0	70.0	70.0				
Moisture Sensor A/Filler	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	Y	Y	Y				
Moisture Sensor B/Filler	MS-2	Check "Y" if ok, "X" if not	Y	Y	Y				
Operational Status of Sample Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y				
Operational Status of Condensate Drain Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y				
Check LED status of Sample Cooler		Check "Y" if ok, "X" if not	Y	Y	Y				
NH3 Scrubber Drain	HV-4	Drain as needed	Y	Y	Y				
<b>Analyzer Sample Flow Meter Readings</b>									
System Flow	FM-1	3-5 LPM	4.3	4.3	4.3				
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.55	1.55	1.55				
NOX Analyzer	FM-3	1.2 - 1.7 LPM	1.6	1.6	1.6				
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.2	1.2	1.2				
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.5	1.5	1.5				
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	N/A	N/A	N/A				
System Flow	FM-7	3-5 LPM	4.3	4.3	4.3				
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.45	1.45	1.45				
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.35	1.35	1.35				
NOX Dry Air	FM-10	500- 700 CCM	650	650	650				
<b>DAHS Checks</b>									
Check DAHS for normal operation. Is system logging data?		Check "Y" if ok, "X" if not	Y	Y	Y				
Check Alarms in DAHS.			Y	Y	Y				
Check chart recorder for normal operation			Y	Y	Y				
Check printer status			Y	Y	Y				
Check analyzer calibration drift. Did all calibrations pass?		Check "Y" if ok, "X" if not	Y	Y	Y				
Is yellow "WARNING" status indicating?		Check "Y" if ok, "X" if not	Y	Y	Y				
Make drift adjustments and perform full hands-off calibration									
<b>REMARKS:</b>									

Mark as either Acceptable "Y", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_

Date: \_\_\_\_\_

## McGrath Peaker Generating Station Quality Assurance Checks Daily Preventive Maintenance

Parameters to Check	Tag ID	Limits	Mon 7/6/20 JW	Tue 7/7/20 JW	Wed	Thu 7/9/20 JW	Fri	Sat	Sun
<b>Technician's Initial</b>									
<b>Calibration Gas Pressures</b>									
O2/CO High Span, NOX Zero	SV1	>150 psi	1110	1050		1030			
NOX Low Span/CO Low Span	SV2	>150 psi	610	580		540			
NOX High Span, O2/CO Zero	SV3	>150 psi	1630	1580		1560			
<b>Stack Sample Line</b>									
Sample Line Temperature	TC1	250°F	250	250		250			
Sample NH3 Temperature -	TC2	760°F	760	760		760			
Sample Line Pressure/Vacuum	PI-1	6.0 "Hg	6.5	6.4		7.4			
Sample Line Pressure/Vacuum	PI-2	6.0 "Hg	5.2	5.2		4.6			
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg	6.5	6.5		6.8			
Sample Line Pressure	PI-5	8 psi	5.8	5.7		5.6			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	Y	Y		Y			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	Y	Y		Y			
<b>Visual Checks</b>									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	69.0	69.5		71.0			
Moisture Sensor A/Filler	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	Y	Y		Y			
Moisture Sensor B/Filler	MS-2		Y	Y		Y			
Operational Status of Sample Pumps (2)		Check "Y" if ok, "X" if not	Y	Y		Y			
Operational Status of Condensate Drain Pumps (2)		Check "Y" if ok, "X" if not	Y	Y		Y			
Check LED status of Sample Cooler		Check "Y" if ok, "X" if not	Y	Y		Y			
NH3 Scrubber Drain	HV-4	Drain as needed	Y	Y		Y			
Please enter readings									
<b>Analyzer Sample Flow Meter Readings</b>									
System Flow	FM-1	3-5 LPM	4.3	4.1		4.0			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.55	1.55		1.45			
NOx Analyzer	FM-3	1.2 - 1.7 LPM	1.6	1.6		1.55			
NOx By-Pass	FM-4	1.2 - 1.7 LPM	1.2	1.2		1.1			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.55	1.55		1.55			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	N/A	N/A		N/A			
System Flow	FM-7	3-5 LPM	4.3	4.3		4.2			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.45	1.45		1.45			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.35	1.35		1.35			
NOX Dry Air	FM-10	500-700 CCM	590	590		590			
<b>DAHS Checks</b>									
Check DAHS for normal operation. Is system logging data?		Check "Y" if ok, "X" if not	Y	Y		Y			
Check Alarms in DAHS.			Y	Y		Y			
Check chat recorder for normal operation			Y	Y		Y			
Check printer status			Y	Y		Y			
Check analyzer calibration drift. Did all calibrations pass?		Check "Y" if ok, "X" if not	Y	Y		Y			
Is yellow "WARNING" status indicating?		Check "Y" if ok, "X" if not	Y	Y		Y			
Make drift adjustments and perform full hands-off calibration				Y					
<b>REMARKS:</b>									

Mark as either Acceptable "Y", Corrective action Required "X" or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_

Date: \_\_\_\_\_

## McGrath Peaker Generating Station Quality Assurance Checks Daily Preventive Maintenance

Parameters to Check	Tag ID	Limits	Mon 7/13/20	Tue 7/14/20	Wed 7/15/20	Thu 7/16/20	Fri	Sat	Sun
Technician's Initial									
Calibration Gas Pressures									
O2/CO High Span, NOX Zero	SV1	>150 psi	1040	1010	1070	1020			
NOX Low Span/CO Low Span	SV2	>150 psi	540	530	530	500			
NOX High Span, O2/CO Zero	SV3	>150 psi	1560	1560	1560	1560			
Stack Sample Line									
Sample Line Temperature	TC-1	250°F	250	250	250	250			
Sample NH3 Temperature -	TC2	760°F	760	760	760	760			
Sample Line Pressure/Vacuum	PI-1	6.0 "Hg	6.5	6.5	6.5	6.3			
Sample Line Pressure/Vacuum	PI-2	8.0 "Hg	5.2	5.2	5.2	5.3			
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg	6.5	6.5	6.5	6.5			
Sample Line Pressure	PI-5	8 psi	5.8	5.7	5.8	5.8			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	Y	Y	Y	Y			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	Y	Y	Y	Y			
Visual Checks									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	71.0	69.0	70.5	68.5			
Moisture Sensor A/Filler	MS-1	Clean and dry, if filler shows buildup and flow levels are dropping, replace filler	Y	Y	Y	Y			
Moisture Sensor B/Filler	MS-2	Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Operational Status of Sample Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Operational Status of Condensate Drain Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check LED status of Sample Cooler		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
NH3 Scrubber Drain	HV-4	Drain as needed	Y	Y	Y	Y			
Analyzer Sample Flow Meter Readings									
System Flow	FM-1	3-5 LPM	4.3	4.3	4.3	4.3			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.55	1.55	1.55	1.55			
NOX Analyzer	FM-3	1.2 - 1.7 LPM	1.8	1.6	1.6	1.6			
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.2	1.2	1.2	1.2			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.55	1.5	1.5	1.5			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	N/A	N/A	N/A	N/A			
System Flow	FM-7	3-5 LPM	4.3	4.4	4.4	4.4			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.45	1.45	1.45	1.45			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.35	1.35	1.35	1.35			
NOX Dry Air	FM-10	500- 700 CCM	580	580	580	580			
DAHS Checks									
Check DAHS for normal operation. Is system logging data?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check Alarms in DAHS.		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check chart recorder for normal operation		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check printer status		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check analyzer calibration drift. Did all calibrations pass?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Is yellow "WARNING" status indicating?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Make drift adjustments and perform full hands-off calibration									
REMARKS:									

Mark as either Acceptable "Y", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_

Date: \_\_\_\_\_

## McGrath Peaker Generating Station Quality Assurance Checks Daily Preventive Maintenance

Parameters to Check	Tag ID	Limits	Mon 7/20/20 JW	Tue 7/21/20 JW	Wed 7/22/20 JW	Thu 7/23/20 JW	Fri	Sat	Sun
<b>Technician's Initial</b>									
<b>Calibration Gas Pressures</b>									
O2/CO High Span, NOX Zero	SV1	>150 psi	950	940	950	960			
NOX Low Span/CO Low Span	SV2	>150 psi	420	410	400	1890			
NOX High Span, O2/CO Zero	SV3	>150 psi	1330	1510	1490	1470			
<b>Stack Sample Line</b>									
<b>Sample Line Temperature</b>									
Sample NH3 Temperature -	TC1	250°F	250	250	250	250			
Sample Line Pressure/Vacuum	TC2	760°F	780	760	780	780			
Sample Line Pressure/Vacuum	PI-1	6.0 "Hg	7.4	6.8	6.5	6.5			
Sample Line Pressure/Vacuum	PI-2	8.0 "Hg	4.7	5.1	5.2	5.2			
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg	6.8	6.5	6.5	6.5			
Sample Line Pressure	PI-5	8 psi	5.8	5.6	5.8	5.8			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	Y	Y	Y	Y			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	Y	Y	Y	Y			
<b>Visual Checks</b>									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	70.5	70.5	71.0	68.5			
Moisture Sensor A/FILTER	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	Y	Y	Y	Y			
Moisture Sensor B/FILTER	MS-2	Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Operational Status of Sample Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Operational Status of Condensate Drain Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check LED status of Sample Cooler		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
NH3 Scrubber Drain	HV-4	Drain as needed	Y	Y	Y	Y			
<b>Analyzer Sample Flow Meter Readings</b>									
Please enter readings									
System Flow	FM-1	3-5 LPM	4.0	4.3	4.3	4.3			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.45	1.55	1.55	1.55			
NOX Analyzer	FM-3	1.2 - 1.7 LPM	1.55	1.6	1.6	1.6			
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.1	1.2	1.2	1.2			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.5	1.5	1.55	1.5			
CO Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	N/A	N/A	N/A	N/A			
System Flow	FM-7	3-5 LPM	4.3	4.3	4.3	4.3			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.45	1.45	1.45	1.45			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.35	1.35	1.35	1.35			
NOX Dry Air	FM-10	500- 700 CCM	640	640	640	640			
<b>DAHS Checks</b>									
Check DAHS for normal operation. Is system logging data?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check Alarms in DAHS.			Y	Y	Y	Y			
Check chart recorder for normal operation			Y	Y	Y	Y			
Check printer status			Y	Y	Y	Y			
Check analyzer calibration drift. Did all calibrations pass?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Is yellow "WARNING" status indicating?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Make drift adjustments and perform full hands-off calibration									
<b>REMARKS:</b>									

Mark as either Acceptable "Y", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator Immediately. Corrective Action performed shall be logged in the CEMS shaker log book.

Reviewed By Supervisor: \_\_\_\_\_

Date: \_\_\_\_\_

## McGrath Peaker Generating Station Quality Assurance Checks Daily Preventive Maintenance

Parameters to Check	Tag ID	Limits	Mon	Tue	Wed	Thu	Fri	Sat	Sun
<b>Dates</b>						7/30/20			
Technician's Initial						JW			
<b>Calibration Gas Pressures</b>									
O2/CO High Span, NOX Zero	SV1	>150 psi				860			
NOX Low Span/CO Low Span	SV2	>150 psi				1730			
NOX High Span, O2/CO Zero	SV3	>150 psi				1440			
<b>Stack Sample Line</b>									
Sample Line Temperature	TC1	250°F				250			
Sample NH3 Temperature -	TC2	760°F				760			
Sample Line Pressure/Vacuum	PI-1	6.0 "Hg				6.4			
Sample Line Pressure/Vacuum	PI-2	8.0 "Hg				5.3			
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg				6.5			
Sample Line Pressure	PI-5	8 psi				5.8			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)				Y			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)				Y			
<b>Visual Checks</b>									
Room Enclose Temperature	Check HVAC controls	72 F (+/-5) F				69.0			
Moisture Sensor A/Filler	MS-1	Clean and dry, if filler shows buildup and flow levels are dropping, replace filler				Y			
Moisture Sensor B/Filler	MS-2					Y			
Operational Status of Sample Pumps (2)		Check "Y" if ok, "X" if not				Y			
Operational Status of Condensate Drain Pumps (2)		Check "Y" if ok, "X" if not				Y			
Check LED status of Sample Cooler		Check "Y" if ok, "X" if not				Y			
NH3 Scrubber Drain	HV-4	Drain as needed				Y			
<b>Analyzer Sample Flow Meter Readings</b>									
Please enter readings									
System Flow	FM-1	3-5 LPM				4.3			
O2 Analyzer	FM-2	1.2 - 1.7 LPM				1.55			
NOX Analyzer	FM-3	1.2 - 1.7 LPM				1.6			
NOX By-Pass	FM-4	1.2 - 1.7 LPM				1.2			
CO Analyzer	FM-5	1.2 - 1.7 LPM				1.5			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7				N/A			
System Flow	FM-7	3-5 LPM				4.3			
NOX/NH3 Analyzer	FM-8	1.5 LPM				1.45			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM				1.35			
NOX Dry Air	FM-10	500- 700 CCM				650			
<b>DAHS Checks</b>									
Check DAHS for normal operation, Is system logging data?		Check "Y" if ok, "X" if not				Y			
Check Alarms in DAHS						Y			
Check chart recorder for normal operation						Y			
Check printer status						Y			
Check analyzer calibration drift. Did all calibrations pass?		Check "Y" if ok, "X" if not				Y			
Is yellow "WARNING" status indicating?		Check "Y" if ok, "X" if not				Y			
Make drift adjustments and perform full hands-off calibration									
<b>REMARKS:</b>									

Mark as either Acceptable "Y", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shaker log book.

Reviewed By Supervisor: \_\_\_\_\_

Date: \_\_\_\_\_

# McGrath Peaker Generating Station

## Quality Assurance Checks

### Daily Preventive Maintenance

Parameters to Check	Tag ID	Limits	Mon 8/3/20 JW	Tue 8/4/20 JW	Wed 8/5/20 JW	Thu 8/6/20 JW	Fri	Sat	Sun
<b>Dates</b>									
Technician's Initial									
<b>Calibration Gas Pressures</b>									
O2/CO High Span, NOX Zero	SV1	>150 psi	830	820	810	810			
NOX Low Span/CO Low Span	SV2	>150 psi	1670	1620	1620	1620			
NOX High Span, O2/CO Zero	SV3	>150 psi	1410	1370	1380	1380			
<b>Stack Sample Line</b>									
<b>Sample Line Temperature</b>									
Sample NH3 Temperature -	TC1	250°F	280	280	280	280			
Sample Line Pressure/Vacuum	TC2	760°F	760	760	760	760			
Sample Line Pressure/Vacuum	PI-1	6.0 "Hg	6.5	6.4	6.6	6.5			
Sample Line Pressure/Vacuum	PI-2	8.0 "Hg	5.3	5.3	5.2	5.2			
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg	6.5	6.5	6.5	6.5			
Sample Line Pressure	PI-5	8 Psi	5.8	5.7	5.8	5.8			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	Y	Y	Y	Y			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	Y	Y	Y	Y			
<b>Visual Checks</b>									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	69.0	69.0	70.5	69.0			
Moisture Sensor A/Filler	MS-1	Clean and dry, if filler shows buildup and flow levels are dropping, replace filler	Y	Y	Y	Y			
Moisture Sensor B/Filler	MS-2		Y	Y	Y	Y			
Operational Status of Sample Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Operational Status of Condensate Drain Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check LED status of Sample Cooler		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
NH3 Scrubber Drain	HV-4	Drain as needed	Y	Y	Y	Y			
<b>Analyzer Sample Flow Meter Readings</b>									
Please enter readings									
System Flow	FM-1	3-5 LPM	4.3	4.3	4.3	4.3			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.55	1.55	1.55	1.55			
NOX Analyzer	FM-3	1.2 - 1.7 LPM	1.6	1.6	1.6	1.6			
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.2	1.2	1.2	1.2			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.5	1.5	1.5	1.5			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	N/A	N/A	N/A	N/A			
System Flow	FM-7	3-5 LPM	4.3	4.3	4.3	4.3			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.45	1.45	1.45	1.45			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.35	1.35	1.35	1.35			
NOX Dry Air	FM-10	500- 700 CCM	580	580	580	580			
<b>DAHS Checks</b>									
Check DAHS for normal operation. Is system logging data?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check Alarms in DAHS.			Y	Y	Y	Y			
Check chart recorder for normal operation			Y	Y	Y	Y			
Check printer status			Y	Y	Y	Y			
Check analyzer calibration drift. Did all calibrations pass?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Is yellow "VARIABLE" status indicating?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Make drift adjustments and perform full hands-off calibration									
<b>REMARKS:</b>									

Mark as either Acceptable "Y", Corrective action Required "X" or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shaker log book.

Reviewed By Supervisor: \_\_\_\_\_

Date: \_\_\_\_\_



# McGrath Peaker Generating Station

## Quality Assurance Checks

### Daily Preventive Maintenance

Parameters to Check	Tag ID	Limits	Mon	Tue	Wed	Thu	Fri	Sat	Sun
			8/10/20 JW	8/11/20 JW	8/12/20 JW	8/13/20 JW			
<b>Dates</b>									
Technician's Initial									
<b>Calibration Gas Pressures</b>									
O2/CO High Span, NOX Zero	SV1	>150 psi	800	800	810	780			
NOX Low Span/CO Low Span	SV2	>150 psi	1590	1580	1560	1520			
NOX High Span, O2/CO Zero	SV3	>150 psi	1360	1360	1360	1260			
<b>Stack Sample Line</b>									
Sample Line Temperature	TC1	250°F	250	250	250	250			
Sample NH3 Temperature -	TC2	760°F	760	760	760	760			
Sample Line Pressure/Vacuum	P1-1	6.0 "Hg	6.6	6.5	6.4	6.6			
Sample Line Pressure/Vacuum	P1-2	8.0 "Hg	5.3	5.3	5.3	5.2			
Sample Line Pressure/Vacuum	P1-4	7.5 "Hg	6.5	6.5	6.5	6.6			
Sample Line Pressure	P1-5	8 Psi	5.7	5.8	5.8	5.8			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	Y	Y	Y	Y			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	Y	Y	Y	Y			
<b>Visual Checks</b>									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	69.5	68.5	69.0	70.5			
Moisture Sensor A/Filter	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	Y	Y	Y	Y			
Moisture Sensor B/Filter	MS-2		Y	Y	Y	Y			
Operational Status of Sample Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Operational Status of Condensate Drain Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check LED status of Sample Cooler		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
NH3 Scrubber Drain	HV-4	Drain as needed	Y	Y	Y	Y			
<b>Analyzer Sample Flow Meter Readings</b>									
System Flow	FM-1	3-5 LPM	4.3	4.3	4.3	4.1			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.55	1.55	1.55	1.55			
NOX Analyzer	FM-3	1.2 - 1.7 LPM	1.6	1.6	1.6	1.6			
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.2	1.2	1.2	1.2			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.5	1.5	1.5	1.6			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	N/A	N/A	N/A	N/A			
System Flow	FM-7	3-5 LPM	4.3	4.3	4.3	4.3			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.45	1.45	1.45	1.45			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.35	1.35	1.35	1.35			
NOX Dry Air	FM-10	500- 700 CCM	570	570	570	570			
<b>DAHS Checks</b>									
Check DAHS for normal operation, is system logging data?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check Alarms in DAHS.			Y	Y	Y	Y			
Check chart recorder for normal operation			Y	Y	Y	Y			
Check printer status			Y	Y	Y	Y			
Check analyzer calibration drift, Did all calibrations pass?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Is yellow "WARNING" status indicating?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Make drift adjustments and perform full hands-off calibration									
<b>REMARKS:</b>									

Mark as either Acceptable "Y", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator Immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_

Date: \_\_\_\_\_



# McGrath Peaker Generating Station

## Quality Assurance Checks

### Daily Preventive Maintenance

Parameters to Check	Tag ID	Limits	Mon 8/17/20	Tue 8/18/20	Wed 8/19/20	Thu 8/20/20	Fri	Sat	Sun
<b>Dates</b>									
Technician's Initial			JW	JW	JW	JW			
<b>Calibration Gas Pressures</b>									
O2/CO High Span, NOX Zero	SV1	>150 psi	780	710	710	710			
NOX Low Span/CO Low Span	SV2	>150 psi	1450	1380	1380	1380			
NOX High Span, O2/CO Zero	SV3	>150 psi	1280	1190	1190	1190			
<b>Stack Sample Line</b>									
Sample Line Temperature	TC1	250°F	250	250	250	250			
Sample NH3 Temperature -	TC2	760°F	760	760	760	760			
Sample Line Pressure/Vacuum	PI-1	6.0 "Hg	7.2	6.6	6.6	6.6			
Sample Line Pressure/Vacuum	PI-2	8.0 "Hg	4.6	5.2	5.1	5.1			
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg	6.6	6.5	6.5	6.5			
Sample Line Pressure	PI-5	8 Psi	5.7	5.8	5.8	5.8			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	Y	Y	Y	Y			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	Y	Y	Y	Y			
<b>Visual Checks</b>									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	70.5	68.5	70.0	70.0			
Moisture Sensor A/Filter	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	Y	Y	Y	Y			
Moisture Sensor B/Filter	MS-2		Y	Y	Y	Y			
Operational Status of Sample Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Operational Status of Condensate Drain Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check LED status of Sample Cooler		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
NH3 Scrubber Drain	HV-4	Drain as needed	Y	Y	Y	Y			
<b>Analyzer Sample Flow Meter Readings</b>									
System Flow	FM-1	3-5 LPM	4.1	4.3	4.3	4.3			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.5	1.55	1.55	1.55			
NOx Analyzer	FM-3	1.2 - 1.7 LPM	1.55	1.6	1.6	1.6			
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.2	1.2	1.2	1.2			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.55	1.6	1.6	1.6			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	N/A	N/A	N/A	N/A			
System Flow	FM-7	3-5 LPM	4.0	4.3	4.3	4.3			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.45	1.45	1.45	1.45			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.35	1.35	1.35	1.35			
NOX Dry Air	FM-10	500-700 CCM	590	580	560	640			
<b>DAHS Checks</b>									
Check DAHS for normal operation. Is system logging data?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check Alarms in DAHS.			Y	Y	Y	Y			
Check chart recorder for normal operation			Y	Y	Y	Y			
Check printer status			Y	Y	Y	Y			
Check analyzer calibration drift. Did all calibrations pass?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Is yellow "WARNING" status indicating?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Make drift adjustments and perform full hands-off calibration									
<b>REMARKS:</b>									

Mark as either Acceptable "Y", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shaker log book.

Reviewed By Supervisor: \_\_\_\_\_

Date: \_\_\_\_\_

# McGrath Peaker Generating Station

## Quality Assurance Checks

### Daily Preventive Maintenance

Parameters to Check		Tag ID	Limits	Mon	Tue	Wed	Thu	Fri	Sat	Sun
Technician's Initial										
Calibration Gas Pressures										
O2/CO High Span, NOX Zero	SV1	>150 psi	660	610	600					
NOX Low Span/CO Low Span	SV2	>150 psi	1300	1240	1230					
NOX High Span, O2/CO Zero	SV3	>150 psi	1160	1120	1110					
Stack Sample Line										
Sample Line Temperature	TC1	250°F	250	250	250					
Sample NH3 Temperature -	TC2	760°F	760	760	760					
Sample Line Pressure/Vacuum	PI-1	6.0 "Hg	6.6	6.6	6.9					
Sample Line Pressure/Vacuum	PI-2	8.0 "Hg	5.1	5.1	5.0					
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg	6.6	6.6	6.6					
Sample Line Pressure	PI-5	8 Psi	5.7	5.7	5.6					
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	Y	Y	Y					
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	Y	Y	Y					
Visual Checks										
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	71.0	70.5	71.0					
Moisture Sensor A/Filler	MS-1	Clean and dry, if filler shows buildup and flow levels are dropping, replace filler	Y	Y	Y					
Moisture Sensor B/Filler	MS-2	Check "Y" if ok, "X" if not	Y	Y	Y					
Operational Status of Sample Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y					
Operational Status of Condensate Drain Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y					
Check LED status of Sample Cooler		Check "Y" if ok, "X" if not	Y	Y	Y					
NH3 Scrubber Drain	HV-4	Drain as needed	Y	Y	Y					
Analyzer Sample Flow Meter Readings										
System Flow	FM-1	3.5 LPM	4.3	4.3	4.3					
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.55	1.55	1.55					
NOX Analyzer	FM-3	1.2 - 1.7 LPM	1.6	1.6	1.6					
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.2	1.2	1.2					
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.6	1.65	1.65					
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	N/A	N/A	N/A					
System Flow	FM-7	3.5 LPM	4.3	4.3	4.3					
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.45	1.45	1.45					
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.35	1.35	1.35					
NOX Dry Air	FM-10	500- 700 CCM	640	640	640					
DAHS Checks										
Check DAHS for normal operation. Is system logging data?		Check "Y" if ok, "X" if not	Y	Y	Y					
Check Alarms in DAHS.			Y	Y	Y					
Check chart recorder for normal operation			Y	Y	Y					
Check printer status			Y	Y	Y					
Check analyzer calibration drift. Did all calibrations pass?		Check "Y" if ok, "X" if not	Y	Y	Y					
Is yellow "WARNING" status indicating?		Check "Y" if ok, "X" if not	Y	Y	Y					
Make drift adjustments and perform full hands-off calibration										
REMARKS:										

Mark as either Acceptable "Y", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shaker log book.

Reviewed By Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_

# McGrath Peaker Generating Station

## Quality Assurance Checks

### Daily Preventive Maintenance

Parameters to Check	Tag ID	Limits	Mon	Tue	Wed	Thu	Fri	Sat	Sun
<b>Dates</b>									
Technician's Initial			6/31/20	9/1/20	9/2/20	9/3/20			
<b>Calibration Gas Pressures</b>									
O2/CO High Span, NOX Zero	SV1	>150 psi	550	550	570	530			
NOX Low Span/CO Low Span	SV2	>150 psi	1190	1150	1160	1110			
NOX High Span, O2/CO Zero	SV3	>150 psi	1100	1100	1100	1010			
<b>Stack Sample Line</b>									
Sample Line Temperature	TC1	250°F	250	250	250	250			
Sample NH3 Temperature -	TC2	760°F	760	760	760	760			
Sample Line Pressure/Vacuum	P1-1	6.0 "Hg	6.5	6.6	6.6	6.6			
Sample Line Pressure/Vacuum	P1-2	8.0 "Hg	5.2	5.2	5.2	5.2			
Sample Line Pressure/Vacuum	P1-4	7.5 "Hg	6.5	6.5	6.5	6.5			
Sample Line Pressure	P1-5	8 Psi	5.8	5.8	5.8	5.8			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	Y	Y	Y	Y			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	Y	Y	Y	Y			
<b>Visual Checks</b>									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	69.0	69.5	69.5	69.5			
Moisture Sensor A/Filter	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	Y	Y	Y	Y			
Moisture Sensor B/Filter	MS-2	Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Operational Status of Sample Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Operational Status of Condensate Drain Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check LED status of Sample Cooler		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
NH3 Scrubber Drain	HV-4	Drain as needed	Y	Y	Y	Y			
<b>Analyzer Sample Flow Meter Readings</b>									
System Flow	FM-1	3-5 LPM	4.3	4.3	4.3	4.3			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.55	1.55	1.55	1.55			
NOX Analyzer	FM-3	1.2 - 1.7 LPM	1.6	1.6	1.6	1.6			
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.2	1.2	1.2	1.2			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.65	1.65	1.6	1.65			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	N/A	N/A	N/A	N/A			
System Flow	FM-7	3-5 LPM	4.3	4.3	4.3	4.3			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.45	1.45	1.45	1.45			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.35	1.4	1.4	1.4			
NOX Dry Air	FM-10	500- 700 CCM	640	640	600	590			
<b>DAHS Checks</b>									
Check DAHS for normal operation. Is system logging data?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check Alarms in DAHS.			Y	Y	Y	Y			
Check chart recorder for normal operation			Y	Y	Y	Y			
Check printer status			Y	Y	Y	Y			
Check analyzer calibration drift. Did all calibrations pass?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Is yellow "WARNING" status indicating?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Make drift adjustments and perform full hands-off calibration						Y			
<b>REMARKS:</b>									
Please enter readings:									

Mark as either Acceptable "Y" Corrective action Required "X" or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_

Date: \_\_\_\_\_

# McGrath Peaker Generating Station

## Quality Assurance Checks

### Daily Preventive Maintenance

Parameters to Check	Tag ID	Limits	Mon	Tue	Wed	Thu	Fri	Sat	Sun
<b>Technician's Initial</b>									
<b>Calibration Gas Pressures</b>									
O2/CO High Span, NOX Zero	SV1	>150 psi		400	400	400			
NOX Low Span/CO Low Span	SV2	>150 psi		980	950	910			
NOX High Span, O2/CO Zero	SV3	>150 psi		830	830	820			
<b>Stack Sample Line</b>									
Sample Line Temperature	TC1	250°F		250	250	250			
Sample NH3 Temperature -	TC2	760°F		760	780	760			
Sample Line Pressure/Vacuum	P1-1	6.0 "Hg		6.8	6.5	6.5			
Sample Line Pressure/Vacuum	P1-2	8.0 "Hg		5.1	5.2	5.4			
Sample Line Pressure/Vacuum	P1-4	7.5 "Hg		6.5	6.5	6.5			
Sample Line Pressure	P1-5	8 psi		5.6	5.7	5.8			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)		Y	Y	Y			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)		Y	Y	Y			
<b>Visual Checks</b>									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F		69.5	69.0	68.0			
Moisture Sensor A/Filler	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter		Y	Y	Y			
Moisture Sensor B/Filler	MS-2			Y	Y	Y			
Operational Status of Sample Pumps (2)		Check "Y" if ok, "X" if not		Y	Y	Y			
Operational Status of Condensate Drain Pumps (2)		Check "Y" if ok, "X" if not		Y	Y	Y			
Check LED status of Sample Cooler		Check "Y" if ok, "X" if not		Y	Y	Y			
NH3 Scrubber Drain	HV-4	Drain as needed		Y	Y	Y			
<b>Analyzer Sample Flow Meter Readings</b>									
System Flow	FM-1	3-5 LPM		4.3	4.3	4.3			
O2 Analyzer	FM-2	1.2 - 1.7 LPM		1.55	1.55	1.55			
NOX Analyzer	FM-3	1.2 - 1.7 LPM		1.6	1.6	1.6			
NOX By-Pass	FM-4	1.2 - 1.7 LPM		1.2	1.2	1.2			
CO Analyzer	FM-5	1.2 - 1.7 LPM		1.65	1.65	1.6			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7		N/A	N/A	N/A			
System Flow	FM-7	3-5 LPM		4.3	4.3	4.3			
NOX/NH3 Analyzer	FM-8	1.5 LPM		1.45	1.45	1.45			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM		1.4	1.4	1.4			
NOX Dry Air	FM-10	500-700 CCM		560	560	560			
<b>DAHS Checks</b>									
Check DAHS for normal operation. Is system logging data?		Check "Y" if ok, "X" if not		Y	Y	Y			
Check Alarms in DAHS.				Y	Y	Y			
Check chart recorder for normal operation				Y	Y	Y			
Check printer status				Y	Y	Y			
Check analyzer calibration drift. Did all calibrations pass?		Check "Y" if ok, "X" if not		Y	Y	Y			
Is yellow "WARNING" status indicating?		Check "Y" if ok, "X" if not		Y	Y	Y			
Make drift adjustments and perform full hands-off calibration									
<b>REMARKS:</b>									

Mark as either Acceptable "Y", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shaker log book.

Reviewed By Supervisor: \_\_\_\_\_

Date: \_\_\_\_\_

# McGrath Peaker Generating Station

## Quality Assurance Checks

### Daily Preventive Maintenance

Parameters to Check	Tag ID	Limits	Mon	Tue	Wed	Thu	Fri	Sat	Sun
<b>Dates</b>									
Technician's Initial			9/14/20 JW	9/15/20 JW	9/16/20 JW	9/17/20 JW			
<b>Calibration Gas Pressures</b>									
O2/CO High Span, NOX Zero	SV1	>150 psi	370	2030	1910	1820			
NOX Low Span/CO Low Span	SV2	>150 psi	890	820	780	730			
NOX High Span, O2/CO Zero	SV3	>150 psi	810	800	670	630			
<b>Stack Sample Line</b>									
Sample Line Temperature	TC1	250°F	250	250	250	250			
Sample NH3 Temperature -	TC2	760°F	760	760	760	760			
Sample Line Pressure/Vacuum	PI-1	6.0 "Hg	6.8	6.4	6.6	6.7			
Sample Line Pressure/Vacuum	PI-2	6.0 "Hg	5.3	5.4	5.2	5.2			
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg	6.5	6.5	6.5	6.5			
Sample Line Pressure	PI-5	8 Psi	5.8	5.8	5.8	5.7			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	Y	Y	Y	Y			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	Y	Y	Y	Y			
<b>Visual Checks</b>									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	68.5	69.0	69.5	71.0			
Moisture Sensor A/Filler	MS-1	Clean and dry, if filter shows buildup and flow levels are dropping, replace filter	Y	Y	Y	Y			
Moisture Sensor B/Filler	MS-2	Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Operational Status of Sample Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Operational Status of Condensate Drain Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check LED status of Sample Cooler		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
NH3 Scrubber Drain	HV-4	Drain as needed	Y	Y	Y	Y			
<b>Analyzer Sample Flow Meter Readings</b>									
System Flow	FM-1	3-5 LPM	4.3	4.3	4.3	4.1			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.55	1.55	1.55	1.55			
NOx Analyzer	FM-3	1.2 - 1.7 LPM	1.6	1.6	1.6	1.6			
NOx By-Pass	FM-4	1.2 - 1.7 LPM	1.2	1.2	1.2	1.2			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.65	1.65	1.65	1.65			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	N/A	N/A	N/A	N/A			
System Flow	FM-7	3-5 LPM	4.3	4.3	4.3	4.3			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.45	1.45	1.45	1.45			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.4	1.4	1.4	1.4			
NOX Dry Air	FM-10	500- 700 CCM	550	550	630	630			
<b>DAHS Checks</b>									
Check DAHS for normal operation. Is system logging data?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check Alarms In DAHS.			Y	Y	Y	Y			
Check chart recorder for normal operation			Y	Y	Y	Y			
Check printer status			Y	Y	Y	Y			
Check analyzer calibration drift. Did all calibrations pass?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Is yellow "WARNING" status indicating?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Make drift adjustments and perform full hands-off calibration			Y	Y	Y	Y			
<b>REMARKS:</b>									
Please enter readings									

Mark as either Acceptable "Y", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shelter log book.

Reviewed By Supervisor: \_\_\_\_\_

Date: \_\_\_\_\_

# McGrath Peaker Generating Station

## Quality Assurance Checks

### Daily Preventive Maintenance

Parameters to Check	Tag ID	Limits	Mon	Tue	Wed	Thu	Fri	Sat	Sun
<b>Technician's Initial</b>									
Calibration Gas Pressures									
O2/CO High Span, NOX Zero	SV1	>150 psi	1740	1840	1880	1840			
NOX Low Span/CO Low Span	SV2	>150 psi	680	630	610	520			
NOX High Span, O2/CO Zero	SV3	>150 psi	610	610	530	490			
<b>Stack Sample Line</b>									
Sample Line Temperature -	TC1	260°F	250	250	250	250			
Sample NH3 Temperature	TC2	760°F	760	760	760	760			
Sample Line Pressure/Vacuum	PI-1	6.0 "Hg	6.7	6.5	6.6	6.5			
Sample Line Pressure/Vacuum	PI-2	8.0 "Hg	5.3	5.3	5.3	5.4			
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg	6.5	6.5	6.5	6.5			
Sample Line Pressure	PI-5	8 Psi	5.8	5.9	5.8	5.9			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	Y	Y	Y	Y			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	Y	Y	Y	Y			
<b>Visual Checks</b>									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	70.5	69.0	71.0	68.5			
Moisture Sensor A/Filler	MS-1	Clean and dry, if filler shows buildup and flow levels are dropping, replace filler	Y	Y	Y	Y			
Moisture Sensor B/Filler	MS-2	Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Operational Status of Sample Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Operational Status of Condensate Drain Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check LED status of Sample Cooler		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
NH3 Scrubber Drain	HV-4	Drain as needed	Y	Y	Y	Y			
<b>Analyzer Sample Flow Meter Readings</b>									
System Flow	FM-1	3-5 LPM	4.3	4.3	4.3	4.3			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.55	1.55	1.55	1.55			
NOX Analyzer	FM-3	1.2 - 1.7 LPM	1.65	1.6	1.6	1.65			
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.2	1.2	1.2	1.2			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.65	1.65	1.65	1.65			
Cell Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	N/A	N/A	N/A	N/A			
System Flow	FM-7	3-5 LPM	4.3	4.3	4.3	4.3			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.45	1.45	1.45	1.45			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.4	1.4	1.4	1.4			
NOX Dry Air	FM-10	500- 700 CCM	630	630	630	640			
<b>DAHS Checks</b>									
Check DAHS for normal operation. Is system logging data?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check Alarms in DAHS.			Y	Y	Y	Y			
Check chart recorder for normal operation			Y	Y	Y	Y			
Check printer status			Y	Y	Y	Y			
Check analyzer calibration drift. Did all calibrations pass?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Is yellow "WARNING" status indicating?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Make drift adjustments and perform full hands-off calibration			Y			Y			
<b>REMARKS:</b>									

Mark as either Acceptable "Y", Corrective action Required "X" or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shaker log book.

Reviewed By Supervisor: \_\_\_\_\_

Date: \_\_\_\_\_

# McGrath Peaker Generating Station

## Quality Assurance Checks

### Daily Preventive Maintenance

Parameters to Check	Tag ID	Limits	Mon 9/28/20	Tue 9/29/20	Wed 9/30/20	Thu 10/1/20	Fri	Sat	Sun
Technician's Initial									
Calibration Gas Pressures									
O2/CO High Span, NOX Zero	SV1	>150 psi	1790	1780	1720	1820			
NOX Low Span/CO Low Span	SV2	>150 psi	560	530	510	580			
NOX High Span, O2/CO Zero	SV3	>150 psi	490	480	440	430			
Stack Sample Line									
Sample Line Temperature	TC1	250°F	250	250	250	250			
Sample NH3 Temperature -	TC2	760°F	760	760	760	760			
Sample Line Pressure/Vacuum	PI-1	6.0 "Hg	6.5	6.4	6.7	6.5			
Sample Line Pressure/Vacuum	PI-2	8.0 "Hg	5.4	5.4	5.2	5.2			
Sample Line Pressure/Vacuum	PI-4	7.5 "Hg	6.5	6.5	6.5	6.5			
Sample Line Pressure	PI-5	8 psi	5.7	5.9	5.7	5.8			
Verify Functionality of Sample Pump A Flow Switch	FS-1	5-7 LPM (set point)	Y	Y	Y	Y			
Verify Functionality of Sample Pump B Flow Switch	FS-2	5-7 LPM (set point)	Y	Y	Y	Y			
Visual Checks									
Room Enclosure Temperature	Check HVAC controls	72 F (+/-5) F	69.5	68.5	71.0	69.5			
Moisture Sensor A/Filler	MS-1	Clean and dry, if filler shows buildup and flow levels are dropping, replace filler	Y	Y	Y	Y			
Moisture Sensor B/Filler	MS-2	Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Operational Status of Sample Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Operational Status of Condensate Drain Pumps (2)		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check LED status of Sample Cooler		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
NH3 Scrubber Drain	HV-4	Drain as needed	Y	Y	Y	Y			
Analyzer Sample Flow Meter Readings									
System Flow	FM-1	3-5 LPM	4.3	4.3	4.1	4.1			
O2 Analyzer	FM-2	1.2 - 1.7 LPM	1.55	1.55	1.55	1.55			
NOX Analyzer	FM-3	1.2 - 1.7 LPM	1.65	1.6	1.6	1.6			
NOX By-Pass	FM-4	1.2 - 1.7 LPM	1.2	1.2	1.2	1.2			
CO Analyzer	FM-5	1.2 - 1.7 LPM	1.65	1.65	1.65	1.6			
Cal Gas Flow (only during Calibration)	FM-6	> than FM-1 & FM-7	N/A	N/A	N/A	N/A			
System Flow	FM-7	3-5 LPM	4.3	4.3	4.3	4.3			
NOX/NH3 Analyzer	FM-8	1.5 LPM	1.45	1.45	1.45	1.45			
NOX/NH3 Analyzer By-Pass	FM-9	1.2 - 1.5 LPM	1.4	1.4	1.4	1.4			
NOX Dry Air	FM-10	500- 700 CCM	580	580	580	580			
DAHS Checks									
Check DAHS for normal operation. Is system logging data?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Check Alarms In DAHS.			Y	Y	Y	Y			
Check chart recorder for normal operation			Y	Y	Y	Y			
Check printer status			Y	Y	Y	Y			
Check analyzer calibration drift. Did all calibrations pass?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Is yellow "WARNING" status indicating?		Check "Y" if ok, "X" if not	Y	Y	Y	Y			
Make drift adjustments and perform full hands-off calibration									
REMARKS:									

Mark as either Acceptable "Y", Corrective action Required "X", or Actual Readings, where required  
 Note: All deficiencies must be reported to the Control Operator immediately. Corrective Action performed shall be logged in the CEMS shaker log book.

Reviewed By Supervisor: \_\_\_\_\_

Date: \_\_\_\_\_