



**Ormond Beach Power, LLC**  
Ormond Beach Generating Station  
6635 S. Edison Drive  
Oxnard, CA 93033

February 6, 2025

Mr. Steve Bova  
**Ventura County Air Pollution Control District**  
669 County Square Drive  
Ventura, CA 93003

**RE: 2024 Title V Annual Compliance Certification**  
**Ormond Beach Power, LLC**  
**Ormond Beach Generating Station**  
**Permit No. 00065**

Dear Mr. Bova:

Ormond Beach Power, LLC is submitting the 2024 Title V Annual Compliance Certification Report for the Ormond Beach Generating Station (Federal Operating Permit No. 00065, permit term October 16, 2019, to December 31, 2023) located in Oxnard, CA.

Please find enclosed VCAPCD Signature Cover Form - Certification by Responsible Official, Permit Attachment Form and supporting documents. These documents serve as the annual certification for the period January 01, 2024, through December 31, 2024, and the deviation report for the period January 01, 2024, through December 31, 2024.

If you have any questions or require additional information, please do not hesitate to contact me at (805) 341-6167 or roger.kahle@genon.com.

Sincerely,  
**Ormond Beach Generating Station**

Roger Kahle  
Environmental Specialist

cc: Ms. Roshni Brahmbhatt  
Enforcement & Compliance Enforcement Division  
EPA Region 9  
75 Hawthorne Street  
San Francisco, CA 94105

Enclosures

RECEIVED  
VENTURA COUNTY  
A.P.C.D.  
2025 FEB 13 PM 11:29



Ventura County  
Air Pollution  
Control District

**ANNUAL COMPLIANCE CERTIFICATION  
SIGNATURE COVER FORM**

TV Permit # 00065

A copy of each Annual Compliance Certification shall be submitted to EPA, Region 9, at the following address:

Ms. Roshni Brahmhatt  
Enforcement & Compliance Enforcement Division  
EPA Region 9  
75 Hawthorne Street  
San Francisco, CA 94105


RECEIVED  
VENTURA REGION 9  
A.P.C.D.  
2025 FEB 13 PM 4:03

**Confidentiality**

All information in a Part 70 permit compliance certification is public information. The Part 70 permit is also public information.

**Certification by Responsible Official**

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in this compliance certification are true, accurate, and complete.

<p>Signature and Title of Responsible Official:</p>  <p>Title: Plant Manager</p>	<p>Date:</p> <p><u>2-13-2025</u></p>
---	--------------------------------------

<p>Time Period Covered by Compliance Certification</p> <p><u>01</u> / <u>01</u> / <u>24</u> (MM/DD/YY) to <u>12</u> / <u>31</u> / <u>24</u> (MM/DD/YY)</p>
--



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01/01/24 (MM/DD/YY) to 12/31/24 (MM/DD/YY)

Ormond Beach Generating Station

<p>A. Attachment # or Permit Condition #: Attachment 59N1, Condition #1</p>	<p>D. Frequency of monitoring:</p> <p>Continuous</p>
<p>B. Description: NOx Emission Limit</p> <p>Condition 1a – Certified CEMS data demonstrates that there have been no exceedances of the 0.10 lbs/NMW-hr limit.</p> <p>Condition 1b – Ormond Beach is prohibited from burning fuel oil in these units. None was burned during the compliance certification time period.</p> <p>Condition 1c – Ormond Beach is prohibited from burning mixed fuel oil/natural gas in these units. None was burned during the compliance certification time period.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: CEMs Records and Emission Calculations</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 59N1, Condition #2</p>	<p>D. Frequency of monitoring:</p> <p>Continuous</p>
<p>B. Description: Oil Burned During Force Majeure</p> <p>Ormond Beach Generating Station is only permitted to burn natural gas in its boilers.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Fuel Usage Logs</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 59N1, Condition #3</p>	<p>D. Frequency of monitoring:</p> <p>Continuous</p>
<p>B. Description: NH3 Emissions</p> <p>The Annual Ammonia Slip test for Unit 1 was conducted on June 11, 2024 and the average ammonia slip result was 1.3 ppm @ 3% O<sub>2</sub>, which is within the 10 ppmv limit.</p> <p>No Annual Ammonia Slip test was required for Unit 2 due to insufficient quarterly operating hours.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable BAAQMD method ST-1B dated 01/20/1982</p>
<p>C. Method of monitoring: Source Testing</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01/01/24 (MM/DD/YY) to 12/31/24 (MM/DD/YY)

Ormond Beach Generating Station

<p>A. Attachment # or Permit Condition #: Attachment 59N1, Condition #4</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Cold Start-up waiver for NOx and NH3 Emission Limits The Unit 1 and Unit 2 cold start log is documented and maintained on site. Plant records indicate that no cold start-up lasted more than 20 hours, nor have any excess NOx emissions lasted longer than a cold start-up procedure.</p>	<p>Continuous</p>
<p>C. Method of monitoring: CEMs Records and Operator Logs</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u>  Y  </u></p> <p>G. Compliance Status? (C or I): <u>  C  </u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>  N  </u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 59N1, Condition #5</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: NOx lbs/NMW-Hr Condition 5a - CEMs are used to monitor and calculate the NOx emission rate. Condition 5b - The megawatt metering calibration test was performed on 12/28/2024 Condition 5c - The hourly lb/NMW-hr NOx is measured according to the procedures in 40 CFR 75.10(d)(1). Condition 5d - The documents are retained at the plant and available for District review.</p>	<p>Continuous</p>
<p>C. Method of monitoring: CEMs Records, physical inspection, and Emission Calculations</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u>  Y  </u></p> <p>G. Compliance Status? (C or I): <u>  C  </u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>  N  </u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 59N1, Conditions #6 &amp; #7</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Hourly Recordkeeping The Station maintains operational records as detailed in Conditions 6 and 7. Such records are provided to the District every quarter and made available to the District upon request.</p>	<p>Continuous</p>
<p>C. Method of monitoring: CEMs Records and Operator Logs</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u>  Y  </u></p> <p>G. Compliance Status? (C or I): <u>  C  </u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>  N  </u></p> <p>*If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01/01/24 (MM/DD/YY) to 12/31/24 (MM/DD/YY)  
Ormond Beach Generating Station

<p>A. Attachment # or Permit Condition #: Attachment 59N3, Condition #1</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: NOx Limits (Aux Boilers) 0.040 lbs/MMBTU There were no Auxiliary Boiler exceedances in 2024.</p>	<p>Continuous</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: CEMs Records and Emission Calculations</p>	<p>F. Currently in Compliance? (Y or N): <u>  Y  </u></p> <p>G. Compliance Status? (C or I): <u>  C  </u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>  N  </u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 59N3, Condition #2</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Cold Start-up, NOx Emission Limits The North Auxiliary Boiler cold starts and South Auxiliary Boiler cold starts are logged and maintained on site during the compliance period. These units are subject to a 4-hour NOx emission exemption period.</p>	<p>Continuous</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: CEMs Records and Operator Logs</p>	<p>F. Currently in Compliance? (Y or N): <u>  Y  </u></p> <p>G. Compliance Status? (C or I): <u>  C  </u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>  N  </u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 59N3, Condition #3</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: NOx Limits (Aux Boilers) calculation method Hourly natural gas emissions figures are calculated as required by this permit condition.</p>	<p>Continuous</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: CEMs Records and Emission Calculations</p>	<p>F. Currently in Compliance? (Y or N): <u>  Y  </u></p> <p>G. Compliance Status? (C or I): <u>  C  </u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>  N  </u></p> <p>*If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01/01/24 (MM/DD/YY) to 12/31/24 (MM/DD/YY)  
Ormond Beach Generating Station

<p>A. Attachment # or Permit Condition #: Attachment 59N3, Conditions #4 - #5</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Record keeping Daily and hourly records are maintained as required.</p>	<p>Continuous</p>
<p>C. Method of monitoring: CEMS Records and Operator Logs</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u> Y </u></p> <p>G. Compliance Status? (C or I): <u> C </u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u> N </u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 74.9N7 , Conditions #1 - #4</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Stationary Internal Combustion Engines Condition 1 - Hourly operating records verify compliance with the 50 hour annual limit. Condition 2 - A non-resettable elapsed hour meter is operated on the unit. Condition 3 - The Cummins model NTA 855-G5 emergency generator is located in the emergency generator building next to (south of) the administration building. Condition 4 - Calendar year hours of maintenance and operation are reported by Feb 15.</p>	<p>Periodic</p>
<p>C. Method of monitoring: Maintenance and Operating Logs</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u> Y </u></p> <p>G. Compliance Status? (C or I): <u> C </u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u> N </u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment ATCM Engine N2, Conditions #1 - #3</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Fuel Use and Operation Recordkeeping Condition 1 - Only CARB Diesel Fuel is used at the facility Condition 2 - Maintenance and testing operation of the emergency generator is limited to 20 hr/yr and is logged monthly Condition 3 - Records of operation and fuel purchased (type and quantity) are maintained on site.</p>	<p>Periodic</p>
<p>C. Method of monitoring: Purchase Records and Operation Log</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u> Y </u></p> <p>G. Compliance Status? (C or I): <u> C </u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u> N </u></p> <p>*If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01/01/24 (MM/DD/YY) to 12/31/24 (MM/DD/YY)

Ormond Beach Generating Station

<p>A. Attachment # or Permit Condition #: Attachment RICE MACT, Conditions #1 - #2</p>	<p>D. Frequency of monitoring:  Periodic</p>
<p>B. Description: Maintenance and Operation Recordkeeping Condition 1 – Engines inspected, serviced and oil changed annually or every 500 hours Condition 2 – Operated according to manufacturer specifications</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Generator Service Report</p>	<p>F. Currently in Compliance? (Y or N): <u>  Y  </u> G. Compliance Status? (C or I): <u>  C  </u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>  N  </u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment RICE MACT, Conditions #3 - #9</p>	<p>D. Frequency of monitoring:  Continuous</p>
<p>B. Description: Operation Recordkeeping Condition 3 – The engine is equipped with a non-resettable timer Condition 4 – Engine idle time is restricted to less than 30 minutes per event Condition 5-9 – Operation is limited to less than the 100 hours and in compliance with 40 CFR part 63, Subpart ZZZZ (RICE MACT).</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Maintenance and Operation Log</p>	<p>F. Currently in Compliance? (Y or N): <u>  Y  </u> G. Compliance Status? (C or I): <u>  C  </u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>  N  </u> *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 103N1-65, Conditions #1 - #3</p>	<p>D. Frequency of monitoring:  Continuous</p>
<p>B. Description: Continuous Monitoring Systems Conditions 1, 2 – A CEMS system is installed on Unit 1 and Unit 2. The CEMS system is operated and maintained at the station and meets the requirements of Rule 103.A.1 and 103.C.1. Condition 3 - Monitored violations are reported to the District within 96 hours of each occurrence pursuant with Rule 103.B.1.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: CEMs Inspection, Maintenance, Testing, and Reporting Records</p>	<p>F. Currently in Compliance? (Y or N): <u>  Y  </u> G. Compliance Status? (C or I): <u>  C  </u> H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>  N  </u> *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01/01/24 (MM/DD/YY) to 12/31/24 (MM/DD/YY)

Ormond Beach Generating Station

<p>A. Attachment # or Permit Condition #: Attachment 103N1-65, Conditions #4 - #6</p>	<p>D. Frequency of monitoring:</p> <p style="text-align: center;">Continuous</p>
<p>B. Description: Continuous Monitoring Systems</p> <p>Condition 4 – Permanent CEMS records are maintained as required.</p> <p>Condition 5 – Data is reduced according to Appendix F of 40 CFR Part 75.</p> <p>Condition 6 - CEMS and excess emission reports are submitted to the District quarterly.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: CEMs Inspection, Maintenance, Testing, and Reporting Records</p>	<p>F. Currently in Compliance? (Y or N): <u>  Y  </u></p> <p>G. Compliance Status? (C or I): <u>  C  </u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>  N  </u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 103N3-65, Conditions #1 - #3</p>	<p>D. Frequency of monitoring:</p> <p style="text-align: center;">Continuous</p>
<p>B. Description: Continuous Monitoring Systems</p> <p>Conditions 1, 2 – A CEMS system is installed on AUX-N and AUX-S. The CEMS system is operated and maintained at the station and meets the requirements of Rule 103.A.3 and 103.C.3.</p> <p>Condition 3 – Monitored violations are reported to the District within 96 hours of each occurrence pursuant with Rule 103.B.1.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: CEMs Inspection, Maintenance, Testing, and Reporting Records</p>	<p>F. Currently in Compliance? (Y or N): <u>  Y  </u></p> <p>G. Compliance Status? (C or I): <u>  C  </u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>  N  </u></p> <p>*If yes, attach Deviation Summary Form</p>





## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01/01/24 (MM/DD/YY) to 12/31/24 (MM/DD/YY)

Ormond Beach Generating Station

<p>A. Attachment # or Permit Condition #: Attachment 103N3-65, Conditions #4 - #6</p>	<p>D. Frequency of monitoring:</p> <p>Continuous</p>
<p>B. Description: Continuous Monitoring Systems</p> <p>Condition 4 – Permanent CEMS records are maintained as required.</p> <p>Condition 5 – Data is reduced as required by the condition.</p> <p>Condition 6 - CEMS and excess emission reports are submitted to the District quarterly.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p>N/A</p>
<p>C. Method of monitoring: CEMs Inspection, Maintenance, Testing, and Reporting Records</p>	<p>F. Currently in Compliance? (Y or N): <u>  Y  </u></p> <p>G. Compliance Status? (C or I): <u>  C  </u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>  N  </u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: PO00065PC1-231, Conditions #1 - #2</p>	<p>D. Frequency of monitoring:</p> <p>Continuous</p>
<p>B. Description: General Recordkeeping Requirements and Solvent Cleaning Additional Requirements</p> <p>Condition 1 - Monthly record-keeping of permitted throughput and consumption are maintained on-site.</p> <p>Condition 2 - Ormond Beach only uses cleaning products in non-refillable aerosol cans (Rule F.6) and &lt;160 oz. per day, &lt;25g/liter of ROC or SCAQMD Clean Air Solvents . Records are maintained on-site.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p>N/A</p>
<p>C. Method of monitoring: Rules 26 and 29 Fuel Throughput/Consumption and Rule 29 Solvent Usage Records</p>	<p>F. Currently in Compliance? (Y or N): <u>  Y  </u></p> <p>G. Compliance Status? (C or I): <u>  C  </u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>  N  </u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: PO00065PC2, Conditions #1 - #2, #3 - #4, #5</p>	<p>D. Frequency of monitoring:</p> <p>Continuous</p>
<p>B. Description: Rule 26 Permitted Throughput and Consumption Limit for Unit 1 and 2, Aux. Boilers and Rule 29 Natural Gas Only Requirement</p> <p>Conditions 1, 2 - Monthly and rolling 12-month records are maintained on-site.</p> <p>Conditions 3, 4 - Units 1 and 2 and the north and south auxiliary boilers only fire natural gas.</p> <p>Condition 5 - Emissions and fuel records and source test reports are maintained on-site.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p>N/A</p>
<p>C. Method of monitoring: Fuel Usage, Emission Records, and Test Reports</p>	<p>F. Currently in Compliance? (Y or N): <u>  Y  </u></p> <p>G. Compliance Status? (C or I): <u>  C  </u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>  N  </u></p> <p>*If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01/01/24 (MM/DD/YY) to 12/31/24 (MM/DD/YY)

Ormond Beach Generating Station

<p>A. Attachment # or Permit Condition #: Attachment 50, Conditions #1 – #4</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Opacity Limitations</p> <p>Method 9 opacity readings were done on the following sources during the compliance period; records are attached verifying no visible emissions</p> <p>Main Units Auxiliary Boilers Emergency Generator</p>	<p>Periodic</p>
<p>C. Method of monitoring: Routine Visual Surveillance and Certification Records</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u>  Y  </u></p> <p>G. Compliance Status? (C or I): <u>  C  </u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>  N  </u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 54.B.1, Conditions #1 - #3</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Sulfur Compounds</p> <p>Compliance with Rule 64 ensures compliance with this rule based on District analysis. Compliance is assured because only PUC-regulated natural gas is combusted at the facility.</p>	<p>Annually</p>
<p>C. Method of monitoring: Natural Gas Analyses for Sulfur</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u>  Y  </u></p> <p>G. Compliance Status? (C or I): <u>  C  </u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>  N  </u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 54.B.2, Conditions #1 - #4</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Sulfur Compounds Ground Level</p> <p>Units 1, 2, and the auxiliary boilers burn PUC-quality natural gas. A fuel sulfur sample analysis is conducted annually to ensure compliance. Laboratory analysis of natural gas sample dated June 24, 2024 confirms compliance.</p>	<p>Annually</p>
<p>C. Method of monitoring: Recordkeeping, Natural Gas Analyses for Sulfur and Modeling Demonstration</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u>  Y  </u></p> <p>G. Compliance Status? (C or I): <u>  C  </u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>  N  </u></p> <p>*If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01/01/24 (MM/DD/YY) to 12/31/24 (MM/DD/YY)

Ormond Beach Generating Station

<p>A. Attachment # or Permit Condition #: Attachment 55, Conditions #1 - #7</p>	<p>D. Frequency of monitoring:</p> <p>Periodic</p>
<p>B. Description: Fugitive Dust</p> <p>There are no operations, disturbed surface areas, or man-made conditions subject to Rule 55.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: On-site Operations Review - Permit Condition Not Currently Applicable</p>	<p>F. Currently in Compliance? (Y or N): <u>  Y  </u></p> <p>G. Compliance Status? (C or I): <u>  C  </u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>  N  </u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 57.1, Conditions #1 - #3</p>	<p>D. Frequency of monitoring:</p> <p>Continuous</p>
<p>B. Description: Particulate Emissions from Fuel Burning Equipment</p> <p>Periodic Monitoring not required. District Rule 57.B analysis dated 12/03/97 is sufficient to certify compliance.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Rule 57.B District Analysis</p>	<p>F. Currently in Compliance? (Y or N): <u>  Y  </u></p> <p>G. Compliance Status? (C or I): <u>  C  </u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>  N  </u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 64.B.1, Conditions #1 - #4</p>	<p>D. Frequency of monitoring:</p> <p>Continuous</p>
<p>B. Description: Sulfur Content of Gaseous Fuels</p> <p>Only PUC-regulated Natural Gas is combusted at this facility. Records are available on site.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Natural Gas Analyses for Sulfur</p>	<p>F. Currently in Compliance? (Y or N): <u>  Y  </u></p> <p>G. Compliance Status? (C or I): <u>  C  </u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>  N  </u></p> <p>*If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01/01/24 (MM/DD/YY) to 12/31/24 (MM/DD/YY)

Ormond Beach Generating Station

<p>A. Attachment # or Permit Condition #: Attachment 64.B.2, Conditions #1 - #3</p>	<p>D. Frequency of monitoring:</p> <p>Continuous</p>
<p>B. Description: Sulfur Content of Liquid Fuel</p> <p>The site uses CARB-approved diesel exclusively in the emergency generator. Gasoline and diesel purchase records are maintained onsite for District review; delivery records are available for confirming use of CARB-certified diesel fuels. Gasoline is purchased from a local gasoline station.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p>N/A</p>
<p>C. Method of monitoring: CARB Diesel Fuel Delivery Records</p>	<p>F. Currently in Compliance? (Y or N): <u>  Y  </u></p> <p>G. Compliance Status? (C or I): <u>  C  </u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>  N  </u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 74.6, Conditions #1 - #15</p>	<p>D. Frequency of monitoring:</p> <p>Continuous</p>
<p>B. Description: Surface Cleaning and Degreasing</p> <p>Regulated cleaning products used at Ormond Beach are dispensed in non-refillable aerosol cans. Records are maintained onsite.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p>N/A</p>
<p>C. Method of monitoring: Routine surveillance of Solvent Usage and Activity Records</p>	<p>F. Currently in Compliance? (Y or N): <u>  Y  </u></p> <p>G. Compliance Status? (C or I): <u>  C  </u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>  N  </u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 74.11.1, Conditions #1 - #4</p>	<p>D. Frequency of monitoring:</p> <p>N/A</p>
<p>B. Description: Large Water Heaters and Small Boilers</p> <p>Only electric water heaters are used at the site and no small boilers exist at the facility, consequently, Rule 74.11.1 is not applicable.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p>N/A</p>
<p>C. Method of monitoring: Equipment Design Record Review - Permit Condition Not Currently Applicable</p>	<p>F. Currently in Compliance? (Y or N): <u>  Y  </u></p> <p>G. Compliance Status? (C or I): <u>  C  </u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>  N  </u></p> <p>*If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01/01/24 (MM/DD/YY) to 12/31/24 (MM/DD/YY)

Ormond Beach Generating Station

<p>A. Attachment # or Permit Condition #: Attachment 74.22, Conditions #1 - #3</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Natural gas Fired Fan-type Central Furnaces</p> <p>No natural gas-fired fan-type central furnaces, to which this attachment applies, exist at the facility, compliance with the requirements is not required.</p>	<p>N/A</p>
<p>C. Method of monitoring: Equipment Design Record Review - Permit Condition Not Currently Applicable</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p>N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 74.1, Conditions #1 - #7</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Abrasive Blasting</p> <p>Bead blast was replaced with a Zero Emissions enclosed blast unit in October 2014 - Permit Condition Not Currently Applicable</p>	<p>N/A</p>
<p>C. Method of monitoring: Onsite Operations Review - Permit Condition Not Currently Applicable</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p>N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 74.2, Conditions #1 - #6</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Architectural Coatings</p> <p>Facility maintains records of paints used and VOC content for District review. Contractors who maintain an Architectural Coating Permit are employed for coating and the contractor maintains their usage and VOC records for District review in accordance with their permit.</p>	<p>Continuous</p>
<p>C. Method of monitoring: Routine Surveillance of GenOn Paint Usage and Activity Records. Contractor maintains their own permit with the District</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p>N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01/01/24 (MM/DD/YY) to 12/31/24 (MM/DD/YY) Ormond Beach Generating Station

<p>A. Attachment # or Permit Condition #: Attachment 74.29N3, Conditions #1 - #14</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Soil Decontamination Operations No soil remediation has taken place at the Ormond Beach Generating Station.</p>	<p>N/A</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Onsite Operations Review - Permit Condition Not Currently Applicable</p>	<p>F. Currently in Compliance? (Y or N): <u>  Y  </u>            G. Compliance Status? (C or I): <u>  C  </u>            H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>  N  </u>            *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 40CFR61.M, Conditions #1 - #2</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Asbestos Standard Inspection, Notification, and Contractor Records are maintained on-site.</p>	<p>Periodic</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Inspection, Notification, and Contractor Records</p>	<p>F. Currently in Compliance? (Y or N): <u>  Y  </u>            G. Compliance Status? (C or I): <u>  C  </u>            H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>  N  </u>            *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment Part 70 General, Conditions #1 - #4</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: General Part 70 Permit Conditions            Condition 1 - Compliance status of each federally enforceable condition is reviewed.            Condition 2 - Facility strives to comply with all applicable conditions.            Condition 3 - Deviations from Part 70 requirements are reported within 4 hours after detection.            Condition 4 - Facility understands that the need to halt an activity to comply is not a defense against enforcement action</p>	<p>Continuous</p>
	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Title V Reports and Periodic Review of Requirements</p>	<p>F. Currently in Compliance? (Y or N): <u>  Y  </u>            G. Compliance Status? (C or I): <u>  C  </u>            H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>  N  </u>            *If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01/01/24 (MM/DD/YY) to 12/31/24 (MM/DD/YY)

Ormond Beach Generating Station

<p>A. Attachment # or Permit Condition #: Attachment Part 70 General, Conditions #5</p>	<p>D. Frequency of monitoring:</p> <p>Continuous</p>
<p>B. Description: General Part 70 Permit Conditions</p> <p>Condition 5 - All required records, monitoring data, and support information are maintained for a period of 5 years.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p>N/A</p>
<p>C. Method of monitoring: Title V Reports and Periodic Review of Requirements</p>	<p>F. Currently in Compliance? (Y or N): <u>  Y  </u></p> <p>G. Compliance Status? (C or I): <u>  C  </u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>  N  </u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment Part 70 General, Conditions #6 - #7</p>	<p>D. Frequency of monitoring:</p> <p>Continuous</p>
<p>B. Description: General Part 70 Permit Conditions</p> <p>Condition 6 – Upon request, facility furnishes District-requested information within a reasonable time.</p> <p>Condition 7 - Facility provides District access to facilities and records.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p>N/A</p>
<p>C. Method of monitoring: Title V Reports and Periodic Review of Requirements</p>	<p>F. Currently in Compliance? (Y or N): <u>  Y  </u></p> <p>G. Compliance Status? (C or I): <u>  C  </u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>  N  </u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment Part 70 General, Conditions #8 - #10</p>	<p>D. Frequency of monitoring:</p> <p>Continuous</p>
<p>B. Description: General Part 70 Permit Conditions</p> <p>Condition 8 - Facility understands that the permit may be modified, revoked, reopened, reissued, or terminated for cause</p> <p>Condition 9 - Facility understands that the permit may be reopened by the District under specific conditions.</p> <p>Condition 10 - Facility strives to pay all fees in a timely manner to maintain the permit active.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p> <p>N/A</p>
<p>C. Method of monitoring: Title V Reports and Periodic Review of Requirements</p>	<p>F. Currently in Compliance? (Y or N): <u>  Y  </u></p> <p>G. Compliance Status? (C or I): <u>  C  </u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>  N  </u></p> <p>*If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01/01/24 (MM/DD/YY) to 12/31/24 (MM/DD/YY)  
Ormond Beach Generating Station

<p>A. Attachment # or Permit Condition #: Attachment Part 70 General, Conditions #11 - #15</p>	<p>D. Frequency of monitoring:  Continuous</p>
<p>B. Description: General Part 70 Permit Conditions</p> <p>Condition 11 - Facility recognizes that the permit does not provide any specific property rights</p> <p>Condition 12 - Facility recognizes that the permit provisions are severable.</p> <p>Condition 13 - Facility recognizes that an application for permit renewal is required no more than 18 months and no less than 6 months prior to the expiration date</p> <p>Condition 14 - Facility recognizes that any document submitted on behalf of this permit must be certified by a responsible official</p> <p>Condition 15 - Facility submits a certification of compliance with all applicable requirements to the District and EPA on an annual basis.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Title V Reports and Periodic Review of Requirements</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO General, Conditions #1 - #2</p>	<p>D. Frequency of monitoring:  Continuous</p>
<p>B. Description: General Permit to Operate Conditions</p> <p>Condition 1 - Facility recognizes that petitions to review or revise conditions issued on a permit to operate must be submitted within 30 days of receipt of permit to operate.</p> <p>Condition 2 - Facility maintains copies of the permit reasonably close to the equipment and readily accessible for District review.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Periodic Review of Requirements</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment PO General, Conditions #3 - #4</p>	<p>D. Frequency of monitoring:  Continuous</p>
<p>B. Description: General Permit to Operate Conditions</p> <p>Condition 3 - Facility recognizes that equipment that is not permitted as portable is not transferable from one location to another</p> <p>Condition 4 - Facility recognizes that the District may suspend the permit if District is denied access to requested information within a reasonable amount of time</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Periodic Review of Requirements</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u></p> <p>G. Compliance Status? (C or I): <u>C</u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u></p> <p>*If yes, attach Deviation Summary Form</p>





## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01/01/24 (MM/DD/YY) to 12/31/24 (MM/DD/YY)

Ormond Beach Generating Station

<p>A. Attachment # or Permit Condition #: Attachment SHIELD - D, Da, Db</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Permit Shield - New Source Performance Standards Facility periodically reviews applicability of identified NSPS subparts</p>	<p>Continuous</p>
<p>C. Method of monitoring: Periodic Review of Potentially Applicable Requirements</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u>  Y  </u></p> <p>G. Compliance Status? (C or I): <u>  C  </u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>  N  </u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 40CFR68RMP-65</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Risk Management Plan The site has a current and complete federal Risk Management Plan on-file with the Oxnard Fire Department's Certified Unified Program Agency (CUPA).</p>	<p>Annually</p>
<p>C. Method of monitoring: Risk Management Plan Documentation and Review</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u>  Y  </u></p> <p>G. Compliance Status? (C or I): <u>  C  </u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>  N  </u></p> <p>*If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: Attachment 40CFR72-78</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description: Acid Rain Program Facility maintains records to ensure compliance with monitoring, emission limits, recordkeeping, and reporting requirements.</p>	<p>Continuous</p>
<p>C. Method of monitoring: Periodic Review of Requirements</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
	<p>F. Currently in Compliance? (Y or N): <u>  Y  </u></p> <p>G. Compliance Status? (C or I): <u>  C  </u></p> <p>H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>  N  </u></p> <p>*If yes, attach Deviation Summary Form</p>



## ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Period Covered by Compliance Certification: 01/01/24 (MM/DD/YY) to 12/31/24 (MM/DD/YY)

Ormond Beach Generating Station

<p>A. Attachment # or Permit Condition #: Attachment 40CFR82</p>	<p>D. Frequency of monitoring: Continuous</p>
<p>B. Description: Protection of Stratospheric Ozone Certified contractors are used to conduct any air conditioning work in the plant.</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A</p>
<p>C. Method of monitoring: Inspection, Notification, and Contractor Records</p>	<p>F. Currently in Compliance? (Y or N): <u>Y</u>            G. Compliance Status? (C or I): <u>C</u>            H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u>            *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: INTENTIONALLY LEFT BLANK</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description:</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p>
<p>C. Method of monitoring:</p>	<p>F. Currently in Compliance? (Y or N): _____            G. Compliance Status? (C or I): _____            H. *Excursions, exceedances, or other non-compliance? (Y or N): _____            *If yes, attach Deviation Summary Form</p>

<p>A. Attachment # or Permit Condition #: INTENTIONALLY LEFT BLANK</p>	<p>D. Frequency of monitoring:</p>
<p>B. Description:</p>	<p>E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable</p>
<p>C. Method of monitoring:</p>	<p>F. Currently in Compliance? (Y or N): _____            G. Compliance Status? (C or I): _____            H. *Excursions, exceedances, or other non-compliance? (Y or N): _____            *If yes, attach Deviation Summary Form</p>



Ventura County  
Air Pollution  
Control District

# ANNUAL COMPLIANCE CERTIFICATION

## SOURCE TEST SUMMARY FORM

Period Covered by Compliance Certification: 01/01/24 (MM/DD/YY) 12/31/24 (MM/DD/YY)

A. Emission Unit Description: Ormond Beach Unit 1			B. Pollutant: NO <sub>x</sub>
C. Measured Emission Rate: 0.0%	D. Limited Emission Rate: 0.10 lbs./NMWh	E. Specific Source Test or Monitoring Record Citation: Attachment 59N1, Condition 1	F. Test Date: 06/11/2024

A. Emission Unit Description: Ormond Beach Unit 1			B. Pollutant: NH <sub>3</sub>
C. Measured Emission Rate: 1.33ppm @ 3% O <sub>2</sub>	D. Limited Emission Rate: 10 ppmv	E. Specific Source Test or Monitoring Record Citation: Attachment 59N1, Condition 3	F. Test Date: 06/11/2024

A. Emission Unit Description: Ormond Beach Unit 2			B. Pollutant: NO <sub>x</sub>
C. Measured Emission Rate: Insufficient runtime to require a RATA	D. Limited Emission Rate: 0.10 lbs./NMWh	E. Specific Source Test or Monitoring Record Citation: Attachment 59N1, Condition 1	F. Test Date:

A. Emission Unit Description: Ormond Beach Unit 2			B. Pollutant: NH <sub>3</sub>
C. Measured Emission Rate: Insufficient runtime to require a Ammonia Slip	D. Limited Emission Rate: 10 ppmv	E. Specific Source Test or Monitoring Record Citation: Attachment 59N1, Condition 3	F. Test Date:



# ANNUAL COMPLIANCE CERTIFICATION DEVIATION SUMMARY FORM

Period Covered by Compliance Certification: 01/01/24 (MM/DD/YY) 12/31/24 (MM/DD/YY)

A. Attachment # or Permit Condition #:  There were no deviations in 2024	B. Equipment description:	C. Deviation Period: Date & Time Begin: End: When Discovered:
D. Parameters monitored:	E. Limit:	F. Actual:
G. Probable Cause of Deviation:	H. Corrective actions taken:	

A. Attachment # or Permit Condition #:	B. Equipment description:	C. Deviation Period: Date & Time Begin: End: When Discovered:
D. Parameters monitored:	E. Limit:	F. Actual:
G. Probable Cause of Deviation:	H. Corrective actions taken:	

A. Attachment # or Permit Condition #:	B. Equipment description:	C. Deviation Period: Date & Time Begin: End: When Discovered:
D. Parameters monitored:	E. Limit:	F. Actual:
G. Probable Cause of Deviation:	H. Corrective actions taken:	

**2024**  
**ANNUAL COMPLIANCE CERTIFICATION**  
**ATTACHMENTS**

**ORMOND BEACH GENERATING STATION**  
**PERMIT NO. 00065**

## **ATTACHMENTS**

- 1. AMMONIA SLIP TEST**
- 2. COLD START-UP LOG**
- 3. HIGH ACCURACY METER TEST**
- 4. EMERGENCY GENERATOR RUN-TIME REPORT**
- 5. CARB APPROVED DIESEL FUEL USE**
- 6. RICE NESHAP ZZZZ REPORT**
- 7. EMERGENCY GENERATOR ANNUAL SERVICE**
- 8. SOLVENT & AEROSOL USE LOG**
- 9. CUMMULATIVE EMISSIONS OPERATING HOURS & FUEL USE**
- 10. VISUAL EMISSIONS REPORT**
- 11. ANNUAL GAS CERTIFICTION**
- 12. ASBESTOS NOTIFICATIONS**
- 13. RELATIVE ACCURACY TEST AUDIT**
- 14. V-CONE CALIBRATION REPORT**
- 15. LINEARITY REPORT**

## **AMMONIA SLIP TEST**

# TEST REPORT FOR 2024 ANNUAL AMMONIA SLIP TEST AT ORMOND BEACH POWER, LLC UNIT 1

Prepared For:

**Ormond Beach Power, LLC**  
**Ormond Beach Generating Station**  
6635 S. Edison Drive  
Oxnard, California 93033

For Submittal To:

**Ventura County Air Pollution Control District**  
4567 Telephone Road, 2<sup>nd</sup> Floor  
Ventura, California 92876

Prepared By:

**Montrose Air Quality Services, LLC**  
1631 E. St. Andrew Pl.  
Santa Ana, California 92705  
(714) 279-6777

John Peterson

Test Date: **June 11, 2024**  
Production Date: **July 15, 2024**  
Report Number: **W002AS-041566-RT-6249**






## CONFIDENTIALITY STATEMENT


***Except as otherwise required by law or regulation, this information contained in this communication is intended exclusively for the individual or entity to which it is addressed. This communication may contain information that is proprietary, privileged or confidential or otherwise legally exempt from disclosure. If you are not the named addressee, you are not authorized to read, print, retain, copy, or disseminate this message or any part of it.***

### REVIEW AND CERTIFICATION

All work, calculations, and other activities and tasks performed and presented in this document were carried out by me or under my direction and supervision. I hereby certify that, to the best of my knowledge, Montrose operated in conformance with the requirements of the Montrose Quality Management System and ASTM D7036-04 during this test project.

Signature:  Date: 7/15/2024  
Name: John Peterson Title: District Manager

I have reviewed, technically and editorially, details, calculations, results, conclusions, and other appropriate written materials contained herein. I hereby certify that, to the best of my knowledge, the presented material is authentic, accurate, and conforms to the requirements of the Montrose Quality Management System and ASTM D7036-04.

Signature:  Date: 7/15/2024  
Name: Surya Adhikari Title: Reporting/QC Specialist

## TABLE OF CONTENTS

<b><u>SECTION</u></b>	<b><u>PAGE</u></b>
1.0 INTRODUCTION AND SUMMARY .....	5
2.0 UNIT AND CEMS DESCRIPTION .....	6
2.1 UNIT DESCRIPTION .....	6
2.2 CEMS DESCRIPTION .....	6
2.3 TEST CONDITIONS.....	6
2.4 SAMPLE LOCATION .....	6
3.0 TEST DESCRIPTION .....	7
4.0 TEST RESULTS AND OVERVIEW .....	8
4.1 TEST RESULTS.....	8
4.2 TEST OVERVIEW.....	8

### LIST OF APPENDICES

A TEST DATA.....	9
A.1 Sample Location Data .....	10
A.2 Sample Data Sheets .....	12
A.3 Laboratory Data.....	16
A.4 QA/QC Data .....	18
B FACILITY CEMS DATA .....	21
C CALCULATIONS .....	28
C.1 General Emissions Calculations.....	29
C.2 Spreadsheet Summaries.....	33
D QUALITY ASSURANCE .....	36
D.1 Quality Assurance Program Summary .....	37
D.2 STAC Certification.....	43
D.3 Individual QI Certificates .....	45

### LIST OF TABLES

1-1 AMMONIA SLIP TEST RESULTS SUMMARY .....	5
4-1 AMMONIA SLIP TEST RESULTS .....	8

### LIST OF FIGURES

3-1 SCAQMD METHOD 207.1 SAMPLING EQUIPMENT .....	7
--	---

## 1.0 INTRODUCTION AND SUMMARY

Montrose Air Quality Services, LLC (MAQS) was contracted by Ormond Beach Power, LLC (Ormond Beach) to perform the annual ammonia slip test at Ormond Beach Unit 1 as required by Authority to Construct Number 0065, Condition Number 11. This report documents the results of the ammonia slip test performed on June 11, 2024. The test was conducted in accordance with the test plan Document Number W002AS-026975-PP-750 submitted to Ormond Beach on April 21, 2023. The test was performed by John Peterson, Adrian Enwright, Travis Maestri, and Patrick Rubio of MAQS. John Peterson and Adrian Enwright were the on-site Qualified Individuals for MAQS. Roger Kahle and Sheila Reilly of Ormond Beach Power, LLC coordinated and documented unit operation during the test. Ed Swede of the Ventura County Air Pollution Control District was on-site to witness the NH<sub>3</sub> slip test.

The test consisted of triplicate, 36-minute, ammonia tests which were performed while the unit was operating at a steady operating condition of 261.1 gross megawatts. The results of the tests are summarized in Table 1-1. The table shows that the ammonia slip from this unit was less than the permitted limit of 10 ppm corrected to 3% O<sub>2</sub>.

Section 2.0 of this document provides a brief description of the unit, test conditions, sample location, and CEMS. Details of the test procedures are provided in Section 3.0. Section 4.0 provides the results of the test. All raw data, calculations, quality assurance data, unit operating conditions, and CEMS data are provided in the appendices.

**TABLE 1-1  
 AMMONIA SLIP TEST RESULTS SUMMARY  
 ORMOND BEACH GENERATING STATION  
 UNIT 1  
 JUNE 11, 2024**

Parameter/Units	Average Measured Value	Permit Limit
Load, MW	261.1	--
O <sub>2</sub> , %	3.92	--
<b>NH<sub>3</sub></b>		
ppm	1.26	--
ppm @ 3% O <sub>2</sub>	1.33	10
lb/hr	1.66	--
lb/MMBtu	0.0006	--
lb/MMSCF	0.63	--

## **2.0 UNIT AND CEMS DESCRIPTION**

### **2.1 UNIT DESCRIPTION**

Unit 1 at the Ormond Beach Generating Station consists of a utility boiler and steam turbine electric generator. The boiler and generator have a full load rating of 750 megawatts. The boiler is fired on natural gas only. The unit is equipped with selective catalytic reduction (SCR) for NO<sub>x</sub> reduction.

### **2.2 CEMS DESCRIPTION**

NO<sub>x</sub> emissions from the unit is monitored by a dry, extractive Continuous Emission Monitoring System (CEMS). Stack flow rate is determined from fuel flow rate, O<sub>2</sub> concentration, standard F-Factor, and fuel higher heating value using EPA Method 19.

### **2.3 TEST CONDITIONS**

The test was performed on June 11, 2024, with the unit operating at 35% of full load (261.1 gross megawatts). The test was performed while the unit was firing natural gas and operating under normal conditions. Unit operation was established by the operators and unit operations data are contained in the facility CEMS 1-minute printouts in the Appendix.

### **2.4 SAMPLE LOCATION**


The reference method measurements were made from sample ports accessible from the stack sampling platform on the unit. There are four six-inch sample ports equally spaced at this location. The sample ports are located greater than 2.0 diameters downstream of the nearest flow disturbance and greater than 0.5 diameters from the stack exit. A diagram of the sample location and traverse points is located in Appendix A.1.

### 3.0 TEST DESCRIPTION

The test consisted of triplicate, 36-minute, flue gas samples which were collected non-isokinetically using Bay Area Air Quality Management District (BAAQMD) ST-1B. The sample gas was drawn through a Teflon sample line, two impingers each containing 100 ml of 0.1N HCl, an empty impinger, an impinger containing silica gel, and a dry gas meter. The test was performed using a 12-point traverse. Each traverse point was selected using EPA Method 1 and sampled for 3 minutes. The contents of the sample line and the first three impingers were recovered and analyzed by BAAQMD Lab Method-1A for ammonia concentration by ion specific electrode analysis. A diagram of the sampling equipment is presented as Figure 3-1.

Stack O<sub>2</sub> concentration and volumetric flow rate data were recorded from the certified Continuous Emission Monitoring System (CEMS) which is installed on the unit. These data were used to correct the ammonia concentration to 3% O<sub>2</sub> and to calculate the ammonia mass emission rate in units of pounds per hour.

**FIGURE 3-1  
BAAQMD METHOD ST-1B SAMPLING EQUIPMENT**



## 4.0 TEST RESULTS AND OVERVIEW

### 4.1 TEST RESULTS

The results of the test are presented in Table 4-1. The results show that the average ammonia slip was 1.6 ppm @ 3% O<sub>2</sub> which is less than the permitted limit of 10 ppm @ 3% O<sub>2</sub>.

**TABLE 4-1  
 AMMONIA SLIP TEST RESULTS  
 ORMOND BEACH UNIT 1  
 JUNE 11, 2024**

Parameter/Units	1-NH <sub>3</sub> -1	2-NH <sub>3</sub> -1	3-NH <sub>3</sub> -1	Average	Limit
<b>Start Time</b>	15:00	15:48	16:35	--	--
<b>End Time</b>	15:39	16:27	17:14	--	--
<b>Load, MW</b>	260.2	261.3	261.9	261.1	--
<b>Stack Flow, dscfm @ T<sub>ref</sub><sup>(1)</sup></b>	497,900	498,700	501,200	499,267	--
<b>O<sub>2</sub>, %<sup>(1)</sup></b>	3.95	3.91	3.91	3.92	--
<b>NO<sub>x</sub><sup>(1)</sup></b>	6.03	6.04	6.00	6.02	
ppm	6.37	6.36	6.32	6.35	--
ppm @ 3% O <sub>2</sub>					--
<b>NH<sub>3</sub></b>					
ppm	1.30	1.32	1.15	1.26	--
ppm @ 3% O <sub>2</sub>	1.38	1.39	1.21	1.33	10
lb/hr	1.72	1.74	1.53	1.66	--
lb/MMBtu	0.0006	0.0006	0.0005	0.0006	--
lb/MMSCF	0.65	0.66	0.57	0.63	--

(1) From facility CEMS.

### 4.2 TEST OVERVIEW

The test program was successful in meeting the program objectives. The sample train was leak checked before and after the test and all QA/QC requirements of BAAQMD ST-1B1 were satisfied.

## **APPENDIX A TEST DATA**



## **Appendix A.1 Sample Location Data**


## METHOD 1 DATA SHEET SAMPLE LOCATION

Client: GenOn Energy

Date: 6/11/24

Sample Location: Unit 1

Performed By: JP/PR/TM/AE



Diameter (in.)	<u><b>384.0</b></u>	Sample Point	% of Diameter	Dist from Wall (inches)	Dist from Port (inches)
Upstream (ft.)	<u><b>&gt; 64.0</b></u>	1	4.4	16.9	28.9
Downstream (ft.)	<u><b>&gt; 16.0</b></u>	2	14.6	56.1	68.1
Coupling (in.)	<u><b>12.0</b></u>	3	29.6	113.7	125.7
Stack Area (ft <sup>2</sup> )	<u><b>804.25</b></u>	4	70.4	270.3	282.3
		5	85.4	327.9	339.9
		6	95.6	367.1	379.1

## **Appendix A.2**

### **Sample Data Sheets**

BAY AREA AQMD AMMONIA WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET

CLIENT: Ormond Beach  
 LOCATION: Unit 1  
 DATE: 06/11/24  
 RUN NO: 1-243  
 OPERATOR: PRUBIO  
 METER BOX NO: SWCS  
 METER ΔH@: 1.814  
 METER Yd: 0.991  
 STACK AREA, FT<sup>2</sup>:  
 TRAVERSE POINTS, MIN/POINT: 3/12pts  
 ΔH# 1 X ΔP:  
 Probe Condition, pre/post test: N  
 Silica Gel Expended, Y/N: N  
 Filter Condition after Test: N  
 Check Weight: 449.9/500.0

AMBIENT TEMPERATURE: 65°F  
 BAROMETRIC PRESSURE: 29.81  
 ASSUMED MOISTURE: 15%  
 PITOT TUBE COEFF, Cp: NA  
 PROBE ID NO/MATERIAL: NA/SS  
 PROBE LENGTH: 11  
 NOZZLE ID NO/MATERIAL: NA  
 NOZZLE DIAMETER: NA  
 FILTER NO/TYPE: NA  
 PRE-TEST LEAK RATE: 20.002 CFM@ 10 in. Hg.  
 POST-TEST LEAK RATE: 20.002 CFM@ 10 in. Hg.  
 PITOT LEAK CHECK - PRE: NA POST: NA  
 CHAIN OF CUSTODY: SAMPLE CUSTODIAN AF  
SAMPLER PR  
SAMPLE CUSTODIAN AF

Imp. # Contents Post-Test - Pre-Test = Difference  
 1 0.1N HCL 671.8 710.9  
 2 0.1N HCL 734.4 733.5  
 3 Empty 640.7 639.6  
 4 Silica Gel 935.7 928.3  
 5 LR 0 100  
 6  
 Total: \_\_\_\_\_

Point	Time	Meter Volume, ft <sup>3</sup>	ΔP in. H <sub>2</sub> O	ΔH in. H <sub>2</sub> O	Stack Temp, °F	Probe Temp, °F	Filter Temp, °F	Imp. Out Temp, °F	Meter Temp, °F In	Meter Temp, °F Out	Vacuum in. Hg.	O <sub>2</sub> %	Pstatic in. H <sub>2</sub> O
3	1500	390.900	N/A	1.5	NA	N/A	N/A	60	76	76	5		
2	1503	392.940						60	76	76	5		
1	1506	394.975						57	75	75	5		
6	1509	396.945						57	75	75	PR		
3	1510	396.945						57	76	76	5		
2	1513	398.870						57	75	75	5		
1	1516	400.750						58	76	76	5		
6	1519	402.810											
3	1520	401.750						60	76	76	4		
2	1523	401.750						59	76	76	5		
1	1526	406.735						60	81	76	5		
6	1529	408.825											
3	1530	400.825						60	81	76	5		
2	1533	410.810						60	82	76	5		
1	1536	412.895						60	82	77	5		
6	1539	414.930											
Average:													

Comments: \_\_\_\_\_



# BAY AREA AQMD AMMONIA WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET

CLIENT: Ormond Beach  
 LOCATION: VmitZ  
 DATE: 06/11/24  
 RUN NO: 3 - NPS  
 OPERATOR: P. Rubio  
 METER BOX NO: 5WCS  
 METER ΔH@: 1.814  
 METER Yd: 0.991  
 STACK AREA, FT<sup>2</sup>:  
 TRAVERSE POINTS, MIN/POINT: 3 / 12pts  
 ΔH= \_\_\_\_\_ X ΔP: \_\_\_\_\_  
 Probe Condition, pre/post test: Good / Good  
 Silica Gel Expended, Y/N: N  
 Filter Condition after Test: NA  
 Check Weight: 499.9 / 500.0

AMBIENT TEMPERATURE: 65°F  
 BAROMETRIC PRESSURE: 29.81  
 ASSUMED MOISTURE: 15%  
 PITOT TUBE COEFF, Cp: NA  
 PROBE ID NO/MATERIAL: NA/SS  
 PROBE LENGTH: 11"  
 NOZZLE ID NO/MATERIAL: NA  
 NOZZLE DIAMETER: NA  
 FILTER NO/TYPE: NA  
 PRE-TEST LEAK RATE: 5.002 CFM@ in. Hg.  
 POST-TEST LEAK RATE: 5.002 CFM@ in. Hg.  
 PITOT LEAK CHECK - PRE: NA POST: NA  
 CHAIN OF CUSTODY: SAMPLE CUSTODIAN AE  
SAMPLER PR  
SAMPLE CUSTODIAN AE

Imp. # Contents Post-Test - Pre-Test = Difference  
 1 0.1N HCL 895.5 706.5  
 2 0.1N HCL 735.1 735.2  
 3 Empty 641.3 640.7  
 4 Silica Gel 941.7 935.6  
 5 LR -100  
 6 \_\_\_\_\_  
 Total: \_\_\_\_\_

Point	Time	Meter Volume, ft <sup>3</sup>	ΔP in. H <sub>2</sub> O	ΔH in. H <sub>2</sub> O	Stack Temp, °F	Probe Temp, °F	Filter Temp, °F	Imp. Out Temp, °F	Meter Temp, °F In	Meter Temp, °F Out	Vacuum in. Hg.	O <sub>2</sub> %	Pstatic in. H <sub>2</sub> O
3	1635	441.710	NA	1.5	NA	NA	NA	60	79	77	5		
2	1638	443.670						59	80	77	5		
1	1641	445.635						56	80	77	5		
E	1644	447.580											
3	1645	447.580						55	79	77	5		
2	1648	449.565						53	80	76	5		
1	1651	451.550						54	80	76	5		
E	1654	453.615											
3	1655	453.615						55	82	78	5		
2	1658	455.610						55	80	76	5		
1	1701	457.610						55	80	76	5		
G	1704	459.625											
3	1705	459.625						56	79	76	5		
2	1708	461.670						53	79	76	5		
1	1711	463.710						55	79	75	5		
E	1714	465.875											
Average:													

Comments: \_\_\_\_\_

**BAY AREA AQMD AMMONIA WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET**

CLIENT: Orrmond Beach  
 LOCATION: Unit 1  
 DATE: 06/11/24  
 RUN NO: 2-NH3  
 OPERATOR: PRUBIO  
 METER BOX NO: 5 WCS  
 METER ΔH@: 1.814  
 METER Yd: 0.991  
 STACK AREA, FT²:  
 TRAVERSE POINTS, MIN/POINT: 3/12 pts  
 ΔH= X ΔP:  
 Probe Condition, pre/post test:  
 Silica Gel Expended, Y/N: N  
 Filter Condition after Test:  
 Check Weight: max. 4500.0

AMBIENT TEMPERATURE: 65°F  
 BAROMETRIC PRESSURE: 29.81  
 ASSUMED MOISTURE: 15%  
 PITOT TUBE COEFF, Cp: NA  
 PROBE ID NO/MATERIAL: NA/SS  
 PROBE LENGTH: 11"  
 NOZZLE ID NO/MATERIAL: NA  
 NOZZLE DIAMETER: NA  
 FILTER NO/TYPE: NA  
 PRE-TEST LEAK RATE: 4.002 CFM@ 10 in. Hg.  
 POST-TEST LEAK RATE: 4.002 CFM@ 10 in. Hg.  
 PITOT LEAK CHECK - PRE: NA POST: NA  
 CHAIN OF CUSTODY: SAMPLE CUSTODIAN AB  
SAMPLER PR  
SAMPLE CUSTODIAN AB

Imp. # Contents Post-Test - Pre-Test = Difference  
 1 0.1N HCL 849.0 718.1  
 2 0.1N HCL 7142.9 741.6  
 3 Empty 637.3 636.3  
 4 Silica Gel 928.3 974.2  
 5 LR -100  
 6  
 Total: \_\_\_\_\_

Point	Time	Meter Volume, ft³	ΔP in. H2O	ΔH in. H2O	Stack Temp, °F	Probe Temp, °F	Filter Temp, °F	Imp. Out Temp, °F	Meter Temp, °F In	Meter Temp, °F Out	Vacuum in. Hg.	O2 %	Pstatic in. H2O
3	1548	416.310	NA	1.5	NA	NA	NA	60	80	77	5		
2	1551	418.350						59	82	77	5		
1	1554	420.310						56	82	77	5		
6	1557	422.420						55	82	77	5		
3	1558	422.420						55	82	78	5		
2	1601	424.430						55	83	78	5		
1	1604	426.365						57	84	79	5		
6	1607	428.330						56	82	78	5		
3	1608	428.330						56	83	78	5		
2	1611	430.340						56	83	78	5		
1	1614	432.390						57	83	78	5		
6	1617	434.595						57	82	78	5		
3	1618	434.595						57	82	78	5		
2	1621	436.485						57	82	78	5		
1	1624	438.440						57	82	78	5		
6	1627	440.410											
<b>Average:</b>													

Comments: \_\_\_\_\_

## **Appendix A.3 Laboratory Data**

**Ammonia by Ion Selective Electrode Analysis**District Method: BAAQMD ST-1A

Project Number: PROJ-041566  
 Client/Location: Ormund Beach  
 Sample Location: Unit 1  
 Slope: -55.9

Sample Date: 6/11/2024  
 Analysis Date: 6/11/2024  
 Analyst's Initials: AE

Sample	NH <sub>3</sub> conc. (µg/ ml, as N)	TV (ml)	Aliquot (ml)	DF	Spike (µg/ml as N)	µg NH <sub>3</sub> / sample	Recovery %	Temp. (°C) /pH
Standard Check: 4 µg NH <sub>3</sub> /ml	4.03	-----	49	1	0	-----	100.8	22.4 / <2
1-NH <sub>3</sub>	1.18	418.2	49	1	0	611.45	-----	20.6/ <2
2-NH <sub>3</sub>	1.12	443.6	49	1	0	615.61	-----	21.1 / <2
3-NH <sub>3</sub>	1.91	480.2	49	1	1	541.45	-----	21.0 / <2
Standard Check: 4 µg NH <sub>3</sub> /ml	3.96	-----	49	1	0	-----	99.0	22.0 / <2

**Notes:**

- Total volume of samples and standards used: 49 ml
- Volume of pH adjusting ISA used: 1 ml
- Absorbing solution: 0.1 N HCl
- DF = Dilution Factor. DF = 1 if no dilution is made, = 2 if concentration is diluted 50%.
- Dilution Factor = Volume diluted to / sample aliquot
- 1st Cal Point: 1.0 ppm NH<sub>3</sub> as N
- 2nd Cal Point: 10.0 ppm NH<sub>3</sub> as N
- <https://www.baaqmd.gov/~media/files/records/mop/vol-3/mop-1a.pdf?la=en>
- Slope acceptable values (-54 to -60)

**Calculations:**

- mg NH<sub>3</sub>/sample = (mg/ ml NH<sub>3</sub> as N - Spike) x 50 ml/ Al ml x DF x TV x 17 / 14
- mg/sample = (mg /sample)/ 1000
- ppm NH<sub>3</sub> = mg NH<sub>3</sub>/sample x 1/Vmstd x 1/454000 x SV/17 x 106



## **Appendix A.4 QA/QC Data**

SEMI-ANNUAL DRY GAS METER/ORIFICE CALIBRATION

Model #: Nutech  
 ID #: 5-WCS  
 Date: 4/24/2024  
 Bar. Pressure: 29.97 (in. Hg)  
 Performed By: L. Olivares  
 Reviewed By: Surya Adhikari

CRITICAL ORIFICE READINGS													
dH (in H2O)	Time (min)	Volume (cu ft)		Initial Temps. (deg F)		Final Temps. (deg F)		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	Ambient Temperature (deg F)		
		Initial	Final	Inlet	Outlet	Inlet	Outlet				Initial	Final	Average
0.14	26.00	295.900	301.525	74.0	72.0	73.0	72.0	14742-33	0.1618	19.0	70.0	70.0	69.5
0.14	26.00	307.150	312.775	73.0	72.0	73.0	72.0	14742-33	0.1618	19.0	70.0	70.0	70.0
0.66	12.00	278.600	284.120	76.0	71.0	75.0	71.0	PK-48	0.3452	17.0	68.0	68.0	68.0
0.66	12.00	289.655	295.185	75.0	71.0	71.0	69.0	PK-48	0.3452	17.0	68.0	68.0	68.0
1.80	7.00	262.000	267.205	75.0	69.0	76.0	69.0	PK-63	0.5666	16.0	67.0	68.0	67.5
1.80	7.00	267.205	272.415	76.0	69.0	76.0	70.0	PK-63	0.5666	16.0	68.0	68.0	68.0
1.80	7.00	272.415	277.600	76.0	70.0	77.0	70.0	PK-63	0.5666	16.0	68.0	68.0	68.0
3.40	5.00	245.200	250.310	71.0	66.0	73.0	67.0	PK-73	0.7871	15.0	66.0	67.0	66.5
3.40	5.00	250.310	255.410	73.0	67.0	75.0	68.0	PK-73	0.7871	15.0	67.0	67.0	67.0
3.40	5.00	255.410	260.495	75.0	67.0	77.0	68.0	PK-73	0.7871	15.0	67.0	67.0	67.0

DRY GAS METER				DRY GAS METER CALIBRATION FACTOR				ORIFICE CALIBRATION FACTOR				
VOLUME CORRECTED Vm(sld) (cu ft)	VOLUME CORRECTED Vm(sld) (liters)	VOLUME CORRECTED Ver(sld) (cu ft)	VOLUME CORRECTED Ver(sld) (liters)	VOLUME NOMINAL Vm (cu ft)	VOLUME NOMINAL Vm (liters)	Y Value (number)	dH@ (in H2O)	Individual Run	Individual Orifice	Orifice Average	Orifice Average	Orifice Average
								0.95 < Y < 1.05?	Ymax - Ymin < 0.010?	0.98 < Y/Yd < 1.02?	dH@ - dH@ av < 0.155?	
5.584	158.1	5.479	155.2	5.488	155.2	0.981	1.763	Pass	Pass	Pass	Pass	Pass
5.481	155.2	5.403	153.0	5.396	153.0	0.986	1.824	Pass	Pass	Pass	Pass	Pass
5.499	155.7	5.403	153.0	5.396	153.0	0.981	1.828	Pass	Pass	Pass	Pass	Pass
5.509	156.0	5.403	153.0	5.396	153.0	0.983	1.825	Pass	Pass	Pass	Pass	Pass
5.193	147.1	5.175	146.6	5.164	146.6	0.997	1.852	Pass	Pass	Pass	Pass	Pass
5.193	147.1	5.173	146.5	5.166	146.5	1.002	1.850	Pass	Pass	Pass	Pass	Pass
5.163	146.2	5.173	146.5	5.166	146.5	0.998	1.851	Pass	Pass	Pass	Pass	Pass
5.147	145.8	5.140	145.6	5.119	145.6	0.999	1.818	Pass	Pass	Pass	Pass	Pass
5.125	145.1	5.138	145.5	5.122	145.5	1.003	1.816	Pass	Pass	Pass	Pass	Pass
5.068	144.4	5.138	145.5	5.122	145.5	1.003	1.817	Pass	Pass	Pass	Pass	Pass
				Average Yd:	0.991	dH@:	1.814					
				Q @ dH = 1:	0.557							

*[Signature]*

Date: 04/24/2024  
 Date: 04/24/2024



**DIGITAL TEMPERATURE READOUT CALIBRATION**

Digital Temperature Readout ID: 5-WCS  
 Readout Description: Control Box  
 Date: 1/2/2024  
 Performed By: JS

Calibrated Thermocouple ID: TC-295  
 T1 Reference Thermometer ID: 313010  
 T2 Reference Thermometer ID: 2736  
 T3 Reference Thermometer ID: 2786

T/C I.D.	Readout I.D.	T/C - Readout °F				Reference Thermometer °F				Difference			
		Reading 1	Reading 2	Reading 3	Average	Reading 1	Reading 2	Reading 3	Average	°F	%, (°R)		
TC-295													
T3 (~370 F)	5-WCS	371	371	371	371	370	370	370	370	1.0	0.1%	Pass	
T2 (~212 F)	5-WCS	214	215	215	215	212	212	212	212	2.7	0.4%	Pass	
T1 (~32 F)	5-WCS	34	34	34	34	32	32	32	32	2.0	0.4%	Pass	

- 1) Difference % (°R) = Difference (°F) / (Average Tref + 460)
- 2) Pass if all Differences are less than 1.5% (°R)

Thermocouple Source Readings

T/C Source S/N	T/C - Readout °F				T/C Source °F				Difference			
	Reading 1	Reading 2	Reading 3	Average	Reading 1	Reading 2	Reading 3	Average	°F	%, (°R)		
T4 (~650 F)	125097	653	652	652	652	650	650	650	650	2.3	0.2%	Pass
T3 (~370 F)	125097	373	372	372	372	370	370	370	370	2.3	0.3%	Pass
T2 (~212 F)	125097	215	215	215	215	212	212	212	212	3.0	0.4%	Pass
T1 (~32 F)	125097	35	35	35	35	32	32	32	32	3.0	0.6%	Pass

- 1) Difference % (°R) = Difference (°F) / (Average Tref + 460)
- 2) Pass if all Differences are less than 1.5% (°R)

## **APPENDIX B FACILITY CEMS DATA**

UHZ Run 1

# Average Data

Plant: ORMOND BEACH GEN STA

Interval: 1 Minute

Type: Roll

Report Period: 06/11/2024 15:00 Through 06/11/2024 15:39

Time Online Criteria: 1 minute(s)

Source	Parameter Unit	GASFLOW (HSCFH)	LOADMW (MW)	NH3FLOW (GPM)	NOX#/MM (LB/MMBTU)	NOX#/NMW (LB/NMW)	NOXPPM (PPM)	O2 (PERCENT)	STKFLOW (KSCFM)	UNITOPHR (MIN)
06/11/24	15:00	26,460.9	261.1	0.16	0.009	0.093	6.56	4.07	501.8	1.0
06/11/24	15:01	26,915.6	261.7	0.17	0.008	0.094	6.58	3.84	501.4	1.0
06/11/24	15:02	26,605.4	261.6	0.11	0.007	0.082	5.74	4.03	501.5	1.0
06/11/24	15:03	26,731.2	261.3	0.00	0.007	0.080	5.61	3.93	500.9	1.0
06/11/24	15:04	26,838.4	260.9	0.11	0.008	0.085	5.93	3.86	502.9	1.0
06/11/24	15:05	26,630.1	259.7	0.11	0.008	0.084	5.95	3.81	496.1	1.0
06/11/24	15:06	26,305.8	259.6	0.00	0.007	0.081	5.75	3.82	490.1	1.0
06/11/24	15:07	26,248.1	259.3	0.00	0.008	0.085	6.04	3.87	491.9	1.0
06/11/24	15:08	26,033.2	258.7	0.14	0.008	0.091	6.45	4.06	493.7	1.0
06/11/24	15:09	26,563.0	259.0	0.17	0.009	0.096	6.73	3.90	497.8	1.0
06/11/24	15:10	26,358.5	259.0	0.00	0.007	0.080	5.72	3.81	491.0	1.0
06/11/24	15:11	26,408.2	259.2	0.00	0.007	0.076	5.42	3.80	492.0	1.0
06/11/24	15:12	26,542.0	259.4	0.00	0.007	0.084	5.92	3.85	494.5	1.0
06/11/24	15:13	26,357.4	259.3	0.13	0.008	0.091	6.46	3.91	493.9	1.0
06/11/24	15:14	26,168.0	259.5	0.14	0.008	0.090	6.39	4.04	493.3	1.0
06/11/24	15:15	26,485.2	259.4	0.13	0.008	0.087	6.14	3.93	496.3	1.0
06/11/24	15:16	26,410.6	259.5	0.11	0.007	0.082	5.79	3.95	497.8	1.0
06/11/24	15:17	26,622.5	259.8	0.12	0.008	0.087	6.09	3.97	501.8	1.0
06/11/24	15:18	26,439.5	260.0	0.12	0.008	0.086	6.07	3.93	495.4	1.0
06/11/24	15:19	26,329.5	260.2	0.10	0.007	0.082	5.80	4.05	496.3	1.0
06/11/24	15:20	26,541.2	260.4	0.12	0.008	0.086	6.08	3.94	497.4	1.0
06/11/24	15:21	26,384.9	260.2	0.13	0.008	0.086	6.11	3.92	494.4	1.0
06/11/24	15:22	26,621.8	260.3	0.13	0.008	0.087	6.12	3.96	501.8	1.0
06/11/24	15:23	26,518.8	260.5	0.12	0.008	0.084	5.95	3.87	496.9	1.0
06/11/24	15:24	26,544.9	260.4	0.11	0.008	0.084	5.93	3.89	500.4	1.0
06/11/24	15:25	26,411.1	260.4	0.12	0.008	0.084	5.97	3.95	494.9	1.0
06/11/24	15:26	26,676.7	260.7	0.12	0.008	0.085	6.00	3.93	499.9	1.0
06/11/24	15:27	26,387.3	260.5	0.13	0.008	0.086	6.07	3.97	497.4	1.0
06/11/24	15:28	26,648.9	260.6	0.13	0.008	0.089	6.19	4.06	505.3	1.0
06/11/24	15:29	26,440.2	260.5	0.15	0.008	0.089	6.24	4.05	498.4	1.0
06/11/24	15:30	26,754.6	260.3	0.12	0.008	0.084	5.89	3.97	504.3	1.0
06/11/24	15:31	26,655.7	260.3	0.11	0.007	0.082	5.75	4.00	502.5	1.0
06/11/24	15:32	26,387.3	260.4	0.12	0.008	0.084	5.91	4.08	500.4	1.0
06/11/24	15:33	26,569.5	260.4	0.12	0.008	0.085	5.98	4.01	500.8	1.0
06/11/24	15:34	26,545.1	260.2	0.13	0.008	0.086	6.04	3.95	497.4	1.0

**F = Unit Offline**    **E = Exceedance**    **C = Calibration**    **S = Substituted**    **I = Invalid**  
**M = Maintenance**    **T = Out Of Control**    **\* = Suspect**    **U = Startup**    **D = Shutdown**

Report Generated: 06/11/24 17:04

Version 6.18

GONPRODU\Sheila.Relly

# Average Data

Plant: ORMOND BEACH GEN STA

Interval: 1 Minute

Type: Roll

Report Period: 06/11/2024 15:00 Through 06/11/2024 15:39

Time Online Criteria: 1 minute(s)

*Handwritten:* NTKM  
15:38

Source	ORB1									
Parameter Unit	GASFLOW (HSCFH)	LOADMW (MW)	NH3FLOW (GPM)	NOX#MM (LBMMBTU)	NOX#NMW (LBINMW)	NOXPPM (PPM)	O2 (PERCENT)	STKFLOW (KSCFM)	UNITOPHR (MIN)	
06/11/24 15:35	26,571.8	260.5	0.13	0.008	0.087	6.06	4.03	500.9	1.0	
06/11/24 15:36	26,439.3	260.9	0.12	0.008	0.086	6.02	4.07	501.3	1.0	
06/11/24 15:37	26,490.3	260.7	0.12	0.008	0.084	5.92	3.94	496.4	1.0	
06/11/24 15:38	26,544.0	260.5	0.11	0.007	0.082	5.81	3.87	497.4	1.0	
06/11/24 15:39	26,491.9	260.4	0.12	0.008	0.085	5.96	3.97	499.4	1.0	
Average	26,502.0	260.2	0.11	0.008	0.086	6.03	3.95	497.9	1.0	
Minimum	26,033.2	258.7	0.00	0.007	0.078	5.42	3.80	490.1	1.0	
Maximum	26,915.6	261.7	0.17	0.009	0.096	6.73	4.08	505.3	1.0	
Summation	1,060,078.4	10,407.3	4.28	0.312	3.421	241.14	157.96	19,918.0	40.0	
Included Data Points	40	40	40	40	40	40	40	40	40	
Total number of Data Points	40	40	40	40	40	40	40	40	40	

**F = Unit Offline**    **E = Exceedance**    **C = Calibration**    **S = Substituted**    **I = Invalid**  
**M = Maintenance**    **T = Out Of Control**    **\* = Suspect**    **U = Startup**    **D = Shutdown**

Report Generated: 06/11/24 17:04

Version 6.18

GONPRODU\Sheila.Reilly

KH3 Run 2

# Average Data

Plant: ORMOND BEACH GEN STA

Interval: 1 Minute

Type: Roll

Report Period: 06/11/2024 15:48 Through 06/11/2024 16:27

Time Online Criteria: 1 minute(s)

Source	Parameter Unit	GASFLOW (HSCFH)	LOADMW (MW)	NH3FLOW (GPM)	NOX#/MM (LB/MMBTU)	NOX#/NMW (LB/NMW)	NOXPPM (PPM)	O2 (PERCENT)	STKFLOW (KSCFM)	UNITOPHR (MIN)
06/11/24	15:48	26,489.6	261.1	0.13	0.008	0.088	6.18	3.99	499.3	1.0
06/11/24	15:49	26,677.5	261.2	0.15	0.008	0.090	6.33	3.98	502.9	1.0
06/11/24	15:50	26,573.9	261.5	0.14	0.008	0.086	6.07	3.96	500.9	1.0
06/11/24	15:51	26,756.9	261.5	0.00	0.007	0.080	5.65	3.88	501.4	1.0
06/11/24	15:52	26,575.2	261.7	0.10	0.007	0.081	5.75	3.94	498.0	1.0
06/11/24	15:53	26,652.5	261.5	0.12	0.008	0.086	6.07	3.91	499.4	1.0
06/11/24	15:54	26,547.6	261.2	0.13	0.008	0.086	6.15	3.82	494.6	1.0
06/11/24	15:55	26,385.2	261.2	0.11	0.008	0.085	6.00	3.95	497.4	1.0
06/11/24	15:56	26,542.3	261.3	0.13	0.008	0.088	6.21	3.92	497.4	1.0
06/11/24	15:57	26,385.0	261.2	0.14	0.008	0.088	6.25	3.93	494.4	1.0
06/11/24	15:58	26,488.9	261.1	0.11	0.008	0.083	5.88	3.91	496.4	1.0
06/11/24	15:59	26,597.9	261.5	0.13	0.008	0.084	5.92	3.90	498.4	1.0
06/11/24	16:00	26,625.7	261.2	0.13	0.008	0.086	6.08	3.84	496.0	1.0
06/11/24	16:01	26,680.4	260.9	0.14	0.008	0.088	6.23	3.90	500.0	1.0
06/11/24	16:02	26,654.6	261.0	0.12	0.008	0.086	6.02	3.93	499.5	1.0
06/11/24	16:03	26,493.2	261.0	0.12	0.008	0.084	5.96	3.98	499.4	1.0
06/11/24	16:04	26,651.5	261.0	0.11	0.008	0.083	5.88	3.88	499.4	1.0
06/11/24	16:05	26,440.3	261.0	0.11	0.008	0.083	5.92	3.91	495.5	1.0
06/11/24	16:06	26,650.7	261.1	0.12	0.008	0.087	6.15	3.85	499.4	1.0
06/11/24	16:07	26,466.7	261.0	0.12	0.008	0.086	6.14	3.91	496.0	1.0
06/11/24	16:08	26,623.2	261.1	0.13	0.008	0.086	6.07	3.89	498.9	1.0
06/11/24	16:09	26,519.3	261.2	0.13	0.008	0.086	6.06	3.95	496.9	1.0
06/11/24	16:10	26,571.1	261.1	0.13	0.008	0.087	6.10	4.00	500.9	1.0
06/11/24	16:11	26,572.2	261.4	0.12	0.008	0.084	5.98	3.90	497.9	1.0
06/11/24	16:12	26,438.7	261.3	0.12	0.008	0.085	6.00	3.97	498.4	1.0
06/11/24	16:13	26,596.5	261.5	0.13	0.008	0.087	6.14	3.95	501.3	1.0
06/11/24	16:14	26,519.8	261.6	0.13	0.008	0.086	6.09	3.89	497.0	1.0
06/11/24	16:15	26,651.2	261.6	0.11	0.007	0.082	5.83	3.90	499.4	1.0
06/11/24	16:16	26,709.6	261.8	0.12	0.008	0.084	5.93	3.94	500.5	1.0
06/11/24	16:17	26,601.2	261.7	0.14	0.008	0.089	6.23	4.01	501.4	1.0
06/11/24	16:18	26,709.4	261.4	0.15	0.008	0.089	6.22	3.94	500.5	1.0
06/11/24	16:19	26,786.5	261.3	0.11	0.007	0.081	5.74	3.85	502.0	1.0
06/11/24	16:20	26,787.1	261.1	0.00	0.007	0.079	5.59	3.84	499.0	1.0
06/11/24	16:21	26,656.2	261.2	0.00	0.007	0.082	5.79	3.85	499.5	1.0
06/11/24	16:22	26,573.6	261.3	0.12	0.008	0.088	6.21	3.92	498.0	1.0

**F = Unit Offline**    **E = Exceedance**    **C = Calibration**    **S = Substituted**    **I = Invalid**  
**M = Maintenance**    **T = Out Of Control**    **\* = Suspect**    **U = Startup**    **D = Shutdown**

Report Generated: 06/11/24 17:04

Version 6.18

GONPRODU\Sheila.Reilly

# Average Data

Plant: ORMOND BEACH GEN STA

Interval: 1 Minute

Type: Roll

Report Period: 06/11/2024 15:48 Through 06/11/2024 16:27

Time Online Criteria: 1 minute(s)

R 2  
A H C W

Source		ORB1									
Parameter	Unit	GASFLOW (HSCFH)	LOADMW (MW)	NH3FLOW (GPM)	NOX#MM (LB/MMBTU)	NOX#NMW (LB/NMW)	NOXPPM (PPM)	O2 (PERCENT)	STKFLOW (KSCFM)	UNITOPHR (MIN)	
06/11/24	16:23	26,498.9	261.1	0.14	0.008	0.088	6.28	3.88	495.4	1.0	
06/11/24	16:24	26,676.7	260.9	0.12	0.008	0.085	5.99	3.85	499.9	1.0	
06/11/24	16:25	26,574.5	261.2	0.10	0.007	0.082	5.85	3.83	495.1	1.0	
06/11/24	16:26	26,572.6	261.2	0.12	0.008	0.087	6.11	3.97	500.9	1.0	
06/11/24	16:27	26,652.6	261.0	0.15	0.008	0.090	6.35	3.91	499.4	1.0	
Average		26,589.2	261.3	0.12	0.008	0.085	6.04	3.91	498.7	1.0	
Minimum		26,385.0	260.9	0.00	0.007	0.079	5.59	3.82	494.4	1.0	
Maximum		26,787.1	261.8	0.15	0.008	0.090	6.35	4.01	502.9	1.0	
Summation		1,063,566.5	10,450.2	4.61	0.313	3.415	241.40	156.53	19,948.0	40.0	
Included Data Points		40	40	40	40	40	40	40	40	40	
Total number of Data Points		40	40	40	40	40	40	40	40	40	

**F = Unit Offline**    **E = Exceedance**    **C = Calibration**    **S = Substituted**    **I = Invalid**  
**M = Maintenance**    **T = Out Of Control**    **\* = Suspect**    **U = Startup**    **D = Shutdown**

Report Generated: 06/11/24 17:04

Version 6.18

GONPRODU\Sheila.Reilly



# Average Data

Plant: ORMOND BEACH GEN STA

Interval: 1 Minute

Type: Roll

Report Period: 06/11/2024 16:35 Through 06/11/2024 17:14

Time Online Criteria: 1 minute(s)

06-10-24-0

Source	ORB1									
Parameter Unit	GASFLOW (HSCFH)	LOADMW (MW)	NH3FLOW (GPM)	NOX#/MM (LB/MMBTU)	NOX#/NMW (LB/NMW)	NOXPPM (PPM)	O2 (PERCENT)	STKFLOW (KSCFM)	UNITOPHR (MIN)	
06/11/24 16:35	26,678.2	261.6	0.13	0.008	0.086	6.08	3.90	499.9	1.0	
06/11/24 16:36	26,710.4	261.6	0.13	0.008	0.084	5.93	3.91	500.5	1.0	
06/11/24 16:37	26,866.8	261.8	0.12	0.008	0.084	5.86	3.90	503.5	1.0	
06/11/24 16:38	26,659.0	261.8	0.13	0.008	0.086	6.03	4.00	502.5	1.0	
06/11/24 16:39	26,785.3	261.7	0.14	0.008	0.087	6.13	3.93	501.9	1.0	
06/11/24 16:40	26,576.5	261.6	0.12	0.007	0.083	5.93	3.86	498.0	1.0	
06/11/24 16:41	26,890.5	261.7	0.11	0.007	0.082	5.77	3.81	501.0	1.0	
06/11/24 16:42	26,524.3	261.7	0.11	0.008	0.083	5.90	3.94	497.1	1.0	
06/11/24 16:43	26,756.7	262.0	0.13	0.008	0.088	6.22	3.86	501.4	1.0	
06/11/24 16:44	26,496.7	261.8	0.11	0.008	0.085	6.05	3.85	493.6	1.0	
06/11/24 16:45	26,517.8	262.2	0.00	0.007	0.082	5.83	3.82	494.0	1.0	
06/11/24 16:46	26,652.6	262.2	0.12	0.008	0.086	6.07	3.92	499.4	1.0	
06/11/24 16:47	26,547.9	262.2	0.17	0.008	0.093	6.56	3.97	500.4	1.0	
06/11/24 16:48	26,917.3	262.4	0.15	0.008	0.089	6.22	3.87	504.4	1.0	
06/11/24 16:49	26,977.0	262.1	0.12	0.007	0.082	5.74	3.88	505.5	1.0	
06/11/24 16:50	26,898.2	261.2	0.10	0.007	0.080	5.65	3.81	501.1	1.0	
06/11/24 16:51	26,552.0	261.0	0.00	0.007	0.081	5.71	3.92	497.6	1.0	
06/11/24 16:52	26,864.7	262.0	0.12	0.008	0.087	6.16	3.78	500.5	1.0	
06/11/24 16:53	26,444.6	261.9	0.12	0.008	0.087	6.19	3.95	498.5	1.0	
06/11/24 16:54	26,650.2	262.2	0.12	0.008	0.086	6.09	3.85	496.5	1.0	
06/11/24 16:55	26,387.2	261.9	0.12	0.008	0.085	6.06	3.92	494.5	1.0	
06/11/24 16:56	26,887.9	261.9	0.13	0.008	0.087	6.11	3.86	503.9	1.0	
06/11/24 16:57	26,763.3	261.4	0.16	0.008	0.090	6.35	3.94	501.5	1.0	
06/11/24 16:58	26,974.1	261.8	0.13	0.007	0.084	5.92	3.81	502.5	1.0	
06/11/24 16:59	26,764.6	261.8	0.00	0.007	0.080	5.62	3.94	501.6	1.0	
06/11/24 17:00	26,656.1	261.9	0.12	0.008	0.085	6.01	3.93	499.5	1.0	
06/11/24 17:01	26,654.2	261.9	0.13	0.008	0.089	6.23	3.99	502.4	1.0	
06/11/24 17:02	26,520.7	262.0	0.14	0.008	0.087	6.15	3.96	499.9	1.0	
06/11/24 17:03	26,678.6	261.9	0.13	0.008	0.086	6.05	4.00	502.9	1.0	
06/11/24 17:04	26,759.6	262.0	0.13	0.008	0.086	6.06	3.92	501.5	1.0	
06/11/24 17:05	26,576.2	261.8	0.14	0.008	0.085	6.00	4.04	501.0	1.0	
06/11/24 17:06	26,944.2	262.1	0.15	0.008	0.088	6.11	3.99	507.9	1.0	
06/11/24 17:07	26,871.3	262.1	0.15	0.008	0.087	6.06	4.04	506.5	1.0	
06/11/24 17:08	26,789.2	262.1	0.12	0.007	0.082	5.77	3.96	505.0	1.0	
06/11/24 17:09	26,815.0	262.0	0.11	0.007	0.081	5.73	3.90	502.5	1.0	

F = Unit Offline    E = Exceedance    C = Calibration    S = Substituted    I = Invalid  
M = Maintenance    T = Out Of Control    \* = Suspect    U = Startup    D = Shutdown

02-27-24

# Average Data

Plant: ORMOND BEACH GEN STA

Interval: 1 Minute

Type: Roll

Report Period: 06/11/2024 16:35 Through 06/11/2024 17:14

Time Online Criteria: 1 minute(s)

Source	ORB1									
Parameter Unit	GASFLOW (HSCFH)	LOADMW (MW)	NH3FLOW (GPM)	NOX#MM (LB/MMBTU)	NOX#NMW (LB/NMW)	NOXPPM (PPM)	O2 (PERCENT)	STKFLOW (KSCFM)	UNITOPHR (MIN)	
06/11/24 17:10	26,762.1	262.0	0.12	0.008	0.084	5.89	3.96	504.5	1.0	
06/11/24 17:11	26,760.7	262.1	0.15	0.008	0.089	6.24	3.96	504.4	1.0	
06/11/24 17:12	26,761.5	261.6	0.13	0.008	0.086	6.02	3.90	501.5	1.0	
06/11/24 17:13	26,840.6	261.7	0.12	0.007	0.082	5.78	3.88	503.0	1.0	
06/11/24 17:14	26,976.6	261.8	0.11	0.007	0.083	5.80	3.80	502.6	1.0	
Average	26,727.8	261.9	0.12	0.008	0.085	6.00	3.91	501.2	1.0	
Minimum	26,387.2	261.0	0.00	0.007	0.080	5.62	3.78	493.6	1.0	
Maximum	26,977.0	262.4	0.17	0.008	0.093	6.56	4.04	507.9	1.0	
Summation	1,069,110.4	10,474.5	4.74	0.309	3.407	240.08	156.43	20,046.4	40.0	
Included Data Points	40	40	40	40	40	40	40	40	40	
Total number of Data Points	40	40	40	40	40	40	40	40	40	

**F = Unit Offline**    **E = Exceedance**    **C = Calibration**    **S = Substituted**    **I = Invalid**  
**M = Maintenance**    **T = Out Of Control**    **\* = Suspect**    **U = Startup**    **D = Shutdown**

Report Generated: 06/11/24 17:53

Version 6.18

GONPRODU'Sheila.Reilly

## APPENDIX C CALCULATIONS

## **Appendix C.1**

### **General Emissions Calculations**

## GENERAL EMISSION CALCULATIONS

### I. Stack Gas Velocity

A. Stack gas molecular weight, lb/lb-mole

$$MW_{dry} = 0.44 * \%CO_2 + 0.32 * \%O_2 + 0.28 * \%N_2$$

$$MW_{wet} = MW_{dry} * (1 - B_{wo}) + 18 * B_{wo}$$

B. Absolute stack pressure, iwg

$$P_s = P_{bar} + \frac{P_{sg}}{13.6}$$

C. Stack gas velocity, ft/sec

$$V_s = 2.9 * C_p * \sqrt{\Delta P} * \sqrt{T_s} * \sqrt{\frac{29.92 * 28.95}{P_s * MW_{wet}}}$$

### II. Moisture

A. Sample gas volume, dscf

$$V_{mstd} = 0.03342 * V_m * (P_{bar} + \frac{\Delta H}{13.6}) * \frac{T_{ref}}{T_m} * Y_d$$

B. Water vapor volume, scf

$$V_{wstd} = 0.0472 * V_{lc} * \frac{T_{ref}}{528 \text{ } ^\circ R}$$

C. Moisture content, dimensionless

$$B_{wo} = \frac{V_{wstd}}{(V_{mstd} + V_{wstd})}$$

### III. Stack gas volumetric flow rate

A. Actual stack gas volumetric flow rate, wacfm

$$Q = V_s * A_s * 60$$

B. Standard stack gas flow rate, dscfm

$$Q_{sd} = Q * (1 - B_{wo}) * \frac{T_{ref}}{T_s} * \frac{P_s}{29.92}$$

IV. Gaseous Mass Emission Rates, lb/hr

$$M = \frac{\text{ppm} * MW_i * Q_{sd} * 60}{SV * 10^6}$$

V. Emission Rates, lb/MMBtu

$$\frac{\text{lb}}{\text{MMBtu}} = \frac{\text{ppm} * MW_i * F}{SV * 10^6} * \frac{20.9}{20.9 - \%O_2}$$

VI. Percent Isokinetic

$$I = \frac{17.32 * T_s (V_{mstd})}{(1-Bwo) * 0 * V_s * P_s * Dn2} * \frac{520^{\circ}R}{T_{ref}}$$

VII. Particulate emissions

(a) Grain loading, gr/dscf  
C = 0.01543 (M<sub>n</sub>/V<sub>m std</sub>)

(b) Grain loading at 12% CO<sub>2</sub>, gr/dscf  
C<sub>12% CO<sub>2</sub></sub> = C (12/% CO<sub>2</sub>)

(c) Mass emissions, lb/hr  
M = C x Qsd x (60 min/hr)/(7000 gr/lb)

(d) Particulate emission factor  
lb/10<sup>6</sup> Btu = C x  $\frac{1 \text{ lb}}{7000 \text{ gr}}$  x F x  $\frac{20.9}{20.9 - \% O_2}$

Nomenclature:

A <sub>s</sub>	= stack area, ft <sup>2</sup>
B <sub>wo</sub>	= flue gas moisture content, dimensionless
C <sub>12%CO<sub>2</sub></sub>	= particulate grain loading, gr/dscf corrected to 12% CO <sub>2</sub>
C	= particulate grain loading, gr/dscf
C <sub>p</sub>	= pitot calibration factor, dimensionless
D <sub>n</sub>	= nozzle diameter, in.
F	= fuel F-Factor, dscf/MMBtu @ 0% O <sub>2</sub>
H	= orifice differential pressure, iwg
I	= % isokinetics
M <sub>n</sub>	= mass of collected particulate, mg
M <sub>i</sub>	= mass emission rate of specie i, lb/hr
MW	= molecular weight of flue gas, lb/lb-mole
M <sub>wi</sub>	= molecular weight of specie i: SO <sub>2</sub> : 64 NO <sub>x</sub> : 46 CO: 28 HC: 16
0	= sample time, min.
ΔP	= average velocity head, iwg = $(\sqrt{\Delta P})^2$
P <sub>bar</sub>	= barometric pressure, inches Hg
P <sub>s</sub>	= stack absolute pressure, inches Hg
P <sub>sg</sub>	= stack static pressure, iwg
Q	= wet stack flow rate at actual conditions, wacfm
Q <sub>sd</sub>	= dry standard stack flow rate, dscfm
SV	= specific molar volume of an ideal gas at standard conditions, ft <sup>3</sup> /lb-mole
T <sub>m</sub>	= meter temperature, °R
T <sub>ref</sub>	= reference temperature, °R
T <sub>s</sub>	= stack temperature, °R
V <sub>s</sub>	= stack gas velocity, ft/sec
V <sub>lc</sub>	= volume of liquid collected in impingers, ml
V <sub>m</sub>	= uncorrected dry meter volume, dcf
V <sub>mstd</sub>	= dry meter volume at standard conditions, dscf
V <sub>wstd</sub>	= volume of water vapor at standard conditions, scf
Y <sub>d</sub>	= meter calibration coefficient

## **Appendix C.2**

### **Spreadsheet Summaries**



OB1 3Q24 RATA\_1  
Ammonia

Client	GenOn Energy			Parameter	NH3
Location	Ormond Beach			Fuel	GAS
Unit	Unit 1			Data By	JP/PR/TM/AE
Test Number	1-NH3-1	2-NH3-2	3-NH3-3	AVERAGE	
Reference Temperature, F	68	68	68		
Test Date	6/11/2024	6/11/2024	6/11/2024		
Test Method	BAAQMD ST-1B	BAAQMD ST-1B	BAAQMD ST-1B		
Sample Train	5 WCS	5 WCS	5 WCS		
Meter Calibration Factor	0.991	0.991	0.991		
Stack Area (sq ft)	n/a	n/a	n/a		
Sample Time (Min)	36	36	36		
Barometric Pressure (in Hg)	29.81	29.81	29.81		
Start Time	15:00	15:48	16:35		
Stop Time	15:39	16:27	17:14		
Meter Volume (acf)	24.030	24.050	24.165		
Meter Temperature (F)	77.5	80.0	78.1		
Meter Pressure (iwg)	1.50	1.50	1.50		
Liquid Volume (ml)	70.3	87.3	95.6		
F-Factor (dscf/MMBtu)	8,710	8,710	8,710		
HHV(Btu/SCF)	1,050	1,050	1,050		
Stack O <sub>2</sub> (%) (From Facility)	3.95	3.91	3.91	3.92	
Stack NO <sub>x</sub> (ppm)	6.03	6.04	6.00	6.02	
Stack NO <sub>x</sub> (ppmc)	6.37	6.36	6.32	6.35	
Unit Load MW	260.2	261.3	261.9	261.1	
Standard Sample Volume (SCF)	23.391	23.301	23.497		
Moisture Fraction	0.124	0.150	0.161		
Stack Flow Rate (dscfm)	497,900	498,700	501,200	499,267	
Gas Constant (ft-lbf/lb-mole-R)	1545.33	1545.33	1545.33		
Standard Pressure (lbf/ft <sup>2</sup> )	2116.224	2116.224	2116.224		
Molecular Weight NH <sub>3</sub> (lb/lb-mole)	17	17	17		
Specific Molar Volume (ft <sup>3</sup> /lb-mole)	385.34	385.34	385.34		
Mass Conversion (lb/ug)	2.20E-09	2.20E-09	2.20E-09		
O <sub>2</sub> Correction Factor (%)	3	3	3		
Mass NH <sub>3</sub> (Ug)	611.45	615.61	541.45		
Mass NH <sub>3</sub> (mg)	0.611	0.616	0.541		
Mass NH <sub>3</sub> (lb)	1.35E-06	1.36E-06	1.19E-06		
PPM NH <sub>3</sub> (flue gas)	1.31	1.32	1.15	1.26	
PPM NH <sub>3</sub> @ O <sub>2</sub> Correction	1.38	1.39	1.21	1.33	
Ib/hr NH3	1.72	1.74	1.53	1.66	
Ib/MMBtu	0.0006	0.0006	0.0005	0.0006	
Ib/MMSCF	0.65	0.66	0.57	0.63	

**NH3 EQUATIONS:**

ppm NH3 = (mass NH3 \* Gas Const \* Ref Temp \* 10<sup>6</sup>) / (Sample vol. \* Press \* MW)

ppm NH3 @ O2 correction = ppm \* (20.9 - O2 Corr) / (20.9 - %O2)

Ib/hr NH3 = (ppm \* stack flow \* MW \* 60) / Specific Molar Volume / 10<sup>6</sup>

## BAAQMD ST-1B EXAMPLE CALCULATION

### TEST NUMBER: 1-NH3-1

Identifier	Description	Units	Equation	Value
A	Reference Temperature	F	--	68
B	Reference Temperature	R	A + 460	528
C	Meter Calibration Factor (Yd)	--	--	0.991
D	Barometric Pressure	" Hg	--	29.81
E	Meter Volume	acf	--	24.030
F	Meter Temperature	F	--	77.5
G	Meter Temperature	R	F + 460	537.5
H	Delta H	" H <sub>2</sub> O	--	1.5
I	Meter Volume (standard)	dscf	0.03342 * E * (D + H/13.6) * B/G * C	23.391
J	Liquid Collected	grams	--	70.3
K	Water vapor volume	scf	0.0472 * J * B/528	3.318
L	Moisture Content	--	K/(K + I)	0.124
M	Gas Constant	ft-lbf/lb-mole-R	--	1545.33
N	Specific Molar Volume	SCF/lb-mole	385.3 * B / 528	385.3
O	F-Factor	dscf/MMBtu	--	8,710
P	HHV	Btu/SCF	--	1,050
Q	Mass Conversion Factor	lb/ug	--	2.20E-09
R	O <sub>2</sub> Correction Factor	--	--	3
S	Stack Flow Rate @ 68 F	dscfm	--	497,900
T	Stack Flow Rate @ Tref	dscfm	S * B/528	497,900
U	Mass NH <sub>3</sub>	ug	--	611
V	Mass NH <sub>3</sub>	lb	U * Q	1.35E-06
W	MW of NH <sub>3</sub>	lb/lb-mole	--	17.03
X	NH <sub>3</sub>	ppm	(V * N * 10 <sup>b</sup> )/(I * W)	1.3
Y	Flue Gas O <sub>2</sub>	%	--	3.95
Z	NH <sub>3</sub>	ppmc	X * (20.9 - R)/(20.9 - Y)	1.4
AA	NH <sub>3</sub>	lb/hr	X * T * W * 60/(N * 10 <sup>b</sup> )	1.7
AB	NH <sub>3</sub>	lb/MMBtu	(X * W * O)/(385.3 * 10 <sup>b</sup> ) * 20.9/(20.9 - Y)	0.001
AC	NH <sub>3</sub>	lb/MMSCF	AB * P	0.6

**Note:**

(1) Some values may be slightly different from those shown on the run sheets due to round off errors. This page is intended to show the calculation methodology only.

## **APPENDIX D QUALITY ASSURANCE**

## **Appendix D.1**

# **Quality Assurance Program Summary**

## QUALITY ASSURANCE PROGRAM SUMMARY

As part of Montrose Air Quality Services, LLC (Montrose) ASTM D7036-04 certification, Montrose is committed to providing emission related data which is complete, precise, accurate, representative, and comparable. Montrose quality assurance program and procedures are designed to ensure that the data meet or exceed the requirements of each test method for each of these items. The quality assurance program consists of the following items:

- Assignment of an Internal QA Officer
- Development and use of an internal QA Manual
- Personnel training
- Equipment maintenance and calibration
- Knowledge of current test methods
- Chain-of-custody
- QA reviews of test programs

Assignment of an Internal QA Officer: Montrose has assigned an internal QA Officer who is responsible for administering all aspects of the QA program.

Internal Quality Assurance Manual: Montrose has prepared a QA Manual according to the requirements of ASTM D7036-04 and guidelines issued by EPA. The manual documents and formalizes all of Montrose's QA efforts. The manual is revised upon periodic review and as Montrose adds capabilities. The QA manual provides details on the items provided in this summary.

Personnel Testing and Training: Personnel testing and training is essential to the production of high quality test results. Montrose training programs include:

- A requirement for all technical personnel to read and understand the test methods performed
- A requirement for all technical personnel to read and understand the Montrose QA manual
- In-house testing and training
- Quality Assurance meetings
- Third party testing where available
- Maintenance of training records.

Equipment Maintenance and Calibration: All laboratory and field equipment used as a part of Montrose's emission measurement programs is maintained according to manufacturer's recommendations. A summary of the major equipment maintenance schedules is summarized in Table 1. In addition to routine maintenance, calibrations are performed on all sampling equipment according to the procedures outlined in the applicable test method. The calibration intervals and techniques for major equipment components is summarized in Table 2. The calibration technique may vary to meet regulatory agency requirements.

Knowledge of Current Test Methods: Montrose maintains current copies of EPA, ARB, and SCAQMD Source Test Manuals and Rules and Regulations.

Chain-of-Custody: Montrose maintains chain-of-custody documentation on all data sheets and samples. Samples are stored in a locked area accessible only to Montrose source test personnel. Data sheets are kept in the custody of the originator, program manager, or in locked storage until return to Montrose office. Electronic field data is duplicated for backup on secure storage media. The original data sheets are used for report preparation and any additions are initialed and dated.

QA Reviews: Periodic field, laboratory, and report reviews are performed by the in-house QA coordinator. Periodically, test plans are reviewed to ensure proper test methods are selected and reports are reviewed to ensure that the methods were followed and any deviations from the methods are justified and documented.

## **ASTM D7036-04 Required Information**

### Uncertainty Statement

Montrose is qualified to conduct this test program and has established a quality management system that led to accreditation with ASTM Standard D7036-04 (Standard Practice for Competence of Air Emission Testing Bodies). Montrose participates in annual functional assessments for conformance with D7036-04 which are conducted by the American Association for Laboratory Accreditation (A2LA). All testing performed by Montrose is supervised on site by at least one Qualified Individual (QI) as defined in D7036-04 Section 8.3.2. Data quality objectives for estimating measurement uncertainty within the documented limits in the test methods are met by using approved test protocols for each project as defined in D7036-04 Sections 7.2.1 and 12.10. Additional quality assurance information is presented in the report appendices.

### Performance Data

Performance data are available for review.

### Qualified Personnel

A qualified individual (QI), defined by performance on a third party or internal test on the test methods, is present on each test event.

### Plant Entry and Safety Requirements

#### **Plant Entry**

All test personnel are required to check in with the guard at the entrance gate or other designated area. Specific details are provided by the facility and project manager.

## Safety Requirements

All personnel shall have the following personal protective equipment (PPE) and wear them where designated:

- Hard Hat
- Safety Glasses
- Steel Toe Boots
- Hearing Protection
- Gloves
- High Temperature Gloves (if required)
- Flame Resistant Clothing (if required)

The following safety measures are followed:

- Good housekeeping
- SDS for all on-site hazardous materials
- Confine selves to necessary areas (stack platform, mobile laboratory, CEMS data acquisition system, control room, administrative areas)
- Knowledge of evacuation procedures

Each facility will provide plant specific safety training.

**TABLE 1  
 EQUIPMENT MAINTENANCE SCHEDULE**

<b>Equipment</b>	<b>Acceptance Limits</b>	<b>Frequency of Service</b>	<b>Methods of Service</b>
Pumps	<ol style="list-style-type: none"> <li>1. Absence of leaks</li> <li>2. Ability to draw manufacturers required vacuum and flow</li> </ol>	As recommended by manufacturer	<ol style="list-style-type: none"> <li>1. Visual inspection</li> <li>2. Clean</li> <li>3. Replace parts</li> <li>4. Leak check</li> </ol>
Flow Meters	<ol style="list-style-type: none"> <li>1. Free mechanical movement</li> </ol>	As recommended by manufacturer	<ol style="list-style-type: none"> <li>1. Visual inspection</li> <li>2. Clean</li> <li>3. Calibrate</li> </ol>
Sampling Instruments	<ol style="list-style-type: none"> <li>1. Absence of malfunction</li> <li>2. Proper response to zero span gas</li> </ol>	As recommended by manufacturer	As recommended by manufacturer
Integrated Sampling Tanks	<ol style="list-style-type: none"> <li>1. Absence of leaks</li> </ol>	Depends on nature of use	<ol style="list-style-type: none"> <li>1. Steam clean</li> <li>2. Leak check</li> </ol>
Mobile Van Sampling System	<ol style="list-style-type: none"> <li>1. Absence of leaks</li> </ol>	Depends on nature of use	<ol style="list-style-type: none"> <li>1. Change filters</li> <li>2. Change gas dryer</li> <li>3. Leak check</li> <li>4. Check for system contamination</li> </ol>
Sampling Lines	<ol style="list-style-type: none"> <li>1. Sample degradation less than 2%</li> </ol>	After each test series	<ol style="list-style-type: none"> <li>1. Blow dry, inert gas through line until dry</li> </ol>



**TABLE 2  
MAJOR SAMPLING EQUIPMENT CALIBRATION REQUIREMENTS**

Sampling Equipment	Calibration Frequency	Calibration Procedure	Acceptable Calibration Criteria
Continuous Analyzers	Before and After Each Test Day	3-point calibration error test	< 2% of analyzer range
Continuous Analyzers	Before and After Each Test Run	2-point sample system bias check	< 5% of analyzer range
Continuous Analyzers	After Each Test Run	2-point analyzer drift determination	< 3% of analyzer range
CEMS System	Beginning of Each Day	leak check	< 1 in. Hg decrease in 5 min. at > 20 in. Hg
Continuous Analyzers	Semi-Annually	3-point linearity	< 1% of analyzer range
NO <sub>x</sub> Analyzer	Daily	NO <sub>2</sub> -> NO converter efficiency	> 90%
Differential Pressure Gauges (except for manometers)	Semi-Annually	Correction factor based on 5-point comparison to standard	± 5%
Differential Pressure Gauges (except for manometers)	Bi-Monthly	3-point comparison to standard, no correction factor	± 5%
Barometer	Semi-Annually	Adjusted to mercury-in-glass or National Weather Service Station	± 0.1 inches Hg
Dry Gas Meter	Semi-Annually	Calibration check at 4 flow rates using a NIST traceable standard	± 2%
Dry Gas Meter	Bi-Monthly	Calibration check at 2 flow rates using a NIST traceable standard	± 2% of semi-annual factor
Dry Gas Meter Orifice	Annually	4-point calibration for ΔH@	--
Temperature Sensors	Semi-Annually	3-point calibration vs. NIST traceable standard	± 1.5%

Note: Calibration requirements that meet applicable regulatory agency requirements are used.

## **Appendix D.2 STAC Certification**



American Association for Laboratory Accreditation

## Accredited Air Emission Testing Body

A2LA has accredited

## MONTROSE AIR QUALITY SERVICES

In recognition of the successful completion of the joint A2LA and Stack Testing Accreditation Council (STAC) evaluation process, this laboratory is accredited to perform testing activities in compliance with ASTM D7036:2004 - Standard Practice for Competence of Air Emission Testing Bodies.



Presented this 27<sup>th</sup> day of February, 2024.

Vice President, Accreditation Services  
For the Accreditation Council  
Certificate Number: 3925.01  
Valid to February 28, 2026

*This accreditation program is not included under the A2LA ILAC Mutual Recognition Arrangement.*

## **Appendix D.3 Individual QI Certificates**

**CERTIFICATE OF COMPLETION**

**John Peterson**

This document certifies that this individual has passed a comprehensive examination and is now a Qualified Individual (QI) as defined in Section 8.3 of ASTM D7036-04 for the following method(s):

**BAAQMD ST-1B**

Certificate Number: 002-2022-22

*Tate Strickler*  
Tate Strickler, VP – Quality Systems

DATE OF ISSUE: 01/20/2022

DATE OF EXPIRATION: 01/19/2027

 **MONTROSE**  
ENVIRONMENTAL

## **THIS IS THE LAST PAGE OF THIS DOCUMENT**

If you have any questions, please contact one of the following individuals by email or phone.

Name: Mr. John Peterson  
Title: District Manager  
Region: West  
Email: [JPeterson@montrose-env.com](mailto:JPeterson@montrose-env.com)  
Phone: (714) 279-6777

Name: Mr. Matt McCune  
Title: Regional Vice President  
Region: West  
Email: [MMccune@montrose-env.com](mailto:MMccune@montrose-env.com)  
Phone: (714) 279-6777

## **COLD START-UP LOG**

**ORMOND BEACH POWER, LLC**  
**ORMOND BEACH GENERATING STATION**  
**COLD START-UP TRACKING**

January 2024    through    December 2024

<b>QTR.</b>	<b>MONTH</b>	<b>UNIT #1</b>	<b>UNIT #2</b>	<b>NAB</b>	<b>SAB</b>
1ST	January	0	1	1	1
	February	1	0	6	3
	March	0	0	0	0
2ND	April	0	0	0	0
	May	2	4	9	10
	June	1	1	1	2
3RD	July	1	1	2	5
	August	1	2	7	5
	September	2	2	5	6
4TH	October	0	1	1	1
	November	1	0	2	1
	December	0	0	0	0
<b>YTD REPORTING TOTAL:</b>		<b>9</b>	<b>12</b>	<b>34</b>	<b>34</b>

Note: The start-up #s above must be verified with the VCAPCD Air Quality Specialist

Cold Start = First 20 hrs runtime (Units 1&2) or >550°; 4 hrs runtime (N-Aux & S-Aux) no temp.



# **HIGH ACCURACY METER TEST**

# ORMOND BEACH GENERATING STATION HIGH ACCURACY ELECTRONIC WATT-HOUR METER TEST

Single Phase  
Poly Phase



(Glass)

WORK ORDER #:

LOCATION: OBGS      CIRCUIT: Whit / Generator MW      SERIAL #: 314202186  
 MANUFACTURER: SEL      MODEL: 735      WIRE: 3      PULSE/HOUR: 1151AC      NOMINAL ANALOG: 4.20 mA  
 WATTS: 5A      PHASE: 3      ELEMENT: 2      STD. SER. NO.:      STD. mA:      MULTIPLIER:      STD. WATTS:  
 P.T. RATIO: 240/1      C.T. RATIO: 2500/5      WATT-HOUR COUNT: 1236918.07      WATT-HOUR COUNT: 1236993.09

START OF TEST

TIME:

WATT DISPLAY 0.0

WATT-HOUR COUNT: 1236918.07

END OF TEST

TIME:

WATT DISPLAY 0.0

WATT-HOUR COUNT: 1236993.09

## TEST DATA

NOMINAL SETTINGS				DIGITAL OUTPUT				ANALOG OUTPUT				WATTS DISPLAY					
Sec. Volts	Sec. Amps	P.F.	TM Coil	Run Pulses	RO Count	Standard Count		IND %E	TRUE %E	UT mA	STD std. mA	IND. %E	TRUE %E	Display Watts	STD. Watts	IND. %E	TRUE %E
						Run #1	Run #2										
115	5.0	1.0				1.0	1.0			19.95	20.00			1195.0	1195.0		
115	4.167	1.0				1.0	1.0			17.30	17.30			996.0	996.0		
115	2.5	1.0				1.0	1.0			11.99	11.99			598.0	598.0		
115	2.083	1.0				1.0	1.0			10.66	10.66			498.0	498.0		
115	1.042	1.0				1.0	1.0			7.34	7.34			249.0	249.0		
115	0.50	1.0				1.0	1.0			5.61	5.61			119.4	119.3		
115	0.00	1.0				1.0	1.0			4.02	4.00			0.00	0.00		
AS FOUND / AS LEFT																	
COMMENTS: <u>Equip. - Actes 440</u>																	

Test Tech: Jim Samuel      Signed: Jim Samuel      Date: 12/28/2024  
 Contact Information: (805) 986-7294      Cell: (805) 377-5410      isamuel@obgs.com

# ORMOND BEACH GENERATING STATION HIGH ACCURACY ELECTRONIC WATT-HOUR METER TEST

Single Phase   
Poly Phase

LOCATION: 0865 WORK ORDER #: \_\_\_\_\_  
 MANUFACTURER: SEL SERIAL #: 314202187  
 WATTS: 34 PHASE: 3 ELEMENT: 2 MODEL: WHT / A.E. Trans. M/W  
 P.T. RATIO: 240/1 C.T. RATIO: 1200/5 WIRE: 3 VOLTS: 115VAC NOMINAL ANALOG: 4.20 mA  
 STD. ELE.: \_\_\_\_\_ STD. SER. NO.: \_\_\_\_\_ PULSE/HOUR: 5730 Ke: 18 MULTIPLIER: \_\_\_\_\_  
 \_\_\_\_\_ STD. WATTS: \_\_\_\_\_

START OF TEST TIME: \_\_\_\_\_  
 END OF TEST TIME: \_\_\_\_\_  
 WATT DISPLAY: 0.03  
 WATT-HOUR COUNT: 67033.07  
 WATT-HOUR COUNT: 67036.56

### TEST DATA

NOMINAL SETTINGS				DIGITAL OUTPUT				ANALOG OUTPUT				WATTS DISPLAY						
Sec. Volts	Sec. Amps	P.F.	T/M Coil	Run Pulses	RO Count	STD & IT % E	Standard Count		IND %E	TRUE %E	UT mA	STD std. mA	IND. % E	TRUE %E	Display Watts	STD. Watts	IND. %E	TRUE %E
				Run #1	Run #2	Ave.	Run #1	Run #2	Ave.									
115	5.00	1.0					1.0	Markets			20.00	20.00			57.27	57.26		
115	4.167	1.0					"	"			17.96	17.96			47.82	47.80		
115	2.50	1.0					"	"			12.03	12.03			28.70	28.69		
115	2.083	1.0					"	"			10.69	10.69			23.91	23.91		
115	1.042	1.0					"	"			7.36	7.36			11.96	11.96		
115	0.50	1.0					"	"			5.62	5.62			5.75	5.75		
115	0.00	1.0					"	"			4.02	4.00			0.03	0.00		

AS FOUND / AS LEFT

COMMENTS: Equip. - ARTES 440

Signed: Jim Samuel Date: 12/28/2024  
 Cell: (805) 377-5410 isamuel@scgen.com  
 Contact Information: \_\_\_\_\_

# ORMOND BEACH GENERATING STATION HIGH ACCURACY ELECTRONIC WATT-HOUR METER TEST

LOCATION: 0865 WORK ORDER #: \_\_\_\_\_  
 MANUFACTURER: SEL SERIAL #: 314202188  
 WATTS: 31 PHASE: 3 ELEMENT: 2 MODEL: 151AC VOLTS: \_\_\_\_\_  
 P.T RATIO: 240/1 C.T. RATIO: 2500/5 STD. SER. NO.: \_\_\_\_\_ PULSE/HOUR: 180000 Ke MULTIPLIER: \_\_\_\_\_  
 STD. ELE.: \_\_\_\_\_ WIRE: 3 STD. Ke: \_\_\_\_\_ STD. mA: \_\_\_\_\_  
 (Grass)

START OF TEST TIME: \_\_\_\_\_ WATT DISPLAY: 0.0  
 END OF TEST TIME: \_\_\_\_\_ WATT-HOUR COUNT: 1792335.72  
 WATT-HOUR COUNT: 1792413.17

### TEST DATA

NOMINAL SETTINGS				DIGITAL OUTPUT			ANALOG OUTPUT			WATTS DISPLAY						
Sec. Volts	Sec. Amps	P.F.	T.M. Coil	Run Pulses	RO Count	Standard Count		IND %E	TRUE %E	UT mA	STD. .mA	IND. %E	Display Watts	STD. Watts	IND. %E	TRUE %E
						Run #1	Run #2									
115	5.00	1.0				1.0				19.95	20.00		196.3	1795.00		
115	4.167	1.0				"	"			17.30	17.30		99.29	996.00		
115	2.50	1.0				"	"			11.99	11.99		598.0	598.49		
115	2.083	1.0				"	"			10.66	10.66		498.1	498.28		
115	1.042	1.0				"	"			7.34	7.34		349.0	349.00		
115	0.50	1.0				"	"			5.61	5.61		119.41	119.00		
115	0.00	1.0				"	"			4.02	4.00		0.0	0.00		

AS FOUND / AS LEFT

Sec. Volts	Sec. Amps	P.F.	T.M. Coil	Run Pulses	RO Count	Standard Count	IND %E	TRUE %E	UT mA	STD. .mA	IND. %E	Display Watts	STD. Watts	IND. %E	TRUE %E

COMMENTS: Equip. - APTES 476

Signed: *Jim Samuel* Date: 12/28/2024  
 Cell: (805) 377-5410  
 Contact Information: Jim Samuel (805) 986-7294  
 isamuel@gsb.com

# ORMOND BEACH GENERATING STATION HIGH ACCURACY ELECTRONIC WATT-HOUR METER TEST

Single Phase   
Poly Phase

LOCATION: 0895 WORK ORDER #: 314202185  
 MANUFACTURER: SEL SERIAL #: W12Ax. TANKS. MW  
 WATTS: 34 MODEL: 755 VOLTS: 115VAC NOMINAL ANALOG: 4-2 mA  
 P.T. RATIO: 240/1 PHASE: 3 ELEMENT: 2 WIRE: 3 PULSE/HOUR: 5700 Ke: 1.8 MULTIPLIER:  
 STD. ELE.: 1200/5 STD. SER. NO.: 1200/5 STD. Ke: 1.8 STD. WATTS:

START OF TEST TIME: 0.03 END OF TEST TIME: 0.03  
 WATT DISPLAY: 0.03 WATT DISPLAY: 0.03  
 WATT-HOUR COUNT: 86944.58 WATT-HOUR COUNT: 86944.58

### TEST DATA

NOMINAL SETTINGS				DIGITAL OUTPUT				ANALOG OUTPUT				WATTS DISPLAY						
Sec. Volts	Sec. Amps	P.F.	T/M Coil	Run Pulses	RO Count	STD & IT % E	Standard Count		IND % E	TRUE % E	UT mA	STD. std. mA	IND. % E	TRUE % E	Display Watts	STD. Watts	IND. % E	TRUE % E
					Run #1	Run #2	Ave.											
115	5.00	1.0			1.0	1.0	1.0	AS FOUND / AS LEFT										
115	4.67	1.0			"	"	"								57.4	57.3		
115	2.56	1.0			"	"	"								17.84	17.80		
115	2.083	1.0			"	"	"								28.70	28.69		
115	1.042	1.0			"	"	"								23.91	23.91		
115	0.50	1.0			"	"	"								11.95	11.96		
115	0.00	1.0			"	"	"								5.74	5.75		
					"	"	"								0.03	0.00		

COMMENTS: Exp. - Arise 440

Test Tech: Jim Samuel (805) 986-7294  
 Contact Information: Cell: (805) 397-5410  
 Signed: Samuel Samuel Date: 12/28/2024  
 Samuel G. Eberhart  
 Cell: COM

# ORMOND BEACH GENERATING STATION HIGH ACCURACY ELECTRONIC WATT-HOUR METER TEST

Single Phase   
Poly Phase

LOCATION: 089S WORK ORDER #: 34202189  
 MANUFACTURER: SEL SERIAL #: 1157AC  
 WATTS: 34 PHASE: 3 ELEMENT: 2 MODEL: 735 VOLTS: 115VAC NOMINAL ANALOG: 4-20 mA  
 P.T. RATIO: 120/1 C.T. RATIO: 600/5 WIRE: 3 PULSE/HOUR: 7200 KE: 1.8 MULTIPLIER: 1  
 STD. ELE.:          STD. SER. NO.:          STD. Ke:          STD. mA:          STD. WATTS:         

START OF TEST TIME: 0.03 END OF TEST TIME: 0.03  
 WATT DISPLAY: 0.03 WATT-HOUR COUNT: 142712.08  
 WATT-HOUR COUNT: 142716.75

## TEST DATA

NOMINAL SETTINGS					DIGITAL OUTPUT				ANALOG OUTPUT				WATTS DISPLAY				
Sec. Volts	Sec. Amps	P.F.	TMI Coil	Run Pulses	RO Count	Standard Count		IND %E	TRUE %E	UT mA	STD std. mA	IND. % E	TRUE %E	Display Watts	STD. Watts	IND. %E	TRUE %E
						Run #1	Run #2										
115	5.00	1.0				1.0				19.94	20.00			71.76	72.00		
115	4.167	1.0				11				17.29	17.33			59.79	59.75		
115	2.60	1.0				11				11.98	11.98			35.87	35.84		
115	2.083	1.0				11				10.65	10.65			29.88	29.87		
115	1.042	1.0				11				7.34	7.34			14.95	14.95		
115	0.50	1.0				11				5.61	5.61			7.17	7.18		
115	0.00	1.0				11				4.02	4.00			0.03	0.00		

AS FOUND / AS LEFT																	

COMMENTS: EQUIP. - APPROX 440

Test Tech: Jim Samuel (805) 986-7294  
 Contact Information:           
 Signed: Jim Samuel Date: 12/28/2024  
 Cell: (85) 377-5410 isamuel@gsb.com

**EMERGENCY GENERATOR  
RUN-TIME REPORT**

**ORMOND BEACH MONTHLY  
ENGINE RUN-TIME RECORDS**

FIRST OF MONTH	EMER. GENERATOR		RUNNING 12-MONTH	Operational Reason
	METER	TESTING		
Jan 2024	158.6	2.1	7.5	Bi-Annual Service
Feb 2024	160.7	0.1	7.6	Maintenance
Mar 2024	160.8	0.1	7.7	Maintenance
Apr 2024	160.9	0.0	7.4	Maintenance
May 2024	160.9	0.8	7.7	Maintenance
Jun 2024	161.7	0.0	6.4	Annual Service
Jul 2024	161.7	0.1	6.5	Maintenance
Aug 2024	161.8	0.6	6.8	Maintenance
Sep 2024	162.4	0.2	6.5	Maintenance
Oct 2024	162.6	0.1	4.2	Maintenance
Nov 2024	162.7	0.0	4.1	Maintenance
Dec 2024	162.7	0.7	4.8	Maintenance



# **CARB APPROVED DIESEL FUEL USE**

The Ormond Beach Generating Station did not purchase any fuel for the Emergency Diesel Engine Generator in 2024.


**RICE NESHAP**  
**ZZZZ REPORT**

**EMERGENCY DIESEL ENGINE  
2024 ANNUAL REPORT FORM**

Reporting Period: January 1 through December 31, 2024

**Due Date: See Notice to Supply Information (NTSI) Issued During Inspection**

Your APCD Permit to Operate requires your facility to submit reports of the annual hours of operation and/or maintenance and testing, and emergency use for each diesel emergency engine. If the annual operating hours, excluding emergency operation, exceed the specified annual permit limit, please include an explanation. Please Note: California Health and Safety Code 42304 requires the holder of an APCD Permit to Operate to furnish the information requested by the APCD within a reasonable time or the APCD may suspend the Permit to Operate.

<b>PERMIT NUMBER: 0065</b>			
Facility Name:	Ormond Beach Power, LLC	Contact:	Roger Kahle
Facility Address:	6635 Edison Drive	Title:	Environmental Specialist
Facility City:	Oxnard	Phone:	(805) 341-6167
<b>ENGINE DETAILS</b>			
Engine BHp Rating:		605	BHp 605
Engine Description (Manufacturer, Model, Serial Number, etc.):			
Cummings Model No. NTA855-G5 S/N: 11856001 Mftg. Year: 1997			
<b>REPORTING REQUIREMENTS FOR CALENDAR YEAR 2024</b>			
	Date of Reading		Meter Reading
First of 2024:	January 1, 2024	First of 2024:	158.6
End of 2024:	January 2, 2025	End of 2024:	163.4
<b>Total annual hours for: Maintenance &amp; Testing:</b>			4.8
Hours of Emergency use:			0
<b>Total Hours of operation:</b>			4.8
Has the engine listed above exceeded the permit limit for maintenance and testing? If yes, please explain here or <b>attach additional pages</b> :			
No The engine listed herein has not exceeded the permit limit.			
<b>Signature of person supplying the information: "I certify that the above information is correct."</b>			
Signature:		Date:	2-13-2025
Print Name:	Thomas A. Di Ciolli	Title:	Plant Manager
Phone #:	(805) 986-7241	Email:	thomas.diciolli@genon.com
<b>SEND REPORT TO:</b>			
Inspector Name:	Steve Bova	Email:	steve@vcapcd.org
Ventura County Air Pollution Control District 4567 Telephone Road, 2nd Floor, Ventura, CA 93003 or FAX: 805/456-7797			

**ORMOND BEACH MONTHLY  
ENGINE RUN-TIME RECORDS**

FIRST OF MONTH	EMER. GENERATOR		RUNNING 12-MONTH	Operational Reason
	METER	TESTING		
Jan 2024	158.6	2.1	7.5	Bi-Annual Service
Feb 2024	160.7	0.1	7.6	Maintenance
Mar 2024	160.8	0.1	7.7	Maintenance
Apr 2024	160.9	0.0	7.4	Maintenance
May 2024	160.9	0.8	7.7	Maintenance
Jun 2024	161.7	0.0	6.4	Annual Service
Jul 2024	161.7	0.1	6.5	Maintenance
Aug 2024	161.8	0.6	6.8	Maintenance
Sep 2024	162.4	0.2	6.5	Maintenance
Oct 2024	162.6	0.1	4.2	Maintenance
Nov 2024	162.7	0.0	4.1	Maintenance
Dec 2024	162.7	0.7	4.8	Maintenance

**EMERGENCY GENERATOR  
ANNUAL SERVICE**

**LEDDY POWER SYSTEMS, INC.**  
**SERVICE REPORT**

Service Date		Customer ID		Contact Name / Phone No.	
1/16/2024		GenOn Holdings		John / 805-985-7309	
Service Tech ID(s)		Reference / Invoice No.		Equipment Location	
1020-1011		2846		6635 Edison Dr, Oxnard, CA	
Equipment Make / Model No.		Serial No.	Spec No.	Eng. Hours (Start)	Eng. Hours (End)
CUMMINS/400DFCE		H970646232	89568B	158.7	160.7
Engine Make / Model No.		Serial No.	Spec No.	Fuel Type	Fuel Level
CUMMINS/NTA855-G5		11856001	41111	DIESEL	FULL
KW Rating	RPM Rating	HZ Rating	Voltage Rating	Application	DEF Level (T4F)
400	1800	60	480	STANDBY	N/A
<b>Reason for Service</b>		<b>Bi-Annual (6M) PM Generator Service and Load Bank</b>			
<b>Multi-Point Inspection</b>					
<b>X</b>	<b>No Action Required</b>	<b>W</b>	<b>Warning / Action Required</b>	<b>N</b>	<b>Not Applicable</b>
General			Cooling System		
Inspect outside of the equipment and area		X	Inspect coolant level		W
Inspect enclosure and access doors		X	Inspect radiator and expansion tank		X
Inspect seismic anchoring		X	Inspect radiator fan and fan clutch		X
Inspect engine block and cylinder head		X	Inspect hoses		W
Inspect engine mounts		X	Inspect block heater(s)		X
Inspect AC generator and mounting		X	Inspect coolant pump(s)		X
Instrumentation			Inspect raw water pump(s)		N
Inspect controls and instrumentation		X	Inspect belt(s) and pulley(s)		X
Inspect for active alarms and fault codes		X	Inspect heat exchanger(s), cooler(s), zinc anode(s)		N
Inspect operating parameters while running		X	Lubrication System		
Inspect remote annunciator(s)		X	Inspect oil level and condition		X
Electrical			Inspect oil PSI		X
Inspect wiring, connections, and conduit		X	Inspect oil lines/hoses for leaks and damages		X
Inspect batteries		X	Inspect oil filter(s)		X
Inspect battery charger(s)		X	Air Intake / Ventilation / Exhaust System		
Inspect alternator(s)		X	Inspect air filter(s) and piping		X
Inspect belt(s) and pulley(s)		X	Inspect crankcase ventilation		X
Inspect engine starting system		X	Inspect air to air cooler		N
Inspect spark ignition system (NG/LP Only)		N	Inspect air ventilation louver motor(s) and controls		X
Fuel System			Inspect exhaust manifold and piping		X
Inspect fuel level		X	Inspect turbocharger(s)		X
Inspect fuel tank		X	Inspect muffler(s)		X
Inspect fuel pump(s)		X	Inspect DEF level and tank		N
Inspect fuel PSI(s)		X	Inspect dosage valve, hoses, and pump		N
Inspect fuel lines, hoses, filters, and manifolds		X	Inspect SCR catalysts and EATS		N
Inspect regulator(s) and shutoff(s) (NG/LP Only)		N	Inspect diesel particulate filter		N
Inspection Comments					
(W) Found coolant to be 3 gal. low and air relief coolant hose had burst. Customer tagged failed hose on 1/13/2024.					
Detailed Service Summary					

**LEDDY POWER SYSTEMS, INC.**  
**SERVICE REPORT**

Performed Bi-Annual (6M) PM Generator Service. Performed multipoint inspection. Found blown air relief coolant hose. Went to California Hose and had new hose made. Installed hose and filled unit with 3 gal. of coolant. Test ran unit. Hooked up load bank and performed 2hr load bank. Unit performed with no issues. Disconnected load bank and reconnected generator to building.

Please, refer to Leddy Power Systems, Inc. Terms and Conditions of Sale and Service.



**LEDDY POWER SYSTEMS, INC.  
SERVICE REPORT**

Service Date		Customer ID		Contact Name / Phone No.	
06/13/2024		GenOn Holdings		Todd Kinsley / (909) 285-7707	
Service Tech ID(s)		Reference / Invoice No.		Equipment Location	
1023		3001		6635 Edison Dr, Oxnard, CA	
Equipment Make / Model No.		Serial No.	Spec No.	Eng. Hours (Start)	Eng. Hours (End)
Cummins/ 400DFCE		H970646232	89568B	161.7	161.7
Engine Make / Model No.		Serial No.	Spec No.	Fuel Type	Fuel Level
Cummins/ NTA855-65		11856001	41111	Diesel	90%
KW Rating	RPM Rating	HZ Rating	Voltage Rating	Application	DEF Level (T4F)
400	1800	60	120/208	Standby	N/A
<b>Reason for Service</b>		<b>Annual Level 2 PM Generator Service</b>			
<b>Multi-Point Inspection</b>					
<b>X</b>	<b>No Action Required</b>	<b>W</b>	<b>Warning / Action Required</b>	<b>N</b>	<b>Not Applicable</b>
General			Cooling System		
Inspect outside of the equipment and area		X	Inspect coolant level		X
Inspect enclosure and access doors		X	Inspect radiator and expansion tank		X
Inspect seismic anchoring		X	Inspect radiator fan and fan clutch		X
Inspect engine block and cylinder head		X	Inspect hoses		X
Inspect engine mounts		X	Inspect block heater(s)		X
Inspect AC generator and mounting		X	Inspect coolant pump(s)		X
Instrumentation			Inspect raw water pump(s)		N
Inspect controls and instrumentation		X	Inspect belt(s) and pulley(s)		X
Inspect for active alarms and fault codes		X	Inspect heat exchanger(s), cooler(s), zinc anode(s)		N
Inspect operating parameters while running		X	Lubrication System		
Inspect remote annunciator(s)		N	Inspect oil level and condition		X
Electrical			Inspect oil PSI		X
Inspect wiring, connections, and conduit		X	Inspect oil lines/hoses for leaks and damages		X
Inspect batteries		X	Inspect oil filter(s)		X
Inspect battery charger(s)		X	Air Intake / Ventilation / Exhaust System		
Inspect alternator(s)		X	Inspect air filter(s) and piping		X
Inspect belt(s) and pulley(s)		X	Inspect crankcase ventilation		X
Inspect engine starting system		X	Inspect air to air cooler		X
Inspect spark ignition system (NG/LP Only)		N	Inspect air ventilation louver motor(s) and controls		X
Fuel System			Inspect exhaust manifold and piping		X
Inspect fuel level		X	Inspect turbocharger(s)		X
Inspect fuel tank		X	Inspect muffler(s)		X
Inspect fuel pump(s)		X	Inspect DEF level and tank		N
Inspect fuel PSI(s)		X	Inspect dosage valve, hoses, and pump		N
Inspect fuel lines, hoses, filters, and manifolds		X	Inspect SCR catalysts and EATS		N
Inspect regulator(s) and shutoff(s) (NG/LP Only)		N	Inspect diesel particulate filter		N
Inspection Comments					

**Detailed Service Summary**

Completed multi-point inspection, replaced oil/ oil filter, coolant filter, air filter, fuel and fuel water separator filters. Took fuel and oil samples. ran unit for approximately 5 min. unit was found in off position, technician was told by site contact to leave in off position.

Please, refer to Leddy Power Systems, Inc. Terms and Conditions of Sale and Service.

## **SOLVENT & AEROSOL USE LOG**







Purchases Added												
Total	22	22	22	22	22	22	22	22	22	22	22	22
Monthly Usage												
<b>18. RTV Silicone</b>												
Starting Inventory	8	8	8	8	8	8	8	8	8	8	8	8
Purchases Added												
Total	8	8	8	8	8	8	8	8	8	8	8	8
Monthly Usage												
<b>19. CRC Food Grade Silicone 3.3 oz.</b>												
Starting Inventory	23	23	23	23	23	21	21	21	19	19	19	19
Purchases Added												
Total	23	23	23	23	21	21	21	19	19	19	19	19
Monthly Usage					2			1				
<b>20. Jump Start</b>												
Starting Inventory	20	20	20	20	20	20	20	20	20	20	20	20
Purchases Added												
Total	20	20	20	20	20	20	20	20	20	20	20	20
Monthly Usage												
<b>21. Crystal Clear</b>												
Starting Inventory	15	15	15	15	15	15	15	15	15	15	15	15
Purchases Added												
Total	15	15	15	15	15	15	15	15	15	15	15	15
Monthly Usage												
<b>22. Red Insulating Varnish</b>												
Starting Inventory	7	7	7	6	4	4	4	4	4	11	10	10
Purchases Added				2					12			
Total	7	7	6	4	4	4	4	4	11	10	10	10
Monthly Usage			1	4					5	1		
<b>23. Red Paint</b>												
Starting Inventory	8	8	8	8	13	13	13	13	13	13	13	13
Purchases Added				7								
Total	8	8	8	13	13	13	13	13	13	13	13	13
Monthly Usage				2								
<b>24. Royal Blue Paint</b>												
Starting Inventory	10	6	9	16	16	16	15	15	15	15	13	13
Purchases Added		4	7									
Total	6	10	16	16	16	15	15	15	15	13	13	13
Monthly Usage	4	1				1				2		
<b>25. Gray Primer</b>												
Starting Inventory	15	12	12	13	13	13	11	11	11	11	7	7
Purchases Added			3	2		4						

Total	12	12		13	13	7	11	11	11	7	7	7
Monthly Usage	3		2	2		6				4		
<b>26. White Paint</b>												
Starting Inventory	4	4	4	4	4	4	17	17	17	17	17	17
Purchases Added						14						
Total	4	4	4	4	4	17	17	17	17	17	17	17
Monthly Usage						1						
<b>27. Semi-Gloss/Flat Black</b>												
Starting Inventory	10	7	17	17	17	17	17	17	17	17	17	17
Purchases Added		12										
Total		19	17	17	17	17	17	17	17	17	17	17
Monthly Usage	3	2										
<b>28. Gloss Black</b>												
Starting Inventory	8	5	16	13	8	8	7	7	7	7	10	10
Purchases Added		12								4		
Total	5	17	13	8	8	7	7	7	7	10	10	10
Monthly Usage	3	1	3	5		1				1		
<b>29. High Heat Aluminum Paint</b>												
Starting Inventory	8	8	8	8	8	8	8	8	8	8	8	8
Purchases Added												
Total	8	8	8	8	8	8	8	8	8	8	8	8
Monthly Usage												
<b>30. FLEX SEAL</b>												
Starting Inventory	8	8	8	8	8	8	8	8	8	8	8	8
Purchases Added												
Total	8	8	8	8	8	8	8	8	8	8	8	8
Monthly Usage												
<b>31. Dykem Aerosol Remover</b>												
Starting Inventory	6	5	5	5	5	5	5	5	5	5	5	5
Purchases Added												
Total	5	5	5	5	5	5	5	5	5	5	5	5
Monthly Usage	1											
<b>32. White Lithium</b>												
Starting Inventory	7	15	15	15	15	14	14	14	14	14	14	14
Purchases Added	12											
Total	15	15	15	15	14	14	14	14	14	14	14	14
Monthly Usage	4				1							
<b>33. Glass Cleaner</b>												
Starting Inventory	7	9	9	7	7	7	7	5	5	14	13	13
Purchases Added	3								10			
Total	9	9	7	7	7	7	5	5	14	13	13	13



Monthly Usage	1		2				2		1	1		
<b>34. Yellow/White Marker Paint</b>												
Starting Inventory	3	3	3	3	3	3	3	3	3	3	3	3
Purchases Added												
Total	3	3	3	3	3	3	3	3	3	3	3	3
Monthly Usage												
<b>35. High Heat Black Paint</b>												
Starting Inventory	7	7	7	7	7	7	7	7	7	7	7	7
Purchases Added												
Total	7	7	7	7	7	7	7	7	7	7	7	7
Monthly Usage												
<b>36. Gray(Stainless)Paint</b>												
Starting Inventory	4	4	4	4	4	4	4	4	4	4	4	4
Purchases Added												
Total	4	4	4	4	4	4	4	4	4	4	4	4
Monthly Usage												
<b>38. Contact Cleaner</b>												
Starting Inventory	9	3	10	9	6	0	10	17	7	7	19	13
Purchases Added	12	15	21	9		18	11	3	12	27		
Total	3	18	9	6	0	18	17	7	7	19	13	11
Monthly Usage	24	8	25	12	6	8	4	14	12	8	6	2
<b>39. Fluid Film/Linebacker</b>												
Starting Inventory	11	11	10	20	20	20	20	13	11	21	19	19
Purchases Added			10					3	12	2		
Total	11	10	20	20	20	20	20	11	21	19	19	15
Monthly Usage		1					7	5	2	4		4
<b>40. Polyurethane Foam Sealant</b>												
Starting Inventory	9	8	8	8	8	8	8	8	8	8	8	8
Purchases Added												
Total	8	8	8	8	8	8	8	8	8	8	8	8
Monthly Usage	1											
<b>41. Spray Adhesive</b>												
Starting Inventory	32	31	31	28	28	21	21	20	20	20	19	19
Purchases Added												
Total	31	31	28	28	21	21	20	20	20	19	19	19
Monthly Usage	1		3		7		1			1		

**CUMULATIVE EMISSIONS  
OPERATING HOURS & FUEL USE**

# Cumulative Emissions

Plant: ORB

Cumulative Emissions for: 2024

	AUX-N				AUX-S			
	GASFLOW KSCFH	NOX#/HR LB/HR	UNITOPHR OpTime	UNITOPHR OpHrs	GASFLOW KSCFH	NOX#/HR LB/HR	UNITOPHR OpTime	UNITOPHR OpHrs
January	1,358.6	45.7	22.1	23	1,474.8	42.7	24.7	26
February	3,660.9	136.7	63.4	69	3,985.5	119.7	57.6	62
March	0.1	0.0	0.0	1	25.6	0.0	0.1	1
April	0.0	0.0	0.0	0	0.0	0.0	0.0	0
May	11,305.4	386.4	134.1	142	19,809.8	583.0	251.1	261
June	3,528.1	111.4	33.6	36	4,473.0	120.1	47.5	50
July	3,869.6	115.9	48.5	50	4,733.2	132.3	75.6	82
August	7,398.6	254.3	96.2	103	6,898.8	186.5	87.8	94
September	5,320.3	137.8	63.9	70	9,467.7	235.8	112.4	119
October	1,482.3	46.5	29.2	31	1,753.2	41.8	32.2	34
November	1,980.5	64.5	27.8	30	1,989.1	59.3	26.2	27
December	0.0	0.0	0.0	0	0.0	0.0	0.0	0
Quarter 1	5,019.7	182.3	85.5	93	5,486.0	162.4	82.5	89
Quarter 2	14,833.5	497.8	167.7	178	24,282.7	703.1	298.6	311
Quarter 3	16,588.6	508.0	208.5	223	21,099.7	554.7	275.8	295
Quarter 4	3,462.8	111.0	57.0	61	3,742.3	101.1	58.4	61
YTD	<b>39,904.6</b>	<b>1,299.1</b>	<b>518.7</b>	<b>555</b>	<b>54,610.7</b>	<b>1,521.3</b>	<b>715.2</b>	<b>756</b>

# Cumulative Emissions

Plant: ORB

Cumulative Emissions for: 2024

	ORB1				ORB2			
	GASFLOW HSCFH	NOX#/HR LBS/HR	UNITOPHR OpTime	UNITOPHR OpHrs	GASFLOW HSCFH	NOX#/HR LBS/HR	UNITOPHR OpTime	UNITOPHR OpHrs
January	0.0	0.0	0.0	0	47,591.2	74.4	10.4	11
February	75,527.6	651.0	15.0	16	0.0	0.0	0.0	0
March	0.0	0.0	0.0	0	0.0	0.0	0.0	0
April	0.0	0.0	0.0	0	0.0	0.0	0.0	0
May	370,450.1	617.5	25.3	27	330,213.3	526.2	29.0	33
June	309,611.9	521.4	22.6	24	3,454.8	4.3	1.3	3
July	6,098.8	6.4	2.8	4	320,052.0	155.9	32.4	34
August	396,313.1	388.5	20.2	22	462,775.3	418.9	26.1	29
September	1,538,668.2	1,327.0	84.8	87	1,587,705.8	1,012.2	99.8	101
October	0.0	0.0	0.0	0	90,036.0	89.2	17.1	18
November	96,950.1	204.7	12.6	13	0.0	0.0	0.0	0
December	0.0	0.0	0.0	0	0.0	0.0	0.0	0
Quarter 1	75,527.6	651.0	15.0	16	47,591.2	74.4	10.4	11
Quarter 2	680,061.9	1,138.9	47.9	51	333,668.1	530.5	30.4	36
Quarter 3	1,941,080.0	1,721.9	107.8	113	2,370,533.0	1,586.9	158.2	164
Quarter 4	96,950.1	204.7	12.6	13	90,036.0	89.2	17.1	18
YTD	<b>2,793,619.6</b>	<b>3,716.5</b>	<b>183.3</b>	<b>193</b>	<b>2,841,828.3</b>	<b>2,281.0</b>	<b>216.1</b>	<b>229</b>

# **VISUAL EMISSIONS REPORT**



July 15, 2024

Mr. Roger Kahle  
Ormond Beach Power, LLC  
6635 S. Edison Drive  
Oxnard, California 93033

**Subject: Ormond Beach Unit 1, Auxiliary Boiler North, Auxiliary Boiler South, and  
Emergency Standby Engine Visual Emissions Report - 2024  
Report Number: W002AS-041566-RT-6251**

Dear Roger,

Montrose Air Quality Services, LLC (MAQS) performed visual emission opacity observations for Ormond Beach Generating Station Four Sources: Unit 1, Auxiliary Boiler North, Auxiliary Boiler South, and Emergency Standby Engine on June 11, 2024. Josh Suzuki, a CARB certified visible emission evaluator (most recent re-certification performed 1/24/2024), performed the tests.

The results of the tests show that no visible emissions were observed during the tests for Unit 1, Auxiliary Boiler North, Emergency standby engine, and Auxiliary Boiler South. The maximum opacity was observed at 0% for all the sources which is less than the 20% opacity limit stipulated in Ventura County Air Pollution Control District (VCAPCD) Rule 50. The raw data sheets are provided as an attachment.

Please give me a call if you have any questions or comments regarding this report at (714) 279-6777.

Sincerely,

A handwritten signature in black ink that reads "Josh Suzuki".

Josh Suzuki  
Field Project Manager  
**Montrose Air Quality Services, LLC**

JS/rcr  
Attachments

## **ATTACHMENTS**

VISIBLE EMISSION OBSERVATION DATA SHEET


38715  
 Facility Name: NRG Ormond Beach  
 Street Address: 6635 Edison Dr  
 City: Oxnard State: CA Zip: 93033  
 Phone: \_\_\_\_\_

Process Equipment: Unit 1 Operating Mode: on  
 Control Equipment: \_\_\_\_\_ Operating Mode: \_\_\_\_\_

Describe Emission Point:  
stack exit  
 Ht. Above Ground Level: 200' Ht. Rel. to Observer: 200'  
 Dist. from Observer: 600' Dir. from Observer: NE

Describe Emissions  
 Start: None End: None  
 Emission Color: \_\_\_\_\_  
 Start: N/A End: N/A  
 Water Plume Present? Yes  
 Point in the Plume at which Opacity was Determined:  
stack exit

Describe Plume Background:  
sky  
 Background Color:  
 Start: gray End: gray  
 Sky Conditions:  
 Start: OVC End: OVC  
 Wind Speed:  
 Start: 5mph End: 5mph  
 Wind Direction:  
 Start: S End: S  
 Ambient Temperature:  
 Start: 62° End: 62°



Observation Date:	Start Time	End Time:	Seconds			
<u>6/11/2024</u>	<u>1643</u>	<u>1703</u>	0	15	30	45
Minute	0	15	30	45		
1	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
2	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
3	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
4	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
5	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
6	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
7						
8	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
9	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
10	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
11	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
12	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
13	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
14						
15	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
16	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
17	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
18	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
19	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
20	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
21						
22						
23						
24						
25						
26						
27						
28						
29						
30						
31						
32						
33						
34						
35						
36						
37						
38						
39						
40						

Observers Name: Josh Suzuki  
 Observers Signature: [Signature] Date: 6/11/2024  
 Company Name: Montrose Air Quality Services  
 Certified By: \_\_\_\_\_ Date: \_\_\_\_\_  
 Cal. Air Resources Board

DS903062

Date of Last Revision 2/10/2017

W002AS-041566-RT-6251

Master Documents/Forms/Datasheets/Field Datasheets



VISIBLE EMISSION OBSERVATION DATA SHEET

SA  
7115


Facility Name: TRG Ormond Beach  
 Street Address: 6635 Edison Dr  
 City: Oxnard State: CA Zip: 93033  
 Phone: \_\_\_\_\_

Process Equipment: Diesel Generator Operating Mode: ON  
 Control Equipment: \_\_\_\_\_ Operating Mode: \_\_\_\_\_

Describe Emission Point: Stack exit  
 Ht. Above Ground Level: 10' Ht. Rel. to Observer: 10'  
 Dist. from Observer: 30' Dir. from Observer: NE

Describe Emissions  
 Start: None End: None  
 Emission Color: Start: N/A End: N/A  
 Water Plume Present? No  
 Point in the Plume at which Opacity was Determined: stack exit

Describe Plume Background: sky  
 Background Color: Start: gray End: gray  
 Sky Conditions: Start: oVC End: oVC  
 Wind Speed: Start: 5mph End: 5mph  
 Wind Direction: Start: SE End: SE  
 Ambient Temperature: Start: 62° End: 62°



Observation Date:	Start Time	End Time:	Seconds				
6/11/2024	1554	1614	Minute	0	15	30	45
1	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>			
2	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>			
3	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>			
4	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>			
5	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>			
6	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>			
7							
8	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>			
9	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>			
10	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>			
11	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>			
12	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>			
13	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>			
14							
15	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>			
16	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>			
17	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>			
18	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>			
19	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>			
20	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>			
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							
32							
33							
34							
35							
36							
37							
38							
39							
40							

Observers Name: Josh Suzuki  
 Observers Signature: \_\_\_\_\_ Date: 6/11/2024  
 Company Name: Montrose Air Quality Services  
 Certified By: \_\_\_\_\_ Date: \_\_\_\_\_  
 Cal. Air Resources Board

DS903062

Date of Last Revision 2/10/2017

W002AS-041566-RT-6251

Master Documents/Forms/Datasheets/Field Datasheets

VISIBLE EMISSION OBSERVATION DATA SHEET


SA Facility Name: NRG Ormond Beach  
 Street Address: 6635 Edison Dr  
 City: Oxnard State: CA Zip: 93033  
 Phone: \_\_\_\_\_

Process Equipment: Aux Boiler N Operating Mode: on  
 Control Equipment: \_\_\_\_\_ Operating Mode: \_\_\_\_\_

Describe Emission Point: stack exit  
 Ht. Above Ground Level: 50' Ht. Rel. to Observer: 50'  
 Dist. from Observer: 150' Dir. from Observer: NW

Describe Emissions  
 Start: None End: None  
 Emission Color: \_\_\_\_\_  
 Start: N/A End: N/A  
 Water Plume Present? No  
 Point in the Plume at which Opacity was Determined: stack exit

Describe Plume Background: sky  
 Background Color: \_\_\_\_\_  
 Start: gray End: gray  
 Sky Conditions: \_\_\_\_\_  
 Start: OVC End: OVC  
 Wind Speed: \_\_\_\_\_  
 Start: 3mph End: 3mph  
 Wind Direction: \_\_\_\_\_  
 Start: NE End: NE  
 Ambient Temperature: \_\_\_\_\_  
 Start: 63° End: 63°



Observation Date:	Start Time:	End Time:	Seconds				
6/11/2024	1620	1640	Minute	0	15	30	45
1	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
2	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
3	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
4	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
5	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
6	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
7	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
8	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
9	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
10	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
11	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
12	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
13	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
14	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
15	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
16	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
17	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
18	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
19	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
20	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
21	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
22	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
23	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
24	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
25	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
26	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
27	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
28	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
29	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
30	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
31	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
32	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
33	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
34	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
35	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
36	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
37	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
38	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
39	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
40	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>

Observers Name: Josh Suzuki  
 Observers Signature:  Date: 6/11/2024  
 Company Name: Montrose Air Quality Services  
 Certified By: \_\_\_\_\_ Date: \_\_\_\_\_  
 Cal. Air Resources Board

VISIBLE EMISSION OBSERVATION DATA SHEET

sa 7/15


Facility Name: NRG Ormond Beach  
 Street Address: 6635 Edison Dr  
 City: Ormond State: CA Zip: 93033  
 Phone: \_\_\_\_\_

Process Equipment: Aux Boiler S Operating Mode: on  
 Control Equipment: \_\_\_\_\_ Operating Mode: \_\_\_\_\_

Describe Emission Point:  
stack exit  
 Ht. Above Ground Level: 50' Ht. Rel. to Observer: 50'  
 Dist. from Observer: 150' Dir. from Observer: NW

Describe Emissions  
 Start: None End: None  
 Emission Color: \_\_\_\_\_  
 Start: N/A End: N/A  
 Water Plume Present? No  
 Point in the Plume at which Opacity was Determined:  
stack exit

Describe Plume Background:  
sky  
 Background Color:  
 Start: gray End: gray  
 Sky Conditions:  
 Start: OVC End: OVC  
 Wind Speed:  
 Start: 3mph End: 3mph  
 Wind Direction:  
 Start: NE End: NE  
 Ambient Temperature:  
 Start: 63° End: 63°



Observation Date:	Start Time	End Time:	Seconds			
<u>6/11/2024</u>	<u>1620</u>	<u>1640</u>	0	15	30	45
Minute	0	15	30	45		
1	0	0	0	0		
2	0	0	0	0		
3	0	0	0	0		
4	0	0	0	0		
5	0	0	0	0		
6	0	0	0	0		
7						
8	0	0	0	0		
9	0	0	0	0		
10	0	0	0	0		
11	0	0	0	0		
12	0	0	0	0		
13	0	0	0	0		
14						
15	0	0	0	0		
16	0	0	0	0		
17	0	0	0	0		
18	0	0	0	0		
19	0	0	0	0		
20	0	0	0	0		
21						
22						
23						
24						
25						
26						
27						
28						
29						
30						
31						
32						
33						
34						
35						
36						
37						
38						
39						
40						

Observers Name: Josh Suzuki  
 Observers Signature: [Signature] Date: 6/11/2024  
 Company Name: Montrose Air Quality Services  
 Certified By: \_\_\_\_\_ Date: \_\_\_\_\_  
 Cal. Air Resources Board

DS903062

Date of Last Revision 2/10/2017

W002AS-041566-RT-6251

Master Documents/Forms/Datasheets/Field Datasheets



Air Quality Training Program

*Awards This Certificate To*

**Josh Suzuki**

*For Completion Of*

**MM106 - Visible Emissions Evaluation: Day Certification**

In  
El Cajon

On  
Wednesday, January 24, 2024

This certificate expires six months after the evaluation completion date.

A handwritten signature in black ink that reads 'Heather Quiros'.

Heather Quiros, Acting Chief

## **THIS IS THE LAST PAGE OF THIS DOCUMENT**

If you have any questions, please contact one of the following individuals by email or phone.

Name: Mr. Matt McCune  
Title: Regional Vice President  
Region: West  
Email: [MMccune@montrose-env.com](mailto:MMccune@montrose-env.com)  
Phone: (714) 279-6777



August 29, 2024

Mr. Roger Kahle  
Ormond Beach Power, LLC  
6635 S. Edison Drive  
Oxnard, California 93033

**Subject: Ormond Beach Unit 2 Visual Emissions Report – 3Q24**  
**Report Number: W002AS-045002-RT-6472**

Dear Roger,

Montrose Air Quality Services, LLC (MAQS) performed visual emission opacity observations for Ormond Beach Unit 2 on August 28, 2024. Surya Adhikari, a CARB certified visible emission evaluator (most recent re-certification performed 8/1/2024), performed the tests.

The results of the tests show that no visible emissions were observed during the test. The raw data sheets are provided as an attachment.

Please give me a call if you have any questions or comments regarding this report at (714) 279-6777.

Sincerely,

A handwritten signature in black ink, appearing to read "Surya", with a long horizontal flourish extending to the right.


Surya Adhikari  
Senior Reporting QC Specialist  
**Montrose Air Quality Services, LLC**

SA/rcr  
Attachments

## ATTACHMENTS

# FIGURE 9-1. RECORD OF VISUAL DETERMINATION OF OPACITY

Company: Ormond Beach Power, LLC  
 Location: Unit-2  
 Test No.: 1-2-3-VEE-2  
 Date: 8-28-2024  
 Type Facility: Natural gas Utility Boiler  
 Control Device: SCR  
 Hours of Observation: 11:28 - 11:45  
 Observer: Surya Adhikari  
 Observer Certification Date: 8/1/2024  
 Point of Emissions: Stack  
 Observer Affiliation: Montrose Environmental  
 Height of Discharge Point: ~ 220'



### KEY

- X = Observer
- = Sun
- WD = Wind Direction
- O = Stack

CLOCK TIME	Initial	Final
Distance to Discharge	~ 700'	~ 700' <sup>SA</sup> 11/18
Direction from Discharge	N	N
Height of Observation Point	Ground	Ground
BACKGROUND DESCRIPTION	SKY - Pt. cloudy	SKY - Pt. cloudy
WEATHER CONDITIONS		
Wind Direction	SW	SW
Wind Speed	6 mph	7 mph
Ambient Temperature	69°F	70°F
SKY CONDITIONS (clear, over-cast, % clouds, etc.)	partly cloudy	partly cloudy
PLUME DESCRIPTION		
Color	Steam	steam
Distance Visible	1/2 - 3/4 mile	1/2 - 3/4 mile
OTHER INFORMATION		

### SUMMARY OF AVERAGE OPACITY

Set Number	Time Start - End	Opacity	
		Sum	Average
1	11:28 - 11:33	0	0
2	11:34 - 11:39	0	0
3	11:40 - 11:45	0	0

Readings ranged from 0 to 0 % opacity.  
 The source was/was not in compliance with        at the time the evaluation was made.



Figure 9-2. Observation record.



Company Ormond Beach Observer Surya Adhikan  
 Location Unit-2 Type facility Natural gas Utility Boiler  
 Test Number 1-2-3 = VEE Point of emissions Stack

HR.	MIN.	SECONDS				STEAM PLUME (check if applicable)		Comments
		0	15	30	45	ATTACHED	DETACHED	
	0							
	1							
	2							
	3							
	4							
	5							
	6							
	7							
	8							
	9							
	10							
	11							
	12							
	13							
	14							
	15							
	16							
	17							
	18							
	19							
	20							
	21							
	22							
	23							
	24							
	25							
	26							
	27							
R1	28	00	00	00	00	Steam plume		Thick attached steam plume
	29	00	00	00	00			
	30	00	00	00	00			
R2	31	00	00	00	00			
	32	00	00	00	00			
	33	00	00	00	00			
	34	00	00	00	00			
	35	00	00	00	00			
	36	00	00	00	00			
R3	37	00	00	00	00			
	38	00	00	00	00			
	39	00	00	00	00			
	40	00	00	00	00			
	41	00	00	00	00			
	42	00	00	00	00			
	43	00	00	00	00			
	44	00	00	00	00			
	45	00	00	00	00			
46								
47								
48								
49								
50								
51								
52								
53								
54								
55								
56								
57								
58								
59								



Air Quality Training Program

*Awards This Certificate To*

**Surya Adhikari**

*For Completion Of*

**MM106 - Visible Emissions Evaluation: Day Certification**

In  
Long Beach

On  
Thursday, August 1, 2024

This certificate expires six months after the evaluation completion date.

A handwritten signature in blue ink that reads 'Heather Quiros'. The signature is written in a cursive style.

---

Heather Quiros, Chief  
Enforcement Division


## **THIS IS THE LAST PAGE OF THIS DOCUMENT**

If you have any questions, please contact one of the following individuals by email or phone.

Name: Mr. Surya Adhikari  
Title: Senior Reporting QC Specialist  
Region: West  
Email: [suadhikari@montrose-env.com](mailto:suadhikari@montrose-env.com)  
Phone: (714) 279-6777

Name: Mr. Matt McCune  
Title: Regional Vice President  
Region: West  
Email: [MMccune@montrose-env.com](mailto:MMccune@montrose-env.com)  
Phone: (714) 279-6777

# **ANNUAL GAS CERTIFICATION**



## Atmospheric Analysis & Consulting, Inc.

---

CLIENT : Ormond Power LLC/Genon  
PROJECT NAME : Annual Natural Gas  
AAC PROJECT NO. : 241349  
REPORT DATE : 06/24/2024


On June 11<sup>th</sup> 2024, Atmospheric Analysis & Consulting, Inc. received one (1) Tedlar Bag for BTU analysis by ASTM D-3588/5504. Upon receipt, the sample was assigned a unique Laboratory ID number as follows:

Client ID	Lab No.
Ormond Power LLC	241349-59592


This analysis is performed in accordance with AAC's Quality Manual. Test results apply to the sample(s) as received. For detailed information pertaining to specific EPA, NCASI, ASTM and SCAQMD accreditations (Methods & Analytes), please visit our website at [www.aaclab.com](http://www.aaclab.com).

I certify that this data is technically accurate, complete, and in compliance with the terms and conditions of the contract. No problems were encountered during receiving, preparation, and/or analysis of this sample. The Technical Director or his/her designee, as verified by the following signature, has authorized release of the data.

If you have any questions or require further explanation of data results, please contact the undersigned.

  
Sucha Parmar, Ph.D.  
Technical Director

This report consists of 7 pages.



# Atmospheric Analysis & Consulting, Inc.

## Laboratory Analysis Report ASTM-D3588 (BTU and F-Factor)


CLIENT : Ormond Power LLC/Genon  
PROJECT NO. : 241349

SAMPLING DATE : 06/11/2024  
ANALYSIS DATE : 06/13/2024

Client ID: AAC ID:		Ormond Power LLC 241349-59592			
Component		Mole %	Mole % SRL	Weight %	Weight % SRL
FIXED GASES	H <sub>2</sub>	< 0.100	1.00	< 0.001	0.001
	O <sub>2</sub>	0.494	0.100	0.904	0.002
	N <sub>2</sub>	2.57	0.100	4.12	0.001
	CO	< 0.100	0.100	< 0.001	0.001
	CO <sub>2</sub>	0.787	0.100	1.98	0.002
	CH <sub>4</sub>	91.1	0.00005	83.6	0.004
	He	NM	NM	NM	NM
	Ar	< 0.100	0.100	< 0.002	0.002
HYDROCARBONS	C <sub>2</sub> (as Ethane)	4.41	0.00005	7.58	0.0001
	C <sub>3</sub> (as Propane)	0.492	0.00005	1.24	0.0001
	C <sub>4</sub> (as Butane)	0.127	0.00005	0.423	0.0002
	C <sub>5</sub> (as Pentane)	0.0320	0.00005	0.132	0.0002
	C <sub>6</sub> (as Hexane)	0.00814	0.00005	0.0401	0.0002
	C <sub>6+</sub> (as Hexane)	0.00422	0.00005	0.0208	0.0002
TRS	Total Reduced Sulfur	0.000215	0.0000010	0.000419	0.000002
H2O	Moisture content	NM	NM	NM	NM

*All results have been normalized to 100% on a dry basis.*

Fuel Gas Specifications			
Atomic Breakdown - (scf/lb) / %		HHV Btu/lb	22055
Carbon ( C )	70.7	LHV Btu/lb	19878
Hydrogen ( H )	22.9	HHV Btu/dscf	1016
Oxygen ( O )	2.34	LHV Btu/dscf	917
Nitrogen ( N )	4.12	F-Factor	8653
Helium ( He )	0.00	Relative Density	0.604
Argon ( Ar )	0.00	C2-C6+ Weight %	0.00
Sulfur ( S )	0.00	MW lb/lb-mole	17.5
Motor Octane Number	129	Methane Number	89.8
		Wobbe Number	1308



# Atmospheric Analysis & Consulting, Inc.

## LABORATORY ANALYSIS REPORT


CLIENT : Ormond Power LLC/Genon  
PROJECT NO. : 241349  
MATRIX : AIR  
UNITS : ppmV

SAMPLING DATE : 06/11/2024  
ANALYSIS DATE : 06/12/2024

### Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	Ormond Power LLC
AAC ID	241349-59592
Analyte	Result
Hydrogen Sulfide	< 0.050
COS / SO <sub>2</sub>	< 0.050
Methyl Mercaptan	<b>0.159</b>
Ethyl Mercaptan	< 0.050
Dimethyl Sulfide	<b>0.058</b>
Carbon Disulfide	< 0.050
Isopropyl Mercaptan	< 0.050
tert-Butyl Mercaptan	<b>0.696</b>
n-Propyl Mercaptan	< 0.050
Methylethylsulfide	< 0.050
sec-Butyl Mercaptan / Thiophene	< 0.050
iso-Butyl Mercaptan	< 0.050
Diethyl Sulfide	< 0.050
n-Butyl Mercaptan	< 0.050
Dimethyl Disulfide	<b>0.267</b>
2-Methylthiophene	< 0.050
3-Methylthiophene	< 0.050
Tetrahydrothiophene	<b>0.895</b>
Bromothiophene	< 0.050
Thiophenol	< 0.050
Diethyl Disulfide	< 0.050
Total Unidentified Sulfur	< 0.050
Total Reduced Sulfurs	<b>2.08</b>

All unidentified compound's concentrations expressed in terms of H<sub>2</sub>S (TRS does not include COS and SO<sub>2</sub>)  
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.



# Atmospheric Analysis & Consulting, Inc.

## Quality Control/Quality Assurance Report

Date Analyzed : 06/13/2024  
 Analyst : DM/NR  
 Units : %

Instrument ID : TCD #1  
 Calb Date : 09/26/23  
 Reporting Limit : 0.1%

### I - Opening Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	H <sub>2</sub>	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	CO <sub>2</sub>
CCV	Spike Conc	10.0	9.9	19.9	10.0	10.0	10.0
	Result	9.9	9.9	22.8	9.9	9.2	9.7
	% Rec *	98.9	99.9	114.3	99.4	91.7	97.1

### II - Method Blank - BTU/ASTM D-1945

AAC ID	Analyte	H <sub>2</sub>	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	CO <sub>2</sub>
MB	Concentration	ND	ND	ND	ND	ND	ND

### III - Laboratory Control Spike & Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	H <sub>2</sub>	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	CO <sub>2</sub>
Lab Control Standards	Sample Conc	0.0	0.0	0.0	0.0	0.0	0.0
	Spike Conc	10.0	9.9	19.9	10.0	10.0	10.0
	LCS Result	10.2	10.7	22.9	9.9	9.2	9.7
	LCSD Result	10.4	10.3	22.4	10.3	9.5	10.0
	LCS % Rec *	101.4	107.4	114.8	99.7	91.8	97.3
	LCSD % Rec *	103.1	104.0	112.7	103.1	94.9	100.6
	% RPD ***	1.7	3.2	1.8	3.4	3.3	3.3

### IV - Sample & Sample Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	H <sub>2</sub>	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	CO <sub>2</sub>
241247-59152	Sample	0.0	11.5	49.8	0.2	0.0	0.8
	Sample Dup	0.0	11.6	50.2	0.2	0.0	0.8
	Mean	0.0	11.6	50.0	0.2	0.0	0.8
	% RPD ***	0.0	0.8	0.8	4.1	0.0	1.2

### V - Matrix Spike & Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	H <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	CO <sub>2</sub>
241247-59152	Sample Conc	0.0	25.0	0.1	0.0	0.4
	Spike Conc	10.0	10.0	10.0	10.0	10.0
	MS Result	10.7	36.5	10.6	9.7	10.6
	MSD Result	10.5	36.7	10.3	9.5	10.4
	MS % Rec **	106.9	115.3	105.0	97.0	102.7
	MSD % Rec **	104.8	117.0	102.9	94.9	100.6
	% RPD ***	1.9	1.5	2.0	2.2	2.1

### VI - Closing Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	H <sub>2</sub>	O <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	CO <sub>2</sub>
CCV	Spike Conc	10.0	9.9	19.9	10.0	10.0	10.0
	Result	10.5	10.1	22.6	10.6	9.8	10.3
	% Rec *	104.5	101.9	113.7	106.7	98.3	103.6

\* Must be 85-115%


\*\* Must be 75-125%

\*\*\* Must be < 25%

ND = Not Detected

<RL = less than Reporting Limit





# Atmospheric Analysis & Consulting, Inc.

## Quality Control/Quality Assurance Report

Date Analyzed : 06/13/2024  
 Analyst : RW  
 Units : ppmv

Instrument ID : FID#6  
 Calb Date : 10/17/2023  
 Reporting Limit : 0.5 ppmv

### I - Opening Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
CCV	Spike Conc	98.9	99.1	98.7	98.1	98.1	99.7
	Result	112.0	111.9	110.7	110.1	111.0	106.7
	% Rec *	113.3	112.9	112.1	112.2	113.1	106.9

### II - Method Blank - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
MB	Concentration	ND	ND	ND	ND	ND	ND

### III - Laboratory Control Spike & Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
Lab Control Standards	Sample Conc	0.0	0.0	0.0	0.0	0.0	0.0
	Spike Conc	98.9	99.1	98.7	98.1	98.1	99.7
	LCS Result	94.3	92.9	92.1	92.4	93.2	90.2
	LCSD Result	90.4	89.4	89.3	88.5	89.3	85.9
	LCS % Rec *	95.4	93.7	93.3	94.2	94.9	90.4
	LCSD % Rec *	91.4	90.2	90.5	90.2	91.0	86.1
	% RPD ***	4.3	3.8	3.1	4.3	4.2	4.9

### IV - Sample & Sample Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
232089-49905	Sample	2.8	0.0	0.0	0.0	0.0	0.0
	Sample Dup	2.9	0.0	0.0	0.0	0.0	0.0
	Mean	2.8	0.0	0.0	0.0	0.0	0.0
	% RPD ***	1.1	0.0	0.0	0.0	0.0	0.0

### V - Matrix Spike & Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
232089-49905	Sample Conc	1.4	0.0	0.0	0.0	0.0	0.0
	Spike Conc	49.4	49.6	49.4	49.0	49.1	49.9
	MS Result	56.1	53.7	53.2	53.2	53.3	51.2
	MSD Result	55.2	53.0	52.4	52.6	52.7	52.1
	MS % Rec **	110.7	108.4	107.9	108.4	108.6	102.6
	MSD % Rec **	108.8	106.9	106.1	107.2	107.5	104.4
	% RPD ***	1.7	1.3	1.7	1.1	1.0	1.7

### VI - Closing Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
CCV	Spike Conc	98.9	99.1	98.7	98.1	98.1	99.7
	Result	105.0	104.5	104.2	104.8	106.1	103.4
	% Rec *	106.2	105.5	105.6	106.9	108.1	103.7


\* Must be 85-115%

\*\* Must be 75-125%

\*\*\* Must be < 25%

ND = Not Detected

<RL = less than Reporting Limit



# Atmospheric Analysis & Consulting, Inc.

## Quality Control/Quality Assurance Report ASTM D-5504

Date Analyzed: 6/12/2024  
Analyst: KM  
Units: ppbV

Instrument ID : SCD#10  
Calb. Date: : 04/03/2024

### Opening Calibration Verification Standard

*510.5 ppbV H2S (GC-110223-01)*

H <sub>2</sub> S	Resp. (area)	Result	% Rec *	% RPD ****
Initial	13912	496	97.2	0.3
Duplicate	13645	487	95.3	2.2
Triplicate	14289	510	99.8	2.4

*501.8 ppbV H2S (GC-110223-01)*

MeSH	Resp. (area)	Result	% Rec *	% RPD ****
Initial	12022	502	100.0	2.0
Duplicate	12395	517	103.1	1.0
Triplicate	12399	518	103.2	1.0

*497.0 ppbV H2S (GC-110223-01)*

DMS	Resp. (area)	Result	% Rec *	% RPD ****
Initial	18391	498	100.2	0.2
Duplicate	18170	492	99.0	1.4
Triplicate	18745	508	102.2	1.7

### Method Blank

Analyte	Result
H <sub>2</sub> S	<PQL
MeSH	<PQL
DMS	<PQL

### Duplicate Analysis

Sample ID 231800-48645

Analyte	Sample Result	Duplicate Result	Mean	% RPD ***
H <sub>2</sub> S	<PQL	<PQL	0.0	0.0
MeSH	<PQL	<PQL	0.0	0.0
DMS	<PQL	<PQL	0.0	0.0

### Matrix Spike & Duplicate

Sample ID 231800-48645

Analyte	Sample Conc.	Spike Added	MS Result	MSD Result	MS % Rec **	MSD % Rec **	% RPD ***
H <sub>2</sub> S	<PQL	255.3	246.0	240.0	96.4	94.0	2.5
MeSH	<PQL	250.9	252.8	245.9	100.8	98.0	2.8
DMS	<PQL	248.5	260.7	263.6	104.9	106.1	1.1

### Closing Calibration Verification Standard

Analyte	Std. Conc.	Result	% Rec **
H <sub>2</sub> S	510.5	482.6	94.5
MeSH	501.8	513.3	102.3
DMS	497.0	505.8	101.8

\* Must be 95-105%, \*\* Must be 90-110%, \*\*\* Must be < 10%, \*\*\*\* Must be < 5% RPD from Mean result.

MeSH: PQL = 10.5 ppbV, MDL = 1.12 ppbV  
DMS: PQL = 11.0 ppbV, MDL = 1.12 ppbV

**CHAIN OF CUSTODY AND ANALYSIS REQUEST** – Chain of Custody is a LEGAL DOCUMENT. Complete all relevant fields.



Atmospheric Analysis and Consulting · Phone: 805-650-1642 · Email: info@aaclab.com · 2225 Sperry Ave, Ventura, CA 93003

AAC Project No.:

Client/Company Name: **LLC /**  
 Project Manager Name: **Project Number**

Project Name: **ANALYTICAL NATURAL GAS**  
 Project Number: **805-341-6167**

Turnaround Time:  
 Rush 24 h  Same Day  
 Rush 48 h  5 Days  
 Rush 72 h  Normal

Sampler Name: **Parke Russell**  
 Print: **Parke Russell**  
 Signature: *[Signature]*

Client Sample Name: **DRYWELL PAPER LLC**  
 Sample ID: **OB NAT GAS 11-Tube 21/1355**  
 Container Type/Qty: **BA9 1**

Analysis Requested:  
 NAT GAS ANALYSIS  
 ASTH B1945 + D9588  
 TOTAL REDUCED SULFUR  
 METHOD GC/PPPD  
 GA/100 SCF

Send Report To (Name/Email/Address): **ROGER KAHLE @ GEXON.COM**  
 Send Invoice To (Name/Email/Address): **PER 341 6167**  
 PO Number: **805-341-6167**

LAB USE ONLY  
 Lab ID: \_\_\_\_\_  
 Sample Received via:  
 FedEx  
 UPS  
 Courier  
 Other \_\_\_\_\_

Temperature: \_\_\_\_\_ °C  
 Thermometer ID: \_\_\_\_\_  
 Initials: \_\_\_\_\_

Returned Eqmt: \_\_\_\_\_  
 Total cans: \_\_\_\_\_  
 Unused cans: \_\_\_\_\_  
 Flow Controllers: \_\_\_\_\_

Client Notes/Special Instructions: **PLEASE ROLL AS FAST AS 232145**  
**EMAIL TO: ROGER.KAHLE@GAXON.COM**

Relinquished By: \_\_\_\_\_ Date: \_\_\_\_\_  
 Received By: \_\_\_\_\_ Date: \_\_\_\_\_

Signature: **PARKE RUSSELL**  
 Print: \_\_\_\_\_  
 Signature: \_\_\_\_\_

Relinquished By: \_\_\_\_\_ Date: \_\_\_\_\_  
 Received By: \_\_\_\_\_ Date: \_\_\_\_\_

Signature: *[Signature]*  
 Print: \_\_\_\_\_  
 Signature: \_\_\_\_\_

Relinquished By: \_\_\_\_\_ Date: \_\_\_\_\_  
 Received By: \_\_\_\_\_ Date: \_\_\_\_\_

Signature: \_\_\_\_\_  
 Print: \_\_\_\_\_  
 Signature: \_\_\_\_\_

Relinquished By: \_\_\_\_\_ Date: \_\_\_\_\_  
 Received By: \_\_\_\_\_ Date: \_\_\_\_\_

Signature: \_\_\_\_\_  
 Print: \_\_\_\_\_  
 Signature: \_\_\_\_\_

Relinquished By: \_\_\_\_\_ Date: \_\_\_\_\_  
 Received By: \_\_\_\_\_ Date: \_\_\_\_\_

Signature: \_\_\_\_\_  
 Print: \_\_\_\_\_  
 Signature: \_\_\_\_\_

Relinquished By: \_\_\_\_\_ Date: \_\_\_\_\_  
 Received By: \_\_\_\_\_ Date: \_\_\_\_\_

Signature: \_\_\_\_\_  
 Print: \_\_\_\_\_  
 Signature: \_\_\_\_\_

Relinquished By: \_\_\_\_\_ Date: \_\_\_\_\_  
 Received By: \_\_\_\_\_ Date: \_\_\_\_\_

# **ASBESTOS NOTIFICATION**



**Asbestos Notification Form ENF-62 for Demolition or Renovation**

Ventura County Air Pollution Control District  
 4567 Telephone Road, 2nd Floor Ventura, California 93003  
 Contact: Kourtney Heald 805/303-3702 or  
 Ken Hall 805/303-3709 [asbestos@vcapcd.org](mailto:asbestos@vcapcd.org)

**NOTIFICATION OF DEMOLITION OR RENOVATION**

Notifications for non-residential renovation or demolition operations shall be delivered no later than 10 working days prior to commencement of demolition or renovation work.

*Only typed forms will be accepted*

NOTIFICATION MUST ALSO BE SENT TO CAL-OSHA (EPA REGION IX DOES NOT REQUIRE A COPY OF NOTIFICATION). CAL-OSHA ~ 6150 Van Nuys Blvd, Suite 405, Van Nuys, CA 91401 PHONE: 818/901-5403 FAX: 818/901-5578 (Prefer FAX)			
<b>I. TYPE OF NOTIFICATION</b>		Owner/Contractor Project #	
<input checked="" type="radio"/> Original <input type="radio"/> Revised <input type="radio"/> Cancelled IF REVISION, state: Change in amount, start/completion date, other?		50309D	
Annual Asbestos Notification Original - 2024			
<b>II. FACILITY INFORMATION [Identify owner and removal contractor]</b>			
PROPERTY OWNER(S): Gen On Energy Ormond Beach Generation Station			
ADDRESS: [No Post Office Boxes] 6635 Edison Drive			
CITY: Oxnard		STATE: CA.	ZIP: 93033
CONTACT: Rodger Kahle		TELEPHONE: 805-984-5217	Email: Rodger.Kahle@genon.cc
REMOVAL CONTRACTOR: D2 Industrial Services			
ADDRESS: [No Post Office Boxes] 1501 W. Fountainhead Parkway			
CITY: Tempe		STATE: AZ.	ZIP: 85282
CONTRACTOR'S SITE FOREMAN: Kenneth Bringuez		ABATEMENT CONTRACTOR OFFICE TELEPHONE: 310-608-8070	
RULE 62.7.B.2.K: For operations involving the removal of friable ACM, Ventura County APCD requires proof of California State Contractor's License Certification #, CAL OSHA Reg. #, and date of expiration			
CA STATE CONTRACTOR LIC. NO. #1035992		CAL OSHA REG. NO. #1182	EXPIRATION DATE: 10/10/2024
<b>III. TYPE OF OPERATION</b>		<input type="checkbox"/> DEMO <input type="checkbox"/> ORDERED DEMO <input checked="" type="checkbox"/> RENOVATION <input type="checkbox"/> EMERGENCY RENOVATION <small>Demo definition: Removal of load bearing wall.</small>	
<b>IV. IS ASBESTOS PRESENT?</b>		<input checked="" type="radio"/> YES <input type="radio"/> NO	
<b>V. FACILITY DESCRIPTION [ Include building name, number, and floor or room number]</b>			
BUILDING NAME: Unit-1,2			
ADDRESS: 6635 Edison Drive			
CITY: Oxnard		STATE: CA.	ZIP: 93033
BUILDING SIZE (sqft): N/A		NUMBER OF FLOORS: N/A	
SITE LOCATION: [i.e., basement, attic, crawl space, etc.] Unit-1,2			
PRESENT USE: Power Generation Station		PRIOR USE: Power Generation Station	
<b>VI. PROCEDURE, INCLUDING ANALYTICAL METHOD, IF APPROPRIATE, USED TO DETECT THE PRESENCE OF ASBESTOS MATERIAL:</b>			
PLM - Bulk sampling by third party state certified consultant group			
<b>VII. APPROXIMATE AMOUNT OF ASBESTOS REMOVED (SqFt):</b>		Description of friable asbestos to be removed (i.e., TSI, aircell)	
		List Unit of measurements below (Rule 62.7.B.2.f requires pipe measurement in BOTH LnFt & SqFt)	
		UNITS	
Pipes	6000	LnFt: 6000	SqFt:    Category I:    SqFt.
Surface area or volume	6000	SqFt: 6000	CuFt: 6000    Category II:    SqFt.
<b>VIII. SCHEDULED REMOVAL DATES (mm/dd/yyyy):</b>		Start: 1/1/2024	Complete: 12/31/2024
<b>IX. SCHEDULED DEMO DATES (mm/dd/yyyy):</b>		Start:	Complete:

VCAPCD Notification No. \_\_\_\_\_



**NOTIFICATION OF DEMOLITION OR RENOVATION (continued)**

X. DESCRIPTION OF PLANNED DEMOLITION WORK, AND METHOD(S) TO BE USED: (Do not list South Coast Procedures.)		
Equip and pipelagging insulation removal and disposal from Unit 1,2 utilizing wet methods		
XI. DESCRIPTION OF WORK PRACTICES AND ENGINEERING CONTROLS TO BE USED TO PREVENT EMISSIONS OF ASBESTOS AT THE DEMOLITION AND RENOVATION SITE: (Do not list South Coast Procedures.)		
Wet gross removal within a NPE containments, glove bagging with general hand tools, he		
XII. WASTE TRANSPORTER #1		
NAME: <b>MP Environmental Services</b>		
ADDRESS: [No post office box numbers] <b>3400 Manor Street</b>		
CITY: <b>Bakersfield</b>	STATE: <b>CA.</b>	ZIP: <b>93308</b>
CONTACT: <b>Amanda Little / Lauren Kaufman</b>	TELEPHONE: <b>800-458-3036</b>	
XIII. WASTE TRANSPORTER #2		
NAME: <b>N/A</b>		
ADDRESS: [No post office box numbers]		
CITY:	STATE:	ZIP:
CONTACT:	TELEPHONE:	
XIV. WASTE DISPOAL SITE		
NAME: <b>Azusa Land Reclamation</b>		
ADDRESS: <b>1211 West Gladstone</b>		
CITY: <b>Azusa</b>	STATE: <b>CA.</b>	ZIP: <b>91702</b>
CONTACT: <b>Steve Amromin</b>	TELEPHONE: <b>626-969-1384.Ext.47</b>	
XV. IF DEMOLITION ORDERED BY GOVERNMENTAL AGENCY, PLEASE IDENTIFY THE AGENCY BELOW:		
NAME:	TITLE:	
AGENCY:		
DATE OF ORDER: [mm/dd/yyyy]	DATE ORDERED TO BEGIN: [mm/dd/yyyy]	
XVI. FOR EMERGENCY RENOVATIONS [Attach additional sheets if necessary]		
EMERGENCY	DATE [mm/dd/yyyy]:	TIME (am/pm):
DESCRIPTION OF THE SUDDEN, UNEXPECTED EVENT:		
EXPLANATION OF HOW THE EVENT CAUSED UNSAFE CONDITIONS OR WOULD CAUSE EQUIPMENT DAMAGE OR AN UNREASONABLE FINANCIAL BURDEN TO PROPERTY OWNER:		
XVII. DESCRIPTION OF PROCEDURES TO BE FOLLOWED IN THE EVENT THAT UNEXPECTED ASBESTOS IS FOUND OR PREVIOUSLY NONFRIABLE ASBESTOS MATERIAL BECOMES CRUMBLLED, PULVERIZED, OR REDUCED TO POWDER. [Attach additional sheets if necessary]		
Stop Work, Assess Problem, Sample Materials, Report Findings Accordingly to Agency		
XVIII. I CERTIFY THAT AN INDIVIDUAL TRAINED IN THE PROVISIONS OF THIS REGULATION (RULE 62.7.B.2.n) WILL BE ON-SITE DURING THE DEMOLITION OR RENOVATION AND EVIDENCE THAT THE REQUIRED TRAINING HAS BEEN ACCOMPLISHED BY THIS PERSON WILL BE AVAILABLE FOR INSPECTION DURING NORMAL BUSINESS HOURS. <b>NOTE: MISSING SIGNATURE WILL RESULT IN NOTIFICATION BEING RETURNED AS INCOMPLETE.</b>		
Richard Smith	 SIGNATURE OF OWNER/OPERATOR	12/18/2023 DATE
PRINT OWNER/OPERATOR NAME		
XIX. I CERTIFY THAT THE ABOVE INFOMRATION IS CORRECT. <b>NOTE: MISSING SIGNATURE WILL RESULT IN NOTIFICATION BEING RETURNED AS INCOMPLETE.</b>		
Richard Smith	 SIGNATURE OF OWNER/OPERATOR	12/18/2023 DATE
PRINT OWNER/OPERATOR NAME		

**SUBMIT**



**Asbestos NESHAP Fees**

<b>Demolition Projects without Asbestos:</b>	
Notification Fee	\$ 176.80
<b>Demolition or Renovation Projects with Asbestos:</b>	
Greater than or equal to 100 but less than 1,000 square feet of asbestos containing material (100 – 999 sqft)	\$ 270.40
Greater than or equal to 1,000 but less than 5,000 square feet of asbestos containing material (1,000 – 4,999 sqft)	\$ 644.80
Greater than or equal to 5,000 square feet of asbestos containing material (≥ 5,000 sqft)	\$ 1014.00
<b>Revisions:</b>	
Any notification revision	\$ 62.40

Payment shall be due prior to the commencement of asbestos removal per [Rule 45.2](#).

**NOTIFICATION SUBMITTAL:** Original notifications and revisions may be submitted by email (PDF required), mail, or hand delivered. Email completed forms to [asbestos@vcapcd.org](mailto:asbestos@vcapcd.org) (preferred). Notifications for non-residential renovation or demolition operations shall be typewritten and postmarked or delivered no later than 10 working days prior to commencement of demolition or renovation work. Notifications for residential renovation or demolition operations shall be typewritten and received by the District prior to commencement of demolition or renovation work.

**FEE PAYMENT:** Payment may be made online, check, or cash. Submit online payments here: <https://www.govpaynow.com/gps/user/cyg/plc/a004cn>

**DEMOLITION:** Notification and 10 working day wait required on all subject demolitions even if Asbestos Containing Material (ACM) is not present.

**RENOVATION:** A separate notification is required for each planned renovation operation involving 100 square feet or more of ACM except Category I nonfriable ACM that is removed in accordance with the requirements of Subsection E.2.a of [Rule 62.7](#).

**DEMOLITION:** A separate notification is required for each planned demolition operation where any amount of ACM is present.

**REVISIONS:** Revisions are required if there are any changes to removal or demolition dates, amounts of asbestos present or removed, or to contractors, transporters, or disposal site. Each revision shall be assessed a fee of \$62.40.

\*Additional fees MAY apply to any project if significant APCD staff time is needed to determine compliance. For additional information, an Asbestos NESHAP Notification Form, or other Asbestos related issues, visit our website at <http://www.vcapcd.org/asbestos.htm> or call either VCAPCD Inspector Ken Hall at (805) 303-3709 or Kourtney Heald (805) 303-3709



AllPaid  
7820 Innovation Boulevard Suite 250  
Indianapolis, IN 46278  
24hr. Customer Service #: 888-604-7888

**Asbestos Demolition/renovation Fees Payment Confirmation (Ref #: 40743312)**

**PLC:** Apcd  
**A004CN** 4567 Telephone Rd 2nd Floor  
Ventura, California 93003  
**For: Asbestos Demolition/renovation Fees**

**Date:** 12/21/2023 13:25 EST

**TRANSACTION INFORMATION**

<b>Type Of Payment:</b>	Abatement	<b>Transaction Reference #:</b>	40743312
<b>Contact Name:</b>	Richard Eugene Smith	<b>Transaction Date/Time:</b>	12/21/2023 13:25 EST
<b>Contact Phone Number:</b>	(707)373-3866		
<b>Email Address:</b>	Ricks@asrcindustrial.com		
<b>Contractor:</b>	D2 Industrial Services		
<b>Project Address:</b>	Genon Energy 6635 Edison Drive Oxnard, Ca 93033		
<b>Project Start Date:</b>	01/01/2024		
<b>Asbestos Fee Amounts:</b>	Abatement 5,000+ Sqft Acn = \$1,014.00		

**BILLING INFORMATION**

<b>Name:</b>	Richard E Smith
<b>Address:</b>	2009 Gold Dust Drive
<b>City, State Zip:</b>	Lake Havasu, Az 86404
<b>Phone #:</b>	(707)373-3866
<b>Card #:</b>	xxxx-xxxx-xxxx-9643

**PAYMENT INFORMATION**

<b>Approval #:</b>	015776
<b>Payment Amount:</b>	\$1014.00
<b>Service Fee:</b>	\$27.89
<b>Total Amount:</b>	\$1041.89

**The service fee is not refundable.**

**ATTENTION CARDHOLDER**

If you have questions about the processing of your payment, please call AllPaid at 888-604-7888.

Thank you for using AllPaid



The Ormond Beach Generating Station did not renovate more than 100 square feet of asbestos in association with the 2024 outage. Consequently, an ACM outage notification is not required pursuant to section B.1.a of the Ventura County Air Pollution Control District's Rule 62.7.

# **RELATIVE ACCURACY TEST AUDIT**

# TEST REPORT FOR 2024 EPA 40 CFR, PART 75 ANNUAL RELATIVE ACCURACY TEST AUDIT AT ORMOND BEACH POWER, LLC UNIT 1

Prepared For:

**Ormond Beach Power, LLC**  
**Ormond Beach Generating Station**  
6635 S. Edison Drive  
Oxnard, California 93033

For Submittal To:

**Ventura County Air Pollution Control District**  
4567 Telephone Road, 2<sup>nd</sup> Floor  
Ventura, California 93003

Prepared By:

**Montrose Air Quality Services, LLC**  
1631 E. St. Andrew Pl.  
Santa Ana, California 92705  
(714) 279-6777

John Peterson

Test Date: **June 11, 2024**  
Production Date: **July 15, 2024**  
Report Number: **W002AS-041566-RT-6248**




## CONFIDENTIALITY STATEMENT


***Except as otherwise required by law or regulation, this information contained in this communication is intended exclusively for the individual or entity to which it is addressed. This communication may contain information that is proprietary, privileged or confidential or otherwise legally exempt from disclosure. If you are not the named addressee, you are not authorized to read, print, retain, copy, or disseminate this message or any part of it.***

### REVIEW AND CERTIFICATION

All work, calculations, and other activities and tasks performed and presented in this document were carried out by me or under my direction and supervision. I hereby certify that, to the best of my knowledge, Montrose operated in conformance with the requirements of the Montrose Quality Management System and ASTM D7036-04 during this test project.

Signature:  Date: 7/15/2024  
Name: John Peterson Title: District Manager

I have reviewed, technically and editorially, details, calculations, results, conclusions, and other appropriate written materials contained herein. I hereby certify that, to the best of my knowledge, the presented material is authentic, accurate, and conforms to the requirements of the Montrose Quality Management System and ASTM D7036-04.

Signature:  Date: 7/15/2024  
Name: Surya Adhikari Title: Reporting/QC Specialist

## TABLE OF CONTENTS

<b><u>SECTION</u></b>	<b><u>PAGE</u></b>
1.0 INTRODUCTION AND SUMMARY .....	5
2.0 UNIT DESCRIPTION AND TEST CONDITIONS .....	6
2.1 UNIT DESCRIPTION .....	6
2.2 TEST CONDITIONS.....	6
2.3 SAMPLE LOCATION .....	6
2.4 CEMS DESCRIPTION .....	6
3.0 TEST DESCRIPTION .....	8
3.1 REFERENCE METHODS .....	9
3.2 CEMS DATA .....	9
4.0 TEST RESULTS AND OVERVIEW .....	10
4.1 TEST RESULTS.....	10
4.2 TEST OVERVIEW.....	11

### LIST OF APPENDICES

A TEST DATA.....	12
A.1 Sample Location Data .....	13
A.2 Reference Method Data Logger Data .....	15
A.3 Quality Assurance Data.....	33
B FACILITY CEMS DATA.....	47
C CALCULATIONS .....	57
C.1 General Emissions Calculations.....	58
C.2 Spreadsheet Summary.....	64
D QUALITY ASSURANCE .....	66
D.1 Quality Assurance Program Summary .....	67
D.2 STAC Certification.....	73
D.3 Individual QI Certificates .....	75

### LIST OF TABLES

1-1 RESULTS SUMMARY .....	5
2-1 ANALYZER SPECIFICATIONS .....	6
3-1 MEASUREMENT PROCEDURES.....	9
4-1 NO <sub>x</sub> LB/MMBTU RELATIVE ACCURACY TEST RESULTS.....	10

## 1.0 INTRODUCTION AND SUMMARY

Montrose Air Quality Services, LLC (MAQS) was contracted by Ormond Beach Power, LLC (Ormond Beach) to perform the annual Relative Accuracy Test Audit (RATA) of the Continuous Emission Monitoring System (CEMS) serving Ormond Beach Unit 1. The test was performed to determine the Relative Accuracy for NO<sub>x</sub> emissions on a pounds per million Btu basis and determine compliance with EPA 40 CFR, Part 75.

The test was performed on June 11, 2024. The test was conducted in accordance with the test plan Document Number W002AS-026975-PP-750 submitted to Ormond Beach on April 21, 2023. The MAQS test team consisted of John Peterson, Travis Maestri, and Patrick Rubio. John Peterson was the on-site Qualified Individual for MAQS. Roger Kahle and Sheila Reilly of Ormond Beach coordinated the test and documented unit and CEMS operation. Ed Swede of the Ventura County Air Pollution Control District was on-site to witness the test.

Air Emission Test Body and on-site Qualified Individual information is presented in Appendix D.

Nine sets of reference method tests were performed. Each reference method test consisted of independent measurements of flue gas O<sub>2</sub> and NO<sub>x</sub> concentrations. All nine runs were used to calculate the NO<sub>x</sub> emission rate in units of pounds per million Btu. The calculated values for each run were then compared to the corresponding Unit 1 CEMS data and the Relative Accuracy of the CEMS was calculated. The Relative Accuracy data set was also evaluated to determine the Bias Adjustment Factor (BAF). The results of the test are summarized in Table 1-1. Test results show the Unit 1 CEMS passed the RATA because the average difference between the reference method and the Unit 1 CEMS was 0.001 lb/MMBtu which meets the 0.02 lb/MMBtu criteria of EPA 40 CFR, Part 75 and also meets the annual incentive criteria of 0.015 lb/MMBtu. Therefore, the next RATA will be due on an annual basis.

**TABLE 1-1  
 RESULTS SUMMARY  
 ORMOND BEACH GENERATING STATION  
 UNIT 1  
 JUNE 11, 2024**

Parameter	Results	Limit
Relative Accuracy	-0.001 lb/MMBtu	10% or +/-0.020 lb/MMBtu absolute difference
Bias Adjustment Factor	1.000	N/A
Next RATA	Annual	N/A

Section 2.0 of this report provides a description of the process tested and the test conditions under which it was operating while the test was performed. Section 3.0 describes the test methodology. Section 4.0 contains more detailed results including data for each test run.

## 2.0 UNIT DESCRIPTION AND TEST CONDITIONS

### 2.1 UNIT DESCRIPTION

Unit 1 at the Ormond Beach Generating Station consists of a utility boiler and steam turbine generator. The boiler and generator have a full load rating of 750 megawatts. The boiler fires natural gas exclusively. The unit is equipped with a Selective Catalytic Reduction (SCR) system for NO<sub>x</sub> control.

### 2.2 TEST CONDITIONS

The tests were performed while the unit was firing natural gas and operating under normal conditions. The unit was operating at an average load of 261.0 gross megawatts, (35% of full load).

### 2.3 SAMPLE LOCATION

The reference method measurements were made from one of the four, equally spaced, sample ports located on the exhaust stack. The stack inside diameter at this location is approximately 32 feet. The sample ports are located greater than 2.0 diameters downstream of the nearest flow disturbance and greater than 0.5 diameters upstream of the nearest flow disturbance. The location of individual sampling traverse points is defined in Appendix A.1.

### 2.4 CEMS DESCRIPTION

The extractive CEMS installed on this unit is designed to determine emissions-related information including stack gas volumetric flow rate and NO<sub>x</sub> mass emission rates. This system directly extracts a stack gas sample, then continuously measures NO<sub>x</sub> and O<sub>2</sub> concentrations. The system is equipped with a dual range NO<sub>x</sub> analyzer (Component/System ID # = 011/101) and a single range O<sub>2</sub> analyzer (Component/System ID # = 012/101). The make, model, serial number, and range of the analyzers are summarized in Table 2-1.

**TABLE 2-1  
ANALYZER SPECIFICATIONS  
ORMOND BEACH GENERATING STATION  
UNIT 1**

Component	Manufacturer	Model	Serial Number	Range(s)
NO <sub>x</sub> Analyzer	TECO	42CHL	42 CHL-66196-351	0-10/250 ppm
O <sub>2</sub> Analyzer	Thermox	2000	10202872	0-20%

Sample gases are extracted through a probe assembly and transported through heated Teflon sample tubes to the analyzer enclosure. The analyzer cabinet houses the components of the sample control, conditioning system, and the analyzers. Control signals (calibration, sample, etc.) are generated by the data logger.



The analyzer signals are transmitted to the data logger where 40 CFR Part 75 calculations are performed. These calculated results are stored in the DAS computer. The CEMS calculates the NO<sub>x</sub> emission rate (lb/MMBtu) from the measured NO<sub>x</sub> and O<sub>2</sub> concentrations and fuel F-Factor using the following equation:

$$M = \text{ppm} * F * 1.194 * 10^{-7} * \frac{20.9}{20.9 - \%O_2}$$

Where:

- M = NO<sub>x</sub> emission rate (lb/MMBtu)
- ppm = NO<sub>x</sub> concentration (ppmv, dry)
- F = EPA Method 19 F-Factor (dscf/MMBtu)
- % O<sub>2</sub> = O<sub>2</sub> concentration (% , dry)

### 3.0 TEST DESCRIPTION

Nine sets of reference method measurements were performed with the sample times synchronized with the CEMS. Each set of tests consisted of independent measurements of NO<sub>x</sub> and O<sub>2</sub> concentrations and calculation of the NO<sub>x</sub> emission rate (lb/MMBtu) using EPA Method 19. The CEMS data from the same intervals were then compared to the reference method results and the Relative Accuracy was calculated according to the following equation:

$$RA = \frac{|\bar{d}| + |CC|}{\overline{RM}} \times 100\%$$

Where:

RA = relative accuracy

$|\bar{d}|$  = Absolute value of the difference between RM and CEMS (RM - CEMS)

$|CC|$  = confidence coefficient of the difference between RM and CEMS

$\overline{RM}$  = mean value of the reference method

$$CC = \frac{t_{\text{value}} * \text{Std. Dev.}}{\sqrt{n}}$$

Where:

$t_{\text{value}}$  = statistical function of number of tests

Std. Dev. = sample standard deviation of the difference between RM and CEMS

n = number of valid tests

In addition to determining the relative accuracy of the CEMS, the test data were used to determine the Bias Adjustment Factor (BAF) which is applied to the CEMS data. If the mean difference (RM - CEMS) is less than the confidence coefficient, the BAF is 1.000. If the mean difference (RM - CEMS) is greater than the confidence coefficient, then a BAF is generated using the following equation:

$$BAF = 1 + \frac{|\bar{d}|}{CEMS}$$

### 3.1 REFERENCE METHODS

NO<sub>x</sub> and O<sub>2</sub> concentrations were measured according to the procedures described in EPA methods 7E and 3A, respectively. A three-point traverse was performed during each test run. The traverse points were selected according to EPA 40 CFR, Part 60, Appendix B, Performance Specification 2. The measured concentrations were averaged over the sampling period and then corrected for system bias and analyzer drift. Copies of the reference method DAS data, strip charts, raw data, and quality assurance data are presented in Appendix A. Facility CEMS data is presented in Appendix B, and calculations are presented in Appendix C.

One of MAQS' mobile emission measurement laboratories was used for the performance of O<sub>2</sub> and NO<sub>x</sub> measurements. The laboratory is outfitted to provide a clean, quiet, environmentally controlled base for the testing operations. The laboratory has lighting, electrical distribution, air conditioning and heating to support the test instruments and provide for optimal test performance.

NO<sub>x</sub> and O<sub>2</sub> concentrations are measured using an extractive sampling system consisting of a heated probe, a heat traced Teflon sample line connected to a thermo-electrically cooled sample dryer. Following the dryer, the sample is drawn into a Teflon lined pump where it is pressurized and then filtered for delivery to the gas analysis portion of the system.

NO<sub>x</sub> concentration is determined using a CAI chemiluminescence analyzer (model #600). The analyzer was operated on a 0-10 ppm range during the test. The analyzer is equipped with a carbon NO<sub>2</sub> - NO converter for the determination of total nitrogen oxides without interference from other nitrogen containing compounds.

Oxygen concentration is determined using a CAI electro-chemical cell analyzer (model #600). The analyzer was operated on a 0-10% range during the test. The cell contains an electrolytic fluid that reacts with oxygen to generate an electrical signal proportional to the concentration.

The analyzers and sampling system are subjected to a variety of calibration and quality assurance procedures including leak checks, linearity and calibration error determinations before sampling, and system bias and drift determinations as part of each test run. Data are corrected for any observed bias or drift in accordance with the reference methods.

**TABLE 3-1  
MEASUREMENT PROCEDURES**

Parameter	Test Method	Measurement Principle	Comments
O <sub>2</sub>	EPA 3A	Electro-chemical Cell	3-point traverse
NO <sub>x</sub>	EPA 7E	Chemiluminescence	3-point traverse

### 3.2 CEMS DATA

The CEMS data were collected from the data logger by printing the one-minute average data over each test interval. The data logger report provides the average of the one-minute averages over each test interval for comparison to the reference method.

## 4.0 TEST RESULTS AND OVERVIEW

### 4.1 TEST RESULTS

The results of the NO<sub>x</sub> emission rate Relative Accuracy test audit are summarized in Table 4-1. The table shows that NO<sub>x</sub> emissions were less than 0.20 lb/MMBtu which qualifies for low emitter status. The relative accuracy average difference between the reference method and CEMS was -0.001 lb/MMBtu which meets the 0.020 lb/MMBtu criteria of EPA 40 CFR, Part 75 and also meets the annual incentive criteria of < 0.015 lb/MMBtu.

**TABLE 4-1  
 NO<sub>x</sub> LB/MMBTU RELATIVE ACCURACY TEST RESULTS  
 ORMOND BEACH GENERATING STATION  
 UNIT 1**

<b>Station:</b> Ormond Beach	<b>Parameter:</b> NO <sub>x</sub>
<b>Unit:</b> 1	<b>Units:</b> lb/MMBtu
<b>Date:</b> 6/11/2024	<b>Performed By:</b> JP/PR/TM/AE

Test #	Date	Time		RM	CEMS	Difference	Valid Run (1=Yes, 0=No)
		Start	Stop	NO <sub>x</sub> lb/MMBtu	NO <sub>x</sub> lb/MMBtu	NO <sub>x</sub> lb/MMBtu	
1	6/11/2024	13:38	14:02	0.008	0.008	0.000	1
2	6/11/2024	14:13	14:40	0.007	0.008	-0.001	1
3	6/11/2024	14:50	15:11	0.007	0.008	-0.001	1
4	6/11/2024	15:19	15:40	0.007	0.008	-0.001	1
5	6/11/2024	15:54	16:15	0.008	0.008	0.000	1
6	6/11/2024	16:23	16:44	0.007	0.008	-0.001	1
7	6/11/2024	16:56	17:17	0.007	0.008	-0.001	1
8	6/11/2024	17:23	17:44	0.008	0.008	0.000	1
9	6/11/2024	17:50	18:11	0.008	0.008	0.000	1
<b>Average</b>				<b>0.007</b>	<b>0.008</b>	<b>-0.001</b>	<b>--</b>

<b>Reference Method Average:</b>	0.007	lb/MMBtu
<b>Average Difference:</b>	-0.001	lb/MMBtu
<b>Number of Tests:</b>	9	
<b>Standard Deviation:</b>	0.001	lb/MMBtu
<b>t Value:</b>	2.306	
<b>Confidence Coefficient:</b>	0.000	lb/MMBtu
<b>Relative Accuracy:</b>	12.9	%
<b>Bias Adjustment Factor:</b>	1.000	
<b>Test Condition:</b>	261	MW

- (1) Since  $d < CC$ , the system passes the bias test.  
 (2) Average difference is less than 0.020 lb/MMBtu - CEMS passes the RATA per the low emitter criteria.  
 (3) Average difference is less than 0.015 lb/MMBtu - CEMS meets the annual incentive per the low emitter criteria.

## 4.2 TEST OVERVIEW

The test program was successful in meeting the program objectives. All nine runs were included in the Relative Accuracy calculations. Raw data from all nine runs can be found in appendix A.

## **APPENDIX A TEST DATA**

## **Appendix A.1 Sample Location Data**

---

**Montrose Air Quality Services, LLC**

**Sample Point Location Data**

**EPA Method 1**



---

Location: Ormond Beach

Date: 6/11/2024

Unit: 1

By: JP/PR/TM/AE

Stack Area (ft<sup>2</sup>): 804.2

Downstream Disturbances > 2.0 diameters

Stack Diameter (in.): 384.0

Upstream Disturbances: > 0.5 diameters

Coupling Length (in.): 12

---

Point	CEMS Sample Points (Long Line)			CEMS Sample Points (Short Line)		
	% of Duct	Inches from Wall <sup>(1)</sup>	Inches from Nozzle	% of Duct	Inches from Wall <sup>(1)</sup>	Inches from Nozzle
1	16.7	64.1	76.1	n/a	15.7	27.7
2	50	192.0	204.0	n/a	47.2	59.2
3	83.3	319.9	331.9	n/a	78.7	90.7

---

(1) From 40 CFR Part 60 Appendix B

---



## **Appendix A.2**

### **Reference Method Data Logger Data**

**Montrose Air Quality Services, LLC**

**RUN NUMBER 1 RM DAS**



RM 1-MINUTE AVERAGE DATA				
RUN NUMBER 1				
Date	Time	O <sub>2</sub>	NO <sub>x</sub>	CO
6/11/2024	1:39:00 PM	4.034	6.114	
6/11/2024	1:40:00 PM	4.108	6.018	
6/11/2024	1:41:00 PM	3.985	6.67	
6/11/2024	1:42:00 PM	4.106	6.258	
6/11/2024	1:43:00 PM	4.106	5.445	
6/11/2024	1:44:00 PM	4.12	6.561	
6/11/2024	1:45:00 PM	4.146	7.37	
6/11/2024	1:46:00 PM	4.061	5.702	
6/11/2024	1:47:00 PM	3.971	4.679	
6/11/2024	1:48:00 PM	4.241	5.822	
6/11/2024	1:49:00 PM	4.225	6.675	
6/11/2024	1:50:00 PM	4.256	5.572	
6/11/2024	1:51:00 PM	4.3	5.027	
6/11/2024	1:52:00 PM	4.223	5.905	
6/11/2024	1:56:00 PM	4.178	8.335	
6/11/2024	1:57:00 PM	4.105	6.728	
6/11/2024	1:58:00 PM	4.107	5.749	
6/11/2024	1:59:00 PM	4.071	6.794	
6/11/2024	2:00:00 PM	4.113	7.964	
6/11/2024	2:01:00 PM	4.14	7.217	
6/11/2024	2:02:00 PM	4.149	6.013	
Average		4.13	6.32	#DIV/0!

Pt 1 Avg.	4.086	6.348
Pt 2 Avg.	4.182	5.626
Pt 3 Avg.	4.123	6.971

**Montrose Air Quality Services, LLC**

**RUN NUMBER 2 RM DAS**



RM 1-MINUTE AVERAGE DATA				
RUN NUMBER 2				
Date	Time	O2	NOx	CO
6/11/2024	2:14:00 PM	4.181	5.615	
6/11/2024	2:15:00 PM	4.15	5.229	
6/11/2024	2:16:00 PM	4.16	5.802	
6/11/2024	2:17:00 PM	4.234	6.422	
6/11/2024	2:18:00 PM	4.124	6.032	
6/11/2024	2:19:00 PM	4.041	5.405	
6/11/2024	2:20:00 PM	4.085	5.474	
6/11/2024	2:21:00 PM	4.142	6.429	
6/11/2024	2:22:00 PM	4.034	6.031	
6/11/2024	2:23:00 PM	4.04	5.217	
6/11/2024	2:24:00 PM	4.327	5.476	
6/11/2024	2:25:00 PM	4.202	6.71	
6/11/2024	2:26:00 PM	4.054	5.953	
6/11/2024	2:27:00 PM	4.115	5.056	
6/11/2024	2:34:00 PM	4.037	6.004	
6/11/2024	2:35:00 PM	4.089	5.761	
6/11/2024	2:36:00 PM	3.996	5.446	
6/11/2024	2:37:00 PM	4.103	5.579	
6/11/2024	2:38:00 PM	4.134	5.971	
6/11/2024	2:39:00 PM	4.182	5.947	
6/11/2024	2:40:00 PM	4.132	5.645	
Average		4.12	5.77	

Pt 1 Avg.	4.139	5.711
Pt 2 Avg.	4.131	5.839
Pt 3 Avg.	4.096	5.765

**Montrose Air Quality Services, LLC**

**RUN NUMBER 3 RM DAS**




RM 1-MINUTE AVERAGE DATA				
RUN NUMBER 3				
Date	Time	O2	NOx	CO
6/11/2024	2:51:00 PM	4.083	6.192	
6/11/2024	2:52:00 PM	4.054	5.593	
6/11/2024	2:53:00 PM	4.114	5.448	
6/11/2024	2:54:00 PM	4.12	5.84	
6/11/2024	2:55:00 PM	4.115	6.088	
6/11/2024	2:56:00 PM	4.08	5.884	
6/11/2024	2:57:00 PM	4.041	5.655	
6/11/2024	2:58:00 PM	4.097	5.605	
6/11/2024	2:59:00 PM	4.106	5.984	
6/11/2024	3:00:00 PM	4.063	5.695	
6/11/2024	3:01:00 PM	4.042	5.496	
6/11/2024	3:02:00 PM	4.234	6.343	
6/11/2024	3:03:00 PM	3.99	6.258	
6/11/2024	3:04:00 PM	4.141	5.448	
6/11/2024	3:05:00 PM	4.05	5.425	
6/11/2024	3:06:00 PM	4.03	5.667	
6/11/2024	3:07:00 PM	4.022	5.673	
6/11/2024	3:08:00 PM	4.021	5.548	
6/11/2024	3:09:00 PM	4.052	5.831	
6/11/2024	3:10:00 PM	4.259	6.252	
6/11/2024	3:11:00 PM	4.117	6.478	
Average		4.09	5.83	

Pt 1 Avg.	4.087	5.814
Pt 2 Avg.	4.096	5.833
Pt 3 Avg.	4.079	5.839

**Montrose Air Quality Services, LLC**

**RUN NUMBER 4 RM DAS**



<b>RM 1-MINUTE AVERAGE DATA</b>				
<b>RUN NUMBER 4</b>				
Date	Time	O2	NOx	CO
6/11/2024	3:20:00 PM	4.169	5.803	101.92
6/11/2024	3:21:00 PM	4.251	5.633	57.094
6/11/2024	3:22:00 PM	4.198	5.977	66.073
6/11/2024	3:23:00 PM	4.163	5.884	78.782
6/11/2024	3:24:00 PM	4.266	5.964	64.941
6/11/2024	3:25:00 PM	4.174	5.705	137.17
6/11/2024	3:26:00 PM	4.237	5.782	56.553
6/11/2024	3:27:00 PM	4.169	5.787	85.429
6/11/2024	3:28:00 PM	4.153	5.91	87.202
6/11/2024	3:29:00 PM	4.17	5.969	72.434
6/11/2024	3:30:00 PM	4.18	6.108	44.09
6/11/2024	3:31:00 PM	4.197	6.06	35.094
6/11/2024	3:32:00 PM	4.101	5.706	57.817
6/11/2024	3:33:00 PM	4.175	5.63	44.618
6/11/2024	3:34:00 PM	4.203	5.698	25.658
6/11/2024	3:35:00 PM	4.139	5.794	44.096
6/11/2024	3:36:00 PM	4.139	5.844	80.088
6/11/2024	3:37:00 PM	4.209	5.869	52.084
6/11/2024	3:38:00 PM	4.288	5.868	26.255
6/11/2024	3:39:00 PM	4.213	5.748	72.975
6/11/2024	3:40:00 PM	4.16	5.637	108.5
Average		4.19	5.83	66.61

Pt 1 Avg.	4.208	5.821	80.362
Pt 2 Avg.	4.164	5.881	60.955
Pt 3 Avg.	4.193	5.780	58.522

**Montrose Air Quality Services, LLC**

**RUN NUMBER 5 RM DAS**




<b>RM 1-MINUTE AVERAGE DATA</b>				
<b>RUN NUMBER 5</b>				
Date	Time	O2	NOx	CO
6/11/2024	3:55:00 PM	4.162	5.902	105.92
6/11/2024	3:56:00 PM	4.122	6.024	164.22
6/11/2024	3:57:00 PM	4.147	5.951	108.02
6/11/2024	3:58:00 PM	4.232	6.067	96.101
6/11/2024	3:59:00 PM	4.275	6.12	62.593
6/11/2024	4:00:00 PM	4.242	5.731	114.43
6/11/2024	4:01:00 PM	4.256	5.809	111.29
6/11/2024	4:02:00 PM	4.219	5.968	171.09
6/11/2024	4:03:00 PM	4.078	6.022	116.12
6/11/2024	4:04:00 PM	4.095	5.889	79.685
6/11/2024	4:05:00 PM	4.265	5.876	35.305
6/11/2024	4:06:00 PM	4.153	5.77	147.37
6/11/2024	4:07:00 PM	4.144	5.797	84.305
6/11/2024	4:08:00 PM	4.062	5.957	161.38
6/11/2024	4:09:00 PM	4.103	5.97	87.282
6/11/2024	4:10:00 PM	4.065	5.91	97.709
6/11/2024	4:11:00 PM	4.136	5.947	84.377
6/11/2024	4:12:00 PM	4.139	5.948	85.751
6/11/2024	4:13:00 PM	4.097	5.828	109.52
6/11/2024	4:14:00 PM	4.205	5.809	80.872
6/11/2024	4:15:00 PM	4.17	5.977	73.65
Average		4.16	5.92	103.67

Pt 1 Avg.	4.205	5.943	108.937
Pt 2 Avg.	4.145	5.897	113.608
Pt 3 Avg.	4.131	5.913	88.451

**Montrose Air Quality Services, LLC**

**RUN NUMBER 6 RM DAS**



RM 1-MINUTE AVERAGE DATA				
RUN NUMBER 6				
Date	Time	O2	NOx	CO
6/11/2024	4:24:00 PM	4.21	6.046	85.995
6/11/2024	4:25:00 PM	4.213	6.153	95.303
6/11/2024	4:26:00 PM	4.1	5.865	150.98
6/11/2024	4:27:00 PM	4.12	5.703	145.81
6/11/2024	4:28:00 PM	4.298	5.973	121.86
6/11/2024	4:29:00 PM	4.233	6.261	79.442
6/11/2024	4:30:00 PM	4.246	5.971	112.06
6/11/2024	4:31:00 PM	4.185	5.69	123.91
6/11/2024	4:32:00 PM	4.181	5.811	81.675
6/11/2024	4:33:00 PM	4.134	5.821	99.733
6/11/2024	4:34:00 PM	4.102	5.928	141.13
6/11/2024	4:35:00 PM	4.112	5.953	101.62
6/11/2024	4:36:00 PM	4.268	6.077	36.467
6/11/2024	4:37:00 PM	4.199	5.959	88.475
6/11/2024	4:38:00 PM	4.202	5.775	84.131
6/11/2024	4:39:00 PM	4.139	5.736	121.9
6/11/2024	4:40:00 PM	4.215	5.844	58.437
6/11/2024	4:41:00 PM	4.148	5.993	68.694
6/11/2024	4:42:00 PM	4.16	5.762	85.22
6/11/2024	4:43:00 PM	4.123	5.636	177.92
6/11/2024	4:44:00 PM	4.197	5.77	112.65
Average		4.18	5.89	103.50

Pt 1 Avg.	4.203	5.996	113.065
Pt 2 Avg.	4.169	5.891	96.144
Pt 3 Avg.	4.169	5.788	101.279

**Montrose Air Quality Services, LLC**

**RUN NUMBER 7 RM DAS**




RM 1-MINUTE AVERAGE DATA			
RUN NUMBER 7			
Date	Time	O2	NOx
6/11/2024	4:57:00 PM	4.242	5.945
6/11/2024	4:58:00 PM	4.189	5.937
6/11/2024	4:59:00 PM	4.378	6.158
6/11/2024	5:00:00 PM	4.234	5.734
6/11/2024	5:01:00 PM	4.331	5.538
6/11/2024	5:02:00 PM	4.329	5.922
6/11/2024	5:03:00 PM	4.309	6.134
6/11/2024	5:04:00 PM	4.185	6.06
6/11/2024	5:05:00 PM	4.146	5.918
6/11/2024	5:06:00 PM	4.072	5.961
6/11/2024	5:07:00 PM	4.311	5.906
6/11/2024	5:08:00 PM	4.177	5.918
6/11/2024	5:09:00 PM	4.267	5.951
6/11/2024	5:10:00 PM	4.232	5.667
6/11/2024	5:11:00 PM	4.177	5.621
6/11/2024	5:12:00 PM	4.175	5.779
6/11/2024	5:13:00 PM	4.289	6.138
6/11/2024	5:14:00 PM	4.284	5.928
6/11/2024	5:15:00 PM	4.156	5.681
6/11/2024	5:16:00 PM	4.072	5.622
6/11/2024	5:17:00 PM	4.173	5.701
Average		4.23	5.87

Pt 1 Avg.	4.287	5.910
Pt 2 Avg.	4.199	5.912
Pt 3 Avg.	4.189	5.781



**Montrose Air Quality Services, LLC**

**RUN NUMBER 8 RM DAS**



RM 1-MINUTE AVERAGE DATA			
RUN NUMBER 8			
Date	Time	O2	NOx
6/11/2024	5:24:00 PM	4.202	6.034
6/11/2024	5:25:00 PM	4.175	6.088
6/11/2024	5:26:00 PM	4.202	5.969
6/11/2024	5:27:00 PM	4.222	6.074
6/11/2024	5:28:00 PM	4.298	5.981
6/11/2024	5:29:00 PM	4.257	5.897
6/11/2024	5:30:00 PM	4.198	5.967
6/11/2024	5:31:00 PM	4.28	6.046
6/11/2024	5:32:00 PM	4.278	6.061
6/11/2024	5:33:00 PM	4.137	5.912
6/11/2024	5:34:00 PM	4.157	5.695
6/11/2024	5:35:00 PM	4.044	5.663
6/11/2024	5:36:00 PM	4.159	5.81
6/11/2024	5:37:00 PM	4.174	6.059
6/11/2024	5:38:00 PM	4.238	6.007
6/11/2024	5:39:00 PM	4.108	5.928
6/11/2024	5:40:00 PM	4.191	5.754
6/11/2024	5:41:00 PM	4.188	5.763
6/11/2024	5:42:00 PM	4.184	5.712
6/11/2024	5:43:00 PM	4.303	5.743
6/11/2024	5:44:00 PM	4.131	5.943
Average		4.20	5.91

Pt 1 Avg.	4.222	6.001
Pt 2 Avg.	4.176	5.892
Pt 3 Avg.	4.192	5.836

**Montrose Air Quality Services, LLC**

**RUN NUMBER 9 RM DAS**



RM 1-MINUTE AVERAGE DATA			
RUN NUMBER 9			
Date	Time	O2	NOx
6/11/2024	5:51:00 PM	4.203	6.092
6/11/2024	5:52:00 PM	4.219	5.818
6/11/2024	5:53:00 PM	4.167	5.786
6/11/2024	5:54:00 PM	4.247	5.96
6/11/2024	5:55:00 PM	4.244	6.237
6/11/2024	5:56:00 PM	4.246	5.965
6/11/2024	5:57:00 PM	4.147	5.728
6/11/2024	5:58:00 PM	4.163	5.508
6/11/2024	5:59:00 PM	4.175	5.821
6/11/2024	6:00:00 PM	4.201	6.279
6/11/2024	6:01:00 PM	4.28	6.257
6/11/2024	6:02:00 PM	4.182	5.837
6/11/2024	6:03:00 PM	4.23	5.75
6/11/2024	6:04:00 PM	4.268	5.897
6/11/2024	6:05:00 PM	4.199	6.238
6/11/2024	6:06:00 PM	4.091	5.921
6/11/2024	6:07:00 PM	4.115	5.732
6/11/2024	6:08:00 PM	4.155	5.669
6/11/2024	6:09:00 PM	4.071	5.561
6/11/2024	6:10:00 PM	4.115	5.58
6/11/2024	6:11:00 PM	4.108	5.77
Average		4.18	5.88

Pt 1 Avg.	4.210	5.941
Pt 2 Avg.	4.214	5.907
Pt 3 Avg.	4.122	5.782

**Montrose Air Quality Services, LLC**



**Reference Method DAS**

Date	Time	O <sub>2</sub> %	NO <sub>x</sub> PPM	CO PPM	Comments
6/11/2024	12:32:00	-0.001	-0.002	-0.777	
6/11/2024	12:33:00	5.575	1.358	26.928	
6/11/2024	12:34:00	9.116	6.648	188.607	
6/11/2024	12:35:00	9.145	7.92	201.77	
6/11/2024	12:36:00	9.129	8.37	201.684	
6/11/2024	12:37:00	9.13	8.507	237.089	
6/11/2024	12:38:00	9.127	8.531	210.707	
6/11/2024	12:39:00	9.144	8.455	39.432	
6/11/2024	12:40:00	8.399	8.445	47.407	
6/11/2024	12:41:00	4.091	8.454	19.118	
6/11/2024	12:42:00	5.825	8.463	630.34	
6/11/2024	12:43:00	3.741	8.473	459.16	
6/11/2024	12:44:00	3.462	8.367	339.004	
6/11/2024	12:45:00	3.075	7.473	20.247	
6/11/2024	12:46:00	0.272	8.505	22.829	
6/11/2024	12:47:00	0.18	8.499	17.891	
6/11/2024	12:48:00	-0.011	8.508	1.593	
6/11/2024	12:49:00	5.366	8.513	143.236	
6/11/2024	12:50:00	8.873	8.527	241.391	
6/11/2024	12:51:00	8.372	8.539	235.864	
6/11/2024	12:52:00	9.177	8.539	211.807	
6/11/2024	12:53:00	9.142	8.539	69.334	Direct High
6/11/2024	12:54:00	1.433	2.825	0.578	
6/11/2024	12:55:00	0.045	0.014	1.845	
6/11/2024	12:56:00	0.042	0.014	1.33	Direct Zero
6/11/2024	12:57:00	4.087	3.478	82.37	
6/11/2024	12:58:00	4.585	4.602	41.754	
6/11/2024	12:59:00	4.587	4.601	2.544	Direct Mid
6/11/2024	13:00:00	5.257	4.87	-0.571	
6/11/2024	13:01:00	10.771	6.798	8.316	Direct NO2
6/11/2024	13:02:00	6.025	6.812	519.795	
6/11/2024	13:03:00	1.314	1.467	-685.007	
6/11/2024	13:04:00	3.567	0.064	15.035	
6/11/2024	13:05:00	5.554	0.033	0.762	
6/11/2024	13:06:00	10.617	0.026	-23.247	
6/11/2024	13:07:00	1.155	0.015	4.262	
6/11/2024	13:08:00	2.557	0.009	-6.369	
6/11/2024	13:09:00	5.902	0.018	51.693	
6/11/2024	13:10:00	10.769	0.029	226.897	
6/11/2024	13:11:00	10.769	0.016	228.236	
6/11/2024	13:12:00	10.769	0.026	228.239	
6/11/2024	13:13:00	10.769	0.008	32.451	
6/11/2024	13:14:00	10.769	0.017	0.03	Direct Zero CO
6/11/2024	13:15:00	10.769	0.02	196.914	
6/11/2024	13:16:00	10.769	0.018	228.22	
6/11/2024	13:17:00	10.769	0.024	228.203	Direct High CO

Date	Time	O <sub>2</sub> %	NO <sub>x</sub> PPM	CO PPM	Comments
6/11/2024	13:17:00	10.769	0.024	228.203	Direct High CO
6/11/2024	13:18:00	10.769	0.018	125.113	
6/11/2024	13:19:00	10.769	0.019	110.74	Direct Mid CO
6/11/2024	13:20:00	6.791	0.011	45.339	
6/11/2024	13:21:00	4.624	0.007	0.374	Sys O2
6/11/2024	13:22:00	1.964	1.96	-0.811	
6/11/2024	13:23:00	0.062	4.526	-1.532	Sys NOx
6/11/2024	13:24:00	0.06	2.945	48.538	
6/11/2024	13:25:00	0.062	0.017	109.129	Sys CO
6/11/2024	13:26:00	1.158	0.012	104.254	
6/11/2024	13:27:00	10.769	0.009	0.229	
6/11/2024	13:28:00	10.769	0.006	-0.844	
6/11/2024	13:29:00	10.669	0.015	0.654	
6/11/2024	13:30:00	4.268	5.504	108.616	
6/11/2024	13:31:00	4.322	6.543	82.387	
6/11/2024	13:32:00	4.257	6.761	95.916	
6/11/2024	13:33:00	4.218	6.633	90.632	
6/11/2024	13:34:00	4.243	7.007	71.031	
6/11/2024	13:35:00	4.203	6.782	79.705	
6/11/2024	13:36:00	4.14	6.414	72.379	
6/11/2024	13:37:00	4.057	6.186	102.951	
6/11/2024	13:38:00	4.103	6.548	68.403	Run 1 / Strat Check
6/11/2024	13:39:00	4.034	6.114	104.376	
6/11/2024	13:40:00	4.108	6.018	86.454	
6/11/2024	13:41:00	3.985	6.67	129.902	
6/11/2024	13:42:00	4.106	6.258	85.04	
6/11/2024	13:43:00	4.106	5.445	97.231	
6/11/2024	13:44:00	4.12	6.561	94.704	
6/11/2024	13:45:00	4.146	7.37	49.66	Pt 2
6/11/2024	13:46:00	4.061	5.702	36.907	
6/11/2024	13:47:00	3.971	4.679	75.683	
6/11/2024	13:48:00	4.241	5.822	68.122	
6/11/2024	13:49:00	4.225	6.675	95.258	
6/11/2024	13:50:00	4.256	5.572	129.592	
6/11/2024	13:51:00	4.3	5.027	75.552	
6/11/2024	13:52:00	4.223	5.905	133.503	Pt 1
6/11/2024	13:53:00	5.473	6.059	94.862	
6/11/2024	13:54:00	10.774	0.14	-3.948	
6/11/2024	13:55:00	4.962	5.684	10.039	
6/11/2024	13:56:00	4.178	8.335	59.021	
6/11/2024	13:57:00	4.105	6.728	83.395	
6/11/2024	13:58:00	4.107	5.749	62.79	
6/11/2024	13:59:00	4.071	6.794	67.742	
6/11/2024	14:00:00	4.113	7.964	91.545	
6/11/2024	14:01:00	4.14	7.217	72.14	
6/11/2024	14:02:00	4.149	6.013	75.346	Pt 3
6/11/2024	14:03:00	4.167	6.479	54.638	

Date	Time	O <sub>2</sub> %	NO <sub>x</sub> PPM	CO PPM	Comments
6/11/2024	14:04:00	9.966	2.164	11.308	
6/11/2024	14:05:00	10.773	0.03	-4.995	
6/11/2024	14:06:00	5.498	0.025	4.553	
6/11/2024	14:07:00	4.534	0.017	-3.068	Sys O2
6/11/2024	14:08:00	2.922	1.033	-3.768	
6/11/2024	14:09:00	0.044	4.544	-6.045	Sys NOx
6/11/2024	14:10:00	0.049	4.03	18.305	
6/11/2024	14:11:00	0.006	0.071	106.703	
6/11/2024	14:12:00	0.015	0.019	106.871	Sys CO 1411
6/11/2024	14:13:00	3.448	4.424	127.565	
6/11/2024	14:14:00	4.181	5.615	37.887	Run 2
6/11/2024	14:15:00	4.15	5.229	101.839	
6/11/2024	14:16:00	4.16	5.802	123.2	
6/11/2024	14:17:00	4.234	6.422	96.697	
6/11/2024	14:18:00	4.124	6.032	126.809	
6/11/2024	14:19:00	4.041	5.405	138.982	
6/11/2024	14:20:00	4.085	5.474	175.295	Pt 3
6/11/2024	14:21:00	4.142	6.429	114.574	
6/11/2024	14:22:00	4.034	6.031	164.29	
6/11/2024	14:23:00	4.04	5.217	148.155	
6/11/2024	14:24:00	4.327	5.476	26.027	
6/11/2024	14:25:00	4.202	6.71	46.245	
6/11/2024	14:26:00	4.054	5.953	189.297	
6/11/2024	14:27:00	4.115	5.056	141.487	Pt 2
6/11/2024	14:28:00	4.094	5.216	157.75	
6/11/2024	14:29:00	4.665	5.757	124.192	
6/11/2024	14:30:00	5.729	5.647	86.105	
6/11/2024	14:31:00	5.978	4.865	126.272	
6/11/2024	14:32:00	6.019	4.698	-5.462	
6/11/2024	14:33:00	5.201	5.175	-2.234	
6/11/2024	14:34:00	4.037	6.004	-0.006	
6/11/2024	14:35:00	4.089	5.761	184.774	
6/11/2024	14:36:00	3.996	5.446	448.254	
6/11/2024	14:37:00	4.103	5.579	448.758	
6/11/2024	14:38:00	4.134	5.971	448.19	
6/11/2024	14:39:00	4.182	5.947	447.358	
6/11/2024	14:40:00	4.132	5.645	447.315	Pt 1
6/11/2024	14:41:00	3.986	3.898	278.734	
6/11/2024	14:42:00	4.575	0.039	-0.275	
6/11/2024	14:43:00	4.542	0.03	-0.308	Sys O2 / Direct CO Zero
6/11/2024	14:44:00	4.434	0.777	21.375	
6/11/2024	14:45:00	0.232	4.272	447.637	
6/11/2024	14:46:00	0.012	4.558	451.331	Sys NOx / Direct High CO
6/11/2024	14:47:00	1.781	4.95	256.143	
6/11/2024	14:48:00	4.095	5.616	232.17	Direct Mid CO
6/11/2024	14:49:00	4.074	5.742	118.849	

Date	Time	O <sub>2</sub> %	NO <sub>x</sub> PPM	CO PPM	Comments
6/11/2024	14:50:00	4.092	6.147	61.988	
6/11/2024	14:51:00	4.083	6.192	48.217	Run 3
6/11/2024	14:52:00	4.054	5.593	83.744	
6/11/2024	14:53:00	4.114	5.448	75.408	
6/11/2024	14:54:00	4.12	5.84	59.275	
6/11/2024	14:55:00	4.115	6.088	66.419	
6/11/2024	14:56:00	4.08	5.884	95.257	
6/11/2024	14:57:00	4.041	5.655	111.78	
6/11/2024	14:58:00	4.097	5.605	86.551	Pt 2
6/11/2024	14:59:00	4.106	5.984	87.48	
6/11/2024	15:00:00	4.063	5.695	110.609	
6/11/2024	15:01:00	4.042	5.496	136.426	
6/11/2024	15:02:00	4.234	6.343	28.765	
6/11/2024	15:03:00	3.99	6.258	104.124	
6/11/2024	15:04:00	4.141	5.448	85.876	
6/11/2024	15:05:00	4.05	5.425	88.282	Pt 1
6/11/2024	15:06:00	4.03	5.667	136.56	
6/11/2024	15:07:00	4.022	5.673	212.167	
6/11/2024	15:08:00	4.021	5.548	192.17	
6/11/2024	15:09:00	4.052	5.831	136.912	
6/11/2024	15:10:00	4.259	6.252	67.82	
6/11/2024	15:11:00	4.117	6.478	149.315	
6/11/2024	15:12:00	3.86	4.988	149.895	Sys O2
6/11/2024	15:13:00	4.622	0.099	0.315	
6/11/2024	15:14:00	4.628	0.025	0.005	
6/11/2024	15:15:00	1.834	2.084	-0.739	
6/11/2024	15:16:00	0.037	4.569	-1.601	
6/11/2024	15:17:00	0.031	2.503	120.614	
6/11/2024	15:18:00	0.02	0.037	229.274	
6/11/2024	15:19:00	2.379	2.615	146.078	Sys NOx
6/11/2024	15:20:00	4.169	5.803	101.921	
6/11/2024	15:21:00	4.251	5.633	57.094	
6/11/2024	15:22:00	4.198	5.977	66.073	
6/11/2024	15:23:00	4.163	5.884	78.782	
6/11/2024	15:24:00	4.266	5.964	64.941	
6/11/2024	15:25:00	4.174	5.705	137.171	
6/11/2024	15:26:00	4.237	5.782	56.553	Pt 3
6/11/2024	15:27:00	4.169	5.787	85.429	
6/11/2024	15:28:00	4.153	5.91	87.202	
6/11/2024	15:29:00	4.17	5.969	72.434	
6/11/2024	15:30:00	4.18	6.108	44.09	
6/11/2024	15:31:00	4.197	6.06	35.094	
6/11/2024	15:32:00	4.101	5.706	57.817	
6/11/2024	15:33:00	4.175	5.63	44.618	Pt 2
6/11/2024	15:34:00	4.203	5.698	25.658	
6/11/2024	15:35:00	4.139	5.794	44.096	
6/11/2024	15:36:00	4.139	5.844	80.088	

Date	Time	O <sub>2</sub> %	NO <sub>x</sub> PPM	CO PPM	Comments
6/11/2024	15:37:00	4.209	5.869	52.084	
6/11/2024	15:38:00	4.288	5.868	26.255	
6/11/2024	15:39:00	4.213	5.748	72.975	
6/11/2024	15:40:00	4.16	5.637	108.498	
6/11/2024	15:41:00	3.948	5.545	69.04	Pt 1
6/11/2024	15:42:00	4.164	5.449	71.067	
6/11/2024	15:43:00	4.06	5.758	133.766	
6/11/2024	15:44:00	4.478	3.215	110.064	
6/11/2024	15:45:00	4.672	0.029	0.004	
6/11/2024	15:46:00	4.621	0.02	0.005	Sys O2
6/11/2024	15:47:00	2.979	0.995	-0.825	
6/11/2024	15:48:00	0.044	4.556	-2.959	Sys NOx
6/11/2024	15:49:00	2.52	5.183	59.996	
6/11/2024	15:50:00	4.174	6.004	68.216	
6/11/2024	15:51:00	1.313	3.18	155.045	
6/11/2024	15:52:00	0.114	0.025	228.779	Sys CO
6/11/2024	15:53:00	1.244	0.559	205.697	
6/11/2024	15:54:00	4.207	5.487	76.576	
6/11/2024	15:55:00	4.162	5.902	105.915	Run 5
6/11/2024	15:56:00	4.122	6.024	164.215	
6/11/2024	15:57:00	4.147	5.951	108.019	
6/11/2024	15:58:00	4.232	6.067	96.101	
6/11/2024	15:59:00	4.275	6.12	62.593	
6/11/2024	16:00:00	4.242	5.731	114.425	
6/11/2024	16:01:00	4.256	5.809	111.288	Pt 3
6/11/2024	16:02:00	4.219	5.968	171.093	
6/11/2024	16:03:00	4.078	6.022	116.117	
6/11/2024	16:04:00	4.095	5.889	79.685	
6/11/2024	16:05:00	4.265	5.876	35.305	
6/11/2024	16:06:00	4.153	5.77	147.373	
6/11/2024	16:07:00	4.144	5.797	84.305	
6/11/2024	16:08:00	4.062	5.957	161.376	Pt 2
6/11/2024	16:09:00	4.103	5.97	87.282	
6/11/2024	16:10:00	4.065	5.91	97.709	
6/11/2024	16:11:00	4.136	5.947	84.377	
6/11/2024	16:12:00	4.139	5.948	85.751	
6/11/2024	16:13:00	4.097	5.828	109.515	
6/11/2024	16:14:00	4.205	5.809	80.872	
6/11/2024	16:15:00	4.17	5.977	73.65	Pt 1
6/11/2024	16:16:00	4.063	3.703	39.397	
6/11/2024	16:17:00	4.652	0.026	-0.112	Sys O2
6/11/2024	16:18:00	2.113	1.814	-1.82	
6/11/2024	16:19:00	0.057	4.562	-3.215	Sys NOx
6/11/2024	16:20:00	0.04	2.828	106.613	
6/11/2024	16:21:00	0.039	0.023	228.581	Sys CO
6/11/2024	16:22:00	1.409	0.942	216.359	

Date	Time	O <sub>2</sub> %	NO <sub>x</sub> PPM	CO PPM	Comments
6/11/2024	16:23:00	4.161	5.603	128.251	
6/11/2024	16:24:00	4.21	6.046	85.995	Run 6
6/11/2024	16:25:00	4.213	6.153	95.303	
6/11/2024	16:26:00	4.1	5.865	150.982	
6/11/2024	16:27:00	4.12	5.703	145.806	
6/11/2024	16:28:00	4.298	5.973	121.864	
6/11/2024	16:29:00	4.233	6.261	79.442	
6/11/2024	16:30:00	4.246	5.971	112.064	Pt 3
6/11/2024	16:31:00	4.185	5.69	123.914	Pt 2
6/11/2024	16:32:00	4.181	5.811	81.675	
6/11/2024	16:33:00	4.134	5.821	99.733	
6/11/2024	16:34:00	4.102	5.928	141.128	
6/11/2024	16:35:00	4.112	5.953	101.615	
6/11/2024	16:36:00	4.268	6.077	36.467	
6/11/2024	16:37:00	4.199	5.959	88.475	
6/11/2024	16:38:00	4.202	5.775	84.131	Pt 1
6/11/2024	16:39:00	4.139	5.736	121.899	
6/11/2024	16:40:00	4.215	5.844	58.437	
6/11/2024	16:41:00	4.148	5.993	68.694	
6/11/2024	16:42:00	4.16	5.762	85.22	
6/11/2024	16:43:00	4.123	5.636	177.923	
6/11/2024	16:44:00	4.197	5.77	112.651	
6/11/2024	16:45:00	4.313	3.33	68.223	
6/11/2024	16:46:00	4.611	0.031	0.051	Sys O2
6/11/2024	16:47:00	2.445	1.434	-0.642	
6/11/2024	16:48:00	0.086	4.557	-1.901	Sys NOx
6/11/2024	16:49:00	0.068	2.804	111.699	
6/11/2024	16:50:00	0.053	0.028	229.539	Sys CO
6/11/2024	16:51:00	0.063	0.018	230.17	
6/11/2024	16:52:00	3.836	4.105	231.739	Direct Mid CO
6/11/2024	16:53:00	4.146	5.484	45.124	
6/11/2024	16:54:00	4.112	5.904	-0.103	Direct Zero CO
6/11/2024	16:55:00	4.196	6.097	-0.082	
6/11/2024	16:56:00	4.168	5.987	0.01	
6/11/2024	16:57:00	4.242	5.945	0.008	Run 7
6/11/2024	16:58:00	4.189	5.937	0.008	
6/11/2024	16:59:00	4.378	6.158	0.01	
6/11/2024	17:00:00	4.234	5.734	0.007	
6/11/2024	17:01:00	4.331	5.538	0.009	
6/11/2024	17:02:00	4.329	5.922	0.041	
6/11/2024	17:03:00	4.309	6.134	0.516	
6/11/2024	17:04:00	4.185	6.06	0.803	
6/11/2024	17:05:00	4.146	5.918	1.001	
6/11/2024	17:06:00	4.072	5.961	1.002	
6/11/2024	17:07:00	4.311	5.906	1	
6/11/2024	17:08:00	4.177	5.918	0.999	
6/11/2024	17:09:00	4.267	5.951	0.999	



Date	Time	O <sub>2</sub> %	NO <sub>x</sub> PPM	CO PPM	Comments
6/11/2024	17:10:00	4.232	5.667	0.998	Pt 2
6/11/2024	17:11:00	4.177	5.621	0.998	
6/11/2024	17:12:00	4.175	5.779	1.002	
6/11/2024	17:13:00	4.289	6.138	1.001	
6/11/2024	17:14:00	4.284	5.928	0.998	
6/11/2024	17:15:00	4.156	5.681	0.998	
6/11/2024	17:16:00	4.072	5.622	1.016	
6/11/2024	17:17:00	4.173	5.701	0.985	Pt 1
6/11/2024	17:18:00	4.185	2.639	1.02	
6/11/2024	17:19:00	4.645	0.027	1.271	Sys O2
6/11/2024	17:20:00	1.735	2.124	1.54	
6/11/2024	17:21:00	0.102	4.556	1.635	Sys NOx
6/11/2024	17:22:00	2.455	5.117	1.895	
6/11/2024	17:23:00	4.129	6.049	1.985	
6/11/2024	17:24:00	4.202	6.034	2.001	Run 8
6/11/2024	17:25:00	4.175	6.088	2.006	
6/11/2024	17:26:00	4.202	5.969	2.007	
6/11/2024	17:27:00	4.222	6.074	2.006	
6/11/2024	17:28:00	4.298	5.981	1.99	
6/11/2024	17:29:00	4.257	5.897	2.007	
6/11/2024	17:30:00	4.198	5.967	2.009	Pt 3
6/11/2024	17:31:00	4.28	6.046	2.008	
6/11/2024	17:32:00	4.278	6.061	2.008	
6/11/2024	17:33:00	4.137	5.912	2.008	
6/11/2024	17:34:00	4.157	5.695	2.01	
6/11/2024	17:35:00	4.044	5.663	2.01	
6/11/2024	17:36:00	4.159	5.81	2.01	
6/11/2024	17:37:00	4.174	6.059	2.008	Pt 2
6/11/2024	17:38:00	4.238	6.007	2.003	
6/11/2024	17:39:00	4.108	5.928	2.003	
6/11/2024	17:40:00	4.191	5.754	2.004	
6/11/2024	17:41:00	4.188	5.763	2.037	
6/11/2024	17:42:00	4.184	5.712	2.044	
6/11/2024	17:43:00	4.303	5.743	2	
6/11/2024	17:44:00	4.131	5.943	2.051	Pt 1
6/11/2024	17:45:00	4.081	4.609	2.005	
6/11/2024	17:46:00	4.636	0.053	2.028	Sys O2
6/11/2024	17:47:00	1.745	2.085	2.007	
6/11/2024	17:48:00	0.053	4.554	2.004	Sys NOx
6/11/2024	17:49:00	2.696	5.313	2.012	
6/11/2024	17:50:00	4.209	6.192	2.011	
6/11/2024	17:51:00	4.203	6.092	2.024	Run 9
6/11/2024	17:52:00	4.219	5.818	2.007	
6/11/2024	17:53:00	4.167	5.786	2.01	
6/11/2024	17:54:00	4.247	5.96	2.012	
6/11/2024	17:55:00	4.244	6.237	2.04	
6/11/2024	17:56:00	4.246	5.965	2.011	

Date	Time	O <sub>2</sub> %	NO <sub>x</sub> PPM	CO PPM	Comments
6/11/2024	17:57:00	4.147	5.728	2.192	Pt 3
6/11/2024	17:58:00	4.163	5.508	2.171	
6/11/2024	17:59:00	4.175	5.821	2.384	
6/11/2024	18:00:00	4.201	6.279	2.424	
6/11/2024	18:01:00	4.28	6.257	2.331	
6/11/2024	18:02:00	4.182	5.837	2.407	
6/11/2024	18:03:00	4.23	5.75	2.247	
6/11/2024	18:04:00	4.268	5.897	2.171	Pt 2
6/11/2024	18:05:00	4.199	6.238	2.146	
6/11/2024	18:06:00	4.091	5.921	2.111	
6/11/2024	18:07:00	4.115	5.732	2.014	
6/11/2024	18:08:00	4.155	5.669	2.066	
6/11/2024	18:09:00	4.071	5.561	2.075	
6/11/2024	18:10:00	4.115	5.58	2.013	
6/11/2024	18:11:00	4.108	5.77	2.072	Pt 1
6/11/2024	18:12:00	3.997	4.552	2.014	
6/11/2024	18:13:00	4.584	0.066	1.981	Sys O2
6/11/2024	18:14:00	2.453	1.351	2.009	
6/11/2024	18:15:00	0.062	4.547	2.01	Sys NOx
6/11/2024	18:16:00	3.878	4.59	1.99	
6/11/2024	18:17:00	4.66	4.614	2.005	Direct Mid
6/11/2024	18:18:00	0.461	1.509	2.028	
6/11/2024	18:19:00	-0.118	0.008	2.002	Direct Zero
6/11/2024	18:20:00	-0.19	0.018	1.928	

## **Appendix A.3**

### **Quality Assurance Data**

**Montrose Air Quality Services, LLC**  
**CEMS Performance Data Sheet**



Client: GenOn Energy  
 Location: Ormond Beach Unit 1  
 CEMS ID#: 4-CEMS

Date: 6/11/2024  
 Performed By: JP/PR/TM/AE

Analyzer:	O <sub>2</sub>	CO <sub>2</sub>	NO <sub>x</sub>	CO	SO <sub>2</sub>
Manufacturer:	CAI	--	CAI	Thermo	--
Serial Number:	U02022		T10007	0634019583	
CEMS Probe:	Material:	S.S.	Length:	14'	Gas Temp: 250 °F
Heated Line	Material:	Teflon	Length:	10'	Gas Temp: 250 °F
Sample Conditioner:			Type:	Universal	Gas Temp: 33.8 °F
CEMS Line:	Material:	Teflon	Length:	150'	
Bias Line:	Material:	Teflon	Length:	150'	
Upscale Response Time:	30		Downscale Response Time:	30	seconds
Sample Pressure (psi):	6		Sample Flow Rate:	6	SCFH

**Montrose Air Quality Services, LLC**  
**SPAN GAS RECORD AND CALIBRATION ERROR**



CLIENT/LOCATION: Ormond Beach Unit 1  
 TRUCK/CEM I.D.: 4-CEMS

DATE: 6/11/24  
 BY: JP/PR/TM/AE

	CYLINDER NO.	CONCENTRATION	Expiration Date	Vendor ID
ZERO	CC70210	0.0	4/2/2032	
O <sub>2</sub>	CC252942	4.50	4/17/2032	B32024
O <sub>2</sub>	EB0160719	9.14	12/7/2030	F22022
NO <sub>x</sub>	CC8732	4.490	5/1/2026	F22023
NO <sub>x</sub>	CC437328	8.411	4/3/2027	B32024
CO	DT0010548	228.0	11/3/2030	F22022
CO	ALM055503	451.4	5/6/2032	B32024
NO <sub>2</sub>	CC506459	7.43	4/24/2027	B32024

**PRE-TEST INSTRUMENT CALIBRATION ERROR**

	ANALYZER				STATUS
	O <sub>2</sub>	NO <sub>x</sub>	CO		
Calibration Span	9.14	8.41	451.4		
Zero Gas Value	0.0	0.0	0.0		--
Analyzer Reads	0.04	0.014	-0.31		--
Error (% of scale)	0.5%	0.2%	-0.1%		PASS
High Gas Value	9.14	8.411	451.4		--
Analyzer Reads	9.14	8.54	451.33		--
Error (% of scale)	0.0%	1.5%	0.0%		PASS
Mid Gas Value	4.50	4.490	228.0		--
Analyzer Reads	4.59	4.60	232.17		--
Error (% of scale)	0.9%	1.3%	0.9%		PASS

**Montrose Air Quality Services, LLC**  
**NO2 to NO Converter Efficiency Test**



Analyzer Manufacturer: CAI	NO Cal Gas Value: 8.411
Analyzer Model: 600	NO <sub>2</sub> Cal Gas Value: 7.43      C <sub>1</sub>
Analyzer Serial Number: T10007	Performed By: JP/PR/TM/AE
Date: 6/11/24	CEMS ID#: 4-CEMS

GAS	ANALYZER MODE	ANALYZER RESPONSE	CAL CORRECTED	LABEL
Zero	NO <sub>x</sub>	0.01	--	--
NO	NO <sub>x</sub>	8.54	--	--
NO <sub>2</sub>	NO <sub>x</sub>	6.80	6.69	C <sub>2</sub>

	Requirement
CE = C <sub>2</sub> /C <sub>1</sub> * 100%: 90.1%	≥ 90%

Cylinder #	Exp. Date
NO bottle: CC437328	4/3/2027
NO <sub>2</sub> bottle: CC506459	4/24/2027

**REFERENCE METHOD CEMS QUALITY ASSURANCE DATA AND WORKSHEET  
SAMPLE SYSTEM BIAS AND ANALYZER DRIFT RESULTS**

Generating Station: Ormond Beach  
 Unit: 1  
 Test Date: 6/11/2024

Performed By: JP/PR/TM/AE  
 Test Condition: 261 MW  
 Fuel F-Factor: 8,710 dscf/MMBtu

Run Number	1		2		3		4		5		6		7		8		9	
	6/11/2024 13:38	6/11/2024 14:02	6/11/2024 14:13	6/11/2024 14:40	6/11/2024 14:50	6/11/2024 15:11	6/11/2024 15:19	6/11/2024 15:40	6/11/2024 15:54	6/11/2024 16:15	6/11/2024 16:23	6/11/2024 16:44	6/11/2024 16:56	6/11/2024 17:17	6/11/2024 17:23	6/11/2024 17:44	6/11/2024 17:50	6/11/2024 18:11
	O <sub>2</sub>	NO <sub>x</sub>	O <sub>2</sub>	NO <sub>x</sub>	O <sub>2</sub>	NO <sub>x</sub>	O <sub>2</sub>	NO <sub>x</sub>	O <sub>2</sub>	NO <sub>x</sub>	O <sub>2</sub>	NO <sub>x</sub>	O <sub>2</sub>	NO <sub>x</sub>	O <sub>2</sub>	NO <sub>x</sub>	O <sub>2</sub>	NO <sub>x</sub>
Calibration Span	9.14	8.411	9.14	8.411	9.14	8.411	9.14	8.411	9.14	8.411	9.14	8.411	9.14	8.411	9.14	8.411	9.14	8.411
Span Gas Value	4.50	4.49	4.50	4.49	4.50	4.49	4.50	4.49	4.50	4.49	4.50	4.49	4.50	4.49	4.50	4.49	4.50	4.49
Analyzer Zero	0.04	0.01	0.04	0.01	0.04	0.01	0.04	0.01	0.04	0.01	0.04	0.01	0.04	0.01	0.04	0.01	0.04	0.01
Analyzer Span	4.59	4.60	4.59	4.60	4.59	4.60	4.59	4.60	4.59	4.60	4.59	4.60	4.59	4.60	4.59	4.60	4.59	4.60
Pre-Test Zero Bias	0.06	0.01	0.04	0.02	0.01	0.03	0.04	0.03	0.04	0.02	0.06	0.03	0.09	0.03	0.10	0.03	0.05	0.05
Pre-Test Span Bias	4.62	4.53	4.53	4.54	4.54	4.56	4.63	4.57	4.62	4.56	4.65	4.56	4.61	4.56	4.65	4.56	4.64	4.55
Post-Test Zero Bias	0.04	0.02	0.01	0.03	0.04	0.03	0.04	0.02	0.06	0.03	0.09	0.03	0.10	0.03	0.05	0.05	0.06	0.07
Post-Test Span Bias	4.53	4.54	4.54	4.56	4.63	4.57	4.62	4.56	4.65	4.56	4.61	4.56	4.65	4.56	4.64	4.55	4.58	4.55
Pre-Test Zero Bias(%):	0.2%	-0.1%	0.0%	0.0%	-0.3%	0.2%	-0.1%	0.1%	0.0%	0.1%	0.2%	0.1%	0.5%	0.2%	0.7%	0.2%	0.1%	0.5%
Pre-Test Span Bias(%):	0.4%	-0.9%	-0.6%	-0.7%	-0.5%	-0.5%	0.4%	-0.4%	0.4%	-0.5%	0.7%	-0.5%	0.3%	-0.5%	0.6%	-0.5%	0.5%	-0.6%
Post-Test Zero Bias (%):	1.8%	0.1%	1.4%	0.3%	1.7%	0.2%	1.8%	0.1%	1.9%	0.2%	2.2%	0.3%	2.4%	0.2%	1.9%	0.5%	2.0%	0.7%
Post-Test Span Bias(%):	-1.4%	-0.8%	-1.3%	-0.7%	-0.4%	-0.5%	-0.4%	-0.7%	-0.1%	-0.6%	-0.5%	-0.7%	-0.2%	-0.7%	-0.3%	-0.7%	-0.8%	-0.8%
Zero Drift (%):	-0.2%	0.1%	-0.4%	0.2%	0.3%	-0.1%	0.1%	-0.1%	0.1%	0.1%	0.3%	0.1%	0.2%	0.0%	-0.5%	0.3%	0.1%	0.2%
Span Drift (%):	-1.0%	0.2%	0.1%	0.2%	0.9%	0.1%	-0.1%	-0.2%	0.3%	0.1%	-0.4%	-0.1%	0.4%	0.0%	-0.1%	0.0%	-0.6%	-0.1%

**ABBREVIATED STRATIFICATION CHECK  
EPA "LONG LINE"  
Ormond Beach Unit 1**



Date	Time	O <sub>2</sub>	NO <sub>x</sub>		O <sub>2</sub> Avg.	NO <sub>x</sub> Avg.
6/11/2024	13:39:00	4.034	6.114			
6/11/2024	13:40:00	4.108	6.018			
6/11/2024	13:41:00	3.985	6.67			
6/11/2024	13:42:00	4.106	6.258			
6/11/2024	13:43:00	4.106	5.445			
6/11/2024	1:44:00 PM	4.12	6.561			
6/11/2024	1:45:00 PM	4.146	7.37	Point 2	4.09	6.35
6/11/2024	1:46:00 PM	4.061	5.702			
6/11/2024	1:47:00 PM	3.971	4.679			
6/11/2024	1:48:00 PM	4.241	5.822			
6/11/2024	1:49:00 PM	4.225	6.675			
6/11/2024	1:50:00 PM	4.256	5.572			
6/11/2024	1:51:00 PM	4.3	5.027			
6/11/2024	1:52:00 PM	4.223	5.905	Point 1	4.18	5.63
6/11/2024	1:56:00 PM	4.178	8.335			
6/11/2024	1:57:00 PM	4.105	6.728			
6/11/2024	1:58:00 PM	4.107	5.749			
6/11/2024	1:59:00 PM	4.071	6.794			
6/11/2024	2:00:00 PM	4.113	7.964			
6/11/2024	2:01:00 PM	4.14	7.217			
6/11/2024	2:02:00 PM	4.149	6.013	Point 3	4.12	6.97

Average	4.13	6.32
Maximum	4.18	6.97
Minimum	4.09	5.63
Maximum Difference from Average	0.05	0.69
Max Difference (% of average)	1.3%	10.9%
Status	Pass	Pass

**Notes:**

**If max difference is < 10%, short-line may be used**

**If max difference is < 5 ppm for NO<sub>x</sub> and 0.5% for O<sub>2</sub>, short line may be used.**



## CERTIFICATE OF BATCH ANALYSIS

### Grade of Product: CEM-CAL ZERO

Part Number: NICZ15A	Reference Number: 48-403008504-1
Cylinder Analyzed: CC 210052	Cylinder Volume: 142.0 CF
Laboratory: 124 - Los Angeles (SAP) - CA	Cylinder Pressure: 2000 PSIG
Analysis Date: Apr 02, 2024	Valve Outlet: 580
Lot Number: 48-403008504-1	

Expiration Date: Apr 02, 2032

### ANALYTICAL RESULTS

Component	Requested Purity	Certified Concentration
NITROGEN	99.9995 %	99.9995 %
NOx	0.1 PPM	<LDL 0.018 PPM
SO2	0.1 PPM	<LDL 0.095 PPM
THC	0.1 PPM	<LDL 0.006 PPM
CARBON MONOXIDE	0.5 PPM	<LDL 0.012 PPM
CARBON DIOXIDE	1.0 PPM	<LDL 0.016 PPM

**Permanent Notes:** Airgas certifies that the contents of this cylinder meet the requirements of 40 CFR 72.2

**Cylinders in Batch:**

CC 210052, CC190141, CC345865, CC484536, CC70210, CC724938

Impurities verified against analytical standards traceable to NIST by weight and/or analysis.



N<sub>2</sub>  
CC70210  
EXP. 04/02/2032

  
 \_\_\_\_\_  
 Approved for Release

Lo 05 110/2024  
Page 1 of 1

# CERTIFICATE OF ANALYSIS

## Grade of Product: EPA PROTOCOL STANDARD

Part Number: E03NI86E15A62Q5	Reference Number: 48-403017517-1
Cylinder Number: CC252942	Cylinder Volume: 150.0 CF
Laboratory: 124 - Los Angeles (SAP) - CA	Cylinder Pressure: 2015 PSIG
PGVP Number: B32024	Valve Outlet: 580
Gas Code: CO2,O2,BALN	Certification Date: Apr 17, 2024

**Expiration Date: Apr 17, 2032**

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted. The results relate only to the items tested. The report shall not be reproduced except in full without approval of the laboratory. Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	4.500 %	4.503 %	G1	+/- 0.8% NIST Traceable	04/17/2024
CARBON DIOXIDE	9.000 %	9.090 %	G1	+/- 0.6% NIST Traceable	04/17/2024
NITROGEN	Balance				

CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	11060709	CC338159	4.861 % OXYGEN/NITROGEN	+/- 0.4%	Nov 02, 2028
NTRM	13060402	CC411643	7.489 % CARBON DIOXIDE/NITROGEN	+/- 0.6%	May 14, 2025

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
SIEMENS 6E CO2	NDIR	Mar 26, 2024
SIEMENS OXYMAT 6	PARAMAGNETIC	Mar 25, 2024

Triad Data Available Upon Request



O<sub>2</sub> 4.503%  
 CO<sub>2</sub> 9.090%  
 CC252942  
 EXP. 04/17/2032  
 B32024

Approved for Release

LO 05/07/2024



Making our world more productive

DocNumber: 529578



Linde Gas & Equipment Inc. 5700 S. Alameda Street Los Angeles CA 90058 Tel: 323-585-2154 Fax: 714-542-6689 PGVP ID: F22022

# CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

### Customer & Order Information

MONROSE AIR QUALITY SERVICES  
1631 E ST ANDREWS PLACE  
SANTA ANA CA 92705

Certificate Issuance Date: 12/08/2022

Linde Order Number: 72275211

Part Number: NI CD905E-AS

Customer PO Number: 80281340

Fill Date: 12/02/2022

Lot Number: 70086233606

Cylinder Style & Outlet: AS CGA 590

Cylinder Pressure and Volume: 2000 psig 146 ft3

### Certified Concentration

Expiration Date:	12/07/2030	NIST Traceable
Cylinder Number:	EB0160719	Expanded Uncertainty
9.13 %	Carbon dioxide	± 0.04 %
9.14 %	Oxygen	± 0.04 %
Balance	Nitrogen	

### ProSpec EZ Cert



### Certification Information:

Certification Date: 12/07/2022

Term: 96 Months

Expiration Date: 12/07/2030

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1. Uncertainty above is expressed as absolute expanded uncertainty at a level of confidence of approximately 95% with a coverage factor k = 2. Do Not Use this Standard if Pressure is less than 100 PSIG.

CO2 responses have been corrected for Oxygen IR Broadening effect.

### Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

#### 1. Component:

Carbon dioxide

Requested Concentration: 9 %  
Certified Concentration: 9.13 %  
Instrument Used: Horiba VIA-510 S/N 20C194WK  
Analytical Method: NDIR  
Last Multipoint Calibration: 11/11/2022

#### Reference Standard:

Type / Cylinder #: GMIS / CC176580

Concentration / Uncertainty: 14.26 % ± 0.03 %

Expiration Date: 01/21/2030

Traceable to: SRM # / Sample # / Cylinder #: NTRM / N/A / CC726055

SRM Concentration / Uncertainty: 19.34% / ± 0.03%

SRM Expiration Date: 01/12/2027

First Analysis Data:				Date			
Z:	0	R:	14.26	C:	9.14	Conc:	9.13
R:	14.28	Z:	0	C:	9.14	Conc:	9.13
Z:	0	C:	9.13	R:	14.27	Conc:	9.12
UOM:	%	Mean Test Assay:		9.13	%		

Second Analysis Data:				Date			
Z:	0	R:	0	C:	0	Conc:	0
R:	0	Z:	0	C:	0	Conc:	0
Z:	0	C:	0	R:	0	Conc:	0
UOM:	%	Mean Test Assay:			%		

#### 2. Component:

Oxygen

Requested Concentration: 9 %  
Certified Concentration: 9.14 %  
Instrument Used: Siemens Oxymat 6E S/N 7MB20211AA000CA1  
Analytical Method: Paramagnetic  
Last Multipoint Calibration: 11/11/2022

#### Reference Standard:

Type / Cylinder #: GMIS / SGAL2761

Concentration / Uncertainty: 14.98 % ± 0.02 %

Expiration Date: 07/19/2026

Traceable to: SRM # / Sample # / Cylinder #: SRM 2659a / 71-E-19 / FF22331

SRM Concentration / Uncertainty: 20.863% / ± 0.021%

SRM Expiration Date: 08/23/2021

First Analysis Data:				Date			
Z:	0	R:	14.98	C:	9.139	Conc:	9.14
R:	14.98	Z:	0	C:	9.136	Conc:	9.14
Z:	0	C:	9.137	R:	14.98	Conc:	9.14
UOM:	%	Mean Test Assay:		9.14	%		

Second Analysis Data:				Date			
Z:	0	R:	0	C:	0	Conc:	0
R:	0	Z:	0	C:	0	Conc:	0
Z:	0	C:	0	R:	0	Conc:	0
UOM:	%	Mean Test Assay:			%		

Analyzed By

Christopher Hernandez

Certified By

Courtney Zielke

O<sub>2</sub> 9.14 %  
CO<sub>2</sub> 9.13 %  
EB0160719  
Exp. 12/7/30  
F22022

Information contained herein has been prepared at your request by qualified experts within Linde Gas & Equipment Inc. While we believe that the information is accurate within the limits of the analytical methods employed and is complete to the extent of the specific analyses performed, we make no warranty or representation as to the suitability of the use of the information for any purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall the liability of Linde Gas & Equipment Inc., arising out of the use of the information contained herein exceed the fee established for providing such information.

Page 1 of 1

JS 6/6/23



Making our world more productive

DocNumber: 538772



Linde Gas & Equipment Inc. 5700 S. Alameda Street Los Angeles CA 90058 Tel: 323-585-2154 Fax: 714-542-6689 PGVP ID: F22023

# CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

### Customer & Order Information

MONTROSE AIR QUALITY SERVICES  
1631 E ST ANDREWS PLACE  
SANTA ANA CA 92705

Certificate Issuance Date: 05/01/2023

Linde Order Number: 95892301

Part Number: NI NO4.5ME-AS

Customer PO Number: ALFRED STEWART

Fill Date: 04/20/2023

Lot Number: 70086310907

Cylinder Style & Outlet: AS

CGA 660

Cylinder Pressure and Volume: 2000 psig 140 ft3

### Certified Concentration

Expiration Date:	05/01/2026	NIST Traceable
Cylinder Number:	CC8732	Expanded Uncertainty
4.47 ppm	Nitric oxide	± 0.03 ppm
Balance	Nitrogen	

### ProSpec EZ Cert



For Reference Only: NOx 4.49 ppm

Certification Information: Certification Date: 05/01/2023 Term: 36 Months Expiration Date: 05/01/2026

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1. Uncertainty above is expressed as absolute expanded uncertainty at a level of confidence of approximately 95% with a coverage factor k = 2. Do Not Use this Standard if Pressure is less than 100 PSIG.

### Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

#### 1. Component:

Nitric oxide

Requested Concentration: 4.5 ppm  
Certified Concentration: 4.47 ppm  
Instrument Used: Thermo Electron 42i-LS S/N 1030645077  
Analytical Method: Chemiluminescence  
Last Multipoint Calibration: 04/10/2023

#### Reference Standard:

Type / Cylinder #: GMIS / DT0037199

Concentration / Uncertainty: 5.43 ppm ±0.03 ppm

Expiration Date: 12/15/2024

Traceable to: SRM # / Sample # / Cylinder #: PRM / C2268801 / APEX1429266

SRM Concentration / Uncertainty: 10.01 ppm / ±0.05 ppm

SRM Expiration Date: 09/30/2024

First Analysis Data:				Date	04/24/2023		
Z:	0	R:	5.43	C:	4.46	Conc:	4.46
R:	5.43	Z:	0	C:	4.47	Conc:	4.47
Z:	0	C:	4.45	R:	5.42	Conc:	4.45
UOM:	ppm	Mean Test Assay:		4.46	ppm		

Second Analysis Data:				Date	05/01/2023		
Z:	0	R:	5.43	C:	4.47	Conc:	4.48
R:	5.42	Z:	0	C:	4.46	Conc:	4.47
Z:	0	C:	4.46	R:	5.42	Conc:	4.47
UOM:	ppm	Mean Test Assay:		4.47	ppm		

Analyzed By

Lissette Morales

Certified By

Nelson Ma

NOx 4.49 ppm

CC8732

Exp. 5/1/26

F22023

JS 6/12/23

Information contained herein has been prepared at your request by qualified experts within Linde Gas & Equipment Inc. While we believe that the information is accurate within the limits of the analytical methods employed and is complete to the extent of the specific analyses performed, we make no warranty or representation as to the suitability of the use of the information for any purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall the liability of Linde Gas & Equipment Inc. arising out of the use of the information contained herein exceed the fee established for providing such information. Page 1 of 1

## CERTIFICATE OF ANALYSIS

### Grade of Product: EPA PROTOCOL STANDARD

Part Number: E02NI99E15AC0A0	Reference Number: 48-403001708-1
Cylinder Number: CC437328	Cylinder Volume: 144.0 CF
Laboratory: 124 - Los Angeles (SAP) - CA	Cylinder Pressure: 2015 PSIG
PGVP Number: B32024	Valve Outlet: 660
Gas Code: NO,NOX,BALN	Certification Date: Apr 03, 2024

**Expiration Date: Apr 03, 2027**

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted. The results relate only to the items tested. The report shall not be reproduced except in full without approval of the laboratory. Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	8.500 PPM	8.411 PPM	G1	+/- 0.9% NIST Traceable	03/26/2024, 04/03/2024
NITRIC OXIDE	8.500 PPM	8.355 PPM	G1	+/- 1.1% NIST Traceable	03/26/2024, 04/03/2024
NITROGEN	Balance				

CALIBRATION STANDARDS						
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date	
NTRM	16010112	ND47885	9.95 PPM NITRIC OXIDE/NITROGEN	+/- 1.0%	Jun 07, 2026	
PRM	12402	APEX1324263-NOx	10.01 PPM NOx/NITROGEN	+/- 0.5%	Dec 23, 2022	
GMIS	16010112	ND47885-NOX	9.95 PPM NOx/NITROGEN	+/- 0.6%	May 14, 2024	

The SRM, NTRM, PRM, or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
nCLD 844 S 844N0213 NO	Chemiluminescence	Mar 22, 2024
nCLD 844 S 844N0213 NOx	Chemiluminescence	Mar 22, 2024

Triad Data Available Upon Request



NOX 8.411 PPM  
CC437328  
EXP. 04/03/2027  
B32024

\_\_\_\_\_  
Approved for Release

LO 05/07/2024



Making our world more productive



Linde Gas & Equipment Inc. 5700 S. Alameda Street Los Angeles CA 90058 Tel: 323-585-2154 Fax: 714-542-6689 PGVP ID: F22022

DocNumber: 527374

# CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

### Customer & Order Information

MONTROSE AIR QUALITY SERVICES  
1631 E ST ANDREWS PLACE  
SANTA ANA CA 92705

Certificate Issuance Date: 11/04/2022  
Linde Order Number: 82843861  
Part Number: NI CO225E-AS  
Customer PO Number: LUIS OLIVARES

Fill Date: 10/25/2022  
Lot Number: 70086229807  
Cylinder Style & Outlet: AS CGA 350  
Cylinder Pressure and Volume: 2000 psig 146 ft3

### Certified Concentration

Expiration Date:	11/03/2030	NIST Traceable
Cylinder Number:	DT0010548	Expanded Uncertainty
228.0 ppm	Carbon monoxide	± 0.9 ppm
Balance	Nitrogen	

### ProSpec EZ Cert



### Certification Information:

Certification Date: 11/03/2022 Term: 96 Months Expiration Date: 11/03/2030

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1. Uncertainty above is expressed as absolute expanded uncertainty at a level of confidence of approximately 95% with a coverage factor k = 2. Do Not Use this Standard if Pressure is less than 100 PSIG.

### Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: Carbon monoxide  
Requested Concentration: 225 ppm  
Certified Concentration: 228.0 ppm  
Instrument Used: Horiba VIA-510 S/N 576876015  
Analytical Method: NDIR  
Last Multipoint Calibration: 10/05/2022

Reference Standard: Type / Cylinder #: GMIS / CC174333  
Concentration / Uncertainty: 245.2 ppm ±0.6 ppm  
Expiration Date: 11/13/2029  
Traceable to: SRM # / Sample # / Cylinder #: SRM 2636a / 57-G-06 / FF55714  
SRM Concentration / Uncertainty: 248.87 ppm / ±0.54 ppm  
SRM Expiration Date: 04/13/2024

First Analysis Data:				Date			
Z:	0	R:	245.2	C:	227.9	Conc:	228
R:	245.1	Z:	0	C:	228	Conc:	228.1
Z:	0	C:	227.9	R:	245.1	Conc:	228
UOM: ppm				Mean Test Assay: 228 ppm			

Second Analysis Data:				Date			
Z:	0	R:	0	C:	0	Conc:	0
R:	0	Z:	0	C:	0	Conc:	0
Z:	0	C:	0	R:	0	Conc:	0
UOM: ppm				Mean Test Assay: ppm			

Analyzed By: Christopher Hernandez

Certified By: Courtney Zolke

CO 228  
DT 0010548  
EXP 11-3-30  
F22022

AS 12-27-22

Information contained herein has been prepared at your request by qualified experts within Linde Gas & Equipment Inc. While we believe that the information is accurate within the limits of the analytical methods employed and is complete to the extent of the specific analyses performed, we make no warranty or representation as to the suitability of the use of the information for any purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall the liability of Linde Gas & Equipment Inc. arising out of the use of the information contained herein exceed the fee established for providing such information.

## CERTIFICATE OF ANALYSIS

### Grade of Product: EPA PROTOCOL STANDARD

Part Number: E02NI99E15A0499	Reference Number: 48-403035216-1
Cylinder Number: ALM055503	Cylinder Volume: 144.0 CF
Laboratory: 124 - Los Angeles (SAP) - CA	Cylinder Pressure: 2015 PSIG
PGVP Number: B32024	Valve Outlet: 350
Gas Code: CO,BALN	Certification Date: May 06, 2024

**Expiration Date: May 06, 2032**

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted. The results relate only to the items tested. The report shall not be reproduced except in full without approval of the laboratory. Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
CARBON MONOXIDE	450.0 PPM	451.4 PPM	G1	+/- 0.8% NIST Traceable	05/06/2024
NITROGEN	Balance				

CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	150605-51	CC453980	491.9 PPM CARBON MONOXIDE/	+/- 0.6%	Mar 05, 2027

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet iS50 AUP2110317 CO	FTIR	May 01, 2024

Triad Data Available Upon Request



CO 451.4ppm  
ALM 055503  
EXP. 05/06/2032  
B32024

Approved for Release

LO 05/24/2024

# CERTIFICATE OF ANALYSIS

## Grade of Product: EPA PROTOCOL STANDARD

Part Number: E02AI99E15WC004	Reference Number: 48-403015665-1
Cylinder Number: CC506459	Cylinder Volume: 146.0 CF
Laboratory: 124 - Los Angeles (SAP) - CA	Cylinder Pressure: 2015 PSIG
PGVP Number: B32024	Valve Outlet: 660
Gas Code: NO2,O2,BALN	Certification Date: Apr 24, 2024

**Expiration Date: Apr 24, 2027**

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted. The results relate only to the items tested. The report shall not be reproduced except in full without approval of the laboratory. Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NITROGEN DIOXIDE AIR	7.750 PPM Balance	7.426 PPM	G1	+/- 1.6% NIST Traceable	04/17/2024, 04/24/2024

CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
GMIS	1534012021203	ND73014	10.11 PPM NITROGEN DIOXIDE/NITROGEN	+/- 1.6%	Jun 15, 2025
PRM	12409	D913660	15.01 PPM NITROGEN DIOXIDE/AIR	+/- 1.5%	Feb 18, 2023

The SRM, NTRM, PRM, or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
MKS FTIR NO2 018335821	FTIR	Apr 10, 2024

Triad Data Available Upon Request



NO<sub>2</sub> 7.426 PPM  
CC 506459  
EXP. 04/24/2027  
B32024

\_\_\_\_\_  
Approved for Release

LO 05/24/2024



## **APPENDIX B FACILITY CEMS DATA**

# Average Data

Plant: ORMOND BEACH GEN STA  
Interval: 1 Minute  
Type: Roll

Report Period: 06/11/2024 13:39 Through 06/11/2024 14:02  
Time Online Criteria: 1 minute(s)

Source	ORB1									
Parameter Unit	GASFLOW (HSCFH)	LOADMW (MW)	NH3FLOW (GPM)	NOX#MM (LB/MMBTU)	NOX#NMW (LB/NMW)	NOXPPM (PPM)	NOXPPMC (PPM)	O2 (PERCENT)	UNITOPHR (MIN)	
06/11/24 13:39	26,677.7	258.8	0.00	0.008	0.094	6.55	6.84	3.88	1.0	
06/11/24 13:40	26,601.2	258.8	0.00	0.008	0.095	6.65	6.95	3.94	1.0	
06/11/24 13:41	26,492.9	259.3	0.00	0.007	0.081	5.67	6.00	3.92	1.0	
06/11/24 13:42	26,251.0	258.9	0.00	0.008	0.086	6.07	6.46	3.95	1.0	
06/11/24 13:43	26,594.0	259.4	0.16	0.010	0.108	7.50	7.94	4.02	1.0	
06/11/24 13:44	26,545.8	259.5	0.00	0.008	0.088	6.13	6.50	4.06	1.0	
06/11/24 13:45	26,708.2	259.6	0.00	0.006	0.071	4.93	5.19	3.95	1.0	
06/11/24 13:46	26,627.9	259.4	0.00	0.008	0.088	6.13	6.42	3.93	1.0	
06/11/24 13:47	26,860.7	259.3	0.14	0.009	0.101	7.00	7.37	3.87	1.0	
06/11/24 13:48	26,841.5	259.4	0.00	0.008	0.085	5.92	6.21	3.95	1.0	
06/11/24 13:49	26,713.0	259.6	0.00	0.007	0.075	5.25	5.61	3.95	1.0	
06/11/24 13:50	26,732.2	259.7	0.00	0.008	0.089	6.20	6.53	3.87	1.0	
06/11/24 13:51	26,732.8	259.8	0.12	0.009	0.096	6.72	7.10	3.95	1.0	
06/11/24 13:52	26,711.2	259.7	0.00	0.007	0.082	5.77	6.11	3.88	1.0	
06/11/24 13:53	26,094.4	259.5	0.00	0.007	0.080	5.58	6.00	4.24	1.0	
06/11/24 13:54	26,775.3	259.9	0.17	0.009	0.103	7.18	7.58	3.91	1.0	
06/11/24 13:55	26,711.9	260.3	0.10	0.008	0.088	6.19	6.53	3.90	1.0	
06/11/24 13:56	26,838.7	260.5	0.00	0.007	0.073	5.06	5.37	3.92	1.0	
06/11/24 13:57	26,712.3	260.6	0.00	0.007	0.082	5.76	6.11	3.89	1.0	
06/11/24 13:58	26,812.5	260.9	0.13	0.009	0.096	6.74	7.05	3.90	1.0	
06/11/24 13:59	26,761.3	261.1	0.13	0.008	0.093	6.54	6.84	3.89	1.0	
06/11/24 14:00	26,814.2	260.9	0.00	0.007	0.077	5.35	5.69	3.94	1.0	
06/11/24 14:01	26,734.5	261.1	0.00	0.007	0.081	5.66	6.00	3.92	1.0	
06/11/24 14:02	26,759.5	261.1	0.13	0.008	0.094	6.64	6.95	3.88	1.0	
Average	26,671.0	259.9	0.05	0.008	0.088	6.13	6.47	3.94	1.0	
Minimum	26,094.4	258.8	0.00	0.006	0.071	4.93	5.19	3.87	1.0	
Maximum	26,860.7	261.1	0.17	0.010	0.108	7.50	7.94	4.24	1.0	
Summation	640,104.7	6,237.1	1.08	0.188	2.106	147.19	155.35	94.51	24.0	
Included Data Points	24	24	24	24	24	24	24	24	24	
Total number of Data Points	24	24	24	24	24	24	24	24	24	

W002AS-041566-RT-6248

**F = Unit Offline**    **E = Exceedance**    **C = Calibration**    **S = Substituted**    **I = Invalid**  
**M = Maintenance**    **T = Out Of Control**    **\* = Suspect**    **U = Startup**    **D = Shutdown**

# Average Data

Plant: ORMOND BEACH GEN STA  
Interval: 1 Minute  
Type: Roll

Report Period: 06/11/2024 14:14 Through 06/11/2024 14:40  
Time Online Criteria: 1 minute(s)

Source	ORB1										
Parameter Unit	GASFLOW (HSCFH)	LOADMW (MW)	NH3FLOW (GPM)	NOX#/MM (LB/MMBTU)	NOX#/NMW (LB/NMW)	NOXPPM (PPM)	NOXPPMC (PPM)	O2 (PERCENT)	UNITOPHR (MIN)		
06/11/24 14:14	26,787.2	260.6	0.00	0.008	0.086	6.01	6.32	3.91	1.0		
06/11/24 14:15	26,656.6	260.8	0.14	0.008	0.093	6.53	6.84	3.89	1.0		
06/11/24 14:16	26,731.5	261.1	0.11	0.008	0.087	6.16	6.49	3.82	1.0		
06/11/24 14:17	26,573.9	261.1	0.00	0.007	0.078	5.55	5.76	3.81	1.0		
06/11/24 14:18	26,466.7	260.9	0.00	0.007	0.081	5.77	6.11	3.93	1.0		
06/11/24 14:19	26,728.1	259.4	0.15	0.009	0.095	6.68	7.01	3.82	1.0		
06/11/24 14:20	26,414.1	259.1	0.10	0.008	0.087	6.17	6.53	3.90	1.0		
06/11/24 14:21	26,116.0	258.4	0.00	0.007	0.077	5.49	5.79	3.93	1.0		
06/11/24 14:22	25,770.7	258.3	0.00	0.008	0.085	6.05	6.50	4.14	1.0		
06/11/24 14:23	26,451.5	258.6	0.19	0.009	0.102	7.16	7.58	3.92	1.0		
06/11/24 14:24	26,650.4	258.7	0.13	0.008	0.087	6.14	6.39	3.82	1.0		
06/11/24 14:25	26,709.5	259.2	0.00	0.007	0.076	5.29	5.58	3.87	1.0		
06/11/24 14:26	26,550.5	259.1	0.00	0.007	0.079	5.55	5.76	3.84	1.0		
06/11/24 14:27	26,570.9	259.7	0.12	0.008	0.091	6.41	6.74	3.91	1.0		
06/11/24 14:28	26,438.9	259.3	0.14	0.008	0.093	6.59	6.95	3.88	1.0		
06/11/24 14:29	26,383.6	259.3	0.00	0.007	0.082	5.80	6.14	3.98	1.0		
06/11/24 14:30	26,276.0	259.0	0.00	0.007	0.079	5.62	5.90	3.93	1.0		
06/11/24 14:31	26,353.2	258.9	0.10	0.008	0.085	6.04	6.28	3.83	1.0		
06/11/24 14:32	26,648.5	259.2	0.13	0.008	0.091	6.36	6.74	3.86	1.0		
06/11/24 14:33	26,466.4	259.3	0.12	0.008	0.088	6.20	6.53	3.91	1.0		
06/11/24 14:34	26,677.1	259.6	0.00	0.007	0.083	5.80	6.11	3.87	1.0		
06/11/24 14:35	26,413.4	259.8	0.00	0.008	0.083	5.89	6.21	3.92	1.0		
06/11/24 14:36	26,542.9	260.0	0.12	0.008	0.089	6.27	6.67	3.97	1.0		
06/11/24 14:37	26,251.6	260.1	0.13	0.008	0.089	6.28	6.67	4.01	1.0		
06/11/24 14:38	26,486.9	260.1	0.12	0.008	0.085	6.02	6.32	3.93	1.0		
06/11/24 14:39	26,651.2	260.1	0.10	0.007	0.083	5.84	6.11	3.90	1.0		
06/11/24 14:40	26,653.4	260.1	0.11	0.008	0.085	5.99	6.32	3.94	1.0		
Average	26,497.1	259.6	0.07	0.008	0.086	6.06	6.38	3.91	1.0		
Minimum	25,770.7	256.3	0.00	0.007	0.076	5.29	5.58	3.81	1.0		
Maximum	26,787.2	261.1	0.19	0.009	0.102	7.16	7.58	4.14	1.0		
Summation	715,420.7	7,009.8	2.01	0.209	163.66	172.35	105.44	105.44	27.0		
Included Data Points	27	27	27	27	27	27	27	27	27		
Total number of Data Points	27	27	27	27	27	27	27	27	27		

F = Unit Offline E = Exceedance C = Calibration S = Substituted I = Invalid  
M = Maintenance T = Out Of Control \* = Suspect U = Startup D = Shutdown

Run 3

# Average Data

Plant: ORMOND BEACH GEN STA

Interval: 1 Minute

Type: Roll

Report Period: 06/11/2024 14:51 Through 06/11/2024 15:11

Time Online Criteria: 1 minute(s)

Source	ORB1										
Parameter Unit	GASFLOW (HSCFH)	LOADMW (MW)	NH3FLOW (GPM)	NOX#/MM (LB/MMBTU)	NOX#/NMW (LB/NMW)	NOXPPM (PPM)	NOXPPMC (PPM)	O2 (PERCENT)	UNITOPHR (MIN)		
06/11/24 14:51	26,681.0	261.4	0.00	0.007	0.079	5.56	5.93	3.97	1.0		
06/11/24 14:52	26,653.4	261.6	0.12	0.008	0.085	5.99	6.36	3.97	1.0		
06/11/24 14:53	26,709.5	262.1	0.14	0.008	0.089	6.26	6.63	3.94	1.0		
06/11/24 14:54	26,812.8	262.5	0.13	0.008	0.087	6.11	6.46	3.95	1.0		
06/11/24 14:55	26,840.5	262.8	0.11	0.008	0.083	5.87	6.21	3.90	1.0		
06/11/24 14:56	26,787.3	263.2	0.11	0.007	0.082	5.80	6.11	3.93	1.0		
06/11/24 14:57	27,000.7	262.7	0.13	0.008	0.088	6.12	6.42	3.95	1.0		
06/11/24 14:58	26,525.5	262.4	0.10	0.008	0.084	5.95	6.21	3.90	1.0		
06/11/24 14:59	26,304.4	261.5	0.00	0.007	0.080	5.70	6.00	3.93	1.0		
06/11/24 15:00	26,460.9	261.1	0.16	0.009	0.093	6.56	7.03	4.07	1.0		
06/11/24 15:01	26,915.6	261.7	0.17	0.008	0.094	6.58	6.91	3.84	1.0		
06/11/24 15:02	26,605.4	261.6	0.11	0.007	0.082	5.74	6.04	4.03	1.0		
06/11/24 15:03	26,731.2	261.3	0.00	0.007	0.080	5.61	5.90	3.93	1.0		
06/11/24 15:04	26,838.4	260.9	0.11	0.008	0.085	5.93	6.21	3.86	1.0		
06/11/24 15:05	26,630.1	259.7	0.11	0.008	0.084	5.95	6.28	3.81	1.0		
06/11/24 15:06	26,305.8	259.6	0.00	0.007	0.081	5.75	5.97	3.82	1.0		
06/11/24 15:07	26,248.1	259.3	0.00	0.008	0.085	6.04	6.32	3.87	1.0		
06/11/24 15:08	26,033.2	258.7	0.14	0.008	0.091	6.45	6.93	4.06	1.0		
06/11/24 15:09	26,563.0	259.0	0.17	0.009	0.096	6.73	7.05	3.90	1.0		
06/11/24 15:10	26,358.5	259.0	0.00	0.007	0.080	5.72	5.97	3.81	1.0		
06/11/24 15:11	26,408.2	259.2	0.00	0.007	0.076	5.42	5.65	3.80	1.0		
Average	26,591.1	261.0	0.09	0.008	0.085	5.99	6.31	3.92	1.0		
Minimum	26,033.2	258.7	0.00	0.007	0.076	5.42	5.65	3.80	1.0		
Maximum	27,000.7	263.2	0.17	0.009	0.096	6.73	7.05	4.07	1.0		
Summation	558,413.5	5,481.3	1.81	0.162	1.784	125.84	132.59	82.24	21.0		
Included Data Points	21	21	21	21	21	21	21	21	21		
Total number of Data Points	21	21	21	21	21	21	21	21	21		

F = Unit Offline E = Exceedance C = Calibration S = Substituted I = Invalid  
M = Maintenance T = Out Of Control \* = Suspect U = Startup D = Shutdown

Run 4

# Average Data

Plant: ORMOND BEACH GEN STA  
Interval: 1 Minute  
Type: Roll

Report Period: 06/11/2024 15:20 Through 06/11/2024 15:40  
Time Online Criteria: 1 minute(s)

Source	ORB1										
Parameter Unit	GASFLOW (HSCFH)	LOADMW (MW)	NH3FLOW (GPM)	NOX#/MM (LB/MMBTU)	NOX#/NMW (LB/NMW)	NOXPPM (PPM)	NOXPPMC (PPM)	O2 (PERCENT)	UNITOPHR (MIN)		
06/11/24 15:20	26,541.2	260.4	0.12	0.008	0.086	6.08	6.42	3.94	1.0		
06/11/24 15:21	26,384.9	260.2	0.13	0.008	0.086	6.11	6.42	3.92	1.0		
06/11/24 15:22	26,621.8	260.3	0.13	0.008	0.087	6.12	6.46	3.96	1.0		
06/11/24 15:23	26,518.8	260.5	0.12	0.008	0.084	5.95	6.32	3.87	1.0		
06/11/24 15:24	26,544.9	260.4	0.11	0.008	0.084	5.93	6.25	3.99	1.0		
06/11/24 15:25	26,411.1	260.4	0.12	0.008	0.084	5.97	6.32	3.95	1.0		
06/11/24 15:26	26,676.7	260.7	0.12	0.008	0.085	6.00	6.32	3.93	1.0		
06/11/24 15:27	26,387.3	260.5	0.13	0.008	0.086	6.07	6.46	3.97	1.0		
06/11/24 15:28	26,648.9	260.6	0.13	0.008	0.089	6.19	6.61	4.06	1.0		
06/11/24 15:29	26,440.2	260.5	0.15	0.008	0.089	6.24	6.57	4.05	1.0		
06/11/24 15:30	26,754.6	260.3	0.12	0.008	0.084	5.89	6.25	3.97	1.0		
06/11/24 15:31	26,655.7	260.3	0.11	0.007	0.082	5.75	6.14	4.00	1.0		
06/11/24 15:32	26,387.3	260.4	0.12	0.008	0.084	5.91	6.29	4.08	1.0		
06/11/24 15:33	26,569.5	260.4	0.12	0.008	0.085	5.98	6.36	4.01	1.0		
06/11/24 15:34	26,545.1	260.2	0.13	0.008	0.086	6.04	6.32	3.95	1.0		
06/11/24 15:35	26,571.8	260.5	0.13	0.008	0.087	6.06	6.46	4.03	1.0		
06/11/24 15:36	26,439.3	260.9	0.12	0.008	0.086	6.02	6.39	4.07	1.0		
06/11/24 15:37	26,490.3	260.7	0.12	0.008	0.084	5.92	6.21	3.94	1.0		
06/11/24 15:38	26,544.0	260.5	0.11	0.007	0.082	5.81	6.11	3.87	1.0		
06/11/24 15:39	26,491.9	260.4	0.12	0.008	0.085	5.96	6.36	3.97	1.0		
06/11/24 15:40	26,728.8	260.5	0.15	0.008	0.090	6.29	6.67	3.95	1.0		
Average	26,540.7	260.5	0.12	0.008	0.085	6.01	6.37	3.98	1.0		
Minimum	26,384.9	260.2	0.11	0.007	0.082	5.75	6.11	3.87	1.0		
Maximum	26,754.6	260.9	0.15	0.008	0.090	6.29	6.67	4.08	1.0		
Summation	557,354.1	5,469.6	2.61	0.166	1.795	126.29	133.71	83.48	21.0		
Included Data Points	21	21	21	21	21	21	21	21	21		
Total number of Data Points	21	21	21	21	21	21	21	21	21		

F = Unit Offline    E = Exceedance    C = Calibration    S = Substituted    I = Invalid  
M = Maintenance    T = Out Of Control    \* = Suspect    U = Startup    D = Shutdown

# Average Data

Plant: ORMOND BEACH GEN STA

Interval: 1 Minute

Type: Roll

Report Period: 06/11/2024 15:55 Through 06/11/2024 16:15

Time Online Criteria: 1 minute(s)

*Rms*

W002AS-041566-RT-6248

Source	ORB1										
Parameter Unit	GASFLOW (HSCFH)	LOADMW (MW)	NH3FLOW (GPM)	NOX#MM (LB/MMBTU)	NOX#NMW (LB/NMW)	NOXPPM (PPM)	NOXPPMC (PPM)	O2 (PERCENT)	UNITOPHR (MIN)		
06/11/24 15:55	26,385.2	261.2	0.11	0.008	0.085	6.00	6.36	3.95	1.0		
06/11/24 15:56	26,542.3	261.3	0.13	0.008	0.088	6.21	6.53	3.92	1.0		
06/11/24 15:57	26,385.0	261.2	0.14	0.008	0.088	6.25	6.53	3.93	1.0		
06/11/24 15:58	26,488.9	261.1	0.11	0.008	0.083	5.88	6.21	3.91	1.0		
06/11/24 15:59	26,597.9	261.5	0.11	0.008	0.084	5.92	6.21	3.90	1.0		
06/11/24 16:00	26,625.7	261.2	0.13	0.008	0.086	6.08	6.39	3.84	1.0		
06/11/24 16:01	26,680.4	260.9	0.14	0.008	0.088	6.23	6.53	3.90	1.0		
06/11/24 16:02	26,654.6	261.0	0.12	0.008	0.086	6.02	6.32	3.93	1.0		
06/11/24 16:03	26,493.2	261.0	0.12	0.008	0.084	5.96	6.36	3.98	1.0		
06/11/24 16:04	26,651.5	261.0	0.11	0.008	0.083	5.88	6.21	3.88	1.0		
06/11/24 16:05	26,440.3	261.0	0.11	0.008	0.083	5.92	6.21	3.91	1.0		
06/11/24 16:06	26,650.7	261.1	0.12	0.008	0.087	6.15	6.42	3.85	1.0		
06/11/24 16:07	26,466.7	261.0	0.12	0.008	0.086	6.14	6.42	3.91	1.0		
06/11/24 16:08	26,623.2	261.1	0.13	0.008	0.086	6.07	6.42	3.89	1.0		
06/11/24 16:09	26,519.3	261.2	0.13	0.008	0.086	6.06	6.42	3.95	1.0		
06/11/24 16:10	26,571.1	261.1	0.13	0.008	0.087	6.10	6.46	4.00	1.0		
06/11/24 16:11	26,572.2	261.4	0.12	0.008	0.084	5.98	6.32	3.90	1.0		
06/11/24 16:12	26,438.7	261.3	0.12	0.008	0.085	6.00	6.36	3.97	1.0		
06/11/24 16:13	26,596.5	261.5	0.13	0.008	0.087	6.14	6.46	3.95	1.0		
06/11/24 16:14	26,519.8	261.6	0.13	0.008	0.086	6.09	6.42	3.89	1.0		
06/11/24 16:15	26,651.2	261.6	0.11	0.007	0.082	5.83	6.11	3.90	1.0		
Average	26,550.2	261.2	0.12	0.008	0.085	6.04	6.37	3.92	1.0		
Minimum	26,385.0	260.9	0.11	0.007	0.082	5.83	6.11	3.84	1.0		
Maximum	26,680.4	261.6	0.14	0.008	0.088	6.25	6.53	4.00	1.0		
Summation	557,594.4	5,486.3	2.57	0.167	1.794	126.91	133.67	82.26	21.0		
Included Data Points	21	21	21	21	21	21	21	21	21		
Total number of Data Points	21	21	21	21	21	21	21	21	21		

F = Unit Offline    E = Exceedance    C = Calibration    S = Substituted    I = Invalid  
M = Maintenance    T = Out Of Control    \* = Suspect    U = Startup    D = Shutdown

Report Generated: 06/11/24 16:21

Version 6.18

GONPRODUJSheila.Reilly

1 of 1

*Run 6*

# Average Data

Plant: ORMOND BEACH GEN STA  
Interval: 1 Minute  
Type: Roll

Report Period: 06/11/2024 16:24 Through 06/11/2024 16:44  
Time Online Criteria: 1 minute(s)

Source	ORB1									
Parameter Unit	GASFLOW (HSCFH)	LOADMW (MW)	NH3FLOW (GPM)	NOX#/MM (LB/MMBTU)	NOX#/NMW (LB/NMW)	NOXPPM (PPM)	NOXPPMC (PPM)	O2 (PERCENT)	UNITOPHR (MIN)	
06/11/24 16:24	26,676.7	260.9	0.12	0.008	0.085	5.99	6.32	3.85	1.0	
06/11/24 16:25	26,574.5	261.2	0.10	0.007	0.082	5.85	6.18	3.83	1.0	
06/11/24 16:26	26,572.6	261.2	0.12	0.008	0.087	6.11	6.46	3.97	1.0	
06/11/24 16:27	26,652.6	261.0	0.15	0.008	0.090	6.35	6.63	3.91	1.0	
06/11/24 16:28	26,573.8	261.0	0.14	0.008	0.087	6.12	6.42	3.91	1.0	
06/11/24 16:29	26,757.6	261.0	0.11	0.007	0.082	5.77	6.11	3.89	1.0	
06/11/24 16:30	26,682.4	261.4	0.11	0.008	0.084	5.90	6.21	3.92	1.0	
06/11/24 16:31	26,547.3	261.6	0.12	0.008	0.084	5.96	6.32	3.88	1.0	
06/11/24 16:32	26,599.6	261.7	0.12	0.008	0.086	6.06	6.42	3.90	1.0	
06/11/24 16:33	26,626.5	261.8	0.12	0.008	0.086	6.11	6.42	3.93	1.0	
06/11/24 16:34	26,493.0	261.7	0.14	0.008	0.088	6.21	6.57	4.03	1.0	
06/11/24 16:35	26,678.2	261.6	0.13	0.008	0.086	6.08	6.42	3.90	1.0	
06/11/24 16:36	26,710.4	261.6	0.13	0.008	0.084	5.93	6.21	3.91	1.0	
06/11/24 16:37	26,866.8	261.8	0.12	0.008	0.084	5.86	6.21	3.90	1.0	
06/11/24 16:38	26,659.0	261.8	0.13	0.008	0.086	6.03	6.36	4.00	1.0	
06/11/24 16:39	26,785.3	261.7	0.14	0.008	0.087	6.13	6.42	3.93	1.0	
06/11/24 16:40	26,576.5	261.6	0.12	0.008	0.083	5.93	6.21	3.86	1.0	
06/11/24 16:41	26,890.5	261.7	0.11	0.007	0.082	5.77	6.07	3.81	1.0	
06/11/24 16:42	26,524.3	261.7	0.11	0.008	0.083	5.90	6.21	3.94	1.0	
06/11/24 16:43	26,756.7	262.0	0.13	0.008	0.088	6.22	6.53	3.86	1.0	
06/11/24 16:44	26,496.7	261.8	0.11	0.008	0.085	6.05	6.28	3.85	1.0	
Average	26,652.4	261.5	0.12	0.008	0.085	6.02	6.33	3.90	1.0	
Minimum	26,493.0	260.9	0.10	0.007	0.082	5.77	6.07	3.81	1.0	
Maximum	26,890.5	262.0	0.15	0.008	0.090	6.35	6.63	4.03	1.0	
Summation	559,701.0	5,491.8	2.58	0.165	1.789	126.33	132.98	81.98	21.0	
Included Data Points	21	21	21	21	21	21	21	21	21	
Total number of Data Points	21	21	21	21	21	21	21	21	21	

F = Unit Offline    E = Exceedance    C = Calibration    S = Substituted    I = Invalid  
M = Maintenance    T = Out Of Control    \* = Suspect    U = Startup    D = Shutdown

# Average Data

Plant: **ORMOND BEACH GEN STA**  
Interval: 1 Minute  
Type: Roll

Report Period: 06/11/2024 16:57 Through 06/11/2024 17:17  
Time Online Criteria: 1 minute(s)

Source Parameter Unit	ORB1									
	GASFLOW (HSCFH)	LOADMW (MW)	NH3FLOW (GPM)	NOX#/MM (LB/MMBTU)	NOX#/MMW (LB/MMW)	NOXPPM (PPM)	NOXPPMC (PPM)	O2 (PERCENT)	UNITOPHR (MIN)	

06/11/24 16:57	26,763.3	261.4	0.16	0.008	0.090	6.35	6.63	3.94	1.0
06/11/24 16:58	26,974.1	261.8	0.13	0.007	0.084	5.92	6.18	3.81	1.0
06/11/24 16:59	26,764.6	261.8	0.00	0.007	0.080	5.62	5.90	3.94	1.0
06/11/24 17:00	26,656.1	261.9	0.12	0.008	0.085	6.01	6.32	3.93	1.0
06/11/24 17:01	26,654.2	261.9	0.13	0.008	0.089	6.23	6.57	3.99	1.0
06/11/24 17:02	26,520.7	262.0	0.14	0.008	0.087	6.15	6.57	3.96	1.0
06/11/24 17:03	26,678.6	261.9	0.13	0.008	0.086	6.05	6.46	4.00	1.0
06/11/24 17:04	26,759.6	262.0	0.13	0.008	0.086	6.06	6.42	3.92	1.0
06/11/24 17:05	26,576.2	261.8	0.14	0.008	0.085	6.00	6.36	4.04	1.0
06/11/24 17:06	26,944.2	262.1	0.15	0.008	0.088	6.11	6.46	3.99	1.0
06/11/24 17:07	26,871.3	262.1	0.15	0.008	0.087	6.06	6.46	4.04	1.0
06/11/24 17:08	26,789.2	262.1	0.12	0.007	0.082	5.77	6.14	3.96	1.0
06/11/24 17:09	26,815.0	262.0	0.11	0.007	0.081	5.73	6.00	3.90	1.0
06/11/24 17:10	26,762.1	262.0	0.12	0.008	0.084	5.89	6.25	3.96	1.0
06/11/24 17:11	26,760.7	262.1	0.15	0.008	0.089	6.24	6.57	3.96	1.0
06/11/24 17:12	26,761.5	261.6	0.13	0.008	0.086	6.02	6.32	3.90	1.0
06/11/24 17:13	26,840.6	261.7	0.12	0.007	0.082	5.78	6.11	3.88	1.0
06/11/24 17:14	26,976.6	261.8	0.11	0.007	0.083	5.80	6.07	3.80	1.0
06/11/24 17:15	26,806.6	261.7	0.11	0.008	0.083	5.87	6.21	3.90	1.0
06/11/24 17:16	26,653.1	261.7	0.13	0.008	0.086	6.09	6.42	3.90	1.0
06/11/24 17:17	26,732.5	261.5	0.14	0.008	0.089	6.27	6.63	3.89	1.0

Average	26,755.3	261.9	0.12	0.008	0.085	6.00	6.34	3.93	1.0
Minimum	26,520.7	261.4	0.00	0.007	0.080	5.62	5.90	3.80	1.0
Maximum	26,976.6	262.1	0.16	0.008	0.090	6.35	6.63	4.04	1.0
Summation	561,860.8	5,498.9	2.62	0.162	1.792	126.02	133.05	82.61	21.0
Included Data Points	21	21	21	21	21	21	21	21	21
Total number of Data Points	21	21	21	21	21	21	21	21	21

**F = Unit Offline**    **E = Exceedance**    **C = Calibration**    **S = Substituted**    **I = Invalid**  
**M = Maintenance**    **T = Out Of Control**    **\* = Suspect**    **U = Startup**    **D = Shutdown**

*Fun*



*Ken &*

# Average Data

Plant: ORMOND BEACH GEN STA  
Interval: 1 Minute  
Type: Roll

Report Period: 06/11/2024 17:24 Through 06/11/2024 17:44  
Time Online Criteria: 1 minute(s)

Source	ORB1									
Parameter Unit	GASFLOW (HSCFH)	LOADMW (MW)	NH3FLOW (GPM)	NOX#/MM (LB/MMBTU)	NOX#/NMW (LB/NMW)	NOXPPM (PPM)	NOXPPMC (PPM)	O2 (PERCENT)	UNITOPHR (MIN)	
06/11/24 17:24	26,734.4	261.1	0.12	0.008	0.086	6.03	6.32	3.91	1.0	
06/11/24 17:25	26,894.3	261.4	0.13	0.008	0.087	6.11	6.42	3.90	1.0	
06/11/24 17:26	26,552.0	261.6	0.13	0.008	0.086	6.08	6.46	3.96	1.0	
06/11/24 17:27	26,572.2	261.6	0.13	0.008	0.084	5.96	6.32	3.95	1.0	
06/11/24 17:28	26,811.8	261.8	0.13	0.008	0.086	6.03	6.36	3.96	1.0	
06/11/24 17:29	26,630.0	261.8	0.13	0.008	0.087	6.09	6.46	4.03	1.0	
06/11/24 17:30	26,601.3	262.0	0.15	0.008	0.088	6.16	6.57	4.02	1.0	
06/11/24 17:31	26,919.0	262.0	0.15	0.008	0.086	6.03	6.32	3.94	1.0	
06/11/24 17:32	26,685.5	261.9	0.12	0.007	0.082	5.79	6.14	3.96	1.0	
06/11/24 17:33	26,893.1	262.1	0.11	0.007	0.082	5.75	6.11	3.88	1.0	
06/11/24 17:34	26,736.6	262.0	0.13	0.008	0.084	5.89	6.25	3.99	1.0	
06/11/24 17:35	26,894.2	262.0	0.14	0.008	0.088	6.14	6.46	3.97	1.0	
06/11/24 17:36	26,583.7	261.7	0.14	0.008	0.088	6.15	6.50	4.06	1.0	
06/11/24 17:37	26,780.7	261.8	0.14	0.008	0.087	6.08	6.42	3.93	1.0	
06/11/24 17:38	26,710.8	261.7	0.13	0.008	0.085	5.95	6.25	4.00	1.0	
06/11/24 17:39	26,812.2	261.7	0.13	0.008	0.084	5.89	6.25	4.01	1.0	
06/11/24 17:40	26,736.9	261.8	0.13	0.008	0.083	5.87	6.25	3.96	1.0	
06/11/24 17:41	26,658.1	261.8	0.12	0.007	0.083	5.84	6.14	4.01	1.0	
06/11/24 17:42	26,783.9	261.9	0.14	0.008	0.087	6.10	6.42	3.95	1.0	
06/11/24 17:43	26,815.0	261.7	0.14	0.008	0.086	6.05	6.46	3.97	1.0	
06/11/24 17:44	26,946.3	261.9	0.13	0.008	0.086	6.00	6.32	3.93	1.0	
Average	26,750.1	261.8	0.13	0.008	0.085	6.00	6.34	3.97	1.0	
Minimum	26,552.0	261.1	0.11	0.007	0.082	5.75	6.11	3.88	1.0	
Maximum	26,946.3	262.1	0.15	0.008	0.088	6.16	6.57	4.06	1.0	
Summation	561,752.0	5,497.3	2.77	0.165	1.795	125.99	133.20	83.29	21.0	
Included Data Points	21	21	21	21	21	21	21	21	21	
Total number of Data Points	21	21	21	21	21	21	21	21	21	

F = Unit Offline    E = Exceedance    C = Calibration    S = Substituted    I = Invalid  
M = Maintenance    T = Out Of Control    \* = Suspect    U = Startup    D = Shutdown

# Average Data

Plant: ORMOND BEACH GEN STA  
Interval: 1 Minute  
Type: Roll

Report Period: 06/11/2024 17:51 Through 06/11/2024 18:11  
Time Online Criteria: 1 minute(s)

Source Parameter Unit	ORB1									
	GASFLOW (HSCFH)	LOADMW (MW)	NH3FLOW (GPM)	NOX#MM (LB/MMBTU)	NOX#NMW (LB/NMW)	NOXPPM (PPM)	NOXPPMC (PPM)	O2 (PERCENT)	UNITOPHR (MIN)	
06/11/24 17:51	26,682.7	261.3	0.12	0.007	0.083	5.84	6.11	3.94	1.0	
06/11/24 17:52	26,603.1	261.3	0.12	0.008	0.085	5.97	6.36	4.01	1.0	
06/11/24 17:53	26,782.4	261.4	0.15	0.008	0.090	6.28	6.67	3.97	1.0	
06/11/24 17:54	26,607.1	261.2	0.14	0.008	0.087	6.08	6.46	3.99	1.0	
06/11/24 17:55	26,861.4	261.1	0.12	0.008	0.084	5.85	6.21	3.88	1.0	
06/11/24 17:56	26,610.1	260.7	0.10	0.007	0.079	5.59	5.90	3.86	1.0	
06/11/24 17:57	26,834.0	260.7	0.11	0.007	0.084	5.85	6.11	3.93	1.0	
06/11/24 17:58	26,688.0	261.2	0.14	0.008	0.090	6.31	6.67	3.98	1.0	
06/11/24 17:59	26,603.9	260.9	0.16	0.008	0.092	6.43	6.82	4.09	1.0	
06/11/24 18:00	26,548.1	261.2	0.14	0.008	0.085	5.98	6.36	4.00	1.0	
06/11/24 18:01	26,652.0	261.5	0.11	0.008	0.083	5.80	6.18	4.06	1.0	
06/11/24 18:02	26,498.5	261.7	0.12	0.008	0.084	5.89	6.29	4.08	1.0	
06/11/24 18:03	26,726.3	261.8	0.15	0.008	0.090	6.28	6.67	4.02	1.0	
06/11/24 18:04	26,500.5	261.7	0.15	0.008	0.087	6.14	6.46	3.97	1.0	
06/11/24 18:05	26,883.8	261.7	0.14	0.008	0.085	5.92	6.25	3.98	1.0	
06/11/24 18:06	26,689.6	261.3	0.13	0.007	0.083	5.81	6.14	3.99	1.0	
06/11/24 18:07	26,942.3	261.2	0.11	0.007	0.081	5.65	5.97	3.83	1.0	
06/11/24 18:08	26,872.5	261.1	0.10	0.007	0.080	5.63	5.86	3.84	1.0	
06/11/24 18:09	26,817.7	260.9	0.11	0.007	0.083	5.85	6.07	3.84	1.0	
06/11/24 18:10	26,555.3	260.7	0.12	0.008	0.084	5.98	6.28	3.81	1.0	
06/11/24 18:11	26,780.5	260.7	0.12	0.008	0.087	6.13	6.39	3.83	1.0	
Average	26,701.9	261.2	0.13	0.008	0.085	5.96	6.30	3.95	1.0	
Minimum	26,498.5	260.7	0.10	0.007	0.079	5.59	5.86	3.81	1.0	
Maximum	26,942.3	261.8	0.16	0.008	0.092	6.43	6.82	4.09	1.0	
Summation	560,739.8	5,485.3	2.66	0.161	1.786	125.26	132.23	82.90	21.0	
Included Data Points	21	21	21	21	21	21	21	21	21	
Total number of Data Points	21	21	21	21	21	21	21	21	21	

*Handwritten signature*

**F = Unit Offline**    **E = Exceedance**    **C = Calibration**    **S = Substituted**    **I = Invalid**  
**M = Maintenance**    **T = Out Of Control**    **\* = Suspect**    **U = Startup**    **D = Shutdown**

## **APPENDIX C CALCULATIONS**

## **Appendix C.1**

### **General Emissions Calculations**

## GENERAL EMISSION CALCULATIONS

### I. Stack Gas Velocity

A. Stack gas molecular weight, lb/lb-mole

$$MW_{dry} = 0.44 * \%CO_2 + 0.32 * \%O_2 + 0.28 * \%N_2$$

$$MW_{wet} = MW_{dry} * (1 - B_{wo}) + 18 * B_{wo}$$

B. Absolute stack pressure, iwg

$$P_s = P_{bar} + \frac{P_{sg}}{13.6}$$

C. Stack gas velocity, ft/sec

$$V_s = 2.9 * C_p * \sqrt{\Delta P} * \sqrt{T_s} * \sqrt{\frac{29.92 * 28.95}{P_s * MW_{wet}}}$$

### II. Moisture

A. Sample gas volume, dscf

$$V_{mstd} = 0.03342 * V_m * (P_{bar} + \frac{\Delta H}{13.6}) * \frac{T_{ref}}{T_m} * Y_d$$

B. Water vapor volume, scf

$$V_{wstd} = 0.0472 * V_{lc} * \frac{T_{ref}}{528 \text{ } ^\circ R}$$

C. Moisture content, dimensionless

$$B_{wo} = \frac{V_{wstd}}{(V_{mstd} + V_{wstd})}$$

### III. Stack gas volumetric flow rate

A. Actual stack gas volumetric flow rate, wacfm

$$Q = V_s * A_s * 60$$

B. Standard stack gas flow rate, dscfm

$$Q_{sd} = Q * (1 - B_{wo}) * \frac{T_{ref}}{T_s} * \frac{P_s}{29.92}$$

IV. Gaseous Mass Emission Rates, lb/hr

$$M = \frac{\text{ppm} * MW_i * Q_{sd} * 60}{SV * 10^6}$$

V. Emission Rates, lb/MMBtu

$$\frac{\text{lb}}{\text{MMBtu}} = \frac{\text{ppm} * MW_i * F}{SV * 10^6} * \frac{20.9}{20.9 - \%O_2}$$

VI. Percent Isokinetic

$$I = \frac{17.32 * T_s (V_{mstd})}{(1-Bwo) * 0 * V_s * P_s * Dn2} * \frac{520^{\circ}R}{T_{ref}}$$

VII. Particulate emissions

(a) Grain loading, gr/dscf  
 $C = 0.01543 (M_n/V_{m std})$

(b) Grain loading at 12% CO<sub>2</sub>, gr/dscf  
 $C_{12\% CO_2} = C (12/\% CO_2)$

(c) Mass emissions, lb/hr  
 $M = C * Q_{sd} * (60 \text{ min/hr}) / (7000 \text{ gr/lb})$

(d) Particulate emission factor  
 $\text{lb}/10^6 \text{ Btu} = C * \frac{1 \text{ lb}}{7000 \text{ gr}} * F * \frac{20.9}{20.9 - \% O_2}$

Nomenclature:

$A_s$	= stack area, ft <sup>2</sup>
$B_{wo}$	= flue gas moisture content, dimensionless
$C_{12\%CO_2}$	= particulate grain loading, gr/dscf corrected to 12% CO <sub>2</sub>
$C$	= particulate grain loading, gr/dscf
$C_p$	= pitot calibration factor, dimensionless
$D_n$	= nozzle diameter, in.
$F$	= fuel F-Factor, dscf/MMBtu @ 0% O <sub>2</sub>
$H$	= orifice differential pressure, iwg
$I$	= % isokinetics
$M_n$	= mass of collected particulate, mg
$M_i$	= mass emission rate of specie i, lb/hr
$MW$	= molecular weight of flue gas, lb/lb-mole
$M_{wi}$	= molecular weight of specie i: SO <sub>2</sub> : 64 NO <sub>x</sub> : 46 CO: 28 HC: 16
$t$	= sample time, min.
$\Delta P$	= average velocity head, iwg = $(\sqrt{\Delta P})^2$
$P_{bar}$	= barometric pressure, inches Hg
$P_s$	= stack absolute pressure, inches Hg
$P_{sg}$	= stack static pressure, iwg
$Q$	= wet stack flow rate at actual conditions, wacfm
$Q_{sd}$	= dry standard stack flow rate, dscfm
$SV$	= specific molar volume of an ideal gas at standard conditions, ft <sup>3</sup> /lb-mole
$T_m$	= meter temperature, °R
$T_{ref}$	= reference temperature, °R
$T_s$	= stack temperature, °R
$V_s$	= stack gas velocity, ft/sec
$V_{lc}$	= volume of liquid collected in impingers, ml
$V_m$	= uncorrected dry meter volume, dcf
$V_{mstd}$	= dry meter volume at standard conditions, dscf
$V_{wstd}$	= volume of water vapor at standard conditions, scf
$Y_d$	= meter calibration coefficient

## RATA SPECIFIC EMISSION CALCULATIONS

The following equations are used for Relative Accuracy Test Audit (RATA) Computational Procedures:

### 1. Stack Gas Corrected Concentration

a. 
$$C_{gas} = (\bar{C} - C_o) \frac{C_{ma}}{C_m - C_o}$$

### 2. Relative Accuracy Calculations

#### a. Average Difference

$$\bar{d} = \frac{1}{n} \sum_{i=1}^n d_i$$

#### b. Standard Deviation

$$S_d = \left[ \frac{\sum_{i=1}^n d_i^2 - \frac{\left(\sum_{i=1}^n d_i\right)^2}{n}}{n-1} \right]^{1/2}$$

#### c. Confidence Coefficient

$$CC = t_{0.975} \frac{S_d}{\sqrt{n}}$$

#### d. Relative Accuracy

$$RA = \frac{|\bar{d}| + |cc|}{\overline{RA}} \times 100$$

#### e. Reference Method Average

$$\overline{RM} = \frac{1}{n} \sum_{i=1}^n RM_i$$



3. Bias Adjustment Factor

a.  $BAF = 1 + \frac{|\bar{d}|}{CEM}$


4. Nomenclature

$C_{gas}$	=	Corrected Stack Gas Concentration, ppm dry
$\bar{C}$	=	Average Gas Concentration, ppm dry
$C_o$	=	Average of the Initial and Final Zero Bias Check
$C_m$	=	Average of the Initial and Final Upscale Bias Check
$C_{ma}$	=	Actual Value of Upscale Calibration Gas Concentration
$\bar{d}$	=	Arithmetic Mean
$S_d$	=	Standard Deviation
$N$	=	Number of Tests
$CC$	=	Confidence Coefficient
$RA$	=	Relative Accuracy
$RM$	=	Reference Method
$t_{0.975}$	=	t Value
$ d $	=	Absolute Value of the Mean Difference

## **Appendix C.2**

### **Spreadsheet Summary**

40 CFR PART 75 RATA DATA AND WORKSHEET  
NO<sub>x</sub> lb/MMBtu



Generating Station: Ormond Beach  
Unit: 1  
Test Date: 6/11/2024

Performed By: JP/PR/TM/AE  
Test Condition: 261 MW  
Fuel F-Factor: 8,710 dscf/MMBtu

Run Number	1		2		3		4		5		6		7		8		9	
	6/11/2024	NO <sub>x</sub>	6/11/2024	NO <sub>x</sub>	6/11/2024	NO <sub>x</sub>	6/11/2024	NO <sub>x</sub>	6/11/2024	NO <sub>x</sub>	6/11/2024	NO <sub>x</sub>	6/11/2024	NO <sub>x</sub>	6/11/2024	NO <sub>x</sub>	6/11/2024	NO <sub>x</sub>
Test Date	6/11/2024		6/11/2024		6/11/2024		6/11/2024		6/11/2024		6/11/2024		6/11/2024		6/11/2024		6/11/2024	
Start Time	13:38		14:13		14:50		15:19		15:54		16:23		16:56		17:23		17:50	
Stop Time	14:02		14:40		15:11		15:40		16:15		16:44		17:17		17:44		18:11	
	O <sub>2</sub>	NO <sub>x</sub>	O <sub>2</sub>	NO <sub>x</sub>	O <sub>2</sub>	NO <sub>x</sub>	O <sub>2</sub>	NO <sub>x</sub>	O <sub>2</sub>	NO <sub>x</sub>	O <sub>2</sub>	NO <sub>x</sub>	O <sub>2</sub>	NO <sub>x</sub>	O <sub>2</sub>	NO <sub>x</sub>	O <sub>2</sub>	NO <sub>x</sub>
Calibration Span	9.14	8.41	9.14	8.41	9.14	8.41	9.14	8.41	9.14	8.41	9.14	8.41	9.14	8.41	9.14	8.41	9.14	8.41
Span Gas Value	4.50	4.49	4.50	4.49	4.50	4.49	4.50	4.49	4.50	4.49	4.50	4.49	4.50	4.49	4.50	4.49	4.50	4.49
Pre-Analyzer Zero	0.04	0.01	0.04	0.01	0.04	0.01	0.04	0.01	0.04	0.01	0.04	0.01	0.04	0.01	0.04	0.01	0.04	0.01
Pre-Analyzer Span	4.59	4.60	4.59	4.60	4.59	4.60	4.59	4.60	4.59	4.60	4.59	4.60	4.59	4.60	4.59	4.60	4.59	4.60
Pre-Test Zero Bias	0.06	0.01	0.04	0.02	0.01	0.03	0.04	0.03	0.04	0.02	0.06	0.03	0.09	0.03	0.10	0.03	0.05	0.05
Pre-Test Span Bias	4.62	4.53	4.53	4.54	4.54	4.56	4.63	4.57	4.62	4.56	4.65	4.56	4.61	4.56	4.65	4.56	4.64	4.55
Pt 3	4.09	6.35	4.14	5.71	4.09	5.81	4.21	5.82	4.21	5.94	4.20	6.00	4.29	5.91	4.22	6.00	4.21	5.941
Pt 2	4.18	5.63	4.13	5.84	4.10	5.83	4.16	5.88	4.15	5.90	4.17	5.89	4.20	5.91	4.18	5.89	4.21	5.907
Pt 1	4.12	6.97	4.10	5.76	4.08	5.84	4.19	5.78	4.13	5.91	4.17	5.79	4.19	5.78	4.19	5.84	4.12	5.782
Post-Test Zero Bias	0.04	0.02	0.01	0.03	0.04	0.03	0.04	0.02	0.06	0.03	0.09	0.03	0.10	0.03	0.05	0.05	0.06	0.07
Post-Test Span Bias	4.53	4.54	4.54	4.56	4.63	4.57	4.62	4.56	4.65	4.56	4.61	4.56	4.65	4.56	4.64	4.55	4.58	4.55
Post-Analyzer Zero	-0.12	0.01	-0.12	0.01	-0.12	0.01	-0.12	0.01	-0.12	0.01	-0.12	0.01	-0.12	0.01	-0.12	0.01	-0.12	0.01
Post-Analyzer Span	4.66	4.61	4.66	4.61	4.66	4.61	4.66	4.61	4.66	4.61	4.66	4.61	4.66	4.61	4.66	4.61	4.66	4.61
RM Average	4.13	6.32	4.12	5.77	4.09	5.83	4.19	5.83	4.16	5.92	4.18	5.89	4.23	5.87	4.20	5.91	4.18	5.88
RM Corrected Average	4.06	6.26	4.09	5.70	4.01	5.74	4.07	5.74	4.04	5.83	4.06	5.81	4.10	5.79	4.06	5.84	4.08	5.82
RM lb/MMBtu	0.008		0.007		0.007		0.007		0.008		0.007		0.007		0.008		0.008	
CEMS lb/MMBtu	0.008		0.008		0.008		0.008		0.008		0.008		0.008		0.008		0.008	
Difference (lb/MMBtu)	0.000		-0.001		-0.001		-0.001		0.000		-0.001		-0.001		0.000		0.000	
Difference (%)	0.0%		-14.3%		-14.3%		-14.3%		0.0%		-14.3%		-14.3%		0.0%		0.0%	
F-Factor	8,710		8,710		8,710		8,710		8,710		8,710		8,710		8,710		8,710	
Load, MW	259.9		259.6		261.0		260.5		261.2		261.5		261.9		261.8		261.2	

## **APPENDIX D QUALITY ASSURANCE**

## **Appendix D.1**

# **Quality Assurance Program Summary**

## QUALITY ASSURANCE PROGRAM SUMMARY

As part of Montrose Air Quality Services, LLC (Montrose) ASTM D7036-04 certification, Montrose is committed to providing emission related data which is complete, precise, accurate, representative, and comparable. Montrose quality assurance program and procedures are designed to ensure that the data meet or exceed the requirements of each test method for each of these items. The quality assurance program consists of the following items:

- Assignment of an Internal QA Officer
- Development and use of an internal QA Manual
- Personnel training
- Equipment maintenance and calibration
- Knowledge of current test methods
- Chain-of-custody
- QA reviews of test programs

Assignment of an Internal QA Officer: Montrose has assigned an internal QA Officer who is responsible for administering all aspects of the QA program.

Internal Quality Assurance Manual: Montrose has prepared a QA Manual according to the requirements of ASTM D7036-04 and guidelines issued by EPA. The manual documents and formalizes all of Montrose's QA efforts. The manual is revised upon periodic review and as Montrose adds capabilities. The QA manual provides details on the items provided in this summary.

Personnel Testing and Training: Personnel testing and training is essential to the production of high quality test results. Montrose training programs include:

- A requirement for all technical personnel to read and understand the test methods performed
- A requirement for all technical personnel to read and understand the Montrose QA manual
- In-house testing and training
- Quality Assurance meetings
- Third party testing where available
- Maintenance of training records.

Equipment Maintenance and Calibration: All laboratory and field equipment used as a part of Montrose's emission measurement programs is maintained according to manufacturer's recommendations. A summary of the major equipment maintenance schedules is summarized in Table 1. In addition to routine maintenance, calibrations are performed on all sampling equipment according to the procedures outlined in the applicable test method. The calibration intervals and techniques for major equipment components is summarized in Table 2. The calibration technique may vary to meet regulatory agency requirements.

Knowledge of Current Test Methods: Montrose maintains current copies of EPA, ARB, and SCAQMD Source Test Manuals and Rules and Regulations.

Chain-of-Custody: Montrose maintains chain-of-custody documentation on all data sheets and samples. Samples are stored in a locked area accessible only to Montrose source test personnel. Data sheets are kept in the custody of the originator, program manager, or in locked storage until return to Montrose office. Electronic field data is duplicated for backup on secure storage media. The original data sheets are used for report preparation and any additions are initialed and dated.

QA Reviews: Periodic field, laboratory, and report reviews are performed by the in-house QA coordinator. Periodically, test plans are reviewed to ensure proper test methods are selected and reports are reviewed to ensure that the methods were followed and any deviations from the methods are justified and documented.

## **ASTM D7036-04 Required Information**

### Uncertainty Statement

Montrose is qualified to conduct this test program and has established a quality management system that led to accreditation with ASTM Standard D7036-04 (Standard Practice for Competence of Air Emission Testing Bodies). Montrose participates in annual functional assessments for conformance with D7036-04 which are conducted by the American Association for Laboratory Accreditation (A2LA). All testing performed by Montrose is supervised on site by at least one Qualified Individual (QI) as defined in D7036-04 Section 8.3.2. Data quality objectives for estimating measurement uncertainty within the documented limits in the test methods are met by using approved test protocols for each project as defined in D7036-04 Sections 7.2.1 and 12.10. Additional quality assurance information is presented in the report appendices.

### Performance Data

Performance data are available for review.

### Qualified Personnel

A qualified individual (QI), defined by performance on a third party or internal test on the test methods, is present on each test event.

### Plant Entry and Safety Requirements

#### **Plant Entry**

All test personnel are required to check in with the guard at the entrance gate or other designated area. Specific details are provided by the facility and project manager.

## **Safety Requirements**

All personnel shall have the following personal protective equipment (PPE) and wear them where designated:

- Hard Hat
- Safety Glasses
- Steel Toe Boots
- Hearing Protection
- Gloves
- High Temperature Gloves (if required)
- Flame Resistant Clothing (if required)

The following safety measures are followed:

- Good housekeeping
- SDS for all on-site hazardous materials
- Confine selves to necessary areas (stack platform, mobile laboratory, CEMS data acquisition system, control room, administrative areas)
- Knowledge of evacuation procedures

Each facility will provide plant specific safety training.



**TABLE 1  
 EQUIPMENT MAINTENANCE SCHEDULE**

<b>Equipment</b>	<b>Acceptance Limits</b>	<b>Frequency of Service</b>	<b>Methods of Service</b>
Pumps	1. Absence of leaks 2. Ability to draw manufacturers required vacuum and flow	As recommended by manufacturer	1. Visual inspection 2. Clean 3. Replace parts 4. Leak check
Flow Meters	1. Free mechanical movement	As recommended by manufacturer	1. Visual inspection 2. Clean 3. Calibrate
Sampling Instruments	1. Absence of malfunction 2. Proper response to zero span gas	As recommended by manufacturer	As recommended by manufacturer
Integrated Sampling Tanks	1. Absence of leaks	Depends on nature of use	1. Steam clean 2. Leak check
Mobile Van Sampling System	1. Absence of leaks	Depends on nature of use	1. Change filters 2. Change gas dryer 3. Leak check 4. Check for system contamination
Sampling Lines	1. Sample degradation less than 2%	After each test series	1. Blow dry, inert gas through line until dry

**TABLE 2  
 MAJOR SAMPLING EQUIPMENT CALIBRATION REQUIREMENTS**

Sampling Equipment	Calibration Frequency	Calibration Procedure	Acceptable Calibration Criteria
Continuous Analyzers	Before and After Each Test Day	3-point calibration error test	< 2% of analyzer range
Continuous Analyzers	Before and After Each Test Run	2-point sample system bias check	< 5% of analyzer range
Continuous Analyzers	After Each Test Run	2-point analyzer drift determination	< 3% of analyzer range
CEMS System	Beginning of Each Day	leak check	< 1 in. Hg decrease in 5 min. at > 20 in. Hg
Continuous Analyzers	Semi-Annually	3-point linearity	< 1% of analyzer range
NO <sub>x</sub> Analyzer	Daily	NO <sub>2</sub> -> NO converter efficiency	> 90%
Differential Pressure Gauges (except for manometers)	Semi-Annually	Correction factor based on 5-point comparison to standard	± 5%
Differential Pressure Gauges (except for manometers)	Bi-Monthly	3-point comparison to standard, no correction factor	± 5%
Barometer	Semi-Annually	Adjusted to mercury-in-glass or National Weather Service Station	± 0.1 inches Hg
Dry Gas Meter	Semi-Annually	Calibration check at 4 flow rates using a NIST traceable standard	± 2%
Dry Gas Meter	Bi-Monthly	Calibration check at 2 flow rates using a NIST traceable standard	± 2% of semi-annual factor
Dry Gas Meter Orifice	Annually	4-point calibration for ΔH@	--
Temperature Sensors	Semi-Annually	3-point calibration vs. NIST traceable standard	± 1.5%

Note: Calibration requirements that meet applicable regulatory agency requirements are used.

## **Appendix D.2 STAC Certification**



American Association for Laboratory Accreditation

## Accredited Air Emission Testing Body

A2LA has accredited

## MONTROSE AIR QUALITY SERVICES

In recognition of the successful completion of the joint A2LA and Stack Testing Accreditation Council (STAC) evaluation process, this laboratory is accredited to perform testing activities in compliance with ASTM D7036:2004 - Standard Practice for Competence of Air Emission Testing Bodies.



Presented this 27<sup>th</sup> day of February, 2024.

Vice President, Accreditation Services  
For the Accreditation Council  
Certificate Number: 3925.01  
Valid to February 28, 2026

*This accreditation program is not included under the A2LA ILAC Mutual Recognition Arrangement.*

## **Appendix D.3**

### **Individual QI Certificates**

**Montrose Air Quality Services, LLC**  
**AETB Qualified Individual Data**



Source	Ormond Beach Unit 1
Test Date	6/11/2024
AETB Name	Montrose Air Quality Services, LLC.
AETB Phone Number	714-279-6777
AETB e-mail	qualitymanagement@montrose-env.com
QI Last Name	Peterson
QI First Name	John
QI Middle Initial	S.
QI Exam Date	February 4, 2022
Exam Provider	Source Evaluation Society
Exam Contact	<a href="mailto:gstiprogram@gmail.com">gstiprogram@gmail.com</a>

**CERTIFICATE OF COMPLETION**

**John Peterson**

This document certifies that this individual has passed a comprehensive examination and is now a Qualified Individual (QI) as defined in Section 8.3 of ASTM D7036-04 for the following method(s):

**Source Evaluation Society Group 1: EPA Manual Gas Volume and Flow Measurements and Isokinetic Particulate Sampling Methods**

**Certificate Number: 002-2022-108**

*Tate Strickler*  
Tate Strickler, VP – Quality Systems

DATE OF ISSUE: 10/17/2022

DATE OF EXPIRATION: 10/16/2027

**MONTROSE**  
ENVIRONMENTAL

**CERTIFICATE OF COMPLETION**

**John Peterson**

This document certifies that this individual has passed a comprehensive examination and is now a Qualified Individual (QI) as defined in Section 8.3 of ASTM D7036-04 for the following method(s):

**Source Evaluation Society Group 3: EPA Gaseous Pollutants Instrumental Sampling Methods**

**Certificate Number:** 002-2022-40

*Tate Strickler*  
Tate Strickler, VP – Quality Systems

DATE OF ISSUE: 02/04/2022

DATE OF EXPIRATION: 02/03/2027

**MONTROSE**  
ENVIRONMENTAL



## **THIS IS THE LAST PAGE OF THIS DOCUMENT**

If you have any questions, please contact one of the following individuals by email or phone.

Name: Mr. John Peterson  
Title: Client Project Manager  
Region: West  
Email: [AAleshaiker@montrose-env.com](mailto:AAleshaiker@montrose-env.com)  
Phone: (714) 279-6777


Name: Mr. Matt McCune  
Title: Regional Vice President  
Region: West  
Email: [MMccune@montrose-env.com](mailto:MMccune@montrose-env.com)  
Phone: (714) 279-6777

# **V-CONE CALIBRATION REPORT**

**GenOn Ormond Beach**  
**6635 South Edison Drive**  
**Oxnard, CA. 93033**

**Unit 1**

**V-Cone Boroscope Inspection**  
**March 12, 2024**



**Strut and Start of Flow Conditioner**

V-Cone Mfg: McCrometer Serial Number: 92032631  
 Pipe Diameter 29.250 inch Cone Diameter 24.769 inch

Visual Contaminants & Surface	Clean	Slight	Heavy	Physical Damage
Point #1 Beta Edge	X			None Noted
Point #2 Rear Cone Face	X			None Noted
Point #3 Cone Suspension Strut		X		None Noted
Point #4 Flow Conditioner Face		X		None Noted
Point #5 Upstream Port	X			None Noted
Point #6 Downstream Port	X			None Noted

Inspection Start Time: 07:41 ML DST Inspection Completion Time: 14:45 ML DST

**COMMENTS:**

Boroscope revealed light contaminants on the front strut with very rasporadic spots on the pipe wall. The Beta region appears clean and clear. V-Cone element shows no physical damage, corrosion or obstructions. V-Cone flow conditioner reveals slight areas of contaminants, these spots should not effect the overall flow measurement. Sensing ports are clear and clean with thermowell being intact and clean. Welded rear cone segments beads are intact and secure. Spiral wound upstream flange gasket shows slight damage but not unattached from gasket ring.

**RECOMMENDATIONS:**




**Rear Cone Face**

Inspected by: Daryl T. Briscoe Date 03/12/2024

**Certified  
 Instrument  
 Calibrations**

616 South El Camino Real Suite G-4  
 San Clemente, Ca. 92672-3822  
 Phone (949) 413-8550

**GENON**  
**Ormond Beach Station LLC**

**Unit 1**

**V-Cone Calibration Report**

Calibration Date: March 11, 2024



616 South El Camino Real #G-4

San Clemente, CA.

92672-3822

Phone: (949) 413-8550

## Ormond Beach Generating Station Unit #1

### V-Cone System Information

March 11, 2024

#### Flow Computer Data

Manufacturer	ITT Barton
Model Number	1131 Scanner
Serial Number	002118
Board ID Number	10114204
Unit Node Name	OBGS_1
Software Version	NFlo M4.3.6R
ATOD System Voltage	4.99985
Input Battery Voltage	24.010

#### Flow Element Data

Type	V-Cone
Manufacturer	Ketema McCrometer
Tag Name / Number	1FE6500
Serial Number	92032631
Pipe Diameter D	29.250
Cone Diameter d	24.769
Beta	0.532
M	V0030

#### Transmitter Data

Tag Name	1TT-8331	1PT-8344	1FT-8350C	1FT-8350B	1FT-8350A
Resource	A05	A06	A07	A08	A09
Engineering Unit	Degrees F	Psig	Inches WC	Inches WC	Inches WC
Calibration Range	15 - 115	0 - 100	0 - 125	0 - 24	0 - 4
Manufacturer	Rosemount	Rosemount	Rosemount	Rosemount	Rosemount
Model Number	3144D1NA	3051CG-4A	3051CD-2A	3051CD-1A	3051CD-1A
Serial Number	288665	667576	667574	667579	667578

#### Temperature Element Data

Manufacturer	ThermoElect
Type	J
Tag Number	1TE-8331
Model Number	SL-10655 U4 1/2
Serial Number	None
T/C Element Ser. #	None

**NIST Traceable Instrument Used:  
Control Number 23C1558**

<b>ID#</b>	<b>Serial #</b>	<b>Model #</b>	<b>Cal Date</b>	<b>Due Date</b>	<b>Description</b>
CIC-7601	77601	760-6D	11/30/22	05/29/24	0 - 166.00 "H2O
<b>Calibration Standard Used:</b>					
01-726902-0000	Ruska Instruments, Model 6211-801-C				
02-472474-0000	Ruska Instruments, Model 2465-725				
CL-088757-0000	Ruska Instruments, Model 2462				
CL-471247-0000	Vaisala, Model DL2000				

CIC-7681	77681	760-18D	11/30/22	05/29/24	0 - 498.00 "H2O
<b>Calibration Standard Used:</b>					
CL-017275-0000	Ainsworth, Model 1254M				
02-472474-0000	Ruska Instruments, Model 2465-725				
CL-088757-0000	Ruska Instruments, Model 2462				
CL-471247-0000	Vaisala, Model DL2000				

CIC-9756	69756	760-200G	11/30/22	05/29/24	0 - 200 PSIG
<b>Calibration Standard Used:</b>					
CL-088757-0000	Ruska Instruments, Model 2462				
CL-387004-0000	Ruska Instruments, Model 2645-727				
CL-408461-0000	Ruska Instruments, Model 2460-903				
CL-471247-0000	Vaisala, Model DL2000				

CIC-4283	A14283	1504/5610	12/02/22	05/31/24	0 to 100 Degree C
<b>Calibration Standard Used:</b>					
22-007978-0000	Fluke, Model 1595A				
CL-470663-0000	Vaisala, Model SP-2000-20R				

CIC-8019	1378019	Fluke 8245A	11/22/22	05/21/24	Digital DMM
<b>Calibration Standard Used:</b>					
CL-470177-0000	Vaisala, Model DL-2000				
CL-451043-0000	Fluke, Model 5725A				



Calibration Traceable to the National Institute of Standards and Technology (N.I.S.T.)  
Actual calibration certificates are on file with Certified Instrument Calibrations Company  
and copies may be obtained by request.

Scanner 1100 Analog-in Multi-point Verification Report

Downloaded at : Monday, March 11, 2024 at 08:02 (ML).  
Downloaded from : OBGS\_1  
Unit Serial Number : 002118  
Software Version : NFlo M4.3.6R  
ScanWin Version : B2.2.6W

Verification started: Monday, March 11, 2024 at 07:35 (ML).  
Verification completed: Monday, March 11, 2024 at 08:02 (ML).  
Verification done by: Non-Login

This input has been assigned to:  
Node : OBGS\_1, Flowrun #01 (OBGS\_1)

Channel location : Node OBGS\_1, Slot A, Resource #23  
Channel category Differential Pressure  
Channel text 1FT-8350A  
Xmitter zero 0.000 Inch WC  
Xmitter fullscale 4.000 Inch WC  
Unit Temperature Celsius  
Number of verification points: 5 (Up/Down)

Verification Point Inch WC	As Found Inch WC	Direction	Percent Accuracy (% of Full-Scale)
0.000	0.000	Start	0.000
2.000	2.011	Ascending	0.275
4.000	4.000	Ascending	0.000
3.000	3.019	Descending	0.475
1.000	1.006	Descending	0.150

Scanner 1100 Analog-in Multi-point Verification Report

Downloaded at : Monday, March 11, 2024 at 08:58 (ML).  
Downloaded from : OBGS\_1  
Unit Serial Number : 002118  
Software Version : NFlo M4.3.6R  
ScanWin Version : B2.2.6W

Verification started: Monday, March 11, 2024 at 08:29 (ML).  
Verification completed: Monday, March 11, 2024 at 08:58 (ML).  
Verification done by: Non-Login

This input has been assigned to:  
Node : OBGS\_1, Flowrun #01 (OBGS\_1)

Channel location : Node OBGS\_1, Slot A, Resource #21  
Channel category Differential Pressure  
Channel text 1FT-8350B  
Xmitter zero 0.000 Inch WC  
Xmitter fullscale 24.000 Inch WC  
Unit Temperature Celsius  
Number of verification points: 5 (Up/Down)

Verification Point Inch WC	As Found Inch WC	Direction	Percent Accuracy (% of Full-Scale)
0.000	-0.003	Start	-0.013
12.000	11.990	Ascending	-0.042
24.000	23.999	Ascending	-0.004
18.000	18.009	Descending	0.038
6.000	5.990	Descending	-0.042



Scanner 1100 Analog-in Multi-point Verification Report

Downloaded at : Monday, March 11, 2024 at 09:55 (ML).  
Downloaded from : OBGS\_1  
Unit Serial Number : 002118  
Software Version : NFlo M4.3.6R  
ScanWin Version : B2.2.6W

Verification started: Monday, March 11, 2024 at 09:27 (ML).  
Verification completed: Monday, March 11, 2024 at 09:55 (ML).  
Verification done by: Non-Login

This input has been assigned to:  
Node : OBGS\_1, Flowrun #01 (OBGS\_1)

Channel location : Node OBGS\_1, Slot A, Resource #19  
Channel category Differential Pressure  
Channel text 1FT-8350C  
Xmitter zero 0.000 Inch WC  
Xmitter fullscale 125.000 Inch WC  
Unit Temperature Celsius  
Number of verification points: 5 (Up/Down)

Verification Point Inch WC	As Found Inch WC	Direction	Percent Accuracy (% of Full-Scale)
0.000	-0.006	Start	-0.005
62.500	62.592	Ascending	0.074
125.000	125.003	Ascending	0.002
93.750	93.813	Descending	0.050
31.250	31.289	Descending	0.031

## Scanner 1100 Analog-in Multi-point Verification Report

Downloaded at : Monday, March 11, 2024 at 11:07 (ML).  
Downloaded from : OBGS\_1  
Unit Serial Number : 002118  
Software Version : NFlo M4.3.6R  
ScanWin Version : B2.2.6W

Verification started: Monday, March 11, 2024 at 10:26 (ML).  
Verification completed: Monday, March 11, 2024 at 11:07 (ML).  
Verification done by: Non-Login

This input has been assigned to:  
Node : OBGS\_1, Flowrun #01 (OBGS\_1)

Channel location : Node OBGS\_1, Slot A, Resource #15  
Channel category Static Pressure  
Channel text 1PT-8344  
Xmitter zero 0.000 psi(a)  
Xmitter fullscale 100.000 psi(a)  
Unit Temperature Celsius  
Number of verification points: 5 (Up/Down)

Verification Point psi(a)	As Found psi(a)	Direction	Percent Accuracy (% of Full-Scale)
0.000	-0.028	Start	-0.028
50.000	49.967	Ascending	-0.033
100.000	99.968	Ascending	-0.032
75.000	74.958	Descending	-0.042
25.000	24.972	Descending	-0.028

Control Number 23C1558

## Scanner 1100 Analog-in Multi-point Verification Report

Downloaded at : Monday, March 11, 2024 at 13:41 (ML).  
Downloaded from : OBGS\_1  
Unit Serial Number : 002118  
Software Version : NFlo M4.3.6R  
ScanWin Version : B2.2.6W

Verification started: Monday, March 11, 2024 at 11:43 (ML).  
Verification completed: Monday, March 11, 2024 at 13:41 (ML).  
Verification done by: Non-Login

This input has been assigned to:  
Node : OBGS\_1, Flowrun #01 (OBGS\_1)

Channel location : Node OBGS\_1, Slot A, Resource #17  
Channel category Temperature  
Channel text 1TT-8331  
Xmitter zero 15.000 Fahrenheit  
Xmitter fullscale 115.000 Fahrenheit  
Unit Temperature Celsius  
Number of verification points: 5 (Up)

Verification Point Fahrenheit	As Found Fahrenheit	Direction	Percent Accuracy (% of Full-Scale)
15.000	14.854	Start	-0.146
40.000	39.934	Ascending	-0.066
65.000	65.025	Ascending	0.025
90.000	90.052	Ascending	0.052
115.000	115.109	Ascending	0.109

Control Number 23C1558

Scanner 1100 Analog-in Multi-point Calibration Report

Downloaded at : Monday, March 11, 2024 at 08:29 (ML).  
Downloaded from : OBGS\_1  
Unit Serial Number : 002118  
Software Version : NFlo M4.3.6R  
ScanWin Version : B2.2.6W

Calibration started: Monday, March 11, 2024 at 08:02 (ML).  
Calibration completed: Monday, March 11, 2024 at 08:29 (ML).  
Calibration done by: Non-Login

This input has been assigned to:  
Node : OBGS\_1, Flowrun #01 (OBGS\_1)

Channel location : Node OBGS\_1, Slot A, Resource #23  
Channel category Differential Pressure  
Channel text 1FT-8350A  
Xmitter zero 0.000 Inch WC  
Xmitter fullscale 4.000 Inch WC  
Number of calibration points: 5 (Up/Down)

Calibration Point Inch WC	As Found Inch WC	As Left Inch WC	Calibration Percent Accuracy
0.000	-0.002	0.000	0.000
2.000	2.010	2.006	0.150
4.000	3.949	4.000	0.000
3.000	2.994	3.007	0.175
1.000	1.006	1.003	0.075

High Pressure Zero : 0.8111 mV ( As Found )  
                          : 0.6667 mV ( As Left )  
Span Compensation Factor : 0.0000 % / MPag ( As Found )  
                                  : 0.0000 % / MPag ( As Left )

Control Number 23C1558

## Scanner 1100 Analog-in Multi-point Calibration Report

Downloaded at : Monday, March 11, 2024 at 09:27 (ML).

Downloaded from : OBGS\_1

Unit Serial Number : 002118

Software Version : NFlo M4.3.6R

ScanWin Version : B2.2.6W

Calibration started: Monday, March 11, 2024 at 08:58 (ML).

Calibration completed: Monday, March 11, 2024 at 09:27(ML).

Calibration done by: Non-Login

This input has been assigned to:

Node : OBGS\_1, Flowrun #01 (OBGS\_1)

Channel location : Node OBGS\_1, Slot A, Resource #21

Channel category Differential Pressure

Channel text 1FT-8350B

Xmitter zero 0.000 Inch WC

Xmitter fullscale 24.000 Inch WC

Number of calibration points: 5 (Up/Down)

Calibration Point Inch WC	As Found Inch WC	As Left Inch WC	Calibration Percent Accuracy
0.000	-0.004	0.000	0.000
12.000	11.999	12.001	0.004
24.000	24.006	24.000	0.000
18.000	18.004	18.002	0.008
6.000	5.997	5.998	-0.008

High Pressure Zero : -0.3067 mV ( As Found )

: -0.1263 mV ( As Left )

Span Compensation Factor : 0.0000 % / MPag ( As Found )

: 0.0000 % / MPag ( As Left )

Control Number 23C1558



Scanner 1100 Analog-in Multi-point Calibration Report

Downloaded at : Monday, March 11, 2024 at 11:43 (ML).  
Downloaded from : OBGS\_1  
Unit Serial Number : 002118  
Software Version : NFlo M4.3.6R  
ScanWin Version : B2.2.6W

Calibration started: Monday, March 11, 2024 at 11:07 (ML).  
Calibration completed: Monday, March 11, 2024 at 11:43 (ML).  
Calibration done by: Non-Login

This input has been assigned to:  
Node : OBGS\_1, Flowrun #01 (OBGS\_1)

Channel location : Node OBGS\_1, Slot A, Resource #15  
Channel category Static Pressure  
Channel text 1PT-8344  
Xmitter zero 0.000 psi(a)  
Xmitter fullscale 100.000 psi(a)  
Number of calibration points: 5 (Up/Down)

Calibration Point psi(a)	As Found psi(a)	As Left psi(a)	Calibration Percent Accuracy
0.000	-0.025	0.000	0.000
50.000	49.968	50.000	0.000
100.000	99.966	100.000	0.000
75.000	74.969	75.003	0.003
25.000	24.964	24.996	-0.004

Scanner 1100 Analog-in Multi-point Calibration Report

Downloaded at : Monday, March 11, 2024 at 15:50 (ML).  
Downloaded from : OBGS\_1  
Unit Serial Number : 002118  
Software Version : NFlo M4.3.6R  
ScanWin Version : B2.2.6W

Calibration started: Monday, March 11, 2024 at 13:42 (ML).  
Calibration completed: Monday, March 11, 2024 at 15:50 (ML).  
Calibration done by: Non-Login

This input has been assigned to:  
Node : OBGS\_1, Flowrun #01 (OBGS\_1)

Channel location : Node OBGS\_1, Slot A, Resource #17  
Channel category Temperature  
Channel text 1TT-8331  
Xmitter zero 15.000 Fahrenheit  
Xmitter fullscale 115.000 Fahrenheit  
Number of calibration points: 5 (Up)

Calibration Point Fahrenheit	As Found Fahrenheit	As Left Fahrenheit	Calibration Percent Accuracy
15.000	14.847	15.000	0.000
40.000	39.998	40.000	0.000
65.000	65.043	65.000	0.000
90.000	90.066	90.000	0.000
115.000	115.097	115.000	0.000


Control Number 23C1558



**GenOn Ormond Beach**  
**6635 South Edison Drive**  
**Oxnard, CA. 93033**

**Unit 2**

**V-Cone Boroscope Inspection**  
**March 14, 2024**



**Strut and Start of Flow Conditioner**

V-Cone Mfg: McCrometer Serial Number: 92032632  
 Pipe Diameter 29.250 inch Cone Diameter 24.769 inch

Visual Contaminants & Surface	Clean	Slight	Heavy	Physical Damage
Point #1 Beta Edge	X			None Noted
Point #2 Rear Cone Face		X		None Noted
Point #3 Cone Suspension Strut		X		None Noted
Point #4 Flow Conditioner Face		X		None Noted
Point #5 Upstream Port	X			None Noted
Point #6 Downstream Port	X			None Noted

Inspection Start Time: 07:45 ML DST Inspection Completion Time: 16:15 ML DST

**COMMENTS:**

Boroscope revealed valve grease (white) on the front strut, flow conditioner and internal pipe walls. These areas of valve grease have been shredded before the Beta Region. The element shows no notable physical damage, corrosion or obstructions. The rear cone face revealed areas of grease spots including inside lower ring lip ledge. Beta region is clear with the exception of streaks of grease residual on the pipe wall and through the trailing edge of rear cone face. No obstructions were observed with welds found intact and secure, sensing lines also found clear.

**RECOMMENDATIONS:**

Continue to monitor grease accumulation in vital areas as a concern. Grease accumulation not significantly greater since inspection of last year. McCrometer V-Cone designed to shred contaminants away from measuring section.



**Rear Cone Face**

Inspected by: Daryl T. Briscoe Date: 03/14/2024

**Certified  
 Instrument  
 Calibrations**

Phone (949) 413-8550

**GENON**  
**Ormond Beach Station LLC**

**Unit 2**

**V-Cone Calibration Report**

Calibration Date: March 13, 2024



616 South El Camino Real #G-4

San Clemente, CA.

92672-3822

Phone: (949) 413-8550

## Ormond Beach Generating Station Unit #2

### V-Cone System Information

March 13, 2024

#### Flow Computer Data

Manufacturer	ITT Barton
Model Number	1131 Scanner
Serial Number	002119
Board ID Number	10114195
Unit Node Name	OBGS_2
Software Version	NFlo M4.3.6R
ATOD System Voltage	5.00082
Input Battery Voltage	24.000

#### Flow Element Data

Type	V-Cone
Manufacturer	Ketema McCrometer
Tag Name / Number	2FE6500
Serial Number	92032632
Pipe Diameter D	29.250
Cone Diameter d	24.769
Beta	0.535
M	V0030

#### Transmitter Data

Tag Name	2TT-8331	2PT-8344	2FT-8350C	2FT-8350B	2FT-8350A
Resource	A05	A06	A07	A08	A09
Engineering Unit	Degrees F	Psig	Inches WC	Inches WC	Inches WC
Calibration Range	15 - 115	0 - 100	0 - 125	0 - 24	0 - 4
Manufacturer	Rosemount	Rosemount	Rosemount	Rosemount	Rosemount
Model Number	3144D1NA	3051CG-4A	3051CD-2A	3051CD-1A	3051CD-1A
Serial Number	288666	667577	667575	667580	1236482

#### Temperature Element Data

Manufacturer	Telmar
Type	"J"
Tag Number	2TE-8331
Model Number	570166
Serial Number	10 06 01908
T/C Element Ser. #	MI7573JUL6X12PM30

**NIST Traceable Instrument Used:  
Control Number 23C1558**

<b>ID#</b>	<b>Serial #</b>	<b>Model #</b>	<b>Cal Date</b>	<b>Due Date</b>	<b>Description</b>
CIC-7601	77601	760-6D	11/30/22	05/29/24	0 - 166.00 "H2O
<b>Calibration Standard Used:</b>					
01-726902-0000	Ruska Instruments, Model 6211-801-C				
02-472474-0000	Ruska Instruments, Model 2465-725				
CL-088757-0000	Ruska Instruments, Model 2462				
CL-471247-0000	Vaisala, Model DL2000				

CIC-7681	77681	760-18D	11/30/22	05/29/24	0 - 498.00 "H2O
<b>Calibration Standard Used:</b>					
CL-017275-0000	Ainsworth, Model 1254M				
02-472474-0000	Ruska Instruments, Model 2465-725				
CL-088757-0000	Ruska Instruments, Model 2462				
CL-471247-0000	Vaisala, Model DL2000				

CIC-9756	69756	760-200G	11/30/22	05/29/24	0 - 200 PSIG
<b>Calibration Standard Used:</b>					
CL-088757-0000	Ruska Instruments, Model 2462				
CL-387004-0000	Ruska Instruments, Model 2645-727				
CL-408461-0000	Ruska Instruments, Model 2460-903				
CL-471247-0000	Vaisala, Model DL2000				

CIC-4283	A14283	1504/5610	12/02/22	05/31/24	0 to 100 Degree C
<b>Calibration Standard Used:</b>					
22-007978-0000	Fluke, Model 1595A				
CL-470663-0000	Vaisala, Model SP-2000-20R				

CIC-8019	1378019	Fluke 8245A	11/22/22	05/21/24	Digital DMM
<b>Calibration Standard Used:</b>					
CL-470177-0000	Vaisala, Model DL-2000				
CL-451043-0000	Fluke, Model 5725A				



Calibration Traceable to the National Institute of Standards and Technology (N.I.S.T.)  
Actual calibration certificates are on file with Certified Instrument Calibrations Company  
and copies may be obtained by request.

Scanner 1100 Analog-in Multi-point Verification Report

Downloaded at : Wednesday, March 13, 2024 at 07:16 (ML)  
Downloaded from : OBGS\_2  
Unit Serial Number : 002119  
Software Version : NFlo M4.3.6R  
ScanWin Version : B2.2.6W

Verification started : Wednesday, March 13, 2024 at 06:48 (ML)  
Verification completed: Wednesday, March 13, 2024 at 07:16 (ML)  
Verification done by: Cert-Inst-Cals

This input has been assigned to:  
Node : OBGS\_2, Flowrun #01 (OBGS\_2)

Channel location Node OBGS\_2, Slot A, Resource #23  
Channel category Differential Pressure  
Channel text 2FT-8350A  
Xmitter zero 0.000 Inch WC  
Xmitter fullscale 4.000 Inch WC  
Number of verification points: 5

Verification Point Inch WC	As Found Inch WC	Direction	Percent Accuracy (% of Full-Scale)
0.000	-0.037	Start	-0.925
2.000	1.982	Ascending	-0.450
4.000	3.986	Ascending	-0.350
3.000	2.985	Descending	-0.375
1.000	0.966	Descending	-0.850

Control Number 23C1558

Scanner 1100 Analog-in Multi-point Verification Report

Downloaded at : Wednesday, March 13, 2024 at 08:18 (ML)  
Downloaded from : OBGS\_2  
Unit Serial Number : 002119  
Software Version : NFlo M4.3.6R  
ScanWin Version : B2.2.6W

Verification started: Wednesday, March 13, 2024 at 07:47 (ML)  
Verification completed: Wednesday, March 13, 2024 at 08:18 (ML)  
Verification done by: Cert-Inst-Cals

This input has been assigned to:  
Node : OBGS\_2, Flowrun #01 (OBGS\_2)

Channel location Node OBGS\_2, Slot A, Resource #21  
Channel category Differential Pressure  
Channel text 2FT-8350B  
Xmitter zero 0.000 Inch WC  
Xmitter fullscale 24.000 Inch WC  
Number of verification points: 5

Verification Point Inch WC	As Found Inch WC	Direction	Percent Accuracy (% of Full-Scale)
0.000	-0.005	Start	-0.021
12.000	11.989	Ascending	-0.046
24.000	24.031	Ascending	0.129
18.000	18.036	Descending	0.150
6.000	5.982	Descending	-0.075

Control Number 23C1558

Scanner 1100 Analog-in Multi-point Verification Report

Downloaded at : Wednesday, March 13, 2024 at 09:25 (ML)  
Downloaded from : OBGS\_2  
Unit Serial Number : 002119  
Software Version : NFlo M4.3.6R  
ScanWin Version : B2.2.6W

Verification started: Wednesday, March 13, 2024 at 08:51 (ML)  
Verification completed: Wednesday, March 13, 2024 at 09:25 (ML)  
Verification done by: Cert-Inst-Cals

This input has been assigned to:  
Node : OBGS\_2, Flowrun #01 (OBGS\_2)

Channel location Node OBGS\_2, Slot A, Resource #19  
Channel category Differential Pressure  
Channel text 2FT-8350C  
Xmitter zero 0.000 Inch WC  
Xmitter fullscale 125.000 Inch WC  
Number of verification points: 5

Verification Point Inch WC	As Found Inch WC	Direction	Percent Accuracy (% of Full-Scale)
0.000	-0.050	Start	-0.040
62.500	62.457	Ascending	-0.034
125.000	124.958	Ascending	-0.034
93.750	93.737	Descending	-0.010
31.250	31.219	Descending	-0.025

Control Number 23C1558

Scanner 1100 Analog-in Multi-point Verification Report

Downloaded at : Wednesday, March 13, 2024 at 10:34 (ML)  
Downloaded from : OBGS\_2  
Unit Serial Number : 002119  
Software Version : NFlo M4.3.6R  
ScanWin Version : B2.2.6W

Verification started: Wednesday, March 13, 2024 at 10:02 (ML)  
Verification completed: Wednesday, March 13, 2024 at 10:34 (ML)  
Verification done by: Cert-Inst-Cals

This input has been assigned to:  
Node : OBGS\_2, Flowrun #01 (OBGS\_2)

Channel location Node OBGS\_2, Slot A, Resource #15  
Channel category Static Pressure  
Channel text 2PT-8344  
Xmitter zero 0.000 psi(a)  
Xmitter fullscale 100.000 psi(a)  
Number of verification points: 5

Verification Point psi(a)	As Found psi(a)	Direction	Percent Accuracy (% of Full-Scale)
0.000	0.435	Start	0.435
50.000	50.453	Ascending	0.453
100.000	100.472	Ascending	0.472
75.000	75.472	Descending	0.472
25.000	25.479	Descending	0.479



Scanner 1100 Analog-in Multi-point Verification Report

Downloaded at : Wednesday, March 13, 2024 at 12:44 (ML)  
Downloaded from : OBGS\_2  
Unit Serial Number : 002119  
Software Version : NFlo M4.3.6R  
ScanWin Version : B2.2.6W

Verification started: Wednesday, March 13, 2024 at 10:59 (ML)  
Verification completed: Wednesday, March 13, 2024 at 12:44 (ML)  
Verification done by: Cert-Inst-Cals

This input has been assigned to:  
Node : OBGS\_2, Flowrun #01 (OBGS\_2)

Channel location Node OBGS\_2, Slot A, Resource #17  
Channel category Temperature  
Channel text 2TT-8331  
Xmitter zero 15.000 Fahrenheit  
Xmitter fullscale 115.000 Fahrenheit  
Number of verification points: 5

Verification Point Fahrenheit	As Found Fahrenheit	Direction	Percent Accuracy (% of Full-Scale)
15.000	15.228	Start	0.228
40.000	40.133	Ascending	0.133
65.000	65.189	Ascending	0.189
90.000	90.254	Ascending	0.254
115.000	115.250	Ascending	0.250

Control Number 23C1558

## Scanner 1100 Analog-in Multi-point Calibration Report

Downloaded at : Wednesday, March 13, 2024 at 07:47 (ML)  
 Downloaded from : OBGS\_2  
 Unit Serial Number : 002119  
 Software Version : NFlo M4.3.6R  
 ScanWin Version : B2.2.6W

Calibration started: Wednesday, March 13, 2024 at 07:16 (ML)  
 Calibration completed: Wednesday, March 13, 2024 at 07:47 (ML)  
 Calibration done by: Cert-Inst-Cals

This input has been assigned to:  
 Node : OBGS\_2, Flowrun #01 (OBGS\_2)

Channel location Node OBGS\_2, Slot A, Resource #23  
 Channel category Differential Pressure  
 Channel text 2FT-8350A  
 Xmitter zero 0.000 Inch WC  
 Xmitter fullscale 4.000 Inch WC  
 Number of calibration points: 5 (Up/Down)

Calibration Point Inch WC	As Found Inch WC	As Left Inch WC	Calibration Percent Accuracy
0.000	-0.036	0.000	0.000
2.000	1.980	1.990	-0.250
4.000	3.987	4.000	0.000
3.000	2.986	3.025	0.625
1.000	0.968	1.016	0.400

High Pressure Zero : 5.0789 mV ( As Found )  
 : -9.6889 mV ( As Left )  
 Span Compensation Factor : 0.0000 % / MPag ( As Found )  
 : 0.0000 % / MPag ( As Left )

Control Number 23C1558



Scanner 1100 Analog-in Multi-point Calibration Report

Downloaded at : Wednesday, March 13, 2024 at 10:02 (ML)  
Downloaded from : OBGS\_2  
Unit Serial Number : 002119  
Software Version : NFlo M4.3.6R  
ScanWin Version : B2.2.6W

Calibration started: Wednesday, March 13, 2024 at 09:25 (ML)  
Calibration completed: Wednesday, March 13, 2024 at 10:02 (ML)  
Calibration done by: Cert-Inst-Cals

This input has been assigned to:  
Node : OBGS\_2, Flowrun #01 (OBGS\_2)

Channel location Node OBGS\_2, Slot A, Resource #19  
Channel category Differential Pressure  
Channel text 2FT-8350C  
Xmitter zero 0.000 Inch WC  
Xmitter fullscale 125.000 Inch WC  
Number of calibration points: 5 (Up/Down)

Calibration Point Inch WC	As Found Inch WC	As Left Inch WC	Calibration Percent Accuracy
0.000	-0.030	0.000	0.000
62.500	62.427	62.490	-0.008
125.000	124.958	125.000	0.000
93.750	93.700	93.755	0.004
31.250	31.206	31.254	0.003

High Pressure Zero : -0.8129 mV ( As Found )  
                          : - 0.0542 mV ( As Left )  
Span Compensation Factor : 0.0000 % / MPag ( As Found )  
                                  : 0.0000 % / MPag ( As Left )

Control Number 23C1558

Scanner 1100 Analog-in Multi-point Calibration Report

Downloaded at : Wednesday, March 13, 2024 at 10:59 (ML)  
Downloaded from : OBGS\_2  
Unit Serial Number : 002119  
Software Version : NFlo M4.3.6R  
ScanWin Version : B2.2.6W

Calibration started: Wednesday, March 13, 2024 at 10:34 (ML)  
Calibration completed: Wednesday, March 13, 2024 at 10:59 (ML)  
Calibration done by: Cert-Inst-Cals

This input has been assigned to:  
Node : OBGS\_2, Flowrun #01 (OBGS\_2)

Channel location Node OBGS\_2, Slot A, Resource #15  
Channel category Static Pressure  
Channel text 2PT-8344  
Xmitter zero 0.000 psi(a)  
Xmitter fullscale 100.000 psi(a)  
Number of calibration points: 5 (Up/Down)

Calibration Point psi(a)	As Found psi(a)	As Left psi(a)	Calibration Percent Accuracy
0.000	0.459	0.000	0.000
50.000	50.455	49.995	-0.005
100.000	100.415	100.000	0.000
75.000	75.472	75.017	0.017
25.000	25.452	24.999	-0.001

### Scanner 1100 Analog-in Multi-point Calibration Report

Downloaded at : Wednesday, March 13, 2024 at 14:40 (ML)  
Downloaded from : OBGS\_2  
Unit Serial Number : 002119  
Software Version : NFlo M4.3.6R  
ScanWin Version : B2.2.6W

Calibration started: Wednesday, March 13, 2024 at 12:44 (ML)  
Calibration completed: Wednesday, March 13, 2024 at 14:40 (ML)  
Calibration done by: Cert-Inst-Cals

This input has been assigned to:  
Node : OBGS\_2, Flowrun #01 (OBGS\_2)

Channel location Node OBGS\_2, Slot A, Resource #17  
Channel category Temperature  
Channel text 2TT-8331  
Xmitter zero 15.000 Fahrenheit  
Xmitter fullscale 115.000 Fahrenheit  
Number of calibration points: 5 (Up)

Calibration Point Fahrenheit	As Found Fahrenheit	As Left Fahrenheit	Calibration Percent Accuracy
15.000	15.071	15.000	0.000
40.000	39.986	40.000	0.000
65.000	65.023	65.000	0.000
90.000	90.175	90.000	0.000
115.000	115.254	115.000	0.000

# **LINEARITY REPORT**

# Linearity Test

Plant: ORMOND BEACH GEN STA

Report Period: 07/01/2024 00:00 Through 09/06/2024 23:59

Source: ORB1

Parameter: NOXHI

System ID: 101

Component ID: 015

Span Value: 250.000

Span Scale Code: H

Test End Date/Time: 09/06/24 06:55

Test Number: XML (015-Q3-2024-1) / EDR (1)

Reason for Test: Periodic Quality Assurance

Test Result: **Pass**

Abbreviated?: No

Injection Time	Reference Value	Measured Value	Difference	% of Reference
----------------	-----------------	----------------	------------	----------------

### Low-Level

09/06/24 06:23	59.600	60.000	-0.400	0.7
09/06/24 06:35	59.600	60.100	-0.500	0.8
09/06/24 06:47	59.600	60.000	-0.400	0.7

Reference Mean: 59.600  
Measured Mean: 60.033  
Level Error: 0.7  
APS Indicator: False  
Gas Type Code: BALN,NO,NOX  
Vendor Identifier: B32018  
Cylinder #: CC215900  
Cylinder Exp. Date: 12/19/2026

Injection Time	Reference Value	Measured Value	Difference	% of Reference
----------------	-----------------	----------------	------------	----------------

### Mid-Level

09/06/24 06:27	128.400	128.800	-0.400	0.3
09/06/24 06:39	128.400	128.900	-0.500	0.4
09/06/24 06:51	128.400	128.500	-0.100	0.1

Reference Mean: 128.400  
Measured Mean: 128.733  
Level Error: 0.3  
APS Indicator: False  
Gas Type Code: BALN,NO,NOX  
Vendor Identifier: B32019  
Cylinder #: CC91055  
Cylinder Exp. Date: 04/19/2027

Injection Time	Reference Value	Measured Value	Difference	% of Reference
----------------	-----------------	----------------	------------	----------------

### High-Level

09/06/24 06:31	223.000	223.300	-0.300	0.1
09/06/24 06:43	223.000	223.300	-0.300	0.1
09/06/24 06:55	223.000	223.100	-0.100	0.0

Reference Mean: 223.000  
Measured Mean: 223.233  
Level Error: 0.1  
APS Indicator: False  
Gas Type Code: BALN,NO,NOX  
Vendor Identifier: F22020  
Cylinder #: CC244312  
Cylinder Exp. Date: 10/06/2028



# Linearity Test

Plant: ORMOND BEACH GEN STA

Report Period: 07/01/2024 00:00 Through 09/06/2024 23:59

Source: ORB1

Parameter: O2HI

System ID: 101

Component ID: 016

Span Value: 20.000

Span Scale Code: H

Test End Date/Time: 09/06/24 08:38

Test Number: XML (016-Q3-2024-1) / EDR (1)

Reason for Test: Periodic Quality Assurance

Test Result: **Pass**

Abbreviated?: No

Injection Time	Reference Value	Measured Value	Difference	% of Reference
----------------	-----------------	----------------	------------	----------------

### Low-Level

09/06/24 08:22	5.500	5.500	0.000	0.0
09/06/24 08:28	5.500	5.500	0.000	0.0
09/06/24 08:34	5.500	5.500	0.000	0.0

Reference Mean: 5.500  
Measured Mean: 5.500  
Level Error: 0.0  
APS Indicator: False  
Gas Type Code: BALN,O2  
Vendor Identifier: B32019  
Cylinder #: CC195272  
Cylinder Exp. Date: 07/23/2027

Injection Time	Reference Value	Measured Value	Difference	% of Reference
----------------	-----------------	----------------	------------	----------------

### Mid-Level

09/06/24 08:24	11.100	11.100	0.000	0.0
09/06/24 08:30	11.100	11.100	0.000	0.0
09/06/24 08:36	11.100	11.100	0.000	0.0

Reference Mean: 11.100  
Measured Mean: 11.100  
Level Error: 0.0  
APS Indicator: False  
Gas Type Code: BALN,O2  
Vendor Identifier: B32019  
Cylinder #: CC338195  
Cylinder Exp. Date: 08/05/2027

Injection Time	Reference Value	Measured Value	Difference	% of Reference
----------------	-----------------	----------------	------------	----------------

### High-Level

09/06/24 08:26	18.100	18.200	-0.100	0.6
09/06/24 08:32	18.100	18.200	-0.100	0.6
09/06/24 08:38	18.100	18.200	-0.100	0.6

Reference Mean: 18.100  
Measured Mean: 18.200  
Level Error: 0.6  
APS Indicator: False  
Gas Type Code: BALN,O2  
Vendor Identifier: F22020  
Cylinder #: SA11523  
Cylinder Exp. Date: 12/09/2028

# Linearity Test

Plant: ORMOND BEACH GEN STA

Report Period: 07/01/2024 00:00 Through 09/05/2024 23:59

Source: ORB2

Parameter: NOXHI

System ID: 201

Component ID: 025

Span Value: 250.000

Span Scale Code: H

Test End Date/Time: 09/05/24 06:28

Test Number: XML (025-Q3-2024-1) / EDR (1)

Reason for Test: Periodic Quality Assurance

Test Result: **Pass**

Abbreviated?: No

Injection Time	Reference Value	Measured Value	Difference	% of Reference
----------------	-----------------	----------------	------------	----------------

### Low-Level

09/05/24 06:04	59.600	57.600	2.000	3.4
09/05/24 06:13	59.600	58.300	1.300	2.2
09/05/24 06:22	59.600	59.300	0.300	0.5

Reference Mean: 59.600  
Measured Mean: 58.400  
Level Error: 2.0  
APS Indicator: False  
Gas Type Code: BALN,NO,NOX  
Vendor Identifier: B32018  
Cylinder #: CC215900  
Cylinder Exp. Date: 12/19/2026

Injection Time	Reference Value	Measured Value	Difference	% of Reference
----------------	-----------------	----------------	------------	----------------

### Mid-Level

09/05/24 06:07	128.400	128.500	-0.100	0.1
09/05/24 06:16	128.400	127.800	0.600	0.5
09/05/24 06:25	128.400	128.000	0.400	0.3

Reference Mean: 128.400  
Measured Mean: 128.100  
Level Error: 0.2  
APS Indicator: False  
Gas Type Code: BALN,NO,NOX  
Vendor Identifier: B32019  
Cylinder #: CC91055  
Cylinder Exp. Date: 04/19/2027

Injection Time	Reference Value	Measured Value	Difference	% of Reference
----------------	-----------------	----------------	------------	----------------

### High-Level

09/05/24 06:10	223.000	223.200	-0.200	0.1
09/05/24 06:19	223.000	223.500	-0.500	0.2
09/05/24 06:28	223.000	223.600	-0.600	0.3

Reference Mean: 223.000  
Measured Mean: 223.433  
Level Error: 0.2  
APS Indicator: False  
Gas Type Code: BALN,NO,NOX  
Vendor Identifier: F22020  
Cylinder #: CC244312  
Cylinder Exp. Date: 10/06/2028

# Linearity Test

Plant: ORMOND BEACH GEN STA

Report Period: 07/01/2024 00:00 Through 09/05/2024 23:59

Source: ORB2

Parameter: O2HI

System ID: 201

Component ID: 026

Span Value: 20.000

Span Scale Code: H

Test End Date/Time: 09/05/24 08:43

Test Number: XML (026-Q3-2024-1) / EDR (1)

Reason for Test: Periodic Quality Assurance

Test Result: **Pass**

Abbreviated?: No

Injection Time	Reference Value	Measured Value	Difference	% of Reference
----------------	-----------------	----------------	------------	----------------

### Low-Level

09/05/24 08:19	5.500	5.400	0.100	1.8
09/05/24 08:28	5.500	5.400	0.100	1.8
09/05/24 08:37	5.500	5.400	0.100	1.8

Reference Mean: 5.500  
Measured Mean: 5.400  
Level Error: 1.8  
APS Indicator: False  
Gas Type Code: BALN,O2  
Vendor Identifier: B32019  
Cylinder #: CC195272  
Cylinder Exp. Date: 07/23/2027

Injection Time	Reference Value	Measured Value	Difference	% of Reference
----------------	-----------------	----------------	------------	----------------

### Mid-Level

09/05/24 08:22	11.100	10.900	0.200	1.8
09/05/24 08:31	11.100	10.900	0.200	1.8
09/05/24 08:40	11.100	10.900	0.200	1.8

Reference Mean: 11.100  
Measured Mean: 10.900  
Level Error: 1.8  
APS Indicator: False  
Gas Type Code: BALN,O2  
Vendor Identifier: B32019  
Cylinder #: CC338195  
Cylinder Exp. Date: 08/05/2027

Injection Time	Reference Value	Measured Value	Difference	% of Reference
----------------	-----------------	----------------	------------	----------------

### High-Level

09/05/24 08:25	18.100	18.100	0.000	0.0
09/05/24 08:34	18.100	18.100	0.000	0.0
09/05/24 08:43	18.100	18.100	0.000	0.0

Reference Mean: 18.100  
Measured Mean: 18.100  
Level Error: 0.0  
APS Indicator: False  
Gas Type Code: BALN,O2  
Vendor Identifier: F22020  
Cylinder #: SA11523  
Cylinder Exp. Date: 12/09/2028