

DEPARTMENT OF THE NAVY

NAVAL BASE VENTURA COUNTY 311 MAIN ROAD, SUITE 1 POINT MUGU, CA 93042-5033

20% FEB 12 PH 3: 16

A.P.C.D.

IN REPLY REFER TO 5090 Ser N0000CV/250091 January 31, 2025

Mr. Keith Macias Manager Compliance Division Ventura County Air Pollution Control District 4567 Telephone Road Ventura, CA 93003

Dear Mr. Macias:

SUBJECT: ANNUAL PART 70 PERMIT COMPLIANCE CERTIFICATIONS

Please find enclosures (1) to (3), Annual Compliance Certifications for Naval Base Ventura County's (NBVC) Part 70 Permit numbers 00997, 01006, and 01207. The enclosures document NBVC's Part 70 Permit compliance status for the reporting period of January 1, 2024 through December 31, 2024.

The Annual Compliance Certifications are being provided to fulfill the requirements stated in Condition 15, Section 10 of our Part 70 Permits. If you have any questions regarding the enclosed documents, please contact the Air Quality Program Manager, Mrs. Leticia Martin who can be reached at COMM: (805) 989-3556 or via email: leticia.martin3.civ@us.navy.

Sincerely,

D. W. BROWN Captain, U.S. Navy Commanding Officer

- Enclosures: 1. Annual Compliance Certification for Part 70 Permit Number 00997
 - 2. Annual Compliance Certification for Part 70 Permit Number 01006
 - 3. Annual Compliance Certification for Part 70 Permit Number 01207

			2
35.			

COMPLIANCE CERTIFICATION JANUARY 1, 2024 – DECEMBER 31, 2024

TITLE V FEDERAL OPERATING PERMIT PART 70 PERMIT NO. 01006

NAVAL BASE VENTURA COUNTY PORT HUENEME



For submittal to:

Ventura County Air Pollution Control District 4567 Telephone Rd Ventura, CA 93003 EPA Region IX 75 Hawthorne St. San Francisco, CA 94105 

ANNUAL COMPLIANCE CERTIFICATION SIGNATURE COVER FORM

TV Permit #	01006	

A copy of each Annual Compliance Certification shall be submitted to EPA, Region 9, at the following address:

Ms. Roshni Brahmbhatt
Enforcement & Compliance Enforcement Division
EPA Region 9
75 Hawthorne Street
San Francisco, CA 94105

Confidentiality

All information in a Part 70 permit compliance certification is public information. The Part 70 permit is also public information.

Certification by Responsible Official

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in this compliance certification are true, accurate, and complete.

Signature and Title of Responsible Official:	Date:
Title: Daniel W. Brown, Captain, U.S. Navy Commanding Officer, Naval Base Ventura County	AfeBiors

 e 8



D. Frequency of monitoring:

Period Covered by Compliance Certification: $\underline{01}$ / $\underline{01}$ / $\underline{24}$ (MM/DD/YY) to $\underline{12}$ / $\underline{31}$ / $\underline{24}$ (MM/DD/YY)

A. Attachment # or Permit Condition #: Attachment 70N3-01006- GOV-491, Condition No.

B. Description: General requirements of Rule 70, including requirements for pressure/vacuum relief valves	Periodic
at vent pipes, requirements for bulk transfers, and good operating practices as applicable to the Gasoline Dispensing Facility (GDF) at Building 5307	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
The tank has been out of service since September 29, 2023.	G. Compliance Status? (C or I): C
	H. *Excursions, exceedances, or
	other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form
	I B E
A. Attachment # or Permit Condition #: Attachment 70N3-01006- GOV-491, Condition No. 2	D. Frequency of monitoring:
B. Description: Phase I vapor recovery requirements as applicable to the GDF at Building 5307	Daily inspection of Phase I spill containment devices and annual inspection for the rest of requirements
Thase I vapor recovery requirements as approache to the GDF at Danishing	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable
	N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
The tank has been out of service since September 29, 2023.	G. Compliance Status? (C or I): C
a a	H. *Excursions, exceedances, or
	other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form
A. Attachment # or Permit Condition #: Attachment 70N3-01006- GOV-491, Condition Nos. 3.1 through 3.7	D. Frequency of monitoring:
B. Description:	Monthly for appropriate hose drape and good working order, and annually for the rest of the requirements
Phase II vapor recovery requirements (Conditions 3.1 through 3.7) as applicable to the GDF at Building 5307	
GDF at building 5507	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable
	N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
The tank has been out of service since September 29, 2023.	G. Compliance Status? (C or I): C
	H. *Excursions, exceedances, or
* X	other non compliance? (Y or N): N
	*If yes, attach Deviation Summary Form



A. Attachment # or Permit Condition #: Attachment 70N3-01006- GOV-491, Condition Nos. 3.8 through 3.10	D. Frequency of monitoring:
B. Description:	Periodic
Phase II vapor recovery requirements (Conditions 3.8 through 3.10) specific to the GDF at	T chould
Building 5307	E. Source test reference method, if applicable.
	Attach Source Test Summary Form, if applicable
	N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
The tank has been out of service since September 29, 2023.	G. Compliance Status? (C or I): C
	H. *Excursions, exceedances, or
	other non-compliance? (Y or N): <u>N</u>
	*If yes, attach Deviation Summary Form
A Attachment # or Permit Condition # Attach	7
A. Attachment # or Permit Condition #: Attachment 70N3-01006- GOV-491, Condition 3.11	D. Frequency of monitoring:
B. Description:	Daily
Requirement to perform daily inspection of hanging hardware at Building 5307 GDF	
	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
The tank has been out of service since September 29, 2023.	
	(,
	H. *Excursions, exceedances, or
	other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form
A. Attachment # or Permit Condition #: Attachment 70N3-01006- GOV-491, Condition No.	D. Frequency of monitoring:
B. Description:	Periodic
Requirement that Phase II vapor recovery system at the Building 5307 GDF be maintained	T Canada
and operated with none of the defects listed in California Code of Regulations Section 94006, Subchapter 8, Chapter 1, Part III, of Title 17, adopted 11/12/02 (Rule 70E.2) (4.1), and that defective equipment be tagged "Out of Order" (4.2)	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
The tank has been out of service since September 29, 2023.	G. Compliance Status? (C or I): C
<u> </u>	H. *Excursions, exceedances, or
	other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form



Period Covered by Compliance Certification: <u>01</u> / <u>01</u> / <u>24</u> (MM/DD/YY) to <u>12</u> / <u>31</u> / <u>24</u> (MM/DD/YY)

	3
A. Attachment # or Permit Condition #: Attachment 70N3-01006- GOV-491, Condition No. 5	D. Frequency of monitoring:
B. Description:	Periodic
Requirement that proper signs be posted at Building 5307 GDF as listed in Conditions 5.1 through 5.5	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
The tank has been out of service since September 29, 2023.	G. Compliance Status? (C or I): C
80	H. *Excursions, exceedances, or other non-compliance? (Y or N): N
74	
	*If yes, attach Deviation Summary Form
A AU	D. Fraguanay of manitoring
A. Attachment # or Permit Condition #: Attachment 70N3-01006- GOV-491, Condition No.	D. Frequency of monitoring:
B. Description:	Annual
Requirement to annually perform a static pressure performance test (TP-201.3b) and a	
dynamic Pressure Performance (TP-201.4) at the Building 5307 GDF	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
The tank has been out of service since September 29, 2023.	G. Compliance Status? (C or I): C
	H. *Excursions, exceedances, or
	other non-compliance? (Y or N): <u>N</u>
	*If yes, attach Deviation Summary Form
A. Attachment # or Permit Condition #: Attachment 70N3-01006- GOV-491, Condition No. 7.1	D. Frequency of monitoring:
B. Description:	periodic
Requirement for the Building 5307 GDF to keep records of tests performed on the vapor	
recovery systems	E. Source test reference method, if applicable.
	Attach Source Test Summary Form, if applicable N/A
	NO
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
The tank has been out of service since September 29, 2023.	G. Compliance Status? (C or I): C
	H ₁ *Excursions, exceedances, or
	other non-compliance? (Y or N): <u>N</u>
	*If yes, attach Deviation Summary Form



A. Attachment # or Permit Condition #: Attachment 70N3-01006- GOV-491, Condition No. 7.2	D. Frequency of monitoring:
B. Description:	Periodic
Requirement for the GDF at Building 5307 to keep records of all maintenance performed	
on the vapor recovery systems.	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
The tank has been out of service since September 29, 2023.	
	_
	H. *Excursions, exceedances, or
10	other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form
A. Attachment # or Permit Condition #: Attachment 70N3-01006- GOV-491, Condition	D Formula of the state of
Nos. 7.3	D. Frequency of monitoring:
B. Description:	Daily
Requirement for the GDF at Building 5307 to keep records of daily hanging hardware	
inspections on phase II vapor recovery systems	E. Source test reference method, if applicable.
	Attach Source Test Summary Form, if applicable
	N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
The tank has been out of service since September 29, 2023.	
	G. Compliance Status? (C or I): C
	H. *Excursions, exceedances, or
	other non-compliance? (Y or N): N
30	*If yes, attach Deviation Summary Form
A. Attachment # or Permit Condition #: Attachment 70N3-01006- GOV-491, Condition No.	
8	D. Frequency of monitoring:
B. Description:	As Needed
Requirement to submit an application prior to any major modification to the GDF at	
Building 5307 (8.1) and to pass all required vapor recovery tests within 45 days of modification (8.2)	E. Source test reference method, if applicable.
*	Attach Source Test Summary Form, if applicable
	N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
The tank has been out of service since September 29, 2023.	G. Compliance Status? (C or I): C
	, , _
	H. *Excursions, exceedances, or other non-compliance? (Y or N): N
	other non-compliance? (Y or N): N
	i o ves, angui Devianori Summary Form



D. Frequency of monitoring:

Period Covered by Compliance Certification: $\underline{01}$ / $\underline{01}$ / $\underline{24}$ (MM/DD/YY) to $\underline{12}$ / $\underline{31}$ / $\underline{24}$ (MM/DD/YY)

A. Attachment # or Permit Condition #: Attachment 70N3-01006-E85-491, Condition No. 1

B. Description:	Periodic		
General requirements of Rule 70, including requirements for pressure/vacuum relief valves at vent pipes, requirements for bulk transfers, and good operating practices as applicable to the E-85 fueling facility at Building 5307	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A		
C. Method of monitoring:	F. Currently in Compliance? (Y or N); Y		
All vent pipes are equipped with the appropriate pressure/vacuum relief valve. Proper operation of valves is verified annually at the time of the static pressure performance tests (1.1). All bulk transfers utilized a properly operating California Air Resources Board (CARB)-certified vapor recovery system (1.2). Good operating practices are ensured by periodic monitoring by the Naval Base Ventura County (NBVC) field operations team (1.3).	G. Compliance Status? (C or I): C H. *Excursions, exceedances, or other non-compliance? (Y or N): N *If yes, attach Deviation Summary Form		
	13		
A. Attachment # or Permit Condition #: Attachment 70N3-01006-E85-491, Condition No.	D. Frequency of monitoring:		
B. Description:	Annual		
Phase I vapor recovery requirement for a permanently installed submerged fill pipe which			
extends to within six inches of the tank bottom as applicable to the E-85 fueling facility at Building 5307	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A		
	IVA		
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y		
Presence of submerged fill in the form of a bottom-fed tank inlet is verified at the time of annual inspection and testing.	G. Compliance Status? (C or I): C		
	H. *Excursions, exceedances, or other non-compliance? (Y or N): N		
	*If yes, attach Deviation Summary Form		
A. Attachment # or Permit Condition #: Attachment 70N3-01006-E85-491, Condition Nos. 2.2 through 2.5	D. Frequency of monitoring:		
B. Description:	Periodic		
Phase I vapor recovery requirements as applicable to the E-85 fueling facility at Building			
5307	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A		
	,		
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y		
An uncertified Phase I vapor recovery system has been installed on E-85 fueling facility	G. Compliance Status? (C or I): C		
under CARB Research and Development (R&D) Authorization. E-85 fueling facility will use a CARB certified Phase I vapor recovery system when such a system is certified by	H. *Excursions, exceedances, or		
CARB.	other non-compliance? (Y or N): N		
	*If yes, attach Deviation Summary Form		



A. Attachment # or Permit Condition #: Attachment 70N3-01006-E85-491, Condition No. 2.6	D. Frequency of monitoring:
B. Description:	Daily
Requirement that standing E-85 fuel in Phase I spill containment device is prohibited at F-	
85 fueling facility at Building 5307	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
A daily inspection of E-85 fueling facility ensures that Phase I spill containment device is	=
clean and free of E-85 fuel.	G. Compliance Status? (C or I): C
	H. *Excursions, exceedances, or
_ ii	other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form
A. Attachment # or Permit Condition #: Attachment 70N3-01006-E85-491, Condition No. 3	D Fragues of a wife i
B. Description:	D. Frequency of monitoring:
-	As Needed
The requirement for a Phase II vapor recovery system does not apply to the E-85 fueling facility (3.1) because at least 95 percent of motor vehicles fueled there are equipped with Onboard Vehicle Vapor Recovery (ORVR) (3.2)	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
The E-85 fueling facility at NBVC Port Hueneme Building 5307 is not equipped with a Phase II vapor recovery system (3.1). All E-85 motor vehicles fueled at the facility are	G. Compliance Status? (C or I): C
equipped with ORVR as mandated by the United States Environmental Protection Agency for passenger cars manufactured after 2000 and light trucks manufactured after 2006 (3.2).	H. *Excursions, exceedances, or
(C. 2)	other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form
A. Attachment # or Permit Condition #: Attachment 70N3-01006 E85-491, Condition No. 4	T
	D. Frequency of monitoring:
B. Description: Requirement that proper signs be posted at Building 5307 E-85 fueling facility as listed in	Periodic
Conditions 4.1 through 4.5	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Periodic checks for proper signage are conducted by the NBVC Air Quality Program.	
Proper signage is also verified at the time of the annual compliance inspection.	(= = - , =
	H. *Excursions, exceedances, or
	other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form



Period Covered by Compliance Certification: 01 / 01 / 24 (MM/DD/YY) to 12 / 31 / 24 (MM/DD/YY)

A. Attachment # or Permit Condition #: Attachment 70N3-01006-E85-491, Condition No. 6.1	D. Frequency of monitoring:		
B. Description:	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A		
Requirement for E-85 fueling facility at Building 5307 to keep records of vehicle make, model year, identification number, license plate number, and a statement that an ORVR system is in place and functional for each vehicle fueled from the E-85 fuel tank			
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y		
All E-85 motor vehicles fueled at the facility are equipped with ORVR as mandated by the United States Environmental Protection Agency for passenger cars manufactured after	G. Compliance Status? (C or I): C		
2000 and light trucks manufactured after 2006.	H. *Excursions, exceedances, or		
	other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form		
	i yes, attach Deviation Summary Form		
A. Attachment # or Permit Condition #: Attachment 70N3-01006-E85-491, Condition Nos. 6.2 and 6.3	D. Frequency of monitoring:		
B. Description:	Periodic		
Requirement for the E-85 fueling facility at Building 5307 to keep records of all tests and			
maintenance performed on the vapor recovery systems	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A		
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y		
Records of all tests and maintenance of the vapor recovery system at the Building 5307 E-85 fueling facility are maintained by the Environmental Division Air Quality Program	G. Compliance Status? (C or I): C		
(EDAQP). Records contain the required elements and are reviewed periodically by the EDAQP staff. Appendix E includes the test results performed during this compliance	H. *Excursions, exceedances, or		
certification period.	other non-compliance? (Y or N): N *If yes, attach Deviation Summary Form		
	in yes, attach beviation cummary rom		
A. Attachment # or Permit Condition #: Attachment 70N3-01006-E85-491, Condition No. 7	D. Frequency of monitoring:		
B. Description: Requirement to submit an application prior to any major modification to the E-85 fueling	As Needed		
facility at Building 5307 (7.1) and to pass all required vapor recovery tests within 45 days of modification (7.2)	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A		
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y		
No major modification occurred at Building 5307 E-85 fueling facility during this reporting period.	G. Compliance Status? (C or I): C		
poriod.	H. *Excursions, exceedances, or		
	other non-compliance? (Y or N): N		
	*If yes, attach Deviation Summary Form		



A. Attachment # or Permit Condition #: Attachment 70-01006-Exchange-491,501, Condition No. 1	D. Frequency of monitoring:
B. Description:	Periodic
General requirements of Rule 70 and California Air Resources Board (CARB) Executive	
Order VR-202, including requirements for pressure/vacuum relief valves at vent pipes, requirements for bulk transfers, and good operating practices as applicable to Navy Exchange Gasoline Dispensing Facility (GDF).	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
All vent pipes are equipped with the appropriate pressure/vacuum relief valve (1.1), all bulk transfers utilized a properly operating CARB-certified vapor recovery system (1.2), and	G. Compliance Status? (C or I): C
good operating practices are ensured by periodic monitoring by the Naval Base Ventura County (NBVC) field operations team (1.3).	H. *Excursions, exceedances, or
County (NBVC) neid operations team (1.3).	other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form
A. Attachment # or Permit Condition #: Attachment 70-01006-Exchange-491,501, Condition No.2	D. Frequency of monitoring:
B. Description:	Daily inspection of Phase I spill containment devices
Phase I vapor recovery requirements as applicable to the Navy Exchange GDF	and vapor recovery equipment, and annual inspection for requirements 2.1, 2.2, and 2.4.
2	E. Source test reference method, if applicable.
	Attach Source Test Summary Form, if applicable
	N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Presence and length of submerged fill pipes (2.1) are verified at the time of annual inspection and testing. The Navy Exchange GDF employs a permanently installed, CARB	G. Compliance Status? (C or I): C
Certified, Phase I EVR (2.2) equipped with CARB certified poppetted drybreaks (2.4) as required. Lack of leaks (2.3) is ensured during annual static pressure performance tests. A	H. *Excursions, exceedances, or
daily inspection of Phase I spill containment devices ensures that the containment devices	other non-compliance? (Y or N): <u>N</u>
are clean and free of gasoline (2.5).	*If yes, attach Deviation Summary Form
A AU 1	
A. Attachment # or Permit Condition #: Attachment 70-01006-Exchange-491,501, Condition No. 3	D. Frequency of monitoring:
B. Description:	Daily inspection of hanging hardware and annual inspection for the rest of the requirements
Phase II vapor recovery requirements as applicable to the Navy Exchange GDF	E. Source test reference method, if applicable.
	Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Presence of CARB-certified Phase II system was verified at the time of installation (3.1). "Good working order" and the absence of leaks (3.3) are verified by the annual pressure	G. Compliance Status? (C or I): <u>I</u>
performance tests. All vapor and liquid lines are gravity drained to the USTs as required	H. *Excursions, exceedances, or
(3.4). The presence of clearly marked components (3.2), UL listed riser hoses (3.5); insertion interlocks (3.6); coaxial vapor recovery hoses (3.7); and clean air separator (3.9)	other non-compliance? (Y or N): Y
are verified at the time of the annual inspections. Vapor to Liquid Volume Ratio Test was performed on 11/14/2024 (3.8). The annual compliance inspection revealed a failure in	*If yes, attach Deviation Summary Form
Vapor to Liquid Ratio test at fueling point numbers 1, 3, 4, 5, and 10 in accordance with Rule 70.E.1. NOV #25211 was issued. Repairs were made the same day and later passed	
the test. Hanging hardware on Phase II EVR system is inspected daily by Navy Exchange	*



ANNUAL COMPLIANCE CERTIFICATION DEVIATION SUMMARY FORM

Period Covered by Compliance Certification: 01 / 01 / 24 (MM/DD/YY) to 12 / 31 / 24 (MM/DD/YY)

A. Attachment # or Permit Condition #:	B. Equipment description:		C. Deviation Period: Date & Time
70-01006-Exchange-491,501, Condition No. 3.8	Healy Phase II EVR system	1	Begin: November 14, 2024, at 1400
140. 0.0			End: November 14, 2024, at 1644
General Part 70 Permit			When Discovered: Date & Time
			November 14, 2024, at 1400
D. Parameters monitored: E. Limit:			F. Actual:
The vapor to liquid (V/L) ratio of the system on fueling point numbers 1, 3, 4, 5, and 10	and operated in the same m	quipment shall be maintained	Fueling point numbers 1, 3, 4, 5, and 10 were not maintained and operated in the same manner as when certified by CARB.
G. Probable Cause of Deviation:		H. Corrective actions taken:	
Failure of the V/L ratio testing is due to unknown circumstances.		V/L ratio at Port Hueneme Navy Exchange Gas Station initially failed. The hoses were replaced on fueling points numbers 1, 3, 4, 5, and 10 during the inspection and the test later passed. NOV #25211 was issued.	



A, Attachment # or Permit Condition #: Attachment 70-01006-Exchange-491,501,	D. Frequency of monitoring:
Condition No. 4	
B. Description:	Periodic
Requirement that Phase II vapor recovery systems at the Navy Exchange GDF be	
operated with none of the defects listed in the California Code of Regulations Section 94006, Subchapter 8, Chapter 1, Part III, of Title 17 (4.1) and that defective equipment be	E. Source test reference method, if applicable.
tagged "out of order" and not operated per Condition 4.2.	Attach Source Test Summary Form, if applicable
C. Method of monitoring:	N/A
	F. Currently in Compliance? (Y or N): Y
Proper ongoing maintenance of the Navy Exchange GDF is ensured by the GDF manager. Periodic checks for proper GDF maintenance are conducted by the Environmental Division	G. Compliance Status? (C or I): C
Air Quality Program (EDAQP) staff. Proper maintenance is also verified at the time of the annual compliance inspection. None of the defects listed in California Code of Regulations	H. *Excursions, exceedances, or
Section 94006, Subchapter 8, Chapter 1, Part III, of Title 17 were found to exist at the	other non-compliance? (Y or N): N
Navy Exchange GDF during inspections (4.1). Any defective equipment found during daily maintenance inspections carried out by the GDF staff is tagged "out of order" and not	*If yes, attach Deviation Summary Form
operated until repaired as required (4.2).	
A. Attachment # or Permit Condition #: Attachment 70-01006-Exchange-491,501, Condition No. 5	D. Frequency of monitoring:
B. Description:	Periodic
Requirement that proper signs be posted at the Navy Exchange GDF as listed in	
Conditions 5.1 through 5.5	E. Source test reference method, if applicable.
	Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Periodic checks for proper signage are conducted by the EDAQP. Proper signage is also	
verified at the time of the annual compliance inspection.	G. Compliance Status? (C or I): C
2	H. *Excursions, exceedances, or
	other non-compliance? (Y or N): N
	^If yes, attach Deviation Summary Form
A Attachment # or Permit Condition # Attachment 70 04000 F	
A. Attachment # or Permit Condition #: Attachment 70-01006-Exchange-491,501, Condition Nos. 6.1 through 6.6	D. Frequency of monitoring:
B. Description:	Annual
Requirement to perform a Static Pressure Performance Test (TP-201.3), Determination of	
Static Pressure Performance of the Healy Clean Air Separator Test (Exhibit 4), Vapor to Liquid Volume Ratio for Healy including Veeder-Root ISD Test (Exhibit 5), ISD Operability	E. Source test reference method, if applicable.
Test Procedure (Exhibit 9), and Dynamic Back Pressure Test (TP-201 4) annually at the	Attach Source Test Summary Form, if applicable
Navy Exchange GDF	N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
The most recent tests at the Navy Exchange GDF were performed and passed on (11/14/2024). The district was notified and test results submitted per rule	G. Compliance Status? (C or I): C
requirements. Appendix E includes the results of the gas station testing during this	H. *Excursions, exceedances, or
compliance certification period.	other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form



D. Frequency of monitoring:

Period Covered by Compliance Certification: $\underline{01}$ / $\underline{01}$ / $\underline{24}$ (MM/DD/YY) to $\underline{12}$ / $\underline{31}$ / $\underline{24}$ (MM/DD/YY)

A, Attachment # or Permit Condition #: Attachment 70-01006-Exchange-491,501,

Condition No. 6.7	
B. Description:	Every three years
Requirement to perform the following tests once every three years: Determination of 2 Inch WC Static Pressure Performance of Vapor Recovery Systems of Dispensing Facilities (TP-201.3), Static Torque of Rotatable Phase I Adaptors (TP-201.1B), Leak Rate of Drop Tube/Drain Valve Assembly (TP-201.1C), and Leak Rate and Cracking Pressure of Pressure/Vacuum Vent Valves (TP-201.1E)	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
The most recent tests at the Navy Exchange GDF were performed and passed on 11/28/2023. The District was notified and test results submitted per rule requirements.	G. Compliance Status? (C or I): C
11/20/2020. The bibliot was notified and toot results of the province of the bibliot was notified and toot results of the bibliot was not find an analysis of the bibl	H. *Excursions, exceedances, or
	other non-compliance? (Y or N): <u>N</u>
#	*If yes, attach Deviation Summary Form
A. Attachment # or Permit Condition #: Attachment 70-01006-Exchange-491,501, Condition No. 7.1	D. Frequency of monitoring:
B. Description:	Periodic
Requirement for the Navy Exchange GDF to keep records of tests performed on the vapor	
recovery systems	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable
	N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Records of tests of the vapor recovery systems at the Navy Exchange GDF are maintained by the EDAQP. Appendix E includes the results of the gas station testing during this	G. Compliance Status? (C or I): C
compliance certification period.	H. *Excursions, exceedances, or
	other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form
A. Attachment # or Permit Condition #: Attachment 70-01006-Exchange-491,501,	D. Frequency of monitoring:
Condition No. 7.2	Periodic
B. Description:	
Requirement for the Navy Exchange GDF to keep records of all maintenance performed on the vapor recovery systems	E. Source test reference method, if applicable.
U.	Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Records of all maintenance of the vapor recovery system at the Navy Exchange GDF are maintained by the station manager. Records contain the required elements and are	G. Compliance Status? (C or I): C
reviewed periodically by the EDAQP staff.	H. *Excursions, exceedances, or
	other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form



A. Attachment # or Permit Condition #: Attachment 70-01006-Exchange-491,501, Condition No. 7.3	D. Frequency of monitoring:
B. Description:	Daily
Requirement for the Navy Exchange GDF to keep records of daily hanging hardware inspections	
inspections	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Records of all daily hanging hardware inspections are kept at the Navy Exchange GDF and reviewed routinely by EDAQP staff.	G. Compliance Status? (C or I): C
	H. *Excursions, exceedances, or
	other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form
A. Attachment # or Permit Condition #: Attachment 70-01006-Exchange-491,501,	
Condition No. 8	D. Frequency of monitoring:
B. Description:	As Needed
Requirement to submit an application prior to any major modification to the Navy Exchange GDF (8.1) and to pass all required vapor recovery tests within 45 days of modification (8.2)	
(8.2)	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable.

A. Attachment # or Permit Condition #: Attachment 70-01006-Exchange-491,501, Condition No. 8	D. Frequency of monitoring:
B. Description:	As Needed
Requirement to submit an application prior to any major modification to the Navy Exchange	
GDF (8.1) and to pass all required vapor recovery tests within 45 days of modification (8.2)	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
No major modification was performed at the Navy Exchange GDF during this compliance certification period.	G. Compliance Status? (C or I): C
	H. *Excursions, exceedances, or other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form



B. Description:

A. Attachment # or Permit Condition #: Attachment 74.6, Condition No. 1

Surface Cleaning and Degreasing -- Solvent ROC and/or Vapor Pressure

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Periodic

D. Frequency of monitoring:

Period Covered by Compliance Certification: 01 / 01 / 24 (MM/DD/YY) to 12 / 31 / 24 (MM/DD/YY)

	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable
	N/A
s	i
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Compliance with ROC and vapor pressure limits is ensured by the fact that all solvents must be approved by Environmental Division Air Quality Program (EDAQP) staff before	G. Compliance Status? (C or I): C
they can be issued and used by any Naval Base Ventura County (NBVC) entity or tenant organization aboard NBVC.	H. *Excursions, exceedances, or
	other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form
A. Attachment # or Permit Condition #: Attachment 74.6, Condition Nos. 2 through 7	D. Frequency of monitoring:
B. Description:	Periodic
Conditions relating to solvent handling procedures	E. Source test reference method, if applicable.
	Attach Source Test Summary Form, if applicable
	N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Compliance with Conditions 2 through 7 of Attachment 74.6 is verified by means of routine surveillance of solvent activities that are carried out by EDAQP staff.	G. Compliance Status? (C or I): <u>C</u>
	H. *Excursions, exceedances, or
	other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form
A. Attachment # or Permit Condition #: Attachment 74.6, Condition No. 8	D. Frequency of monitoring:
B. Description:	
Equipment and work practice requirements applicable to all cold cleaners (except remote	Routine
reservoir type) Measurement of freeboard height, verification of initial boiling point, ROC content, and ROC composite partial pressure	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
	E Oursette is Osmalianas O
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Routine inspection of solvent activities that are carried out by EDAQP staff confirmed that no non-remote reservoir cold cleaners exist.	G. Compliance Status? (C or I): C
	H. *Excursions, exceedances, or
	other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form



A. Attachment # or Permit Condition #: Attachment 74.6, Condition No. 9

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

D. Frequency of monitoring:

B. Description: Equipment and work practice standards as applicable to remote reservoir cold cleaners	Routine	
Measurement of freeboard height, verification of initial boiling point, ROC content, and ROC composite partial pressure	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A	
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y	
It has been determined that all remote reservoir cold cleaners have either been removed from service or replaced with units that use either aqueous cleaning solutions or non-ROC	G. Compliance Status? (C or I): C	
solvents.	H _□ *Excursions, exceedances, or	
	other non-compliance? (Y or N): N	
	*If yes, attach Deviation Summary Form	
A Attachment # or Permit Condition # Attachment 74.0.0 and the state		
A. Attachment # or Permit Condition #: Attachment 74.6, Condition No. 10	D. Frequency of monitoring:	
B, Description:	Periodic	
Conditions related to cold cleaning operation		
	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable	
	N/A	
C. Mothod of maritadian.		
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y	
Compliance with Condition 10 of Attachment 74.6 is verified by means of routine surveillance carried out by EDAQP staff.	F. Currently in Compliance? (Y or N): Y G. Compliance Status? (C or I): C	
Compliance with Condition 10 of Attachment 74.6 is verified by means of routine	G. Compliance Status? (C or I): C H. *Excursions, exceedances, or	
Compliance with Condition 10 of Attachment 74.6 is verified by means of routine	G. Compliance Status? (C or I): C	
Compliance with Condition 10 of Attachment 74.6 is verified by means of routine	G. Compliance Status? (C or I): C H. *Excursions, exceedances, or	
Compliance with Condition 10 of Attachment 74.6 is verified by means of routine surveillance carried out by EDAQP staff.	G. Compliance Status? (C or I): C H. *Excursions, exceedances, or other non-compliance? (Y or N): N *If yes, attach Deviation Summary Form	
Compliance with Condition 10 of Attachment 74.6 is verified by means of routine surveillance carried out by EDAQP staff. A. Attachment # or Permit Condition #: Attachment 74.6, Condition Nos. 14 and 16	G. Compliance Status? (C or I): C H. *Excursions, exceedances, or other non-compliance? (Y or N): N	
Compliance with Condition 10 of Attachment 74.6 is verified by means of routine surveillance carried out by EDAQP staff. A. Attachment # or Permit Condition #: Attachment 74.6, Condition Nos. 14 and 16 B. Description:	G. Compliance Status? (C or I): C H. *Excursions, exceedances, or other non-compliance? (Y or N): N *If yes, attach Deviation Summary Form	
Compliance with Condition 10 of Attachment 74.6 is verified by means of routine surveillance carried out by EDAQP staff. A. Attachment # or Permit Condition #: Attachment 74.6, Condition Nos. 14 and 16 B. Description: Recordkeeping requirements associated with surface cleaning and degreasing and routine	G. Compliance Status? (C or I): C H. *Excursions, exceedances, or other non-compliance? (Y or N): N *If yes, attach Deviation Summary Form D. Frequency of monitoring:	
Compliance with Condition 10 of Attachment 74.6 is verified by means of routine surveillance carried out by EDAQP staff. A. Attachment # or Permit Condition #: Attachment 74.6, Condition Nos. 14 and 16 B. Description:	G. Compliance Status? (C or I): C H. *Excursions, exceedances, or other non-compliance? (Y or N): N *If yes, attach Deviation Summary Form D. Frequency of monitoring: Periodic E. Source test reference method, if applicable.	
Compliance with Condition 10 of Attachment 74.6 is verified by means of routine surveillance carried out by EDAQP staff. A. Attachment # or Permit Condition #: Attachment 74.6, Condition Nos. 14 and 16 B. Description: Recordkeeping requirements associated with surface cleaning and degreasing and routine	G. Compliance Status? (C or I): C H. *Excursions, exceedances, or other non-compliance? (Y or N): N *If yes, attach Deviation Summary Form D. Frequency of monitoring: Periodic	
Compliance with Condition 10 of Attachment 74.6 is verified by means of routine surveillance carried out by EDAQP staff. A. Attachment # or Permit Condition #: Attachment 74.6, Condition Nos. 14 and 16 B. Description: Recordkeeping requirements associated with surface cleaning and degreasing and routine surveillance to comply with Rule 74.6	G. Compliance Status? (C or I): C H. *Excursions, exceedances, or other non-compliance? (Y or N): N *If yes, attach Deviation Summary Form D. Frequency of monitoring: Periodic E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A	
Compliance with Condition 10 of Attachment 74.6 is verified by means of routine surveillance carried out by EDAQP staff. A. Attachment # or Permit Condition #: Attachment 74.6, Condition Nos. 14 and 16 B. Description: Recordkeeping requirements associated with surface cleaning and degreasing and routine surveillance to comply with Rule 74.6 C. Method of monitoring:	G. Compliance Status? (C or I): C H. *Excursions, exceedances, or other non-compliance? (Y or N): N *If yes, attach Deviation Summary Form D. Frequency of monitoring: Periodic E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A F. Currently in Compliance? (Y or N): Y	
Compliance with Condition 10 of Attachment 74.6 is verified by means of routine surveillance carried out by EDAQP staff. A. Attachment # or Permit Condition #: Attachment 74.6, Condition Nos. 14 and 16 B. Description: Recordkeeping requirements associated with surface cleaning and degreasing and routine surveillance to comply with Rule 74.6 C. Method of monitoring: Compliance with the requirement to maintain a current material list showing the name, ROC and vapor pressure, and intended uses of each solvent material is accomplished by	G. Compliance Status? (C or I): C H. *Excursions, exceedances, or other non-compliance? (Y or N): N *If yes, attach Deviation Summary Form D. Frequency of monitoring: Periodic E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A	
Compliance with Condition 10 of Attachment 74.6 is verified by means of routine surveillance carried out by EDAQP staff. A. Attachment # or Permit Condition #: Attachment 74.6, Condition Nos. 14 and 16 B. Description: Recordkeeping requirements associated with surface cleaning and degreasing and routine surveillance to comply with Rule 74.6 C. Method of monitoring: Compliance with the requirement to maintain a current material list showing the name, ROC and vapor pressure, and intended uses of each solvent material is accomplished by means of a database that records each issuance of a solvent material at NBVC Port	G. Compliance Status? (C or I): C H. *Excursions, exceedances, or other non-compliance? (Y or N): N *If yes, attach Deviation Summary Form D. Frequency of monitoring: Periodic E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A F. Currently in Compliance? (Y or N): Y	
Compliance with Condition 10 of Attachment 74.6 is verified by means of routine surveillance carried out by EDAQP staff. A. Attachment # or Permit Condition #: Attachment 74.6, Condition Nos. 14 and 16 B. Description: Recordkeeping requirements associated with surface cleaning and degreasing and routine surveillance to comply with Rule 74.6 C. Method of monitoring: Compliance with the requirement to maintain a current material list showing the name, ROC and vapor pressure, and intended uses of each solvent material is accomplished by	G. Compliance Status? (C or I): C H. *Excursions, exceedances, or other non-compliance? (Y or N): N *If yes, attach Deviation Summary Form D. Frequency of monitoring: Periodic E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A F. Currently in Compliance? (Y or N): Y G. Compliance Status? (C or I): C	



B. Description:

A. Attachment # or Permit Condition #: Attachment 74.6.1, Condition No. 1

Requirement that the batch loaded vapor degreaser be equipped with specific mechanical

ANNUAL COMPLIANCE CERTIFICATION PERMIT ATTACHMENT FORM

Periodic

D. Frequency of monitoring:

Period Covered by Compliance Certification: 01 / 01 / 24 (MM/DD/YY) to 12 / 31 / 24 (MM/DD/YY)

and administrative controls designed to limit emissions.	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
The batch loaded vapor degreaser is equipped with a primary condenser and	G. Compliance Status? (C or I): C
circumferential trough (a), a water separator (c), a snug fitting cover (d), a high vapor cutoff thermostat (e), a pump spray control switch (f), and a condenser water flow switch (g).	H. *Excursions, exceedances, or
The freeboard ratio is 1.25 (b), a General Operation Guideline is posted on the machine (h). Periodic inspection of the vapor degreaser confirms that the degreaser is in	other non-compliance? (Y or N): N
compliance with the Condition 1 requirement.	*If yes, attach Deviation Summary Form
	D. Francisco de maritarione
A. Attachment # or Permit Condition #: Attachment 74.6.1, Condition Nos. 2 Through 15	D. Frequency of monitoring:
B. Description:	Periodic
Conditions for operating the batch loaded vapor degreaser	
	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable
•	N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
The General Operation Guidelines for the vapor degreaser includes instructions which follow the requirements of Conditions 2 through 15 of Attachment 74.6.1. These	G. Compliance Status? (C or I): <u>C</u>
requirements are also verified by means of routine surveillance of solvent activities that are carried out by EDAQP personnel.	H. *Excursions, exceedances, or
carried out by EDAGE possession.	other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form
A. Attachment # or Permit Condition #: Attachment 74.6.1, Condition No. 16	D. Frequency of monitoring:
B. Description	Routine
Recordkeeping requirement conditions	rodine
	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable
	N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
The volume of solvent is recorded each time solvent is added to or removed from the degreaser. These records are reported to the EDAQP on a monthly basis.	G. Compliance Status? (C or I): C
	H. *Excursions, exceedances, or
	other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form



A. Attachment # or Permit Condition #: Attachment 74.9N7, Condition No. 1	D. Frequency of monitoring:		
B. Description:	Monthly		
Requirement that emergency standby stationary internal combustion engines shall be operated only during an emergency, or for maintenance operation not to exceed 50 hours per year	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable		
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y		
Base-wide Instructions prohibit the use of emergency generators for "non-emergency" purposes. An investigation into the hours of operation of all emergency standby stationary internal combustion engines greater than 50 BHP is performed monthly. Logs maintained at each engine are reviewed regularly. Hour meter readings are recorded before and after each maintenance operation, typically 0.25 hours, once per month. Any additional operation events are readily apparent upon review of the logs. All such events are further investigated to verify that they were the result of an emergency. In addition, EDAQP is notified by Public Works of all planned maintenance of the power distribution system and construction of power distribution system prior to the maintenance.	G. Compliance Status? (C or I): C H. *Excursions, exceedances, or other non-compliance? (Y or N): N *If yes, attach Deviation Summary Form		
A. Attachment # or Permit Condition #: 74.9N7, Condition No. 2	D. Frequency of monitoring;		
B. Description: Requirement that each emergency standby engine shall be equipped with an operating,	Monthly		
non-resettable, elapsed-time hour meter	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A		
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y		
All emergency engines are equipped with operating, non-resettable, elapsed-time hour meters. Breakdown of a non-resettable digital hour meter due to a battery malfunction	G. Compliance Status? (C or I): <u>I</u>		
occurred for emergency standby engine 435 BHP, Cummins Model NT855G6, Serial No 30346676 located at Bldg. 382. The failed non-resettable digital hour meter was removed	H. *Excursions, exceedances, or		
and replaced with a new non-resettable digital hour meter. Observations indicate no further discrepancies.	other non-compliance? (Y or N): Y		
9	*If yes, attach Deviation Summary Form		
A. Attachment # or Permit Condition #: Attachment 74.9N7, Condition Nos. 3 and 4	D. Frequency of monitoring:		
B. Description:	Annually		
Requirement that engine operating hours for maintenance be reported annually. The report must also include engine manufacturer, engine model number, operator identification number, and location. In addition, the specified report must accompany the Annual Compliance Certification	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A		
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y		
Engine operating hours for maintenance is reported to the District annually. A formatted	0.000		
report detailing annual maintenance operating hours for each engine has been included in Appendix-C of this Compliance Certification as required.	(=/-		
	H. *Excursions, exceedances, or other non-compliance? (Y or N): N		
	other non-compliance? (Y or N): N *If yes, attach Deviation Summary Form		
	in yes, attach Deviation Summary Form		



ANNUAL COMPLIANCE CERTIFICATION DEVIATION SUMMARY FORM

Period Covered by Compliance Certification: 01/01/24 (MM/DD/YY) to 12/31/24 (MM/DD/YY)

A. Attachment # or Permit Condition #: 74.9N7, Condition No. 2; ATCM Engine N2, Condition No. 2 and 3(a&b); 40CFR63ZZZZN3, Condition No. 3; General Part 70 Permit	B. Equipment description: Emergency Standby Engin Model NT855G6, Serial No 382		C. Deviation Period: Date & Time Begin: September 30, 2024, at 0942 End: October 1, 2024 at 0700 When Discovered: Date & Time September 30, 2024, at 0942
D. Parameters monitored: Requirement that each emergency standby engine shall be equipped with an operating, non-resettable, elapsed-time hour meter	E. Limit: Maintain operating, non-res meter	settable, elapsed-time hour	F. Actual: Failure of a non-resettable, elapsed-time hour meter.
G. Probable Cause of Deviation: Breakdown of a non-resettable digital homalfunction occurred.	our meter due to a battery	meter was removed and repi meter. NBVC monitored the indicate no further discrepan recordkeeping. Notification w	breakdown, the failed non-resettable digital hour laced with a new non-resettable digital hour efficacy of the completed repairs. Observations cies. Facts of this matter were documented for was made to notifications@vacapcd.org covery and 10/7/2024 for corrective actions



A. Attachment # or Permit Condition #: Attachment ATCM Engine N2, Condition Nos. 1 and 3c	D. Frequency of monitoring:
B. Description:	Periodic
Non-federally enforceable requirement to use only California Air Resources Board (CARB)	A.
diesel fuel in emergency standby stationary CI engines(1) and provide documentation supporting such use(3c)	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
All diesel fuel combusted in stationary emergency standby engines at Naval Base Ventura County (NBVC) during the compliance period was supplied by the NBVC Supply	G. Compliance Status? (C or I): C
Department, Fuel Branch. All diesel fuel received by the Supply Department, Fuel Branch, is CARB certified. Data demonstrating the use of CARB-Certified fuel is provided in Appendix A.	H. *Excursions, exceedances, or other non-compliance? (Y or N): N *If yes, attach Deviation Summary Form
A. Attachment # or Permit Condition #: Attachment ATCM Engine N2, Conditions No. 2, 3a, and 3b	D. Frequency of monitoring:
B. Description:	Periodic
Non-federally enforceable requirement that as of January 1, 2006, annual hours of operation for maintenance and testing of the emergency engine(s) not to exceed 20 hours per year. Also, requirement to equip engine(s) with a non-resettable hour meter and maintain a log that differentiates operation during maintenance and testing from emergency use. In addition, the operational hours of each engine shall be summarized by use (emergency or maintenance/testing) on a monthly basis and compiled into a 12-month rolling-sum report	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C, Method of monitoring:	F. Currently in Compliance? (Y or N): Y
All stationary emergency standby engines at NBVC are equipped with non-resettable hour meters. Hours of maintenance and emergency use are recorded for each engine on a	G. Compliance Status? (C or I): <u>I</u>
monthly basis and summarized into 12-month rolling-sum reports as required. Breakdown of a non-resettable digital hour meter due to a battery malfunction occurred for emergency standby engine 435 BHP, Cummins Model NT855G6, Serial No 30346676 located at	H. *Excursions, exceedances, or other non-compliance? (Y or N): Y
Bldg. 382. The falled non-resettable digital hour meter was removed and replaced with a new non-resettable digital hour meter. Observations indicate no further discrepancies.	*If yes, attach Deviation Summary Form



ANNUAL COMPLIANCE CERTIFICATION DEVIATION SUMMARY FORM

Period Covered by Compliance Certification: 01 / 01 / 24 (MM/DD/YY) to 12 / 31 / 24 (MM/DD/YY)

A. Attachment # or Permit Condition #: 74.9N7, Condition No. 2; ATCM Engine N2, Condition No. 2 and 3(a&b); 40CFR63ZZZZN3, Condition No. 3; General Part 70 Permit	B. Equipment description: Emergency Standby Engin Model NT855G6, Serial No 382		C. Deviation Period: Date & Time Begin: September 30, 2024, at 0942 End: October 1, 2024 at 0700 When Discovered: Date & Time September 30, 2024, at 0942
D. Parameters monitored: Requirement that each emergency standby engine shall be equipped with an operating, non-resettable, elapsed-time hour meter.	E. Limit: Maintain operating, non-res meter	settable, elapsed-time hour	F. Actual: Failure of a non-resettable, elapsed-time hour meter.
G. Probable Cause of Deviation: Breakdown of a non-resettable digital homalfunction occurred.	our meter due to a battery	meter was removed and rep meter. NBVC monitored the indicate no further discrepan recordkeeping. Notification v	breakdown, the failed non-resettable digital hour laced with a new non-resettable digital hour efficacy of the completed repairs. Observations icies. Facts of this matter were documented for was made to notifications@vacapcd.org



A. Attachment # or Permit Condition #: Attachment ATCM Engine N4, Condition Nos. 1 and 4c	D. Frequency of monitoring:	
B. Description:	Periodic	
Non-federally enforceable requirement to use only California Air Resources Board (CARB) diesel fuel in emergency standby stationary compression ignition engines(1) and provide documentation supporting such use(4c)	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable	
	N/A	
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y	
All diesel fuel combusted in stationary emergency standby engines at Naval Base Ventura County (NBVC) during the compliance period was supplied by the NBVC Supply	G. Compliance Status? (C or I): C	
Department, Fuel Branch. All diesel fuel received by the Supply Department, Fuel Branch, is CARB certified. Data demonstrating the use of CARB-Certified fuel is provided in	H. *Excursions, exceedances, or	
Appendix A.	other non-compliance? (Y or N): N	
	*If yes, attach Deviation Summary Form	
A Attachment # or Permit Condition # Attachment ATOM F : NA CO. W.		
A. Attachment # or Permit Condition #: Attachment ATCM Engine N4, Condition Nos. 2 and 4(a&b)	D. Frequency of monitoring:	
B. Description:	Periodic	
Non-federally enforceable requirement to equip emergency standby stationary compression ignition engines with hour meters and limit the number of hours these engines	ç	
are operated for maintenance and testing to no more than 50 hours during any 12- month period. In addition, the operational hours of each engine shall be summarized by use (emergency or maintenance/testing) on a monthly basis and compiled into a 12-month	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A	
rolling-sum report		
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y	
All stationary emergency standby engines at NBVC are equipped with non-resettable hour meters. Hours of maintenance and emergency use are recorded for each engine on a	G. Compliance Status? (C or I): C	
monthly basis and summarized into 12-month rolling-sum reports as required.	H. *Excursions, exceedances, or	
	other near compliance O	
	other non-compliance? (Y or N): N	
	*If yes, attach Deviation Summary Form	
A Attachment # or Permit Condition #: Attachment ATCM Engine NA Condition No. 0	*If yes, attach Deviation Summary Form	
A. Attachment # or Permit Condition #: Attachment ATCM Engine N4, Condition No. 3		
B. Description:	*If yes, attach Deviation Summary Form	
B. Description: Non-federally enforceable requirement that all "in-use" emergency standby stationary compression ignition engines subject to this rule to be EPA/CARB certified to meet the	*If yes, attach Deviation Summary Form D. Frequency of monitoring: Ensured at ATC application submittal E. Source test reference method, if applicable.	
B. Description: Non-federally enforceable requirement that all "in-use" emergency standby stationary.	*If yes, attach Deviation Summary Form D. Frequency of monitoring: Ensured at ATC application submittal E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable	
B. Description: Non-federally enforceable requirement that all "in-use" emergency standby stationary compression ignition engines subject to this rule to be EPA/CARB certified to meet the particulate matter standard of 0.15 grams/BHP-hr	*If yes, attach Deviation Summary Form D. Frequency of monitoring: Ensured at ATC application submittal E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A	
B. Description: Non-federally enforceable requirement that all "in-use" emergency standby stationary compression ignition engines subject to this rule to be EPA/CARB certified to meet the particulate matter standard of 0.15 grams/BHP-hr C. Method of monitoring:	*If yes, attach Deviation Summary Form D. Frequency of monitoring: Ensured at ATC application submittal E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable	
B. Description: Non-federally enforceable requirement that all "in-use" emergency standby stationary compression ignition engines subject to this rule to be EPA/CARB certified to meet the particulate matter standard of 0.15 grams/BHP-hr	*If yes, attach Deviation Summary Form D. Frequency of monitoring: Ensured at ATC application submittal E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A F. Currently in Compliance? (Y or N): Y G. Compliance Status? (C or I): C	
B. Description: Non-federally enforceable requirement that all "in-use" emergency standby stationary compression ignition engines subject to this rule to be EPA/CARB certified to meet the particulate matter standard of 0.15 grams/BHP-hr C. Method of monitoring: All "in-use" emergency standby stationary compression ignition engines subject to this rule.	*If yes, attach Deviation Summary Form D. Frequency of monitoring: Ensured at ATC application submittal E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A F. Currently in Compliance? (Y or N): Y G. Compliance Status? (C or I): C H. *Excursions, exceedances, or	
B. Description: Non-federally enforceable requirement that all "in-use" emergency standby stationary compression ignition engines subject to this rule to be EPA/CARB certified to meet the particulate matter standard of 0.15 grams/BHP-hr C. Method of monitoring: All "in-use" emergency standby stationary compression ignition engines subject to this rule.	*If yes, attach Deviation Summary Form D. Frequency of monitoring: Ensured at ATC application submittal E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A F. Currently in Compliance? (Y or N): Y G. Compliance Status? (C or I): C	



Period Covered by Compliance Certification: 01 / 01 / 24 (MM/DD/YY) to 12 / 31 / 24 (MM/DD/YY)

A. Attachment # or Permit Condition #: Attachment ATCM Engine N5, Condition Nos. 1 and 4c	D. Frequency of monitoring:
B. Description:	Periodic
Non-federally enforceable requirement to use only California Air Resources Board (CARB) diesel fuel in emergency standby stationary CI engines installed after January 1, 2005 (1)	
and provide documentation supporting such use(4)	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable
and the second second	N/A
	α
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
All diesel fuel combusted in stationary emergency standby engines at Naval Base Ventura County (NBVC) during the compliance period was supplied by the NBVC Supply	G. Compliance Status? (C or I): C
Department, Fuel Branch, All diesel fuel received by the Supply Department, Fuel Branch,	H. *Excursions, exceedances, or
is CARB certified. Data demonstrating the use of CARB-Certified fuel is provided in Appendix A.	other non-compliance? (Y or N): N
0	*If yes, attach Deviation Summary Form
- De	
A. Attachment # or Permit Condition #: Attachment ATCM Engine N5, Condition No. 2	D. Frequency of monitoring:
B. Description:	Monthly
Non-federally enforceable requirement that all emergency standby stationary CI engines	
installed after January 1, 2005 be EPA/CARB certified to meet the particulate matter emission standard of 0.15 grams/BHP-hr	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable
	N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
All stationary emergency standby engines installed after January 1, 2005 at NBVC are CARB certified as required. Certification documents are available upon request.	G. Compliance Status? (C or I): C
OAINE CEITINES as required. Certification accuments are available aport request.	H. *Excursions, exceedances, or
a · · · · · · · ·	other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form
A. Attachment # or Permit Condition #: Attachment ATCM Engine N5, Conditions No. 3, 4.a, and 4.b	D. Frequency of monitoring:
B. Description:	Ensured at ATC application submittal
Non-federally enforceable requirement to equip emergency standby stationary CI engines	
installed after January 1, 2005 with hour meters and limit the number of hours these engines are operated for maintenance and testing to no more than 50 hours during any 12-	E. Source test reference method, if applicable.
month period. In addition, the operational hours of each engine shall be summarized by	Attach Source Test Summary Form, if applicable
use (emergency or maintenance/testing) on a monthly basis and compiled into a 12-month rolling-sum report. Also, when not being operated for maintenance or testing, the	N/A
emergency engine(s) are used only for "emergency use".	
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
All stationary emergency standby engines installed after January 1, 2005 at NBVC are equipped with non-resettable hour meters. Hours of maintenance and emergency use are	G. Compliance Status? (C or I): C
recorded for each engine on a monthly basis and summarized into 12-month rolling-sum	H. *Excursions, exceedances, or
reports as required.	other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form



Period Covered by Compliance Certification: <u>01</u> / <u>01</u> / <u>24</u> (MM/DD/YY) to <u>12</u> / <u>31</u> / <u>24</u> (MM/DD/YY)

A. Attachment # or Permit Condition #: Attachment ATCM Portable Engine Condition No.	D. Frequency of monitoring:
B. Description:	Periodic
Non-federally enforceable requirement to use only California Air Resources Board (CARB) diesel fuel in portable diesel engines	
deserruer in portable dieser engines	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
All diesel fuel combusted in portable diesel engines at Naval Base Ventura County (NBVC) during the compliance period was supplied by the NBVC Supply Department, Fuel Branch.	G. Compliance Status? (C or I): C
All diesel fuel received by the Supply Department, Fuel Branch, is CARB certified. Data demonstrating the use of CARB-Certified fuel is provided in Appendix A.	H. *Excursions, exceedances, or
The state of the s	other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form
A Attachment # or Dermit Condition #: Attachment ATCM Deatable Facility On William	F
A. Attachment # or Permit Condition #: Attachment ATCM Portable Engine Condition No.	D. Frequency of monitoring:
B. Description:	Periodic
Non-federally enforceable requirement that all portable diesel-fueled engines permitted	
prior to January 1, 2010 be certified to meet federal or California standard for newly manufactured engines	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
All portable diesel-fueled engines permitted prior to January 1, 2010 at NBVC meet federal or California standard for newly manufactured engines. All Tier zero portable diesel-fueled	G. Compliance Status? (C or I): C
engines owned by NBVC were removed from service before January 1, 2010.	H. *Excursions, exceedances, or
v.	other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form
A. Attachment # or Permit Condition #: Attachment ATCM Portable Engine Condition No.	D Farmer of the state of
3	D. Frequency of monitoring:
B. Description:	Periodic
Non-federally enforceable requirement that all portable diesel-fueled engines permitted on	
or after January 1, 2010 be certified to the most stringent standards contained in the federal or California emission standards for nonroad engines	E. Source test reference method, if applicable.
	Attach Source Test Summary Form, if applicable N/A
	a a
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
All portable diesel-fueled engines permitted on or after January 1, 2010 at NBVC are certified to the most stringent standards contained in the federal or California emission	G. Compliance Status? (C or I): C
standards for nonroad engines.	H. *Excursions, exceedances, or
	other non-compliance? (Y or N): <u>N</u>
	*If yes, attach Deviation Summary Form



A. Attachment # or Permit Condition #: Attachment ATCM Portable Engine Condition No. 4	D. Frequency of monitoring:
B. Description:	Periodic
Non-federally enforceable requirement that the weighted average particulate matter emission rate for the fleet of portable diesel engines shall not exceed the standards specified at Section 93116.3(c), Title 17, California Code of Regulations	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Naval Base Ventura County is unable to meet the fleet average of 0.10 g/bhp-hr beginning 1/1/2020 and has elected the Phase Out Option beginning 1/1/2022. Two Tier 2 portable generators were phased out prior to 1/1/2022 in order to meet the Portable ATCM	G. Compliance Status? (C or I): C H. *Excursions, exceedances, or
requirement.	other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form



A. Attachment # or Permit Condition #: Attachment CARB Truck & Bus, Condition No. 1	D. Frequency of monitoring:
B. Description: Non-federally enforceable requirement that all sweeper vehicle auxiliary engines be operated with the applicable requirements of CARB Regulation to reduce emissions from in-use heavy-duty diesel-fueled vehicles	Periodic E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring: All portable diesel sweeper engines operate at NBVC are in compliance with the applicable requirements of CARB "Regulation to Reduce Emission of Diesel Particulate Matter, NOx, and Other Pollutants from In-Use Heavy-Duty Diesel-Fueled Vehicles". All two-engine sweepers at NBVC are operated in compliance with the Regulation and planned to be phased out in accordance with Section (f)(1).	I. Currently in Compliance? (Y or N): Y J. Compliance Status? (C or I): C K. *Excursions, exceedances, or other non-compliance? (Y or N): N *If yes, attach Deviation Summary Form

A. Attachment # or Permit Condition #: Attachment CARB Truck & Bus, Condition No.2	D. Frequency of monitoring:
B. Description:	Periodic
The permittee shall maintain a status record of each sweeper vehicle's compliance requirements and compliance status with the Regulation to Reduce Emissions of Diesel Particulate Matter, Oxides of Nitrogen and Other Criteria Pollutants, from In-Use and Heavy-Duty Diesel-Fueled Vehicles, specifically the requirements for sweeper vehicle auxiliary engines located in Section (n).	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Records of all sweepers are included in an inventory of NBVC's Truck & Bus Fleet. The inventory that includes sweepers is kept on file and updated periodically. The inventory includes compliance requirements and replacement schedules, as per the Regulation, including Section (n).	G. Compliance Status? (C or I): C H. *Excursions, exceedances, or
including Section (ii).	other non-compliance? (Y or N): N *If yes, attach Deviation Summary Form
365 W	



A. Attachment # or Permit Condition #: Attachment 74.12N1	D. Frequency of monitoring:
B. Description:	Monthly
ROC limits for coatings, application method requirements, solvents and vapor pressure limits for solvents, and recordkeeping requirements associated with the coating of metal parts and products	E. Source test reference method, if applicable Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
All coating and solvent materials must be approved by Environmental Division Air Quality Program (EDAQP) before they can be procured. A description of the item coated is made for the purpose of determining whether Rule 74.12 or another rule applies. A current material list showing the name and manufacturer of the components is accomplished by means of a database that records each issuance of a coating and solvent. In addition, volume of all coatings applied to any metal substrate, manufacturer, ROC Content, mix ratio, and type of coatings are recorded by each coating operation on a daily basis. These records are submitted to the EDAQP on a monthly basis. Volume of all coatings are compiled and reported against permit limits as total coatings applied. Only solvents with ROC contents of 25 grams per liter and less are used for substrate surface cleaning and cleanup. Routine inspection of the coating activities is made to ensure compliance with all standards.	G. Compliance Status? (C or I): C H. *Excursions, exceedances, or other non-compliance? (Y or N): N *If yes, attach Deviation Summary Form



A. Attachment # or Permit Condition #: Attachment 74.15N1	D. Frequency of monitoring:
B. Description:	Biennial
Emissions not to exceed 40 ppmvd NOx and 400 ppmvd CO, as demonstrated by biennial source test report. Routine surveillance is also required	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable CARB Method 100
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Wharfs 3 and Wharf 4 boilers have been out of service during the compliance certification period.	G. Compliance Status? (C or I): C
	H. *Excursions, exceedances, or other non-compliance? (Y or N): N *If yes, attach Deviation Summary Form



A. Attachment # or Permit Condition #: Attachment 74.15.1N1	D. Frequency of monitoring:
B. Description: Emissions not to exceed 30 ppmvd NOx and 400 ppmvd CO, as demonstrated by	Screening annually, source test every 48 months
quadrennial source test analysis. Also, requirement to conduct annual screening analysis when source test is not performed.	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable CARB Method 100
	4
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
The 1.825 MMBTU/hr Laars boiler, located at Building 2 was removed 04/2023.	G. Compliance Status? (C or I): C
	H. *Excursions, exceedances, or other non-compliance? (Y or N): N *If yes, attach Deviation Summary Form



A. Attachment # or Permit Condition #: Attachment 74.15.1N2	D. Frequency of monitoring:
B. Description:	Annual
Requirement to perform tune-ups, install totalizing fuel meter, and keep records. Submit tune-up reports to District every 12 months	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
The 2.1 MMBTU/hr Hurst Boiler is used for training purposes only and is fired on fuel oil and natural gas. It is equipped with fuel meters for both fuels. Reading from both meters	G. Compliance Status? (C or I): C
are taken on a monthly basis and compiled into a 12-month rolling sum report. Tune-up completed 3/1/2023 (biennially per VCAPCD agreement for boiler, building 1419 and de-	H. *Excursions, exceedances, or
icers).	other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form



A. Attachment # or Permit Condition #: Attachment 74.15.1N5	D. Frequency of monitoring:
B. Description: Emissions not to exceed 20 ppmvd NOx and 400 ppmvd CO, as demonstrated by quadrennial source test analysis. Also, requirement to conduct annual screening analysis when source test is not performed.	Screening annually, source test every 48 months, E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable CARB Method 100
C. Method of monitoring:	F. Currently in Compliance? (Y or N): \underline{Y}
Two 1.44 MMBTU/hr Lochinvar boilers located at Building 1479 were last source tested on 5/10/2023. The test reported NOx, CO, and Stack Gas Oxygen values in accordance with	G. Compliance Status? (C or I): C
California Air Resources Board Method 100. The emission screening was conducted on	H. *Excursions, exceedances, or
both boilers on 5/8/24. Boilers source test and emission screening results are presented in Appendix B.	other non-compliance? (Y or N): N
Appendix 6.	*If yes, attach Deviation Summary Form



A, Attachment # or Permit Condition #: Attachment 74.18N1	D. Frequency of monitoring:
B. Description: ROC limits for coatings and solvents, work practice and application method requirements and vapor pressure limits for solvents, and recordkeeping requirements associated with the coating of motor vehicles and mobile equipment	Periodic
	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring: All coating and solvent materials must be approved by Environmental Division Air Quality Program (EDAQP) before they can be procured. A current material list showing the name and manufacturer of the components issued to any operation abroad Naval Base Ventura	F. Currently in Compliance? (Y or N): Y G. Compliance Status? (C or I): C
Country accomplished by means of a database that records each issuance of a coating and solvent material. For each issuance of material, this database contains a reference to the applicable SDS sheet. In addition, daily usage records of the type, manufacturer, ROC content, mix ratio, and volume of coatings are submitted to the EDAQP on a monthly basis. ROC contents of 25 grams per liter and less are used for substrate surface cleaning and cleanup. Routine inspection of coating operations is performed to ensure compliance with all standards.	H. *Excursions, exceedances, or other non-compliance? (Y or N): N *If yes, attach Deviation Summary Form * The state of the stat



A. Attachment # or Permit Condition #: Attachment 74.24N1	D. Frequency of monitoring:
B. Description:	Periodic
ROC limits for coatings and solvents, vapor pressure limits for solvents, work practice standards, and recordkeeping requirements associated with marine coating operations	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
All coating and solvent materials must be approved by Environmental Division Air Quality Program before they can be procured. A current material list showing the name and manufacturer of the components issued to any operation abroad Naval Base Ventura County accomplished by means of a database that records each issuance of a coating and solvent material. For each issuance of material, this database contains a reference to the applicable SDS sheet. In addition, daily usage records of the type, manufacturer, ROC content, mix ratio, and volume of coatings are submitted to the EDAQP on a monthly basis. Volume of all coatings are recorded, compiled, and reported against permit limits as total coatings applied. ROC contents of 25 grams per liter and less are used for substrate surface cleaning and cleanup. Routine inspection of coating activities is performed to ensure compliance with all requirements.	G. Compliance Status? (C or I): C H. *Excursions, exceedances, or other non-compliance? (Y or N); N *If yes, attach Deviation Summary Form



A. Attachment # or Permit Condition #: Attachment 74.29N2	D. Frequency of monitoring:
B. Description: Rule 74.29, Soil decontamination operations and recordkeeping procedures	N/A E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring: The vapor extraction system at the "Navy Exchange Gas Station" (formerly VCAPCD Permit #00902) did not extract vapors from the subsurface at any time during this compliance certification period. The system has been dormant and inactive during this certification period.	F. Currently in Compliance? (Y or N): Y G. Compliance Status? (C or I): C H. *Excursions, exceedances, or other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form



Period Covered by Compliance Certification: <u>01</u> / <u>01</u> / <u>24</u> (MM/DD/YY) to <u>12</u> / <u>31</u> / <u>24</u> (MM/DD/YY)

A. Attachment # or Permit Condition #: Attachment 74.30N1	D. Frequency of monitoring:
B. Description: ROC limits for coatings and solvents and vapor pressure limits for solvents, work practice standards, and recordkeeping requirements associated with wood products coating operations	Periodic E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring: All coating and solvent materials must be approved by Environmental Division Air Quality Program before they can be procured. Volume of all coatings are recorded, compiled, and reported against permit limits as total coatings applied. Routine inspection of the coating operations ensures that they are in compliance with all requirements	F. Currently in Compliance? (Y or N): Y G. Compliance Status? (C or I): C H. *Excursions, exceedances, or other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form



A. Attachment # or Permit Condition #: Attachment 40CFR63II	D. Frequency of monitoring:
B. Description: Requirement to keep records to demonstrate the stationary source is not a major source of HAPs	As Needed E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring: Hazardous Air Pollutant (HAP) emission calculations were performed to demonstrate that NBVC Port Hueneme site is not a major source of HAPs. No changes occurred during 2024 that would have influenced Naval Base Ventura County (NBVC)'s HAP status. Documentation of the original HAP calculations is maintained by the NBVC Air Program	F. Currently in Compliance? (Y or N): Y G. Compliance Status? (C or I): C H. *Excursions, exceedances, or
and is available upon request.	other non-compliance? (Y or N): N *If yes, attach Deviation Summary Form



D. Frequency of monitoring:

Period Covered by Compliance Certification: $\underline{01}$ / $\underline{01}$ / $\underline{24}$ (MM/DD/YY) to $\underline{12}$ / $\underline{31}$ / $\underline{24}$ (MM/DD/YY)

A. Attachment # or Permit Condition #: Attachment 40CFR63ZZZZN3, Condition No. 1

B. Description: National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (RICE)- Requirements to change filter and oil , and inspect air cleaner, hoses, and belts	Air cleaner inspection: every 1000 hours of operation or annually, whichever comes first Oil and filter change: every 500 hours of operation or annually, whichever comes first Hoses and belts inspection: every 500 hours of operation or annually, whichever comes first
	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Naval Base Ventura County has a maintenance plan to ensure compliance with the maintenance requirements of Attachment 40CFR63ZZZZN3. Annual data collection for compliance certification revealed a failure to have either a passing oil analysis conducted or	G. Compliance Status? (C or I): <u>I</u>
complete an oil and filter change as described in 40CFR63ZZZZN3, Condition 1.a. for Bldg.	H. *Excursions, exceedances, or other non-compliance? (Y or N): Y
225 - 170 BHP Cummins and Bldg. 527 - 545 BHP Caterpillar. NOV #24490 was issued. Maintenance to the engines was performed and results were provided to the district on	
3/25/2024.	*If yes, attach Deviation Summary Form
· .	
A. Attachment # or Permit Condition #: Attachment 40CFR63ZZZZN3, Condition No. 2	D. Frequency of monitoring:
B. Description: Requirement that all existing emergency diesel stationary RICE are operated and	Routine
maintained according to the manufacture's emission-related written instructions or NVBC plan in a manner to minimize emissions	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable
	N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
All existing emergency diesel stationary RICE were operated and maintained according to the manufacturer's instructions and RICE NESHAP maintenance requirements during the	G. Compliance Status? (C or I): C
compliance certification period.	H. *Excursions, exceedances, or
	other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form
A. Attachment # or Permit Condition #: Attachment 40CFR63ZZZZN3, Condition No. 3	D. Frequency of monitoring:
B. Description:	Monthly
Requirement that existing emergency diesel stationary RICE are equipped with a non-	
resettable hour meter	Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
All existing emergency diesel stationary RICE are equipped with a non-resettable hour meter. Breakdown of a non-resettable digital hour meter due to a battery malfunction occurred for emergency standby engine 435 BHP, Cummins Model NT855G6, Serial	G. Compliance Status? (C or I): H. *Excursions, exceedances, or
No 30346676 located at Bldg. 382. The failed non-resettable digital hour meter was	other non-compliance? (Y or N): Y
removed and replaced with a new non-resettable digital hour meter. Observations indicate no further discrepancies.	*If yes, attach Deviation Summary Form
	, 20, 211211 2 2112111 2 21111111 7



ANNUAL COMPLIANCE CERTIFICATION DEVIATION SUMMARY FORM

A. Attachment # or Permit Condition #: 40CFR63ZZZZN3, Condition 1.a General Part 70 Permit	B. Equipment description Stationary engines: Bldg. 22 Bldg. 527 - 545 BHP Caterp	25 - 170 BHP Cummins and	C. Deviation Period: Date & Time Begin: October 12, 2023 End: March 25, 2024, at 0935 When Discovered: Date & Time March 4, 2024, at 1411
D. Parameters monitored: Oil and oil filter	E. Limit: Change oil and filter every 5 annually, whichever comes as described in Section 63,6 to extend the specified oil ch	first. An oil analysis program 6625(i) can be utilized in order	F. Actual: The oil and filter were not maintained as described in 40CFR63ZZZZN3, Condition 1.a.
G. Probable Cause of Deviation: Investigation for probable cause of deviate		H. Corrective actions taken:	was performed and results were provided to the



ANNUAL COMPLIANCE CERTIFICATION DEVIATION SUMMARY FORM

A. Attachment # or Permit Condition #: 74.9N7, Condition No. 2; ATCM Engine N2, Condition No. 2 and 3(a&b); 40CFR63ZZZZN3, Condition No. 3; General Part 70 Permit	B. Equipment description: Emergency Standby Engin Model NT855G6, Serial No 382		C. Deviation Period: Date & Time Begin: September 30, 2024, at 0942 End: October 1, 2024 at 0700 When Discovered: Date & Time September 30, 2024, at 0942
D. Parameters monitored: Requirement that each emergency standby engine shall be equipped with an operating, non-resettable, elapsed-time hour meter	E. Limit: Maintain operating, non-res meter	settable, elapsed-time hour	F. Actual: Failure of a non-resettable, elapsed-time hour meter.
G. Probable Cause of Deviation: Breakdown of a non-resettable digital homalfunction occurred.	our meter due to a battery	meter was removed and rep meter. NBVC monitored the indicate no further discrepan recordkeeping. Notification v	breakdown, the failed non-resettable digital hour laced with a new non-resettable digital hour efficacy of the completed repairs. Observations cies. Facts of this matter were documented for was made to notifications@vacapcd.org covery and 10/7/2024 for corrective actions



*If yes, attach Deviation Summary Form

other non-compliance?

Period Covered by Compliance Certification: $\underline{01}$ / $\underline{01}$ / $\underline{24}$ (MM/DD/YY) to $\underline{12}$ / $\underline{31}$ / $\underline{24}$ (MM/DD/YY)

Measure (ATCM) for stationary compression ignition engines limits the maintenance hours of operation to 20 hours per calendar year for engines installed prior to January 1, 2005 and 50 hours per calendar year for engines installed after January 1, 2005.

A. Attachment # or Permit Condition #: Attachment 40CFR63ZZZZN3, Condition No. 4	D. Frequency of monitoring:	
B. Description: Requirement that permittee minimize the engine's time spent at idle during startup, not to exceed 30 minutes	Routine	
	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A	
C ₊ Method of monitoring:	F. Currently in Compliance? (Y or N): Y	
To conserve resources and reduce emissions, NBVC limits the idling of stationary engines to the period of time required to bring the subject engines to a mechanically optimal operating temperature. In no case do these periods of optimization exceed 30 minutes.	G. Compliance Status? (C or I): C	
periods of optimization exceed 50 minutes.	H. *Excursions, exceedances, or other non-compliance? (Y or N): N	
	*If yes, attach Deviation Summary Form	
A. Attachment # or Permit Condition #: Attachment 40CFR63ZZZZN3, Condition No. 5(b)	D. Frequency of monitoring:	
B. Description: Requirement that existing emergency diesel stationary RICE operations are limited to 100 hours per calendar year for maintenance and testing, emergency demand response, frequency deviation situations, and up to 50 hours per year for non-emergency situations.	N/A	
	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A	
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y	
Federally enforceable Rule 74.9 limits the maintenance hours of operation to 50 hours per calendar year for the emergency standby stationary internal combustion engines rated at 50 or more break-horsepower operated at NBVC. In addition, Airborne Toxic Control	G. Compliance Status? (C or I): C	
Measure (ATCM) for stationary compression ignition engines limits the maintenance house	H. *Excursions, exceedances, or	

(Y or N):

<u>N</u>



Period Covered by Compliance Certification: <u>01</u> / <u>01</u> / <u>24</u> (MM/DD/YY) to <u>12</u> / <u>31</u> / <u>24</u> (MM/DD/YY)

A. Attachment # or Permit Condition #: Attachment 40CFR63ZZZZN3, Condition No. 5(c)	D. Frequency of monitoring:
B. Description:	N/A
Operation of the existing emergency diesel stationary RICE for Peak shaving or non- emergency demand response program	
#	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable
	N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
None of the existing emergency stationary RICE located at NBVC was operated for peak shaving or non-emergency demand response during the compliance certification period.	G. Compliance Status? (C or I): C
	H. *Excursions, exceedances, or
	other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form



A. Attachment # or Permit Condition #: Attachment 40CFR63ZZZZN3, Condition No. 6	D. Frequency of monitoring:
B. Description: Recordkeeping requirements	Monthly
	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Naval Base Ventura County has developed a maintenance plan to ensure compliance with the maintenance requirements of 40 CFR Part 63, Subpart ZZZZ. The records of maintenance are retained by the Environmental Division Air Quality Program (EDAQP). All stationary emergency RICE at NBVC are equipped with non-resettable hour meters. Hours of maintenance and emergency use are recorded for each engine on a monthly basis by the EDAQP.	G. Compliance Status? (C or I): C H. *Excursions, exceedances, or
	other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form
A. Attachment # or Permit Condition #: Attachment 40CFR63ZZZZN3, Condition No. 9	D. Frequency of monitoring:
B. Description:	1 N/A
Requirement that on an annual basis, the permittee certify that all engines at the stationary source are operating in compliance with 40 CFR Part 63, Subpart ZZZZ, NESHAP for	E. Source test reference method, if applicable.

A. Attachment # or Permit Condition #: Attachment 40CFR63ZZZZN3, Condition No. 9	D. Frequency of monitoring:
B. Description:	N/A
Requirement that on an annual basis, the permittee certify that all engines at the stationary source are operating in compliance with 40 CFR Part 63, Subpart ZZZZ, NESHAP for RICE	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable
C. Method of monitoring:	
C. Method of monitoring,	F. Currently in Compliance? (Y or N): Y
All engines at NBVC were operated in compliance with 40 CFR Part 63, Subpart ZZZZ, NESHAP for RICE during the compliance certification period.	G. Compliance Status? (C or I): C
	H. *Excursions, exceedances, or other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form



A. Attachment # or Permit Condition #: Attachment 40CFR63ZZZZN12, Condition No. 1	D. Frequency of monitoring:	
B. Description:	N/A	
National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (RICE). Operation of the existing commercial emergency stationary RICE for emergency demand response when an Energy Emergency Alert has been authorized, for periods of a deviation from standard voltage or frequency, and to supply power as party of a financial arrangement with another entity.	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A	
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y	
None of the existing emergency stationary RICE located at NBVC was operated for emergency demand response when an Energy Emergency Alert has been authorized, for periods of a deviation from standard voltage or frequency, and to supply power as party of a financial arrangement with another entity.	G. Compliance Status? (C or I): C H. *Excursions, exceedances, or	
	other non-compliance? (Y or N): N	
	*If yes, attach Deviation Summary Form	



A. Attachment # or Permit Condition #: Attachment 40CFR60IIIIN1, Condition No. 1	D Francisco of markets
	D. Frequency of monitoring:
B. Description: Requirement that stationary compression ignition engines which are 2007 model or later, are used for appropriate the stationary compression ignition engines which are 2007 model or later,	Per Event
are used for emergency purposes, and have an engine displacement of less than 10 liters per cylinder comply with the certification emission standards for new nonroad compression ignition engines for the same model year and maximum engine power found in 40 CFR 89.112 and 40 CFR 89.113.	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Environmental Division Air Quality Program staff review and verify the California Air Resources Board (CARB) and Environmental Protection Agency emission certification for	G. Compliance Status? (C or I): C
the new stationary compression ignition internal combustion engine prior to purchasing and installing the engine. In addition, VCAPCD Rule 26.2 has required Best Available Control Technology (BACT) for all new emissions units. Therefore, all new emergency diesel engines installed and permitted in Ventura County after 2007 are in compliance with this requirement because the BACT requirements are at least as stringent as the engine standards of 40 CFR 89.112 and 40 CFR 89.113.	H. *Excursions, exceedances, or other non-compliance? (Y or N): N *If yes, attach Deviation Summary Form
A Attacher and the December 2	
A. Attachment # or Permit Condition #: Attachment 40CFR60IIIIN1, Condition No. 2	D. Frequency of monitoring:
B. Description:	Periodic
Requirement to use CARB diesel fuel in stationary compression ignition emergency engines	
a and a second s	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
	_
NBVC) during the compliance period was supplied by the NBVC Supply Department Fuel	G. Compliance Status? (C or I): C
All diesel fuel combusted in stationary emergency engines at Naval Base Ventura County (NBVC) during the compliance period was supplied by the NBVC Supply Department, Fuel Branch. All diesel fuel received by the Supply Department, Fuel Branch, is CARB certified. Data demonstrating the use of CARB-certified fuel is provided in Appendix A	G. Compliance Status? (C or I): C H. *Excursions, exceedances, or
(NBVC) during the compliance period was supplied by the NBVC Supply Department Fuel	` ′ =



Period Covered by Compliance Certification: 01 / 01 / 24 (MM/DD/YY) to 12 / 31 / 24 (MM/DD/YY)

A. Attachment # or Permit Condition #: Attachment PO01006PC1-671, Condition No. 1	D. Frequency of monitoring:
B. Description:	Monthly
Requirement to keep monthly records of throughput/usage for all operations listed in Table 3 of Permit 01006. On an ongoing basis, monthly usage for each operation is to be summed for the previous 12 months, and the totals reported.	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
All applicable data are gathered each month and entered into a database. For each throughput/usage limit, data are compiled to determine the throughput/usage for each	G. Compliance Status? (C or I): C
month. Monthly data are then summed for each period of 12 consecutive months. These	H. *Excursions, exceedances, or
12-month rolling sums are reported.	other non-compliance? (Y or N): <u>N</u>
The state of the s	*If yes, attach Deviation Summary Form
A August word to a Descrit Condition to Attachment DOMANCOCC 674 Condition No. 2	D. Frequency of monitoring:
A. Attachment # or Permit Condition #: Attachment PO01006PC1-671, Condition No. 2	D. Frequency of monitoring.
B. Description: For solvent cleaning activities, requirement to keep monthly records of solvents purchased,	Monthly
recycled, or disposed	E. Source test reference method, if applicable.
	Attach Source Test Summary Form, if applicable
	N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Records of solvents purchased are extracted from a database called Enterprise Resources Planning (ERP), which keeps a record each time a hazardous material is issued to the end	G. Compliance Status? (C or I): C
user. Some data as to solvents disposed is gathered from a database called Hazardous Waste Declaration System (HWDS). There are not always records of solvents disposed,	H. *Excursions, exceedances, or
and in such cases, the solvents are conservatively assumed to have evaporated, and are	other non-compliance? (Y or N): N
reported as such.	*If yes, attach Deviation Summary Form
A. Attachment # or Permit Condition #: Attachment PO01006PC1-671, Condition No. 3	D. Frequency of monitoring:
	B. Frequency of monitoring.
B. Description: Requirement that all State-registered portable equipment comply with State registration	Annual
requirements, and that a copy of State registration be available	E. Source test reference method, if applicable.
	Attach Source Test Summary Form, if applicable
	N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Tactical support equipment are registered with the California Air Resources Board's Portable Equipment Registration Program (PERP). PERP requirements for tactical support	G. Compliance Status? (C or I): C
equipment are minimalrequiring only a description of each type of equipment and the number of units attached to the facility. Documentation of equipment registration is	H. *Excursions, exceedances, or
maintained in the Air Quality Program Office. Prior to the annual PERP renewal date, a	other non-compliance? (Y or N): <u>N</u>
survey is conducted of all tactical support equipment located at the facility.	*If yes, attach Deviation Summary Form



A, Attachment # or Permit Condition #: Attachment PO01006PC2-rev881, Condition No. 1	D. Frequency of monitoring:
B. Description:	Periodic
Requirement that the sulfur content of distillate fuel burned in portable internal combustion engines shall not exceed 0.05% by weight	
The state of the s	E. Source test reference method, if applicable.
	Attach Source Test Summary Form, if applicable
	N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
All diesel fuel burned in portable internal combustion engines is supplied by the Naval Base Ventura County (NBVC) Supply Department, Fuel Branch. All diesel fuel received by	G. Compliance Status? (C or I): C
the Supply Department, Fuel Branch, is California Air Resources Board (CARB) certified.	H. *Excursions, exceedances, or
Data demonstrating the use of CARB-certified fuel are provided in Appendix A. Data indicating the use of CARB-certified fuel is maintained at the facility and provided with this	other non-compliance? (Y or N): N
annual compliance certification in Appendix A.	. , , =
STATE CONTROL OF THE STATE OF	*If yes, attach Deviation Summary Form
A. Attachment # or Permit Condition #: Attachment PO01006PC2-rev881, Condition No. 2, as applicable to individual engines with limits expressed in hours per year	D. Frequency of monitoring:
as application to manifestal original manifestal expressed in nodes per year	Monthly
B. Description:	Working
Requirement that affected engines be equipped with hour meter, and their hours of	
operation be recorded monthly and compiled so as to demonstrate compliance with the usage limits of Table 3	E. Source test reference method, if applicable.
	Attach Source Test Summary Form, if applicable
	N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Each engine with an applicable limit is equipped with a properly installed and maintained hour meter. Hour meters of each engine are read on a monthly basis or more often to	G. Compliance Status? (C or I): C
ensure compliance with the rolling-12-month limits. The data are compiled monthly and	H. *Excursions, exceedances, or
compared to the applicable limits.	other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form
	,,
A. Attachment # or Permit Condition #: Attachment PO01006PC2-rev881, Condition No. 2,	D. Frequency of monitoring:
as applicable to engines that are part of an engine group where the limit is expressed in BHP-hrs/year	-
B. Description:	Monthly
Requirement that engine usage be properly recorded and compiled so as to demonstrate	
compliance with the usage limits of Table 3	E Source test reference mathed if a live !
	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable
<u>s</u>	N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Each engine is equipped with a properly installed and maintained hour meter. Hour meters	G. Compliance Status? (C or I): C
of each engine are read monthly. Monthly hours of operation are determined and multiplied by the BHP rating of each engine to determine BHP-hours for that engine for that	(= /- =
month. Values for all engines in a group are summed to determine total BHP-hours for that	H. *Excursions, exceedances, or
month. Each month, total monthly BHP-hrs are summed for the previous 12 months and compared to the applicable BHP-hr/year limit.	other non-compliance? (Y or N): <u>N</u>



D. Frequency of monitoring:

Period Covered by Compliance Certification: 01 / 01 / 24 (MM/DD/YY) to 12 / 31 / 24 (MM/DD/YY)

A. Attachment # or Permit Condition #: Attachment PO01006PC2-rev881, Condition No. 3

B. Description:	Per Operation
Non-federally enforceable requirement that the five portable John Deere engines (4- 165 BHP units and 1- 315 BHP unit) provide power to a) individual buildings housing critical infrastructure during grid maintenance and electrical repair operations, b) provide power during emergency use, and C) maintenance and testing use of the combined five engines shall not exceed the 95,750 BHP-hr per year limit.	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring: Each engine is equipped with a non-resettable hour meter. A log of engine operation which includes usage record and describes the purpose of each engine use is maintained by Environmental Division Air Quality Program office.	F. Currently in Compliance? (Y or N): Y G. Compliance Status? (C or I): C H. *Excursions, exceedances, or other non-compliance? (Y or N): N *If yes, attach Deviation Summary Form
A. Attachment # or Permit Condition #: Attachment PO01006PC2-rev881, Condition No. 4	D. Frequency of monitoring: Per Operation
B. Description: Non-Federally enforceable requirement to notify Ventura County Air Pollution Control (VCAPCD) of long term operations requiring the use of portable engines	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable
C. Method of monitoring: During this compliance certification period, no portable engines were used at any single location where operations lasted for more than 30 days. Therefore, no notification on this subject was made to VCAPCD.	F. Currently in Compliance? (Y or N): Y G. Compliance Status? (C or I): C H. *Excursions, exceedances, or other non-compliance? (Y or N): N *If yes, attach Deviation Summary Form
A. Attachment # or Permit Condition #: Attachment PO01006PC2-rev881, Condition No. 5 B. Description: Prohibition against using a portable engine to perform a permanent function	D. Frequency of monitoring: Periodic E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable
C. Method of monitoring: Portable engines at NBVC are used by the Public Works Department. Due to the inherent nature of their work, engines are constantly moved from one location to another within the site to perform work.	F. Currently in Compliance? (Y or N): Y G. Compliance Status? (C or I): C H. *Excursions, exceedances, or
	other non-compliance? (Y or N): N *If yes, attach Deviation Summary Form



A. Attachment # or Permit Condition #: Attachment PO01006PC2-rev881, Condition No. 6	D. Frequency of monitoring:
B. Description:	Periodic
NOx emission requirements for sweeper engines, as per Rule 26	
*	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
All sweeper vehicle portable diesel engines have NOx emission certification documents.	G. Compliance Status? (C or I): C
	H. *Excursions, exceedances, or
	other non-compliance? (Y or N): N
- C	*If yes, attach Deviation Summary Form



Period Covered by Compliance Certification: <u>01</u> / <u>01</u> / <u>24</u> (MM/DD/YY) to <u>12</u> / <u>31</u> / <u>24</u> (MM/DD/YY)

A. Attachment # or Permit Condition #: Attachment PO01006PC4- rev671, Condition No. 1	D. Frequency of monitoring:
B. Description: Requirement that the gasoline loading rack at Building 5307 be equipped with a California	N/A [©]
Air Resources Board (CARB)-certified vapor recovery system	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Naval Base Ventura County has a letter from CARB dated November 21, 2003, stating that the 20,000-gallon Bryant Fuel Systems bulk plant system installed at Port Hueneme will	G. Compliance Status? (C or I): C
meet the 95% vapor recovery efficiency requirement as required for site-specific certification.	H. *Excursions, exceedances, or
	other non-compliance? (Y or N): N *If yes, attach Deviation Summary Form
	in yes, attach Deviation Summary Form
A. Attachment # or Permit Condition #: Attachment PO01006PC4- rev671, Condition No. 1	D. Frequency of monitoring:
B. Description:	Monthly
Requirement that no more than 100,000 gallons of gasoline per year are transferred from the loading rack to delivery vessels, and that no more than 100,000 gallons of gasoline per year are subsequently delivered to non-motor vehicle equipment. Monthly recordkeeping to demonstrate compliance is also required	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Fuel transfers are recorded in a database at the point at which they are transferred from the delivery vessel to the end user (dispensed into equipment that is not a motor vehicle).	G. Compliance Status? (C or I): `C
Data from this database is compiled into monthly reports. Fuel transfers from the loading rack to the delivery vessel are assumed equal fuel deliveries. The gasoline tank at Building No. 5307 was out of service during the compliance period, therefore no gasoline transfers were made.	H. *Excursions, exceedances, or other non-compliance? (Y or N): N *If yes, attach Deviation Summary Form



A. Attachment # or Permit Condition #: Attachment PO01006PC5-671, Condition No. 1	D. Frequency of monitoring:
B. Description:	Appuellu
Federally enforceable requirement that five boilers (one at Wharf 3, one at Wharf 4, one at Building 2, and two at Building 1479) and one burner at Building 1100 be fired only on PUC	Annually
regulated natural gas	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	E. Currenthy in Correliance C
Compliance is demonstrated by the fact that the only fuel supply to these boilers is by the	F. Currently in Compliance? (Y or N): Y
natural gas utility distribution system, which is PUC-regulated. Boilers at Wharf 3, Wharf 4, and Building 2 were out of service during the compliance certification period. The boiler at	G. Compliance Status? (C or I): C
Building 2 was removed 04/2023.	H. *Excursions, exceedances, or other non-compliance? (Y or N); N
w*	, , , , ,
	*If yes, attach Deviation Summary Form
A. Attachment # or Permit Condition #: Attachment PO01006PC5-671, Condition No. 2	D. Frequency of monitoring:
B. Description:	Monthly
Requirement that natural gas usage for each boiler shall not exceed the limits listed in Section No. 3, "Permitted Throughput and Consumption Limit Table"	Montally
Table	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable
	N/A
*	
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Boiler gas meter readings are taken each month. These readings are compiled into reports that express gas usage on a monthly basis and usage over the preceding 12	G. Compliance Status? (C or I): C
months. Reports were generated for each of the twelve month periods that ended during the compliance certification period.	H. *Excursions, exceedances, or
period.	other non-compliance? (Y or N): <u>N</u>
	*If yes, attach Deviation Summary Form
A. Attachment # or Permit Condition #: Attachment PO01006PC5-671, Condition No. 3, as applicable to distillate oil consumption in the Hurst Boiler at Building 1419	D. Frequency of monitoring:
B. Description:	Monthly
Requirement that the total distillate oil consumption in the Hurst Boiler shall not exceed	
1,000 gallons per year. Associated recordkeeping to ensure compliance is also required	E. Source test reference method, if applicable.
7	Attach Source Test Summary Form, if applicable N/A
	8:
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
The 2.1 MMBTU Hurst boiler at Building 1419 is fitted with two totalizing fuel metersone on the fuel delivery line, and one on the return line. Consumption is determined by	G. Compliance Status? (C or I): <u>C</u>
subtracting the fuel returned from the fuel delivered.	H. *Excursions, exceedances, or
	other non-compliance? (Y or N): <u>N</u>
	*If yes, attach Deviation Summary Form



Period Covered by Compliance Certification: <u>01</u> / <u>01</u> / <u>24</u> (MM/DD/YY) to <u>12</u> / <u>31</u> / <u>24</u> (MM/DD/YY)

A. Attachment # or Permit Condition #: Attachment PO01006PC5-671, Condition No. 3, as applicable to natural gas consumption in the Hurst Boiler at Building 1419	D. Frequency of monitoring:
B. Description:	Monthly .
Requirement that the total natural gas consumption in the Hurst Boiler shall not exceed 0.1	
MMCF per year. Associated recordkeeping to ensure compliance is also required	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Natural gas consumption in the 2.1 MMBTU Hurst Boiler at Building 1419 was determined by a totalizing fuel meter.	G. Compliance Status? (C or I): C
Y X	H. *Excursions, exceedances, or
	other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form
DOLLARD DE 1811 N. 1	D. Farancia and American
A. Attachment # or Permit Condition #: Attachment PO01006PC5-671, Condition No. 3, as applicable to the Global boilers	D. Frequency of monitoring:
B. Description:	Monthly
Requirement that the annual hours of operation for the two Global aircraft de-icer process	
heaters does not exceed 200 hours. Associated recordkeeping to ensure compliance is also required	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable
<u>*</u>	N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
The two Global aircraft de-icers are equipped with dedicated totalizing hour meters and the hour meter readings are taken each month.	G. Compliance Status? (C or I): <u>C</u>
	H. *Excursions, exceedances, or
	other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form
A August word # or Republican #1 Attachment PO01006PO5 671 Condition No. 4	D. Frequency of monitoring:
A. Attachment # or Permit Condition #: Attachment PO01006PC5-671, Condition No. 4	B. I requarity of monitoring.
B. Description:	Periodic
Requirement that the sulfur content of distillate fuel burned in the Hurst and Global boilers shall not exceed 0.05% by weight.	Course test reference reathed if emplicable
	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable
	N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Compliance with this requirement is demonstrated by the fact that all diesel fuel burned in boilers is supplied by the Naval Base Ventura County Supply Department, Fuel Branch,	G. Compliance Status? (C or I): C
and that all diesel fuel received by the Supply Department, Fuel Branch is California Air Resources Board certified. Please see Appendix A for documentation.	H. *Excursions, exceedances, or
Tresources Board Certified. I leade doe ripperidix / Tol documentation.	other non-compliance? (Y or N): <u>N</u>
	*If you attack Doviction Cummons Form



A. Attachment # or Permit Condition #: Attachment PO01006PC5-671, Condition No. 5	D. Frequency of monitoring:
B. Description:	Biennial
BACT condition for the two 8.4 MMBTU/hr Superior boilers at Wharf #3 and Wharf #4 that limits NOx emissions to 12 ppmvd at 3% oxygen, averaged over 16 consecutive minutes. Source testing requirement is also specified at a minimum of every 24 months	
	E. Source test reference method, if applicable.
5 The state of the	Attach Source Test Summary Form, if applicable
	CARB Method 100 and EPA Method 19
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Both Boilers were out of service during the compliance certification period.	G. Compliance Status? (C or I): C
	H. *Excursions, exceedances, or
	other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form
	· ,
A. Attachment # or Permit Condition #: Attachment PO01006PC5-671, Condition No. 6	D. Frequency of monitoring:
B. Description:	Monthly
Requirement to install dedicated totalizing natural gas fuel meters on the two 8.4	Morally
MMBTU/hr Superior boilers at Wharf 3 and Wharf 4	E. Source test reference method, if applicable.
	Attach Source Test Summary Form, if applicable
	N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Dedicated totalizing fuel meters were installed on Wharves 3 and 4 boilers. Both Boilers were out of service during the compliance certification period.	G. Compliance Status? (C or I): C
	H. *Excursions, exceedances, or
	other non-compliance? (Y or N): <u>N</u>
	*If yes, attach Deviation Summary Form
A. Attachment # or Permit Condition #: Attachment PO01006PC5-671, Condition No. 7	D. Frequency of monitoring:
B. Description:	Monthly
Requirement that the two 4.8 MMBTU/hr Global aircraft de-icers be equipped with	
dedicated hour meters	E. Source test reference method, if applicable.
	Attach Source Test Summary Form, if applicable
	N/A
C. Method of monitoring:	F. Oursealle in Orangilian D.
Compliance with this requirement is demonstrated by the fact that the two Global aircraft	F. Currently in Compliance? (Y or N): Y
de-icers are equipped with dedicated totalizing hour meters.	G. Compliance Status? (C or I): C
	H. *Excursions, exceedances, or
	other non-compliance? (Y or N): <u>N</u>
_	*If yes, attach Deviation Summan, Form



D. Frequency of monitoring:

Period Covered by Compliance Certification: 01 / 01 / 24 (MM/DD/YY) to 12 / 31 / 24 (MM/DD/YY)

A. Attachment # or Permit Condition #: Attachment PO01006PC5-671, Condition No. 8

B. Description:	Periodic
Requirement that the two 4.8 MMBTU/hr Global aircraft de-icers are to be used only for aircraft deicing training purposes only	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring: Compliance with this requirement is ensured by the fact that the de-icer vehicles in which the boilers are permanently mounted are not readily suitable for any purpose other than aircraft de-icing. Routine inspections ensure that the units are not altered. Since there is never any ice in Port Hueneme to remove, or any aircraft to de-ice, it is logical that the boilers are only used for training purposes. A. Attachment # or Permit Condition #: Attachment PO01006PC5-671, Condition No. 9 B. Description: Requirement that the Hurst boiler located in building 1419 be used for training purposes only	F. Currently in Compliance? (Y or N): Y G. Compliance Status? (C or I): C H. *Excursions, exceedances, or other non-compliance? (Y or N); N *If yes, attach Deviation Summary Form D. Frequency of monitoring: Monthly E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring: Compliance with this requirement is demonstrated by the fact that the boiler is plumbed in such a manner that any steam or hot water produced by it cannot serve any useful purpose. Logically, it can only be used for training purposes.	F. Currently in Compliance? (Y or N): Y G. Compliance Status? (C or I): C H. *Excursions, exceedances, or other non-compliance? (Y or N): N *If yes, attach Deviation Summary Form
A. Attachment # or Permit Condition #: Attachment PO01006PC5-671, Condition No. 10 B. Description: BACT requirement that the Hurst boiler located in building 1419 operates in compliance with APCD Rule 74.16.1 and Rule 74.16.1.B.2	D. Frequency of monitoring: Periodic E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring: Though the annual heat input of the 2.1 MMBTU/hr Hurst boiler is less than 300 MMBTU, it is operated per the requirements of Rule 74.16.1.B.2 for boilers with an annual heat input greater than 300 MMBTU (and less than 1,800 MMBTU). Per 3/21/2021 agreement with VCAPCD, tune-ups are performed on a biennial basis; last tune-up completed 3/1/2023.	F. Currently in Compliance? (Y or N): Y G. Compliance Status? (C or I): C H. *Excursions, exceedances, or other non-compliance? (Y or N): N *If yes, attach Deviation Summary Form



A. Attachment # or Permit Condition #: Attachment PO01006PC5-671, Condition No. 11	D. Frequency of monitoring:
B. Description:	Periodic
Requirement that the NCEL Burner shall be used for testing purposes only	
	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
The NCEL burner is designed to produce a very high speed flame to simulate a jet engine exhaust. It is impractical to use this burner for any purpose other than for testing. Routine	G. Compliance Status? (C or I): C
inspections ensure that the burner is used for testing only.	H. *Excursions, exceedances, or
	other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form



Period Covered by Compliance Certification: <u>01</u> / <u>01</u> / <u>24</u> (MM/DD/YY) to <u>12</u> / <u>31</u> / <u>24</u> (MM/DD/YY)

A. Attachment # or Permit Condition #: Attachment PO01006PC6-831, Conditions No.1 and 2	D. Frequency of monitoring:
B. Description:	Daily during operations and monthly for recordkeeping
Federally enforceable requirement that the ROC and throughput of coatings and solvents	purposes
used at NBVC Port Hueneme do not exceed the limits listed in Table 3 of Title V Permit #01006.	E. Source test reference method, if applicable.
#01000.	Attach Source Test Summary Form, if applicable
3	N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Compliance with this requirement is demonstrated by means of daily logs (compiled on a monthly basis) that record the ROC and volume of coating applied and a description of the	G. Compliance Status? (C or I): C
item coated. To ensure compliance with the ROC requirement, the Environmental Division Air Quality Program (EDAQP) screens the coatings and solvents prior to purchase and use	H. *Excursions, exceedances, or
in coating operations. In addition, routine inspections of paint cabinets are performed to	other non-compliance? (Y or N): N
ensure compliance with ROC content requirements. Monthly usage is summed each month and for the previous 12 months to demonstrate compliance. No coatings were	*If yes, attach Deviation Summary Form
applied by the Port Services Department during the compliance certification period other	
than architectural coatings for routine maintenance purposes.	
A AU L CALL CONTRACTOR OF STATE OF STAT	D. Fraguepou of monitoring
A. Attachment # or Permit Condition #: Attachment PO01006PC6-831, Condition No. 3	D. Frequency of monitoring:
B. Description:	As Needed
ROC content limit of 2.8 lbs/gallon for coating of marine vessels by Naval Surface Warfare	
Center (NSWC). Associated recordkeeping is also required	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable
	N/A
O Mathad of manifestary	F. Currently in Compliance? (Y or N): Y
C. Method of monitoring:	
All coating and solvent materials must be approved by EDAQP before they can be procured. Approval of any coating with ROC content in excess of 2.8 lbs/gallon is not	G. Compliance Status? (C or I): C
granted. Routine inspection of coating activities is performed to ensure compliance with all	H. *Excursions, exceedances, or
requirements including maintaining records of coatings and ROC content.	other non-compliance? (Y or N): <u>N</u>
	*If yes, attach Deviation Summary Form
A. Attachment # or Permit Condition #: Attachment PO01006PC6-831, Condition No. 4	D. Frequency of monitoring:
B. Description:	Periodic
Requirement that only inorganic solvents are used in surface preparation or cleanup of	
application equipment associated with the coating of marine vessels at Naval Surface Warfare Center (NSWC) buildings.	Source test reference method, if applicable. Attach Source Test Summary Form, if applicable
4	N/A
	1971
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
All materials must be approved by EDAQP before they can be procured. Compliance is also ensured by periodic inspection of the paint storage lockers by Air Quality Program	G. Compliance Status? (C or I): <u>C</u>
personnel.	
porconnect	H. *Excursions, exceedances, or
posessino.	H. *Excursions, exceedances, or other non-compliance? (Y or N): <u>N</u>



A. Attachment # or Permit Condition #: Attachment PO01006PC6-831, Condition No. 5	D. Frequency of monitoring:
B. Description: Non-Federally enforceable requirement for paint spray booths and painting rooms to be fitted with overspray filters, and that the filters be replaced before the spray booth manometer reaches 0.5 inches of water column.	Periodic
	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Each spray booth is equipped with overspray filters and a manometer. Compliance is ensured by periodic monitoring and inspection of coating operations in spray booths and	G. Compliance Status? (C or I): C
paint rooms performed by EDAQP staff. If a manometer reached 0.5 inches of water column before the overspray filters can be replaced, the booth is designated as Not in Service, and prohibited from use until overspray filters are replaced.	H. *Excursions, exceedances, or other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form
A. Attachment # or Permit Condition #: Attachment PO01006PC6-831, Condition No. 6	D. Frequency of monitoring:
B, Description:	Periodic
Non-Federally enforceable prohibiting the use of coatings containing lead or hexavalent	renduc
chromium.	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Compliance with this requirement is demonstrated by the fact that all coatings must be approved by the EDAQP prior to their purchase or use in coating operations. No coatings	G. Compliance Status? (C or I): C
containing lead or hexavalent chromium are approved for use.	H. *Excursions, exceedances, or other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form



Period Covered by Compliance Certification: <u>01</u> / <u>01</u> / <u>24</u> (MM/DD/YY) to <u>12</u> / <u>31</u> / <u>24</u> (MM/DD/YY)

A. Attachment # or Permit Condition #: Attachment PO01006PC7-rev721, Conditions No.	D. Frequency of monitoring:
B. Description:	Periodic
Limit of one ton per year of abrasives for use in unconfined abrasive blasting operations	
	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Projects that involve unconfined blasting are required to go through the Public Works Project Review Board. Such projects are reviewed by Environmental Division Air Quality Program (EDAQP) staff, who require that the quantity of the abrasive blasting materials used is reported to the EDAQP.	G. Compliance Status? (C or I): C H. *Excursions, exceedances, or other non-compliance? (Y or N): N *If yes, attach Deviation Summary Form
A. Attachment # or Permit Condition #: Attachment PO01006PC7-rev721, Conditions No.	D. Frequency of monitoring:
B. Description:	Periodic
Limit of seven tons per year of abrasives for combined use in four abrasive blast cabinets	
Limit of seven tons per year of abrasives for combined dec in four distance state.	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Monthly abrasive usage records for the four abrasive blast cabinets are submitted to the EDAQP and compiled into rolling 12 month throughput reports.	G. Compliance Status? (C or I): C
	H. *Excursions, exceedances, or
*	other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form
A. Attachment # or Permit Condition #: Attachment PO01006PC7-rev721, Conditions No. 3	D. Frequency of monitoring:
B. Description:	Periodic
Requirement that unconfined abrasive blasting operations comply with Rule 74.1	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Projects that involve unconfined blasting are required to go through the Public Works	G. Compliance Status? (C or I): C
Project Review Board. Such projects are reviewed by EDAQP staff, which in turn requires that all contractors comply with Rule 74.1.	H. *Excursions, exceedances, or
and an obligation obling marriage ()	other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form



A. Attachment # or Permit Condition #: Attachment PO01006PC7-rev721, Condition No. 4(a)	D. Frequency of monitoring:
B. Description:	Annual
Opacity survey from confined abrasive blasting operations at Buildings 813 and 1497	<u>*</u>
*	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
The Building 1497 large blast room was out of service during the compliance certification period. Opacity survey was performed on the blast cabinets located inside Buildings 813 and	G. Compliance Status? (C or I): C
1497 on 11/5/2024. No opacity was noted.	H. *Excursions, exceedances, or other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form

A. Attachment # or Permit Condition #: Attachment PO01006PC7-rev721, Condition No. 4(b)	D. Frequency of monitoring:
B. Description:	Annual
Requirement to control PM emissions from dust collectors, a floor reclaim system, bucket elevator, and media cleaning unit associated with the Building 1497 large blast room.	E. Source test reference method, if applicable.
This includes maintenance of the dust collector system and inspection and/or replacement of each filter cartridge on an annual basis.	Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
The Building 1497 large blast room was out of service during the compliance certification period.	G. Compliance Status? (C or I): C
	H. *Excursions, exceedances, or
	other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form

A. Attachment # or Permit Condition #: Attachment PO01006PC7-rev721, Condition No. 4(c) and (d)	D. Frequency of monitoring:
B. Description:	Routine
Requirement to follow dust handling and filters inspection protocols and to operate the	
Clemco abrasive blast cabinet at Building 813 pursuant to manufacturer's specifications.	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
The three Clemco abrasive blast cabinets dust collectors and their pulse jet cleaning systems were operated pursuant to manufacturer's specifications. All filters were	G. Compliance Status? (C or I): C
inspected 11/5/2024. A record of filter inspection is maintained at the facility.	H. *Excursions, exceedances, or
	other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form



Period Covered by Compliance Certification: 01 / 01 / 24 (MM/DD/YY) to 12 / 31 / 24 (MM/DD/YY)

A. Attachment # or Permit Condition #: Attachment PO01006PC7-rev721, Condition No. 4(e)	D. Frequency of monitoring:
B. Description:	Routine
Requirement to use manufacturer's approved blast media in the Building 813 and Building 1497 blast cabinets	Course test reference method if applicable
	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Routine surveillance of the blast cabinets at Buildings 813 and 1497 confirms that only blast media that is approved by the manufacturer was used during the compliance	G. Compliance Status? (C or I): C
certification period.	H. *Excursions, exceedances, or
	other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form
9	
A. Attachment # or Permit Condition #: Attachment PO01006PC7-rev721, Condition No. 5	D. Frequency of monitoring:
B. Description: Requirement to keep a record of the annual survey and inspection of duct collector filters,	Monthly for abrasive usage and annually for opacity and filter inspection
and monthly and twelve month rolling sum of abrasive blast media used in Building 813 and 1497 blast cabinets	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Records of the annual inspection of duct collector filters, and monthly and twelve month rolling sums of abrasive blast media used in Building 813 and 1497 blast cabinets are	G. Compliance Status? (C or I): C
maintained by EDAQP.	H. *Excursions, exceedances, or
3.00).	other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form



A. Attachment # or Permit Condition #: Attachment PO1006PC8	D. Frequency of monitoring:
B, Description:	1 _{N/A}
Conditions associated with alternative operating scenarios	
	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C, Method of monitoring:	F. Currently in Compliance? (Y or N): Y
No surge condition or national security emergency was declared at any time during this compliance certification period.	G. Compliance Status? (C or I): C
a a	H. *Excursions, exceedances, or
^	other non-compliance? (Y or N): <u>N</u>
	*If yes, attach Deviation Summary Form



Period Covered by Compliance Certification: 01 / 01 / 24 (MM/DD/YY) to 12 / 31 / 24 (MM/DD/YY)

A. Attachment # or Permit Condition #: Attachment PO01006PC9-rev491	D. Frequency of monitoring:
B. Description: Requirement that any equipment designated as "Out of Service" in Tables 2, 3, and 4 of this permit is shut down and not operated. C. Method of monitoring: All the equipment designated as "Out of Service" in Tables 2, 3, and 4 of this permit were shut down and did not operate during the compliance period.	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A F. Currently in Compliance? (Y or N): Y G. Compliance Status? (C or I): C H. *Excursions, exceedances, or
	other non-compliance? (Y or N): N *If yes, attach Deviation Summary Form
A. Attachment # or Permit Condition #: Attachment PO01006PC9-rev491, Condition 2	D. Frequency of monitoring:
B. Description: Requirement that before operating any equipment designated as "Out of Service", a	As Needed
Modification to Part 70 Permit application be submitted.	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
A Modification to Part 70 Permit application is submitted before operating any equipment designated as "Out of Service".	G. Compliance Status? (C or I): C H. *Excursions, exceedances, or other non-compliance? (Y or N): N *If yes, attach Deviation Summary Form

;,

<u> 2</u>



A. Attachment # or Permit Condition #: Rule 50 Opacity,	D. Frequency of monitoring:
B. Description: Prohibition of visible emissions, requirement for routine surveillance and a formal opacity survey	Annual E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring: Surveillance of all equipment is conducted on a routine basis as required. A formal survey of all emission units at the facility was completed during the compliance certification period. A formal survey noted no visible emissions. Appendix C contains a copy of the	F. Currently in Compliance? (Y or N): Y G. Compliance Status? (C or I): C H. *Excursions, exceedances, or
formal survey results.	other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form



A. Attachment # or Permit Condition #: Attachment 54.B.1	D. Frequency of monitoring:
B. Description:	1 N/A
Sulfur emissions at point of discharge	147
	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Compliance with Attachment 54.B.1 is demonstrated by compliance with Rule 64 as noted in the Applicability section of Attachment 54.B.1.	G. Compliance Status? (C or I): C
2	H. *Excursions, exceedances, or
	other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form



Period Covered by Compliance Certification: <u>01</u> / <u>01</u> / <u>24</u> (MM/DD/YY) to <u>12</u> / <u>31</u> / <u>24</u> (MM/DD/YY)

A. Attachment # or Permit Condition #: Attachment 54.B.2	D. Frequency of monitoring:
B. Description:	N/A
Ground or sea level sulfur emissions at or beyond the stationary source property line	
e ×	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Compliance with Attachment 54.B.2 is demonstrated by screening level dispersion modeling tests referenced in the Ventura County Air Pollution Control District (VCAPCD) Memorandum dated May 23, 1996, authored by Terri Thomas of the VCAPCD.	G. Compliance Status? (C or I): C H. *Excursions, exceedances, or
36%	other non-compliance? (Y or N): N
2	*If yes, attach Deviation Summary Form



A. Attachment # or Permit Condition #: Attachment 55	D. Frequency of monitoring:
B. Description: Applicable requirements for activities capable of generating fugitive dust	Routine
	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
The Public Works Project Review Board requires that contractors who perform construction activities at Naval Base Ventura County and are capable of generating fugitive dust to	G. Compliance Status? (C or I): C
comply with the Ventura County Air Pollution Control District Rule 55 conditions.	H. *Excursions, exceedances, or
	other non-compliance? (Y or N): <u>N</u>
	*If yes, attach Deviation Summary Form



A. Attachment # or Permit Condition #: Attachment 55.1	D. Frequency of monitoring:
B. Description: Applicable requirements for paved and unpaved road activities	Routine
	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
The Public Works Project Review Board requires that contractors who perform road construction activities at Naval Base Ventura County to comply with the Ventura County Air	G. Compliance Status? (C or I): C
Pollution Control District Rule 55.1 conditions.	H. *Excursions, exceedances, or
	other non-compliance? (Y or N); <u>N</u>
	*If yes, attach Deviation Summary Form



A. Attachment # or Permit Condition #: Attachment 57.1	D. Frequency of monitoring:
B. Description:	N/A
Limit on emissions of particulate matter to 0.12 pounds per MMBTU of fuel input	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
According to an analysis of the facility by Ventura County Air Pollution Control District using Rule 57.B dated December 3, 1997 periodic monitoring is not necessary to demonstrate compliance with Rule 57.1 Compliance with other conditions of this permit is sufficient to ensure compliance with Rule 57.1.	G. Compliance Status? (C or I): C
	H. *Excursions; exceedances, or other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form



A. Attachment # or Permit Condition #: Rule 64	D. Frequency of monitoring:
B. Description:	Periodic
Sulfur Content of Fuels	
E 253	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable
E E E	N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Compliance with Rule 64.B.1 is demonstrated by the fact that P.U.C. regulated natural gas is the only gaseous fuel combusted at this facility. Compliance with Rule 64.B.2 is	G. Compliance Status? (C or I): C
demonstrated by the fact that the diesel fuel and reformulated gasoline combusted at this	H. *Excursions, exceedances, or
facility are California Air Resources Board certified. All of these fuels comply with the 0.5% sulfur content limits of Rule 64. Supporting document for purchase of CARB certified diesel	other non-compliance? (Y or N): <u>N</u>
is included in Appendix A. All of the fuels complied with the 0.5% sulfur content limits of Rule 64 during the compliance period.	*If yes, attach Deviation Summary Form



A. Attachment # or Permit Condition #: Attachment 74.6, Condition No. 1	D. Frequency of monitoring:
B. Description:	Periodic
Surface Cleaning and Degreasing Solvent ROC and/or Vapor Pressure	
	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Compliance with ROC and vapor pressure limits is ensured by the fact that all solvents must be approved by Environmental Division Air Quality Program (EDAQP) staff before	G. Compliance Status? (C or I): C
they can be issued and used by any Naval Base Ventura County (NBVC) entity or tenant organization aboard NBVC.	H. *Excursions, exceedances, or
	other non-compliance? (Y or N): <u>N</u>
	*If yes, attach Deviation Summary Form
A. Attachment # or Permit Condition #: Attachment 74.6, Condition Nos. 2 through 7	D. Frequency of monitoring:
	D. Frequency of Monitoring.
B. Description:	Periodic
Conditions relating to solvent handling procedures	
	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable
	N/A
	~
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Compliance with Conditions 2 through 7 of Attachment 74.6 is verified by means of routine surveillance of solvent activities that are carried out by EDAQP staff during routine visits to	G. Compliance Status? (C or I): <u>C</u>
subject facilities.	H. *Excursions, exceedances, or
	other non-compliance? (Y or N): <u>N</u>
	*If yes, attach Deviation Summary Form
A. Attachment # or Permit Condition #: Attachment 74.6, Condition No. 8	D. Frequency of monitoring:
B. Description:	Routine
Equipment and work practice requirements applicable to all cold cleaners (except remote reservoir type) Measurement of freeboard height, verification of initial boiling point, ROC	
content, and ROC composite partial pressure.	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable
	N/A
C. Method of monitoring	
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Routine inspection of solvent activities that are carried out by EDAQP staff confirmed that no non-remote reservoir cold cleaners exist.	G. Compliance Status? (C or I): C
	H. *Excursions, exceedances, or
	other non-compliance? (Y or N): <u>N</u>
	*If yes, attach Deviation Summary Form



A. Attachment # or Permit Condition #: Attachment 74.6, Condition No. 9	D. Frequency of monitoring:
B. Description: Equipment and work practice standards as applicable to remote reservoir cold cleaners	Routine
Measurement of freeboard height, verification of initial boiling point, ROC content, and ROC composite partial pressure	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Ongoing investigation has determined that all remote reservoir cold cleaners have either been removed from service or replaced with units that use either aqueous cleaning solutions or non-ROC solvents.	G. Compliance Status? (C or I): C H. *Excursions, exceedances, or
	other non-compliance? (Y or N): <u>N</u>
	*If yes, attach Deviation Summary Form
	X
A. Attachment # or Permit Condition #: Attachment 74.6, Condition No. 10	D. Frequency of monitoring:
B. Description: Conditions related to cold cleaning operation	Periodic
	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Compliance with Condition 10 of Attachment 74.6 is verified by means of routine surveillance carried out by EDAQP staff during routine visits to subject facilities.	G. Compliance Status? (C or I): C
P	H. *Excursions, exceedances, or other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form
A. Attachment # or Permit Condition #: Attachment 74.6, Condition Nos. 14 and 16	D. Frequency of monitoring:
B. Description: Recordkeeping requirements associated with surface cleaning and degreasing and routine	Periodic
surveillance to comply with Rule 74.6	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Compliance with the requirement to maintain a current material list showing the name, ROC and vapor pressure, and intended uses of each solvent material is accomplished by means of a database that records each issuance of a solvent material to any operation aboard NBVC. For each issuance of material, this database contains a reference to the applicable SDS sheet. The database also contains references to the recipient of the material, and ultimately to the screening sheet, which is the document that approved the material, and describes all intended uses. In addition, EDAQP staff performs routine inspection of the applicable solvent cleaning activities to ensure compliance with Rule 74.6.	G. Compliance Status? (C or I): C H. *Excursions, exceedances, or other non-compliance? (Y or N): N *If yes, attach Deviation Summary Form



A. Attachment # or Permit Condition #: Attachment 74.11	D. Frequency of monitoring:
B. Description: Natural gas-fired water heaters rated at less than 75,000 BTU/hr installed after July 1,	Upon Installation
2010	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring: Through the Public Works Project Review Board, installers of natural gas-fired water heaters are required to comply with conditions of Ventura County Air Pollution Control	F. Currently in Compliance? (Y or N): Y G. Compliance Status? (C or I): C
District Rule 74.11. In addition, a Standard Operating Procedure (SOP) was developed and implemented by the Environmental Division Air Quality Program (EDAQP). The SOP requires the installers of water heaters to obtain a copy of the certification document from the seller or manufacturer and submit it to the EDAQP for review and approval prior to purchase. Appendix C includes the result of a limited survey of natural gas-fired water heaters rated at less than 75,000 BTU/hr installed during this compliance certification period.	H. *Excursions, exceedances, or other non-compliance? (Y or N): N *If yes, attach Deviation Summary Form



A. Attachment # or Permit Condition #: Attachment 74.11.1	D. Frequency of monitoring:
B. Description: Natural gas-fired large water heaters and small boilers, steam generators and process heaters with a rated heat input capacity greater than 75,000 BTU/hr and less than or equal to 1,000,000 BTU/hr	Routine E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring: Through the Public Works Project Review Board, installers of natural gas-fired large water heaters, small boilers, steam generators, and process heaters are required to comply with conditions of Ventura County Air Pollution Control District Rule 74.11.1. In addition a Standard Operating Procedure (SOP) was developed and implemented by the Environmental Division Air Quality Program (EDAQP) which requires the purchasers or installers of such devices to obtain certification documents from the seller or manufacturer and submit them to the EDAQP for review and approval. Appendix C includes the result of a limited survey of natural gas-fired water heaters rated at greater than 75,000 BTU/hr and less than or equal to 1,000,000 BTU/hr installed during this compliance certification period.	F. Currently in Compliance? (Y or N): Y G. Compliance Status? (C or I): C H. *Excursions, exceedances, or other non-compliance? (Y or N): N *If yes, attach Deviation Summary Form



A. Attachment # or Permit Condition #: Attachment 74.22	D. Frequency of monitoring:
B. Description:	Routine
Natural Gas-Fired Fan-Type Central Furnaces	
	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Through the Public Works Project Review Board, installers of natural gas-fired fan-type central furnaces are required to comply with conditions of Ventura County Air Pollution	G. Compliance Status? (C or I): C
Control District Rule 74.22. In addition, a Standard Operating Procedure (SOP) was developed and implemented by the Environmental Division Air Quality Program (EDAQP) which requires the purchasers or installers of natural gas-fired fan-type furnaces to obtain certification documents from the seller or manufacturer and submit it to the EDAQP for review and approval.	H. *Excursions, exceedances, or other non-compliance? (Y or N): N *If yes, attach Deviation Summary Form



A. Attachment # or Permit Condition #: Attachment 74.1, Condition No. 1	D. Frequency of monitoring:
B. Description:	Routine
Requirement that abrasive blasting of moveable items take place within a permanent	
building	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable
×	N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
As a Navy policy, all abrasive blasting of moveable items must take place within an abrasive blast room or an abrasive blast cabinet equipped with a dust control device.	G. Compliance Status? (C or I): C
Routine surveillance of abrasive blasting operations is conducted to verify compliance.	H. *Excursions, exceedances, or
	other non-compliance? (Y or N): N
· · · · · · · · · · · · · · · · · · ·	*If yes, attach Deviation Summary Form
A. Attachment # or Permit Condition #: Attachment 74.1, Condition No. 2	D. Frequency of monitoring:
	D. Frequency of monitoring.
B. Description:	Per Operation
Requirement that permissible outdoor blasting take place using approved methods	E. Source test reference method, if applicable.
	Attach Source Test Summary Form, if applicable
	N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
All projects that involve permissible outdoor blasting are required to go through the Public Works Project Review Board. Such projects are reviewed by a member of the	G. Compliance Status? (C or I): C
Environmental Division Air Quality Program (EDAQP) to ensure compliance with Rule	H. *Excursions, exceedances, or
74.1.	other non-compliance? (Y or N): <u>N</u>
6	*If yes, attach Deviation Summary Form
A. Attachment # or Permit Condition #: Attachment 74.1, Condition Nos. 3 and 4	D. Frequency of monitoring:
B. Description:	Per Operation
Requirements for the blasting of pavement and stucco	
	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable
	N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
All projects that involve blasting of pavernent and stucco are required to go through the Public Works Project Review Board. All such projects reviewed by a member of EDAQP to	G. Compliance Status? (C or I): C
ensure compliance with Rule 74.1.	H. *Excursions, exceedances, or
8	other non-compliance? (Y or N): <u>N</u>
15	*If yes, attach Deviation Summary Form



A. Attachment # or Permit Condition #: Attachment 74.1, Condition No. 7	D. Frequency of monitoring:
B. Description: Requirement to monitor each abrasive blasting operation and keep records associated with permissible outdoor blasting	Per Operation E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
EDAQP requires all contractors to follow Rule 74.1 when conducting outdoor abrasive blasting operations. Contractors are required to submit the records specified in Condition 7 of Attachment 74.1 to the Environmental Division.	G. Compliance Status? (C or I): C H. *Excursions, exceedances, or
	other non-compliance? (Y or N): <u>N</u> *If yes, attach Deviation Summary Form



A. Attachment # or Permit Condition #: Attachment 74.2, Condition Nos. 1 and 2	D. Frequency of monitoring:
B. Description: VOC content limits for flat, nonflat, nonflat-high gloss, specialty, and industrial maintenance	Per Operation
architectural coatings	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
The Naval Base Ventura County (NBVC) Public Works Project Review Board requires contractors who perform architectural coating operations at NBVC to comply with the VOC	G. Compliance Status? (C or I): C
limits of Ventura County Air Pollution Control District (VCAPCD) Rule 74.2.	H. *Excursions, exceedances, or other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form
A. Attachment # or Permit Condition #: Attachment 74.2, Condition No. 3	D. Frequency of monitoring:
B. Description:	Routine
Requirement that all the architectural coating are applied directly from the containers, and any VOC-containing materials used for thinning and cleanup be stored in closed containers	
when not in use.	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable
	N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
The NBVC Public Works Project Review Board requires contractors to comply with conditions of VCAPCD Rule 74.2. In addition, hazardous material storage areas and	G. Compliance Status? (C or I): C
coating operations are routinely inspected by the Environmental Division Air Quality	H, *Excursions, exceedances, or
Program (EDAQP).	other non-compliance? (Y or N): N
<u> </u>	*If yes, attach Deviation Summary Form
A. Attachment # or Permit Condition #: Attachment 74.2, Condition No. 4	D. Frequency of monitoring:
B. Description:	Por Operation
Requirement to comply with the architectural coating VOC limits specified in Rule 74.2.B.1	Per Operation
	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable
	N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
The Public Works Project Review Board requires contractors who perform architectural	G. Compliance Status? (C or I): C
coating operations at NBVC to comply with the VOC limits of VAPCD Rule 74.2.	H. *Excursions, exceedances, or
	other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form



A. Attachment # or Permit Condition #: Attachment 74.2, Condition No. 5	D. Frequency of monitoring:
B. Description: Requirement to monitor each architectural coating operation, specify VOC compliant architectural coatings, and to maintain VOC records for the coatings used.	Per Operation E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring: The Public Works Project Review Board requires contractors who perform architectural coating operations at NBVC to comply with the VOC limits of VCAPCD Rule 74.2. The VOC records of architectural coatings are kept by EDAQP.	F. Currently in Compliance? (Y or N): Y G. Compliance Status? (C or I): C H. *Excursions, exceedances, or other non-compliance? (Y or N): N *If yes, attach Deviation Summary Form



Period Covered by Compliance Certification: <u>01</u> / <u>01</u> / <u>24</u> (MM/DD/YY) to <u>12</u> / <u>31</u> / <u>24</u> (MM/DD/YY)

A. Attachment # or Permit Condition #: Attachment 74.4	D. Frequency of monitoring:
B. Description:	Per Operation
Short-term cutback asphalt activities	
3	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
No cutback asphalt activities took place during the compliance certification period.	G. Compliance Status? (C or I): C
	H. *Excursions, exceedances, or
	other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form



A. Attachment # or Permit Condition #: Attachment 74.27	D. Frequency of monitoring:
B. Description: Short-term gasoline and ROC liquid storage tank degassing operations	Per Operation E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring: Through the Public Works Project Review Board, the Environmental Division Air Quality Program (EDAQP) staff is notified of any planned large projects that may involve emissions of air contaminants. The EDAQP staff reviews the applicability of air regulations	F. Currently in Compliance? (Y or N): Y G. Compliance Status? (C or I): C
to the project and inspects the activities, as needed.	H. *Excursions, exceedances, or other non-compliance? (Y or N): N *If yes, attach Deviation Summary Form



A. Attachment # or Permit Condition #: Attachment 74.28	D. Frequency of monitoring:
B. Description:	Per Operation
Short-term asphalt roofing operations	
	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
8	N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Through the Public Works Project Review Board, Environmental Division Air Quality Program (EDAQP) staff is notified of any planned large projects that may involve	G. Compliance Status? (C or I): C
emissions of air contaminants. The EDAQP staff reviews the applicability of air regulations	H. *Excursions, exceedances, or
to the project and inspects the activities, as needed.	other non-compliance? (Y or N): <u>N</u>
R	*If yes, attach Deviation Summary Form



A. Attachment # or Permit Condition #: Attachment 74.29	D. Frequency of monitoring:			
B. Description: Short-term soil decontamination operations	Per Operation E. Source test reference method, if applicable.			
	Attach Source Test Summary Form, if applicable N/A			
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y			
No short-term soil decontamination activities occurred at the Naval Base Ventura County Port Hueneme site during this compliance certification period.	G. Compliance Status? (C or I): C			
	H. *Excursions, exceedances, or other non-compliance? (Y or N): N			
	*If yes, attach Deviation Summary Form			



A. Attachment # or Permit Condition #: 40CFR61.M	D. Frequency of monitoring:
B. Description:	Periodic
Short-term asbestos demolition or renovation activities - requirements for inspection, notification, removal, and disposal procedures	
Troumbatton, Territoria, and disposal processaries	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable
	N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
All short-term demolition and renovation activities undertaken at Naval Base Ventura County (NBVC) are performed by contractors. The Public Works Department at NBVC	G. Compliance Status? (C or I): C
requires contractors to meet all inspection, notification, removal, and disposal requirements of Attachment 40 CFR 61.M as a condition of contract. In addition, the NBVC Asbestos	H. *Excursions, exceedances, or
Program Manager routinely monitors asbestos abatement contractor activity, and ensures	other non-compliance? (Y or N): <u>N</u>
that all requirements for inspection, notification, removal, and disposal are met as required.	*If yes, attach Deviation Summary Form



A. Attachment # or Permit Condition #: General Part 70 Permit	D. Frequency of monitoring;
B. Description:	Periodic
General Part 70 Permit Requirements	
	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Naval Base Ventura County Environmental Division personnel have conducted regular inspections of permitted sources, retained records as required, and reviewed records for compliance. Annual compliance inspection at Navy Exchange Gas Station revealed a failure	G. Compliance Status? (C or I): <u>I</u>
in Vapor to Liquid Ratio test at fueling point numbers 1, 3, 4, 5, and 10 in accordance with	H. *Excursions, exceedances, or
Rule 70.E.1. NOV #25211 was issued. Repairs were made the same day and later passed	other non-compliance? (Y or N): Y
the test. Breakdown of a non-resettable digital hour meter due to a battery malfunction occurred for emergency standby engine 435 BHP, Cummins Model NT855G6, Serial No 30346676 located at Bidg. 382. The failed non-resettable digital hour meter was removed and	*If yes, attach Deviation Summary Form
replaced with a new non-resettable digital hour meter. Annual data collection for compliance	<u>*</u>
certification revealed a failure to have either a passing oil analysis conducted or complete an oil and filter change as described in 40CFR63ZZZZN3, Condition 1.a. for Bldg. 225 - 170 BHP	
Cummins and Bidg. 527 - 545 BHP Caterpillar. NOV #24490 was issued. Maintenance to the engines was performed and results were provided to the district on 3/25/2024.	



ANNUAL COMPLIANCE CERTIFICATION DEVIATION SUMMARY FORM

A. Attachment # or Permit Condition #: 74.9N7, Condition No. 2; ATCM Engine N2, Condition No. 2 and 3(a&b); 40CFR63ZZZZN3, Condition No. 3; General Part 70 Permit	B. Equipment description: Emergency Standby Engir Model NT855G6, Serial No 382		C. Deviation Period: Date & Time Begin: September 30, 2024, at 0942 End: October 1, 2024 at 0700 When Discovered: Date & Time
D. Parameters monitored: Requirement that each emergency standby engine shall be equipped with an operating, non-resettable, elapsed-time hour meter	E. Limit: Maintain operating, non-re meter	settable, elapsed-time hour	September 30, 2024, at 0942 F. Actual: Failure of a non-resettable, elapsed-time hour meter.
G. Probable Cause of Deviation: Breakdown of a non-resettable digital ho malfunction occurred.	our meter due to a battery	meter was removed and repl meter. NBVC monitored the indicate no further discrepan recordkeeping. Notification w	breakdown, the failed non-resettable digital hour laced with a new non-resettable digital hour efficacy of the completed repairs. Observations cies. Facts of this matter were documented for was made to notifications@vacapcd.org covery and 10/7/2024 for corrective actions



ANNUAL COMPLIANCE CERTIFICATION DEVIATION SUMMARY FORM

A Attachment # or Permit Condition #:	B. Equipment description		C. Deviation Period: Date & Time			
70-01006-Exchange-491,501, Condition	Healy Phase II EVR system	-	Begin: November 14, 2024, at 1400			
No. 3.8			End: November 14, 2024, at 1644			
General Part 70 Permit			When Discovered: Date & Time			
		November 14, 2024, at 1400				
D. Parameters monitored:	E. Limit:		F. Actual:			
The vapor to liquid (V/L) ratio of the system on fueling point numbers 1, 3, 4, 5, and 10	and operated in the same m	quipment shall be maintained	Fueling point numbers 1, 3, 4, 5, and 10 were not maintained and operated in the same manner as when certified by CARB.			
G. Probable Cause of Deviation:		H. Corrective actions taken:				
Failure of the V/L ratio testing is due to u	nknown circumstances,	hoses were replaced on fueli	avy Exchange Gas Station initially failed. The ng points numbers 1, 3, 4, 5, and 10 during the passed. NOV #25211 was issued.			
<u> </u>						



ANNUAL COMPLIANCE CERTIFICATION DEVIATION SUMMARY FORM

A. Attachment # or Permit Condition #: 40CFR63ZZZZN3, Condition 1.a General Part 70 Permit	B. Equipment description Stationary engines: Bldg. 22 Bldg. 527 - 545 BHP Caterp	25 - 170 BHP Cummins and	C. Deviation Period: Date & Time Begin: October 12, 2023 End: March 25, 2024, at 0935 When Discovered: Date & Time March 4, 2024, at 1411
D. Parameters monitored: Oil and oil filter		first. An oil analysis program 6625(i) can be utilized in order	F. Actual: The oil and filter were not maintained as described in 40CFR63ZZZZN3, Condition 1.a.
G. Probable Cause of Deviation: Investigation for probable cause of devia	***	H. Corrective actions taken:	was performed and results were provided to the



Period Covered by Compliance Certification: <u>01</u> / <u>01</u> / <u>24</u> (MM/DD/YY) to <u>12</u> / <u>31</u> / <u>24</u> (MM/DD/YY)

A. Attachment # or Permit Condition #: General Permit to Operate	D. Frequency of monitoring:
B. Description:	Periodic
General Permit to Operate conditions	
,	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Routine inspections by Environmental Division Air Quality Program staff ensure that permits are posted and other general permits to operate conditions are complied with.	G. Compliance Status? (C or I): C
	H. *Excursions, exceedances, or
	other non-compliance? (Y or N): N
	*If yes, attach Deviation Summary Form



A. Attachment # or Permit Condition #: 40CFRPart 68	D. Frequency of monitoring:
B. Description:	N/A
Accidental Release Prevention and Risk Management Plans	
	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable N/A
(*)	
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
No substances regulated by the California Accidental Release Prevention (ARP) Program or the federal Risk Management Plan (RMP) were contained in a process in a quantity that	G. Compliance Status? (C or I): C
exceeded the respective threshold for California ARP Program or federal RMP.	H. *Excursions, exceedances, or
	other non-compliance? (Y or N): <u>N</u>
	*If yes, attach Deviation Summary Form



A. Attachment # or Permit Condition #: 40CFR82	D. Frequency of monitoring:
B. Description:	Periodic
Protection of stratospheric ozone.	T Should
	E. Source test reference method, if applicable. Attach Source Test Summary Form, if applicable
	N/A
C. Method of monitoring:	F. Currently in Compliance? (Y or N): Y
Naval Base Ventura County (NBVC) Port Hueneme has an established Ozone Depleting Substances (ODS) management policy and maintains records of all ODS procured, utilized	G. Compliance Status? (C or I): C
and recovered from units subject to the record keeping requirements of 40 CFR Part 82, Subpart F. NBVC also verifies all technician certifications, utilizes compliant ODS recovery equipment, follows safe disposal protocols for ODS, adheres to all ODS executation.	H. *Excursions, exceedances, or other non-compliance? (Y or N): N
requirements, and follows leak detection and management protocols outlined in 40 CFR Part 82.	*If yes, attach Deviation Summary Form
Subpart F. NBVC also verifies all technician certifications, utilizes compliant ODS recovery equipment, follows safe disposal protocols for ODS, adheres to all ODS evacuation requirements, and follows leak detection and management protocols outlined in 40 CFR	other non-compliance? (Y or N): <u>N</u>

Appendix A

NBVC Port Hueneme Supporting Documentation for Use of Compliant Fuel

STRAIGHT BILL OF LADING - SHORT FORM - ORIGINAL - NOT NEGOTIABLE

RECEIVED, subject to the constructions and training field battle at effect on the date of the same of this Bit of Leding the primarity described below in accurate 1,000 order, except as noted incortains and constitut of contains of packages unknown), marked, consigned, and destined as indicated below, which add contains are consistent of packages unknown), marked, consigned, and destined as indicated the contains as most contained as the contained as most contained as the contained as the contained as the most packages unknown), marked, consigned, and graves to a carry for the small older of address of the contained as the con





1920 Lugger Way • Long Beach, CA 90813 • 562-435-8364

CAUTION: SEE REVERSE SIDE FOR HAZARD WARNING

BILLING ADDRESS: Falcon Fuels Contract 7300 Alondra Blvd Suite 204 P.O. Box 347 Paramount, CA 90723

SHIPPING ADDRESS: Falcon Fuels RD Contract

01/22/24	лме IN 05:38	05:57	Trailer License Plai		PPED FROM AY • LONG BEACH	_	k License A 4VJ82			STOMER NO 315601 ***	970061
AATW	AATW Agua Amarilla Trasport INC 3001 PRODUCT DESCRIPTION					1	YEHICLE NO 150			CUSTOMER EMERG	and the second second
						ADD+	TEMP G		RAV	GROSS GAL.	NET GAL
Renewable R95B5 ULSD 15PPM Max				3,311	***************************************	266	62.4	48.	0	7,609	7,598
na 1993, DIES	SEL FUEL, 3	, PG III				82				19	
	ž			· §	3			i		v s *	
	* 8				60						
			(*)		e.		¹⁸ s			(3)	
	(27		a (
			(8 II	¢:							
			e .								
28		&	£		⊕ B:						9
	(*)		*ADDITIVE INJEC	CTED (OUNCES)		1	TOTAL M	men (Marie	Pe-	7,609	7,598
D.O.T. HAZARDOL	IS MATERIAL DE	SCRIPTION								7,609 (Gross
ta.		1 Carg	o Tank					Р(D #:		21
MESSAGES Petro-Diamond ChemTel Cont	d Incorporate ract # MIS00	ed EPA reg 004859	pistration # 4088.								
Gasoline and	diesel fuel m	eet all CAR	RB & EPA require	ements.							
This is to certify that packaged, marked, an to the applicable regu	d labeled and are in p	roper condition for	rly classified, described, transporation according in.	I this commodity	that the cargo tank s . If this shipment mo en shipper and carr r.	ves, in oth	er than ship	oper's v	ehicle.	the terms will be	those ist of the
TRA	NSPORTATION Call CHEM		* 1	Filiberto Jr	Hernandez				8	-	
1-8	00-25	5-392	4					2		·	
	24 hours a day, 7 d	ays a week			IDRIVER NAME			~		(DRIVER SIGNATUR	E)

STRAIGHT BILL OF LADING - SHORT FORM - ORIGINAL - NOT NEGOTIABLE





CAUTION: SEE REVERSE SIDE FOR HAZARD WARNING

BILLING ADDRESS: Falcon Fuels Contract 7300 Alondra Blvd Suite 204 P.O. Box 347

SHIPPING ADDRESS: Falcon Fuels RD Contract

04/25/24	05:21	11ME OUT 05:38	Trailer License Plate CA 1VE8361 1920 LU	SHIPPED FRO						CUSTOMER NO. CA 315601 ***		
CARRIER CODE	Alliance P	CARRIER NAME DRIVER NO. 236 010				VEHICLE NO. 152015201				983447 SENCY PHONE		
7			UCT DESCRIPTION			ADD*	TEMP	GR	AV GRO	NET GAL		
Renewable R9 na 1993, DIES			ax .		ě	73	67.9	47.8	3	6,008	5,982	
			e)					١.	1*			
	e				.27							
							_ (8)					
27		5)	2						a	×	<u> </u>	
8												
ā!	8			Ŀ								
DOT WATEROOM	O LITERAL DE		*ADDITIVE INJECTED (O	UNCES)		1	TOTAL =		-	6,008	5,982	
D.O.T. HAZARDOU	S MATERIAL DI	SCRIPTION) @	Section					(10)	6,008	Gross	
		2 Carg	go Tanks	*1				PC) # ;			

Petro-Diamond Incorporated EPA registration # 4088. ChemTel Contract # MIS0004859

Gasoline and diesel fuel meet all CARB & EPA requirements.

This is to certify that the above — named materials are properly of packaged, marked, and tabeled and are in proper condition for tran	lassified, described,
price agost mention and enough and an proper condition for tran	speration according
to the applicable regulations of the Department of Transportation.	T - 3- 5

Carrier certilies that the cargo tank supplied for this shipment is a proper container for the transportation of this commodity. If this shipment moves, in other than shipper's vehicle, the terms will be those (a) of the contract between shipper and carrier or (b) the terms of the lawfully applicable tariffs if the carrier is a common carrier.

TRANSPORTATION EMERGENCY Call CHEMTEL

1-800-255-3924

Oscar Floreshagen	Oscar	Fic	pres	hag	gen
-------------------	-------	-----	------	-----	-----

IDRIVER NAME (DRIVER SIGNATURE)

STRAIGHT BILL OF LADING - SHORT FORM + ORIGINAL - NOT NEGOTIABLE

RECEIVED subject to the classifications and ignifically lifed tatiffs in effect on the date of the assure of this Bib of Lading.

The property described below in apparent pool order except as noted too literia and condition of contents of packages unknown), marked consigned, and destined as indicated below, which said cannot the word cannot below in apparent pool offer except as noted too interest and contents as the assurance of the property indicated and thoughout this contract as meaning any person or exposition in possible on the property and the contract agrees to carry by its assurance of the property and any of conditions of a discount of the property of the contract agrees of the property over all or any portion of said contracts to contract below to participate and to each party all any time internsion in as or any of said property, that exity service to be performed retrieved by the subject to all the terms and conditions of the fallowing property of the contract below to the performed retrieved by the performance that the subject to all the terms and conditions of the said that is a motion cannot straight all the said terms and conditions of the said that is a motion cannot subject to the applicable makes cannot cannot cannot all the terms and conditions are hereby agreed to by the shaper and accepted for himself and his assigns.



PETRO (DIAMOND

1920 Lugger Way • Long Beach CA 90813 • 562-435-8364

CAUTION: SEE REVERSE SIDE FOR HAZARD WARNING

BILLING ADDRESS: Falcon Fuels Contract 7300 Alondra Blvd Suite 204 P.O. Box 347 Paramount, CA 90723

SHIPPING ADDRESS: Falcon Fuels RD Contract

04/26/24	TIME IN 05:47	TIME OUT 06:04		PED FROM AY • LONG BEACH	_	k License F A 4VJ829	_ 1	315601 ***	983667
AATW	Agua Ama		carrier name Driver no ort INC 3001			VEHICLE NO 15 0		CUSTOMER EMERGENCY PHONE	
		PROD	UCT DESCRIPTION		ADD*	TEMP	GRAV	GROSS GAL	NET GAL
Renewable R9	5B5 ULSD 1	5PPM Ma	XX		100	68.2	47.8	7,607	7,571
na 1993, DIES	EL FUEL, 3	, PG III					·		
	ā							221	
			*ADDITIVE INJECTED (OUNCES)		T	OTAL ==	nu di tuta	7,607	7,571

7.607 Gross

1 Cargo Tank

PO #:

MESSAGES
Petro-Diamond Incorporated EPA registration # 4088. ChemTel Contract # MIS0004859

Gasoline and diesel fuel meet all CARB & EPA requirements.

This is to certify that the above — named materials are properly classified, described, packaged, marked, and labeled and are in proper condition for transporation according to the applicable regulations of the Department of Transportation

Carrier certifies that the cargo tank supplied for this shipment is a proper container for the transportation of this commodity. If this shipment moves, in other than shipper's vehicle, the terms will be these (a) of the contract between shipper and carrier or (b) the terms of the lawfully applicable tariffs if the carrier is a common carrier.

TRANSPORTATION EMERGENCY Call CHEMTEL


1-800-255-3924 24 hours a day, 7 days a week

(DRIVER NAME)

Filiberto Jr Hernandez

(DRIVER SIGNATURE)

STRAIGHT BILL OF LADING - SHORT FORM - ORIGINAL - NOT-NEGOTIABLE







Caution: see reverse side for hazard warning

BILLING ADDRESS: Falcon Fuels Contract 7300 Alondra Blvd Suite 204 P.O. Box 347 Paramount, CA 90723

This is to cortify that the above — named materials are properly classified, described, packaged, marked, and labeled and are in proper condition for transportation according to the applicable regulations of the Department of Transportation.

TRANSPORTATION EMERGENCY

Call CHEMTEL 1-800-255-3924 24 hours a duy, 7 days a week

SHIPPING ADDRESS: Falcon Fuels RD Contract

Carrier certifies that the cargo tank supplied for this shipment is a proper container for the transportation of this commodity. If this shipment moves, in other than shipper's vehicle, the terms will be those (a) of the contract between shipper and carrier or (b) the terms of the lawfully applicable tariffs if the carrier is a

(DRIVER SIGNATURE)

DATE SHIPPED 10/28/24	03:55	TIME OUT 04:17	Trailer License Pla	te SHIPF	PED FROM	Truc	k License F A 4AS11	2,000,000	CUSTOMER NO. 315601 ***	B/E NO 12749
CAFRIER CODE	Alliance P			ansport 236 012			/EHICLE NO /10	1 0,	CUSTOMER EMERGENCY PHONE	
			UCT DESCRIPTION			ADD*	TEMP	GRAV	GROSS GAL	NET GAL
Renewable R9				W.		98	71.6	49.7	7,500	7,449
na 1993, DIES	EL FUEL, 3,	PG III					2			1.,
			*	•0						1
		21		Or .						
W. **				¥2						
		·					ii ii	2		02
0.				*:						
			2.	21.					× .	
		2.7					•81		388	
	, ×									
			2							
					8					
			AND TO THE INCIDENT	OTES (0) 11 15 15 15 15 15 15 15 15 15 15 15 15					7,500	7.440
D.O.T. HAZARDOUS	MATERIAL DE	SCRIPTION	"ADDITIVE INJEC	CTED (OUNCES)		ļ	OTAL ==	-	7,500	7,449
									7,500 (Gross
	M	1 Carg	o Tank					PO#		W.
MESSAGES Petro-Diamond ChemTel Contr	Incorporate act # MIS00	d EPA reg 04859	gistration # 4088							
Gasoline and di	iesel fuel me	et all CAF	RB & EPA require	ements		*		TV.		

common carrier.

Mauricio Valadez

IDRIVER NAME

Appendix B

NBVC Port Hueneme Tune up/Emission Screening Summary Forms

ii â

	Na	val Base Ve	ntura Cou	nty Boiler E	mission Sc	reening Report
				Boiler 1		
Location: Port Hueneme Bldg: 1479-1						Permit: 1006
Make: Lo	chinvar			Rating: 1.44 MMBTU/Hr		
				Analyzer		
Make: Te	esto		Model: 330-1-LX			Cal. Date: August 20, 2023
		-56		Screening		
Date: May 8, 2024			Time: 1009			Weather: Sunny
	Raw data		@ 3% O2 Notes: PA			SS
O2 %	CO ppm	NOx ppm	CO ppm	NOx ppm		
7.9	25	3	34	4		
	1- 1 - H	Limit	400	20		

testo 330-1 03241694/USA V2. 25 10:09:36 05/08/2024 Location SITE Combustion Type 2nd combustion type ADDRESS Natural Gas Fuel: 3.0 % 02ref. 11.7 % CO2 Max: Combustion test 34 ppm cCO NOx 3 ppm NO2 addition 3.0 % Oxygen 7.9 % 7. 28 <u>%</u> 257. 7 F CO2 Temp, stack 84.5 % Eff. net 60.8 % Excess air cN0x 4 ppm cNO 4 ppm CO 25 ppm

NO

3 ppm

	Na	val Base Ve	ntura Cou	nty Boiler E	mission Sci	reening Report		
				Boiler 2				
Location:	Port Huene	me	Bldg: 1479	9-2		Permit: 1006		
Make: Lo	chinvar		Model: CF	N1442PM		Rating: 1.44 MMBTU/Hr		
				Analyzer				
Make: Testo			Model: 330-1-LX			Cal. Date: August 20, 2023		
				Screening				
Date: May 8, 2024 Tim			Time: 100	1		Weather: Sunny		
	Raw data	Raw data @ 3% O2 Notes: P				SS		
O2 %	CO ppm	Nox ppm	CO ppm	Nox ppm				
8.7	29	2	43	3				
		Limit	400	20		2		

SITE Combustion Type 2nd combustion type

ADDRESS

Fuel: Natural Gas 02ref. 3.0 % CO2 Max: 11.7 %

Combustion test

43 ppm cC0 NOx 2 ppm 3.0 % NO2 addition 8.7 % 0xygen 6.83 % CO2 253.4 °F Temp. stack 84.2 % Eff. net 71.3 % Excess air 3 ррш cN0x 3 ррш cN0 29 ppm CO 2 ppm NO

Appendix C

NBVC Port Hueneme Formal Surveys & Engines Hours of Operations

5 × 6

NBVC Port Hueneme Stationary Standby Engines Emergency and Maintenance 12-Month Rolling Sum Hours of Operation

NBVC Port Hueneme Stationary Standby Engines 2024 Emergency Hours of Operation 12-Month Rolling Sum Report

Permit Description	Model #	Serial #		יופו	Foh	Eob Mar Anr) V	May	May Inn		217	200	2	Non	[2
1490 BHP Cummins	QST30-G5	37235098	2 2 2 2 2	0.0	8.4	0.0	000	0.0	0.0	0.0		000	000	-	300
252 BHP Cummins	6CTAA8.3-G2	46261737	22	0.0	4.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
170 BHP Cummins	6BTA5.9-G4	46555763	225	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
56 BHP Cummins	B3.3-G1	6800962	372	0.0	4.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
435 BHP Cummins	NT855G6	30346676	382	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
585 BHP Detroit	6V92TA	80637405	437	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
545 BHP Caterpillar	3412-D1	389S5953	527	0.0	4.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
90 BHP Cummins	4BT3.9-G4	42266702	810	0.2	5.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
285 BHP Cummins	6CTAA8.3-G3	46350107	1000	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
217 BHP Caterpillar	C-6.6	E6M01866	1300	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
173 BHP Cummins	QSB5-G13	B200737795	1387	0.0	1.1	0.0	0.0	4.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	R 1238A36 12V														
985 BHP Detroit	2000 G44	5352006058	1388	0.0	0.0	0.0	0.0	0.0	0.0	0.0	9.3	0.0	0.0	0.0	0.0
599 BHP Caterpillar	3406	1LS01484	1388	0.0	0.0	0.0	0.0	2.0	0.0	0.0	9.5	0.0	0.0	0.1	0.1
324 BHP Cummins	QSB7-G5-NR3	73759244	1402	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	QSL/QSL9-G7												£		
464 BHP Cummins	NTR3	1190634556	1412	29.3	4.6	0.0	0.0	0.0	0.0	7.4	0.0	0.0	0.0	0.0	0.0
90 BHP Cummins	4BT3.9-G4	4626695	1440	0.0	4.7	0.0	0.0	4.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0
145 BHP Cummins	QSB5-G3 NR3	73391959	1443	0.0	4.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
96 BHP Caterpillar (Perkins C4.4LC	sC4.4LC	E5G13580	1445	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
63 BHP Perkins	LD70295	U733229B	1512B	0.0	4.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
161 BHP Perkins	C4.4	E5G00789	1524	0.0	4.7	0.0	0.0	4.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0
585 BHP Detroit	6V92TA	WA504448	1526	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
755 BHP Cummins	QSX15-G9	79914017	5035	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
									l					ĺ	

NBVC Port Hueneme Stationary Standby Engines 2024 Maintenance Hours of Operation 12-Month Rolling Sum Report

			- L				2								8
Permit Description	Model #	Serial #	BLDG	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1490 BHP Cummins	QST30-G5	37235098	2	0.0	0.0	0.0	0.0	0.0	1.0	0.0	0.0	0.0	0.0	1.0	0.0
252 BHP Cummins	6CTAA8.3-G2	46261737	22	0.0	0.0	0.2	0.8	0.2	0.0	0.0	0.2	0.2	0.0	0.2	0.0
170 BHP Cummins	6BTA5.9-G4	46555763	225	0.2	0.3	0.5	0.5	0.1	0.0	0.1	0.0	0.3	0.0	0.2	0.0
56 BHP Cummins	B3.3-G1	6800962	372	0.0	0.0	0.2	0.5	0.2	0.0	0.0	0.2	0.2	0.0	0.0	0.7
435 BHP Cummins	NT855G6	30346676	382	0.2	0.2	0.2	0.4	0.0	0.0	0.0	0.2	0.0	0.2	0.0	0.2
585.BHP Detroit	6V92TA	80637405	437	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
545 BHP Caterpillar	3412-D1	389S5953	527	0.3	0.0	0.2	0.0	0.2	0.0	0.0	7.9	0.2	0.0	0.0	0.2
90 BHP Cummins	4BT3.9-G4	42266702	810	2.7	0.0	1.9	1.3	1.1	0.0	1.7	0.2	1.6	0.0	1.7	8.0
285 BHP Cummins	6CTAA8.3-G3	46350107	1000	0.3	0.0	0.2	0.4	0.2	0.0	0.2	0.0	0.0	0.2	0.2	0.0
217 BHP Caterpillar	C-6.6	E6M01866	1300	0.5	0.2	0.2	0.7	0.2	0.0	0.0	0.0	0.2	0.0	0.3	0.0
173 BHP Cummins	QSB5-G13	B200737795	1387	0.0	0.0	0.2	0.2	0.0	0.2	0.0	0.3	0.0	0.3	0.2	0.0
	R 1238A36 12V														
985 BHP Detroit	2000 G44	5352006058	1388	0.5	0.3	0.0	1.3	0.0	0.8	0.0	0.1	0.0	0.3	0.3	0.0
599 BHP Caterpillar	3406	1LS01484	1388	2.7	0.3	0.8	0.3	8.0	0.3	0.3	0.0	0.0	0.3	0.4	0.2
324 BHP Cummins	QSB7-G5-NR3	73759244	1402	0.5	0.0	0.4	1.1	0.0	0.3	0.3	0.4	0.5	0.0	2.0	4.0
	QSL/QSL9-G7														
464 BHP Cummins	NTR3	1190634556	1412	1.0	1.7	1.1	1.3	1.0	1.0	0.0	2.5	1.0	4.1	1.2	1.1
90 BHP Cummins	4BT3.9-G4	4626695	1440	0.2	0.0	0.2	0.0	0.0	0.0	4.0	0.3	0.0	0.2	0.0	0.3
145 BHP Cummins	QSB5-G3 NR3	73391959	1443	0.2	0.0	0.2	0.3	0.2	0.0	0.0	0.0	9.0	0.0	0.2	0.0
96 BHP Caterpillar (Perkins C4.4LC	SC4.4LC	E5G13580	1445	0.0	0.0	0.0	0.0	0.0	0.0	3.6	0.0	1.0	0.0	0.0	1.2
63 BHP Perkins	LD70295	U733229B	1512B	0.3	0.0	0.3	4.0	0.2	0.0	0.4	0.0	0.5	0.0	0.5	0.0
161 BHP Perkins	C4.4	E5G00789	1524	0.2	0.0	0.3	0.5	0.0	0.3	0.0	0.2	0.4	0.0	0.3	0.0
585 BHP Detroit	6V92TA	WA504448	1526	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
755 BFP Cummins	QSX15-G9	79914017	5035	0.0	0.0	0.0	0.1	0.0	0.0	0.1	0.2	0.0	0.3	0.2	0.0

NBVC Port Hueneme Stationary Standby Engines Annual Report Form

in the second se

EMERGENCY DIESEL ENGINE ANNUAL REPORT FORM REPORTING PERIOD: JANUARY 1 TO DECEMBER 31, 2024 PERMIT NO: 01006 - NAVAL BASE VENTURA COUNTY

Engine BHP/Make	Engine Model Number	Engine Serial Number	Location	Hour Meter Reading on 1/3/2024	Hour Meter Reading on 1/2/2025	Total M&T Hours in 2024	Total Emergency Hours in 2024	Total Hours in 2024
1490 BHP Cummins	QST30-G5	37235098	2	397.2	404.0	2.0	4.8	6.8
252 BHP Cummins	6CTAA8.3-G2	46261737	22	386.4	392.7	1.8	4.5	6.3
170 BHP Cammins	6BTA5.9-G4	46555763	225	274.6	276.2	1.6	0.0	1.6
56 BHP Cummins	B3.3-G1	6800962	372	491.0	496.9	1.7	4.2	5.9
435 BHP Cummins	NT855G6	30346676	382	18.6	0.4	1.6	0.0	1.6
585 BHP Detroit	6V92TA	80637405	437	324.9	324.9	0.0	0.0	0.0
545 BHP Caterpillar	3412-D1	389S5953	527	41.0	54.3	9.0	4.3	13.3
90 BHP Cummins	4BT3.9-G4	42266702	810	454.2	472.8	13.0	5.6	18.6
285 BHP Cummins	6CTAA8.3-G3	46350107	1000	283.5	285.2	1.7	0.0	1.7
217 BHP Caterpillar	C-6.6	E6M01866	1300	240.4	242.4	2.0	0.0	2.0
173 BHP Cummins	QSB5-G13	B200737795	1387	98.6	105.9	1.4	5.9	7.3
985 BHP Detroit	R 1238A36 12V 2000 G44	5352006058	1388	126.7	139.6	3.6	9.3	12.9
599 BHP Caterpillar	3406	1LS01484	1388	309.3	327.0	6.1	11.6	17.7
324 BHP Cummins	QSB7-G5-NR3	73759244	1402	93.7	9.66	5.9	0.0	5.9
464 BHP Cummins	QSL/QSL9-G7 NTR3	1190634556	1412	203.3	258.9	14.3	41.3	55.6
90 BHP Cummins	4BT3.9-G4	4626695	1440	476.2	487.4	1.6	9.6	11.2
145 BHP Cummins	QSB5-G3 NR3	73391959	1443	259.4	265.6	1.7	4.5	6.2
96 BHP Caterpillar (Perkins)	C4.4LC	E5G13580	1445	1.5	7.3	5.8	0.0	5.8
63 BHP Perkins	LD70295	U733229B	1512B	360.7	367.7	2.6	4.4	7.0
161 BHP Perkins	C4.4	E5G00789	1524	149.8	161.6	2.2	9.6	11.8
585 BHP Detroit	6V92TA	WA504448	1526	227.2	227.2	0.0	0.0	0.0
755 BHP Cummins	QSX15-G9	79914017	5035	267.5	268.4	6.0	0.0	0.0

NBVC Port Hueneme Portable Engines Operation

SEV SEV

Permitted Portable Engines Emergency and Non Emergency/Maintenance Hours of Operation Record Permit No: 01006 - Naval Base Ventura County, Port Hueneme 2024

	51-2	51-26066	51-2	51-26067	51-2	51-28008
	Emergency	Maintenance/ Non Emergency	Emergency	Maintenance/ Non Emergency	Emergency	Maintenance/ Non Emergency
January	0.0	0.0	0.0	0.0	0.0	0.0
February	0.0	0.0	0.0	0.0	0.0	0.0
March	0.0	0.0	0.0	0.0	0.0	0.0
April	0.0	0.0	0.0	0.0	0.0	0.0
May	0.0	0.0	0.0	0.0	0.0	0.0
June	0.0	0.0	0.0	0.0	0.0	0.0
July	0.0	0.0	0.0	0.0	0.0	0.0
August	0.0	0.0	0.0	0.0	0.0	0.0
September	0.0	0.0	0.0	0.0	0.0	0.0
October	0.0	0.0	0.0	0.0	0.0	0.0
November	0.0	0.0	0.0	0.0	0.0	0.0
December	0.0	0.0	0.0	0.0	0.0	0.0

NBVC Port Hueneme Opacity Survey

at a second of the second of t

¥

Equipment Category	Description of Equipment in Permit Table (abbreviated)	Date of Equipment Inspection	Time of Equipment Inspection	Opacity Noted (Y/N)	Operating During Inspection (Y/N)	Comments
Boiler	8.4 MMBTU Superior, Wharf 3	N/A	N/A	N/A	N/A	Out of Service during the Compliance period
Boiler	8.4 MMBTU Superior, Wharf 4	N/A	N/A	N/A	N/A	Out of Service during the Compliance period
Boiler	1.6 M NCEL burner, Building- 1100	11/5/2024	1113	N	N	×
Boiler	2.1 MMBTU Hurst, Building 1419	11/5/2024	0947	N	N	
Boiler	4.8 MMBTU GL1800 Aircraft Deicer Boiler, Building 1420	11/5/2024	1213	N	N	
Boiler	4.8 MMBTU GL1800 Aircraft Deicer Boiler, Building 1420	11/5/2024	1213	N	N	
Boiler	1.44 MMBTU Lochinvar, Building 1479	11/5/2024	1123	N	Υ	
Boiler	1.44 MMBTU Lochinvar, Building 1479	11/5/2024	1123	N	Υ	
Crane	173 BHP Daimler/Chrysler, 82-05666	11/5/2024	1137	N	N	
Crane	322 BHP Daimler/Chrysler, 82-05721	11/5/2024	1137	N	N	a a
Sweeper	134 BHP John Deere	11/15/2024	0815	N	N	Located at Point Mugu
Sweeper	69.7 BHP Yanmar Sweeper Aux	11/5/2024	1148	N	N	
Portable Generator	165 BHP John Deere Diesel Generator, 51-26066	11/15/2024	0827	N	N	Located at Point Mugu
Portable Generator	165 BHP John Deere Diesel Generator, 51-26067	11/15/2024	0824	N	N	Located at Point Mugu

Equipment Category	Description of Equipment in Permit Table (abbreviated)	Date of Equipment Inspection	Time of Equipment Inspection	Opacity Noted (Y/N)	Operating During Inspection (Y/N)	Comments
Portable Generator	165 BHP John Deere Diesel Generator, 51-26068	11/15/2024	0826	N	N	Located at Point Mugu
Portable Generator	165 BHP John Deere Diesel Generator, 51-26069	11/15/2024	0827	N	N	Located at Point Mugu
Portable Generator	315 BHP John Deere Diesel Generator, 51-28008	11/15/2024	0830	N	N	Located at Point Mugu
Wood Chipper	70.9 BHP Yanmar Diesel Engine	N/A	N/A	N/A	N/A	Did not operate during the compliance period
Spray Booth	DeVilbiss Model 20389, Dry, Building 815	N/A	_ N/A	N/A	N/A	Out of Service during the Compliance period
Spray Booth	Spray King Model 300-FAF, Dry, Building 1193	N/A	N/A	N/A	N/A	Out of Service during the Compliance period
Spray Booth	Spray King Model 300-FAF, Dry, Building 1193	~ N/A	N/A	N/A	N/A	Out of Service during the Compliance period
Spray Booth	Spray King Model 300-FAF, Dry, Building 1193	N/A	N/A	N/A	N/A	Out of Service during the Compliance period
Spray Booth	Spray King Model 300-FAF, Dry, Building 1193	N/A	N/A	N/A	N/A	Out of Service during the Compliance period
Spray Booth	United Air Specialists Dust Hog Model, Dry, Building 1224	11/15/2024	1408	N	N	
Spray Booth	Large paint room with filters, 28x19x84, Building 1497	11/5/2024	1229	N	N	
Spray Booth	Small paint room with filters, 28x19x64, Building 1497	11/5/2024	1229	N	N	
Spray Booth	Small paint room (Converted) with filters, 27x20x65, Building 1497	11/5/2024	1230	N	Υ	
Abrasive Blasting	Large blast room, Building 1497	N/A	N/A	N/A	N/A	Out of Service during the compliance period

Equipment Category	Description of Equipment in Permit Table (abbreviated)	Date of Equipment Inspection	Time of Equipment Inspection	Opacity Noted (Y/N)	Operating During Inspection (Y/N)	Comments
Abrasive Blasting	Clemco blast cabinet, Building 1497	11/5/2024	1234	N	N	
Abrasive Blasting	Clemco blast cabinet, Building 813	11/5/2024	1241	N	N	
Abrasive Blasting	Clemco blast cabinet, Building 813	11/5/2024	1247	N	N	
Abrasive Blasting	Clemco blast cabinet, Building 813	11/5/2024	1253	N	N	
Emerg. Stationary Engine	1490 BHP Cummins diesel generator, Building 2	11/5/2024	1020	N	N	
Emerg. Stationary Engine	252 BHP Cummins diesel generator, Building 22	11/5/2024	1023	N	N	
Emerg. Stationary Engine	170 BHP Cummins diesel generator, Building 225	11/5/2024	0958	N	N	5
Emerg. Stationary Engine	56 BHP Cummins diesel generator, Building 372	11/5/2024	1011	N	N	
Emerg. Stationary Engine	435 BHP Cummins diesel generator, Building 382	11/5/2024	1041	N	N	
Emerg. Stationary Engine	585 BHP Detroit diesel generator, Building 437	N/A	N/A	N/A	N/A	Out of Service during the Compliance period
Emerg. Stationary Engine	285 BHP Cummins diesel generator, Building 1000	11/5/2024	1058	N	N	9
Emerg. Stationary Engine	324 BHP Cummins diesel generator, Building 1402	11/5/2024	0940	Ν	N	
Emerg. Stationary Engine	464 BHP Cummins diesel generator, Building 1412	11/5/2024	1420	N	N	ji.
Emerg. Stationary Engine	90 BHP Cummins diesel generator, Building 1440	11/5/2024	1349	N	N	

Equipment Category	Description of Equipment in Permit Table (abbreviated)	Date of Equipment Inspection	Time of Equipment Inspection	Opacity Noted (Y/N)	Operating During Inspection (Y/N)	Comments
Emerg. Stationary Engine	145 BHP Cummins diesel generator, Building 1443	11/5/2024	1026	N	N	
Emerg. Stationary Engine	63 BHP Perkins diesel generator, Building 1512-B	11/5/2024	0932	N	N	
Emerg. Stationary Engine	161 BHP Caterpillar diesel generator, Building 1524	11/5/2024	1349	N	N	
Emerg. Stationary Engine	585 BHP Detroit diesel generator, Building 1526	N/A	N/A	N/A	N/A	Out of Service during the Compliance period
Emerg. Stationary Engine	755 BHP Cummins diesel generator, Building 5035	11/5/2024	1336	N	N	
Emerg. Stationary Engine	90 BHP Cummins diesel generator, Building 810	11/5/2024	1157	N	N	
Emerg. Stationary Engine	545 BHP Caterpillar diesel generator, Building 527	11/5/2024	1032	N	N	
Emerg. Stationary Engine	173 BHP Cummins diesel generator, Building 1387	11/5/2024	1312	N	N	
Emerg. Stationary Engine	985 BHP Detroit diesel generator, Building 1388	11/5/2024	1321	N	N	(a
Emerg. Stationary Engine	599 BHP Caterpillar diesel generator, Building 1388	11/5/2024	1324	N	N	
Emerg. Stationary Engine	96 BHP Caterpillar diesel generator, Building 1445	11/5/2024	1431	N	N	
Emerg. Stationary Engine	217 BHP Caterpillar diesel generator, Building 1300	11/5/2024	0952	N	N	

NBVC Port Hueneme Rules 74.11 and 74.11.1 Small Boilers and Water Heaters Survey

€.

2024 NBVC Port Hueneme Rules 74.11 and 74.11.1 Survey Result

In Compliance with the Rule 74.11 and 74.11.1?		
Year Installed		
Serial Number		*
Model	new boilers installed in 2024	
Make	No new boile	
Heat Input (BTU/HR)		
Building Number		٠
Location		

Appendix D

NBVC Port Hueneme RICE NESHAP Maintenance Records

ж

NAVFAC PORT HUENEME RICE NESHAP MAINTENANCE RECORD

Bldg	Device	Engine C	Engine Oil Analysis	Engine and Fil	Engine and Filter Oil Change	Air Cleane	Air Cleaner Inspection	Hoses and Be	Hoses and Belts Inspection
		Date of Engine Oil Sample Collection	Hour Meter Reading at Time of Engine Oil Sample Collection	Date of Engine Oil and Oil Filter Change	Hour Meter Reading at Time of Engine Oil and Oil Filter Change	Date of Inspection	Hour Meter Reading at Time of Inspection	Date of Inspection	Hour Meter Reading at Time of Inspection
2	1490 BHP Cummins		Post 2006 Construction	on, Maintenance not Required	ired				
22	252 BHP Cummins	7/22/2024	392.1	Passing Analysis - N/R Passing Analysis - N/R	Passing Analysis - N/R	7/22/2024	392.1	7/22/2024	392.1
225	170 BHP Cummins	N/A	N/A	7/22/2024	275.7	7/22/2024	275.7	7/22/2024	275.7
372	56 BHP Cummins	N/A	N/A	7/29/2024	496.0	7/29/2024	496	7/29/2024	496
382	435 BHP Cummins	8/6/2024	20	Passing Analysis - N/R	Passing Analysis - N/R Passing Analysis - N/R	8/6/2024	20	8/6/2024	20
437	585 BHP Detroit	Out of 8	Out of Service on Title V Perm	nit #01006, Maintenance not Required	ot Required				
527	545 BHP Caterpillar	N/A	N/A	7/19/2024	46.3	7/19/2024	46.3	7/19/2024	46.3
810	90 BHP Cummins	N/A	N/A	7/17/2024	468.7	7/17/2024	468.7	7/17/2024	468.7
1000	285 BHP Cummins	7/22/2024	285.0	Passing Analysis - N/R	Passing Analysis - N/R Passing Analysis - N/R	7/22/2024	285.0	7/22/2024	285.0
1300	217 BHP Caterpillar		Post 2006 Constructio	on, Maintenance not Required	red				
1388-1	599 BHP Caterpillar	N/A	N/A	1/27/2024	312	1/27/2024	312.0	1/27/2024	312.0
1388-2	985 BHP Detroit		Post 2006 Constructio	Post 2006 Construction, Maintenance not Required	peu				
1402	324 BHP Cummins		Post 2006 Constructio	on, Maintenance not Required	ired				
1440	90 BHP Cummins	N/A	N/A	7/29/2024	486.9	7/29/2024	486.9	7/29/2024	486.9
1443	145 BHP Cummins		Post 2006 Constructio	on, Maintenance not Required	ired	THE STATE OF THE S			
1524	161 BHP Perkins		Post 2006 Constructio	on, Maintenance not Required	ired				
1526	585 BHP Detroit	Out of 3	Service on Title V Perm	Out of Service on Title V Permit #01006, Maintenance not Required	ot Required				
5035	755 BHP Cummins		Post 2006 Constructio	Post 2006 Construction, Maintenance not Required	ired				

PORT HUENEME COMISSARY RICE NESHAP MAINTENANCE RECORD

Bldg	Device	Engine and Filter	Iter Oil Change	Air Cleaner	Air Cleaner Inspection	Hoses and Be	Hoses and Belts Inspection
		Date of Engine Oil and Oil Filter Change	Hour Meter Reading at Time of Engine Oil and Oil Filter Change	Date of Inspection	Hour Meter Reading at Time of Inspection	Date of Inspection	Hour Meter Reading at Time of Inspection
1512B	63 BHP Perkins	6/4/2013	212.2	6/4/2013	212.2	6/4/2013	212.2
1512B	63 BHP Perkins	5/7/2014	234.4	5/7/2014	234.4	5/7/2014	234.4
1512B	63 BHP Perkins	5/6/2015	242.7	5/6/2015	242.7	5/6/2015	242.7
1512B	63 BHP Perkins	5/10/2016	259.4	5/10/2016	259.4	5/10/2016	259.4
1512B	63 BHP Perkins	5/1/2017	271.2	5/1/2017	271.2	5/1/2017	271.2
1512B	63 BHP Perkins	12/11/2018	283.3	12/11/2018	283.3	12/11/2018	283.3
1512B	63 BHP Perkins	1/8/2020	302.3	1/8/2020	302.3	1/8/2020	302.3
1512B	64 BHP Perkins	1/15/2021	312.8	1/15/2021	312.8	1/15/2021	312.8
1512B	64 BHP Perkins	Exempt	mpt from 4Z requireme	from 4Z requirements per 40 CFR 63.6585(f)	85(f)		
_							
-				\$C			
Н			-				

Appendix E

NBVC Port Hueneme Gas Station Dispensing Facilities Verification Testing Results

· ·

NBVC Port Hueneme E85 Dispensing Facility Verification Testing Results



VENTURA COUNTY AIR POLLUTION CONTROL DISTRICT

4567 TELEPHONE ROAD, 2ND FL, VENTURA, CA 93003 PHONE (805) 303-4005

TEST OF VAPOR RECOVERY EQUIPMENT FINAL TEST REPORT COVER SHEET

TEST COMPANY INFORMATION: WESTERN PUMP INC. NAME: ADDRESS: 3235 F STREET, SAN DIEGO, CALIFORNIA 92102 CONTACT PERSON NAME: JARID S. MARTIN TELEPHONE NUMBER ICC CERTIFICATION #: 5254111 GABRIEL PEDROZA TESTER NAME(S): TEST INFORMATION: DATE OF TEST(S): 2024-10-08 TEST AUTHORIZATION NUMBER: PERMIT HOLDER NAME: NBVC - PORT HUENEME PERMIT No.: 01006 LOCATION OF EQUIPMENT TESTED: 1000 23RD AVENUE, PORT HUENEME, CA 93041 EQUIPMENT TESTED: PHASE II E.O. No.: PRE-EVR PRESSURE MANAGEMENT EQUIPMENT: N/A TESTS CONDUCTED AND DATA FORMS ATTACHED: Check all applicable: ☑ TP-201.3 Static Leak Decay ☐ TP-201.3C Tie Tank ☐ TP-201.4 Dynamic Back Pressure □ VR-201/202 Exhibit 4 Clean Air Separator □ VR-201/202 Exhibit 5 Vapor to Liquid Ratio □ VR-201/202 Exhibit 7 or VR-203/204 Exhibit 10 Nozzle Bag Test ☐ TP-201.1B Static Torque of Phase I Rotatable Adaptor ☐ TP-201.1C Leak Rate of Drop Tube / Drain Valve ☐ TP-201.1D Leak Rate of Drop Tube Overfill Devices ☑ TP-201.1E Leak Rate / Crack Pressure of PV Vent Valves ☐ TP-201.5 Vapor to Liquid Ratio ☐ TP-201.6 Hose Liquid Removal Rate □ VR-202/204 ISD Operability Test(s) ☐ Vapor Processor Test Hirt VCS-100 ☐ Liquid Condensate Trap Test Others: Statement of Compliance [Pursuant to Rule 461 (e)(3)(E)] The undersigned declares, under penalty of perjury under the laws of the state of California that the above checked tests were conducted at the location identified above, the attached data form(s) include all data obtained during the test(s) which show the system or component meets the required standards, and that the information provided in this submittal are true, accurate, and complete. DATE: 2024-10-08 SIGNATURE OF TESTER:

Instructions: This form must be signed and submitted along with completed specific test data forms and all

raw data obtained during the test(s).



TP201.3 2" Pressure Decay

		<u>, Te</u>	esting	Company	L	×	
Site Name	: NBVC - PORT HUENEME	[⊮] Na	ame:	WESTERN P	JMP, INC.		
Address:	1000 23RD AVENUE,			3235 F STRE			
	PORT HUENEME, CA 93041			SAN DIEGO,		CA	92102
Phone:	(805) 645-1400	Ph	one:	(619) 239-998	8		
Phase I Syst	tem? VR-402		Tanks	Manifolded?	N/A		
Phase II Sys				Pot Present?			-
Total # of Noz		Total # of T		4			-
Products per		TOTAL # OF I	airks			50	
Troducto por	NOZE						
	Tank Information		1	2	3	4	All
1. Prod	luct Grade		-E85-				(1)
	al Tank Capacity, gallons		10335				10335
	oline Volume, gallons	×	5414		*		5414
4. Ullag	ge, (V) gallons (line #2 minus line#3)		4921				4921
	Test Information		1	2	3	4	5
5. Star	t time		0945	_ _			
	al Test Pressure, inches H ₂ O		2.00				
	sure after 1 minute, inches H ₂ O		2.07				
	sure after 2 minutes, inches H ₂ O		2.13				
9. Pres	sure after 3 minutes, inches H ₂ O		2.14				
10. Pres	sure after 4 minutes, inches H ₂ O		2.19				
11. Pres	sure after 5 minutes, inches H ₂ O		2.21				
	vable Final Pressure		1.60				
13. Pass	s / Fail (Enter "GF" for Gross failure)		(P)				
2024-10-08	_ Requested Test Date.						
09:00	_ Requested Test Time.	10					
MARK III DIGITA	_		,				
2024-08-29	Calibration date for pressure de	•	,				
0.00	Enter initial tank ullage pressure	Ovent if over 0).5 in. w.c.	, then start the 3	0 min no dispe	nsing period)	
2	Enter flowmeter rate, F(Must be	1 to 5 CF	IVI).				
1.617	Calculate ullage fill time, t ₂ .					t 2=	
3.234	Calculate gross failure time (Tw	,					[1522]F
0.00" WC	Enter ending value of drift test (
2.08" WC	Record Vapor Coupler Integrity						ation.
PHASE I	Nitrogen introduction point. Pha	ase I vapoi	couple	er or Phase	ell vapor r	iser?	
Tester:	GABRIEL PEDROZA			Tester Id:	175656		
Signature:				Test Date:	2024-10-08		



TP201.1E - Leak Rate and Cracking Pressure of P/V Vent Valves

Testing Company

Site Name:	NBVC - PORT HUENEME		Name:	WESTERN PUMP I	NC.	
Address:	1000 23RD AVENUE,	tr	Address:	3235 F STREET,		
	PORT HUENEME,	CA 93041		SAN DIEGO,	CA	92102
Phone:	(805) 645-1400		Phone:	(619) 239-9988		
			-			
P/V Valve I	Manufacturer:	HUSKY	Model Number:	5885	Pass/Fail:	(P)
Manufacture Positive Lea	er Specified ak Rate (CFH):	0.050	Manufacturer Spe Negative Leak Ra		0.210	
Measured Po	sitive Leak Rate(CFH)	0.025	Measured Negative	Leak Rate (CFH)	0.010	
Positive Crack	king Pressure (in. H2O)	3.75	Negative Cracking P	ressure (in. H2O)	8.87	
			T			
	Manufacturer:		Model Number:		Pass/Fail:	
Manufacture Positive Lea	er Specified ak Rate (CFH):		Manufacturer Spe Negative Leak Ra		4	
Measured Po	sitive Leak Rate(CFH)		Measured Negative	Leak Rate (CFH)		
	king Pressure (in. H2O)	4	Negative Cracking P	ressure (in. H2O)		
T COMITO CITAL	ung ricocare (minimiz)					
P/V Valve I	Manufacturer:		Model Number:		Pass/Fail:	
Manufacture ositive Lea	er Specified ak Rate (CFH):		Manufacturer Spe Negative Leak Ra			
Measured Positive Leak Rate(CFH)			Measured Negative	Leak Rate (CFH)		
	king Pressure (in. H2O)		Negative Cracking P			
						_
	Manufacturer:		Model Number:		Pass/Fail:	L
Manufacture			Manufacturer Spe Negative Leak Ra			
	ak Rate (CFH):					
	ositive Leak Rate(CFH)		Measured Negative		-	
Positive Crac	king Pressure (in. H2O)		Negative Cracking P	ressure (in. H2O)		
DA/ Valva	Manufacturer:		Model Number:		Pass/Fail:	
Manufacture			Manufacturer Spe	cified	1 440071 4411	
	ak Rate (CFH):		Negative Leak Ra			
	ositive Leak Rate(CFH)		Measured Negative	Leak Rate (CFH)		
Positive Crac	king Pressure (in. H2O)		Negative Cracking P	ressure (in. H2O)		
P/V Valve	Manufacturer:		Model Number:	*	Pass/Fail:	
Manufactur			Manufacturer Spe			
	ak Rate (CFH):		Negative Leak Ra			
	ositive Leak Rate(CFH)		Measured Negative			
Positive Crac	king Pressure (in. H2O)		Negative Cracking P	ressure (in. H2O)	L	
`ester:	GABRIEL PEDROZA	/	v	Tester Id:	175656	
Signature:			>	Test Date:	2024-10-08	
	7//					

U.S.NAVAL BASE 1000 23RD AVE POFT HUENEME CA 30619006505001

OCT 8, 2024 1 9:27 AM

SYSTEM STATUS REPORT

T 1:LOW PRODUCT ALARM

T 1:INVALID FUEL LEVEL

T 1:DELIVERY NEEDED

L 9: FUEL ALARM

INVENTORY REPORT

T 1:MOGAS
T 1:INVALID FUEL LEVEL
VOL INVALID 211 GALS
ULLAGE = 11853 GALS
90% ULLAGE = 10646 GALS
TC VOLUME = 210 GALS
HGT INVALID 4.51 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 63.1 DEG F

T 2:F-24 JET FUEL

VOLUME = 12139 GALS

ULLAGE = 9729 GALS

90% ULLAGE= 7542 GALS

TC VOLUME = 12114 GALS

HEIGHT = 63.03 INCHES

WATER VOL = 0 GALS

WATER = 0.00 INCHES

TEMP = 64.3 DEG F

T 3:DIESEL DS-2
VOLUME = 11663 GALS
ULLAGE = 10205 GALS
90% ULLAGE= 8018 GALS
TC VOLUME = 11642 GALS
HEIGHT = 61.04 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 63.9 DEG F

T 4:E-85

VOLUME = 5419 GALS

ULLAGE = 4921 GALS

90' ULLAGE = 3887 GALS

TC VOLUME = 5402 GALS

HEIGHT = 49.31 INCHES

TEMP = 64.3 DEG F

U.S.NAVAL BASE 11700 23RD AVE 1 FT HUENEME CA 1061 9006505001

OCT 8, 2024 9:27 AM

T 4:E-85 INVENTORY INCREASE

INCREASE START AUG 1. 2024 1:56 PM

T 4:INVALID FUEL LEVEL VOLUME = 16 GALS HEIGHT = 0.90 INCHES TEMP = 66.1 DEG F

INCREASE END AUG 1, 2024 2:08 PM

VOLUME = 10340 GALS HEIGHT = 95.11 INCHES TEMP = 70.2 DEG F

GENOSS INCREASE = 10324 TO NET INCREASE = 10252

NBVC Port Hueneme Navy Exchange Gasoline Dispensing Facility Verification Testing Results

¥ 2 4



Contractor License No. 866381 HAZ • SWRCB License No. 94-1411 • www.verdugotesting.com

November 14, 2024 Attn: Robert Rankin King George LLC Facility: Navy Exchange Building 797 320 Hemphill Street Fort Worth, TX 76104 Port Hueneme, CA 93043 **RE: Annual Compliance Vapor Recovery Test Report** Agency Notification Date: 9/24/2024 Test Completion Date: 11/14/2024 Dear Mr. Rankin, Enclosed is the Ventura County Air Pollution Control District annual compliance vapor recovery test report. Verdugo Testing scheduled the annual compliance test for Permit Number 01006. Phase I testing is required triennially, testing not performed for the year 2024. The following is a summary of the test results. **VAPOR RECOVERY TEST RESULTS Pass** <u>Fail</u> Exhibit 4 Clean Air Separator Integrity Test \times \times TP 201.3 Static Pressure Leak Decay Test

Verdugo Testing completed the testing required to satisfy the conditions of the Permit to Operate. Certified technicians conducted all tests in compliance with applicable vapor recovery regulations and safety requirements. The final test report was submitted to the Ventura County Air Pollution Control District in accordance with agency report submittal guidelines.

X

X

If you have any questions please feel free to contact me.

VP 1000 Vacuum Pump Integrity Test

Exhibit 5 Vapor to Liquid Ratio Test

Exhibit 9 ISD Operability Test

Sincerely,

Alexis Patino

Verdugo Testing Co., Inc

Environmental Compliance Department

Attachments - Annual Compliance Vapor Recovery Test Report

Cc: Ventura County Air Pollution Control District

VAPOR RECOVERY TEST DATA COVER SHEET

✓ Renewal Test ☐ Quarterly ☐ Combined (eng/com)	☐ ISD Alarm Response ☐ District Witness/Testing
Facility DBA: NBVC - NCBC Point Hueneme	Permit Number: 01006
Site Address: 3201 N. Ventura Rd.	City/Zip Code: Port Hueneme/93043
Test Company Name: Verdugo Testing Co. Inc	Phone: (619) 691-0600
Address, City/Zip Code: 862 Starboard St, Chula Vista / 91914	4
Date of Test: 11/14/2024	District Witness: Steve Bova
Veeder Root ISD Cert Number: C31102	Expiration Date: 12/6/2024 Expiration Date: 8/2/2026 Expiration Date: 11/12/2025
INCON Level V Cert Number: 2. Tester's Name: SCAQMD Cert No:	Signature:
ICC (VR System Installation, Repair- VI/VT) Cert No: Phase I Manufacturer Cert Number: Phase II Manufacturer Cert Number: Veeder Root ISD Cert Number: INCON Level V Cert Number:	Expiration Date: Expiration Date: Expiration Date: Expiration Date:
Tests Conducted and Data Forms Attached: Exhibit 4 VR-201/202, [Exhibit 14 VR-203/204] Determination of Stall TP 201.1E Leak Rate of Pressure/Vacuum Relief Vent Valves TP 201.1B Static Torque of Rotable Phase I Adaptors TP 201.1C/D Drop Tube/Drain Valve Pressure Integrity TP 96-1, TP 201.3 or EO 401/402 Exhibit 4 Pressure Decay Test TP 201.4 Dynamic Back Pressure Liquid Removal for Exhibit 5 of VR-203/204 Option 1 and TP 201.6C Exhibit 8 VST ECS Hydrocarbon Scnsor Verification Test Procedure for Exhibit 9 Determination of VST ECS Processor Activation Pressure for Exhibit 10 Vapor Pressure Sensor Verification Procedure for VR-203/204 Exhibit 11 Veeder Root Vapor Polisher Operability Test Procedure VF Exhibit 13 Hirt VCS 100 Processor with Indicator Panel Operability Test Exhibit 15 Green Machine Compliance Procedure - Exhibit 9 of VR-201 Exhibit 17 Veeder Root ISD Vapor Flow Meter Operability Test for V Exhibit 19/20 (19) INCON ISD flow meter operability, [VR 208 Ex 10 Exhibit 5 Vapor to Liquid Ratio VR 201/202 (Roots) Exhibit 7 (VR201-208), Nozzle Bag Test Exhibit 9 Veeder Root ISD Operability VR 202 Exhibit 10 INCON ISD Operability VR 202 VP 1000 Vacuum Pump Tightness Test VR 201/202 IOM Exhibit 4 (G-70-187) Vapor Return Line Vacuum Integrity Test Exhibit 5 (G-70-187) Fillneck Vapor Pressure Regulation Test	Liquid Removal (Pre EVR) For VR-203/204 For VR-203/204

REV 02/2016 (NOTE: TESTS MUST BE CONDUCTED IN THE SEQUENCE SPECIFIED IN ATTACHMENT A OR L AS APPLICABLE)

This form must be complete, accurate and submitted along with the specific test data form in order for your data to meet District requirements. By completing and submitting this form you certfiy the tester named was repsonsible for conducting all tests checked. Any testers responsible for conducting tests must be recorded on this form with applicable certification numbers, REV (03/16/2016)

DETERMINATION OF STATIC PRESSURE PERFORMANCE OF THE HEALY CLEAN AIR SEPARATOR

Exhibit 4 of ARB E.O. VR-201/202-XX and Exhibit 14 of ARB E.O VR-203/204-XX

Cacility Name: NBVC - NCBC Point Hueneme A/C	C or PO Nu	ımber: <u>01006</u>	
For ISD Alarm Response Purposes Only: CAS	Ball Valve p	oositions checke	d for proper orientations: Yes or No
Time and Date of most recent delivery:	11:19	11/13/2024	Leak Check Conducted: Yes or No
Date of Last Calibration of Pressure Measurement Dev	/ice: 9/2	26/2024	Phase II Executive Order #: VR-202

If the station pressure is -2.00" W.C. or more negative, a vacuum test must be performed followed by a pressure test. If the pressure is less negative than -2.00" W.C., a pressure test must be performed. Anytime a vacuum test is conducted a subsequent pressure test shall **also** be conducted immediately after the vacuum test.

Existing station pressure: __0.170__

VACUUM TEST

VACUUMITES	* ************************************
Time (Minutes)	Vacuum Measurement (in wc)
Beginning of Test	Al
At 1 minute	
At 2 minutes	
At 3 minutes	
At 4 minutes	
At 5 minutes	
Allowable Minimum Vacuum (from Table 1)	

PRESSURE TEST

Time (Minutes)	Pressure Measurement (in wc)
Beginning of Test	2.00"
At 1 minute	2.10"
At 2 minutes	2.16"
At 3 minutes	2.22"
At 4 minutes	2.26"
At 5 minutes	2.32"
Allowable Final Pressure	1.77

PRESSURE DECAY TEST

✓ 2" TP-201	.3	Exhibit 4, EO-VR 40	01/2-XX
Facility Name: NBVC - NCBC Point Huer	nemeA/C or PO Num	ber: 01006	
Date/Time of Most Recent A/L or		Date/Time of Most Recent	
V/L Test as applicable:	11/12/2024 12:00	Delivery:	11/13/2024 11:19
Pressure Measuring Device Type:	Digital Manometer	Device Calibration Date:	9/26/2024
Certain Executive Orders (EO) contain requirements must be followed in acco	rdance with the applicable E.O.	in order for the pressure decay tes	pressure decay test. These t result to be valid.
EO VR - 201/202 (Ex. 8) 203/204 (Ex. 4)		1	
1. All four CAS ball valves clo	Required Steps		Verification Yes√ NO □
2. All dispenser piping test val			Yes NO
	normal operating positions after test	?	Yes NO
,=			103[-110
EO VR - 203/204 (Ex. 4) - Vapor Polishe	Required Steps		¥7 •6°
1. Inlet ball valve (mechanical		Verification	
2. Vapor Valve closed prior to		Yes NO	
2. Vapor valve closed prior to			Yes NO
	2		Yes NO
3. Inlet ball valve locked and of	open after test?		Yes NO 🗌
EO VR - 203/204 (Ex. 4) - Membrane Pr	ocessor/Green Machine NA		
	Required Steps		Verification
1. All ball valves open prior to	test?		Yes NO
2. Processor turned off prior to	test?	2	Yes NO
3. All ball valves in open and	locked position after test?		Yes NO
4. Processor turned back on af	ter test?		Yes NO
EO VR - 208 (Ex. 4) -Thermal Oxidizer	NA 🗷		
	Required Steps		Verification
1. Inlet ball valve open prior t		Yes NO	
2. Power switch off before tes		Yes NO	
3. Inlet ball valve locked and		Yes NO	
4. Power switch on after test?			Yes NO
EO VR - 401/402 (Ex. 4)	NA 🗹		
	Required Steps		Verification
1. Product level measured abo	ve the highest opening of the subme	erged drop tube	Inches
			3300000377

✓ 2" TP-201.3	☐ 10" TP 96-1	Exhibit 4, EO-VR 401/2-XX
Facility Name: NBVC - NCBC Point Hueneme	_ A/C or PO Numb	per: 01006

PRESSURE DECAY DATA

Tank Number:	1	2	3	4	Total
Product Grade:	87	91			
Tank Capacity, gallons:	20,078	20,078			40,156
Gasoline, gallons:	10,073	12,270			22,343
Ullage, gallons 1:	10,005	7,808			17,813
Initial Pressure ² , wcg:	2.00"				
Pressure @ 1 minutes:	2.03"				
Pressure @ 2 minutes:	2.04"				
Pressure @ 3 minutes:	2.05"			×	
Pressure @ 4 minutes:	2.06"				
Final pressure @ 5 minutes:	2.09"				
Allowable Final Pressure, wcg:	1.90"				
Pressure Decay Test Results:	▽ P/ □F	□P/ □F	□P/ □F	□P/ □F	□P/ □F
Tank Tie Test:	▽ P/ □F	′ □P/ □F	□P/ □F	□P/ □F	□P/ □F

VP-1000 VACUUM PUMP TIGHTNESS TEST IOM Manual for the Healy Phase II EVR Systems

Facility Name: NBVC - NCBC Point HuenenA/C or PO Number: 01006

	В-3	I	3-4		B-5	B-6
Dispenser No.	Vacuum Reading Initial ¹ (WC)	Vacuum Reading After closing the ball valve ¹ (WC)	Vacuum Reading After 60 sec. ² (WC)	Dispenser Side	Dispensing Vacuum ³ (WC)	Change in Speed (check one)
1-2		84"	84"	A		
		04	04	В		☐ YES ☐ NO
3-4		84"	84"	A		☐ YES ☐ NO
<u> </u>		04	04	В		
5-6		81"	81"	A		☐ YES ☐ NO
		01	01	В		
7-8		78"	78"	A		☐ YES ☐ NO
			76	В		
9-10		80"	80"	A		☐ YES ☐ NO
			00	В		
11-12		78"	78"	A		☐ YES ☐ NO
		, 0	70	В		
				A		☐ YES ☐ NO
				В		
				A		☐ YES ☐ NO
				В		1.1.2.2.

Not required by Air Air Agency.

These vacuum readings shall be at least 60" Water Column (WC)

Final vacuum reading shall not fall more than 4" WC from the reading taken after closing the ball valve.

The dispensing vacuum shall not be less than 60" WC

VAPOR TO LIQUID VOLUME RATIO FOR HEALY PHASE II EVR SYSTEMS Tritester Version 2.01 Executive Order 201 and 202

Facility Name: NBVC - NCBC Point Hueneme A/C or PO Number: 01006

Time of Day ¹	Grade Point ²	Serial Number of Nozzle	Gallons Dispensed (gal) ³	Flow (GPM) ⁴	V/L ⁵	V/L Average ⁶ (if applicabl e)	Pass (P) Fail (F) or (NT) ⁷	Comment ⁸
	1-87	31225589	2.017	7.81	1.165		F	
	1-87		2.038	7.50	1.182		F	
	1-87		2.039	7.77	1.186	1.178	F	AVERAGE IS 1.178 NOZZLE FAILED V/L
	1-87		2.036	7.92	1.148		Р	ADJUSTED VALVE ON NOZZLE
	1-89		2.042	7.75	1.106		Р	
	1-91		2.033	7.83	1.148		P.	
	2-89	03234767	2.039	7.69	1.033		Р	
	2-91		2.027	7.44	1.044		Р	
	3-87	18171801	2.028	7.58	1,161		F	Ä. II
	3-87		2.033	7.41	1.165		F	
	3-87		2.030	7.63	1.168	1.164	F	AVERAGE IS 1.164 NOZZLE FAILED V/L
	3-87		2.017	7.71	1.150		Р	ADJUSTED VALVE ON NOZZLE
	3-89		2.033	7.09	1.134		Р	

Time of Day ¹	Grade Point ²	Serial Number of Nozzle	Gallons Dispensed (gal) ³	Flow (GPM) ⁴	V/L ⁵	V/L Average 6 (if applicab le)	Pass (P) Fail (F) or (NT) ⁷	Comments ⁸
	3-91		2.037	7.89	1.150		Р	
	4-89	32225983	2.025	7.26	1.172		F	
	4-89		2.025	7.25	1.179		F	
	4-89		2.023	6.98	1.151	1.167	F	AVERAGE IS 1.167 NOZZLE FAILED V/L
	4-89		2.022	6.80	1.113		Р	ADJUSTED VALVE ON NOZZLE
	4-91		2.018	7.28	1.141		Р	*
	5-87	50223546	2.029	7.46	0.933		F	
	5-87		2.013	7.13	0.950		Р	* 11
	5-87		2.025	5.92	0.936	.939	F	AVERAGE IS 939 NOZZLE FAILED V/L
	5-87	11227892	2.034	7.01	1.057		Р	REPLACED HEALY NOZZLE
	5-89		2.040	6.68	0.995		Р	
	5-91		2.033	7.09	1.061		Р	
	6-89	22241168	2.023	7.14	0.981		Р	
	6-91		2.021	7.19	1.030		Р	
	7-87	20240587	2.028	7.52	1.075		Р	

Record the time of test (time piece shall be synchronized with time on TLS console)(Only required when conducting test in conjunction with Ex 9 ISD Operability Test with VR 202-XX)

REV 2/16

² Grade point: This test shall be performed for all fueling points

³ Amount of gasoline dispensed during test, in gallons, recorded to the nearest hundredth

⁴ Dispensing Rate, in gallons per minute, recorded to the nearest hundredth

⁵ Vapor to Liquid Ratio, recorded to the nearest thousandth

⁶ If the V/L Volumetric Ratio is between 0.76 - 0.94, or greater than or equal to 1.16, conduct the test two additional times. Do not make adjustments to the gasoline dispensing or vapor recovery lines until all three test runs have been completed. Adjustments of the V/L test equipment, including the V/L adaptor and nozzle, are allowed as may be necessary to ensure measurement accuracy. If the V/L test equipment is adjusted, then the prior test run results for that grade point tested should not be used. Calculate the numerical average of the three test runs. If the average V/L value of these three test runs is within the allowable limits, compliance has been verified.

⁷ If the V/L Volumetric Ratio is between 0.95 –1.15, the grade point complies with the specifications. Non-tests include: Nozzle spouts that are damaged such that the V/L adaptor cannot fit over the nozzle spout or refueling points not capable of achieving dispensing rates required for conducting the V/L test, as specified in Exhibit 2 of applicable ARB Executive Order (between 6.0 and 10.0 gpm). NT=Non Test

⁸ Comments (e.g. reason for non-test, equipment adjustments, etc.)

⁹District recommends leak checking equipment during test to minimize lost data due to failure of post test leak check.

Facility Name: NBVC - NCBC Point Hueneme A/C or PO Number: 01006

Time of Day ¹	Grade Point ²	Serial Number of Nozzle	Gallons Dispensed (gal) ³	Flow (GPM) ⁴	V/L ⁵	V/L Average (if applicab le)	Pass (P) Fail (F) or (NT) ⁷	Comments ⁸
	7-89		2.033	7.56	1.033		Р	
	7-91		2.031	7.67	1.078		Р	
	8-89	12238522	2.035	7.14	1.040		Р	
	8-91		2.025	7.67	1.089		Р	R
	9-87	37222275	2.018	7.21	1.099		Р	<u> </u>
	9-89		2.033	6.64	1.071		P	
	9-91		2.014	7.21	1.120		Р	
".	10-89	22241171	2.041	6.90	0.912	1	F	
	10-89		2.042	6.59	0.940		F	
	10-89		2.029	6.52	0.915	.922	F	AVERAGE IS .922, NOZZLE FAILED V/L
	10-89		2.018	6.58	0.971		Р	ADJUSTED VALVE ON NOZZLE
	10-91	(K)	2.015	6.96	1.026		Р	
	11-87	19248921	2.027	7.16	0.960		Р	
	11-89	>	2.029	7.28	0.971		Р	
	11-91	F:	2.008	7.18	0.974		Р	

Record the time of test (time piece shall be synchronized with time on TLS console)(Only required when conducting test in conjunction with Ex 9 ISD Operability Test with VR 202-XX)

Page 3 of 3

² Grade point: This test shall be performed for all fueling points

³ Amount of gasoline dispensed during test, in gallons, recorded to the nearest hundredth

⁴ Dispensing Rate, in gallons per minute, recorded to the nearest hundredth

⁵ Vapor to Liquid Ratio, recorded to the nearest thousandth

If the V/L Volumetric Ratio is between 0.76 - 0.94, or greater than or equal to 1.16, conduct the test two additional times. Do not make adjustments to the gasoline dispensing or vapor recovery lines until all three test runs have been completed. Adjustments of the V/L test equipment, including the V/L adaptor and nozzle, are allowed as may be necessary to ensure measurement accuracy. If the V/L test equipment is adjusted, then the prior test run results for that grade point tested should not be used. Calculate the numerical average of the three test runs. If the average V/L value of these three test runs is within the allowable limits, compliance has been verified.

⁷ If the V/L Volumetric Ratio is between 0.95 –1.15, the grade point complies with the specifications. Non-tests include: Nozzle spouts that are damaged such that the V/L adaptor cannot fit over the nozzle spout or refueling points not capable of achieving dispensing rates required for conducting the V/L test, as specified in Exhibit 2 of applicable ARB Executive Order (between 6.0 and 10.0 gpm). NT=Non Test

⁸ Comments (e.g. reason for non-test, equipment adjustments, etc.)

⁹District recommends leak checking equipment during test to minimize lost data due to failure of post test leak check.

Time of Day ¹	Grade Point ²	Serial Number of Nozzle	Gallons Dispensed (gal) ³	Flow (GPM) ⁴	V/L ⁵	V/L Average (if applicab le)	Pass (P) Fail (F) or (NT) ⁷	Comments ⁸
	12-89	22241170	2.02	7.11	1.037		Р	
	12-91		2.03	7.04	1.096		Р	
391								
		8						
								15.

Record the time of test (time piece shall be synchronized with time on TLS console)(Only required when conducting test in conjunction with Ex 9 ISD Operability Test with VR 202-XX)

² Grade point: This test shall be performed for all fueling points

Amount of gasoline dispensed during test, in gallons, recorded to the nearest hundredth

⁴Dispensing Rate, in gallons per minute, recorded to the nearest hundredth

Vapor to Liquid Ratio, recorded to the nearest thousandth

⁶ If the V/L Volumetric Ratio is between 0.76 - 0.94, or greater than or equal to 1.16, conduct the test two additional times. Do not make adjustments to the gasoline dispensing or vapor recovery lines until all three test runs have been completed. Adjustments of the V/L test equipment, including the V/L adaptor and nozzle, are allowed as may be necessary to ensure measurement accuracy. If the V/L test equipment is adjusted, then the prior test run results for that grade point tested should not be used. Calculate the numerical average of the three test runs. If the average V/L value of these three test runs is within the allowable limits, compliance has been verified.

⁷ If the V/L Volumetric Ratio is between 0.95 –1.15, the grade point complies with the specifications. Non-tests include: Nozzle spouts that are damaged such that the V/L adaptor cannot fit over the nozzle spout or refueling points not capable of achieving dispensing rates required for conducting the V/L test, as specified in Exhibit 2 of applicable ARB Executive Order (between 6.0 and 10.0 gpm). NT=Non Test

⁸ Comments (e.g. reason for non-test, equipment adjustments, etc.)

District recommends leak checking equipment during test to minimize lost data due to failure of post test leak check.

VAPOR TO LIQUID VOLUME RATIO FOR HEALY PHASE II EVR SYSTEMS

Digital Roots Tri-Tester Equivalent Procedure of Exhibit 5 ARB EOs VR-201-XX and VR 202-XX

To be used for V/Ls obtained for Exhibits 9 and 10 ARB EOs 201/202

To calculate V/L use equation in footnote 10 and always use y=1.

Final volume dispensed (read from dispenser totalizer) required to be 4.5-5.0 gallons.

Dispensing time/rate values not required on this form if obtained during 2 gallon V/L assessment.

Facility Name: NBVC - NCBC Point Adeletile	A/C of PO Number: 01000	
For ISD Alarm Response Purposes only H	anging hardware visually inspected at the affected dispenser(s): Yes No	

Time of Day ¹	Grade Point ²	Nozzle³	Initial Dispenser Totalizer ⁴ G _i (Gallons)	Final Dispenser Totalizer ⁵ G _f (Gallons)	Time ⁶ t (Sec.)	Dispensing Rate ⁷ Q _g (GPM)	Initial Gas Meter Reading ⁸ V _i (ft ³)	Final Gas Meter Reading ⁹ V _f (ft³)	V/L ¹⁰	V/L Average ¹¹ (if applicable)	Pass/ Fail ¹²
12:59	2-87	Healy 900	0.000	4.560	34.76	7.87	0.000	0.644	1.057		Pass
13:05	4-87	Healy 900	0.000	4.541	35.15	7.75	0.000	0.692	1.140		Pass
14:02	6-87	Healy 900	0.000	4.545	35.85	7.61	0.000	0.629	1.035		Pass
14:05	8-87	Healy 900	0.000	4.562	32.98	8.30	0.000	0.665	1.091		Pass
14:07	10-87	Healy 900	0.000	4.541	36.44	7.48	0.000	0.654	1.077		Pass
14:09	12-87	Healy 900	0.000	4.530	36.10	7.53	0.000	0.665	1.098	Ť	Pass
			3.63								
			383	14		1					

ISD OPERABILITY TEST PROCEDURE

Exhibit 9 of ARB E.O. VR 202-XX

Facility Name: NBVC - NCBC Point Hueneme	VC or PO Number: 01006
--	------------------------

For ISD Alarm Response Purposes only: ISD Pressu	are Sensor verified to be in proper orientation: Yes or No
Pressure Sensor Location:	Busganus Sanaar Sanial Na 6022
Dispenser No.:1/2	Pressure Sensor Serial No6922
Ullage Pressure from Digital Manometer 2.00 Compare the two readings and enter the difference	
Non-Calibrated Sensor Value0.044	"w.c.

Dispenser ¹	Fueling Point ²	Meter Serial	Real Time A/L Values from PC Setup Tool ⁴	V/L reading for the lowest grade per Exhibit ⁵	V/L Difference (Real Time A/L From PC Setup Tool Minus V/L From Test) ⁶	Pass/ Fail ⁷	reading lowest (Exh	onal V/L gs for the grade per libit 5 quired) ⁸ #3	Average of 3 V/L readings (per Exhibit 5)9	Pass/ Fail ¹⁰
1-2	2-87	38388	1.05	1.057	-0.007	Pass		m3		
3-4	4-87	62128	1.12	1.140	-0.020	Pass				
5-6	6-87	56089	0.90	1.035	-0.135	Pass				
7-8	8-87	88246	1.04	1.091	-0.051	Pass				
9-10	10-87	88257	0.98	1.077	-0.097	Pass				
11-12	12-87	88025	1.06	1.098	-0.038	Pass				
Ü										
		e.								

Exhibit 9 of ARB E.O. VR 202-XX

Facility Name: NBVC - NCBC Point Huen A/C or PO Number: 01006

Dispenser ¹	Fueling Point ²	Real Time A/L Values from PC Setup Tool ⁴	V/L reading for the lowest grade per Exhibit ⁵	V/L Difference (Real Time A/L From PC Setup Tool Minus V/L From Test) ⁶	Pass/ Fail ⁷	reading lowest (Exh	onal V/L gs for the grade per ibit 5 quired) ⁸ #3	Average of 3 V/L readings (per Exhibit 5) ⁹	Pass/ Fail ¹⁰
		-	9						
				E					
TES								5	

Site Shutdown Test			
Is the power to submersible pumps off after removing power from TLS Console?	✓Yes	□No	
There shall be no dispensing when the TLS power is off			
Must be performed by a certified Veeder Root contractor.			
Must be performed by a certified veeder Root contractor.			

Appendix F

NBVC Port Hueneme Annual Throughput/Consumption Report

#i

e

3

ted

10

Title V Description	Annual Throughput Limit	Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24	Jul-24	Aug-24	Sep-24	Oct-24	Nov-24	Dec-24
Boilers													
8.4 MMBTU Boiler (Wharf 3) - Out of Service	2 MMCF	0.000	0.000	0.000	0.000	0:000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8.4 MMBTU Bciler (Wharf 4) - Out of Service	2 MMCF	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1.6 MMBTU "NCEL" Burner (Building 1100)	2.7 MMCF Nat Gas	0.016	0.016	0.016	0.016	0.016	0.016	0.016	0.016	0.016	0.016	0.009	0.007
2 - 4.8 MMBTU Portable Boilers	200 Hours Combined	3.000	4.000	5.000	4.500	4.900	4.900	5.300	5.500	3.500	3.500	3.500	3.800
2.1 MMBTU (Building 1419) Fuel Oil	1,000 Gal	19.000	15.000	8.000	8.000	8.000	15.000	15.000	15.000	7.000	15.000	15.000	15.000
2.1 MMBTU (Building 1419) Natural Gas	0.1 MMCF	0.004	0.004	0.004	0.004	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.001
2 - 1.44 MMBTU Boilers (Building 1479)	10 MMCF Combined	1.582	1.597	1.587	1.735	1.968	2.362	2.913	4.347	5.795	6.641	7.217	7.773
Portable Internal Combustion Engines	n Engines												
Crane Diesel Engines	218,180 BHP-Hrs	54,775	54,333	53,300	54,833	56,563	52,930	46,529	41,324	41,252	48,288	52,551	55,997
Sweeper Veh cle Diesel Engines	75,000 BHP-Hrs	13,661	13,870	15,195	15,613	15,822	16,101	14,358	14,219	15,683	16,867	16,310	17,634
Five Diesel Generator Engines	95,750 BHP-Hrs	973	973	973	973	16	16	16	16	0	0	0	0
MWR Wood Chipper	300 Hours	0.0	0:0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Surface Coating Operations													
Marine Coatings at 2.8 lb/gal ROC	943 Gallons	169.88	145.02	155.48	161.60	152.84	153.75	154.13	156.21	153.36	132.41	126.63	135.28
Coatings at 3.5 lb/gal ROC	5,661 Gallons	232.37	227.57	224.59	190.42	170.66	167.52	173.18	173.99	173.99	161.29	155.08	157.97
Pretreatment wash primers at 6.5 lb/gal ROC	20 Gallons	0.00	0.00	00:00	0.00	0.00	00.00	0.00	0.00	00:00	00.00	00:00	0.00
Coatings at 7.0 lb/gal ROC	250 gallons	0.87	0.77	0.85	0.91	0.95	1.09	1.25	1.27	1.32	1.22	1.19	1.20
Solvents at 6.6 lb/gal ROC	50 Gallons	00.00	0.00	0.00	00:00	00:00	0.00	00.00	0.00	0.00	0.00	0.00	0.00

Title V Description	Annual Throughput Limit	Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24	Jul-24	Aug-24	Sep-24	Oct-24	Nov-24	Dec-24
Boilers													
8.4 MMBTU Boiler (Wharf 3) - Out of Service	2 MMCF	0.000	0.000	0000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8.4 MMBTU Boiler (Wharf 4) - Out of Service	2 MMCF	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
1.6 MMBTU "NCEL" Burner (Building 1100)	2.7 MMCF Nat Gas	0.016	0.016	0.016	0.016	0.016	0.016	0.016	0.016	0.016	0.016	0.009	0.007
2 - 4.8 MMBTU Portable Boilers	200 Hours Combined	3.000	4.000	5.000	4.500	4.900	4.900	5.300	5.500	3.500	3.500	3.500	3.800
2.1 MMBTU (Building 1419) Fuel Oil	1,000 Gal	19.000	15.000	8.000	8.000	8.000	15.000	15.000	15.000	7.000	15.000	15.000	15.000
2.1 MMBTU (Building 1419) Natural Gas	0.1 MMCF	0.004	0.004	0.004	0.004	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.001
2 - 1.44 MMBTU Boilers (Building 1479)	10 MMCF Combined	1.582	1.597	1.587	1.735	1.968	2.362	2.913	4.347	5.795	6.641	7.217	7.773
Portable Internal Combustion Engines	n Engines	= =											
Crane Diesel Engines	218,180 BHP-Hrs	54,775	54,333	53;300	54,833	56,563	52,930	46,529	41,324	41,252	48,288	52,551	55,997
Sweeper Vehicle Diesel Engines	75,000 BHP-Hrs	13,661	13,870	15,195	15,613	15,822	16,101	14,358	14,219	15,683	16,867	16,310	17,634
Five Diesel Generator Engines	95,750 BHP-Hrs	973	973	973	973	16	16	16	16	0	0	0	0
MWR Wood Chipper	300 Hours	0.0	0.0	0.0	0:0	0.0	0.0	0.0	0.0	0.0	0:0	0.0	0.0
Surface Coating Operations				B			T DESCRIPTION OF	3	100		1000		ò
Marine Ccatings at 2.8 lb/gal ROC	943 Gallons	169.88	145.02	155.48	161.60	152.84	153.75	154.13	156.21	153.36	132.41	126.63	135.28
Coatings at 3.5 lb/gal ROC	5,661 Gallons	232.37	227.57	224.59	190.42	170.66	167.52	173.18	173.99	173.99	161.29	155.08	157.97
Pretreatrient wash primers at 6.5 lb/gal ROC	20 Gallons	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Coatings at 7.0 lb/gal ROC	250 gailons	0.87	0.77	0.85	0.91	0.95	1.09	1.25	1.27	1.32	1.22	1.19	1.20
Solvents at 6.6 lb/gal ROC	50 Gallons	0.00	0.00	0.00	0.00	0.00	00:00	0.00	0.00	00:0	0.00	0.00	0.00

Title V Description	Annual Throughput Limit	Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24	Jul-24	Aug-24	Sep-24	Oct-24	Nov-24	Dec-24
Solvents at 6.8 lb/gal ROC	20 Gallons	0.00	0.00	0.00	0.00	0.00	0.00	0.00	00:00	00:0	0.00	00:0	00.00
Solvents at 6.9 lb/gal ROC	30 Gallons	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	00:00	00:00	0.00
Solvents at 7.1 lb/gal ROC	1,060 Gallons	2.63	2.63	2.63	2.25	0.84	0.33	0.38	0.38	0.45	0.17	0.17	0.22
Coatings and Solvents at 2.8 lb/gal ROC/Auto Hobby Shop (Removed from Permit)	75 Gallons	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Abrasive Blasting Operations	8							10.7				TC	
Basewide Unconfined Blasting Operations; Abrasives Used	1 Ton/yr Abrasives	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Three Clemco Industries Abrasive Blast Cabinets, Buildings 1497 and 813; Abrasive Used	7 Tons/yr Abrasives	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.1	0.1
Gasoline Fuelling Operations	S				THE PERSON NAMED IN	THE STATE OF	J. Malifut	mnfel	URIL	Ammi	- mul	THE REAL PROPERTY.	TIEST.
Motor Vehicle Fueling Facility; Building 5307	350,000 Gallons	7,171.0	7,171.0	7,171.0	7,171.0	7,171.0	7,171.0	7,171.0	7,171.0	0	0	0	0
Motor Vehicle Fueling Operation, Building 5307	250,000 Gallons	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Gasoline Loading Rack, Building 5307	100,000 Gallons	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
E-85 Motor Vehicle Fueling Operation, Building 5307	100,000 Gallons	13,923	13,940	13,996	14,005	13,796	13,379	12,919	12,169	11,720	11,201	10,907	10,460
Navy Exchange Gas Station, Building 797	4,250,000 Gallons	3,474,026	3,613,234	3,616,478	3,611,102	3,616,455	3,624,957	3,663,651	3,650,413	3,626,318	3,589,371	3,558,878	3,545,359
Solvent Cleaning Operations										11			
Vapor Degreaser Solvent at 7.4 Ib/gal ROC	20 Gallons	0.0	0.0	0.0	0.0	0.0	0:0	0.0	0.0	0.0	0.0	0.0	0.0
Solvents at 7.5 lb/gal ROC	95 Gallons	35.2	35.9	27.0	23.1	40.2	40.0	39.6	40.3	32.8	26.4	25.1	25.0
Solvents at 12.5 lb/gal ROC	10 Gallons	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Title V Description	Annual Throughput Limit	Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24	Jul-24	Aug-24	Sep-24	Oct-24	Nov-24	Dec-24
Standby Engines		W 1 1 1											
Operated for Maintenance Purposes				o.		٠			5.5%				
Building Number:													
2	50 Hours	2.2	1.2	1.2	1.2	1.2	2.2	1.2	1.2	1.2	1.0	2.0	2.0
22	50 Hours	1.8	1.6	1.6	2.2	2.2	2.2	1.8	2.0	2.2	2.0	2.0	1.8
225	50 Hours	2.1	2.2	2.2	2.2	2.1	1.9	1.5	1.5	1.8	1.6	1.6	1.6
372	20 Hours	1.0	8.0	9.0	8.0	0.8	9.0	9.0	0.8	1.0	1.0	1.0	1.7
382	20 Hours	2.4	2.4	2.3	2.5	2.3	2.0	1.7	1.7	1.7	1.6	1.4	1.6
437	20 Hours	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
527	20 Hours	14.6	1.9	1.9	1.7	1.7	1.5	1.5	9.0	9.5	9.0	8.8	9.0
810	20 Hours	11.0	9.1	10.2	10.2	10.3	8.4	9.7	6.6	11.5	10.5	12.2	13.0
1000	50 Hours	1.0	0.8	6.0	1.3	1.5	1.5	1.7	1.7	1.7	1.7	1.7	1.7
1300	50 Hours	2.4	2.4	2.4	2.9	2.9	2.7	2.1	1.9	2.1	1.9	2.0	2.0
1387	50 Hours	23.3	23.1	23.1	23.1	14.0	13.8	13.6	9.5	4.6	1.2	1.4	1.4
1388	50 Hours	3.8	3.9	3.7	3.5	3.5	3.3	3.1	3.0	3.0	3.3	3.6	3.6
1388	20 Hours	2.7	2.9	3.7	3.9	4.7	4.9	5.2	5.2	5.2	5.4	5.9	6.1
1402	50 Hours	4.7	4.1	4.1	4.9	4.5	4.7	4.1	4.3	4.7	4.4	6.1	5.9
1412	50 Hours	10.7	11.2	11.2	12.5	13.2	12.0	10.7	12.2	12.7	14.1	14.5	14.3
1440	20 Hours	5.8	5.6	5.6	5.4	5.1	4.9	5.1	5.4	5.2	1.3	1.3	1.6
1443	50 Hours	3.5	2.8	2.8	1.9	1.9	1.7	1.4	1.4	2.0	1.8	2.0	1.7
1445 - New	50 Hours	0.0	0.0	0.0	0.0	0.0	0.0	3.6	3.6	4.6	4.6	4.6	5.8
1512B	20 Hours	4.3	3.6	3.3	3.7	2.5	2.0	2.4	2.3	2.8	2.6	2.9	2.6
1524	50 Hours	16.9	16.7	16.8	17.1	7.8	7.6	7.4	7.4	6.0	2.1	2.4	2.2
1526	20 Hours	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5035	50 Hours	1.4	1.2	1.0	6.0	2.0	0.3	0.2	0.4	0.4	2.0	6.0	6.0

× ×