



Ventura County  
Air Pollution  
Control District

669 County Square Drive  
Ventura, California 93003

tel 805/645-1400  
fax 805/645-1444  
www.vcapcd.org

Michael Villegas  
Air Pollution Control Officer

February 28, 2012

Mr. Hadi Takeuchi  
Paloma Industries, Inc.  
2151 Eastman Ave.  
Oxnard, CA 93030

RE: Ventura County APCD Rule 74.11.1 – Certification of Units

Dear Mr. Takeuchi:

Per your letter dated February 17, 2012, the units listed on the attached table have been certified for sale and installation in Ventura County.

This certification is pursuant to Ventura County Air Pollution Control District Rule 74.11.1, Large Water Heaters and Small Boilers, and is valid for a period of three (3) years from the date of this letter. Rule 74.11.1 applies to units with a rated heat input capacity greater than 75,000 BTU/hour and less than or equal to 2,000,000 BTU/hour.

You should be aware that units with a rated heat input capacity of 1,000,000 BTU/hour, or more, require an APCD Authority to Construct prior to installation and must meet the District's definition of Best Available Control Technology (BACT) at the time the Authority to Construct is issued.

The Ventura County APCD does not endorse or warranty any specific product or manufacturer. Modification of the products listed above will void this certification.

If you have any questions on this matter, please contact me at 805/645-1403.

Sincerely,

A handwritten signature in black ink, appearing to read "Ken Hall".

Ken Hall  
Air Quality Specialist  
Ventura County APCD

Enclosure

**Ventura County APCD  
Large Water Heaters and Small Boilers**

**Paloma Industries, Inc.**

Certified Units  
February 28, 2012  
(Certified @ 14 ng/J NOx)

<b>Paloma (Base Model)</b>	<b>WaiWela</b>	<b>EcoSense</b>	<b>Rheem</b>	<b>Ruud</b>	<b>Max. Heat Input (Btu/Hr)</b>
PHH-32RDVLN	PHH-32RDVLN	ECO200DVLN	RTGH-95DVLN	RUTGH-95DVLN	199,900
PHH-32ROFLN	PHH-32ROFLN	ECO200XLN	RTGH-95XLN	RUTGH-95XLN	199,900
PHH-25RDVLN	PHH-25RDVLN	ECO160DVLN	RTGH-84DVLN	RUTGH-84DVLN	157,000
PHH-25ROFLN	PHH-25ROFLN	ECO160XLN	RTGH-84XLN	RUTGH-84XLN	157,000

<b>Paloma (Base Model)</b>	<b>Richmond</b>	<b>Raypak</b>	<b>Sure Comfort</b>	<b>Max. Heat Input (Btu/Hr)</b>
PHH-32RDVLN	RMTGH95DVLN	NH-209DVLN	SCTH200DVLN	199,900
PHH-32ROFLN	RMTGH95XLN	NH-209XLN	SCTH200XLN	199,900
PHH-25RDVLN	RMTGH84DVLN	NH-159DVLN	SCTH160DVLN	157,000
PHH-25ROFLN	RMTGH84XLN	NH-159XLN	SCTH160XLN	157,000