



**Ventura County  
Air Pollution  
Control District**

669 County Square Drive  
Ventura, California 93003

tel 805/645-1400  
fax 805/645-1444  
www.vcapcd.org

**Michael Villegas  
Air Pollution Control Officer**

May 10, 2011

Mr. Hadi Takeuchi  
Paloma Industries, Inc.  
2151 Eastman Ave.  
Oxnard, CA 93030

RE: Ventura County APCD Rule 74.11.1 – Certification of Units

Dear Mr. Takeuchi:

Per your letter dated May 5, 2011, the units listed on the attached table have been certified for sale and installation in Ventura County.

This certification is pursuant to Ventura County Air Pollution Control District Rule 74.11.1, Large Water Heaters and Small Boilers, and is valid for a period of three (3) years from the date of this letter. Rule 74.11.1 applies to units with a rated heat input capacity greater than 75,000 BTU/hour and less than or equal to 2,000,000 BTU/hour.

You should be aware that units with a rated heat input capacity of 1,000,000 BTU/hour, or more, require an APCD Authority to Construct prior to installation and must meet the District's definition of Best Available Control Technology (BACT) at the time the Authority to Construct is issued.

The Ventura County APCD does not endorse or warranty any specific product or manufacturer. Modification of the products listed above will void this certification.

If you have any questions on this matter, please contact me at 805/645-1403.

Sincerely,

Ken Hall  
Air Quality Specialist  
Ventura County APCD

Enclosure

Paloma 051011 74.11.1.doc

**Ventura County APCD  
Large Water Heaters and Small Boilers**

**Paloma Industries, Inc.**

**Certified Units  
May 10, 2011  
(Certified @ 40 ng/J NOx)**

<b>Raypak</b>	<b>Max. Heat Input (Btu/Hr)</b>
NH-208DVN	199,900
NH-208XN	199,900
NH-188DVN	180,000
NH-188XN	180,000
NH-209DVN	199,900
NH-209XN	199,900
NH-159DVN	157,000
NH-159XN	157,000