tel 805/645-1400

fax 805/645-1444

www.vcapcd.org



September 8, 2011

Mr. Hadi Takeuchi Paloma Industries, Inc. 2151 Eastman Ave. Oxnard, CA 93030

RE: Ventura County APCD Rule 74.11.1 – Certification of Units

Dear Mr. Takeuchi:

Per your letter dated August 29, 2011, the units listed on the attached table have been certified for sale and installation in Ventura County.

This certification is pursuant to Ventura County Air Pollution Control District Rule 74.11.1, Large Water Heaters and Small Boilers, and is valid for a period of three (3) years from the date of this letter. Rule 74.11.1 applies to units with a rated heat input capacity greater than 75,000 BTU/hour and less than or equal to 2,000,000 BTU/hour.

You should be aware that units with a rated heat input capacity of 1,000,000 BTU/hour, or more, require an APCD Authority to Construct prior to installation and must meet the District's definition of Best Available Control Technology (BACT) at the time the Authority to Construct is issued.

The Ventura County APCD does not endorse or warranty any specific product or manufacturer. Modification of the products listed above will void this certification.

If you have any questions on this matter, please contact me at 805/645-1403.

Sincerely,

Ken Hall Air Quality Specialist Ventura County APCD

Enclosure

Ventura County APCD Large Water Heaters and Small Boilers

Paloma Industries, Inc. Certified Units September 8, 2011 (Certified @ 14 ng/J NOx)

Paloma (Base Model)	WaiWela	EcoSense	Rheem	Ruud	Max. Heat Input (Btu/Hr)
PH2-28RDVSLN	PH2-28RDVSLN	ECO200DVLN3	RTG-95DVLN	RUTG-95DVLN	199,900
PH2-28ROFLN	PH2-28ROFLN	ECO200XLN3	RTG-95XLN	RUTG-95XLN	199,900

Paloma (Base Model)	Richmond	Raypak	Sure Comfort	Max. Heat Input (Btu/Hr)
PH2-28RDVSLN	RMTG95DVLN	NH-208DVLN	SCT200DVLN	199,900
PH2-28ROFLN	RMTG95XLN	NH-208XLN	SCT200XLN	199,900