



GASOLINE DISPENSING FACILITY

Please review APCD Rule 70, "Storage and Transfer of Gasoline". Compliance with Rule 70 must be demonstrated for the gasoline dispensing facility. Contact the District if you have any questions on APCD Rule 70 or the California Air Resources board (CARB) Executive Orders for certified gasoline vapor recovery systems. CARB Executive Orders are available at <https://ww2.arb.ca.gov/our-work/programs/vapor-recovery/vapor-recovery-executive-orders>
The application must also include a diagram of the vapor recovery piping from the dispensers to the tanks and vents (not required for dispenser replacement projects where the underground vapor piping is not being modified).

Facility Information

Facility Type	<input type="checkbox"/> Retail <input type="checkbox"/> Non-Retail
Number of Dispensers and Nozzles (Gasoline Only / Not Diesel)	_____ Dispensers _____ Nozzles
Will Existing Dispensers be Replaced? (If applicable)	<input type="checkbox"/> Yes <input type="checkbox"/> No
Actual Gasoline Throughput Last Year (If applicable)	_____ Gallons Per Year
Expected Throughput Next Year	_____ Gallons Per Year
Will 50% or more of the underground vapor piping be replaced or removed?	<input type="checkbox"/> Yes <input type="checkbox"/> No

Information on Tanks – Information is required only for gasoline or methanol/gasoline tanks. Permits and the information below are not required for diesel fuel or waste oil tanks. If existing tanks are not changing, state "no change" below.

Information on First Tank

Capacity of Tank	_____ Gallons
Fill Pipe Distance Must be less than 6 inches	_____ Inches
Type of Tank	<input type="checkbox"/> Aboveground <input type="checkbox"/> Underground
Status of Tank	<input type="checkbox"/> New <input type="checkbox"/> Existing
Does this application involve unburying the top of the tank? (If applicable)	<input type="checkbox"/> Yes <input type="checkbox"/> No

Information on Second Tank

Capacity of Tank	_____ Gallons
Fill Pipe Distance Must be less than 6 inches	_____ Inches
Type of Tank	<input type="checkbox"/> Aboveground <input type="checkbox"/> Underground
Status of Tank	<input type="checkbox"/> New <input type="checkbox"/> Existing
Does this application involve unburying the top of the tank? (If applicable)	<input type="checkbox"/> Yes <input type="checkbox"/> No

For more than 2 tanks, use additional form

GASOLINE DISPENSING FACILITY

Information on Phase I Control System (only required for new Phase I Systems or replacement of existing Phase I Systems)

Piping Design (check one)	<input type="checkbox"/> Phil-Tite (VR-101) <input type="checkbox"/> OPW (VR-102) <input type="checkbox"/> EBW (VR-103) <input type="checkbox"/> CNI Manufacturing (VR-104) <input type="checkbox"/> EMCO Wheaton Retail (VR-105) <input type="checkbox"/> Submerged Fill Pipe Only <input type="checkbox"/> Other (Specify Name and Executive Order)
------------------------------	---

Information on Phase II Control System (please clarify for ALL permit applications)

Underground Tanks (check one)	<input type="checkbox"/> No Phase II System <input type="checkbox"/> Assist (formerly Healy) Phase II EVR <u>without</u> ISD (VR-201) <input type="checkbox"/> Assist (formerly Healy) Phase II EVR with ISD (VR-202) <input type="checkbox"/> Balance (formerly VST) Phase II EVR <u>without</u> ISD (VR-203) <input type="checkbox"/> Balance (formerly VST) Phase II EVR with ISD (VR-204) <input type="checkbox"/> VST Phase II EVR with Hirt VCS 100 T-OX <u>without</u> ISD (VR-205) <input type="checkbox"/> EMCO Wheaton Phase II EVR with Hirt VCS 100 T-OX <u>without</u> ISD (VR-207) <input type="checkbox"/> EMCO Wheaton Phase II EVR with Hirt VCS 100 T-OX with ISD (VR-208) <input type="checkbox"/> VST Phase II EVR with FFS Clean Air Separator <u>without</u> ISD (VR-209) <input type="checkbox"/> Other (Specify Name and Executive Order)
Aboveground Tanks (check one)	<input type="checkbox"/> No Phase II System <input type="checkbox"/> AGT Vault (G-70-160) <input type="checkbox"/> Hirt Model VCS-200 (G-70-139) <input type="checkbox"/> BTC Envirovault (G-70-167) <input type="checkbox"/> Hoover/LubeCube (G-70-148) <input type="checkbox"/> ConVault (G-70-116) <input type="checkbox"/> Steel Tank Institute Fireguard (G-70-162) <input type="checkbox"/> Hallmark Tank Vault (G-70-131) <input type="checkbox"/> Trusco/Supervault (G-70-132) <input type="checkbox"/> Other (Specify Name and Executive Order)
Low throughput	Is the facility equipped with a Phase II System that is not required by Rule 70 due to low throughput (<24,000 gal/year)? <input type="checkbox"/> Yes <input type="checkbox"/> No If yes, do you want the Phase II System to be listed on the permit? <input type="checkbox"/> Yes <input type="checkbox"/> No

Information on Underground Vapor Piping System (only required for new or replacement vapor piping systems)

Piping Configuration (check one)	<input type="checkbox"/> Multiple Product/Manifolded Vapor Return <input type="checkbox"/> Single Product/Single Vapor Return Note: If the vapor recovery lines from the dispensers are manifolded into a single line, this line must also be manifolded to the all of the storage tanks to allow vapors to return to the proper tank. When identifying the Phase I and Phase II Control Systems, also note the ARB Executive Orders (i.e. VR-204) are also included for your use.
Condensate Tanks	<input type="checkbox"/> The Phase II vapor recovery system includes a condensate tank. <input type="checkbox"/> Yes <input type="checkbox"/> No