

**Notice of Decision to Certify Emission Reduction Credits
November 7, 2018**

Pursuant to the requirements of California Health and Safety Code Section 40713 and District Rule 26.7.B.4, all interested persons are notified of the Air Pollution Control Officer's (APCO) decision to certify an Emission Reduction Credit (ERC) for the following applicant(s). The proposed ERC is in units of tons per year.

The public may submit written comments on the preliminary decisions during the 30-day period following the date of publication of this notice. The public is welcome to inspect, at the District office, the information submitted by the applicants and the supporting analyses for the preliminary decisions. After reviewing all comments received, the APCO shall provide written notification of the final decision to grant or deny any ERC to any person or agency submitting comments on the proposed ERC during the comment period.

If you have any questions regarding this notice, please contact Kerby E. Zozula at 805/645-1421 or by email at kerby@vcapcd.org.

Company	ROC	NOx	PM₁₀	SOx
NRG California South LP Mandalay Generating Station 393 North Harbor Blvd., Oxnard, CA Application No. 00013-401 ERC Certificate No. 1243	1.44	5.52	2.68	0.59

The emission reduction will result from the shutdown of the Unit Nos. 1, 2, and 3 at the Mandalay Generating Station in Oxnard. The facility ceased operation in February 2018. Unit Nos. 1 and 2 each consisted of 215 MW electrical generators powered by natural gas-fired 1990 MMBTU/Hr Babcock and Wilcox Steam Generators that operated in compliance with VCAPCD Rule 59, "Electrical Power Generating Equipment – Oxide of Nitrogen Emissions". Unit No. 3 consisted of a 2510 MMBTU/Hr natural gas fired turbine peaking unit that operated in compliance with VCAPCD Rule 74.23, "Stationary Gas Turbines".