

**Pacific Custom Materials
Kiln 3 - Report for Month of November 2010
SOx Emissions**

Title V Permit Limit = 300 Parts per Million by Volume

Units: Parts per Million by Volume

	00:00	01:00	02:00	03:00	04:00	05:00	06:00	07:00	08:00	09:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	Max	Avg	
1	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
2	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
3	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
4	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
5	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
6	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
7	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
8	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
9	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
11	23.81	18.58	22.13	21.39	22.24	25.34	22.30	19.70	21.51	20.79	22.35	24.29	22.26	21.97	20.48	16.92	22.63	25.81	21.53	25.82	26.40	24.18	25.34	27.22	27.22	22.71	22.71
12	19.86	22.33	19.10	17.89	21.12	20.51	22.04	18.18	18.89	23.17	22.74	20.35	19.43	14.80	20.15	10.39	27.73	22.16	22.75	29.22	31.65	20.95	15.66	15.27	31.65	20.68	20.68
13	21.49	25.22	20.42	21.34	21.98	29.04	20.68	19.64	26.39	30.52	29.71	29.35	29.12	29.08	28.60	29.28	25.76	27.25	19.69	12.95	13.93	20.46	22.92	21.17	30.52	24.00	24.00
14	19.22	21.73	26.04	21.09	18.56	17.68	15.48	14.09	18.14	21.24	18.71	18.90	20.10	20.40	18.09	11.56	12.22	22.94	26.16	27.86	22.19	17.03	18.41	25.21	27.86	19.71	19.71
15	25.44	23.13	22.21	19.69	18.13	17.05	21.98	18.83	17.93	20.47	24.80	26.54	24.97	20.99	20.18	21.21	23.55	18.52	24.82	15.71	18.66	19.80	24.16	14.85	26.54	20.98	20.98
16	14.30	12.64	12.36	14.89	18.22	18.26	16.68	16.71	21.28	24.78	25.64	23.33	20.32	21.73	23.97	21.27	21.89	20.86	19.99	21.41	28.52	17.67	19.72	13.64	28.52	19.59	19.59
17	15.06	14.13	11.56	11.25	10.93	12.60	14.01	12.23	17.41	20.61	15.11	18.13	17.12	20.13	21.34	18.50	21.05	19.72	10.46	18.21	23.80	19.10	23.12	18.43	23.80	16.83	16.83
18	18.33	19.01	17.72	19.84	24.35	25.47	23.31	22.76	22.20	23.87	28.86	29.84	25.38	29.28	25.97	28.34	26.96	21.26	21.47	19.05	17.31	17.70	18.70	20.38	29.84	22.81	22.81
19	19.34	17.76	13.09	13.78	15.54	18.69	18.81	22.23	21.73	23.42	21.57	21.82	15.52	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	23.42	10.14	10.14
20	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
21	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
22	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
23	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
24	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
26	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
27	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
28	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
29	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
30	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Max	25.44	25.22	26.04	21.39	24.35	29.04	23.31	22.76	26.39	30.52	29.71	29.84	29.12	29.28	28.60	29.28	27.73	27.25	28.02	29.22	31.65	24.18	27.04	27.22	31.65	6.25	6.25
Avg	5.90	5.82	5.49	5.37	5.70	6.15	5.84	5.48	6.18	6.96	6.98	7.08	6.47	6.06	6.63	6.14	6.90	6.41	6.50	6.57	6.85	5.96	6.50	6.10			

'I' - Invalid
'M' - Maintenance
'W' - Caution
'U' - User Data
'E' - Error
'F' - Frozen FIFO
'C' - Calibration
'O' - Out-of-Control
'D' - Process Down
'X' - Excess Emission

**Pacific Custom Materials
Kiln 4 - Report for Month of November 2010
SOx Emissions**

Title V Permit Limit = 8.28 Pounds per Hour

**Units: Pounds/Hour
Interval: 1-hour average**

	00:00	01:00	02:00	03:00	04:00	05:00	06:00	07:00	08:00	09:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	Max	Avg	
1	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
2	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
3	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
4	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
5	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
6	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
7	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
8	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
9	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	3.65	4.87	6.33	4.87	4.62	4.64	6.35	5.63	5.98	6.56	6.65	6.65	2.51
11	5.11	4.47	5.45	5.29	5.40	5.80	5.54	5.07	5.46	4.89	5.59	6.00	5.58	4.57	4.62	4.57	6.23	6.12	6.01	4.48	5.20	5.78	5.25	5.68	6.23	5.34	
12	5.59	5.36	5.97	5.16	5.38	5.17	5.15	4.88	5.34	5.01	5.29	5.68	3.36	4.93	4.13	3.46	3.86	6.17	6.08	5.90	4.88	6.18	5.24	6.62	6.62	5.20	
13	4.47	4.10	4.50	4.01	5.15	3.88	4.98	4.81	4.34	4.84	4.72	4.37	4.40	4.90	5.77	4.23	3.79	5.27	4.75	5.66	3.06	4.02	4.05	4.43	5.77	4.52	
14	4.30	5.36	4.40	4.42	5.20	4.00	4.76	5.01	4.23	4.74	5.46	4.05	3.24	4.36	3.78	3.13	3.03	4.53	4.11	4.47	4.81	4.67	5.70	4.06	5.70	4.41	
15	4.74	4.41	4.91	4.60	5.82	4.50	5.53	4.70	4.51	4.06	4.01	4.07	3.51	3.62	3.90	3.63	5.26	3.86	2.82	5.00	6.43	5.44	5.09	5.26	6.43	4.57	
16	4.29	4.61	3.40	3.51	3.92	4.55	4.82	3.81	5.08	4.52	4.98	4.15	6.57	4.43	4.07	5.06	5.42	4.74	4.00	4.56	5.36	5.35	4.43	4.87	6.57	4.60	
17	4.49	3.73	5.27	4.86	4.24	4.37	6.07	4.20	4.87	3.38	3.64	5.30	4.08	4.12	4.00	4.08	4.94	4.09	2.51	2.87	2.89	2.85	3.18	3.13	6.07	4.05	
18	3.02	3.21	3.80	3.87	3.57	3.43	3.44	3.26	3.24	3.92	5.22	5.18	4.51	3.40	4.71	5.93	6.74	5.57	5.98	4.77	5.35	4.32	5.10	5.62	6.74	4.46	
19	4.65	3.71	3.75	2.87	2.86	3.30	6.09	3.65	5.01	5.65	3.62	3.86	2.67	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	6.09	2.15	
20	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
21	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
22	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
23	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
24	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
26	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
27	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
28	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
29	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
30	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Max	5.59	5.36	5.97	5.29	5.82	5.80	6.09	5.07	5.46	5.65	5.59	6.00	6.57	4.93	5.77	6.33	6.74	6.17	6.08	6.35	6.43	6.18	6.56	6.65	6.65	6.74	1.39
Avg	1.36	1.30	1.38	1.29	1.38	1.30	1.55	1.31	1.40	1.37	1.42	1.42	1.26	1.27	1.33	1.35	1.47	1.50	1.36	1.47	1.45	1.54	1.49	1.54			

'I' - Invalid
'M' - Maintenance
'W' - Caution

'U' - User Data
'E' - Error
'F' - Frozen FIFO

'C' - Calibration
'O' - Out-of-Control

'D' - Process Down
'X' - Excess Emission

**Pacific Custom Materials
Kiln 4 - Report for Month of November 2010
SOx Emissions**

Title V Permit Limit = 300 Parts per Million by Volume

Units: Parts per Million by Volume

	00:00	01:00	02:00	03:00	04:00	05:00	06:00	07:00	08:00	09:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	Max	Avg
1	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
2	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
3	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
4	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
5	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
6	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
7	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
8	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
9	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	15.44	20.58	26.68	21.27	20.01	20.14	27.53	24.42	25.89	27.30	27.80	27.80	10.71
11	21.47	18.95	23.38	22.46	22.87	24.70	23.50	21.65	23.58	20.89	23.86	25.68	24.00	19.64	19.84	19.72	26.86	26.32	25.78	19.19	22.13	24.50	22.31	24.10	26.86	22.81
12	23.27	22.51	24.96	21.57	22.37	21.35	21.16	20.22	22.12	20.90	22.42	24.41	14.46	21.46	17.92	14.99	16.77	26.55	25.92	25.09	20.70	26.12	22.13	27.98	27.98	21.97
13	18.84	17.23	18.60	16.42	21.11	16.05	20.54	19.90	18.06	20.30	19.92	18.51	18.57	20.93	24.51	17.94	16.04	22.13	19.81	23.65	12.91	16.83	16.90	18.36	24.51	18.92
14	17.95	22.44	18.42	18.53	21.70	16.71	19.84	20.95	17.59	19.94	23.23	17.26	13.83	18.61	16.29	13.53	13.06	19.41	17.46	18.91	20.18	19.50	23.84	16.99	23.84	18.59
15	19.81	18.49	20.53	19.42	24.26	19.05	23.07	19.69	18.87	17.05	16.98	17.23	15.03	15.50	16.97	15.79	23.07	16.71	12.06	21.12	26.98	22.82	21.41	22.00	26.98	19.33
16	17.91	19.23	14.23	14.69	16.38	18.78	20.21	15.84	21.34	19.14	21.28	17.81	28.44	19.40	17.87	22.21	23.45	20.55	17.41	19.57	22.89	22.81	18.70	20.48	28.44	19.61
17	18.93	15.63	22.09	20.20	18.42	19.04	26.37	18.40	21.39	14.98	16.22	23.52	18.04	18.35	17.85	18.19	22.27	18.03	10.95	12.39	12.38	12.24	13.52	13.39	26.37	17.62
18	12.84	13.67	16.17	16.53	15.27	14.64	14.53	13.87	13.86	16.83	22.51	22.38	19.52	14.74	20.48	25.67	28.91	23.90	25.61	20.40	22.72	18.23	21.53	23.59	28.91	19.10
19	19.45	15.56	15.73	12.08	12.09	13.80	25.62	15.48	21.29	23.92	15.31	16.14	10.77	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	25.62	9.05
20	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
21	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
22	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
23	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
24	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
26	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
27	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
28	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
29	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
30	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Max	23.27	22.51	24.96	22.46	24.26	24.70	26.37	21.65	23.58	23.92	23.86	25.68	28.44	21.46	24.51	26.68	28.91	26.55	25.92	27.53	26.98	26.12	27.30	27.98	28.91	5.92
Avg	5.68	5.46	5.80	5.40	5.82	5.47	6.49	5.53	5.94	5.80	6.06	6.10	5.42	5.47	5.74	5.82	6.39	6.45	5.84	6.26	6.18	6.52	6.25	6.49		

'I' - Invalid 'U' - User Data 'C' - Calibration 'D' - Process Down
'M' - Maintenance 'E' - Error 'O' - Out-of-Control 'X' - Excess Emission
'W' - Caution 'F' - Frozen FIFO